MAY 26 1992

Emergency Response Monitoring Activities and Environmental Impact of the K-Reactor Aqueous Tritium Release of December 1991^(U)

D. M. Hamby, R. P. Addis, D. M. Beals, J. R. Cadieux, W. H. Carlton, D. L. Dunn, G. Hall, D. W. Hayes, R. Lorenzo
M. V. Kantelo and R. W. Taylor

Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

Prepared for the U. S. Department of Energy under contract no. DE-AC09-89SR18035

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

**EMERGENCY RESPONSE MONITORING ACTIVITIES AND
ENVIRONMENTAL IMPACT OF THE K-REACTOR AQUEOUS
TRITIUM RELEASE OF DECEMBER 1991 (U)**

D.M. Hamby
R.P. Addis
D.M. Beals
J.R. Cadieux
W.H. Carlton
D.L. Dunn
G. Hall
D.W. Hayes
R. Lorenz
M.V. Kantelo
R.W. Taylor

Publication Date: February 7, 1992

Approved By:

A.L. Boni, Manager ETS

J.D. Heffner, Manager EMS

Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Contents

Summary	1
Introduction	1
Emergency Response	2
Source Term	
Transport Time	
Maximum Concentrations in the Savannah River	
Dose Estimation	
Sample Collection	3
Analytical Results and Discussion	4
Observed Transport Time	
Estimation of Source Term	
Health Impacts	6
Maximum Drinking-Water Dose	
Maximum Dose from the Consumption of Aquatic Species	
Average Individual and Population Dose	
EPA Drinking Water Standard	
Dose to Aquatic Biota	
Special Topics	7
Abercorn Creek/Port Wentworth Intake	
The Savannah River Estuary	
Acknowledgements	8
References	9
Appendix A – Sampling Locations and Maps	
Table A1. Sampling locations on the Savannah River	
Figure A1. Map of SRS to Atlantic Ocean	
Figure A2. Map of area near Beaufort–Jasper and Port Wentworth	
Figure A3. Map of the Savannah River estuary	
Appendix B – Analytical Methods and Data Summary	
Figure B1. Comparison of EMS & ETS monitoring data	
Figure B2. Comparison of GDNr & ETS monitoring data	
Figure B3. Concentrations in Steel Creek	
Figure B4. Concentrations at Highway 301	
Figure B5. Concentrations at Becks Ferry	
Figure B6. Concentrations at Abercorn Creek	

Contents

- Figure B7. Concentrations at Beaufort-Jasper lift station
- Figure B8. Concentrations at Beaufort-Jasper intake
- Figure B9. Concentrations near Fort Pulaski
- Figure B10. Concentrations at Priest Landing
- Figure B11. Concentrations in Savannah River with WINDS arrival predictions
- Figure B12. Historical weekly average of tritium concentrations in the Savannah River
- Figure B13. Estimated monthly maximum tritium dose via drinking water for 1991
- Table B1. Steel Creek survey
- Table B2. Highway 301 survey
- Table B3. Becks Ferry survey
- Table B4. Beaufort-Jasper canal survey before lift station
- Table B5. Beaufort-Jasper lift station survey
- Table B6. Beaufort-Jasper canal survey after lift station
- Table B7. Beaufort-Jasper plant intake survey
- Table B8. Beaufort-Jasper water treatment plant survey
- Table B9. Abercorn Creek survey
- Table B10. Port Wentworth water treatment plant survey
- Table B11. Estuarine study
- Table B12. Estuarine survey
- Table B13. Daily average tritium concentrations in Savannah River
- Table B14. Tritium transported in the Savannah River past Highway 301

Appendix C – Quality Assurance

- Figure C1. Typical uncertainties in the LSC
- Figure C2. Spike results
- Figure C3. Blank results

Appendix D – Tritium Transport in the Savannah River

- Figure D1. December 25, 1991
- Figure D2. December 26 – 27, 1991
- Figure D3. December 31, 1991 – January 1, 1992
- Figure D4. January 2 – 3, 1992
- Figure D5. January 9 – 10, 1992

Emergency Response Monitoring Activities and Environmental Impact of the K-Reactor Aqueous Tritium Release of December 1991^(U)

D. M. Hamby, R.P. Addis, D. M. Beals, J. R. Cadieux, W. H. Carlton, D. L. Dunn, G. Hall, D.W. Hayes, R. Lorenz, M. V. Kantelo and R.W. Taylor

Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

Summary

Approximately 150 gallons of tritiated water leaked from one of the K-Reactor heat exchangers between December 22 and December 25, 1991. Upon notification, the Environmental Technology Section (ETS) activated its emergency response team to provide predictions of river concentrations, transport times, and radiological effects to downstream water users. Additionally, within a few days of the release, ETS and the Environmental Monitoring Section (EMS) began a comprehensive program to collect and analyze surface water samples from SRS down to the Savannah River estuary. The TRAC mobile laboratory was deployed to the Beaufort-Jasper water treatment plant to provide initial analyses for downriver water samples.

Elevated tritium concentrations in the Savannah River at Highway 301 were first detected on December 26, 1991. Further downstream at Becks Ferry, adjacent to the intake canal for the Beaufort-Jasper water treatment plant, elevated tritium concentrations were first detected during the morning of December 28, 1991. Later that afternoon tritium concentrations began to rise at Abercorn Creek, where the lift station for the Port Wentworth water treatment plant is located.

Concentrations at each location reached their peak about 30 hours after arrival of the leading edge. The maximum measured concentration at Highway 301 was 66.9 pCi/mL. Daily average river flow rates and measured tritium concentrations were utilized to determine the daily amounts of tritium transported past the Highway 301 bridge and the Beaufort-Jasper intake canal. From these data, it was estimated that approximately 5700 curies of tritium were released from the leaking heat exchanger to the Savannah River.

The maximum dose to a hypothetical individual, one who consumed 2 liters of water per day at Highway 301 for the duration of plume passage, would have received a dose from drinking water of approximately 0.035 mrem. This dose is more than 100 times smaller than the EPA drinking water standard of 4 mrem/yr. Average individual doses to users of the Beaufort-Jasper and Port Wentworth domestic water supplies are 0.0048 and 0.015 mrem, respectively.

Introduction

At the end of 1991, an unplanned release of tritium occurred at K Reactor. The tritium was released between December 22 and December 25, 1991 through the K-Area secondary cooling water discharge in the form of tritiated heavy water (primary cooling water). Samples of reactor discharge

water taken twice per day showed no evidence of leakage up to the morning of December 22. A sample of discharge water collected on the evening of December 22, however, indicated elevated concentrations of tritium upon later analysis. Analysis of samples collected the following day were inconsistent and the elevated concentrations were not

confirmed until December 24. The leak was positively identified and isolated on December 25.

Released tritium was tracked and measured as it traveled from the cooling canal into Pen Branch, through the Savannah River swamp, past the mouth of Steel Creek, and down the Savannah River, Figure A1. Two Savannah River Site environmental groups, SRL's Environmental Technology Section (ETS) and ESH&QA's Environmental Monitoring Section (EMS) jointly developed and executed sampling programs to monitor the movement of tritium from SRS to the Atlantic Ocean. ETS results were in good agreement with EMS results from water samples taken at Highway 301, Becks Ferry, and Abercorn Creek (Figure B1).

Georgia and South Carolina environmental agencies were also involved in sampling Savannah River water. The Georgia Department of Natural Resources (GDNR) and the South Carolina Department of Health and Environmental Control (SCDHEC) conducted independent sampling and analysis programs. Results of GDNR survey were also in good agreement with SRS results. Figure B2 shows a comparison of GDNR and ETS concentration measurements. Data from SCDHEC were unavailable at the time of this writing.

The Beaufort-Jasper Water and Sewer Authority shut down its river water intake pumps for 9 days while the tritium plume moved further downstream. Because Port Wentworth's water supply, Abercorn Creek, is influenced by tides, the Port Wentworth water treatment plant managed its pumping schedule to minimize the amount of tritium that entered their system. Some industries using water from the Port Wentworth system ceased operations for several days in response to the increased tritium concentrations in the Savannah River.

Emergency Response

At approximately 2:00 pm on December 25, 1991, two members of the ETS reported to the Emergency Operating Facility in Building 703-A. That afternoon the following tasks were accomplished: 1) estimated source term, 2) estimated transport time, 3) estimated the maximum tritium

concentration in the Savannah River, and 4) estimated maximum radiation dose and its impact.

Source Term

The source term was estimated to be 7500 curies. The assumptions used for the estimation in the initial response phase of the incident were as follows:

- The release is assumed to have begun at 12:30 pm on December 22, 1991 (midway between routine sampling times) and terminated at 4:10 am on December 25, 1991, lasting approximately sixty-four hours.
- The average tritium concentration in Pen Branch, 2600 pCi/mL, from 10:20 am, December 23, 1991 until 8:00 am on December 25, 1991, was assumed to be representative of the entire release. The value is based on water collected by an EMS continuous sampler located on Pen Branch.
- It was assumed that the flow rate of Pen Branch at the sample point was 440 ft³/sec for the entire sample period. This flow rate was based on measurements from the U.S. Geological Survey (USGS) monitoring station located at Pen Branch.

The underlined values above were used to calculate the initial source term estimate:

$$(64 \text{ hr}) \left(2600 \frac{\text{pCi}}{\text{mL}} \right) \left(440 \frac{\text{ft}^3}{\text{s}} \right) \left(10^{-12} \frac{\text{ci}}{\text{pCi}} \right) \\ \left(28.32 \frac{\text{L}}{\text{ft}^3} \right) \left(1000 \frac{\text{mL}}{\text{L}} \right) \left(3600 \frac{\text{s}}{\text{hr}} \right) = 7500 \text{ Ci}$$

Transport Time

The WIND System Stream Transport Model was used to predict downstream arrival times of the tritiated water released from K Reactor. The code was executed assuming that all the tritium was released at 12:30 pm, December 22, 1991. The predicted travel and arrival times are shown below.

Predictions of peak travel/arrival time of tritium released from K Reactor.

Location	Predicted Peak Travel Time		Predicted Peak Arrival Time	
Pen Branch at Road A	6 hrs	0 mins	6:30 pm	Dec. 22, 1991
Savannah River at:				
Steel Creek	3 days	11 hrs 30 mins	12:00 am	Dec. 26, 1991
Highway 301	4 days	2 hrs 45 mins	3:15 pm	Dec. 26, 1991
Beaufort-Jasper Intake	6 days	8 hrs 0 mins	8:30 pm	Dec. 28, 1991

Maximum Concentrations in the Savannah River

The initial prediction of maximum tritium concentration in the Savannah River was obtained by scaling the concentration measured in Pen Branch (2600 pCi/mL) with the ratio of the Pen Branch flow (440 cfs) and the measured Savannah River flow rate (6700 cfs) at Augusta, Georgia on December 26:

$$2600 \text{ pCi / ml} \left[6700 \frac{440 \text{ cfs}}{6700 \text{ cfs}} \right] = 170 \text{ pCi / mL}$$

Dose Estimation

A conservative estimate of radiation dose to an individual downstream of the SRS was calculated using the LADTAP XL river flow model.⁵ The maximum individual is assumed to ingest 2 liters of raw river water each day from the Savannah River at a point where complete mixing has occurred. The population dose is calculated based on the consumption of 1 liter of water each day by each of the individuals served by the water treatment facilities at Beaufort-Jasper and Port Wentworth (approximately 65,000 customers). The flow rate of the Savannah River was assumed to be a constant 6700 ft³/sec, based on information supplied by the USGS for Augusta, Georgia. Initial estimates of maximum individual and population dose via the drinking water pathway were 0.06 mrem and 1.9 person-rem, respectively.²

Sample Collection

Water samples were collected periodically from bodies of water and two water treatment plants affected by the

transport of tritium in route to the Atlantic Ocean. The bodies of water consisted of SRS streams, the Savannah River, the intake canal for the Beaufort-Jasper water treatment plant, Abercorn Creek, and the Savannah River estuary. Beaufort-Jasper and Port Wentworth were the two water treatment plants. The following photograph illustrates sampling at Beck's Ferry boat dock, other sampling locations are described in Table A1, Appendix A. Typical sample sizes ranged from 250 to 500 mL. All bottles used in sampling were rinsed with deionized water prior to use.

Two techniques were used in sampling. ETS sampling teams collected grab samples (also known as dip samples) by dipping a plastic bottle below the water surface. Many of the grab samples of raw and finished water were collected by personnel from the water treatment plants. The second technique consisted of battery-powered automatic samplers that collected grab samples at specific time intervals; bottles

for 24 individual samples are contained in each automatic sampler.

Prior to this study, automatic samplers were located at Steel Creek and Highway 301 bridge. Each sampler was programmed to collect a grab sample at 6-hour intervals and combine four successive samples to form a daily composite. During the present study, these samplers and the samplers that were installed down to the estuary were typically programmed to collect an individual grab sample every 60 or 120 minutes. Many locations also had a backup automatic sampler that was programmed to collect a sample midway between the primary sampler's collection interval. This resulted in grab samples being collected at 30 minute intervals.

EMS collected and analyzed daily composite samples from Pen Branch, onsite, Highway 301 and raw and finished water from the Beaufort-Jasper and Port Wentworth water treatment facilities. Additional information on EMS sampling is given in the Special Topics section.

Water samples were retrieved from automatic samplers by sampling teams several times daily. Steel Creek and Highway 301 samples were delivered to SRL for analysis in ETS laboratories. Samples from the other locations were delivered to the TRAC mobile laboratory while it was deployed at the Beaufort-Jasper water treatment plant at Chelsea, South Carolina, from December 29, 1991, to January 15, 1992. Aliquots of selected samples were taken for screening analysis aboard the TRAC thereby expediting turn-around times of crucial measurements. The remaining portion of these samples and all other samples were delivered to the ETS laboratories for analysis.

Analytical Results and Discussions

Tritium concentrations for all sampling locations are summarized in Appendix B. Also included in the Appendix is a discussion of analytical methods (also see Reference 1) used in ETS laboratories and the TRAC vehicle. Appendix C contains quality control data prepared during the analyses.

The peak tritium concentration at Steel Creek, 1350 pCi/mL, occurred during the morning of December 28 (Figure B3 and Table B1). Peak tritium concentrations at Highway 301 exceeded 60 pCi/mL on December 28 and then generally declined daily towards pre-release concentrations (Figure B4 and Table B2). Tritium released from K-Reactor essentially had passed the Highway 301 bridge by January 10.

As shown in Figures B5 and B6, tritium concentrations greater than 50 pCi/mL were measured on December 30 in the Savannah River near both water treatment plants. The concentrations in this part of the river were about 20% lower than the concentrations at the Highway 301 bridge. This is principally due to surface water inflow from streams between these locations.

The Beaufort-Jasper water treatment plant stopped pumping water from the Savannah River at approximately 6:00 am on December 28. Grab samples were collected in the Savannah River at Becks Ferry (Table B3) and from the intake canal leading to the Beaufort-Jasper lift station. The maximum tritium concentration in the canal near the Savannah River on January 1, 1992 was 30 pCi/mL (Table B4). Concentrations had decreased to about 15 pCi/mL by the time the Beaufort-Jasper water treatment plant resumed pumping January 6. Water containing approximately 15 pCi/mL moved down the canal and through the lift station on January 7 (Figure B7).

Grab samples were collected at the lift station (Table B5) and in the canal between the lift station and the treatment plant beginning January 7 (Table B6). The data show the parcel of tritiated water moving down the canal, reaching the receiving pond adjacent to the treatment plant by January 14. The tritium concentration at the pond entrance was half that measured at the lift station due to dilution. Samples collected at the plant intake (Figure B8 and Table B7) confirm that the tritiated water did not reach the Beaufort-Jasper treatment plant until January 15, at a concentration of five to seven pCi/mL. Treatment plant personnel collected samples of the raw and finished drinking water at Beaufort-Jasper. As shown in Table B8 the activity of the drinking water increased slightly after January 15.

Sampling in the Port Wentworth water treatment plant system was not as extensive as at Beaufort-Jasper. The fluctuations in tritium concentrations in Abercorn Creek (Figure B6 and Table B9) are due to tidal effects as discussed in the Special Topics section. The only other samples collected near Port Wentworth were raw and finished water from the treatment plant. Tritium concentrations were elevated in both the raw and finished water from December 30, 1991 through January 7, 1992 (Table B10). As the river's tritium concentration returned to lower values, so did the tritium concentrations in Port Wentworth raw and finished water.

Sampling was also conducted at various locations in the Savannah River estuary. ETS installed samplers at Fort Pulaski, Priest Landing, and St. Lawrence Institute. Measured

concentrations are shown in Figures B9 and B10 and Table B11. Only within the Savannah River itself did tritium concentrations exceed 20 pCi/mL (Table B12). See the section on Special Topics for further discussion of these results.

Observed Transport Time

The WIND System Stream Transport computer code was initially used to predict arrival times at key locations downstream of the SRS. The table below provides original

predictions and actual arrival times at locations downstream of the SRS. Concentrations in the Savannah River at Highway 301, Beaufort-Jasper, and Port Wentworth are plotted in Figure B11 along with predicted peak arrival times. Peak concentrations appeared more than a day after predicted, but predictions were generated assuming a short release at the earliest time possible, December 22, 1991, at 12:30 pm. A color-coded graphic representation of the tritium plume in the Savannah River during the period December 25, 1991 through January 10, 1992 is presented as Appendix D.

Predicted and observed tritium plume arrival times in the Savannah River.

Location	Arrival Time		
	Predicted Peak	Observed Leading Edge	Observed Peak
In Savannah River at:			
Highway 301	3:15 pm, Dec. 26	1:10 am, Dec. 26	9:30 pm, Dec. 27
Beaufort-Jasper Intake	8:30 pm, Dec. 28	10:30 am, Dec. 28	5:00 am, Dec. 30
Port Wentworth Intake	3:15 am, Dec. 29	1:00 pm, Dec. 28	5:30 pm, Dec. 30

Estimation of Source Term

The total amount of tritium released to Pen Branch was originally estimated to be approximately 7500 curies. This estimate was meant to be conservative and was based on tritium concentrations measured in Pen Branch during routine sampling operations. Tritium concentrations measured in the Savannah River at Highway 301 and near the intake to the Beaufort-Jasper canal provide new insight into the amount of tritium actually released from K-Reactor. Historical weekly averages of tritium concentrations in the Savannah River are plotted in Figure B12. Table B13 shows daily average tritium concentrations at Highway 301 bridge and Becks Ferry.

Estimates of the daily activity passing Highway 301 and Beaufort-Jasper were made from December 22, 1991 to January 15, 1992. Prior to December 25, concentrations were at normal levels for these locations. Nominal, five-year averages of tritium concentrations in the Savannah River at Highway 301 and Beaufort-Jasper (3.1 and 2.3 pCi/mL, respectively) were determined and used to remove other sources of tritium from the K-Reactor release estimate. Releases from SRS's Effluent Treatment Facility (ETF) caused tritium concentrations in the Savannah River

to remain at levels slightly above normal in January. However, for conservatism, ETF tritium transported past the Highway 301 bridge between January 10 and 15 is included in the estimate of the total amount of tritium released from K-Reactor. Daily Savannah River flow rates were estimated from data collected at the Highway 301 bridge and at Highway 119 (river-mile 61.5) near Clyo, Georgia. River flow rates, and therefore transport estimates, may be subject to minor changes pending official publication by the USGS; differences are expected to be less than 3%. River flow rates at Highway 119 were used to estimate tritium transport in the Savannah River past Becks Ferry.

Daily river flow rates and tritium transport at the Highway 301 bridge are shown in Table B14. It is estimated that the total tritium transported past monitoring stations at Highway 301 and Becks Ferry to be approximately 5670 and 5730 curies, respectively.⁶ Consideration was given to normal tritium levels when determining the amount of tritium transported down the Savannah River. Therefore, approximately 5700 curies of tritium were released to the Savannah River between December 22 and 25.

Health Impacts

Maximum Drinking-Water Dose

Original estimates of dose to the maximum individual were calculated assuming a tritium concentration of 170 pCi/mL and a water intake of 2 liters per day for 3 days. These assumptions resulted in a predicted dose of 0.06 mrem. Maximum concentrations, however, in the Savannah River at Highway 301 were about three times less than original, conservative estimates.

The Effective Dose Equivalent (EDE) was estimated for a maximum individual who consumed 2 liters of river water each day that the tritium concentrations were elevated.⁶ It was assumed that the maximum individual consumed raw river water collected at the Highway 301 monitoring location. The dose to this person is higher than the actual doses received by users of the Beaufort-Jasper and Port Wentworth water supplies; the Beaufort-Jasper plant closed its intake canals during plume passage and Port Wentworth concentrations are lower than those measured at Highway 301. The average tritium concentration at Highway 301 under normal conditions (3.1 pCi/mL) was subtracted from measured concentrations to determine the dose contribution from the K-Reactor release. A tritium dose factor of 6.3×10^{-8} mrem/pCi was used to estimate the impacts.⁴

The radiation dose from tritium in the maximum individual's drinking water was approximately 0.035 mrem.⁶ The majority of this dose would have been delivered to this hypothetical maximum individual at Highway 301 between December 26 and January 1. Tritium concentrations in the Savannah River at Hwy 301 returned to near normal levels on about January 10.

The maximum dose to individuals consuming treated water from the Beaufort-Jasper or Port Wentworth domestic water systems is 0.0096 and 0.030 mrem, respectively.⁷ Dose estimates are based upon measured tritium concentrations in treated domestic water from the two facilities. Estimates are conservative since they are generated assuming a water consumption rate of 2 liters/day, each day the tritium concentrations were above normal. Additionally, workers at the Savannah Industrial Park (users of Port Wentworth water) were instructed not to drink the water during the time that tritium levels were elevated.

Maximum Dose from the Consumption of Aquatic Species

Estimates of the maximum dose to individuals who harvest fish and/or invertebrates from the Savannah River are presented below. Conservative dose estimates are much smaller via these pathways than through the drinking water pathway.

Concentrations of tritium in fish reach equilibrium with the river water in a few hours. For conservatism, it is assumed that the tritium concentration in fish is equivalent to the maximum daily average of concentrations measured at Highway 301 (56.3 pCi/mL). The dose to an individual who eats 20 fish (approximately 10% of the annual average individual fish consumption, each fish being 50% edible and weighing 100 grams) with a tritium concentration of 56.3 pCi/mL is approximately 0.0035 mrem. For the isolated case of an individual fishing in Steel Creek at the time of the peak tritium concentration, the dose could be as much as 20 times higher.

It is also assumed that invertebrates have been exposed to river water with a tritium concentration equal to the maximum measured concentration at Highway 301 and that tritium uptake is rapid in invertebrates. The dose to an individual who eats 1 quart of invertebrates (freshwater mussels) with a tritium concentration of 56.3 pCi/mL is 0.0035 mrem. The fish and mussel doses are equal since the net intake of tritiated water is 1 liter in both cases. The majority of shellfish (oysters) are harvested, however, in saltwater estuaries where the tritium concentration was about 1/10th the concentration in the Savannah River. Additionally, public concerns resulted in the harvesting of oysters being dramatically reduced during the passage of the tritium plume.

Oysters from the public beds at Fort Pulaski were sampled by both ETS and EMS. Concentrations of tritium in the sampled oysters ranged from about 2.1 pCi/mL to 8.3 pCi/mL.

An individual exposed through all pathways considered (water, fish, and invertebrate ingestion) would receive a maximum dose of about 0.042 mrem resulting from the release at K-Reactor

Average Individual and Population Dose

Elevated tritium concentrations in the Savannah River at Becks Ferry and Abercorn Creek resulted in higher than normal concentrations in the domestic water supplies at Beaufort-Jasper and Port Wentworth. The population dose to customer's of those water systems was calculated based on actual tritium concentration measurements of drinking water.⁷ Data presented here have been used to estimate the dose to the 50,000 consumers on the Beaufort-Jasper system and the 15,000 consumers on the Port Wentworth system, assuming that each user consumes one liter of water per day.

The dose to the average individuals at Beaufort-Jasper and Port Wentworth was 0.0048 and 0.015 mrem, respectively. The population dose to users of domestic water from the Beaufort-Jasper and Port Wentworth systems was approximately 0.24 and 0.23 person-rem, respectively. Details on the dose calculation and tritium concentrations in finished water can be obtained from.⁷

The population dose from consumption of fish and oysters harvested during the traversal of tritium in the Savannah River and its estuary is estimated to be 0.0019 person-rem for fish consumption and 0.0022 person-rem for oyster consumption. Total dose to the population drinking treated water and eating fish and oysters from the Savannah River is approximately 0.47 person-rem.

EPA Drinking Water Standard

The Environmental Protection Agency has established a standard which limits the radiation dose to any individual exposed via the drinking water pathway. The standard (40 CFR 141) reads as follows, "The average annual concentration of beta particle and photon activity from man-made radionuclides in drinking water shall not produce an annual dose equivalent to the total body or any internal organ greater than 4 mrem/yr."

As demonstrated above, the dose to the maximum individual who drinks untreated river water at Highway 301 is less than 0.04 mrem, two orders of magnitude below the EPA standard. The concentrations measured at the water treatment plants were lower than those at Highway 301. Preliminary dose estimates for all of 1991 show that the maximum offsite individual receives a dose of about 0.14 mrem from tritium in the Savannah River (Figure B13). This dose includes all aqueous tritium releases from the SRS, including the K-Reactor incident.

Dose to Aquatic Biota

The Department of Energy, in DOE Order 5400.5, has established an interim dose limit for the protection of native aquatic organisms. The absorbed dose limit to these organisms is 1 rad/day from exposure to radioactive substances in liquid effluents discharged to natural waterways.

Following the K-Reactor tritium release, the highest daily average tritium concentration in the Savannah River at Highway 301 was 56.3 pCi/mL. Since tritium in fish equilibrates with tritium in water in a few hours, the dose to the fish can be calculated for a concentration of 56.3 pCi/g in fish. The maximum dose to a fish at Highway 301 was 0.016 mrad/day.³

The highest daily average tritium concentration in Steel Creek mouth was approximately 1300 pCi/mL (1300 pCi/g in fish). The maximum dose to the fish in Steel Creek was 0.38 mrad/day.³

Special Topics

Several one-time samples were collected for specific purposes. EMS gathered water samples from the K-Area discharge for analysis to determine if any radionuclides other than tritium had been released; no other nuclides were detected. EMS also conducted a survey of the swamp from Pen Branch to Steel Creek on December 31 to determine whether any significant tritium inventory was being held in the swamp rather than being flushed through the swamp with the other water. This survey showed variable concentrations that mimicked the results of surveys at the mouth of Steel Creek, demonstrating that the swamp was not retaining substantial tritium from the release.

Abercorn Creek/Port Wentworth Intake

The pump station for the City of Savannah is located on Abercorn Creek, a tributary of the Savannah River. Abercorn Creek is a small tidal freshwater creek, about five miles long, and its watershed is located within the Savannah River floodplain. The creek joins the Savannah River at river mile 29, about one mile above I-95. Tides that range six feet are present in this freshwater region of the river. These tides result in a considerable amount of water being transported in and out of Abercorn Creek during a tidal cycle. As a result of the tidal movement and mixing of water in Abercorn Creek, pollutant release profiles are altered by

the tidal exchange process in the creek and do not smoothly follow those that are in the river. At high tide, the tritium concentration at the pump station reflects the concentration that is actually in the river. At low tide, the tritium concentration represents the water that was stored in the upper reaches of Abercorn Creek.

The effect of the tides on the tritium concentration in Abercorn Creek at the pump station (Figure B6) are obvious when compared to the tritium concentration measured ten miles upriver at Becks Ferry (Figure B5). In the early stage of the release, the tritium was higher during high tide (river water) and lower during low tide (water from the upper reach of the creek; the first part of the curve in Figure B6). After several tidal cycles, water in the upper reaches of Abercorn Creek had become mixed with the higher tritium concentrations in the river. As the tritium decreased in the Savannah River, the tritium concentration in the upper part of Abercorn Creek was higher than that of the river. When that occurred, the tritium concentration was lower at high tide (river water) and higher at low tide (latter part of the curve in Figure B6). After the river returned to a steady state tritium concentration and several tidal cycles, there was no difference between high and low water tritium concentrations (end of curve in Figure B6).

The Savannah River Estuary

On January 3, 1992, grab samples were collected in the Savannah River and in the estuary to the north and south of the river (Figure A3). The results are shown in Tables B11 and B12. Samples were collected along the Wilmington River from Wassaw Sound to the Savannah River (south sweep). A sweep of the Savannah River was then conducted from Mackey Point down to the river mouth. Finally sampling was performed in the vicinity of New River and Calibogue Sound (north sweep).

Results for the south sweep show that with increasing distance from the Savannah River tritium concentrations in the Wilmington River decreased. Concentrations of 13.5 pCi/mL were measured near the Savannah River, decreasing to levels normally found in the Wassaw Sound. In the north sweep no elevated tritium concentrations were

detected. Tritium concentrations in the Savannah River near Mackey Point reached 26.7 pCi/mL. Samples collected downstream from Mackey Point showed decreasing tritium concentrations. Concentrations at Ft. Pulaski returned to normal levels by January 13 (Figure B9).

Longer-term studies were conducted at Thunderbolt Marina, Lazaretto Creek, Fort Pulaski, Skidaway Institute and Priest Landing (Table B12 and Figure B10). Tritium concentrations were slightly elevated (8–10 pCi/mL) at the Thunderbolt Marina and in Lazaretto Creek during the first week in January but returned to normal levels by January 15. Samples collected at Fort Pulaski showed a tidal influence (Figure B9). At low tide, when the water flow is dominated by the Savannah River, tritium concentrations were elevated. At high tide, when water flow is dominated by influx from the Atlantic Ocean, low tritium concentrations were measured. Samples collected near Skidaway Institute and Priest Landing typically had tritium concentrations of only a few pCi/mL (Table B12 and Figure B10). On January 10 a single sample collected at Priest Landing had a tritium concentration of 11.4 pCi/mL. Since the tritium peak was of short duration, the most likely transport path was in the inland waterway between Savannah River estuary and Wassaw Sound.^a

Acknowledgments

The authors thank the SRS personnel who assisted in the sampling and analysis program. Numerous Senior Laboratory Technicians in ETS and EMS assisted in sample collection, sampler maintenance, courier trips, sample preparation, and counting. J.E. Miller organized and scheduled the work of the ETS Senior Laboratory Technicians. For TRAC's deployment, M. Hendrix provided maintenance support; J.D. Leyba and R.A. Sigg, both from the SRL Analytical Development Section, provided the Ultima Gold XR™ liquid scintillation cocktail. Individuals who are not associated with SRS are acknowledged for their assistance. Personnel from the Beaufort-Jasper and Port Wentworth water treatment plants collected many of the samples of raw and finished water. The TRAC staff thanks the personnel of the Beaufort-Jasper water treatment plant for their assistance during TRAC's deployment.

References

1. Beals, D.M., Dunn, D.L., Hall, G., Kantelo, M.V., "Tritium Sample Analyses in the Savannah River and Associated Waterways Following the K-Reactor Release of December 1991", WSRC-TR-92-24, Westinghouse Savannah River Company, Aiken, SC, February 5, 1992.
2. Carlton, W.H., "Drinking Water Dose from K-Reactor Release", Westinghouse Savannah River Laboratory, SRL-ETS-910619, December 26, 1991.
3. Carlton, W.H., "Dose to Fish as a Result of the 12/91 K-Reactor Tritium Release", Westinghouse Savannah River Laboratory, SRL-ETS-920041, January 20, 1992.
4. US Department of Energy, "Internal Dose Conversion Factors for Calculation of Dose to the Public", DOE/EH-0071, July 1988.
5. Hamby, D.M., "LADTAP XL: An Improved Electronic Spreadsheet Version of LADTAP II", Westinghouse Savannah River Company, WSRC-RP-91-975, November 18, 1991.
6. Hamby, D.M., "Health Impact of Tritium Release from K-Reactor", Westinghouse Savannah River Company, Savannah River Laboratory, SRL-ETS-920001, January 28, 1992.
7. Hamby, D.M., "Individual and Population Dose to Users of the Savannah River Following K-Reactor Tritium Release", SRL-ETS-920061, January 29, 1992.
8. Hayes, D.W., "Tritium in the Savannah River Estuary and Adjacent Marine Waters", IAEA-SM-232/80, In Proceedings of the International Symposium on the Behaviour of Tritium in the Environment, San Francisco, October 1978.

This page intentionally left blank

Appendix A

Sampling Locations and Maps

This page intentionally left blank

Table A1. Water sampling locations from SRS to the Savannah River estuary.

Location	Comments
At SRS	
Steel Creek	0.2 miles from its confluence with the Savannah River at river-mile 141.6
On the Savannah River	
Highway 301 Bridge	River-mile 118.7
Becks Ferry Boat Landing	River-mile 38.9
In the Beaufort-Jasper Water Treatment Plant System	
Canal Locations	Canal begins at river-mile 39.2
200 yards from river	
400 yards from river	
At Black Creek	0.4 miles from the Savannah River
100 yards before lift station	
Lift Station discharge	0.6 miles from the river
Highway 321	2.9 miles from the river
Dirt road	5.8 miles from the river
Highway 17	7.3 miles from the river
Jasper Road	12.8 miles from the river
Highway 278	14.7 miles from the river
End of canal at receiving pond	17.7 miles from the river
End of receiving pond	
Intake to treatment plant	
Raw water	
Finished water	
In the Port Wentworth Water Treatment Plant System	
Lift Station on Abercorn Creek	2 miles from confluence of Abercorn Creek with the Savannah River at river-mile 29.0
Raw water	
Finished water	
Savannah River Estuary	
Fort Pulaski	
Priest Landing	
Skidaway Institute	
Lazaretto Creek	
Thunderbolt Marina	

This page intentionally left blank

Figure A3. Map of the Savannah River estuary

This page intentionally left blank

Appendix B

Data Summary

This page intentionally left blank

Analytical Methods

Laboratory Analyses

Tritium activity in water samples was a determination using liquid scintillation counting (LSC). A Packard Tri-Carb 2050A™ liquid scintillation counter with automatic quench correction was used for the analyses. At least one blank and one spike were prepared with each batch of samples received.

Samples received from the various sampling locations were assigned a sequential identification number and prepared for counting as soon after arrival as possible, usually within 12 hours of collection. Samples were prepared in batches depending on location. Three milliliters of sample were measured into a plastic liquid scintillation vial along with 19 mL of Packard Opti-Fluor™ liquid scintillation cocktail. Each sample was prepared in duplicate. Blanks were prepared using 3.0 mL of distilled water and 19 mL of cocktail. Each spike contained 3.0 mL of distilled water, 19 mL of cocktail and 0.250 mL of a tritiated water standard traceable to the National Institute of Standards and Technology (NIST). The spikes were used to confirm the automatic quench correction for counting efficiency.

Samples, blanks, and spikes were shaken to mix, transferred to the counting facility, placed into the counter, and allowed a 30 minute period for natural fluorescence to diminish before counting. A blank was counted prior to the samples. A single 10 minute count was performed on each sample, blank and spike, and, as time permitted, duplicate samples were counted. Due to time and instrument constraints, duplicates were counted from a few hours to several days after the original sample count. Not all sample duplicates were counted.

The reported concentration in a water sample was taken as either the average of the individual concentrations for duplicates or the individual concentration when duplicates were not analyzed. Individual concentrations were determined based on the volume of sample mixed with cocktail and the computer-assisted calculation of activity for the spectral tritium energy region for blank and gross samples. Net sample activity was calculated by subtracting a running average blank activity. For convenience, concentrations tabulated in this appendix are shown to two decimal places, which in many cases is greater accuracy than warranted by the data. Typical measurement uncertainties, based on counting statistics at the 95% confidence level, are shown in Figure C1.

Analyses Aboard the TRAC

Tritium analyses were performed aboard the TRAC vehicle by LSC. Two different liquid scintillation cocktails were used. During the first week Opti-Fluor™ was used in the proportion of 19 mL cocktail and 3.0 mL sample; this is identical to the proportions used in the ETS laboratory.

Later, analyses were performed with a new cocktail. Packard Ultima Gold XR™ permits a greater proportion of sample to be mixed with cocktail. Consequently 10.0 mL of sample was mixed with 14 mL of Ultima Gold cocktail.

Samples were analyzed in duplicate using two Aston Model 1600 liquid scintillation counters. Reagent blanks were typically counted after every other sample. Reagent blanks were prepared several times daily by mixing deionized water (a substitute for the sample) and cocktail in the appropriate proportions. Samples were typically counted in four sequential 5-minute counting intervals, for a total of 20 minutes; blanks were counted similarly.

LSC pulse height spectra for each counting interval were accumulated by a computer-based multichannel analyzer. Examination of the tritium energy region of individual spectra allowed the occasional outlier results to be excluded. After measurement, 0.100 mL of a NIST traceable tritiated water standard was added to each sample to determine the degree of quench. The standard contained 1192 pCi of tritium. The samples with added standard were then counted for 3 to 5 minutes.

The reported tritium concentration in a water sample was taken as the average of the individual concentrations for the duplicates. Individual concentrations were calculated based on the volume of sample mixed with cocktail, the known tritium content of the added standard, and the count rate in the tritium energy region of the spectra for the blank, the sample, and the

sample with added standard. Typical measurement uncertainties, based on counting statistics at the 95% confidence level, are shown in Figure C1.

Measured tritium concentrations for all samples are reported in units of pCi/mL. When both the original sample and the duplicate were counted, the average result is reported with its precision (68% confidence level). If only the original sample was counted, the activity is reported without an associated uncertainty. TRAC analysis results are identified in all tables of Appendix B by left justified collection times with results and uncertainties to one decimal place. For those samples analyzed by both the TRAC and the ETS laboratory, the results are shown separately in the tables and figures.

Figure B1. Comparison of EMS & ETS monitoring data

Figure B3. Concentrations in Steel Creek

Figure B5. Concentrations at Becks Ferry

Savannah River At Abercorn Creek

Port Wentworth WTP

Figure B6. Concentrations at Abercorn Creek

Figure B7. Concentrations at Beaufort–Jasper lift station

Figure B9. Concentrations near Fort Pulaski

AVERAGE WEEKLY TRITIUM CONCENTRATION IN THE SAVANNAH RIVER AT HIGHWAY 301

Figure B12. Historical weekly average of tritium concentrations in the Savannah River

This page intentionally left blank

Table B1. Steel Creek Survey

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
dec 19	520	7.50	1.46
dec 20	520	7.56	1.33
dec 21	520	7.54	0.60
dec 22	520	7.69	1.38
dec 23	520	7.35	1.08
dec 24	520	7.10	1.21
dec 25	520	67.13	4.22
dec 26	220	447.97	17.01
dec 26	1230	960.87	4.14
dec 26	1330	930.19	18.82
dec 26	1430	1041.47	1.77
dec 26	1530	947.67	8.19
dec 26	1630	1050.65	3.54
dec 26	1730	982.82	6.64
dec 26	1830	997.95	32.80
dec 26	1930	982.06	7.69
dec 26	2030	1076.90	4.33
dec 26	2130	937.36	26.57
dec 26	2230	1050.01	0.72
dec 26	2330	970.75	44.14
dec 27	30	1094.47	46.33
dec 27	130	1000.02	60.27
dec 27	230	1110.67	8.08
dec 27	330	1044.65	21.84
dec 27	430	1095.66	50.59
dec 27	530	1097.92	36.35
dec 27	630	1102.45	92.86
dec 27	730	1089.67	54.38
dec 27	830	1134.74	46.70

Table B1. Steel Creek Survey (Page 2 of 7)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 27	930	1163.83	8.96
dec 27	1030	1170.37	75.10
dec 27	1100	1203.44	61.16
dec 27	1500	1240.95	57.29
dec 27	1900	1235.42	6.24
dec 27	2000	1212.59	
dec 27	2100	1283.95	72.66
dec 27	2200	1240.04	
dec 27	2300	1299.03	80.81
dec 28	0	1250.17	
dec 28	100	1335.55	133.81
dec 28	300	1326.52	81.59
dec 28	400	1253.73	
dec 28	500	1364.47	9.36
dec 28	600	1259.27	
dec 28	700	1348.49	18.43
dec 28	900	1255.30	
dec 28	1100	1224.32	69.28
dec 28	1300	1268.66	
dec 28	1400	1237.44	19.57
dec 28	1600	1209.87	54.23
dec 29	1000	916.33	45.39
dec 29	1130	867.20	
dec 29	1330	847.17	
dec 29	1530	898.53	
dec 29	1630	834.06	
dec 29	1730	845.13	37.05
dec 29	1930	810.93	1.82
dec 29	2130	834.04	54.06
dec 29	2330	835.63	42.72

Table B1. Steel Creek Survey (Page 3 of 7)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
dec 30	130	792.05	10.70
dec 30	330	792.73	3.85
dec 30	530	783.84	12.22
dec 30	730	766.23	2.92
dec 30	830	807.87	
dec 30	1030	727.54	
dec 30	1230	695.08	
dec 30	1430	709.94	
dec 30	1530	728.11	29.20
dec 30	1630	747.73	
dec 30	1830	722.67	
dec 30	2030	696.86	
dec 30	2230	643.13	26.69
dec 31	30	598.69	
dec 31	200	468.92	10.66
dec 31	230	633.08	
dec 31	430	595.65	
dec 31	430	536.13	
dec 31	1100	492.72	4.04
dec 31	1500	500.66	34.27
dec 31	1600	480.49	
dec 31	1700	460.01	
dec 31	1800	460.48	
dec 31	1900	459.05	
dec 31	2000	444.00	16.08
dec 31	2100	435.95	20.87
dec 31	2200	422.20	
dec 31	2300	440.51	4.62
jan 1	0	433.36	
jan 1	100	410.56	24.42
jan 1	200	420.97	9.06
jan 1	300	407.57	0.02
jan 1	400	395.19	21.98
jan 1	500	392.53	19.75

Table B1. Steel Creek Survey (Page 4 of 7)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 1	600	392.96	3.20
jan 1	700	376.23	18.36
jan 1	900	368.00	15.59
jan 1	1000	356.57	22.9
jan 1	1300	351.78	
jan 1	1400	326.39	
jan 1	1800	339.30	
jan 1	2000	331.81	
jan 1	2200	348.05	
jan 2	0	350.47	
jan 2	200	347.68	
jan 2	600	332.31	5.85
jan 2	1000	275.03	
jan 2	1100	273.48	
jan 2	1200	259.99	
jan 2	1400	265.70	10.23
jan 2	1500	246.00	
jan 2	1700	246.15	0.55
jan 2	1900	255.61	
jan 2	2000	250.58	3.06
jan 2	2100	253.66	
jan 2	2300	237.32	4.67
jan 3	100	229.04	
jan 3	300	226.02	
jan 3	500	231.03	
jan 3	700	227.55	4.40
jan 3	930	209.67	7.60
jan 3	1330	209.43	7.79
jan 3	1730	200.85	8.94
jan 3	2130	193.89	12.68
jan 3	2330	197.00	

Table B1. Steel Creek Survey (Page 5 of 7)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 4	130	193.52	1.48
jan 4	330	187.79	
jan 4	530	177.49	
jan 4	730	183.80	10.03
jan 4	1230	163.02	
jan 4	1630	163.00	
jan 4	2030	173.53	
jan 5	30	162.62	2.40
jan 5	230	148.37	6.70
jan 5	330	133.74	
jan 5	430	160.63	
jan 5	730	134.16	3.98
jan 5	830	155.88	
jan 5	1030	144.56	
jan 5	1330	125.44	17.14
jan 5	1630	142.97	
jan 5	1830	128.16	
jan 5	1930	137.44	11.27
jan 5	2230	141.16	1.82
jan 6	30	144.79	
jan 6	430	132.51	3.18
jan 6	830	134.12	
jan 6	1000	138.25	
jan 6	1100	132.03	20.06
jan 6	1200	119.64	14.31
jan 6	1300	136.44	7.94
jan 6	1400	127.50	9.57
jan 6	1500	109.82	5.18
jan 6	1600	120.25	
jan 6	1700	130.57	13.72
jan 6	1800	122.71	
jan 6	1900	104.25	
jan 6	2000	124.37	25.69
jan 6	2100	125.15	
jan 6	2200	129.95	17.25
jan 6	2300	121.54	4.85

Table B1. Steel Creek Survey (Page 6 of 7)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
jan 7	0	125.29	3.25
jan 7	100	111.58	
jan 7	200	125.80	11.84
jan 7	300	111.53	10.87
jan 7	500	119.42	26.25
jan 7	600	115.53	15.78
jan 7	700	100.64	23.34
jan 7	800	121.49	1.14
jan 7	900	118.19	7.71
jan 7	1400	111.05	0.73
jan 7	2000	108.69	1.24
jan 8	200	102.67	1.70
jan 8	800	105.90	4.87
jan 8	1100	109.14	3.05
jan 8	1700	101.01	7.65
jan 8	2300	98.98	4.89
jan 9	500	94.80	0.12
jan 9	1100	95.74	6.87
jan 9	1200	91.59	9.21
jan 9	1300	96.59	0.78
jan 9	1400	91.84	3.46
jan 9	1430	92.87	
jan 9	2000	88.74	3.60
jan 10	200	86.78	2.33
jan 10	800	84.95	2.95
jan 10	1000	84.85	4.59
jan 10	1100	85.49	5.76
jan 10	1200	82.78	3.24
jan 10	1500	83.57	4.77
jan 10	2100	81.95	1.45
jan 11	300	89.78	0.64
jan 11	900	75.62	2.70
jan 11	1500	77.00	2.88

Table B1. Steel Creek Survey (Page 7 of 7)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1sigma</u>
jan 11	2100	77.81	0.41
jan 12	300	76.79	3.57
jan 12	900	72.98	
jan 12	1500	71.19	9.33
jan 12	2100	79.31	2.23
jan 13	300	69.76	3.14
jan 13	900	64.18	2.21
jan 13	1400	56.00	6.82
jan 13	2000	58.32	1.68
jan 14	200	53.74	0.42
jan 14	800	54.78	0.81
jan 14	1000	58.55	2.79
jan 14	1200	71.71	0.20
ian 14	1500	71.21	5.23
jan 14	1800	72.52	1.03
jan 14	2100	73.72	3.13
jan 15	0	78.39	2.04
jan 15	300	74.73	0.16
jan 15	600	78.26	3.18
jan 15	900	76.37	0.25

Table B2. Highway 301 survey

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1sigma</u>
dec 19	410	1.39	0.74
dec 20	410	1.27	0.61
dec 21	410	1.61	0.46
dec 22	410	2.35	0.35
dec 23	410	2.99	0.86
dec 24	410	2.56	0.85
dec 25	410	3.77	1.77
dec 26	110	13.39	1.10
dec 26	1030	27.43	0.28
dec 26	1130	29.71	0.49
dec 26	1230	30.56	1.92
dec 26	1330	32.04	0.93
dec 26	1430	37.44	0.91
dec 26	1530	36.50	1.82
dec 26	1630	36.98	0.65
dec 26	1730	38.11	1.78
dec 26	1830	40.36	3.08
dec 26	1930	42.17	1.56
dec 26	2030	46.61	2.68
dec 26	2130	43.00	1.34
dec 26	2230	50.42	1.41
dec 26	2330	48.70	4.02
dec 27	30	50.68	1.66
dec 27	100	51.58	
dec 27	130	51.07	0.40
dec 27	200	50.79	
dec 27	230	50.62	1.46
dec 27	300	55.27	
dec 27	330	52.12	1.73

Table B2. Highway 301 survey (Page 2 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 27	400	55.38	
dec 27	430	50.91	1.19
dec 27	500	59.51	
dec 27	530	54.16	2.69
dec 27	600	57.25	
dec 27	630	54.07	1.46
dec 27	700	58.94	
dec 27	730	51.07	4.22
dec 27	800	59.71	
dec 27	830	52.26	1.76
dec 27	930	47.22	3.07
dec 27	1000	60.28	
dec 27	1030	55.93	4.31
dec 27	1100	59.07	
dec 27	1130	59.16	0.23
dec 27	1330	57.84	3.66
dec 27	1530	61.79	0.88
dec 27	1730	60.47	5.54
dec 27	1830	59.99	0.16
dec 27	1930	60.73	5.29
dec 27	2030	61.49	2.89
dec 27	2130	62.89	2.90
dec 27	2230	60.74	4.31
dec 27	2330	61.32	3.73
dec 28	30	56.81	
dec 28	130	59.77	1.29
dec 28	230	66.85	
dec 28	330	61.51	2.14
dec 28	430	57.80	
dec 28	530	58.71	5.73
dec 28	630	54.84	
dec 28	730	56.46	3.15
dec 28	830	55.75	
dec 28	900	54.19	0.75
dec 28	1000	54.12	0.11
dec 28	1100	53.69	4.61
dec 28	1200	54.37	3.37

Table B2. Highway 301 survey (Page 3 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 28	1300	55.49	3.20
dec 28	1400	55.02	2.26
dec 28	1500	55.62	0.45
dec 28	1600	56.13	4.49
dec 28	1700	51.18	2.08
dec 28	1800	50.67	
dec 28	1900	48.13	
dec 28	2000	53.40	
dec 28	2100	55.73	1.98
dec 28	2300	51.21	1.46
dec 29	100	51.90	3.85
dec 29	300	51.71	3.27
dec 29	500	50.55	1.23
dec 29	700	51.52	1.82
dec 29	900	48.58	2.18
dec 29	1100	45.94	0.87
dec 29	1300	42.31	
dec 29	1500	47.18	
dec 29	1700	42.48	
dec 29	1800	42.06	
dec 29	1900	38.62	1.97
dec 29	2000	42.23	
dec 29	2100	42.65	
dec 29	2200	42.02	
dec 30	0	39.37	
dec 30	200	38.01	
dec 30	300	33.77	
dec 30	500	37.09	2.68
dec 30	600	34.04	0.02
dec 30	730	34.65	
dec 30	830	34.15	
dec 30	900	34.43	
dec 30	930	41.57	2.75
dec 30	1000	30.83	0.82
dec 30	1030	48.95	1.57
dec 30	1100	32.25	

Table B2. Highway 301 survey (Page 4 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCl/mL</u>	<u>error 1 sigma</u>
dec 30	1130	35.26	2.06
dec 30	1230	35.63	
dec 30	1330	30.33	
dec 30	1430	32.48	
dec 30	1500	30.82	
dec 30	1700	32.86	3.66
dec 30	1800	32.44	
dec 30	1900	31.69	
dec 30	1930	31.73	
dec 30	2000	30.87	2.82
dec 30	2030	30.76	
dec 30	2100	28.52	
dec 30	2130	29.70	
dec 30	2200	29.31	0.38
dec 30	2230	27.19	
dec 30	2300	28.35	
dec 30	2330	27.78	
dec 31	0	28.65	0.11
dec 31	30	28.01	
dec 31	100	26.73	
dec 31	130	30.73	
dec 31	200	25.47	0.75
dec 31	230	25.80	
dec 31	300	24.10	
dec 31	330	26.81	
dec 31	400	25.62	0.91
dec 31	600	25.62	0.39
dec 31	730	24.81	
dec 31	930	24.30	
dec 31	1030	23.26	
dec 31	1100	25.02	
dec 31	1130	21.81	
dec 31	1200	22.45	
dec 31	1230	21.23	
dec 31	1300	22.33	
dec 31	1330	20.69	
dec 31	1400	19.87	

Table B2. Highway 301 survey (Page 5 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 31	1430	19.17	0.88
dec 31	1500	19.89	
dec 31	1530	20.58	0.48
dec 31	1600	19.56	
dec 31	1630	19.75	
dec 31	1700	19.03	
dec 31	1730	20.55	0.30
dec 31	1800	19.26	
dec 31	1830	20.00	
dec 31	1900	20.29	
dec 31	1930	20.09	0.14
dec 31	2000	18.30	
dec 31	2030	16.40	
dec 31	2100	16.07	
dec 31	2130	21.37	2.69
dec 31	2230	17.98	0.69
dec 31	2330	19.30	0.74
jan 1	30	17.34	2.84
jan 1	130	16.36	0.33
jan 1	230	16.96	0.76
jan 1	330	18.87	1.83
jan 1	430	16.16	2.71
jan 1	500	16.03	0.92
jan 1	530	15.70	1.47
jan 1	600	16.68	1.06
jan 1	800	15.49	
jan 1	900	16.97	
jan 1	1000	16.75	
jan 1	1200	15.02	
jan 1	1400	14.73	
jan 1	1500	12.59	
jan 1	1700	13.84	1.03
jan 1	1900	10.92	
jan 1	2100	11.44	
jan 2	900	8.49	
jan 2	1000	9.81	

Table B2. Highway 301 survey (Page 6 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
jan 2	1200	9.47	
jan 2	1400	9.45	
jan 2	1600	10.55	
jan 2	1800	10.12	1.07
jan 2	2000	9.51	
jan 2	2200	8.55	
jan 3	0	8.27	
jan 3	200	8.66	
jan 3	400	11.49	
jan 3	600	9.23	0.21
jan 3	700	11.23	
jan 3	800	10.41	0.47
jan 3	900	11.19	
jan 3	1000	9.08	
jan 3	1100	9.87	
jan 3	1200	11.61	
jan 3	1300	9.90	
jan 3	1400	9.80	
jan 3	1430	9.73	
jan 3	1930	7.86	2.51
jan 3	2130	6.64	1.78
jan 3	2330	9.01	
jan 4	30	6.08	1.06
jan 4	130	7.05	
jan 4	230	6.57	2.33
jan 4	430	9.63	
jan 4	530	10.54	
jan 4	630	8.84	1.68
jan 4	730	9.60	
jan 4	1100	5.49	0.38
jan 4	1400	5.82	0.30
jan 4	1700	5.34	0.37
jan 4	1800	5.41	0.87
jan 4	1900	4.37	1.55
jan 4	2000	4.53	0.43

Table B2. Highway 301 survey (Page 7 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 4	2100	5.20	0.36
jan 4	2200	5.24	0.04
jan 4	2300	5.43	
		5.43	
jan 5	0	6.95	2.59
jan 5	100	4.47	
jan 5	200	5.22	1.33
jan 5	300	4.77	
jan 5	400	5.05	0.18
jan 5	500	5.67	
jan 5	600	4.85	0.73
jan 5	700	5.57	0.25
jan 5	800	5.53	2.26
an 5	900	5.40	1.10
jan 5	1000	5.96	0.64
jan 5	1100	5.93	
jan 5	1200	5.11	0.47
jan 5	1300	5.64	
jan 5	1400	5.69	1.20
jan 5	1500	4.77	
jan 5	1600	5.06	0.54
jan 5	1700	6.22	
jan 5	1800	4.74	0.28
jan 5	1900	5.15	0.69
jan 5	2000	5.36	0.06
jan 5	2100	5.10	
jan 5	2200	5.83	0.87
jan 5	2300	4.76	
jan 6	0	4.56	0.09
jan 6	100	5.25	
jan 6	200	4.73	0.69
jan 6	300	3.78	
jan 6	400	3.31	0.81
jan 6	500	2.92	
jan 6	600	3.77	
jan 6	800	3.85	0.73
jan 6	900	4.85	0.68

Table B2. Highway 301 survey (Page 8 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
jan 6	1000	3.57	
jan 6	1100	3.23	0.67
jan 6	1200	3.17	1.27
jan 6	1300	2.68	0.30
jan 6	1400	3.47	0.33
jan 6	1500	3.12	0.95
jan 6	1600	3.57	1.02
jan 6	1700	4.03	0.43
jan 6	1800	4.20	0.66
jan 6	1900	4.94	0.60
jan 6	2000	4.56	1.22
jan 6	2100	4.51	0.44
jan 6	2200	4.81	0.98
jan 6	2300	3.93	1.00
jan 7	0	4.79	0.08
jan 7	100	5.55	0.60
jan 7	200	3.92	0.92
jan 7	300	5.46	0.38
jan 7	400	4.98	0.43
jan 7	500	4.18	0.70
jan 7	600	5.55	0.69
jan 7	630	4.92	0.85
jan 7	1230	4.23	0.69
jan 7	1830	3.98	0.28
jan 8	30	5.40	0.81
jan 8	630	7.74	0.82
jan 8	930	6.29	0.53
jan 8	1530	2.90	0.03
jan 8	2130	3.15	0.37
jan 9	330	5.36	0.26
jan 9	430	5.87	
jan 9	930	5.12	
jan 9	1030	7.34	1.93
jan 9	1130	6.53	0.92
jan 9	1230	6.81	1.36

Table B2. Highway 301 survey (Page 9 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1sigma</u>
jan 9	1830	4.54	0.54
jan 10	230	2.67	0.59
jan 10	830	3.86	0.82
jan 10	930	3.37	0.99
jan 10	1030	2.59	0.28
jan 10	1300	3.40	1.37
jan 10	1900	6.98	0.12
jan 11	100	4.42	0.37
jan 11	700	3.31	2.25
jan 11	1300	3.84	1.63
jan 11	1900	4.24	0.37
jan 12	100	4.09	0.09
jan 12	700	5.03	0.58
jan 12	1000	2.20	
jan 12	1300	4.57	
jan 12	1900	3.29	0.26
jan 13	100	1.99	0.93
jan 13	700	3.53	0.32
jan 13	1230	2.46	0.36
jan 13	1530	1.84	0.37
jan 13	2130	2.35	1.07
jan 14	330	3.42	0.42
jan 14	930	3.25	0.99
jan 14	1100	3.60	0.67
jan 14	1400	4.00	0.30
jan 14	1700	3.87	0.13
jan 14	2000	4.65	0.44
jan 14	2300	3.49	0.54
jan 15	0	3.89	0.68
jan 15	500	3.32	0.91
jan 15	600	3.48	1.45
jan 15	1100	4.01	0.49

Table B3. Becks Ferry survey (Page 1 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
dec 28	100	4.41	
dec 28	300	2.57	
dec 28	500	3.30	
dec 28	1030	17.15	0.84
dec 28	1230	18.18	0.79
dec 28	1345	21.01	0.32
dec 28	1400	21.54	1.12
dec 28	1430	24.08	3.87
dec 28	1600	24.10	
dec 28	1630	24.82	0.54
dec 28	1700	23.84	1.08
dec 28	1830	28.32	4.41
dec 28	1900	27.10	0.53
dec 28	2030	28.51	0.78
dec 28	2100	30.82	2.95
dec 28	2230	34.83	1.31
dec 28	2300	38.98	1.05
dec 29	0	38.81	
dec 29	30	36.89	
dec 29	100	35.16	
dec 29	130	35.82	
dec 29	230	39.67	1.73
dec 29	330	39.07	
dec 29	430	42.12	3.60
dec 29	530	40.51	
dec 29	600	48.5	
dec 29	630	46.69	0.39
dec 29	700	49.3	
dec 29	730	46.63	
dec 29	730	50.6	
dec 29	900	45.14	1.34
dec 29	1030	45.49	
dec 29	1130	46.48	1.47
dec 29	1230	47.79	
dec 29	1330	49.78	0.25

Table B3. Becks Ferry survey (Page 2 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 29	1700	54.35	4.91
dec 29	1900	55.49	1.70
dec 29	2100	51.71	
dec 29	2100	50.9	
dec 29	2200	49.99	
dec 29	2300	52.54	3.85
dec 30		0	54.67
dec 30		100	55.37
dec 30	300	55.62	5.06
dec 30	500	56.17	
dec 30	700	53.65	
dec 30	700	52.0	
dec 30	900	46.76	
dec 30	1100	47.36	3.06
dec 30	1300	47.51	
dec 30	1300	49.2	
dec 30	1400	50.36	
dec 30	1400	46.9	
dec 30	1500	48.43	
dec 30	1500	46.6	
dec 30	1600	51.06	3.92
dec 30	1600	45.6	
dec 30	1700	51.6	
dec 30	1700	45.57	
dec 30	1800	47.15	
dec 30	1900	51.50	
dec 30	2000	50.21	3.83
dec 30	2100	45.6	
dec 30	2130	43.75	
dec 30	2200	52.99	1.93
dec 31	0	47.62	3.25
dec 31	200	48.11	
dec 31	400	52.41	1.87
dec 31	600	49.19	
dec 31	600	47.6	

Table B3. Becks Ferry survey (Page 3 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
dec 31	700	46.02	0.72
dec 31	900	47.29	2.98
dec 31	1000	47.83	
dec 31	1000	45.5	
dec 31	1100	47.07	
dec 31	1100	42.5	
dec 31	1200	46.84	0.32
dec 31	1200	42.5	
dec 31	1300	47.28	
dec 31	1300	42.5	
dec 31	1400	44.32	2.72
dec31	1400	43.8	
dec 31	1500	44.99	0.74
dec 31	1600	45.00	1.73
dec31	1700	39.22	
dec31	1800	42.88	
dec31	1900	38.7	
dec31	1900	39.77	1.8
dec3	2000	41.0	
dec31	2000	36.78	
dec31	2100	39.05	
dec31	2200	35.21	
dec31	2300	36.27	
jan 1	0	35.51	
jan 1	100	36.62	
jan 1	200	37.58	
jan 1	300	34.67	
jan 1	400	36.82	
jan 1	500	35.21	
jan 1	600	31.57	
jan 1	600	33.6	
jan 1	700	35.63	
jan 1	700	30.8	
jan 1	800	32.06	
jan 1	900	35.01	
jan 1	1000	29.84	

Table B3. Becks Ferry survey (Page 4 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 1	1100	28.35	
jan 1	1200	31.2	
jan 1	1200	30.43	
jan 1	1300	30.65	
jan 1	1400	32.65	
jan 1	1500	30.18	2.47
jan 1	1600	31.75	
jan 1	1700	29.60	
jan 1	1800	28.42	
jan 1	1900	30.44	
jan 1	2000	30.04	
jan 1	2200	28.64	
jan 2	100	24.67	
jan 2	300	27.0	
jan 2	400	24.43	1.58
jan 2	400	28.0	
jan 2	445	23.67	
jan 2	445	25.0	
jan 2	600	28.07	
jan 2	800	23.17	
jan 2	845	24.21	
jan 2	900	22.8	
jan 2	1000	23.07	1.15
jan 2	1000	20.7	
jan 2	1100	21.7	
jan 2	1200	21.52	
jan 2	1400	22.68	
jan 2	1600	19.64	
jan 2	1700	21.40	0.78
jan 2	1800	18.52	
jan 2	2000	19.09	
jan 2	2100	19.74	
jan 2	2200	17.22	
jan 2	2300	17.89	

Table B3. Becks Ferry survey (Page 5 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 3	0	16.61	2.33
jan 3	100	17.87	
jan 3	200	19.27	
jan 3	300	13.54	
jan 3	300	16.6	0.9
jan 3	400	18.42	
jan 3	400	15.8	0.5
jan 3	445	16.04	
jan 3	445	14.6	0.1
jan 3	600	15.35	0.56
jan 3	800	14.60	
jan 3	900	14.85	
jan 3	1000	16.51	
jan 3	1100	15.13	1.13
jan 3	1200	15.94	
jan 3	1300	14.25	
jan 3	1400	12.77	
jan 3	1500	14.97	
jan 3	1600	15.24	
jan 3	1700	12.26	0.52
jan 3	1700	12.7	
jan 3	1800	11.70	0.18
jan 3	1900	11.24	0.21
jan 3	2000	10.68	0.04
jan 3	2100	10.31	2.46
jan 3	2200	10.19	
jan 3	2300	11.48	0.16
jan 4	0	11.29	0.93
jan 4	100	11.70	
jan 4	200	9.78	0.59
jan 4	300	10.72	
jan 4	400	11.27	0.69
jan 4	500	10.68	0.74
jan 4	600	11.07	
jan 4	600	9.7	
jan 4	700	10.93	0.24

Table B3. Becks Ferry survey (Page 6 of 9)

<u>date</u>	<u>ime</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 4	700	7.4	
jan 4	800	9.02	
jan 4	900	8.05	
jan 4	1000	11.98	
jan 4	1100	7.75	
jan 4	1200	6.73	
jan 4	1300	8.71	0.05
jan 4	1400	8.62	
jan 4	1500	11.03	5.06
jan 4	1600	8.32	
jan 4	1700	8.78	0.66
jan 4	1700	8.4	
jan 4	1900	10.02	
jan 4	2000	8.07	0.83
jan 4	2100	6.89	1.03
jan 4	2200	8.63	
jan 4	2300	7.45	
jan 5	0	7.79	
jan 5	100	7.62	2.09
jan 5	300	8.36	
jan 5	400	7.38	
jan 5	500	6.85	1.11
jan 5	600	7.90	1.73
jan 5	700	7.38	
jan 5	700	8.4	
jan 5	800	8.32	
jan 5	900	7.65	0.16
jan 5	1000	5.45	
jan 5	1100	8.04	
jan 5	1200	6.42	
jan 5	1300	6.54	0.40
jan 5	1400	6.05	
jan 5	1700	6.18	
jan 5	1700	8.2	
jan 5	1800	6.08	0.84

Table B3. Becks Ferry survey (Page 7 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 5	1900	6.24	1.70
jan 5	2000	6.06	0.33
jan 5	2100	7.31	
jan 5	2200	5.89	0.35
jan 5	2300	6.35	1.49
jan 6	0	6.01	0.59
jan 6	100	5.89	0.91
jan 6	200	6.04	1.29
jan 6	300	6.82	1.51
jan 6	400	6.26	0.02
jan 6	500	5.65	1.02
jan 6	600	7.14	0.74
jan 6	600	7.0	
jan 6	700	7.03	1.32
jan 6	800	7.64	0.30
jan 6	900	6.74	0.07
jan 6	935	9.45	
jan 6	1500	5.67	0.28
jan 6	2100	5.26	0.81
jan 7	300	5.14	0.10
jan 7	400	5.77	0.60
jan 7	500	7.7	
jan 7	900	4.62	0.01
jan 7	945	6.16	0.21
jan 7	1000	6.14	1.23
jan 7	1500	5.41	0.51
jan 7	2100	6.40	1.26
jan 8	300	4.21	1.10
jan 8	515	5.1	
jan 8	900	6.62	4.31
jan 8	1300	4.44	1.03
jan 8	1900	3.76	0.62

Table B3. Becks Ferry survey (Page 8 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 9	100	4.51	0.64
jan 9	515	4.45	0.49
jan 9	515	3.6	
jan 9	700	4.67	0.23
jan 9	900	6.03	1.07
jan 9	2100	5.27	0.61
jan 10	100	7.52	
jan 10	700	8.1	
jan 10	900	6.02	1.70
jan 10	1300	5.22	
jan 10	1600	4.67	
jan 10	2045	4.27	
jan 10	2200	10.36	
jan 11	400	6.36	0.95
jan 11	1000	6.70	
jan 11	1700	5.10	0.27
jan 11	2300	3.49	0.40
jan 12	500	3.96	0.77
jan 12	500	nd	
jan 12	1300	2.12	0.59
jan 12	1900	3.93	0.16
jan 13	100	4.02	0.72
jan 13	700	2.79	0.34
jan 13	935	3.41	0.26
jan 13	935	2.9	
jan 13	1300	3.23	0.67
jan 13	1900	2.54	

Table B3. Becks Ferry survey (Page 9 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 14	100	3.20	0.93
jan 14	700	2.14	0.45
jan 14	700	2.8	
jan 14	1300	3.1	
jan 14	1900	2.1	0.73
jan 15	100	2.4	0.12
jan 15	1000	2.3	
jan 15	1600	2.4	0.28
jan 15	2200	2.8	1.00
jan 16	400	2.6	
jan 16	1000	3.2	0.64

Table B4. Beaufort-Jasper canal survey before lift station (Page 1 of 2)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u>
200 yds from river	jan 1	1253	29.32	
	jan 2	1300	24.70	
	jan 3	1230	20.07	
	jan 4	1335	16.19	1.30
	jan 4	1335	19.6	
	jan 5	1235	15.69	
	jan 5	1235	17.2	
	jan 6	1245	10.52	0.10
	jan 6	1245	11.7	
	jan 7	1015	5.19	0.32
	jan 7	1025	5.2	
	jan 8	1000	4.73	
	jan 8	1000	4.4	
	jan 8	1010	3.90	
400 yds from river	jan 1	1302	30.33	
	jan 2	1305	22.64	1.21
	jan 3	1235	20.70	0.71
	jan 4	1330	16.59	
	jan 4	1330	18.9	
	jan 5	1240	16.61	
	jan 5	1240	19.2	
	jan 6	645	14.07	
	jan 6	1250	13.71	
	jan 6	1250	15.3	
	jan 7	1020	9.16	1.02
	jan 7	1020	8.6	
	jan 8	1010	5.29	1.80

Table B4. Beaufort-Jasper canal survey before lift station (Page 2 of 2)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCl/mL</u>	<u>error</u>
end of canal at Black Ck.	jan 1	1315	6.87	
	jan 2	1315	16.86	0.30
	jan 3	1240	18.86	
	jan 4	1340	14.56	
	jan 4	1340	20.8	
	jan 5	1245	16.54	0.94
	jan 5	1245	17.6	
	jan 6	1250	15.40	0.67
	jan 6	1255	18.1	
	jan 7	1025	13.16	1.10
	jan 7	1025	12.7	
	jan 8	1015	7.6	
	jan 8	1015	6.83	2.65
100 yds before B-J Lift	jan 1	1320	4.86	0.45
	jan 2	1335	8.49	
	jan 3	1215	6.55	0.28
	jan 4	1310	8.03	1.22
	jan 4	1310	9.2	
	jan 5	1215	8.66	
	jan 5	1215	9.0	
	jan 6	1225	9.56	0.02
	jan 6	1300	9.8	
	jan 7	700	8.1	1.6
	Jan7	1050	14.62	0.80
	jan 7	1050	13.6	
	jan 8	640	8.27	
	jan 8	1035	7.56	1.39

Table B5. Beaufort-Jasper lift station survey (Page 1 of 4)

time date	mean midpoint	error pCi/mL	1 sigma
dec 28	100	3.66	1.07
dec 28	300	2.27	0.42
dec 28	500	2.62	0.96
dec 28	700	3.70	1.00
dec 28	900	4.12	0.62
dec 28	1100	3.86	0.15
dec 29	100	2.48	
dec 29	500	2.39	
dec 31	2130	1.48	
dec 31	2330	2.54	
jan 1	130	2.90	
jan 1	330	4.26	1.97
jan 1	530	3.21	
jan 1	730	1.47	
jan 2	1730	2.53	0.91
jan 2	2330	2.49	
jan 3	330	2.11	
jan 3	930	3.82	
jan 3	1330	2.47	
jan 3	1730	2.82	0.19
jan 3	2130	2.67	
jan 4	130	3.89	
jan 4	530	2.72	1.75
jan 6	100	7.2	
jan 6		300	9.51
jan 6	1200	6.6	1.6
jan 6		1225	8.72
jan 6	1430	9.5	
jan 6	1500	9.22	
jan 6	1600	9.99	1.53
jan 6	1700	9.82	0.23
jan 6	1800	10.50	
jan 6	1900	12.17	2.11
jan 6	2000	12.87	

Table B5. Beaufort-Jasper lift station survey (Page 2 of 4)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 6	2100	6.88	0.02
jan 6	2200	11.91	4.72
jan 6	2300	14.27	0.80
jan 7	0	15.13	2.98
jan 7	100	12.23	
jan 7	200	14.61	2.40
jan 7	300	13.20	0.21
jan 7	545	17.4	
jan 7	600	15.48	0.23
jan 7	700	13.66	0.91
jan 7	800	16.56	2.68
jan 7	900	17.43	0.59
jan 7	930	14.60	0.24
jan 7	1000	17.38	0.30
jan 7	1100	14.79	0.13
jan 7	1100	12.7	
jan 7	1200	13.00	
jan 7	1300	10.96	4.04
jan 7	1400	11.91	
jan 7	1500	12.11	1.61
jan 7	1600	13.13	1.84
jan 7	1700	11.03	1.92
jan 7	1900	11.22	3.06
jan 7	1955	10.84	2.18
jan 7	1955	12.0	0.8
jan 7	2000	10.51	0.69
jan 7	2100	10.97	0.23
jan 7	2200	10.21	
jan 8	0	12.14	
jan 8	100	11.71	
jan 8	200	10.21	0.83
jan 8	300	12.19	0.76
jan 8	400	10.59	1.45
jan 8	500	10.47	
jan 8	500	9.45	0.64
jan 8	525	9.28	0.37
jan 8	525	11.24	

Table B5. Beaufort-Jasper lift station survey (Page 3 of 4)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 8	525	9.7	0.1
jan 8	600	8.31	0.69
jan 8	700	8.88	
Jan 8	800	8.18	
jan 8	900	10.48	0.82
jan 8	1000	9.28	0.91
jan 8	1000	11.6	
jan 8	1200	9.46	2.63
jan 8	1400	7.55	2.02
jan 8	1600	7.26	1.34
jan 8	1755	12.0	0.7
jan 8	1800	7.84	0.02
jan 8	1900	8.56	0.97
jan 8	2000	8.87	
jan 8	2200	8.39	2.62
jan 9	0	6.99	0.11
jan 9	200	6.40	0.20
jan 9	400	6.71	0.78
jan 9	430	6.0	1.0
jan 9	530	5.5	0.0
jan 9	530	6.31	0.46
jan 9	600	6.19	0.27
jan 9	800	7.20	1.20
jan 9	1030	7.93	0.69
jan 9	1330	6.63	1.19
jan 9	1530	6.8	0.4
jan 9	1630	6.14	1.00
jan 10	300	5.80	0.28
jan 10	600	5.6	0.1
jan 10	1615	5.1	0.9
jan 11	300	4.54	1.03
jan 11	600	5.4	
jan 12	900	6.43	2.76
jan 12	900	3.0	
jan 12	1500	4.85	0.71
jan 12	2100	4.71	

Table B5. Beaufort-Jasper lift station survey (Page 4 of 4)

time date	mean midpoint	error pCi/mL	1 sigma
jan 13	300	3.73	1.18
jan 13	900	4.00	0.79
jan 13	950	5.61	
jan 13	950	3.6	
jan 13	1500	3.27	
jan 13	2100	3.40	0.62
jan 14	300	3.69	0.21
jan 14	300	3.2	
jan 14	900	3.26	0.62
jan 14	1500	4.08	
jan 14	2100	3.76	0.59
jan 15	300	4.47	0.81
jan 15	900	4.05	
jan 15	1500	2.91	0.47
jan 15	2100	2.40	
jan 16	300	3.39	0.28
jan 16	900	3.55	

Table B6. Beaufort-Jasper canal survey after lift station (Page 1 of 5)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u>
Highway 321 crossing	jan 7	815	4.9	0.5
	jan 7	815	3.14	0.84
	jan 8	710	14.0	
	jan 8	710	14.46	2.23
	jan 9	800	6.9	0.9
	jan 9	800	11.60	1.78
	jan 9	1530	12.43	0.08
	jan 9	1530	13.2	0.4
	jan 10	745	8.06	0.54
	jan 10	745	9.6	0.2
	jan 10	1645	6.56	1.53
	ian 11	810	6.73	1.06
	jan 11	1320	5.36	0.13
	ian 11	1320	8.3	0.6
	jan 11	1340	6.69	0.54
	jan 12	1200	7.69	4.26
between Hwy 321 and 17	jan 9	745	15.2	1.8
	jan 9	745	13.49	1.00
Highway 17 crossing	jan 7	745	2.9	1.3
	jan 7	745	1.92	0.34
	jan 8	640	1.2	
	jan 8	640	1.97	0.46
	jan 9	735	10.9	1.3
	jan 9	735	12.57	2.74
	jan 9	1500	13.52	0.57
	jan 9	1500	13.8	0.5

Table B6. Beaufort-Jasper canal survey after lift station (Page 2 of 5)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u>
Highway 17 crossing (cont)	jan 10	800	2.20	1.91
	jan 10	800	13.6	1.1
	jan 10	1700	11.18	1.20
	jan 11	840	7.34	1.78
	jan 11	1348	8.56	2.33
	jan 12	1215	6.09	0.59
	ian 12	1225	5.96	0.53
	ian 12	1225	6.1	
	jan 14	1320	3.77	0.69
	jan 14	1320	2.6	
	jan 12	1245	12.1	1.8
	jan 12	1245	13.44	0.18
2 miles before Hwy 278 (Jasper Rd.)	jan 14	1400	6.12	
	jan 14	1400	4.5	
Highway 278 crossing	jan 7	730	3.7	0.5
	jan 7	730	2.28	1.15
	jan 8	615	1.42	
	jan 9	625	2.27	0.92
	jan 9	1425	2.79	1.39
	jan 9	1425	2.8	0.2
	jan 10	830	13.68	0.37
	jan 10	1130	2.69	1.37
	jan 10	1130	2.2	0.9
	jan 10	1300	2.74	1.77
	jan 10	1300	2.1	0.2
	jan 10	1730	3.55	0.25
	ian 10	1730	1.4	0.6

Table B6. Beaufort-Jasper canal survey after lift station (Page 3 of 5)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u>
Highway 278 crossing (cont)	jan 11	915	1.7	0.8
	jan 11	915	1.71	0.10
	jan 11	1445	2.30	1.86
	jan 11	1445	1.9	0.2
	jan 11	1735	1.95	0.97
	jan 11	1735	3.8	0.5
	jan 12	600	9.83	1.15
	jan 12	740	2.81	0.12
	jan 12	740	3.1	0.6
	jan 12	1100	4.93	1.73
	jan 12	1100	4.6	0.6
	jan 12	1300	5.69	2.29
	jan 12	1300	5.0	0.2
	jan 12	1800	6.8	
	jan 13	730	13.49	0.85
	jan 13	730	15.2	
	jan 13	1328	10.70	0.08
	jan 13	1328	7.1	
	jan 13	1730	12.58	
	jan 13	1730	6.9	
	jan 14	705	8.55	0.04
	ian 14	705	6.5	
	jan 14	1145	7.34	0.41
	jan 14	1145	6.7	
	jan 14	1700	7.21	0.13
	jan 14	1700	4.3	
	jan 15	700	5.69	0.01
	jan 15	700	4.5	
	jan 15	1000	5.54	1.28

Table B6. Beaufort-Jasper canal survey after lift station (Page 4 of 5)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u>
Pond Entrance	jan 13	800	3.7	
	jan 13	825	2.08	0.92
	ian 13	830		3.48
	jan 13	1340	nd	
	jan 13	1340	3.07	0.18
	jan 13	1745	2.05	0.70
	jan 13	1745	nd	
	jan 14	715	9.47	1.30
	ian 14	715	7.4	
	jan 14	1200	9.88	0.08
	jan 14	1200	7.9	
	jan 14	1715	5.43	0.36
	ian 14	1715	3.8	
	jan 15	710	8.86	
	jan 15	710	7.3	
	jan 15	1015	6.93	
	jan 15	1150	9.91	3.44
	jan 15	1150	5.4	

Table B6. Beaufort-Jasper canal survey after lift station (Page 5 of 5)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u>
Pond Exit	jan 13	830	2.6	
	jan 13	1345	nd	
	jan 13	1345	4.02	
	jan 13	1750	1.06	0.01
	jan 13	1750	nd	
	jan 14	720	2.08	0.50
	jan 14	720	2.4	
	jan 14	1200	5.28	0.25
	jan 14	1200	5.6	
	jan 14	1720	4.56	
	jan 14	1720	3.3	
	jan 15	710	5.69	0.83
	ian 15	710	5.3	
	jan 15	1019	5.81	0.56
	jan 15	1019	5.2	
	jan 15	1150	4.5	
	jan 15	1155	6.64	

Table B7. Beaufort-Jasper plant intake survey (Page 1 of 3)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 28	0	2.61	0.23
dec 28	200	2.61	0.94
dec 28	400	2.35	0.81
dec 28	600	1.90	0.13
dec 28	800	2.58	1.47
dec 28	1000	1.81	0.18
dec 28	1200	2.00	1.04
jan 2	1200	0.83	
jan 2	1400	0.98	
jan 2	2000	0.46	
jan 3	200	0.13	
jan 3	800	0.59	0.77
jan 3	1400	0.11	
jan 3	1600	nd	
jan 3	1800	nd	
jan 3	2000	0.23	0.40
jan 3	2200	0.05	
jan 4	0	0.52	
jan 4	200	nd	
jan 4	400	0.04	
jan 4	600	0.90	
jan 4	800	0.13	0.22
jan 4	1000	1.13	
jan 4	1200	nd	
jan 4	1400	0.76	
jan 4	1600	0.02	
jan 4	1800	0.30	
jan 4	2000	0.54	0.02
jan 4	2200	0.21	
jan 5	0	0.25	
jan 5	200	0.21	
jan 5	400	0.34	

Table B7. Beaufort-Jasper plant intake survey (Page 2 of 3)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
jan 5	600	0.42	0.42
jan 5	800	nd	
jan 5	1000	0.73	
jan 5	1200	0.69	
jan 5	1400	0.04	
jan 5	1800	0.45	0.40
jan 5	2000	0.17	0.17
jan 5	2200	0.15	0.11
jan 6	0	0.13	0.13
jan 6	200	1.43	0.79
jan 6	600	0.33	0.57
jan 6	800	0.64	0.28
jan 6	1000	0.47	0.47
jan 6	1200	0.17	0.17
jan 6	1400	0.38	0.37
jan 6	1600	0.33	0.43
jan 6	1800	nd	nd
jan 6	2000	0.25	0.42
jan 6	2200	nd	
jan 7	0	nd	nd
jan 7	200	0.34	0.46
jan 7	400	0.57	0.78
jan 7	600	nd	nd
jan 7	800	0.48	0.24
jan 7	1000	1.18	1.64
jan 7	1200	0.89	1.02
jan 7	1400	0.37	0.39
jan 7	2000	1.35	2.25
jan 8	400	0.20	0.28
jan 8	1200	0.14	0.24
jan 8	1600	1.55	1.31

Table B7. Beaufort-Jasper plant intake survey (Page 3 of 3)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
jan 9	400	1.39	0.07
jan 9	1600	1.93	0.81
jan 10	0	2.37	0.79
jan 10	845	2.69	0.45
jan 11	1115	2.71	1.00
jan 12	1600	2.81	1.20
jan 12	2200	1.64	0.07
jan 13	400	1.71	0.34
jan 13	1000	1.09	0.29
jan 13	1600	2.34	0.25
jan 13	2200	2.38	0.93
jan 14	400	2.30	0.59
jan 14	1000	2.57	0.01
jan 14	1600	4.67	0.36
jan 14	2200	4.82	0.79
jan 15	720	2.45	0.88
jan 15	1030	4.81	1.99
jan 15	1200	4.08	0.47

Table B8. Beaufort-Jasper water treatment plant survey (Page 1 of 2)

<u>date</u>	<u>time</u>	Raw water		Finished water	
		mean <u>pCl/mL</u>	error <u>1 sigma</u>	mean <u>pCl/mL</u>	error <u>1 sigma</u>
26-Dec		2.39	0.22	3.58	2.04
27-Dec		1.14	0.42	1.32	0.18
28-Dec		0.54	0.26	2.15	0.24
29-Dec		0.65	0.91	1.37	0.16
30-Dec		1.54	0.29	1.34	0.50
31-Dec		1.32	0.23	0.97	0.20
01-Jan		1.98		1.55	0.45
02-Jan		0.50	0.51	1.52	0.16
03-Jan		0.92		1.88	2.66
04-Jan		0.28	0.30	0.25	0.35
05-Jan		nd	nd	nd	nd
06-Jan		0.32	0.45	2.66	3.10
07-Jan		nd	nd	0.59	0.83
16-Jan		7.80	0.17	7.08	
17-Jan	07:50	7.75	0.41	7.20	0.26
17-Jan	14:45	7.13	0.03	7.79	1.79

Table B8. Beaufort-Jasper water treatment plant survey (Page 2 of 2)

<u>date</u>	<u>time</u>	Raw Water		Finished Water	
		mean pCi/mL	error 1 sigma	mean pCi/mL	error 1 sigma
18-Jan	00:30	7.46	0.08	5.57	0.37
18-Jan	08:30	6.10	0.51	6.46	0.85
19-Jan	00:01	5.72	0.42	5.02	0.71
19-Jan	08:30	4.23	5.06	0.70	
20-Jan	07:30	3.45	3.95	0.40	
21-Jan	07:40	4.28	0.70	4.93	0.42
22-Jan	07:45	4.87	0.39	4.59	0.38
22-Jan	21:00	4.68	0.27	4.63	0.49
23-Jan	08:00	3.99	1.26	5.03	0.75
24-Jan	08:10	3.91	1.03	4.17	0.22
25-Jan	07:25	4.13	0.21	3.82	0.26
26-Jan	07:45	3.91	0.41	3.69	0.64
27-Jan	07:30	3.34	0.14	3.45	0.82

Table B9. Abercorn Creek Survey (Page 1 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCl/mL</u>	<u>error 1 sigma</u>
dec 28	0	2.68	0.75
dec 28	100	2.61	0.01
dec 28	200	3.05	0.01
dec 28	300	3.50	0.83
dec 28	400	3.07	1.20
dec 28	500	2.50	0.34
dec 28	600	3.25	0.25
dec 28	700	2.95	1.07
dec 28	800	2.25	0.40
dec 28	900	2.36	0.28
dec 28	1000	2.32	0.21
dec 28	1100	1.95	0.22
dec 28	1200	2.30	0.25
dec 28	1300	6.06	0.04
dec 28	1400	7.32	1.72
dec 28	1530	14.09	
dec 28	1630	6.13	
dec 28	1730	7.41	
dec 28	1930	5.00	0.70
dec 28	2000	3.58	0.76
dec 28	2130	1.09	1.00
dec 28	2330	1.46	0.48
dec 29	0	1.71	0.11
dec 29	130	13.84	0.47
dec 29	330	23.13	1.51
dec 29	400	24.55	0.67
dec 29	430	25.27	
dec 29	500	20.92	
dec 29	530	24.39	
dec 29	600	22.41	0.81
dec 29	630	26.26	
dec 29	700	23.30	0.06
dec 29	800	17.86	0.06
dec 29	900	5.50	
dec 29	1000	2.84	0.07

Table B9. Abercorn Creek Survey (Page 2 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
dec 29	1030	1.59	
dec 29	1130	1.26	
dec 29	1230	1.80	
dec 29	1330	1.42	
dec 29	1430	35.30	
dec 29	1530	40.26	
dec 29	1630	43.25	
dec 29	1730	44.92	
dec 29	1830	41.15	
dec 29	1900	32.90	
dec 29	1930	18.28	
dec 29	2000	9.58	
dec 29	2300	2.77	0.39
dec 30	0	1.98	
dec 30	100	1.56	
dec 30	200	6.74	
dec 30	400	50.34	
dec 30	600	51.25	2.54
dec 30	800	49.04	
dec 30	1000	7.20	
dec 30	1000	8.70	
dec 30	1030	4.03	
dec 30	1230	2.81	
dec 30	1330	2.81	2.41
dec 30	1430	6.20	
dec 30	1430	10.68	
dec 30	1430	11.80	
dec 30	1530	49.59	
dec 30	1630	49.14	
dec 30	1730	52.73	
dec 30	1900	44.94	
dec 30	1930	27.60	
dec 30	2030	29.16	
dec 30	2100	16.89	
dec 30	2200	6.40	2.12
dec 30	2300	3.28	

Table B9. Abercorn Creek Survey (Page 3 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
dec 31	000	5.47	
dec 31	100	5.01	
dec 31	200	3.44	0.51
dec 31	230	7.22	
dec 31	300	28.77	2.93
dec 31	400	42.50	
dec 31	400	43.30	
dec 31	500	49.56	0.37
dec 31	500	39.70	
dec 31	600	45.79	1.75
dec 31	600	40.50	
dec 31	700	39.19	8.67
dec 31	700	41.30	
dec 31	800	45.97	
dec 31	900	50.12	4.19
dec 31	1000	44.59	
dec 31	1100	31.55	
dec 31	1200	13.59	0.88
dec 31	1300	8.51	
dec 31	1400	8.42	
dec 31	1500	18.31	
dec 31	1530	31.74	1.32
dec 31	1600	38.40	
dec 31	1700	43.93	
dec 31	1800	47.15	0.18
dec 31	1900	48.55	
dec 31	2000	43.46	
dec 31	2100	42.56	
dec 31	2200	23.33	
dec 31	2200	26.80	
dec 31	2300	12.02	
dec 31	2300	13.30	
jan 1	0	8.30	
jan 1	100	12.33	
jan 1	200	11.36	

Table B9. Abercorn Creek Survey (Page 4 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 1	300	19.90	
jan 1	400	38.34	
jan 1	600	39.49	
jan 1	700	36.93	
jan 1	800	38.46	
jan 1	1000	39.24	
jan 1	1200	34.88	1.87
jan 1	1400	14.29	0.06
jan 1	1500	15.60	
jan 1	1600	18.79	
jan 1	1700	32.46	0.01
jan 1	1800	30.11	
jan 1	1900	34.10	
jan 1	2200	34.44	
jan 2	100	19.09	
jan 2	400	15.61	1.97
jan 2	400	15.70	
jan 2	445	21.31	
jan 2	445	29.10	
jan 2	500	29.85	
jan 2	700	31.25	2.45
jan 2	900	34.38	
jan 2	1000	28.55	
jan 2	1100	31.74	
jan 2	1300	29.87	1.31
jan 2	1330	22.11	
jan 2	1500	21.67	
jan 2	1600	22.18	
jan 2	1700	23.90	
jan 2	1900	26.64	
jan 2	1900	23.54	1.34
jan 2	2000	26.02	
jan 2	2200	24.82	
jan 2	2300	23.29	

Table B9. Abercorn Creek Survey (Page 5 of 9)

<u>date</u>	<u>time midpoint</u>	<u>mean pCi/mL</u>	<u>error 1 sigma</u>
jan 3	100	26.22	
jan 3	200	24.20	
jan 3	400	25.35	
jan 3	445	25.96	
jan 3	600	19.53	
jan 3	800	20.45	
jan 3	1000	19.11	0.85
jan 3	1200	19.17	3.45
jan 3	1300	19.13	
jan 3	1400	20.32	
jan 3	1500	24.01	
jan 3	1600	23.64	3.46
jan 3	1700	24.99	
jan 3	1800	20.70	
jan 3	1900	19.06	
jan 3	2000	14.76	2.11
jan 3	2100	13.59	
jan 3	2200	15.00	
jan 3	2300	15.44	
jan 4	0	18.35	
jan 4	100	20.94	
jan 4	200	23.62	
jan 4	300	23.65	
jan 4	400	22.73	
jan 4	500	23.53	
jan 4	600	9.84	5.39
jan 4	700	6.09	0.92
jan 4	800	11.00	
jan 4	800	11.26	1.22
jan 4	900	11.90	
jan 4	1000	12.67	
jan 4	1100	12.40	
jan 4	1200	9.58	0.40
jan 4	1300	12.36	
jan 4	1400	15.04	

Table B9. Abercorn Creek Survey (Page 6 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 4	1500	19.30	0.86
jan 4	1500	21.40	
jan 4	1600	18.61	3.67
jan 4	1700	18.14	
jan 4	1800	15.42	5.28
jan 4	1900	21.12	
jan 4	2000	8.34	
jan 4	2100	8.16	0.25
jan 4	2200	9.05	
jan 4	2300	7.39	
jan 5	0	7.41	
jan 5	100	11.44	
jan 5	200	17.47	0.78
jan 5	300	16.87	
jan 5	400	10.00	0.54
jan 5	500	20.10	
jan 5	500	20.69	
jan 5	600	16.43	0.66
jan 5	700	17.40	
jan 5	700	16.50	
jan 5	800	17.21	
jan 5	900	8.40	
jan 5	900	7.88	
jan 5	1000	9.31	
jan 5	1100	7.69	0.51
jan 5	1200	6.14	
jan 5	1300	7.09	
jan 5	1400	8.58	
jan 5	1600	17.58	
jan 5	1800	16.79	
jan 5	2000	8.66	0.34
jan 5	2200	6.17	
jan 6	0	6.48	
jan 6	200	10.40	0.23
jan 6	300	17.00	2.36

Table B9. Abercorn Creek Survey (Page 7 of 9)

<u>date</u>	<u>time</u> <u>mi./point</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 6	400	15.59	
jan 6	500	14.30	
jan 6	600	12.42	
jan 6	800	5.98	0.85
jan 6	1000	7.43	0.81
jan 6	1200	7.86	1.43
jan 6	1400	6.86	0.15
jan 6	1600	12.81	1.41
jan 6	1800	11.37	0.74
jan 6	2000	12.10	0.87
jan 6	2200	10.15	
jan 7	0	8.73	
jan 7	200	8.66	1.09
jan 7	400	11.80	1.17
jan 7	430	11.49	1.65
jan 7	600	11.83	3.52
jan 7	800	6.81	0.30
jan 7	1000	5.81	2.11
jan 7	1200	6.34	1.06
jan 7	1300	5.10	0.23
jan 7	1500	5.76	0.84
jan 7	1700	9.91	0.63
jan 7	1900	8.43	1.44
jan 7	2100	6.58	1.14
jan 7	2300	5.23	
jan 8	100	4.53	1.20
jan 8	300	6.83	1.90
jan 8	440	10.40	
jan 8	500	10.65	2.69
jan 8	700	8.49	1.56
jan 8	900	5.56	0.11
jan 8	1100	5.00	0.87
jan 8	1300	4.41	0.25
jan 8	1500	5.35	1.05

Table B9. Abercorn Creek Survey (Page 8 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 8	1700	7.28	
jan 8	1900	8.09	2.33
jan 8	2100	9.11	0.95
jan 8	2300	3.72	1.84
jan 9	100	3.03	0.57
jan 9	300	4.59	1.44
jan 9	400	8.36	
jan 9	400	8.19	1.12
jan 9	435	7.99	1.39
jan 9	700	6.57	0.21
jan 9	900	6.37	0.79
jan 9	1100	4.27	1.27
jan 9	1500	4.69	1.20
jan 9	2100	7.87	1.62
jan 10	300	5.53	0.21
jan 10	900	7.14	2.67
jan 10	1927	6.09	2.68
ian 11	139	5.09	0.28
jan 11	751	6.25	0.70
jan 11	1404	6.49	0.45
jan 11	2016	6.17	0.28
jan 12	18	5.83	0.42
jan 12	630	5.10	0.08
jan 12	1453	3.08	0.19
jan 12	2105	4.04	0.36
jan 13	317	3.72	0.92
jan 13	929	4.25	0.64
jan 13	1541	3.15	0.59
jan 13	1600	3.70	
jan 13	2135	1.84	0.57

Table B9. Abercorn Creek Survey (Page 9 of 9)

<u>date</u>	<u>time</u> <u>midpoint</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 14	405	2.04	0.45
jan 14	1017	0.47	0.51
jan 14	1630	0.85	0.38
jan 14	2242	0.11	0.14
jan 15	454	1.97	0.42
jan 15	1106	0.67	0.38

Table B10. Port Wentworth water treatment plant survey (Page 1 of 2)

<u>date</u>	<u>time</u>	Raw water		Finished water	
		mean <u>pCi/mL</u>	error <u>1 sigma</u>	mean <u>pCi/mL</u>	error <u>1 sigma</u>
dec 30	1515	2.45		38.31	
dec 30	2010	46.34		15.11	
dec 31	0915	44.94	3.47	14.25	1.72
dec 31	1600	6.86		34.45	
dec 31	2115	8.75		22.00	
jan 1	1450	23.70		26.76	
jan 2	945	18.97		21.02	
jan 2	1415	29.70		25.55	
jan 3	730	24.29		24.79	
jan 3	1400	18.70		23.23	
jan 3	1930	22.86	0.45	20.26	0.78
jan 4	800	23.74	0.93	20.16	0.45
jan 4	1420	11.90	0.87	21.93	0.14
jan 4	2015	18.68	0.47	16.68	1.24
jan 5	745	17.31	2.07	15.30	
jan 5	1330	18.79	3.90	17.62	0.11
jan 6	645	7.30		11.00	
jan 6	645	8.6		9.8	
jan 7	1225	4.80	1.05	10.57	1.45
jan 7	1900	3.91			
jan 7	1930	10.87	0.18		
jan 8	1225	5.53	0.15	7.81	1.21

Table B10. Port Wentworth water treatment plant survey (Page 2 of 2)

		Raw Water		Finished Water	
<u>date</u>	<u>time</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>	<u>mean</u> <u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
jan 9	1150	6.47	0.25	4.29	0.14
jan 9	1900	6.13		6.36	0.49
jan 10	1045	6.05	1.34	6.41	1.07
jan 10	1515	6.85	0.95	6.95	0.86
jan 10	2015	5.68	0.23	5.66	1.65
jan 11		6.17	0.54	6.21	0.93
jan 11	1030	3.15	2.45	6.21	0.93
jan 12		5.25	1.12	6.21	0.93
jan 13	1540			6.3	
jan 13	1540	3.93	0.18	5.28	1.32
jan 14	1000	3.7			
jan 14	1615	1.28	1.70	1.77	0.87
jan 14	2125	3.35	0.33	3.11	0.58
jan 15	720			2.8	
jan 15	1030			4.4	
jan 15	1200			2.7	

Table B11. Estuarine study (Page 1 of 6)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCl/mL</u>	<u>error</u> <u>1 sigma</u>
Fort Pulaski	dec 31	12:30	2.57	0.27
	dec 31	20:30	2.29	
	jan 1	00:30	4.06	
	jan 1	04:30	1.43	
	jan 1	08:30	0.37	
	jan 1	12:30	6.71	
	jan 1	16:30	4.07	
	jan 1	20:30	3.60	0.47
	jan 2	00:30	10.77	
	jan 2	04:30	5.96	
	jan 2	08:30	8.85	
	jan 2	12:30	0.45	0.09
	jan 2	14:45	14.27	1.92
	jan 2	16:30	8.53	
	jan 2	20:30	10.20	
	jan 3	00:30	0.84	0.07
	jan 3	04:30	9.96	
	jan 3	08:07	3.36	
	jan 3	08:30	0.82	0.48
	jan 3	10:30	4.72	0.20
	jan 3	12:30	4.73	
	jan 3	14:30	13.54	0.57
	jan 3	16:30	11.43	
	jan 3	18:30	3.30	0.13
	jan 3	20:30	3.15	
	jan 3	22:30	8.72	0.49
	jan 4	00:30	13.55	3.65
	jan 4	02:30	16.46	
	jan 4	04:30	14.01	
	jan 4	06:30	3.45	1.22
	jan 4	08:30	3.61	
	jan 4	10:30	1.73	0.51
	jan 4	11:25	8.28	0.13
	jan 4	12:30	12.18	0.13

Table B11. Estuarine study (Page 2 of 6)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCl/mL</u>	<u>error</u> <u>1 sigma</u>
Fort Pulaski (cont)	jan 4	14:30	15.50	1.25
	jan 4	16:30	16.87	1.07
	jan 4	18:30	7.40	0.16
	jan 4	20:30	5.48	2.02
	jan 4	22:30	7.38	0.51
	jan 5	00:30	11.34	1.08
	jan 5	02:30	15.98	0.18
	jan 5	04:30	14.63	0.69
	jan 5	06:30	3.74	1.23
	jan 5	08:30	5.35	0.39
	jan 5	10:30	3.85	0.79
	jan 5	12:30	10.32	1.38
	jan 5	14:30	14.51	0.25
	jan 5	16:30	14.11	1.78
	jan 5	18:30	7.55	0.42
	jan 5	20:30	5.33	0.61
	jan 5	22:30	5.17	0.11
	jan 6	02:30	13.99	0.24
	jan 6	04:30	4.50	0.97
	jan 6	06:30	8.41	2.47
	jan 6	08:30	5.21	1.77
	jan 6	10:30	3.06	0.17
	jan 6	11:30	3.57	0.23
	jan 6	11:40	2.86	0.29
	jan 6	13:30	12.16	0.57
	jan 6	19:30	4.32	0.48
	jan 6	23:30	8.13	0.07
	jan 7	03:30	12.83	1.31
	jan 7	07:30	6.98	1.11
	jan 7	11:30	4.41	0.24
	jan 7	15:30	11.34	0.74
	jan 7	19:30	8.59	
	jan 7	23:30	6.42	0.13
	jan 8	03:30	11.00	0.13
	jan 8	07:30	8.11	2.52
	jan 8	11:30	2.54	0.94
	jan 8	15:30	9.43	1.72

Table B11. Estuarine study (Page 3 of 6)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCl₂/L</u>	<u>error 1 sigma</u>
Fort Pulaski (cont)	jan 8	17:30	10.5	
	jan 8	17:35	8.96	0.74
	jan 8	22:09	4.07	0.08
	jan 9	04:21	9.19	0.38
	jan 9	10:28	3.08	0.74
	jan 9	16:45	10.49	1.75
	jan 9	22:57	4.54	0.50
	jan 10	05:09	8.04	0.01
	jan 10	11:21	5.69	0.60
	jan 10	17:33	7.02	0.35
	jan 10	23:45	3.75	0.64
	jan 11	05:57	6.91	0.09
	jan 11	12:09	4.14	0.61
	jan 11	18:21	6.27	0.40
	jan 12	00:33	2.92	0.24
	jan 12	06:45	4.46	0.28
	jan 12	12:57	3.01	1.37
	jan 12	19:09	4.84	0.98
	jan 13	01:21	2.13	0.18
	jan 13	07:33	3.79	0.32
	jan 13	13:45	3.28	0.64
	jan 13	19:57	4.12	0.66
	jan 14	02:09	1.45	0.06
	jan 14	08:21	3.62	1.12
	jan 14	14:33	2.44	0.81
	jan 14	20:45	4.01	0.04
	jan 15	02:57	1.83	0.41
	jan 15	09:09	3.15	0.36

Table B11. Estuarine study (Page 4 of 6)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCl/mL</u>	<u>error 1 sigma</u>
Priest Landing	jan 2	12:15	0.73	
	jan 4	10:25	nd	nd
	jan 6	13:30	nd	nd
	jan 6	19:00	1.48	
	jan 6	23:00	4.24	
	jan 7	07:00	0.89	
	jan 7	11:00	1.30	
	jan 8	16:53	1.35	0.29
	jan 8	22:09	nd	
	jan 9	04:21	0.68	0.35
	jan 9	10:33	0.24	
	jan 9	16:45	0.81	
	jan 9	22:57	2.08	
	jan 10	05:09	0.58	
	jan 10	11:21	0.87	1.23
	jan 10	17:33	2.10	
	jan 10	23:45	11.43	
	jan 11	05:57	2.56	
	jan 11	12:09	0.24	0.06
	jan 11	18:21	1.21	
	jan 12	00:33	0.86	
	jan 12	06:45	1.69	0.44
	jan 12	12:57	0.57	
	jan 12	19:09	1.15	0.81
	jan 13	01:21	3.32	
	jan 13	07:33	1.69	
	jan 13	13:45	0.55	
	jan 13	14:09	0.26	0.06
	jan 13	19:57	3.52	

Table B11. Estuarine study (Page 5 of 6)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error 1 sigma</u>
Priest Landing (cont)	jan 14	08:21	1.05	
	jan 14	14:33	0.53	0.22
	jan 14	20:45	1.22	
	jan 15	02:57	1.16	
	jan 15	09:09	1.07	
	jan 15	15:21	0.25	0.35
Skidaway Institute	jan 2	12:00	1.82	
	jan 3	12:06	1.07	
	jan 4	10:07	1.44	0.64
	jan 5	03:00	1.21	0.40
	jan 5	07:00	1.19	
	jan 5	11:00	1.19	0.27
	jan 5	15:00	0.58	0.81
	jan 5	19:00	1.68	
	jan 5	23:00	0.67	0.56
	jan 6	03:00	1.02	0.30
	jan 6	07:00	1.34	
	jan 6	11:00	0.86	1.17
	jan 6	14:00	1.15	
	jan 6	15:00	1.54	0.11
	jan 6	19:00	1.26	
	jan 6	23:00	1.35	
	jan 7	03:00	1.32	0.12
	jan 7	07:00	1.32	
	jan 7	11:00	nd	
	jan 7	15:00	2.01	0.04
	jan 7	19:00	2.62	0.99
	jan 7	23:00	0.70	0.13
	jan 8	03:00	1.86	
	jan 8	07:00	2.50	0.19
	jan 8	11:00	0.64	
	jan 8	15:00	1.36	0.08

Table B11. Estuarine study (Page 6 of 6)

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>error</u> <u>1 sigma</u>
Thunderbolt	jan 2	1525	7.67	0.98
	jan 4	1230	8.44	0.02
	jan 6	1200	8.77	0.34
	jan 15	1645	2.89	0.15
LazarettoCreek	jan 3	710	3.97	
	jan 6	1600	6.81	1.55
	jan 8	1750	9.47	0.65
	jan 15	17:50	3.53	1.05

Table B12. Estuarine survey

<u>location</u>	<u>date</u>	<u>time</u>	<u>pCi/mL</u>	<u>1</u>	<u>error</u> <u>sigma</u>
Estuary South (sweep)	jan 3	1125	nd		
	jan 3	1140	nd		
	jan 3	1146	0.53		0.39
	jan 3	1206	nd		
	jan 3	1212	1.38		
	jan 3	1230	7.48		0.59
	jan 3	1247	11.52		0.36
	jan 3	1253	11.76		2.00
	jan 3	1259	12.85		0.27
	jan 3	1620	13.53		0.94
Savannah River (sweep)	jan 3	1335	25.69		0.86
	jan 3	1345	26.72		0.59
	jan 3	1357	25.19		0.66
	jan 3	1403	23.00		
	jan 3	1418	14.57		0.35
	jan 3	1423	11.85		
	jan 3	1430	13.12		
	jan 3	1440	8.96		
EstuaryNorth (sweep)	jan 3	1500	0.87		0.15
	jan 3	1503	0.85		
	jan 3	1518	0.82		0.78
	jan 3	1525	nd		

Table B13. Tritium concentrations measured in the Savannah River (values are calculated daily averages of hourly measured concentrations).

<i>__Daily Average Measured Concentrations (pCi/mL)__</i>		
Date	Hwy 301 Bridge	Beaufort-Jasper Becks Ferry
Dec 22	2.4	
Dec 23	3.0	
Dec 24	2.6	
Dec 25	3.8	
Dec 26	36.9	
Dec 27	56.3	
Dec 28	55.5	22.0
Dec 29	45.7	45.8
Dec 30	33.3	49.8
Dec 31	22.2	43.8
Jan 1	15.4	32.3
Jan 2	9.5	22.6
Jan 3	9.6	14.3
Jan 4	6.6	9.6
Jan 5	5.0	6.8
Jan 6	4.0	6.5
Jan 7	5.1	6.0
Jan 8	7.0	4.0
Jan 9	6.5	4.8
Jan 10	3.8	6.0
Jan 11	4.2	5.3
Jan 12	3.8	3.3
Jan 13	2.6	3.1
Jan 14	3.8	2.6
Jan 15	3.8	3.1

Table B14. Savannah River transport of K-Reactor tritium based on results for the Highway 301 bridge*.

Date	Estimated River Flow, Hwy 301 (cfs)	Daily Transport (Ci)	Cumulative Transport (Ci)
Dec 22, 1991	8981	0	0
Dec 23	6985	0	0
Dec 24	6876	0	0
Dec 25	7135	12	12
Dec 26	7506	621	633
Dec 27	7698	1000	1633
Dec 28	7929	1020	2653
Dec 29	8709	908	3561
Dec 30	8923	659	4220
Dec 31	9101	425	4645
Jan 1, 1992	9113	343	4988
Jan 2	8894	139	5127
Jan 3	8451	134	5261
Jan 4	8590	74	5335
Jan 5	8007	37	5372
Jan 6	8208	18	5390
Jan 7	7824	38	5428
Jan 8	9127	87	5515
Jan 9	9388	78	5593
Jan 10	8527	15	5608
Jan 11	7857	21	5629
Jan 12	8361	14	5643
Jan 13	8327	0	5643
Jan 14	8110	14	5657
Jan 15	9681	17	5674

*The 5-year average tritium concentration at Hwy 301 is 3.1 pCi/mL.

This page intentionally left blank

Appendix C

Quality Assurance

This page intentionally left blank

Quality Assurance

Quality control charts showing the counting results of spike and blank samples prepared with each batch of samples are shown in Figures C2 and C3 of Appendix C. The photo-multiplier tube (PMT) in the Tri-Carb counter failed on January 15 (after blank number 149 and spike number 121). All samples collected prior to the failure had at least one count completed before the PMT failure. After a replacement PMT was installed, greater variability in the blank count rates was apparent, however, the average blank count rate remained the same, within counting uncertainty. Blank number 191 (196 dpm) was excluded from the running average (the line shown in Figure C3, Appendix C).

If the quench correction had no uncertainty associated with it, the expected spike activity would be 6613 dpm (the solid line in Figure C2, Appendix C). This is based on the NIST certified value of the standard. Prior to the PMT failure, recovery of the spike (dpm measured/dpm expected) averaged 1.04, implying that activity in the water samples may have been overestimated by 4%. After the PMT was replaced, spike recovery was significantly higher: Figure C2 shows that the measured sample activity may have been overestimated by up to 20%. However, counting uncertainties (Fig. C1) were greater than 20% for samples counted after the PMT replacement. This was due to the low tritium concentrations at that time. The large counting uncertainties effectively masked the bias in the quench correction.

This page intentionally left blank

Predicted Counting Statistics in LSC Analysis of Tritium in Water

Figure C1

Figure C1. Typical uncertainties in the LSC

Figure C2. Spike results

Blank Results

Figure C3. Blank results

This page intentionally left blank

Appendix D

Tritium Transport in the Savannah River

This page intentionally left blank

Figure D2. December 26 – 27, 1991

Figure D3. December 31, 1991 – January 1992

Figure D5. January 9 – 10, 1992

**EMERGENCY RESPONSE MONITORING ACTIVITIES AND ENVIRONMENTAL IMPACT
OF THE K-REACTOR AQUEOUS TRITIUM RELEASE OF DECEMBER 1991 (U)**

DISTRIBUTION

R.P. Addis, 773A
D.M. Beals, 735A
R.T. Begley, 773A
A.L. Boni, 773A
W.J. Brumley, 703A
J.R. Cadieux, 735-7A
R.R. Campbell, 703A
W.H. Carlton, 773A
T.V. Crawford, 773A
L. Davis, 703-41A
T.S. DeHart, 735A
P. Dickson, 773A
D.L. Dunn, 735A
A.J. Garrett, 773A
G. Hall, 735A
J.E. Halverson, 735A
D.M. Hamby, 773A
D.W. Hayes, 773A
T.F. Heenan, 703A
J.D. Heffner, 735A
J.N. Herrmann, 703A
C.H. Hunter, 773A
M.V. Kantelo, 735A
J.A. Lazzaro, 742-3A
R. Lorenz, 735-16A
F.R. McCoy, 703-41A
D.B. Moore-Shedrow, 773A
L.M. Papouchado, 773A
W.C. Reinig, 742A
P.D. Rice, 703A
J.S. Roberts, 742A
S.J. Smith, 704K
D.A. Stevenson, 735A
R.W. Taylor, 735A
A.L. Towns, 773-41A
R.A. Walker, 703A
D. Woodward, 735-15A
S.R. Wright, 703-41A
R.H. Young, 735-11A
D.N. Zweifel, 703-41A
EDG Files (10)
SRL Files (4)

END

**DATE
FILMED**

7 / 15 / 92