PREDICTIVE MODELLING OF BOILER FOULING**QUARTERLY TECHNICAL PROGRESS REPORT**

For The Period

October 1, 1990 - December 31, 1990

Date Prepared

February 1990

Prepared by

AVCO RESEARCH LABORATORY
2385 REVERE BEACH PARKWAY
EVERETT, MASSACHUSETTS 02149

Prepared for

U.S. DEPARTMENT OF ENERGY

PITTSBURGH ENERGY TECHNOLOGY CENTER
PITTSBURGH, PENNSYLVANIA 15236

UNDER CONTRACT NO. DE-AC22-90PC90098

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

cy 4th Qtr 90

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

ACQUISITION & ASSISTANCE DIV.

91 FEB 21 AM 11:03

RECEIVED
USDOE/PETC

TABLE OF CONTENTS

	<u>Page No.</u>
1.0 PROGRAM OBJECTIVE AND SCOPE OF WORK	1
2.0 SUMMARY OF PROGRESS TO DATE	4
3.0 TECHNICAL PROGRESS	6
3.1 Spatial Discretization	7
3.2 Temporal Discretization	14
3.3 Solution Methods	16
3.4 Method Tradeoff	17
3.5 ReNormalization Group Treatment of Turbulent Flows	19
4.0 CONCLUSION AND PLANS FOR FUTURE WORK	22
4.1 Conclusions to Date	22
4.2 Plan for Next Reporting Period	22

1.0 PROGRAM OBJECTIVE AND SCOPE OF WORK

The primary objective of this work is the development of a comprehensive numerical model describing the time evolution of fouling under realistic heat exchanger conditions. As fouling is a complex interaction of gas flow, mineral transport and adhesion mechanisms, understanding and subsequently improved controlling of fouling achieved via appropriate manipulation of the various coupled, nonlinear processes in a complex fluid mechanics environment will undoubtedly help reduce the substantial operating costs incurred by the utilities annually, as well as afford greater flexibility in coal selection and reduce the emission of various pollutants. In a more specialized context, the numerical model to be developed as part of this activity will be used as a tool to address the interaction of the various mechanisms controlling deposit development in specific regimes or correlative relationships. These should prove of direct use to the coal burning industry.

The Statement of Work comprises a series of related and logically structured tasks described as follows:

Phase I

Task 1

Perform semi-quantitative evaluations of solution and algorithmic details of Higher Level Simulation (HLS) techniques applicable to flow in and around a tube bundle.

Task 2

Assess (quantitatively) HLS predictions for flow and turbulence characteristics of related, simpler problems.

Task 3

Reformulate the algorithm to predict flow details around a cylinder in an isothermal, but otherwise representative environment.

Task 4

Predict heat transfer characteristics for the problem in Task 3.

Task 5

Generalize the algorithm to predict flow, turbulence and heat transfer details for multi-tube configurations including in line and staggered arrangements.

Task 6

Provide project management and financial control with the required technical and financial reports and documentation.

Phase II

Task 1

Develop an appropriate multi-phase, multi-species transport algorithm for a "frozen" gas aerothermal field.

Task 2

Develop sub-modules for surface related processes including adherence and removal.

Task 3

Provide project management and financial control with the required technical and financial reports and documentation.

Phase III

Task 1

Extend the algorithm to couple multi-species, multi-phase transport and deposition models with a comprehensive HLS of flow and heat transfer in a tube bundle for a representative case.

Task 2

Perform pertinent parameter variation studies and develop improved engineering correlations to model fouling in practical boiler configurations and operating environments.

Task 3

Provide project management and financial control with the required technical and financial reports and documentation.

2.0 SUMMARY OF PROGRESS TO DATE

As the work breakdown in this effort was envisaged to be of a sequential nature, the effort in this reporting period was concentrated primarily on adequately evaluating the various solution and algorithmic details of Higher Level Simulation (HLS) techniques applicable to flow in a tube bundle to guide the rest of the Phase I effort. In the past, such techniques have been used primarily to resolve the mean flow and lower moments in geometrically simple configurations including the flat plate, channel flow, flow between Taylor cylinders, and hence applications involving physical and configurational complexity comparable to those in a typical tube bundle are rare. Thus such concerns bring forth issues related to applicability, as well as specific levels of resolution required of flow and turbulence characteristics for use in the description of the various physicochemical processes involved. Such issues, along with the more conventionally available alternative approaches were studied to delineate critical accuracy bounds for the fluid mechanics description, and to further establish comparable criteria to describe adequately the various physicochemical processes involved.

To accomplish this critical comprehensive evaluation of the currently available numerical techniques, dialogues were established with several prominent members of the CFD community including Parviz Moin of Stanford, Tayfun Tezduyar of the University of Minnesota and George Karniadakis of Princeton. These experts and their associated groups have considerable prior experience in the application of such techniques to study detailed turbulent flow physics in related geometries. Specifically, George Karniadakis of the Program in Applied and Computational Mathematics of Princeton along with Steve Orszag who directs the program, have in the past pioneered the development and application of advanced numerical techniques to adequately resolve fundamental flow physics both in simple and practical geometries.

It was concluded at the end of the evaluation effort that HLS techniques are extremely computationally intensive and provide very detailed spatial, temporal resolution (at least for the problems studied) and hence require comparable computational descriptions for the remaining transport processes

involved in fouling. Along with the contemplated use of HLS for boiler fouling, serious consideration was also given to modifying a somewhat more conventional "TEACH" type algorithm (similar to the one used by Humphrey of Berkeley) to incorporate a multi-scale representation of turbulence for improved turbulence field resolution.

During this reporting period, a visit was made to Yale to meet with Daniel Rosner and his team for a productive exchange of ideas. Requirements of a comprehensive fouling model in terms of physical input regarding the details of deposit structure, sticking coefficient, etc., were outlined. Such efforts should clearly delineate a rational path for the various related activities to ensure maximum possible success.

The evaluation effort finalized the choice of the numerical algorithm as incorporating a spatial element formulation in conjunction with a state-of-the-art ReNormalization Group, RNG, to provide sub-grid model effects. Subsequently, a three-dimensional spectral element code embodying these features was installed on the in-house STARDENT computer. Task 2 that aims to quantitatively assess flow and turbulence characteristics of related, but simpler problems was then initiated and is currently in progress.

Concerning the program management (Task 6), a comprehensive project plan was also prepared for submission to DoE along with other documentation required as per the requirements of the contract.

3.0 ALGORITHMIC AND COMPUTATIONAL DETAILS OF THE FORMULATION

The primary technical achievement of this reporting period has been the selection of a spectral element algorithm incorporating RNG techniques to provide sub-grid models, to serve as the basic flow analyzer for the remainder of the effort. As such techniques have not been widely publicized in the literature regarding their algorithmic details and/or physical assumptions embodied in their basic structure, the following is intended to provide a brief overview. The code that incorporates the aforementioned computational algorithm and physical models is given the acronym NEKTON and will be referred to frequently in the following discussion.

The computational algorithm solves the unsteady, incompressible two-dimensional, axisymmetric or three-dimensional Navier Stokes equations with forced or natural convection heat transfer in both stationary or time dependent geometry.

The solution variables are the fluid velocity $\bar{u} = (u_x, u_y, u_z)$, the pressure p , the temperature T , and a specified number of independent passive scalar fields ϕ_i ; all of the above field variables are functions of space $\bar{x} = (x, y, z)$ and time t .

The governing equations used are:

Momentum equation:

$$\rho(\partial_t \bar{u} + (\bar{u} \cdot \bar{\nabla}) \bar{u}) = -\bar{\nabla} p + \bar{\nabla} \cdot [\mu(\bar{\nabla} \bar{u} + (\bar{\nabla} \bar{u})^T)] + \rho \beta T \hat{g} + \rho \bar{f} \quad (3.1)$$

Continuity (mass conservation) equation:

$$\bar{\nabla} \cdot \bar{u} = 0 \quad (3.2)$$

Energy equation:

$$\rho C_p [\partial_t T + (\bar{u} \cdot \bar{\nabla}) T] = \bar{\nabla} \cdot (k \bar{\nabla} T) + q_{vol} \quad (3.3)$$

and a convective-diffusive equation for each passive scalar

$$(\rho C_p)_i \left[\partial_t \phi_i + (\bar{u} \cdot \bar{\nabla}) \phi_i \right] = \bar{\nabla} \cdot (\kappa_i \bar{\nabla} \phi_i) + (q_{vol})_i \quad (3.4)$$

The above governing equations are subject to boundary conditions and initial conditions described below.

3.1 Spatial Discretization

The spatial discretization used in the formulation is based on the spectral element method, a high-order finite element method for partial differential equations. Here the computational domain is represented as a set of (disjoint) macro-elements, with the solution, data and geometry being approximated by high-order polynomial expansions within each macro-element.

This approach offers high order (spectral) accuracy, while maintaining the geometric flexibility of low-order finite-element techniques. In the rest of this section the key features of the spectral element method are discussed with special emphasis on mesh generation.

Domain Decomposition. For two-dimensional domains, the isoparametric spectral element spatial discretization proceeds by first breaking the two-dimensional domain up into (non-degenerate) quadrangles, which are denoted as "macro-" or "spectral" elements. An example of such a decomposition is shown in Figure 3.1a. Three-dimensional domains are broken up into "bricks" in which the two horizontal parallel faces (top and bottom) are non-degenerate quadrangles, Figure 3.2.

Elemental Mesh: Within each element, a local continuum mesh is constructed corresponding to a $N \times N$ (xN) tensor product. Gauss-Lobatto-Legendre collocation points are shown in figure 3.1b. The Gauss-Lobatto points are clustered near elemental boundaries, and are chosen because of their accurate approximation, interpolation and quadrature properties. The

Figure 3.1b Legendre mesh local to a spectral element

Figure 3.2 Example of domain decomposition into three-dimensional hexahedral spectral elements

$\Delta x, \Delta y, \Delta z$ notation used in the following discussion refers to the distance between the collocation points.

Element and Continuity Requirements: The requirements that are placed on individual spectral elements are:

a) Two-dimensional spectral elements are quadrangles, as shown in Figure 3.3a with the interior angle at each of the four corners θ in the range $0 < \theta < 180$ (strict inequality). This is to ensure unique elemental transformations (non-zero Jacobians). Elements that do not satisfy this condition, and are therefore not permitted, are shown in Fig. 3.3b.

b) Three-dimensional elements are defined by two quadrangles on different (parallel) planes which make up the "top" and "bottom" faces of the element. These quadrangles are subject to the rules of the previous paragraph. The four "side" faces of the spectral element are defined by the four surfaces which connect each of the four respective sides of the two quadrangles. Points on the "side" faces are interpolated linearly from the corresponding points on "top" and "bottom" edges, see Figure 3.2.

c) The number of Gauss-Lobatto collocation points in the two or three directions within each spectral element (see Fig 3.1) must be the same and will be denoted by N . It is remarked that whereas (a) is a fundamental restriction, (c) is an artificial constraint (conforming elements).

As regards how elements may be placed together, the fundamental rule dictated by the form of the governing equations is that the solution and geometry must be continuous across elemental boundaries. Given the restrictions on individual elements, (a) - (c), this continuity requirement translates into the following rules of connection for assemblies of elements.

- i) No part of the element may lie in the interior of another element.
Figure 3.4a

Figure 3.3a Illustration of an admissible element

Figure 3.3b Illustration of inadmissible elements

Correct placement

Incorrect placement

Figure 3.4a Illustration of incorrect relative placement of spectral elements

Correct assembly

violates (ii)

Incorrect assembly

Figure 3.4b Illustration of incorrect assembly of spectral elements

- ii) Two elements may be connected only by spatial coincidence of two neighboring vertices of each element (from which it follows that they share an entire common side or face). Examples of correct and incorrect assembly are given in Figure 3.4b.
- iii) To describe a domain, D , elements must cover the entire domain. That is, the only element sides that are not connected to other element sides (per (ii)) must lie on the domain boundary ∂D .
- (iv) The number of Gauss-Lobatto collocation points, N , in each spatial direction within each element is the same for all elements. This follows from the functional and geometrical conformity (continuity) requirement and the restriction (c). It should be noted that (c) and (iv) are automatically taken care of in the code.

Function Interpolation: Similar to standard finite element techniques, within each element the depend variables ($\bar{u}, p, T$) are expanded in terms $(N-1)^{th}$ order tensor-product (polynomial) Lagrangian interpolants through the Gauss-Lobatto-Legendre collocation points. For instance, the temperature is expanded as $T = \sum_i h_i T_i$ where the h_i are the Lagrangian interpolants (that is polynomials which are unity at the i^{th} Gauss-Lobatto node and zero at all others), and T_i are nodal values of the temperature.

Generation of Discrete Equations: The semi-discrete equations (discrete in space) are generated using weighted residual (variational, Galerkin) techniques, corresponding to inserting the assumed forms for the dependent variables (e.g., $T = \sum_i h_i T_i$) into the governing equations, and requiring that the resulting residual vanish in some integral, weighted sense. Note that, since the basis functions chosen are Lagrangian interpolants, the numerical variables that are solved (e.g., the T_i) correspond to the values of the function of interest (e.g, the temperature) at the collocation points of the mesh.

Convergence: Convergence to the exact solution is obtained either by increasing the number of macro-elements, K , ("finite element"), in which case the error decreases algebraically like K^{-N} , or by increasing the order of the interpolants, N , in elements of fixed identity ("spectral") in which case the error decreases exponentially for smooth solutions $e^{-\alpha N}$. As always, any solution obtained numerically is verified to be converged (mesh-independent) by repeating the calculation on a finer mesh.

3.2 Temporal Discretization

Most simulations to be carried out during the course of this effort are time-dependent, that is, the governing equations are solved in the time-dependent evolution form given in (3.1)-(3.4). If a steady state solution exists to the problem, it will be achieved by NEKTON as the time asymptotic result of a transient calculation. The solution is updated to the new time-level using various combinations of multistep and multistage schemes.

In all transient simulations, the convective terms in $(\bar{u} \cdot \bar{\nabla})\bar{u}, (\bar{u} \cdot \bar{\nabla})T, (\bar{u} \cdot \bar{\nabla})\phi_i$ (3.1), (3.3) and (3.4) are usually treated explicitly, that is only data from previous time steps are used. The standard time-stepping procedure in NEKTON uses a third-order Adams-Bashforth scheme and the temporal accuracy associated with these terms are therefore $O(\Delta t^3)$, where Δt is the time step. The reason for the explicit treatment of the convective terms is to avoid the solution of a nonlinear, non-symmetric system of algebraic equations at each time level. However, due to this explicit treatment, a restriction on the time step, Δt , must be enforced in order to obtain stability.

The stability restriction (Courant condition) can be written in the form:

$$\Delta t < C_{\min} \left\{ \frac{\Delta x}{|u_x|}, \frac{\Delta y}{|u_y|}, \frac{\Delta z}{|u_z|} \right\} \quad (3.5)$$

where C is the Courant number, $\Delta x, \Delta y, \Delta z$ are the x,y,z distances between spatial collocation points (see Figure 3.1b), u_x, u_y, u_z are the x,y,z velocities,

respectively and $\min_{\Omega} \Gamma$ refers to the minimum over the entire flow field. The formulation will always ensure that the Courant condition (3.5) is satisfied.

The (prescribed) volumetric forcing functions, f , $-\rho\beta\hat{g}T$, q_{vol} , $(q_{vol})_\phi$ including the subgrid scale contributions to the resolved scales in (3.1), (3.3) and (3.4) are also treated using a third order-explicit Adams-Bashforth time stepping procedure. However the stability restriction (3.5) does not apply to these terms.

The diffusion terms $\nabla \cdot [\mu(\nabla \bar{u}) + (\nabla \bar{u})^T]$, $\nabla k \nabla T$, $\nabla \cdot k_\phi \nabla \phi_i$ in (3.1), (3.3), (3.4) and the pressure incompressibility condition in (3.1)-(3.2) are always treated implicitly using a Q^{th} order backward differentiation multistep scheme. Possible values of Q range from 1 to 3 resulting in a temporal accuracy of $O(\Delta t^Q)$. Due to the implicit treatment, there is no stability restriction associated with these terms, however, a set of linear algebraic equations must be solved at each time level. This can be done efficiently using iterative solvers as described in Section 3.3.

Remark 1: In general, the stability determining convective terms (explicit) and the work-intensive pressure/diffusion terms (implicit) do not coincide in a traditional semi-implicit treatment of the unsteady Navier-Stokes equations. In order to address this issue, a new high-order operator splitting method has been implemented in a variant of the numerical formulation. This method can potentially yield significant speed-up, Section 3.4. Although this scheme can be interpreted as the method of characteristics, it is in fact a particular example of a scheme generated from a more general methodology based on operator integration factor methods.

Remark 2: The algorithm also provides the option of integrating the unsteady Navier-Stokes equations using the classical splitting method (fractional step method). This scheme cannot be applied to stress boundary conditions and the temporal accuracy is $O(\Delta t)$.

3.3 Solution Methods

The selection of the fully discrete set of equations are characterized by use of iterative solvers and tensor-product sum-factorization techniques. For the explicitly treated convective terms, there is no matrix inversion, but only matrix vector product evaluations. This is done efficiently, both in terms of operation count and memory requirement by using sum-factorization techniques on an element-by-element basis.

The implicitly treated diffusion and pressure terms result in a large linear system of equation, which are solved using iterative solution procedures. The basic solver in NEKTON is an elliptic Helmholtz solver, appropriate for inverting the diffusion operator. This solver is based on conjugate gradient iteration, in which the computationally intensive part in each iteration is dominated by a single matrix vector product evaluation. As for the explicit terms, this evaluation is performed using sum-factorization techniques on an element-by-element basis. It is worth emphasizing that the global or elemental matrixes are never formed explicitly, an essential feature for solving large (three-dimensional) problems. The storage requirements in NEKTON is therefore minimal; it is on the order of the number of collocation points in the mesh.

Remark 3. The classical splitting scheme for solving the steady Navier-Stokes equations only involves one elliptic solve for the pressure and one for each of the velocity components. In contrast, a discretization based on consistent approximation spaces (polynomial degree N for velocity and polynomial degree $N-2$ for the pressure) results in nested elliptic solves for the pressure (Uzawa algorithm). While the latter approach is slow, it is generally more accurate.

Remark 4. NEKTON has the capability of using two different elliptic solvers. The first is based on conjugate gradient iteration, while the second one is based on intra-element multigrid procedure. The multigrid technique is particularly attractive for large problems, as the associated convergence rate is almost resolution independent.

The data structure used in the code also allows NEKTON to run efficiently on modern architectures, in particular on distributed memory parallel machines. The loosely coupled spectral elements can readily take advantage of medium-grained parallelism by distributing the elements on different processors, while each individual (tightly coupled) elemental matrix-vector product evaluation can be vectorized. This is in contrast to direct solution techniques such as Gaussian elimination, which are cross-coupled and less effective at exploiting parallel computer architecture.

The motivation behind spectral element (rather than low-order finite element) methods is that the increased coupling introduced by high-order methods increases the work only algebraically, whereas the increase in accuracy is exponential. These arguments only apply for problems with smooth solutions. However, with the exception of boundary-induced singularities, incompressible flow and heat transfer problems will generally satisfy these requirements.

3.4 Method Tradeoff

NEKTON uses several different algorithms for solving problems in fluid mechanics. The selection of the algorithm most appropriate for a given problem can greatly affect the speed and accuracy with which that problem can be solved. In this section, a discussion is provided to outline and compare the capabilities, relative speeds, and accuracies associated with each solution algorithm used by NEKTON.

The solution algorithm has two parts, the problem formulation in which the partial differential equations comprising the Navier-Stokes equations are converted into a set of discrete equations, and the solution, a numerical procedure in which the set of discrete equations are solved simultaneously. The formulation uses three variants, the non-stress formulation, the stress formulation, and the classical splitting scheme. These formulations convert the Navier-Stokes equations into a series of discrete elliptic problems, which are solved iteratively using an elliptic solver; in the code this solver is based on conjugate gradient iteration.

The split formulation gives the fastest solution for any given time-dependent flow problem. Its primary limitation is that it incurs splitting errors which are of order $\nu \Delta t$, where ν denotes kinematic viscosity. Splitting errors are significant where the viscosity is high and the time step is large, as in creeping or Stokes flows. For high Reynolds number problems, the viscosity is low and the time step is small due to stability restrictions (Courant condition), so that generally the splitting errors are small. The split formulation is hence suitable for flows in which $Re > 25$.

The non-stress formulation uses consistent approximation spaces for the velocity and pressure, and gives accurate results for the entire range of Reynolds numbers. It can be used for flows ranging from Stokes flows (where $Re=0$) through transition flows. It is slower than the split formulation by a factor of approximately four.

The stress formulation is a variant of the non-stress formulation in which the three (or two) velocity components are solved for simultaneously and all components of the stress tensor are retained. This formulation allows for additional stress-related boundary conditions: imposed stress, zero stress and moving boundaries, which can be defined in terms of local (tangential and normal) coordinate components. This formulation is the most general and rigorous of the three, but also the most CPU-intensive. It is slower than the non-stress algorithm by a factor of approximately two.

As discussed in Section 3.2, NEKTON solves any convection diffusion problem as a transient problem, with the convective terms treated explicitly. For convection dominated flows ($Re \gg 1$) this explicit treatment can give very severe time step restrictions due to the Courant condition (3.5). For the standard semi-implicit time-stepping strategy, NEKTON uses a default Courant number of $C = 0.25$. However, if the flow problem has prescribed velocity on the whole (fluid) domain boundary, substantial time saving benefits can be realized by increasing the Courant number to about $C = 0.4$.

Bigger savings can be achieved for convection-diffusion problems, however, if the method of characteristics is used, in which the convective terms are decoupled from the pressure and viscous treatment. Hence, the time step

for the (expensive) integration of viscous term, together with the imposition of the incompressibility constraint, can be set much larger than the (restrictive) time step for the integration of the explicitly treated convective terms. If the work is dominated by the pressure solver, an increase in the Courant number (measured using the bigger time step) from $C = 0.25$ to $C = 2.0$ can sometimes give a factor 8 in speed up. The limitations using the method of characteristics are typically related to problems with steep (marginally resolved) normal boundary layers, and if the prescribed in flow boundary conditions do not correspond to fully developed flows.

3.5 ReNormalization Group Treatment of Turbulent Flows

Current trends in turbulence modelling employ methods from statistical mechanics, with turbulence regarded as exhibiting both universal and non-universal behavior. Universal behavior can conceivably be modelled, with the model having a wide range of application. Non-universal behavior is brought about by large scale inhomogeneities, such as geometry, boundary conditions, imposed unsteadiness, etc. Such inhomogeneities must be resolved by the governing equations and cannot be modelled in any general manner. A statistical mechanics approach addresses the universal behavior, looking for ways to model it, or at least its gross effects, on the non-universal part of the flow. A perturbation series is usually applied to the instantaneous equations, resulting in an infinite series in powers of mean flow gradients. The first term in such a series expansion is the isotropic formula, the second term is linear in the mean velocity gradient, and the third term produces quadratic non-linearity.

The constitutive approach to turbulence modelling suffers even on an intuitive level: turbulence is not a material and does not exhibit the necessary characteristics to be considered a optimum material. Constitutive and statistical mechanic approaches also suffer a common weakness: these theories provide no logical means to terminate the expansion, i.e., the theory cannot indicate when a satisfactory order or number of terms has been achieved. Thus one is left to terminate the series when the desired phenomenon is obtained or the algebra inundates the researcher. More problematic, no proof of convergence can be produced for these series, and arbitrarily obtaining higher order terms invites problems. In common with the more widely used phenomenologically

based models, all the constants arising in such formulations must be established by comparing with data - again the theory fails to provide any clue to the values of the constants.

ReNormalization Group (RNG) techniques, like the previous statistical approaches, have proven to be useful tools in theoretical physics and statistical mechanics to study systems with a very large number of degrees of freedom. Although RNG theory has found its way into fluid mechanics relatively recently, particularly in developing turbulence theory, it has provided a series of interesting theoretical and numerical results. A milestone for RNG theory in fluid mechanics was the establishment of the so-called correspondence principle, stating that in the inertial range, the behavior of the small scale Navier-Stokes turbulence is statistically equivalent to the modelled Navier-Stokes equation with the addition of a random noise term. This principle makes it possible to use all the formalism of the classical RNG theory.

Recently RNG methods have been developed to analyze a variety of turbulent flow problems. For homogeneous turbulent flows, such important quantities as the Kolmogorov constant, Batchelor constant, turbulent Prandtl number, rate of decay to isotropy, skewness factor, etc. have been obtained directly from this theory in good agreement with available data. Efforts in developing RNG methods for sub-grid (large eddy simulation) model constants have also been notably successful.

RNG methods involve systematic approximations to the full Navier Stokes and energy equations that are obtained by using perturbation theory to eliminate or decimate infinitely small bands of small scale modes, iterating the perturbation procedure to eliminate finite bands of modes by constructing recursion relations for the renormalized transport coefficients, and evaluating the parameter at a fixed point in the lowest order of dimensional expansion around a certain critical dimension. The decimation procedure, when applied successively to the entire wave-number spectrum leads to the RNG equivalent of full closure of the Reynolds averaged Navier-Stokes and temperature equations.

The resulting RNG transport coefficients are differential in character as opposed to the ad hoc algebraic coefficients of conventional closure methods. All constants and functions appearing in the RNG closures are fully determined by the RNG analysis. In essence, RNG method provides an analytical method to eliminate small scales from the Navier Stokes and passive scalar equations, thus leading to a dynamically consistent description of large scales. The formal process of successive elimination of small scales together with rescaling of the resulting equations results in a calculus for the derivations of transport approximations in turbulent flows.

The ReNormalization Group method has been used to derive a formula for the inverse turbulent Prandtl number, and three different types of models for the eddy viscosity: an algebraic model, a differential κ - ϵ and a sub-grid scale turbulence model for large eddy simulations.

4.0 CONCLUSION AND PLANS FOR FUTURE WORK

4.1 Conclusions to Date

Good technical progress has been made. As HLS applications in the past have concentrated on resolving the turbulence details of semi-idealized, geometrically simple flow problems, applications involving configurations and physical complexity comparable to those in typical tube banks are naturally rare. Hence, the evaluation task critically assessed the computational and algorithm requirements of HLS such that adequate resolution of the flow and turbulence characteristics can be obtained for use in the description of the various physicochemical processes involved. Such issues specifically refer to resolution requirements of the various eddy scales involved, treatment of the near-wall region, implementation of non-homogeneous boundary and initial conditions, solution and algorithm details including cost versus accuracy, etc.

This evaluation has clearly delineated critical accuracy bounds for the fluid mechanics description, as well as establishing comparable criteria for the remaining module development effort. It has also provided for a greater insight into the physical and mathematical nature of the dominant transport mechanism, thereby enabling the development of a rational comparison basis to guide the rest of the effort in regards to the aforementioned issues to predict fouling evolution details in complex multi-tube configurations.

4.2 Plan for Next Reporting Period

In the next reporting period, quantitative assessment of HLS techniques will be finalized, as well as performing representative predictions for the flow (non/isothermal) around an isolated tube.

**DATE
FILMED
8/03/92**