

CRITICALITY EXPERIMENTS WITH MIXED PLUTONIUM
AND URANIUM NITRATE SOLUTION AT A PLUTONIUM
FRACTION OF 0.5 IN SLAB AND CYLINDRICAL GEOMETRY

R. C. Lloyd PNL--5768
 TI87 026327

December 1986

Work performed for the Consolidated
Fuel Reprocessing Program and the
Power Reactor and Nuclear Fuel Development
Corporation of Japan under the Joint
Memorandum of Agreement on Criticality
Data Development

Prepared for
the U. S. Department of Energy
under Contract DE-AC06-76RL0 1830

Pacific Northwest Laboratory
Richland, Washington 99352

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED
rb

SUMMARY

A series of critical experiments was completed with mixed plutonium-uranium solutions having $\text{Pu}/(\text{Pu} + \text{U})$ ratios of approximately 0.5. These experiments were a part of the Criticality Data Development Program between the United States Department of Energy (USDOE), and the Power Reactor and Nuclear Fuel Development Corporation (PNC) of Japan. A complete description of, and data from, the experiments are included in this report. The experiments were performed with mixed plutonium-uranium solutions in cylindrical and slab geometries and included measurements with a water reflector, a concrete reflector, and without an added reflector. The concentration was varied from 112 to 332 g $(\text{Pu} + \text{U})/\text{liter}$. The ratio of plutonium to total heavy metal (plutonium plus uranium) was 52% for all experiments.

CONTENTS

SUMMARY	iii
FIGURES	vii
TABLES	ix
1.0 INTRODUCTION	1.1
2.0 DESCRIPTION OF EXPERIMENTAL ASSEMBLIES	2.1
2.1 GENERAL DESCRIPTION OF THE SOLUTION SYSTEM	2.1
2.2 CYLINDRICAL VESSEL ASSEMBLY	2.4
2.3 EXPANDABLE SLAB TANK SYSTEM	2.8
3.0 EXPERIMENTAL RESULTS	3.1
3.1 CRITICALITY MEASUREMENT TECHNIQUES	3.1
3.2 CRITICALITY DATA	3.1
3.3 SOURCES OF ERROR	3.9
4.0 REFERENCES	4.1
5.0 ACKNOWLEDGEMENTS	5.1
APPENDIX A - ENGINEERING DRAWINGS OF THE CYLINDRICAL VESSEL SYSTEM	A.1
APPENDIX B - ENGINEERING DRAWINGS OF THE EXPANDABLE SLAB TANK SYSTEM	B.1
APPENDIX C - LEAST SQUARE FITS OF THE CRITICAL APPROACH DATA . . .	C.1
APPENDIX D - CHEMICAL ANALYSES DATA OF THE IMPURITIES IN (Pu + U) NITRATE SOLUTIONS	D.1
APPENDIX E - CHEMICAL ANALYSES DATA OF THE REFLECTOR WATER SAMPLES	E.1
APPENDIX F - COMPOSITION OF THE CONCRETE REFLECTOR	F.1
DISTRIBUTION	Dist. 1

FIGURES

2.1	Floor Plan Schematic of the Critical Assembly Room	2.2
2.2	Piping Schematic for the Three Experimental Vessels	2.3
2.3	Photograph of the Cylindrical Vessel System	2.5
2.4	Placement of Cylindrical Vessels in the Reflector Tank	2.6
2.5	Schematic of the Cylindrical Vessel	2.7
2.6	Schematic of the Concrete Reflected Cylindrical Vessel	2.9
2.7	Photograph of the Slab Assembly	2.10
2.8	Critical Experiments Expandable Slab Assembly	2.12
2.9	Schematic of the Expandable Slab Tank Positioned in the Reflector Tank	2.13
2.10	Containment Hood for Expandable Slab Assembly (Looking at South Side of Slab)	2.14
A.1	CFRP Assembly H-2-33856, Sheet 1 of 5	A.1
A.2	CFRP H ₂ O Tank and Cover H-2-33856, Sheet 2 of 5	A.2
A.3	CFRP Process Tanks H-2-33856, Sheet 3 of 5	A.3
A.4	CFRP Tank Covers and Shield H-2-33856, Sheet 4 of 5	A.4
A.5	CFRP Pump Valve H-2-33856, Sheet 5 of 5	A.5
B.1	Tank Assembly H-2-32570 Sheet 1 of 8	B.1
B.2	Bellows Tank Side Plates H-2-32570, Sheet 2 of 8	B.2
B.3	Bellows Tank Lattice Reinforcing H-2-32570, Sheet 3 of 8 . . .	B.3
B.4	Tank Detail H-2-32570, Sheet 4 of 8	B.4
B.5	Bellows Tank Detail H-2-32570, Sheet 5 of 8	B.5
B.6	Bellows Tank Detail H-2-32570, Sheet 6 of 8	B.6
B.7	Bellows Tank Hood Arrangement H-2-32570, Sheet 7 of 8	B.7
B.8	Bellows Tank Dump Line Assembly H-2-32570, Sheet 8 of 8 . . .	B.8
C.1	Least Square Fit CFRP-PNC 046	C.2
C.2	Least Square Fit CFRP-PNC 046R	C.3
C.3	Least Square Fit CFRP-PNC 047	C.4
C.4	Least Square Fit CFRP-PNC 049A	C.5

FIGURES - Continued

C.5	Least Square Fit CFRP-PNC 050	C.6
C.6	Least Square Fit CFRP-PNC 051	C.7
C.7	Least Square Fit CFRP-PNC 054	C.8
C.8	Least Square Fit CFRP-PNC 055	C.9
C.9	Least Square Fit CFRP-PNC 056	C.10
C.10	Least Square Fit CFRP-PNC 056A	C.11
D.1	Spectrographic Analysis Report # 1087	D.2
D.2	Spectrographic Analysis Report # 1095	D.3
D.3	Spectrographic Analysis Report # 1119 and 1121	D.4

TABLES

3.1	Criticality Measurements with (Pu + U) Nitrate Solution in 35.39 cm Diameter Cylinder	3.3
3.2	Criticality Measurements with (Pu + U) Nitrate Solution in Slab Geometry	3.4
3.3	Chemical Analyses Methods	3.5
3.4	Chemical Analysis Values for Americium in Micrograms per milli-liter	3.6
3.5	Isotopic Analyses Values of Pu and U (Wt %)	3.7
3.6	Information on Temperature, Reflector Level and Control and Safety Blade Position	3.8
3.7	Table of Measurement Uncertainties	3.9
E.1	Water Sample Analysis - 046 and 046R	E.1
E.2	Water Sample Analysis - 054 and 055	E.2
F.1	Concentration of Elements in Concrete Reflector	F.2
F.2	Water Content of Concrete Reflector	F.3
F.3	Calculated Atom Densities for the Concrete Reflector	F.5

CRITICALITY EXPERIMENTS WITH MIXED PLUTONIUM AND URANIUM NITRATE
SOLUTION AT A PLUTONIUM FRACTION OF 0.5 IN SLAB AND CYLINDRICAL GEOMETRY

1.0 INTRODUCTION

The design and operation of facilities for recycling fast breeder reactor fuels involves criticality conditions which are much different from those encountered in the light water reactor fuel cycle. Conditions are encountered in plant operations with fissionable materials that involve complex equipment shapes, high plutonium content in solution with uranium, and neutron absorbing materials that affect criticality. Experimental criticality data are required for validation of the calculations and nuclear data used in facility design, operational procedures and related licensing activities to ensure freedom from criticality accidents. In August, 1983 the U. S. Department of Energy (DOE) and the Power Reactor and Nuclear Fuel Development Corporation (PNC) of Japan entered into an agreement to study criticality aspects of nuclear fuels encountered in the development of fast breeder reactor recycle technology. This arrangement was developed through the DOE and PNC Agreement in the Field of Liquid Metal-Cooled Fast Breeder Reactors. Prior to this Joint Memorandum of Agreement (MOA) for Nuclear Criticality Data Development Programs, DOE had initiated an experimental program at the DOE Hanford Critical Mass Laboratory to provide basic criticality data on plutonium-uranium systems in support of the U. S. Liquid Metal Fast Breeder Reactor Program. Under this MOA, PNC has promoted and enlarged the DOE Program to cover areas of mutual interest as well as areas of specific interest to PNC.

Some computer codes for criticality calculations have been developed and applied to FBR fuel cycle facility designs. Application of these codes, however, and the associated cross-section libraries, results in uncertainties in the criticality aspects for FBR fuel under the conditions encountered. Therefore, experimental data are needed which will permit validation of codes and cross-section data to minimize the uncertainties so that facility safety, efficiency, and reliability can be enhanced. The verification of criticality evaluation methods is the subject of regulatory licensing activity.

This report contains a description of, and data from, the criticality experiments conducted with mixed plutonium-uranium solutions at $\text{Pu}/(\text{Pu} + \text{U})$ ratios of approximately 0.5, which documents part of the work in the Project's Subtask 120. The experiments were performed in cylindrical and slab geometry. Reflector conditions of water reflected, concrete reflected and bare were used. The solution concentration was varied from 112 to 332 g $(\text{Pu} + \text{U})/\text{l iter}$. These data have application whenever mixtures of plutonium and uranium exist, in the head-end of a fuel reprocessing plant through the first solvent extraction cycle, in storage vessels and during product conversion when a coprocessing scheme is used.

2.0 DESCRIPTION OF EXPERIMENTAL ASSEMBLIES

This section includes the general description of the experimental assemblies used for obtaining the criticality data.

2.1 GENERAL DESCRIPTION OF THE SOLUTION SYSTEM

An existing experimental system, previously used for solution experiments at the Critical Mass Laboratory, was used in the measurements to provide the data for this report. The solution system is located in the critical assembly room. The addition of solution to the experimental vessel is remotely made from the control room. The layout of equipment in the critical assembly room is shown in Figure 2.1.

The critical assembly room is 10.67 meters square and has a ceiling height of 6.4 meters. The side walls are composed of 1.52 meter thick concrete. The concrete ceiling and floor are each 0.61 meters thick.

The containment hood (Hood 1) was located 1.83 meters from the north wall of the room. The west side of the hood, which faces the wall containing the DS and DM tanks was located 1.52 meters from that wall.

A schematic showing the piping connections between the three experimental vessels is shown in Figure 2.2. This piping arrangement allows critical experiments to be conducted with the same solution in each of three vessels without changing vessels. The small diameter cylinder (35.39 cm) and the variable thickness slab tank were used in these series of experiments.




Figure 2.1 Floor Schematic Plan of the Critical Assembly Room

2.3




Figure 2.2 Piping Schematic for the Three Experimental Vessels

2.2 CYLINDRICAL VESSEL ASSEMBLY

A photograph of the cylindrical vessel system is shown in Figure 2.3. This system contains two cylindrical vessels. The vessel used for the experiments in this report has an inside diameter of 35.39 cm. This vessel can be seen through the window on the left. The control and safety blade mechanisms are mounted above the vessel and can be seen in the figure directly above the vessel. The reflector tank serves to contain water when water reflected vessels are used. Windows of polycarbonate (Lexan) were installed on the front for access to the tank and for visual inspection. This reflector tank was fabricated of carbon steel. The placement of the cylindrical vessels is shown in Figure 2.4.

The small cylindrical vessel (35.39 cm ID and 106.60 cm inside height) was fabricated of 304L stainless steel. The wall thickness was 0.079 cm. The control and safety blades are external to the vessel and are fully withdrawn during the neutron flux determination during the critical approach measurement. A schematic of the cylindrical vessel is shown in Figure 2.5.

The fill, dump and manometer lines enter the bottom of the vessel through the dump valve system. The vessel is connected to the dump valve pedestal by a Marmon flange connection which provides a leak tight seal.

The experiments with the cylinder were conducted with the reflector tank empty, with the reflector tank containing water and with a concrete reflector positioned around the cylindrical vessel. In the "bare" condition, the reflector tank is empty, but some neutrons will, however, be reflected from the adjacent tank walls and the large empty cylinder that is also located in the reflector tank, and the concrete walls of the room. Reflector type control and safety blades of acrylic resin were used for the bare assembly. For the water reflected cases, the reflector tank was filled to a level slightly below the top of the cylindrical vessel.




Figure 2.3 Photograph of the Cylindrical Vessel System

ORNL-DWG 86-11827




Figure 2.4 Placement of Cylindrical Vessels in the Reflector Tank




Figure 2.5 Schematic of the Cylindrical Vessel

In the case of the concrete reflected assemblies, the concrete was 25.2 cm thick. An artist's conception of the concrete reflector, showing the concrete positioned around the experimental vessel, is shown in Figure 2.6. (See Appendix A for Engineering Drawing). The concrete reflector extended to the bottom of the reflector tank.

Engineering drawings are provided in Appendix A for the cylindrical vessel system; these contain detailed dimensions used for fabrication.

2.3 EXPANDABLE SLAB TANK SYSTEM

The expandable slab tank system has been in use for several years and has been used in conducting many experiments (Lloyd, 1973). The engineering drawings for this system are provided in Appendix B. C. R. Richey has performed an analysis on the grid structure for the slab tank system (Richey, 1967) in which he determines its effects on the experiments.

The slab assembly (Figure 2.7) used in these experiments is unique because its thickness can be adjusted over a range of 7.6 to 22.8 cm. This range of adjustments is made possible by means of a stainless steel bellows fabricated around the periphery of the tank. Slab thickness change is accomplished by means of adjustment screws, located at the corners of the vessel, between the opposite sides of the slab; slab thickness is measured by means of a dial caliper. The height and width of the tank is about 106.7 cm, based on the average of the bellows variation. The stainless steel sides (0.159 cm) are reinforced with an egg-crate-type structure that maintains the side position to within ~0.025 cm when filling the tank. The assembly and its parts are of Type 304L stainless steel. A reflected assembly is achieved by attaching gasketed side plates and filling with water. The assembly is positioned in a large hood for contamination control, in the event of leaks.




Figure 2.6 Schematic of the Concrete Reflected Cylindrical Vessel




Figure 10. Construction of the plant system.

The grid structure is composed of 0.3175 cm thick stainless steel plate. The measured average center-to-center spacing of the support grid structure is 10.6 cm. The bellows, visible in Figure 2.7, is constructed with a tip to trough distance of 5.08 cm at a slab thickness of 15.2 cm. The bellows is composed of two sets of four V-shaped structures; the sets are separated by a U-shaped structure having a width of 2.86 cm and a depth of approximately 2.5 cm. The corners of the slab tank are rounded with a 14.4 cm radius measured from the outside of the tank. The bellows are made of type 304L stainless steel and are 0.079 cm in thickness.

The slab tank is positioned inside a metal frame (visible in Figure 2.8) to which gasketed side plates can be attached to form a reflector tank. In both water reflected and "bare" experiments these side plates are present except where noted. In case a water reflector is used, the water level is set at the midpoint of the top bellows of the slab tank. The side plates and end plates for the reflector tank are 0.635 and 0.476 cm thick respectively and are fabricated from stainless steel. A schematic of the expandable slab tank positioned in the reflector tank is shown in Figure 2.9.

The inside dimensions of the water reflector tank are 68.6 cm wide by 142.2 cm long by 143.5 cm high. The slab tank is positioned such that the center of the bellows on the lower edge of the slab is 18.4 cm above the inside face of the lower plate. The slab tank is positioned such that the narrow side faces (Bellows Center) are 17.75 cm from the inside face of the water reflector tank. The distances from the broad faces of the slab tank to the water reflector tank walls is varied according to the critical configuration being examined, from 25.6 cm to 33.2 cm on the south side; and 20.2 cm to 27.8 cm on the north side for tank thickness settings of 22.8 cm to 7.6 cm, respectively.

The slab tank and associated water reflector tank are surrounded by a containment hood (see Figure 2.10). The hood has a stainless steel structure with Plexiglas windows which are 0.95 cm thick. The steel structural material is approximately 0.635 cm thick.

2.12




Figure 2.8 Critical Experiments Expandable Slab Assembly




Figure 2.9 Schematic of the Expandable Slab Tank Positioned in the Reflector Tank




Figure 2.10 Containment Hood for Expandable Slab Assembly
(Looking at South Side of Slab)

The bottom of the water reflector tank is located 100.6 cm above the concrete floor of the experimental cell. The broad faces of the water reflector tank are located 34.3 and 138.4 cm, from the South and North faces of the hood walls, respectively. The narrow faces of the reflector tank are located 24.6 and 109.5 cm, from the West and East hood walls, respectively.

The slab tank is equipped with control and safety blade drive mechanisms which provide for insertion of the control and safety blades directly into the solution. The control and safety rod drive mechanisms are mounted above the slab tank. A 2.5 cm thick steel grate platform is mounted inside the hood, 230 cm above the floor. The grate provides a working platform for the installation of the control and safety blade drive mechanisms.

3.0 EXPERIMENTAL RESULTS

This section provides the results of the experiments including a description of the measurement techniques involved in obtaining the data.

3.1 CRITICALITY MEASUREMENT TECHNIQUES

The critical heights for the experiments reported herein were determined using the critical approach method (Clayton, 1985). In this critical approach method, neutron flux measurements are made as the height of solution is incrementally increased. Inverse count rate is plotted versus solution height. As the delayed critical condition is approached the neutron count rate approaches infinity so the inverse count rate approaches zero. By extrapolation of the inverse multiplication curves to zero value, the critical height is determined for the system. The neutron flux is routinely taken on three boron-lined proportional detectors located near the experimental vessel. The data from the three counters extrapolate to essentially identical values for critical height at near critical values. The computer calculated least squares fit of the inverse multiplication curves, used in determining the critical value of the heights for each experimental assembly, are included in Appendix C. The critical heights given in Appendix C for the slab tank are with respect to the top of the bottom bellows.

3.2 CRITICALITY DATA

The criticality data for this report were obtained from January - September 1985, when three experiments were completed with the small cylindrical vessel and seven with the expandable slab experimental system. The data are summarized in Tables 3.1 and 3.2. The critical indicated heights for the slab tank are shown with respect to the midpoint of the lower bellows. The chemical analyses data for the (Pu + U) nitrate solutions given in these tables were provided by the Chemical and Analysis Section of the Westinghouse Hanford Co. from samples of solution supplied to them. The sample analyses methods and descriptive titles are given in Table 3.3. The critical heights were calculated by a least squares

fit to the inverse neutron multiplication data from three neutron detectors. (Computer printout provided in Appendix C). The ^{241}Am content for each sample analyzed, the analysis date and the experiments covered by that sample are given in Table 3.4. The isotopic analyses values for the plutonium and uranium of the experiments are given in Table 3.5. Table 3.6 provides information on the temperatures of the critical assembly room (CAR), the dump mix tank (DM) and the water reflector. Also in Table 3.6, the reflector water level and the position of the bottom of the control and safety blades are given. (Reference is the vessel top).

Appendix D provides data on the chemical analyses for the impurities found in the (Pu + U) nitrate solutions.

The chemical analyses of the reflector water samples are given in Appendix E.

The composition of the concrete reflector is given in Appendix F. Also provided are the calculated atomic densities used in previous measurements using this concrete reflector (Primm, 1986).

TABLE 3.1 Criticality Measurements with (Pu + U) Nitrate Solution in 35.39 cm I. D. Cylinder

Run Date	Project Case Number	CM Experiment Number	Reflector	Sample Number ⁻¹⁾	Pu (g/liter)	U (g/liter)	Specific Gravity	Free Acid H ⁺	Critical Height, H _c (cm)
01/15/85	1	048	Water	1087	59.35	53.12	1.1968	0.77	23.83
01/17/85	1	048R	Water	1087	59.35	53.12	1.1968	0.77	24.06
01/29/85	2	047	Concrete	1088	59.82	54.12	1.1977	0.75	24.88
04/26/85	10	051	Bare	1096	59.63	53.27	1.1978	0.85	34.93

-1) Samples were not ion exchanged prior to analysis

**TABLE 3.2 Criticality Measurements with (Pu + U)
Nitrate Solution in Slab Geometry**

Run Date	Project Case Number	CML Experiment Number	Reflector	Sample Number ⁻³⁾	Pu (g/liter)	U (g/liter)	Specific Gravity	Free Acid H ⁺	Slab Thickness cm	Solution Critical Height, cm
04/05/85	3	048	Bare -1) (1 Side Tamper Tank)	1095A	174.07	157.48	1.5316	1.15	17.46	*
04/08/85	3	049A	Bare -1) (1 Side Tamper Tank)	1095A	174.07	157.48	1.5316	1.15	18.10	78.74
04/10/85	3	050	Bare -2)	1095B	174.62	157.52	1.5329	1.15	18.10	71.88
09/05/85	6	054	Water	1119	118.94	108.39	1.3714	0.82	12.19	60.62
09/06/85	7	055	Water	1120	60.53	55.17	1.1944	0.55	12.19	83.41
09/09/85	8	056	Bare -2)	1121	61.00	55.52	1.1954	0.53	19.05	45.31
09/10/85	8	056a	Bare -2)	1121	61.00	55.52	1.1954	0.53	17.78	60.15

*Data show criticality not possible in the slab with 17.46 cm thickness with Pu + U nitrate solution being used in this experiment.

-1) The north side was removed

-2) Both sides of tamper tank on

-3) Samples were not ion exchanged prior to analysis

TABLE 3.3 Chemical Analyses Methods

<u>Measurement</u>	<u>Method Title -1)</u>	<u>Date of Approval</u>
Plutonium	Plutonium by Automated Amperometric Titration. (30.3)	03/18/85
Uranium	Uranium by Automated Potentiometric Titration. (30.8)	02/05/86
Impurities	Impurities by Emission Spectroscopy: Direct Reader. (40.13)	06/11/85
^{241}Am	Americium-241 by Anion Exchange and Alpha Analysis. (40.16)	05/14/75
Free Acid	Determination of Free Acid in Uranium/ Plutonium Solutions. (Using an improved oxalate method) (40.22)	02/04/86
Density	Density of Solutions. (Using Mettler/ Paar Density Meter) (40.23)	02/05/86
Isotopic	Isotopic Composition of Plutonium and Uranium by Mass Spectroscopy. (30.6)	09/27/78
Impurities	Impurities by Spark Source Mass Spectrometer. (40.15)	05/22/75

-1) The numbers in brackets are HEDL's method numbers.

TABLE 3.4 Chemical Analysis Values for Americium-241
in Micrograms per milli-liter

Sample Number	^{241}Am (ug/ml)	Analysis Date
1087	290	01/29/85
1095	921	10/21/85
1096	306	05/08/85
1096	307	05/08/85
1119	587	09/23/85
1121	302	09/23/85

Sample 1087 covers experiments 046, 046R and 047

Sample 1095 covers experiments 048, 049A and 050

Sample 1096 covers experiment 051

Sample 1119 covers experiment 054

Sample 1121 covers experiments 055, 056 and 056a.

TABLE 3.5 Isotopic Analyses Values of Pu and U (Wt%)

	<u>Sample 1087</u> ⁻¹⁾	<u>Sample 1095</u> ⁻²⁾	<u>Sample 1119</u> ⁻³⁾	<u>Sample 1121</u> ⁻⁴⁾
<u>Pu</u>				
238	0.029 ± 0.003	0.021 ± 0.002	0.029 ± 0.001	0.027 ± 0.001
239	91.11 ± 0.04	91.11 ± 0.04	91.10 ± 0.04	91.10 ± 0.04
240	8.30 ± 0.04	8.31 ± 0.04	8.31 ± 0.04	8.31 ± 0.04
241	0.474 ± 0.002	0.462 ± 0.003	0.464 ± 0.002	0.467 ± 0.002
242	0.093 ± 0.002	0.092 ± 0.002	0.093 ± 0.002	0.092 ± 0.002
<u>U</u>				
238	99.253 ± 0.005	99.267 ± 0.005	99.265 ± 0.006	99.266 ± 0.006
236	0.027 ± 0.002	0.022 ± 0.002	0.022 ± 0.001	0.022 ± 0.001
235	0.707 ± 0.005	0.701 ± 0.004	0.705 ± 0.005	0.702 ± 0.005
234	0.012 ± 0.001	0.009 ± 0.002	0.009 ± 0.003	0.009 ± 0.003

-1) Sample 1087 is for Experiments 46, 46R, 47 and 51: Date analyzed, 1/31/85.

-2) Sample 1095 is for Experiments 48, 49 and 50: Date analyzed, 10/24/85.

-3) Sample 1119 is for Experiment 54: Date analyzed, 9/25/85.

-4) Sample 1121 is for Experiments 55, 56 and 56a: Date analyzed, 9/25/85.

TABLE 3.6 Information on Temperatures, Reflector Level, and Control and Safety Blade Position

Experiment Number	Temperature C°			Reflector Level Distance Below Vessel Top (cm)	Control and Safety Blade Distance Below Vessel Top (cm)	
	Room	Storage Tank	Reflector		Blade Distance Below Vessel Top (cm)	
<u>Cylinder</u>	046	22.8	17.8	17.8	1.27	2.54
	046R	22.0	17.7	20.3	1.27	2.54
	047	21.9	17.9	21.9	N/A	2.54
	051	17.1	18.8	N/A	N/A	1)
<u>Slab</u>	048	22.0	18.0	N/A	N/A	5
	049A	21.0	17.0	N/A	N/A	5
	050	19.0	20.0	N/A	N/A	5
	054	22.2	24.6	22.5	2.54	5
	055	23.5	24.7	22.2	2.54	5
	058	22.7	24.9	N/A	N/A	5
	058a	21.1	24.6	N/A	N/A	5

N/A - Not Applicable

1) Control & Safety blade top was 1.905 cm below tank bottom.

3.3 SOURCES OF ERROR

It is practically impossible to assess, individually, the effects of all the uncertainties in all of the experimental measurements. Realistically, it is only necessary to examine those variables or combination of variables which might have a reactivity effect which is a significant fraction of the typical uncertainty in a particular KENO calculation. This evaluation was done for the significant measurements involved in earlier experiments and reported (Primm, 1986). From that analysis it was found that the primary uncertainty that caused significant error was from the free acid values. Since those measurements, a study was made and a free acid analysis method developed and reported (J. L. Ryan, 1985). This has significantly reduced uncertainties in the analysis for free acid. Further work provided free acid standards so that the analyses could be confirmed.

The evaluation of uncertainties by (Primm, 1986) included the critical height, plutonium concentration, uranium concentration, density, free acid and composition of reflectors. It was recognized by (Primm, 1986) that the procedure used to derive uncertainties due to experimental and chemical analysis measurements were likely to over estimate the value of each parameter.

The latest estimated values of uncertainties are listed in the following table:

TABLE 3.7 Measurement of Uncertainties

Pu Concentration	\pm	0.1%
U Concentration	\pm	0.1%
Specific Gravity	\pm	0.0003
Free Acid	\pm	0.04 M
Critical Height	\pm	1.6 mm

Values for uncertainties in the chemical analyses were provided by M. C. Burt of the Chemical and Analysis Section of the Westinghouse Hanford Company, Hanford Engineering Development Laboratory. The critical height uncertainty is given as 1.6 mm though the least square fitting of approach data for three counting systems would indicate a smaller value as reasonable. The 1.6 mm is the smallest unit on the sight tube.

4.0 REFERENCES

Clayton, E. D, (1985). Neutron Source Multiplication Method, PNL-SA-13357, Pacific Northwest Laboratory, Richland, WA 99352.

Lloyd, R. C., et. al., (1973). "Criticality of Plutonium Nitrate Solutions in Slab Geometry." Nuclear Technology. 18:225-230.

Primm, R. T. III, et. al., (1986). Critical Experiments with Mixed Plutonium-Uranium Nitrate Solutions having Pu/(Pu + U) Ratios Greater than 0.5. ORNL-6161, Oak Ridge National Laboratory, Oak Ridge, TN 37830.

Richey, C. R. (1968). "Theoretical Analyses of Homogeneous Plutonium Critical Experiments." Nuclear Science & Engineering. 31:32-39.

Ryan, J. L., et. al., (1985). "Preparation of Acid Standards for and Determination of Free Acid in Concentrated Plutonium-Uranium Solutions." Analytical Chemistry. 57:1423.

5.0 ACKNOWLEDGEMENTS

The work performed for this report required the cooperation and assistance of a number of people, some of whom are listed below. Their contributions are greatly appreciated.

- o K. H. Rising (DOE-RL) for assistance in administrative matters.
- o E. D. Clayton for information and guidance on technical matters.
- o M. C. Burt for providing accurate chemical analyses of solutions in a timely manner.
- o J. H. Smith as Senior Reactor Operator in providing valuable advise, and assistance in performing the experiments.
- o L. N. Terry for typing, proofreading and guidance in preparation of this report.

APPENDIX A

ENGINEERING DRAWINGS OF THE CYLINDRICAL VESSEL SYSTEM

APPENDIX B

ENGINEERING DRAWINGS OF THE EXPANDABLE SLAB TANK SYSTEM

APPENDIX C

LEAST SQUARE FITS OF THE CRITICAL APPROACH DATA

APPENDIX C

LEAST SQUARE FITS OF THE CRITICAL APPROACH DATA

The value of the extrapolation for the expandable slab system requires the addition of one inch (2.54 cm). This is due to the zero position of the solution height measuring system having to be at the top of the bellows. The solution heights on all least square plots are in inches.

CFRP-PNC-2-14-2-046 DATE 1-14-85
14" CYL. H₂O REFL. CB&SB OUT




Figure C.1 Least Square Fit CFRP-PNC 046

CFRP-PNC-2-14-0-046R. DATE 1-17-85 14" CYL. H₂O REFL.
TEMP. = T. T. 20.3, C. A. R. 22.0, D. M. 17.7C.
C. B. & S. B. OUT SAMPLE #1087




Figure C.2 Least Square Fit CFRP-PNC 046R

CFRP-PNC-2-14-3-047 DATE 1/29/85
14" CYL. CONCRETE REFL. 100G (PU+U) L
CB & SB OUT SAMPLE #1088 TEMP. 22.1C B.P. 29.480




Figure C.3 Least Square Fit CFRP-PNC 047

CFRP-PNC-3-7.25-1-049A DATE 4-8-85 7.125" INSIDE WIDTH SLAB TANK
NO REFL. NORTH T.T. SIDE OFF. SAMPLE#1095A CB&SB OUT BACK-OFF




Figure C.4 Least Square Fit CFRP-PNC 049A

CFRP-PNC-3-7.25-1-050 DATE 4-10-85 7.125" INSIDE WIDTH SLAB TANK
ALL T.T. SIDES ON. NO REFL. SMPLE #1095B CB&SB OUT




Figure C.5 Least Square Fit CFRP-PNC 050

CFRP-PNC-2-14-1-051 DATE 4-26-85 CONC. SAMPLE#1096 D. M. CALC. HGTS.
14" CYL. BARE REFL. 10.8125" SITE TUBE ZERO
LUCITE CB&SB DOWN. B.P. 29.25 RM. TEMP. 17.1C DM 18.8C




Figure C.6 Least Square Fit CFRP-PNC 051

CFRP-PNC-3-4.925-2-054 DATE 9-5-85 SLAB TANK
T. T. TEMP. = 22.5C. BP=28.89
CB & SB OUT. SAMPLE# 1119 ZERO=0.4975"




Figure C.7 Least Square Fit CFRP-PNC 054

CFRP-PNC -3-4.925-2-055 DATE 9-8-85 SLAB TANK
CB & SB OUT. SAMPLE# 1120 ZERO=0.500"




Figure C.8 Least Square Fit CFRP-PNC 055

CFRP-PNC-9-7.825-1-056 DATE 9-9-85 SLAB TANK
T. T. TEMP. =22.7C BP=29.18
CB & SB OUT. SAMPLE# 1120 ZERO=0.500"




Figure C.9 Least Square Fit CFRP-PNC 056

CFRP-PNC-3-7.125-1-056A DATE 9-10-85 SLAB TANK
T. T. TEMP. =21.1C BP=29.25
CB & SB OUT. SAMPLE# 1121 ZERO=0.500"




Figure C.10 Least Square Fit CFRP-PNC 056A

APPENDIX D

CHEMICAL ANALYSES DATA OF THE IMPURITIES IN (Pu + U) NITRATE SOLUTIONS

APPENDIX D

CHEMICAL ANALYSES DATA OF THE IMPURITIES IN (Pu + U) NITRATE SOLUTIONS

The chemical analyses data for sample 1097 are for experiments 046R, 047 and 051. The analyses data for 1095 are for experiments 048, 049A and 050. The analyses data for 1119 are for experiment 054. The analyses data for 1121 are for experiments 055, 056 and 056a.

LOG NO. <u>#5</u>	Hanford Engineering Development Laboratory	SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS REPORT	
MATERIAL <i>Pu, U, C, NO₃)</i>			
SUBMITTED BY <i>E.S. Murphy</i>	SUBMITTER'S NO. <i>1087 - Q6048</i>	ANALYZED BY <i>JF</i>	DATE REPORTED <i>1/31/85</i>
ELEM. ENT	ELEM. ENT	ELEM. ENT	ELEM. ENT
Li <i>0.2</i>	Ga <i>30</i>	Pm	
Be <i>*</i>	Ge	Sm	
B <i>0.1</i>	As <i>0.4</i>	Eu	
F	Rb	Gd	
Na <i>30</i>	Sr	Tb	
Mg <i>10</i>	Y	Dy	
Al <i>200</i>	Zr <i>40</i>	Ho	
Si <i>30</i>	Nb	Er	
P <i>10</i>	Mo	Tm	
S <i>3</i>	Ru	Yb	
Cl <i>10</i>	Rh	Lu	
K <i>30</i>	Pd	Hf	
Ca <i>40</i>	Ag <i>*</i>	Ta	
Sc <i>30</i>	Cd <i>2</i>	W	
Ti <i>80</i>	In	Re	
V <i>0.2</i>	Sn	Os	
Cr <i>80</i>	Sb	Ir	
Mn <i>80</i>	Cs	Pt	
Fe <i>400 "</i>	Ba <i>40</i>	Au	
Co	La	Hg	
Ni <i>80</i>	Ce <i>40</i>	Tl	
Cu <i>20</i>	Pr	Pb	
Zn <i>4</i>	Nd	Bi	
TYPE OF ANALYSIS			
<input type="checkbox"/> QUALITATIVE	<input checked="" type="checkbox"/> SEMIQUANTITATIVE	<input type="checkbox"/> QUANTITATIVE	
<input type="checkbox"/> PARTS PER MILLION	<input checked="" type="checkbox"/> PARTS PER MILLION	<input type="checkbox"/> PARTS PER MILLION	
<input type="checkbox"/> PERCENT	<input type="checkbox"/> PERCENT	<input type="checkbox"/> PERCENT	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
APPR'X PRECISION ± FACTOR <i>_____</i>	APPR'X PRECISION <i>Factor 3</i>	APPR'X PRECISION ± FACTOR <i>_____</i>	
REMARKS: 			
* INTERFERENCES	REPORT APPROVED <i>Ray L.</i> FD-751 (92) 1-3-71		

Figure D.1 Spectrographic Analysis Report # 1087

SC #119, #120	Hewlett Engineering Development Laboratory		CCI SPEC. LAB.						
SPECTROCHEMICAL ANALYSIS REPORT									
MATERIAL Mixed Oxide									
SUBMITTED BY R. LLOYD	SUBMITTER'S NO.	ANALYZED BY JE	DATE REPORTED 10/24/85						
ELEM- MENT	#119	#120	ELEM- MENT	#119	#120	ELEM- MENT	#119	#120	ELEM- MENT
Ag	< 10	< 10	Hg			Re			Dy
Al	370	700	In			Rh			Er
As			Ir			Ru			Eu
Au			K	140	230	Sb			Gd
B	8	10	La			Sc			Ho
Ba			Li	< 1	< 1	Si	< 40	< 40	Lu
Be	< 2	< 2	Mg	20	40	Sn	< 10	< 10	Nd
Bi			Mo	60	80	Sr			Pr
Ca	100	250	Na	< 30	40	Ta			Sm
Cd	3	5	Nb	< 60	< 60	Th			Tb
Ce			Ni	270	320	Tl	< 35	< 35	Tm
Co	7	7	O ₂			U			Yb
Cr	340	400	P			V	< 50	< 50	
Cu	< 20	< 20	Pb	< 10	< 10	W			
Fe	1300	1600	Pd			Y			
Ga			Pt			Zn	20	40	
Ge			Pu			Zr			
Hf			Rb						
TYPE OF ANALYSIS									
<input type="checkbox"/> QUALITATIVE			<input checked="" type="checkbox"/> SEMIQUANTITATIVE			<input type="checkbox"/> QUANTITATIVE			
SYMBOL	MEANING	APP'X. CONC	SYMBOL	MEANING		SYMBOL	MEANING		
SS	MAJOR DETECTABLE CONSTITUENT		G	CONCENTRATION GREATER THAN		GX	CONC. GREATER THAN		
S	STRONG	GREATER THAN 1%	L	DETECTABLE CONCENTRATION LESS THAN		(LX)	(LESS THAN) CALIBRATED WORKING CURVE		
M	MODERATE	1% TO 0.01%	—	NOT DETECTED		NUMERICAL	<input checked="" type="checkbox"/> PARTS PER MILLION		
T	TRACE	LESS THAN 0.01%			VALUES		<input type="checkbox"/> PERCENT		
—	NOT DETECTED								
*	INTERFERENCE								
?	DETCTION UNCERTAIN. INTERFERENCE		APP'R'X. PRECISION ± FACTOR	2					
REMARKS:									
#119 = 1095 A ² B									
#120 = 1111 A									
					REPORT APPROVED Ray Co				
LABORATORY INFORMATION									
SPECTROGRAPH AND SOURCE		SIZE OF SAMPLE		METHOD OF ANALYSIS		PLATE NO.			

BD-7340-021 (3-73)

Figure D.2 Spectrographic Analysis Report # 1095

LOG NO. <u>123, 125</u>	Hanford Engineering Development Laboratory		SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS REPORT			
MATERIAL <u>WASTE SOLUTIONS</u>						
SUBMITTED BY <u>E. S. Murphy</u>		SUBMITTER'S NO. <u>See Below</u>	ANALYZED BY <u>PK</u>		DATE REPORTED <u>9/26/81</u>	
ELEM. ENT.	<u>123</u>	<u>125</u>	ELEM. ENT.	<u>123</u>	<u>125</u>	ELEM. ENT.
Li	<u>0.2</u>	<u>0.2</u>	Ga	<u>20</u>	<u>30</u>	Pm
Be	*	*	Ge			Sm
B	<u>100</u>	<u>100</u>	As			Eu
F			Rb			Gd
Na	<u>1000</u>	<u>1000</u>	Sr			Tb
Mg	<u>300</u>	<u>300</u>	Y			Dy
Al	<u>2000</u>	<u>2000</u>	Zr			Ho
Si	<u>2000</u>	<u>2000</u>	Nb			Er
P	<u>30</u>	<u>30</u>	Mo	<u>2</u>	<u>2</u>	Tm
S	<u>200</u>	<u>300</u>	Ru			Yb
Cl	<u>10</u>	<u>100</u>	Rh			Lu
K	<u>100</u>	<u>300</u>	Pd			Hf
Ca	<u>5</u>	<u>50</u>	Ag	*	*	Ta
Sc			Cd	<u>1</u>	<u>1</u>	W
Ti	<u>40</u>	<u>40</u>	In			Re
V	<u>0.1</u>	<u>0.3</u>	Sn			Os
Cr	<u>30</u>	<u>50</u>	Sb			Ir
Mn	<u>7</u>	<u>7</u>	Cs			Pt
Fe	<u>30</u>	<u>70</u>	Ba	<u>4</u>	<u>4</u>	Au
Co	<u>0.2</u>	<u>0.2</u>	La			Hg
Ni	<u>30</u>	<u>30</u>	Ce			Tl
Cu	<u>200</u>	<u>600</u>	Pr			Pb
Zn	<u>40</u>	<u>40</u>	Nd			Bi
TYPE OF ANALYSIS						
<input type="checkbox"/> QUALITATIVE	<input checked="" type="checkbox"/> SEMIQUANTITATIVE			<input type="checkbox"/> QUANTITATIVE		
<input type="checkbox"/> PARTS PER MILLION	<input checked="" type="checkbox"/> PARTS PER MILLION <i>mg/g</i>			<input type="checkbox"/> PARTS PER MILLION		
<input type="checkbox"/> PERCENT	<input type="checkbox"/> PERCENT			<input type="checkbox"/> PERCENT		
<input type="checkbox"/>						
APPR'X PRECISION ± FACTOR _____	APPR'X PRECISION ± FACTOR <u>3</u>			APPROX PRECISION ± FACTOR _____		
REMARKS: <u>SOLUTIONS WERE EVAPORATED + IGNITED AT 700°C. RESULTS ARE IN µG/S OF IGNITED RESIDUE</u> <u>123 = 1119 A</u> <u>125 = 1121 A</u>						
* INDEPENDENCE	REPORT APPROVED <i>Ray K</i>			BD-7340-021 (4-77)		

Figure D.3 Spectrographic Analysis Report # 1119 and 1121

APPENDIX E

CHEMICAL ANALYSES DATA OF THE REFLECTOR WATER SAMPLES

TABLE E.1 Water Sample Analysis - 046 and 046R



HANFORD ENVIRONMENTAL
HEALTH FOUNDATION

April 2, 1985

9475

Pacific Northwest Laboratory
209-E Building
200-E Area

Attn: Ray Lloyd

WATER SAMPLE ANALYSIS - TAMPER 046

One water sample, Tamper 046, has been analyzed for the parameters requested. Analysis was done in accordance with Standard Methods for Water and Wastewater, 15th ed.

<u>Parameter</u>	(mg/L) <u>Tamper 046</u>
pH	7.0
Total alkalinity	56.9
HCO_3 alkalinity	54
CO_3 alkalinity	<0.5
Total Dissolved Solids	105
Sulfate	3.8
Nitrate as N	0.10
Fluoride	0.12
Chloride	2.7
Zinc	0.13
Manganese	0.02
Lead	<0.005
Copper	<0.01
Chromium	<0.01
Iron	0.14
Cadmium	<0.005

If you have any questions, please contact Environmental Health Sciences.

M. K. Hamilton

M. K. Hamilton, CIH
Laboratory Director
Environmental Health Sciences

SPM

1628
P. O. BOX 100 RICHLAND, WASHINGTON 99352

TABLE E.2 Water Sample Analysis - 054 and 055



HANFORD ENVIRONMENTAL
HEALTH FOUNDATION

November 19, 1985

CO 10165

Pacific Northwest Laboratories
209-E Building, 200-E Area

Attn: R. Lloyd

WATER ANALYSIS

Following are the results of the water analysis of two samples received October 22. All analyses were performed in accordance with Standard Methods for the Examination of Water & Wastewater, 16th Ed.

Analysis	054 9-5-85	055 10-21-85
pH	7.3	7.3
Total alkalinity mg/L as CaCO ₃	49.1	46.6
Bicarbonate alkalinity mg/L as CaCO ₃	47	44
Carbonate alkalinity mg/L as CaCO ₃	<0.5	<0.5
Total dissolved solids mg/L	77	92
Sulfate mg/L	15	15
Nitrate (as N) mg/L	<0.1	<0.1
Fluoride mg/L	0.12	<0.1
Chloride mg/L	0.43	0.45
Cadmium mg/L	<0.0002	0.0007
Copper mg/L	0.02	<0.01
Chromium mg/L	<0.01	<0.01
Iron mg/L	0.08	1.49
Lead mg/L	<0.002	0.006
Manganese mg/L	<0.01	0.025
Zinc mg/L	<0.05	4.2

If there are any questions concerning this analysis, please contact us.

M. K. Hamilton


M. K. Hamilton, CIH
Laboratory Director
Environmental Health Sciences

lmk

P O BOX 100 RICHLAND WASHINGTON 99352

APPENDIX F

COMPOSITION OF CONCRETE REFLECTOR



APPENDIX F

COMPOSITION OF CONCRETE REFLECTOR⁻¹)

Two samples of the concrete reflector were analyzed for material composition by the use of two techniques - x-ray fluorescence (XRF) and isotope neutron activation analysis (INAA). The procedure involved obtaining a section of the center of the core and reducing the material to powder such that it would pass through a 140 mesh screen. Two aliquots were obtained. Each aliquot was analyzed by XRF and INAA).

The INAA procedure involved a 5-minute irradiation in the neutron multiplier facility, a 5-minute delay, and then a counting of 600 seconds to obtain Al, V, Ti, Mg, and Ca. Approximately 2 hours later the samples were recounted for 1000 seconds to obtain data for Na, K, and Mn. A summary of this data is found in Table F.1.

The XRF procedure involved pelletizing the material to form a thin wafer. The samples were then analyzed by both a Zr and then a Ag secondary source. These data are also shown in Table F.1. The reported error is the 1σ value for each sample and the weighted standard deviation for the mean value $[1/\sum(1/\sigma_i^2)]$.

Each sample was then separated into two aliquots. The water content was determined by the following procedure. Each of the samples was weighed, then heated to 100° for 1 hours, cooled, and reweighed. The samples were then heated to 1000° for 1 hour, cooled, and weighed. The results of the analyses are shown in Table F.2. Based on the data in Table F.2, the hydrogen content of the concrete is determined to be 1.05 ± 0.03 weight percent.

-1) Analyses performed by Elwood Lepel, Pacific Northwest Laboratory documented in a memorandum to Mike Durst, PNL, dated May 27, 1981.

TABLE F.1 Concentration of Elements in Concrete Reflector ^{-a)}

Element	Unit of Measure (Wt)	INAA ^{-b)}				XRF ^{-c)}				Average
		1	2	1	2	1	2	1	2	
Na	%	1.40 ± 0.01	1.46 ± 0.01	-	-	-	-	1.43 ± 0.007		
Mg	%	0.84 ± 0.46	1.00 ± 0.50	-	-	-	-	0.92 ± 0.34		
Al	%	5.27 ± 0.03	5.58 ± 0.03	4.0 ± 1.4	22.3 ± 1.5	4.3 ± 1.4	23.9 ± 1.6	4.79 ± 0.02	23.1 ± 1.1	
Si	%	-	-	<0.6	22.3 ± 1.5	<0.6	23.9 ± 1.6	23.1 ± 1.1		
P	%	-	-	-	0.40 ± 0.09	0.36 ± 0.09	0.38 ± 0.06			
S	%	-	-	0.67 ± 0.04	0.67 ± 0.04	0.67 ± 0.04	0.72 ± 0.3			
K	%	0.86 ± 0.14	0.70 ± 0.15	0.67 ± 0.04	0.67 ± 0.04	0.67 ± 0.04	0.72 ± 0.3			
Ca	%	10.8 ± 0.5	10.4 ± 0.5	13.8 ± 0.7	12.9 ± 0.7	12.0 ± 0.3				
Ti	ppm	3910 ± 340	2900 ± 200	2900 ± 200	2700 ± 200	3320 ± 122				
V	ppm	91.3 ± 3.6	85.5 ± 3.8	91 ± 31	140 ± 30	102 ± 3				
Cr	ppm	-	-	196 ± 21	134 ± 19	165 ± 14				
Mn	ppm	557 ± 4	520 ± 4	606 ± 36	577 ± 34	565 ± 3				
Fe	%	-	-	0.17 ± 3.45	3.29 ± 0.16	3.37 ± 0.12				
Co	ppm	-	-	<49	<49	<49				
Ni	ppm	-	-	57 ± 4	52 ± 6	54 ± 3				
Cu	ppm	-	-	42 ± 3	39 ± 3	40 ± 2				
Zn	ppm	-	-	176 ± 9	146 ± 8	161 ± 6				
Ga	ppm	-	-	12 ± 1	11 ± 1	11.5 ± 0.7				
Pb	ppm	-	-	34 ± 2	23 ± 2	28 ± 1				
As	ppm	-	-	33 ± 2	29 ± 2	31 ± 1				
Rb	ppm	-	-	21 ± 1	20 ± 1	20.5 ± 0.7				
Sr	ppm	-	-	280 ± 20	300 ± 30	290 ± 17				
Y	ppm	-	-	15 ± 1	15 ± 1	15 ± 0.7				
Zr	ppm	-	-	85 ± 7	87 ± 7	86 ± 5				
Nb	ppm	-	-	5.4 ± 1.0	5.3 ± 0.7	5.4 ± 0.6				
Mo	ppm	-	-	6.9 ± 0.8	5.6 ± 0.8	6.2 ± 0.6				

(a) Reported error is the 1σ value for each sample. The weighted standard deviation is reported for the average.

(b) Isotope neutron activation analysis method.

(c) X-ray fluorescence method.

TABLE F.2 Water Content of Concrete Reflector

Sample Number	Weight Loss After Heating to 100°C (wt%) ^{-a)}	Weight Loss After Heating to 1000°C (wt%) ^{-a)}
A1	3.0	9.2
A2	2.9	9.2
B3	3.1	9.6
B4	3.3	9.8
Average	3.1 ± 0.2	9.4 ± 0.3

(a) Referenced to original sample weight.

The major constituents of the concrete are listed in Table F.3. The unidentified mass from the analysis was assumed to be oxygen. The density of the concrete was determined to be 2.3 ± 0.1 g/cm³. The computed atom densities for each element are also listed in Table F.3.

TABLE F.3 Calculated Atom Densities for the Concrete Reflector

Element	Weight Percent	Atom Density (Atoms/b·cm)
O	51.91	4.553E-2
Si	23.10	1.154E-2
Ca	12.00	4.201E-3
Al	4.79	2.491E-3
Fe	3.37	8.468E-4
Na	1.43	8.728E-4
H	1.05	1.462E-2
Mg	0.92	5.310E-4
K	0.72	2.584E-4
S	0.38	1.663E-4
Tl	0.33	9.667E-5

DISTRIBUTION

No. of
Copies

OFFSITE

2 Division of Fuels & Reprocessing
NE-551, U. S. Department of Energy
Washington, DC 20545

D. E. Bailey, Director
R. B. Chitwood

48 Oak Ridge National Laboratory
Martin Marietta Energy Systems, Inc.
Bldg. 7601
PO Box X
Oak Ridge, TN 37830

A. D. Blakeman
W. D. Burch (3)
B. G. Eads
M. J. Feldman
W. S. Groenier
M. J. Haire (10)
C. M. Hopper
H. T. Kerr
R. C. Kryter
S. A. Meacham
J. T. Mihalczo
L. C. Oakes
R. T. Primm, III
G. E. Ragan
C. W. Ricker
R. W. Sharpe (2)
G. R. Smolen (5)
J. G. Stradley (5)
J. T. Thomas
R. M. Westfall
G. E. Whitesides
R. G. Wymer
O. O. Yarbro
ORNL Patent Section
ORNL-RC
ORNL Records (3)

No. of
Copies

OFFSITE

F. P. Baranowski
1110 Dapple Grey Court
Great Falls, VA 22066

R. Little
Princeton Plasma Physics Laboratory
James Forrestal Campus
PO Box 451
Princeton, NJ 08544

M. J. Ohanian, Associate Dean for Research
College of Engineering
University of Florida
300 Weil Hall
Gainesville, FL 32611

J. F. Proctor, Sr. Technical Specialist
E. I. du Pont de Nemours and Company
Savannah River Laboratory
Aiken, SC 29801

M. J. Rohr, Program Manager
Consolidated Fuel Reprocessing Program
Energy Programs Division
Energy Technology Branch
Oak Ridge, TN 37831

Office of Assistant Manager
Energy Research and Development
DOE-ORO
Oak Ridge, TN 37831

48 DOE Technical Information Center
 (Given distribution under
 S-86T Consolidated Fuel
 Reprocessing Program
 Criticality Data
 Development Category)

No. of
Copies


ONSITE

4 DOE Richland Operations Office

K. W. Bracken
D. K. Jones
J. J. Sutey
K. H. Rising

24 Pacific Northwest Laboratory

W. W. Ballard
S. R. Bierman
E. D. Clayton
J. L. McElroy
R. C. Lloyd (10)
L. N. Terry (CML Record Copy) (2)
H. H. Van Tuy1
Publishing Coordination (2)
Technical Information (5)



ABBREVIATIONS	
ANSI	AMERICAN NATIONAL STANDARD
BC	BOLT CIRCLE
CAT	CATALOG
CFRP	CONSOLIDATED FUEL REPROCESSING PROGRAM
CL	CENTER LINE
CO	COMPANY
COL	COLUMN
CTR	CENTER
CUST	CUSTOMER
CYL	CYLINDRICAL
DET	DETAIL
DIA	DIAMETER
DIM	DIMENSION
EQ	EQUAL
FLEX	FLEXIBLE
FS	FOR SIDE
FURN	FURNISHED
GA	GAGE
H.D.	HEAVY
HEX	HEXAGON
ID	INSIDE DIAMETER
KIP	(1000)
L	LONG
MATERIAL	MATERIAL
MAT	MATERIAL
NUMBER	NUMBER
ASTM TAPER THREADS	AMERICAN STANDARD TAPER THREADS
OS	BEAR SIDE
OD	OUTSIDE DIAMETER
PL	PLATE
P/N	PART NUMBER
PSI	POUNDS PER SQUARE INCH
PT	Liquid Penetrant Examination
QTY	QUANTITY
R	REGULAR
RAD	RADIUS
RE-BAR	REINFORCING BAR
REF	REFERENCE
REQD	REQUIRED
SCHED	SCHEDULE
SP	SPACED
SST	STAINLESS STEEL
SYM	SYMMETRICAL
TIR	TOTAL INDICATOR READINGS
Typ	TYPICAL
UNC	WHIPPLE COARSE THREAD
VAC	VOLT ALTERNATING CURRENT
304 SST	ASTM 304 SERIES STAINLESS STEEL


GENERAL NOTES (EXCEPT OTHERWISE SPECIFIED)

- ALL MATERIALS TO BE AS SPECIFIED OR APPROVED EQUAL.
- REMOVE ALL BURRS & BREAK ALL SHARP EDGES.
- ALL MOVING PARTS SHALL OPERATE SMOOTHLY & WITHOUT BINDING.
- STAINLESS STEEL SHALL BE IN ACCORDANCE WITH THE FOLLOWING ASTM SPECIFICATIONS:

 - PLATE, SHEET & STRIP ASTM A 290 - FINISH 20
 - BARS ASTM A 360
 - TUBES ASTM A 299
 - PIPE ASTM A 312

- ALL CARBON STEEL SHALL BE IN ACCORDANCE WITH ASTM A-36.
- ALL A-36 WELDING TO BE MADE WITH E-FORK ELECTRODES.
- BOLTS SHALL BE ASTM A 197.
- FERROUS METALS SHALL BE PAINTED WITH ONE COAT OF ZINC CHROMATE PRIMER ALLOY TYPE AND 2 COATS SEMIGLOSS ENAMEL COLOR TO BE SELECTED BY CUST.
- PIPE END PREPARATION WHERE REQUIRED SHALL HAVE 32 1/2" BEVEL 5 & 1/2" WITH 1/16" LANDS + 0-1/32.
- DIMENSIONS AND TOLERANCES ARE IN ACCORDANCE WITH ASME Y14.5.
- TOLERANCES FOR P/N 12
 - FRACTIONAL ± 1/64
 - DECIMAL ± .005
 - ANGULAR ± 1/2°
- TOLERANCES FOR P/N 4, 5, 6, 7 & 8, 9, 10
 - FRACTIONAL ± 1/32
 - DECIMAL ± .005
 - ANGULAR ± 1/8°
- TOLERANCES FOR P/N 1, 2, 3, 11 & 12
 - FRACTIONAL ± 1/16

14. THE FOLLOWING PART NUMBERS MAY BE REPLACED BY THE ANNULAR TA ASSEMBLY (N-2-05741), 5, 6, 8(1), 10, 11, 12, 17(1), 19(1), 23(1), 24(1), 30(12), 31(6), AND 38(6).



NOZZLE IDENTIFICATION

- A** PROCESS DRAIN
- B** PROCESS FEED
- C** LIQUID LEVEL
- D** LIQUID LEVEL
- E** SPARE
- F** WATER DRAIN

DETAIL I
AS NOTED
DETAIL II
SIMILAR EXCEPT AS NOTED

SCALE: 1" = 1"

QTY	PN	DESCRIPTION	WASH/REF
1		ASSEMBLY	
1	N-2	N ₂ O TANK	SHEET 1
2	9	COVER	SHEET 2
1	4	LARGE CYL TUBE	SHEET 3
1	5	SMALL CYL TUBE	SHEET 3
2	6	CLEVIS	SHEET 3
1	7	COVER	SHEET 4
1	8	COVER	SHEET 4
2	9	PORT COVER	SHEET 4
1	10	SHIELD	SHEET 4
1	11	SHIELD	SHEET 4
1	12	SPool PIECE	SHEET 4
1	13	BUmp VALVE	SHEET 5
2	14	SOLenoid CAT NO CR 0500 R 107 ASA SIDE MOUNTED 230 VAC	GENERAL (ELECTRIC)
1'	15	KNIFE GATE VALVE CAT NO 0300 METAL SEATED ROUND PORT 304 SST ACTUATOR CAT NO CR0300 (ON-OFF) 30-100 PSI AIR SUPPLY	DE ZURK
2	16	FEMALE CONNECTOR CAT NO 55-3200-T-32	SWAGELOK
2	17	MALE CONNECTOR CAT NO 55-600-T-17	SWAGELOK
1	18	UNION ELBOW CAT NO 55-400-9	SWAGELOK
2	19	3/4" HEXAGON HEAD PLUG	SHEET SST
2	20	SS REARUP CLAMP	CUST FURN.
1	21	O-RING CAT NO 07-394 (VITON-A)	PARKER
1	22	O-RING CAT NO 07-395 (VITON-A)	PARKER
3	23	GASKET 1/8" THICK 3 1/2" OD X 3 1/2" ID HOLES TO MATCH P/N 9	TEFLON
1	24	GASKET 1/8" THICK 3 1/2" OD X 3 1/2" ID HOLES TO MATCH FLANGE	TEFLON
1	25	1/8" GASKET FOR 3" ISOP FLANGE	TEFLON
2	26	O-RING 2 1/2" OD X 3 1/2" ID DASH NO 313 (VITON-A)	TEFLON
2	27	O-RING 3 1/2" OD X 3 1/2" ID DASH NO 341 (VITON-A)	J. CRAKE PACKING CO.
2	28	O-RING 1" OD X 1 1/4" ID DASH NO 215	J. CRAKE PACKING CP
2	29	1/8" GASKET (RECTANGULAR) TO MATCH COVER P/N 3 & TANK OPENING AT P/N 2	TEFLON
24	30	SOCKET HEAD CAP SCREW 1/4"-20 UNC-2A X 5/16" L	SHEET SST
12	31	HEX HEAD BOLT 3/8-16 UNC-2A X 2 1/4"	SHEET SST
6	32	HEX HEAD BOLT 7/16-8 UNC-2A X 1 7/8" L	SHEET SST
4	33	HEX HEAD BOLT 5/8-11 UNC-2A X 3 1/4" L	SHEET SST
20	34	HEX BUT 3/8-16 UNC-2A	SHEET SST
6	35	HEX SOCKET BUTTON HEAD CAP SCREW 6-32 UNC-2A X 2 1/4" L	SHEET SST
6	36	HEX BUT 8-32 UNC-2A	SHEET SST
1	37	LOCK BUT 1/4" ID UNC-2A	SHEET SST
30	38	ABR WASHERS 3/8" TYPE B-2	SHEET SST
2	39	CLEVIS PIN 3/8" DIA X 1 3/4" L WITH 1/8" COTTER PIN HOLE	SHEET SST
2	40	COTTER PIN 3/32" X 1" L	SHEET SST
1	41	UNION CAT NO 55-800-4	SWAGELOK
1	42	UNION ELBOW CAT NO 55-800-9	SWAGELOK
1	43	ANULAR TA ASSEMBLY	N-2-05741
1	44	SUPPORT RING	SHEET 2

WELDING AND INSPECTION REQUIREMENTS

<input checked="" type="checkbox"/>	WELDING IN MAGNETIC FIELD
<input type="checkbox"/>	WELDING IN VIBRATION
<input type="checkbox"/>	PERFECTO EPOXY
<input type="checkbox"/>	PERFECTO PAINT
<input type="checkbox"/>	SYNTHETIC PAINT
<input type="checkbox"/>	LIQUID PAINT
<input type="checkbox"/>	RAZORBLADE SCR
<input type="checkbox"/>	LEAF TAPE
OTHER NOTES	

P-42 Cat	7/19	ISSUE DATE 12/6/19 QA# 758
APPROVED FOR USE IN NUCLEAR POWER PLANTS	BY	U. S. Department of Energy Advanced Operations Office
		PACIFIC NORTHWEST LABORATORY OPERATED BY Battelle Memorial Institute
WORKERS	2000	
8000	2000	
4000	1000	
2000	500	
1000	250	
500	125	
250	50	
125	25	
50	10	
25	5	
10	2	
5	1	


CFRP ASSEMBLY

ITEMS IN 5-DIVISIONS

NOT RECD. DATE ISSUED DATE REVISED DATE



H-2-33856 115

REFERENCE DRAWINGS	COMMENTARY	REVISED	REVISIONS	P/N	GENERAL	REVISION	P/N	GENERAL	REVISION	P/N
NOT USED ON										



SECTION A-A


SCALE 1:10'



(2) H₂O TANK

SCALE 1:10'

MATL A 3G



H-2-3385G						25
REF ID:	001	DESIGNER:	WILLIAM J. COOPER	REVISIONS:	1	ISSUE DATE: 4/26/12
REFERENCE DRAWINGS:		DOCUMENT PART NUMBER:	H-2-3385G	CHARGE PAYMENT NO.:		QA# 750
NEXT USED ON:		DRAWING STATUS:	7	HOT RECD:		

J-ROUND ID = 8' DEEP
(1/2) HOLE EQ 20'

SYMM ABOU CL

26.500'

25.395' .000

26.7' AC

OD TO MATCH OD OF SHELL




SHEET .031 THICK
(28 GA)

27.000' ID





0.068 TIR

④ LARGE CYL TANK

SCALE 1" = 10'
MATERIAL 304 L SST



SECTION H-H
SCALE - FULL



△ SECTION L-L
SCALE 2'-0"

(5) SMALL CYL TANK
SCALE 1"-1"
MATERIAL 304 L SST

△ (44) SUPPORT RING



SCALE 1"-1"
MATERIAL 300 SERIES SST
PN 44 NOT SHOWN IN ASSEMBLY
FOR CLARITY. USED AS
REQUIRED

Drawing No.		Title		Drawing No.		Title		Drawing No.		Title	
44	Support Ring	44	Small Cyl Tank	L-L	Front View	44	Front View	L-L	Front View	44	Front View
44	Support Ring	44	Small Cyl Tank	L-L	Front View	44	Front View	L-L	Front View	44	Front View
44	Support Ring	44	Small Cyl Tank	L-L	Front View	44	Front View	L-L	Front View	44	Front View
44	Support Ring	44	Small Cyl Tank	L-L	Front View	44	Front View	L-L	Front View	44	Front View

REV. NO. 1 DATE 1/25/79 BY 750
U.S. Department of Energy
Reactor Operations Office
PACIFIC NORTHWEST LABORATORY
OPERATED BY Battelle Memorial Institute

CFRP
PROCESS TANKS


REV. NO. 1 DATE 1/25/79 BY 750
H-2-33856 1 3 1




7 COVER
SCALE $\frac{1}{4}'' = 1'$

MATL 304 L SST


9 PORT COVER
SCALE $\frac{1}{4}'' = 1'$
MATL $\frac{3}{8}$ " PLEXIGLASS







2 NO ISSUE 11/16/79
QA# 758

DRAWING FOR CONFORMANCE WITH DESIGN CRITERIA		REV
BY	DATE	FOR
APPROVED	11/16/79	RC LLOYD SCL
BY W. Zeller	11/16/79	11/16/79
REVISIONS	NOT RECD	CFRP
COMMITTEE/PART ISSUE NO	DATE	TANK COVERS & SHIELD
REFERENCE DRAWINGS	CHECK P/T ISSUE NO	CFRP
NEXT USED ON	DRAWING STATUS	209 E 2503
10	NONE	H-2-33856 415








A.5

SEE SHEET 8 FOR DUMP LINE MODIFICATIONS

LEVEL INDICATION LH



EE SHEET 6



- GENERAL NOTES:
1. UNLESS OTHERWISE SPECIFIED TOLERANCES ARE FRACTIONAL $\pm \frac{1}{32}$ ANGULARITY $\pm 0^{\circ}30'$ DECIMALS $\pm .005$
 2. MACHINED SURFACES TO BE 63/12 IN ACCORDANCE WITH ASA B46.1 1962
 3. ALL WELDING TO BE PER HWS 4924 S
 4. ROUND ALL EDGES & CORNERS TO FINGER SMOOTHNESS.
 5. MTL TO BE AS SPECIFIED OR APPROVED EQUAL.
 6. $\frac{1}{2}$ TYPE SS-1 TUBING - CLOSE PITCH-316 SST/W $\frac{1}{2}$ TYPE HMW FITTING EACH END - OVERALL LG $30\frac{1}{2}$.
 7. WITH BELLows COMPRESSED AGAINST PART 55 SET VERNIER (PART 57) TO READ 0 & ATTACH CALIPER JAWS TO PARTS 10 & 19 (USING PARTS 58 & 59 LOCATED TO SUIT) REMOVE DEPTH SAGE BAR FROM PORT 57 & GRIND JAWS TO PERMIT VERNIER TO GO 0 MINUS:030-.050

SIMILAR TO
DETAIL III

CONT. E-H-1		REV. NO.		DWG. NO.		DRAWING TITLE	
NO.	DESCRIPTION	REV. BY	APPR. BY	FOR DATE	DATE	REFERENCE DRAWINGS	
	REVISIONS					CLASSIFICATION	MANUFACTURER

B.1

QTY.	REF. NO.	DESCRIPTION
X 1	ASSEMBLY	H-3-32570 SN #2
1	2 SIDE PLATE	A
1	3 SIDE PLATE	#2
2	4 LATTICE REINFORCING	#3
1	5 FRAME	#4
1	6 SIDE PLATE	#4
1	7 SIDE PLATE	#4
1	8 SHAFT SUPPORT	#5
1	9	#5
1	10	#5
1	11	#5
1	12 DRIVE SHAFT	#5
1	13	#6
1	14	#6
1	15	#6
26	16 SPACER	#6
13	17 SCREW	#6
13	18 RH ACME NUT	#6
13	19 LH ACME NUT	#6
1	20 BRACKET	#6
2	21 VALVE SEAT	#6
2	22 EXTENSION ROD	#6
4	23 U-BOLT	#6
2	24 CYLINDER, MILLER, #1/2 AGI-3	
2	25 BEARING, BOSTON #B1016-12	
2	26 O-RING, LINEAR #II-259	
13	27 WORM, BOSTON #D1407K	
13	28 KEY, $\frac{1}{8}$ SQ AMER STD, $1\frac{1}{8} - \frac{1}{16}$ LG, STL	
26	29 FLG'D BEARING, BOSTON #FB-1614-6	
13	30 WORM GEAR, BOSTON #DB1600, 12 PITCH	
4	31 SPACER, $\frac{1}{8}$ OD X $\frac{1}{16}$ ID X LG AS REQD, 304 SST	
X	32 FLEX-HOSE, AMERICAN SEE NOTE 6	
1	33 BELLows, CROLL-REYNOLDS, DWG #D-9590	
2	34 WELD-ELL, $\frac{1}{2}$ STD LR, SST	
1	35 ELBOW-ELL, SCR, $\frac{1}{2}$ STD, SST	
3	36 UNION, $\frac{1}{2}$ STD, SST	
X	37 SHORT NIPPLE, $\frac{1}{2}$ STD, SST, END ONLY	
5	38 FLG'D BEARING, BOSTON NEFB-1014-14 CUT TO	
PAIR	39 MITER GEAR, BOSTON #L102Y, 12 PITCH	
2	40 TUBING, $2\frac{3}{8}$ OD X $2\frac{1}{4}$ ID X 27 LG, SST	
104	41 SCREW, $\frac{5}{16}$ - 18UNC-2A X $1\frac{1}{2}$ LG, SST, HEX HD	
192	42 NUT, $\frac{5}{16}$ - 24UNC-2B, HEX, SST	
27	43 NUT, $\frac{3}{8}$ - 16UNC-2B, HEX, SST (REG)	
216	44 NUT, $\frac{1}{2}$ - 18UNC-2B, HEX, SST (REG)	
3	45 BOLT, $\frac{3}{8}$ - 16UNC-2A X 1" LG, HEX HD, SST	
4	46 BOLT, $\frac{1}{2}$ - 20UNC-2A X 1" LG, HEX HD, SST	
4	47 NUT, $\frac{1}{2}$ - 20UNC-2B, HEX, SST (REG)	
13	48 FLANGED BEARING, BOSTON # FB-810-5	
1	49 HANDLE, REED TOOL CAT. NO CH-6	
19	50 POLLPIN, ESNA NO 79-028-125-1250	
1	51 POLLPIN, ESNA NO 79-028-125-1500	
2	52 FLANGED BEARING, BOSTON # FB-1012-10	
	BALL VALVE - $\frac{1}{2}$ TYPE D33-77	
1	53 WITH PILO PNEUMATIC REMOTE OPERATOR	JAMESBURG
4	54 BEARING, BOSTON GEAR NO B4652-32	
1	55 SPACER: $\frac{64}{33}$ OD X $\frac{15}{32}$ ID X 4.000 LG	SST
1	56 SPACER: $\frac{64}{33}$ OD X $\frac{15}{32}$ ID X .375 LG	SST
1	57 CALIPER-DIAL, VERNIER	BY CUSTOMER
6	58 MACH BOLT: $\frac{6}{32}$ UNC-2A X $\frac{1}{2}$ LS	SST
6	59 LOCKWASHER ~ $\frac{1}{2}$	SST

PARTS LIST CONTINUED ON SHEET 2

H-2-32570

SH REV B/2


CHECK PRINT	COMMENT PRINT	APPROVED FOR CONST	U. S. ATOMIC ENERGY COMMISSION
DATE	NAME	DATE	HANFORD ATOMIC PRODUCTS OPERATION
6/11/64		6/11/64	GENERAL ELECTRIC
APPROVED FOR PURCHASE		APPROVED FOR DESIGN	
6/11/64		6/11/64	
SCALE: NONE		APPROVED FOR DESIGN	
6/11/64		6/11/64	
DRAWN: A.H.		APPROVED FOR DESIGN	
6/11/64		6/11/64	
DESIGNED: V.HILL		APPROVED FOR DESIGN	
6/11/64		6/11/64	
PREDICTED: V.HILL		APPROVED FOR DESIGN	
6/11/64		6/11/64	
CLASIFIED: D.W. HULL		APPROVED FOR DESIGN	
6/11/64		6/11/64	
MANUFACTURED: D.W. HULL		APPROVED FOR DESIGN	
6/11/64		6/11/64	
INSPECTED: D.W. HULL		APPROVED FOR DESIGN	
6/11/64		6/11/64	
TESTED: D.W. HULL		APPROVED FOR DESIGN	
6/11/64		6/11/64	
CRITICAL MASS FACILITY		APPROVED FOR DESIGN	
209E		4700	
H-2-32570-118		APPROVED FOR DESIGN	

TANK ASSEMBLY

CRITICAL MASS FACILITY

209E 4700

H-2-32570-118




2	MOVED S FOR PART
1	VAS E
NO	


TUD (NEAR SIDE)
PE CFF - 304 SST
-2A UNC-2A

ER WELDING (96 FEQD)

R TYP



PIPE - 1 1/2 SCH 405
PART 3 ONLY



H-2-32570 2 1/8 2

VIEW "A-A"


CHECK PRINT		COMMENT PRINT		APPROVED FOR CONST.		U. S. ATOMIC ENERGY COMMISSION	
1	2/1/73	3	DATE	BY	FOR	DATE	HANFORD ATOMIC PRODUCTS OPERATION
SCALE NONE							
DRAWN		APPROVED FOR DESIGN		GENERAL ELECTRIC			
CHECKED		BY		FOR		DATE	
ISSUED		DATE		BY		FOR	
DESIGNER		DATE		BY		FOR	
PROJECT		INSTR. NO.		CLASSIFIED BY		CLASSIFICATION	
NA-A TO ALLOW		C-00932		W. J. COFFMAN		C-700	
T 2 OF 7		REF. NO.		DATE		BLDG NO.	
DESCRIPTION		DWG NO.		NEXT USED ON		REV. NO.	
REVISIONS							
REV. NO.		APP'D BY		FOR DATE		NEXT USED ON	
DATE							
REFERENCE DRAWINGS							
CLASSIFIED BY							
DATE							
B.2							


BELLows TANK
SIDE PLATES

Critical Mass Facility

BLDG NO. 209E INSTR. NO. 4700


REV. NO. H-2-32570 2 1/8






VIEW "C - C"
TYP 13 PLATES

- LOCATE AT TRUE POSITION WITHIN
+ OR - TOLERANCE ON
EACH DIMENSION SHOWING HOLE LOCATION




STORY IV




SEE SHEET NO 1 SAME DWG NO FOR
GENERAL NOTES.

SECTION B-3
(TYPE 2 PLACES)


H-2-32570 3/8 1





SECTION D-D

SECTION E-E

(6) A: NOTED
314-L SST(7) A: NOTED
304-L SST


NO.	Z 1 1/2 - 8 BL		205	GEOL	PH				DRAWING TITLE	REFERENCE DRAWINGS	NEXT USED ON
	REVISIONS	REV. BY									
M	2	Z 1 1/2 - 8 BL	205	GEOL	PH						
		REMOVED GLASS AND GASKET TO BUTT PLATE TO Z 1 1/2 - 8	10-23-85	10-23-85							
F	1	UPPER EEE C. CHAMFER UPPER EEE G. TO UPDATED PER SPEC SHEET 2-7-70	AC	1/2	FL	1/4					
-		UPPER EEE C. CHAMFER UPPER EEE G. TO UPDATED PER SPEC SHEET 2-7-70	AC	1/2	FL	1/4					









B.4

CHECK PRINT	COMMENT	APPROVED FOR CONST
1/20/85	1/23	APPROVED FOR PURCHASE
SCALE: NONE		
INITIALS: HILL		
APPROVED FOR DESIGN		
INITIALS: HILL		
REVIEWED BY: HILL DATE: 1/23/85		
APPROVED BY: HILL DATE: 1/23/85		
FIRESTICK: HILL DATE: 1/23/85		
CLASSIFIED BY: HILL DATE: 1/23/85		
DRAFTED BY: HILL DATE: 1/23/85		
RECHECKED BY: HILL DATE: 1/23/85		
APPROVED BY: HILL DATE: 1/23/85		
CRITICAL MASS FACILITY		
209E 2700		
DRAFT NO. H-7-32570 148		

TANK DETAIL

NONE




10	11	12	13																																																		
QTY.	P/N NO.	DESCRIPTION																																																			
 <p>(1) $\frac{877}{875}$ DIA</p>																																																					
 <p>-$\frac{3}{8}$ SCH 40S PIPE</p> <p>30°</p> <p>$\frac{1}{16}$ TYP BOTH ENDS</p> <p>SECTION H-H (TYP)</p>																																																					
 <p>$\frac{1}{2}$</p> <p>$\frac{877}{875}$ DIA</p> <p>30°</p> <p>$\frac{1}{16}$ TYP BOTH ENDS</p> <p>SECTION J-J (TYP)</p>																																																					
 <p>(1) $\frac{877}{875}$ DIA</p>																																																					
 <p>-$\frac{3}{8}$ SCH 40S PIPE</p> <p>30°</p> <p>$\frac{1}{16}$ TYP BOTH ENDS</p> <p>SECTION K-K</p>																																																					
 <p>$\frac{1}{2}$</p> <p>$\frac{627}{625}$ DIA</p> <p>30°</p> <p>$\frac{1}{16}$ TYP BOTH ENDS</p> <p>SECTION L-L</p>																																																					
 <p>(1) $\frac{877}{875}$ DIA</p>																																																					
 <p>(1) $\frac{877}{875}$ DIA</p>																																																					
<p>SEE SHEET NO 1 SAME DWG NO FOR GENERAL NOTES.</p>																																																					
H-2-32570 5/8 1																																																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">CHECK</td> <td style="width: 15%;">PRINT</td> <td style="width: 15%;">COMMENT</td> <td style="width: 15%;">APPROVED FOR CONST.</td> <td style="width: 15%;">ST. FOR EXCS. BY</td> </tr> <tr> <td>1/4</td> <td>1/4</td> <td>1/4</td> <td>1/4</td> <td>1/4</td> </tr> <tr> <td colspan="5">APPROVED FOR PURCHASE</td> </tr> <tr> <td colspan="5">ST. FOR EXCS. BY</td> </tr> <tr> <td colspan="5">SCALE NONE</td> </tr> <tr> <td colspan="5">DRAWN BY A.H.S. APPROVED FOR DESIGN</td> </tr> <tr> <td colspan="5">DESIGNER J.D.P. DATE 7-16-64</td> </tr> <tr> <td colspan="5">REVIS. BY W.H. DATE 7-16-64</td> </tr> <tr> <td colspan="5">LSD BY V.HILL DATE</td> </tr> <tr> <td colspan="5">PROJECT E-6953</td> </tr> </table> <p>U. S. ATOMIC ENERGY COMMISSION PACIFIC NORTHWEST LABORATORY BATTELLE MEMORIAL INSTITUTE</p>				CHECK	PRINT	COMMENT	APPROVED FOR CONST.	ST. FOR EXCS. BY	1/4	1/4	1/4	1/4	1/4	APPROVED FOR PURCHASE					ST. FOR EXCS. BY					SCALE NONE					DRAWN BY A.H.S. APPROVED FOR DESIGN					DESIGNER J.D.P. DATE 7-16-64					REVIS. BY W.H. DATE 7-16-64					LSD BY V.HILL DATE					PROJECT E-6953				
CHECK	PRINT	COMMENT	APPROVED FOR CONST.	ST. FOR EXCS. BY																																																	
1/4	1/4	1/4	1/4	1/4																																																	
APPROVED FOR PURCHASE																																																					
ST. FOR EXCS. BY																																																					
SCALE NONE																																																					
DRAWN BY A.H.S. APPROVED FOR DESIGN																																																					
DESIGNER J.D.P. DATE 7-16-64																																																					
REVIS. BY W.H. DATE 7-16-64																																																					
LSD BY V.HILL DATE																																																					
PROJECT E-6953																																																					
<p>BELLOWS TANK DETAIL</p> <p>209 E 4700</p> <p>H-2-32570 5/8</p>																																																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">I WAS SHEET 5 OF 7</td> <td style="width: 25%;">REV. 4.3.65</td> <td style="width: 25%;">P.N. 7501</td> <td style="width: 25%;">DWG. NO.</td> </tr> <tr> <td>NO.</td> <td>DESCRIPTION</td> <td>REV. BY DATE</td> <td>APPRD BY DATE</td> </tr> <tr> <td>REVISIONS</td> <td>REFERENCE DRAWINGS</td> <td>FOR DATE</td> <td>NEXT USED ON</td> </tr> </table>				I WAS SHEET 5 OF 7	REV. 4.3.65	P.N. 7501	DWG. NO.	NO.	DESCRIPTION	REV. BY DATE	APPRD BY DATE	REVISIONS	REFERENCE DRAWINGS	FOR DATE	NEXT USED ON																																						
I WAS SHEET 5 OF 7	REV. 4.3.65	P.N. 7501	DWG. NO.																																																		
NO.	DESCRIPTION	REV. BY DATE	APPRD BY DATE																																																		
REVISIONS	REFERENCE DRAWINGS	FOR DATE	NEXT USED ON																																																		

1	I WAS SHEET 5 OF 7	4.3.65	COPY	P.N.	7501	NO.	DWG. NO.	DRAWING TITLE
	DESCRIPTION	REV. BY DATE	APPRD BY DATE	FOR DATE	REFERENCE DRAWINGS			
	REVISIONS				NEXT USED ON			


B.5

CHECK	PRINT	COMMENT	APPROVED FOR CONST.
1/4	1/4	1/4	1/4
APPROVED FOR PURCHASE			
ST. FOR EXCS. BY			
SCALE NONE			
DRAWN BY A.H.S. APPROVED FOR DESIGN			
DESIGNER J.D.P. DATE 7-16-64			
REVIS. BY W.H. DATE 7-16-64			
LSD BY V.HILL DATE			
PROJECT E-6953			
CLASSIFICATION			
209 E 4700			
H-2-32570 5/8			


5




PART NO	A	B
12	44 $\frac{11}{16}$	7
13	11 $\frac{9}{16}$	6
14	54 $\frac{1}{8}$	14
15	39 $\frac{3}{2}$	6





(16) 304 SST



(20) 304-L



(17) 416 SST
HARDEN TO RC 35/10



(18) BRASS


(19) ERASS

10 11 12 13

QTY. NO DESCRIPTION


(3) $\frac{7}{16}$ DIA

Technical drawing showing a top view of a rectangular part. It has a central horizontal slot with a width of $\frac{7}{8}$. On either side of the slot, there are relief features with a depth of $\frac{3}{8}$. The overall width of the part is $\frac{7}{4}$. Below the slot, there is a note "MIN THD RELIEF". The part is labeled "1/13 UNC-2A" at the bottom left and ".625 DIA .625 DIA" at the bottom right.




(22) 304 SST

Technical drawing showing a top view of a rectangular part. It has a central horizontal slot with a width of $\frac{7}{8}$. On either side of the slot, there are relief features with a depth of $\frac{3}{8}$. The overall width of the part is $\frac{7}{4}$. Below the slot, there is a note "MIN THD RELIEF". The part is labeled "1/13 UNC-2A" at the bottom left and ".625 DIA .625 DIA" at the bottom right.



(23) 304 SST




SEE SHEET NO 1 SAME DWG NR FOR GENERAL NOTES.


(21) 304 SST

H-2-32570 6/8/1

1	2	3	4	5	6	7	8	9	10	11	12	13
NO	DESCRIPTION	REV. BY	APPR. BY	FOR DATE	REFERENCE DRAWINGS	DRAWING TITLE						
RF ISIONS												

CHECK PRINT	COMMENT PRINT	APPROVED FOR CONST
1/13/65	1/13/65	1/13/65
APPROVED FOR PURCHASE		1/13/65
SCALE NONE		
PRINT A/R:	DATE APPROVED FOR DESIGN	1/13/65
REVISIONS	DATE APPROVED FOR BLDG	1/13/65
ITEM K-32570	DATE APPROVED FOR TEST	1/13/65
ONE DIA V/HILL	DATE APPROVED FOR SERV	1/13/65
PRINTERS	DATE APPROVED FOR EXP	1/13/65
U. S. ATOMIC ENERGY COMMISSION PACIFIC NORTHWEST LABORATORY BATTELLE MEMORIAL INSTITUTE		
BELLOWS TANK DETAIL		
NO. 209E	INDEX 4700	
H-2-32570	6/8/1	
CLASSIFIED BY	CLASSIFICATION	
S. W. S. 6/8/65	NONE	





NO.	DESCRIPTION	REV. BY	APPR. BY	FOR DATE	NEXT USED ON	REFERENCE DRAWINGS	CLASSIFICATION
1	SHL. 7 OF 7 AS NC B DESIGN CHANGE WAS DIV'D UPGRAD PER CML-	4-4-85	C&T	PNL	4-15-85	H-2-95713 PROCESE PIPING ENG FLOW DIA	4.4.85

U. S. ATOMIC ENERGY COMMISSION RICHLAND OPERATION OFFICE			
SCALE	NONE		
DESIGNER	APPROVED	DATE	REVISIONS
R. H. HILL		4-15-85	1
E. R. ZLU		4-15-85	2
APPROVED			3
APPROVED			4
THE PACIFIC NORTHWEST LABORATORIES A DIVISION OF BATTELLE MEMORIAL INSTITUTE PACIFIC NORTHWEST LABORATORY RICHLAND, WASH.			
BELLOWS TANK HOOD ARRANGEMENT			
PROJ. TITLE: CRITICAL MASS FACILITY			
PROJ. NO. 205-E		PROJ. NO. 4722	WORK NO. 4722
SHEET NO. 1 SHEET NO. 1			
H-2-32570 7 8 1			

A


C

C

6

h

I




ELEVATION Y-Y (FROM SHEET 1)

SCALE: $\frac{1}{4}$

THIS PARTIAL ELEVATION IS ONLY A
REFERENCE TO THE DUMP LINE.
ASSEMBLY REFER TO SHEET 1 FOR
THE REMAINING ASSEMBLY


HEX 2.00 ACR



DETAIL - I

SCALE: $\frac{1}{2}$

A →
 1/8" R75 TYP ALL
 OUTSIDE CORNERS
 1/2 MALE NPT
 SEE NOTE 9




DETAIL - II

SCALE: NONE

MATL: ASTM A276 304L SST

OD TUBE SST,
(LIQUID LEVEL INDICATOR LINE)



SECTION A-A

NOTES:

4. THE VOID BETWEEN TUBE ADAPTER AND EXISTING COUPLING SHALL BE FILLED WITH RTV SEALANT OR AN APPROVED EQUAL. SEALANT TO BE CUSTOMER FURNISHED.
2. DIMENSIONS ARE IN INCHES.
TOLERANCES: FRACTIONS: $\pm \frac{1}{8}$
DECIMALS: $.xx \pm .01$
3. REMOVE ALL BURRS AND BREAK ALL SHARP EDGES
4. ALL MATERIAL TO BE AS SPECIFIED OR APPROVED EQUAL
5. TYGON TUBE AND TUBE ADAPTER SHALL BE ASSEMBLED OUTSIDE OF CONTROL ZONE AND BE HYDROSTATICALLY TESTED AT 40 PSIG FOR 10 MIN NO LEAKS ALLOWED. TESTING SHALL BE WITNESSED AND APPROVED BY PROJECT ENGINEER.
6. PIPE THREADS SHALL BE COATED WITH LEAK-LOCK.
7. METAL SEALING SURFACES SHALL BE CLEANED WITH AN OIL-LESS SOLVENT PRIOR TO INSTALLATION.
8. MACHINED SURFACES $\frac{125}{115}$ IN ACCORDANCE WITH ANSI B46.1
9. MACHINE THREADS TO PROVIDE $\frac{1}{2}$ " MIN THREADED MAKEUP. VERIFY IN SHOP BY THREADING INTO CUSTOMER SUPPLIED COUPLING.

FOR BILL OF MATERIALS AND GENERAL NOTES SEE SHEET 1

FORMERLY SK-2-3864 SH 1 of 1

JQP# 1234

U. S. Department Of Energy
Richland Operations Office
PACIFIC NORTHWEST LABORATORY
OPERATED BY Battelle Memorial

BELLOWS TANK
DUMP LINE
ASSEMBLY

Critical Mass Laboratory
209E 47°C

H-2-32570

APPROVED BY ENGINEER			1/25/02
INITIAL DRAWING DATE			1/25/02
REVISED BY			1/25/02
REVISION NUMBER			1
DRAWING NUMBER			SK-2-3864
REFERENCE DRAWINGS			None
COMMITTAL ISSUE NO.			None
DRAWING STATUS			Not Reqd
NEXT USED ON			None



1996
JULY 15
EMERGENCY DATE

