-T6

DOE/PC/90098--T6

DE92 015874

PREDICTIVE MODELLING OF BOILER FOULING

QUARTERLY TECHNICAL PROGRESS REPORT

For The Period
April 1, 1991 - June 30, 1991

Prepared by
TEXTRON DEFENSE SYSTEMS
2385 REVERE BEACH PARKWAY
EVERETT, MASSACHUSETTS 02149

Prepared for
U.S. DEPARTMENT OF ENERGY

PITTSBURGH ENERGY TECHNOLOGY CENTER
PITTSBURGH, PENNSYLVANIA 15236

UNDER CONTRACT NO. DE-AC22-90PC90098

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

JMS
MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CY 206 91

1.0 PROGRAM OBJECTIVE AND SCOPE OF WORK

The primary objective of this work is the development of a comprehensive numerical model describing the time evolution of fouling under realistic heat exchanger conditions. As fouling is a complex interaction of gas flow, mineral transport and adhesion mechanisms, understanding and subsequently improved controlling of fouling achieved via appropriate manipulation of the various coupled, nonlinear processes in a complex fluid mechanics environment will undoubtedly help reduce the substantial operating costs incurred by the utilities annually, as well as afford greater flexibility in coal selection and reduce the emission of various pollutants. In a more specialized context, the numerical model to be developed as part of this activity will be used as a tool to address the interaction of the various mechanisms controlling deposit development in specific regimes or correlative relationships. These should prove of direct use to the coal burning industry.

The Statement of Work comprises a series of related and logically structured tasks described as follows:

Phase I

Task 1

Perform semi-quantitative evaluations of solution and algorithmic details of Higher Level Simulation (HLS) techniques applicable to flow in and around a tube bundle.

Task 2

Assess (quantitatively) HLS predictions for flow and turbulence characteristics of related, simpler problems.

Task 3

Reformulate the algorithm to predict flow details around a cylinder in an isothermal, but otherwise representative environment.

Task 4

Predict heat transfer characteristics for the problem in Task 3.

Task 5

Generalize the algorithm to predict flow, turbulence and heat transfer details for multi-tube configurations including in line and staggered arrangements.

Task 6

Provide project management and financial control with the required technical and financial reports and documentation.

Phase II

Task 1

Develop an appropriate multi-phase, multi-species transport algorithm for a "frozen" gas aerothermal field.

Task 2

Develop sub-modules for surface related processes including adherence and removal.

Task 3

Provide project management and financial control with the required technical and financial reports and documentation.

Phase III

Task 1

Extend the algorithm to couple multi-species, multi-phase transport and deposition models with a comprehensive HLS of flow and heat transfer in a tube bundle for a representative case.

Task 2

Perform pertinent parameter variation studies and develop improved engineering correlations to model fouling in practical boiler configurations and operating environments.

Task 3

Provide project management and financial control with the required technical and financial reports and documentation.

2.0 SUMMARY OF PROGRESS TO DATE

Efforts were continued to develop and apply the algorithm for prediction of flow, turbulence and heat transfer details around an isolated cylinder as well as a deep tube bank using a ReNormalization Group Large Eddy Simulator. The following qualitative picture that emerges from a careful study of the relevant predictions, as well as related cases extensively reported in the literature, emphasizes the salient aspects of the cylinder flows for various Reynolds numbers.

For a single cylinder, the prevailing flow field depends strongly on the Reynolds number. For $6 \leq Re \leq 40$ a steady state exists, with a pair of symmetric separation bubbles on the leeward side. At higher Reynolds numbers the flow field is inherently unsteady and is characterized by cyclic vortex shedding. Still at higher Reynolds numbers (critical Re range) the laminar boundary layer over the cylinder separates with the formation of the so called separation bubble, followed by reattachment at $\phi \approx 100^\circ$ in the form of a turbulent boundary layer. The pressure on the cylinder surface in the region of the separation bubble remains constant. Here the flow becomes turbulent. In the course of this transition, the boundary layer acquires additional kinetic energy from the free stream, and the separation point moves abruptly to $\phi \approx 140^\circ$. When this type of separation occurs, the wake region downstream of the cylinder narrows and the pressure distribution around the cylinder approaches that of a potential flow over a large portion. At critical Re, when the location of the boundary layer separation is abruptly shifted downstream, a departure from the regular pattern of vortex shedding from the surface occurs. Experimental evidence in the literature indicates that the eddy shedding frequency in supercritical flow over bodies at $Re \geq 3.5 \times 10^6$) is highly regular.

Concentrating on the laminar, asymmetric region of the flow map, it is generally agreed that at a Reynolds number higher than 40, any perturbation excites an unsteady flow, and eventually a periodic vortex shedding is established generating the well-known Von Karman vortex shedding street. In the present effort, the laminar vortex shedding over a cylinder was simulated at select Reynolds numbers. Examination of these cases, as well as evaluation of related predictions reported in the literature (e.g. $Re=200$) reveals that following

a relatively short transient flow, the onset of periodic flow dominated by a single frequency is observed. The amplitude of oscillations and the Strouhal number of the vortex shedding increase with the Reynolds number. Examining instantaneous streamlines for five equally spaced instances along one vortex shedding cycle, the following qualitative picture emerges. Time is normalized by the period and $t=0$ corresponds to the instant when the lift coefficient is maximum. The lift coefficient is minimum and the drag coefficient is maximum at $t=0.5$, while at $t=0.25$ and $t=0.75$ the lift coefficient vanishes and the drag coefficient is minimum.

The flow fields at the beginning of the cycle ($t=0$) and the end of the cycle ($t=1$) are eventually identical indicating the periodic nature of the flow. Moreover, the flow field at $t=0.5$ is a mirror image of the flow field at $t=0$. A similar relationship is found between the flow fields at $t=0.25$ and $t=0.75$, when the instantaneous lift coefficient vanishes. A large separation bubble is created at the upper side of the cylinder at $t=0$. The bubble induces a low pressure field, which causes a large positive lift coefficient as well as maximum drag. The bubble ultimately separates from the body and is washed downstream ($t=0.25$). The lift coefficient is decreased to zero and the drag coefficient is minimum at that time. At $t=0.5$, a large separation bubble is created at the lower side, reversing the direction of the lift coefficient. The bubble is washed downstream and creates the lower vortex of the Von Karman vortex street. The centers of the shed vortices are characterized by a low pressure region.

Regarding the heat transfer details of deep tube bank, the following qualitative picture emerges from a study cases predicted as well as those reported extensively in the literature.

In the range of Reynolds numbers of interest in this study (i.e. $2.10^3 \leq Re \leq 2.10^5$), high intensity in the space between tubes in a bank causes a transition from laminar flow in the boundary layer to a turbulent flow. The transition point coincides with large values of the circumferential angle ϕ , resulting in reduced dimensions of the recirculation zone behind the tube.

With the appearance of turbulence in the boundary layer, the distribution and character of the local heat transfer coefficient changes substantially.

Considering the flow around the frontal region of a tube in the first and inner rows of a staggered bank, the flow accelerates and after crossing the minimum cross-sectional area it decelerates. The location of the minimum cross-sectional area depends on the pitches and could be at $\phi=90^\circ$ or at another angle. For in-line banks it is always located at $\phi=90^\circ$. The acceleration of flow effectively decreases the thickness of the boundary layer, increasing heat transfer; however, transverse velocity fluctuations which enhance turbulent heat transfer are reduced. Vortices generated in intertubular spacing and in the boundary layer spread under the influence of a negative pressure gradient. The local heat transfer, as a result, decreases. The decrease in velocity in intertubular spacing leads to an increase in boundary layer thickness and to the separation of the boundary layer. In the region of positive pressure gradient, velocity and temperature fluctuations increase, particularly the transverse component of velocity, which promotes local heat transfer.

As is evident from experimental studies reported in the literature, for flow through the first rows of banks, turbulence caused by the first and second rows plays a principal role, and the difference in heat transfer of the third and fourth rows lies within the bounds of measurement errors. In the inner rows of in-line and staggered banks, the character of heat transfer is different, particularly in the frontal side of tubes.

It is important to note the specific features of heat transfer in inner rows of in-line and staggered banks at different Reynolds numbers. In the region $\phi=90^\circ-110^\circ$, heat transfer increases as a result of the flow transition from laminar to turbulent and $\phi=150^\circ$, the increase is due to separation of the turbulent boundary layer.

Local heat transfer, $h/\bar{h}$ in an inner row of in-line banks varies slightly. The maximum value of $h/\bar{h}$ occurs at the point of collision of flow and tube, after which $h/\bar{h}$ decreases. In the region of boundary layer transition from laminar to turbulent ($\phi=100^\circ-115^\circ$) and separation of the turbulent boundary layer $h/\bar{h}$ increases. The relation between the maximum and minimum values of $h/\bar{h}$ in in-line banks amounts to 2.5 which indicates strong non-uniformity of thermal loading of the tube in this range of Reynolds numbers.

It is also worth noting that, for a non-gradient flow of the laminar boundary layer, turbulence of the external flow does not give rise to an increase of the local heat transfer coefficient. But for gradient flow, even slight turbulence (1-2%) of the external flow leads to an increase of local heat transfer by 40-60%.

3.0 TECHNICAL PROGRESS

3.1 Details of the RNG Subgrid Viscosity Model

In this reporting period, efforts were continued to develop and apply the algorithm for prediction of flow, turbulence and heat transfer details around an isolated cylinder as well as a deep tube bank, using an ReNormalization Group (RNG) large eddy simulator. Specifically, the following expression for the RNG subgrid viscosity is employed after Yakhot and Orszag:

$$\nu^{(q)} = \left[1 + H \left(\gamma_{mg} \gamma_{iso} \frac{\bar{E}^{(q)} \Lambda^{-4}}{\nu_o^3} - C \right) \right]^{1/3} \quad (1)$$

where

$$\gamma_{mg} = \frac{3}{8} (1.594) A_d, A_d = \frac{d^2 - d}{2(d^2 + 2d)} \quad d = 3 \quad (1.1)$$

$$\gamma_{iso} = \frac{3w^2}{(u^2 + v^2 + w^2)} \quad (1.2)$$

$$\bar{E}^{(q)} = \nu^{(q)} |S_{ij}^{(q)}|^2 \quad (1.3)$$

$$I = \Lambda^{-4} = \pi^{-1} \int_{\Lambda_1}^{\infty} \int_{\Lambda_2}^{\infty} \int_{\Lambda_3}^{\infty} \frac{dq_1 dq_2 dq_3}{(q_1^2 + q_2^2 + q_3^2)^{7/2}} \quad (1.4)$$

where $(\Lambda_i = (\pi/\Delta_i) \quad i = 1, 2, 3)$

In equation (1) γ_{iso} depends on the local resolvable velocities, which reflects the anisotropy of the small-scale structure of the complete flow. Additionally, function $H(x)=x$ when $x \geq 0$ and 0 otherwise, representing the fact that scale elimination only occurs when there are scales to be removed. In the expression for subgrid viscosity, the "average" inverse grid scale Λ also follows directly from the RNG calculus. In principle, the scale elimination procedure leading to the RNG subgrid model may be performed with confidence only for scales much smaller than that corresponding to the energy containing scales of turbulence. If all length scales up to $l \gg \max(\Delta_i)$ are eliminated, where Δ_i is the filter length scale related to the computational mesh size, then the geometrical structure of the mesh is anticipated not to be important and a simple procedure that replaces Λ by π/Δ suffices. In this case, use of a commonly employed expression, i.e.,

$$\Delta = (\Delta_x \Delta_y \Delta_z)^{1/3} \quad (2)$$

(a practice that was also adopted during the course of this study) also produces reasonable predictions. However, only the scales up to $2\Delta_i$ are removed; then it is logical to account more properly for the grid anisotropy. Devising a suitable procedure to numerically evaluate (1.4) to obtain an appropriate integral scale for a grid of general asymmetry, consumed most of the effort in this reporting period. Specifically, the integral was evaluated in the following manner:

$$I = I_s + I_N - (I_{13} + I_{21} + I_{32}) \quad (3)$$

where:

$$I_s = \int_L^\infty \int_0^{\pi/2} \int_0^{\pi/2} \frac{r^2 \sin \theta dr d\theta d\phi}{(r^2)^{7/2}} = \frac{\pi}{8L^4} \quad (3.1)$$

(using spherical coordinates, L is chosen arbitrarily)

$$I_N = \int \int \int_{ABCD} \frac{dk dp dq}{(k^2 + p^2 + q^2)} \quad (3.2)$$

(evaluated numerically using trapezoidal rule)

$$I_{13} = \int_0^{\Lambda_2} \int_{\varphi_3}^{\pi/2} \int_L^{\infty} \frac{dq_2 r dr d\theta}{(r^2 + q_2^2)^{7/2}} = \frac{2\pi}{5} \frac{2 - \varphi_3}{L^4} \mathfrak{I}(\alpha_2)$$

$$\text{where } \varphi_3 = \sin^{-1} \frac{\Lambda_3}{L}$$

$$\alpha_2 = \tan^{-1} \frac{\Lambda_2}{L}$$
(3.3)

$$I_{32} = \int_0^{\Lambda_1} \int_{\varphi_2}^{\pi/2} \int_L^{\infty} \frac{dq_1 r dr d\theta}{(r^2 + q_1^2)^{7/2}} = \frac{2\pi}{5} \frac{2 - \varphi_2}{L^4} \mathfrak{I}(\alpha_1)$$

$$\text{where } \varphi_2 = \sin^{-1} \frac{\Lambda_2}{L}$$

$$\alpha_1 = \tan^{-1} \frac{\Lambda_1}{L}$$
(3.4)

$$I_{21} = \int_0^{\Lambda_3} \int_{\varphi_1}^{\pi/2} \int_L^{\infty} \frac{dq_3 r dr d\theta}{(r^2 + q_3^2)^{7/2}} = \frac{2\pi}{5} \frac{2 - \varphi_1}{L^4} \mathfrak{I}(\alpha_3)$$

$$\text{where } \varphi_1 = \sin^{-1} \frac{\Lambda_1}{L}$$

$$\alpha_3 = \tan^{-1} \frac{\Lambda_3}{L}$$
(3.5)

$$\mathfrak{I}(\alpha) = \sin(\alpha) - \frac{1}{3} \sin^3(\alpha)$$

(approximately using cylindrical coordinates).

Using the above formulation, studies were initiated to simulate various single and multi-cylinder configurations.

3.2 Sample Predictions

In addition to the previously reported cases, additional predictions were carried out to simulate the representative configuration and conditions of utility boilers. These include:

- a) 3-D multi-cylinder flow (four cylinders arranged either in an in-line or staggered fashion) including heat transfer; primarily laminar, but recently extended to cover a turbulent case of $Re\ 2.10^5$, Figure 3.1. The choice of length to diameter ratio (L/D) was made to eliminate cylinder to cylinder flow interactions.

- b) The same as above, but focusing on the effect of the L/D ratio on the flow structure where cylinder to cylinder flow interactions do occur. These refer to a 3x3 matrix of in-line geometry, Figures 3.2 to 3.4, and staggered configuration, Figures 3.5 to 3.7.

These predictions were carried out primarily for sub/critical Reynolds numbers with view to reveal the model capability to simulate transition. This is depicted very clearly in Figures 3.8 to 3.11 that show time histories of the streamwise and spanwise velocities, pressure and temperature at a preselected monitoring point for the staggered configuration. The explosive instability and the ensuing chaotic pattern that sets in following a quasi-laminar flow development period are clearly evident. Furthermore, predictions for the remaining cases that have been simulated appear qualitatively reasonable and are currently being studied in detail to assess the predictive nature of the formulation including issues of computational resources.

cyht61 turb flow

Figure 3.1

low aspect U-vel

Figure 3.2

low aspect in-line

Figure 3.3

low aspect perT

Figure 3.4

staggered U-vel

Figure 3.5

staggered vel field

Figure 3.6

staggered perl

Figure 3.7

Figure 3.8

Figure 3.9

X= -0.577

Y= -1.25

Z= 0.189

502.

1053

485.

0.

2.518

1718

5000 0.01 1.00 10.00 100.00

Figure 3.10

X= -0.677

Y= -1.25

Z= 0.189

63.06

Figure 3.11

-07.8

0

2.988

the

SECRETION CAPING AT 43

4.0 CONCLUSION AND PLANS FOR FUTURE WORK

4.1 Conclusions to Date

Good technical progress has been made. As accurate large eddy simulations in the past have concentrated on resolving the turbulence details of semi-idealized, geometrically simple flow problems, applications involving configurations and physical complexity comparable to those in typical tube banks are naturally rare. The effort in this reporting period has shown spectral element algorithms incorporating RNG techniques can be conveniently used to provide detailed flow and heat transfer information for a truly complex transport field. Furthermore, the RNG technique, as reported in the literature, seems to give a faithful description of the turbulence in the wall region including correct, approximately Reynolds number independent value of the spacing between the streaks for turbulent channel flow. However, more computational experiments are needed to investigate the predictive nature of the model for high Reynolds number flows (similar to those encountered here) and to determine the resolution requirement of this large eddy simulation model for this extremely complex flow field as the Reynolds number increases. In this respect it is worth emphasizing the urgent need for the Cray time as the lack of such a resource has been seriously impeding any meaningful progress of this effort. As a case in point, a typical example is reported herein. A 3-D multi-cylinder case ($Re=2.10^5$) required about five days CPU time for 1.8 seconds of simulation on IBM 3090 that is equivalent to 75% of Cray capacity!

4.2 Plans for Next Reporting Period

Efforts directed towards algorithm development and applications involving flow, turbulence, evolution and heat transfer characteristics around an isolated cylinder and a tube bank will be continued.

END

**DATE
FILMED**

7 / 29 / 92