






AIM

Association for Information and Image Management




1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910
301/587-8202




Centimeter



Inches



MANUFACTURED TO AIM STANDARDS
BY APPLIED IMAGE, INC.



**Cover Sheet for a Hanford
Historical Document
Released for Public Availability**

Released 1994

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**



DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

~~DISTRIBUTION RESTRICTED TO U.S. ONLY~~

DISCLAIMER

This is a **historical document** that is being released for public availability. This was made from the best available copy. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any **warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This document contains restricted data as defined in the Atomic Energy Act of 1954. Its transmission or the disclosure of its contents in any manner by an unauthorized person is prohibited.

This document consists of 3 pages, No. 1 of 8 copies.

PRELIMINARY REPORT

This report was prepared only for use within General Electric Company in the course of work under Atomic Energy Commission Contract AT(45-1)-1350. Any views or opinions expressed in the report are those of the author only.

This document classified by

Prepared

DISTRIBUTION

1. BR Cremer-KP Bokish
2. JW Frymier
3. SM Graves
4. NH Skarshaug
5. AP Vinther
6. GW Wells
7. 300 Files
8. Record Center

Classification Cancelled and Changed To

DECLASSIFIED

By Authority of AMITN

CG-PR-2, 3-16-94

By DK-Hanson, 4-17-94

Verified By J E Savelly 4-18-94

190-H DRAWDOWN TEST

by
K. P. Bokish
B. R. Cremer
Process Engineering Unit
Process Technology Sub-Section
Research and Engineering Section
IRRADIATION PROCESSING DEPARTMENT

January 17, 1963

DECLASSIFIED

190-H DRAWDOWN TEST

Introduction

A discrepancy of about 1000 gpm has existed between the full-flow recorded 190, 105 and ROL¹ flows. While past operating practices have not used the 190 or ROL flow rates for official purposes, the disquieting, though not theoretically unexplicable, differences require some quantitative resolution. On November 24, 1962, a drawdown test of the 190-H storage tanks was performed to establish the accuracy of the various flowmeters.

Summary and Conclusion

The drawdown test of the 190 storage tanks was run at the beginning of a scheduled reactor shutdown. With the full reactor flow supplied by the electric process pumps feeding from the storage tanks, the 183-H supply to the storage tanks was valved off. Additionally, non-process water usually taken from the storage tanks was valved off.² The storage tank water levels were taken then recorded as a function of time. The best results are summarized in Table I.

TABLE I

	<u>Flow</u>	<u>Error</u>	<u>% Error</u>
Average actual 190-H drawdown flow =	83,870	---	---
Average actual drawdown flow - 100 gpm turbine pump bearing coolant =	83,770	---	---
Total average flow metered by the 190-H flowmeters -	82,870	-900	-1.1%
Total average flow metered by the 105-H flow transmitters =	83,300	-470	-0.6%
Average recorded flow on 105-H control room Foxboro recorder =	83,990	+220	+0.3%

From the results shown in Table I it is apparent that normal operating flow is measured and recorded by the 105-H control room recorder to an accuracy

¹ ROL flow is defined as the summation of the individual process tube flow rates, as reported in the Reactor Operating Limits (ROL) print-out.

² To assure continuous water backup adequacy during the drawdown test, the process water used to cool the steam turbine pump bearings was left on. This water, visually estimated at 100 gpm, was the sole non-process use of storage tank water during the test.

well within the 1 per cent accuracy specified by standards.³ Therefore, the current practice of using the 105 control room flow for official calculations and reports, etc. should be continued.

Discussion

While this test established the accuracy of the 105 flow meters in the range of normal operating flow, it is not valid to extrapolate this accuracy into the range of shutdown flow. Because of construction limitations, the 105 flowmeters simply cannot be used to provide reliable flow data below 10,000 to 20,000 gpm. Therefore, reliable shutdown flow data must be supplied by either the 190 flowmeter summation or the newly installed high pressure manometers.

Close agreement between the 105 and 190 flowmeters, while desirable, is not likely to ever occur often because of the precision of the 190 flowmeters. Since each of the 190 flowmeters has a "least count" of 500 gpm, it is quite unlikely that any single reading can be more precise than about 100 gpm. Actually, there is some logic in not claiming a precision greater than 1/2 the least count, or 250 gpm. In any case, however, the contributing error of each of the eight 190 flowmeters can cause a total flow error of as much as $8 \times 250 = 2000$ gpm. More probably, the 190 flowmeter error would be only about 800 gpm; however, even this is significant. Thus it seems prudent to use the present 190 flowmeters only for gross flow checks, or possibly in the low flow range wherein the 105 flowmeter is ineffective.

The ROL flow summation suffers, precisionwise, in the same manner the 190 flowmeters do: relatively small individual errors when multiplied by the total number of flowmeters (i.e., venturis or orifices) cause a significant total flow error. For example, an average individual tube flow error of only 1/2 gpm can cause the total ROL flow to be in error by as much as 1000 gpm. Since individual tube flow errors of 1/2 gpm can easily result from venturi machining tolerances, front header pressure variations, etc., it is imprudent to use the total ROL flow as representative of the true reactor flow.

KP Bokish
Process Engineering Unit
Process Technology Sub-Section
Research and Engineering Section

Byron Cremer
Process Engineering Unit
Process Technology Sub-Section
Research and Engineering Section

KP Bokish:BR Cremer:md

³HW-41000, "Process Equipment Standards, A-010."

DATE

FILMED

6 / 14 / 94

END

