ENERGY DIVISION

**A GOOD INTEGRATED RESOURCE PLAN:
GUIDELINES FOR
ELECTRIC UTILITIES AND REGULATORS**

ERIC HIRST

DECEMBER 1992

Sponsored by
Office of Conservation and Renewable Energy
U.S. Department of Energy

OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37831
operated by
MARTIN MARIETTA ENERGY SYSTEMS, INC.
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-84OR21400

MASTER

TABLE OF CONTENTS

	Page
SUMMARY	v
LIST OF ACRONYMS	vii
1. INTRODUCTION	1
PURPOSE OF THIS REPORT	1
IRP BASICS	4
2. ENERGY AND DEMAND FORECASTS	7
FORECASTING APPROACHES	7
LINKS BETWEEN FORECASTS AND DSM PROGRAMS	8
DEMAND FORECASTS	10
SUMMARY	10
3. ASSESSMENT OF SUPPLY RESOURCES	11
EXISTING RESOURCES	11
RENEWABLE RESOURCES	11
NONUTILITY SOURCES	12
TRANSMISSION AND DISTRIBUTION	14
ASSESSMENT OF OPTIONS	15
4. ASSESSMENT OF DEMAND-SIDE RESOURCES	19
DSM POTENTIALS	21
SCREENING	24
LOAD-BUILDING PROGRAMS	26
ELECTRICITY PRICING AS A RESOURCE	26
EFFECTS OF EXPERIENCE	27
SUMMARY	29
5. RESOURCE INTEGRATION	31
CRITERIA FOR RESOURCE AND PORTFOLIO SELECTION	31
MULTIPLE RESOURCE PLANS TO MEET DIFFERENT OBJECTIVES	32
INTEGRATION METHODS	34
INTERNAL CONSISTENCY	38
AVOIDED COSTS	38

	RELIABILITY AND RESERVE MARGIN	41
	TIME PERIODS FOR ANALYSIS	42
	ENVIRONMENTAL COSTS	42
6.	UNCERTAINTY ANALYSIS	47
7.	ACTION PLANS AND PROGRESS REPORTS	53
	SHORT-TERM ACTION PLANS	53
	ANNUAL PROGRESS REPORTS	54
8.	PUBLIC PARTICIPATION	57
9.	THE IRP REPORT	61
10.	CONCLUSIONS	67
	ACKNOWLEDGMENTS	69
	REFERENCES	71

SUMMARY

Integrated resource planning helps utilities and state regulatory commissions consistently assess a broad range of demand and supply resources to meet customer energy-service needs cost-effectively. Key characteristics of this planning approach include: explicit consideration and fair treatment of a wide variety of demand and supply options, consideration of the environmental and other social costs of providing energy services, public participation in the development of the resource plan, and analysis of the uncertainties associated with different external factors and resource options. Integrated resource planning differs from traditional planning in the types and scope of resources considered, the owners of the resources, the organizations involved in resource planning, and the criteria for resource selection.

This report presents suggestions to utilities on how to conduct such planning and what to include in their resource-planning reports. The suggestions are also useful to staff at regulatory commissions who review utility plans. These suggestions are based on a review of about 50 resource plans as well as discussions with and presentations to regulators and utilities.

The suggestions cover four broad topics, which are detailed in this report:

- The technical competence with which the plan was developed;
- The adequacy, detail, and consistency (with the long-term plan) of the short-term action plan;
- The extent to which the interests of various stakeholders was considered, both in public participation in plan development and in the variety of resource plans developed and assessed; and
- The clarity and comprehensiveness of the utility's report on its plan.

Technical competence includes energy and demand forecasts, assessment of supply and demand resources, resource integration, and treatment of uncertainty. Issues associated with forecasts include forecasting approaches; links between the forecasts of energy use and peak demands; and links between the forecasts and the effects of past, present, and future demand-side management programs.

Utilities should assess a range of supply resources, including those that use new technologies (e.g., clean-coal and renewables, such as photovoltaics and wind). The generic supply categories include: existing utility-owned power plants and contracts; life extension, repowering, or fuel-switching of utility-owned plants; utility construction of new power plants; purchases from other organizations (including other utilities, qualifying facilities, and independent power producers); and transmission and distribution improvements. Utilities should also examine energy-efficiency and load-management technologies and marketing strategies.

Resource integration includes specification of the criteria to use in assessing resource portfolios, development of alternative resource portfolios designed to address different objectives, analytical integration of resources, assurance that the results of the analysis are internally consistent, identification of avoided energy and capacity costs, consideration of reliability and reserve margins, and treatment of the environmental costs of electricity production.

Uncertainty analysis should focus on the key resource decisions that the utility is likely to face in the next few years and the implications of these decisions. Utilities should use a variety of methods in such analyses, including sensitivity, scenario, portfolio, probabilistic, and worst-case analysis techniques.

The action plan must be consistent with the long-term resource plan to assure that what is appropriate for the long haul is actually implemented. The action plan should be specific and detailed, showing the utility's commitment to different actions. Specific tasks should be identified, along with organizational assignments, milestones, and budgets.

The utility should involve interested stakeholders (e.g., state agencies, environmental groups, and customers) in developing its plan as well as in reviewing the draft and final plans. In addition, the utility should develop and present alternative resource portfolios that reflect the preferences of different groups (e.g., plans that minimize total costs; electricity prices; or total societal costs, including environmental externalities). Although the utility bears the ultimate responsibility for developing and implementing a resource plan, other parties should have ample opportunities to participate in its formation.

The utility's resource plan should be well written and appropriately illustrated with figures and tables. One format, successfully used by several utilities, is to publish separate volumes: an executive summary, a plan, and technical appendixes. This format allows readers with different interests and different technical backgrounds to access the plan in ways that best meet their needs.

A plan that meets the guidelines developed here is likely to provide a solid foundation for meeting the future energy-service needs of the utility's customers. Such a plan, because of the extensive public involvement in its preparation, is likely to achieve a much greater consensus than would a plan developed solely by the utility.

LIST OF ACRONYMS

CAAA	Clean Air Act Amendments of 1990
CT	Combustion turbine
DSM	Demand-side management
EPRI	Electric Power Research Institute
IPP	Independent power producer
IRP	Integrated resource planning
LCRA	Lower Colorado River Authority
MCS	Model Conservation Standards
NEES	New England Electric System
NUG	Nonutility generator
PEPCO	Potomac Electric Power Company
PGE	Portland General Electric
PUC	Public utility commission
QF	Qualifying facility (1978 Public Utility Regulatory Policies Act)
RFP	Request for proposals
SCE	Southern California Edison
SDG&E	San Diego Gas & Electric Company
SMUD	Sacramento Municipal Utility District
SONGS1	San Onofree Nuclear Generation Station 1
T&D	Transmission and distribution

INTRODUCTION

PURPOSE OF THIS REPORT

During the past several years, more state public utility commissions (PUCs) have adopted rules that require electric utilities to prepare integrated resource plans. As a consequence, more and more utilities throughout the U.S. now prepare such plans on a regular basis. This report, based on a review of about 50 such plans, offers guidelines to utilities on how to conduct the analyses that support integrated resource planning (IRP) and what to present in the IRP report.* Similarly, this report should be helpful to PUC staff who review and assess these utility plans.

The primary purpose of this study is to present and publicize exemplary practices (analytical methods, planning approaches, and reporting formats) employed by electric utilities during the past few years. These state-of-the-art IRP examples should help other utilities improve the quality of their resource planning and resource reports.

In early 1990, Oak Ridge National Laboratory published a report similar to this one, based on a review of about 30 plans, most of which were prepared in 1988 and 1989 (Hirst et al. 1990). This report revises and updates the earlier one, based largely on the many utility IRP reports issued in 1990, 1991, and 1992.

During the past three years, utilities have made substantial progress in several areas, including more thorough treatment of renewable resources; greater and more competent assessment of demand-side management (DSM) technologies and programs; treatment of uncertainty; consideration of the environmental effects of electricity production, delivery, and use [including analysis of alternative ways to respond to the 1990 Clean Air Act Amendments (CAAA)]; initial efforts to include transmission planning within IRP; treatment of resources specific to the utility rather than "generic" resources; and greater and more meaningful public involvement in the utility planning process.

On the other hand, additional work is needed in several areas, including fuel switching at power plants and for customer end-uses; distribution planning, including use of renewable resources and DSM programs as alternatives thereto; forthright treatment of load-building programs; and the role of electricity pricing as a resource.

Until a few years ago, the leading IRP utilities were concentrated in New England, New York, Wisconsin, and the west coast. As the list of resource plans reviewed here shows

*Although this report deals exclusively with IRP for *electric* utilities, the ideas and examples are relevant to *gas* utilities as well.

(Table 1), utilities in much of the U.S. and Canada are now preparing such plans. The list includes utilities that sell electricity in more than half the states.

This spread of IRP is confirmed by a 1991 survey conducted by Mitchell (1992). She classified 14 locales as having a "full-featured IRP regulatory framework" in place: California, District of Columbia, Georgia, Hawaii, Illinois, Maine, Massachusetts, Nevada, New Hampshire, New York, Oregon, Vermont, Washington, and Wisconsin. Another six states (Florida, Iowa, Maryland, North Carolina, South Carolina, and Utah) had an IRP framework that lacked only one of the necessary components of a full-featured IRP. A similar survey conducted by Mitchell in 1989 found only seven states with full-featured frameworks and seven that lacked only one component. According to these figures, the number of states with active IRP processes almost doubled in two years.

The same four broad topics that were discussed in our previous study form the basis for this project:

- The technical competence with which the plan was developed;
- The adequacy, detail, and consistency (with the long-term plan) of the short-term action plan;
- The extent to which the interests of various stakeholders was considered, both in public participation in plan development and in the variety of resource plans developed and assessed; and
- The clarity and comprehensiveness of the utility's report on the plan.

Each of these topics is discussed in subsequent chapters. For each topic and subtopic, I present general issues and suggestions, supported by one or more utility-specific examples. These examples, interesting and informative in their own right, show that these new approaches are feasible and should be considered by other utilities. Chapters 2 through 6 deal with technical competence. These chapters focus on those activities that rely heavily on data and analysis, including: energy and demand forecasts; assessment and screening of supply resources; assessment and screening of demand resources; resource integration, including development of a preferred resource plan, avoided costs, and reserve margins; and uncertainty analysis. Chapter 7 discusses the short-term action plan, Chapter 8 discusses public participation in plan development and other ways to capture different perspectives in the planning process and resultant plan, and Chapter 9 discusses the IRP report itself. The final chapter summarizes the key suggestions concerning the conduct of an IRP and preparation of a report on the utility's plan.

Table 1. Utilities from which integrated resource plans were reviewed for this study

Utility name	Investor-owned or public	Year(s) of plans ^a	State(s) in which utility serves
Boston Edison	I	1988, 90	MA
British Columbia Hydro	P	1991	British Columbia
California Energy Commission	P	1990	CA
Central Maine Power	I	1991	ME
Cincinnati Gas & Electric	I	1991	OH
Consolidated Edison	I	1991, 92	NY
Consumers Power	I	1990, 92	MI
Detroit Edison	I	1989, 92	MI
Duke Power	I	1989, 92	NC, SC
Florida Power Corp.	I	1991	FL
Georgia Power	I	1988, 92	GA
Idaho Power	I	1991	ID
Green Mountain Power	I	1989, 91	VT
Kansas City Power & Light	I	1991	MO
Lower Colorado River Authority	P	1991, 92	TX
New England Electric	I	1990, 91	MA, NH, RI
Niagara Mohawk	I	1991	NY
Northeast Utilities	I	1992	CT, MA, NH
Northwest Power Planning Council	P	1986, 1991	ID, MT, OR, WA
Nevada Power	I	1991	NV
New York Power Pool	I	1991	NY
Ontario Hydro	P	1989, 92	Ontario
PacifiCorp	I	1989, 92	CA, ID, MT, OR, UT, WA, WY
Potomac Electric	I	1990, 92	DC
Portland General Electric	I	1990	OR
Public Service Co. of Colorado	I	1990	CO
Public Service Co. of New Hampshire	I	1990	NH
Puget Power	I	1989, 92	WA
Seattle City Light	P	1990	WA
Southern California Edison	I	1991	CA
San Diego Gas & Electric	I	1991	CA
Tennessee Valley Authority	P	1991	AL, GA, KY MS, SC, TN, VA
Union Electric	I	1990	MO
Wisconsin Electric	I	1991	WI

^aSome of these utilities issued resource plans in other years. This list includes only those plans reviewed for this study.

IRP BASICS

Until the early 1970s, resource planning at electric utilities was straightforward. Electricity demand was growing steadily, technological developments were lowering the costs of new power plants, and electricity prices were declining. Since then, the utility industry has been shaken by wrenching changes. Perhaps most important, the era of declining costs ended and was replaced by increasing costs. As a consequence, proceedings before PUCs, which had been largely routine during prior decades, became stormy and contentious. Utilities argued for substantial rate increases to pay for escalating capital and fuel costs, while consumer groups opposed these frequent and large price rises.

Although electricity prices have stabilized or declined slightly during the past few years, utilities continue to face fundamental changes. These changes include deregulation of electricity generation; greater access by utilities and others to the transmission systems of other utilities; competition for retail customers from other fuels and even from other electricity suppliers; changes in regulation of electricity prices; growing use of DSM programs as capacity and energy resources; increased concern with the environmental consequences of electricity production; growing public opposition to construction of power plants and transmission lines; and considerable uncertainty about future load growth, fossil-fuel prices and availability, and the costs and construction times of facilities needed to meet future energy needs.

IRP is a process that can help utilities and PUCs deal with these changes. IRP consistently assesses various demand and supply resources to meet customer energy-service needs at the lowest economic and social costs [Cavanagh 1986; Hirst 1988; National Association of Regulatory Utility Commissioners 1988; Hirst and Goldman 1991]. IRP involves deliberations among utility planners and executives, PUCs, and customers. These deliberations lead to the development of a plan that will help provide reliable and low-cost electric-energy services to customers, financial stability for the utility, a reasonable return on investment for shareholders, and protection of the environment.

Typically, a utility begins its IRP process by identifying its goals and the key issues that the resource plan must address (Fig. 1). Corporate goals often concern customer service, returns to shareholders, maintenance of low electricity prices, and protection of the physical environment. Specific issues might involve forthcoming decisions on an aging power plant that could be retired, repowered, or restored to full service; recently begun DSM programs that might be expanded or modified; a response to a recent PUC order requiring the utility to conduct a competitive bidding process to acquire new resources; efforts to restore the utility's bond rating to a higher level; and so on.

Next, the utility develops alternative load forecasts. Then, the utility assesses the costs and remaining lifetimes of its existing resources and identifies the need for additional resources. (Resources refer to any method used to meet customer energy-service needs, including power plants, contracts to buy electricity from other organizations, and programs that improve the efficiency or timing of customer electricity use.)

Fig. 1. The activities involved in integrated resource planning.

The utility then assesses a broad array of alternatives that could satisfy the need for more electric-energy services, including supply, demand, transmission and distribution (T&D), and pricing options. Supply resources include modifications to existing power plants that extend their lifetimes or increase their output, purchase of power from other utilities and from nonutility companies, as well as the construction of new power plants. Utility DSM programs might include (1) promotion of new lighting systems, motors, and other equipment to improve energy efficiency or (2) direct control of customer loads at critical times. These DSM programs constitute resources that can substitute for power plants, transmission lines, and distribution systems.

Different combinations of these supply and demand resources are then analyzed to see how well they meet future electricity needs and how expensive they are. These analyses are repeated time and again to test various resource portfolios for their resilience against different uncertainties. These analyses test (1) different assumptions about the external environment (e.g., local economic growth and fossil-fuel prices), (2) different estimates of the costs and performances of different resources, and (3) different combinations of resources. Such uncertainty analysis helps to identify a mix of resource options that meets the growing demand for electricity, is consistent with the utility's corporate goals, avoids exposure to undue risks, and satisfies other environmental and social criteria.

Then the utility prepares a formal report based on the preceding analyses and on public involvement. That report presents the preferred resource plan and the reasons why, in the utility's view, this plan represents the best mix of resources. After acceptance or approval by the PUC, the plan is implemented, and resources are acquired. Although the PUC formally reviews the plan and various nonutility parties participate in its preparation, the utility has ultimate responsibility for its issuance and implementation.

While the plan is in force, the utility monitors changes in its environment and its implementation of the resource plan, and the plan is modified as events and opportunities change. Although resource planning is an ongoing process, only once every two or three years does the utility issue a formal plan along the lines discussed here.

As described above, IRP has several key elements:

- Integration of supply, demand, T&D, and pricing alternatives;
- Coordination and communication among people from various utility departments;
- Treatment of uncertainty;
- Participation in the planning process by outside experts, customers, and regulators;
- Consideration of environmental factors;
- Implementation of the plan, including acquisition of supply and demand resources, and collection and analysis of data needed to improve planning; and
- Continued monitoring of the plan's implementation and iteration of the planning process.

ENERGY AND DEMAND FORECASTS

The forecasts of annual electricity use and peak demand are, in some respects, the starting point for resource planning. To a large extent, these forecasts, when compared with the utility's existing and committed resources, determine the amounts, timing, and types of future resources that the utility will need during its planning period.

FORECASTING APPROACHES

Utilities use two types of methods to develop their forecasts, econometric and end-use. Econometric models are characterized by modest data requirements and by their statistical foundation. The data needed to construct econometric models are typically readily available within utilities. An econometric model of commercial energy use, for example, might statistically relate annual electricity use in the commercial sector to several explanatory variables, such as the price of electricity, the price of natural gas, and economic activity in the commercial sector. Utilities often prefer econometric models because they require much less data to construct than do end-use models and because the accuracy of the models can be quantified on the basis of their statistical properties.

While econometric models are aggregate, typically dealing with an entire customer class, end-use models are disaggregate. End-use models take an engineering approach and estimate customer-class electricity use from the individual end-use details. An end-use model of commercial energy use, for example, might include engineering estimates of electricity use for lighting, air conditioning, ventilation, and other functions in different building types (e.g., office, retail, education, and health care). The primary advantage of end-use models is their detail, which allows analysts and others to understand the factors that affect changes in electricity use over time.

Several organizations, especially the Electric Power Research Institute (EPRI), have developed forecasting models that combine the best features of the econometric and end-use approaches. These engineering/economic models include the behavioral features of the econometric models (e.g., sensitivity of electricity use to the price of electricity) and the detail of end-use models (e.g., disaggregation of electricity use by end use and building type). Examples of these models include REEPS, COMMEND, and INDEPTH for the residential, commercial, and industrial sectors, respectively.

While the composition and end uses of the residential and commercial sectors are similar across utilities, the makeup of the industrial sector differs substantially. Therefore, utilities often devote special attention in their forecasting models to the few industries that

account for much of their electricity sales. For BC Hydro (1991), five industrial sectors account for almost 80% of total industrial sales and are modeled separately from the rest of the industrial sector. These sectors include paper and allied products, wood manufacturing, chemical and chemical manufacturing, metal mining, and coal mining. For Detroit Edison (1992), motor-vehicle production and steel production are key industrial sectors that drive industrial load growth.

LINKS BETWEEN FORECASTS AND DSM PROGRAMS

Because forecasts of electricity use and demand are so important in IRP, the forecasts should be detailed (e.g., by building type, end use, and technology). Such detail is needed so that the utility can link its forecasts with its assessment, planning, and evaluation of DSM programs. Specifically, the forecasts should show clearly the effects on electricity use of:

- Past and present utility DSM programs (possible future programs are considered separately, as discussed below).
- Government efficiency standards and DSM programs, and
- Normal market forces (e.g., changes in electricity and fuel prices, incomes and economic activity, and energy-using technologies).

These details will ensure that the forecasts appropriately account for changes in energy efficiency caused by different factors, with no under- or double-counting of effects.

The load-forecasting process used by Wisconsin Electric (1991) demonstrates these points well (Fig. 2). The utility first developed a forecast without any DSM programs. It then developed forecasts that included nonutility DSM, existing utility DSM programs, and all DSM programs. Thus, the difference between the top two forecasts in Fig. 2 is the effect of nonutility DSM programs, the difference between the second and third forecasts is the effect of existing DSM programs, and the difference between the bottom two forecasts is the effect of new (planned) utility DSM programs.

PacifiCorp's (1992) recent resource plan shows clearly the link between the load forecasts and the amount of energy-efficiency resource that can be obtained (Fig. 3). Higher load growth is caused by increases in the number of new customers (i.e., construction of new buildings and factories) and by greater use of electricity in existing facilities (Ford and Geinzer 1990). Both factors increase the potential for cost-effective energy savings, as shown by the PacifiCorp analysis.

Fig. 2. Demand forecasts from Wisconsin Electric (1991), showing the effects of different factors, including utility DSM programs, on electricity use over time.

Fig. 3. Relationship between the amount of DSM available in the PacifiCorp service area and future load growth. [A MWa (average MW), a commonly used energy term in the Pacific Northwest, is equal to 8.76 GWh/year.]

DEMAND FORECASTS

The energy and load forecasts should be linked together. Some utilities develop detailed (i.e., end-use) forecasts of annual energy use but produce a peak-load forecast with a single-equation model. Worse yet, this simple model is not linked to annual energy use. In such situations, certain changes (for example in the federal efficiency standards for air conditioners) would have no effect on the forecast of peak demand. However, such changes could dramatically affect future demands at the time of system peak. One utility developed separate forecasts of annual energy use for 14 residential end uses of electricity, 12 commercial building types, and 14 industrial sectors. The forecasts of winter and summer peaks, however, were based only on three years of data on "historic load factors." In other words, estimates of future peak demand were based on a single number, the company's system load factor.

On the other hand, New England Electric System (NEES 1992) uses EPRI's Hourly Electric Load Model (HELM) to produce detailed forecasts of peak demands:

Energy sales from the detailed sector models are input into HELM. The model allocates forecasted annual energy to months, days, and hours of the year based on detailed load shapes estimated for nine commercial building types, sixteen manufacturing groups, and residential load profiles for the three retail companies. Typical day-type load shape data is estimated from the Company's load research data.

SUMMARY

Load forecasts play a vital role in IRP. They help determine the need for new resources, identify the range of uncertainties affecting that need, document the potential for energy-efficiency and load-management programs (e.g., those end-use/customer-class combinations with rapid growth), and show how these potentials vary with load growth.

Because of the importance of future load growth in determining the amounts of resources to acquire, utilities usually develop multiple forecasts (Fig. 3). For example, the Northwest Power Planning Council (1991) developed four forecasts — called low, medium low, medium high, and high — and developed resource plans to meet each one.

The utility's IRP report should document the forecasting results and the underlying methods. Results should include electricity consumption for each major customer class, offsystem sales, T&D losses, plus summer and winter peak demands for each year of the forecast. The explanation of forecasting methods should include the data and assumptions as well as the specific models used to produce the forecasts.

ASSESSMENT OF SUPPLY RESOURCES

The utility should next examine a broad range of supply alternatives, including those that use new technologies (e.g., clean-coal and renewables, such as photovoltaics and wind). The generic categories include: existing utility-owned power plants and contracts; life extension, repowering, or fuel-switching of utility-owned plants; utility construction of new power plants; purchases from other organizations [including other utilities, qualifying facilities (QFs), and independent power producers (IPPs)]; and T&D improvements. These alternatives include different technologies, fuels, and ownership of the resources. A key element in review of both supply and demand alternatives is to consider a sufficiently wide array to be sure that potentially attractive options are not overlooked.

EXISTING RESOURCES

The plan prepared by Central Maine Power (1991) emphasizes stewardship of existing resources (especially the company's hydroelectric facilities and older fossil-fired power plants). The plan discusses the actions the company will take to be sure that these resources continue to provide reliable electricity. Detroit Edison's (1992) plan discusses the possible return to service of existing capacity that is currently on standby (because of excess capacity); such restarts can provide additional resources at low capital cost with short leadtimes. Such a focus on deployment and preservation of existing resources (both power plants and contracts) is especially important for a utility that faces long-term surpluses and is in no immediate need of new resources.

Some utilities, especially those with substantial generating capacity beyond that needed to meet native loads, are active in wholesale markets. To illustrate, 20% of PacifiCorp's 1991 electric generation was sold to other utilities. Public Service Company of New Mexico (1992) sold 38% of its output to other utilities in 1991 and is selling portions of its "excess" generating units to other utilities. Utilities should analyze the implications on both retail customers and shareholders of these wholesale transactions and asset sales.

RENEWABLE RESOURCES

Renewable resources, including solar-thermal, wind, geothermal, and photovoltaics, are rarely considered seriously by utilities. One utility, to illustrate, wrote that it "will continue to monitor developments in alternative energy technologies and may be involved in the demonstration of promising technologies. With the exception of small hydro, alternative energy projects are not included in this plan"

On the other hand, some utilities, including the Sacramento Municipal Utility District (SMUD), PacifiCorp, and NEES, are making commitments to renewable resources. These utilities are pursuing renewables because of their economics, environmental benefits, contribution to resource diversity, contribution to risk reduction (e.g., from a tax on CO₂), or help in lowering the long-term costs of renewable resources.

SMUD (1991) committed to a 50-MW wind plant to be constructed on land purchased by the utility. In addition, the utility plans to acquire an additional 350 to 400 MW of "advanced and renewable technologies" by the year 2000. The utility is running an "Advanced and Renewable Technologies Development Program" to ensure that it can acquire such new resources by the end of the decade (Fig. 4). NEES (1991) issued a request for proposals to acquire up to 200 GWh/year from environmentally benign power sources. This request is meant to "stimulate the renewable energy industry in New England" and may include wind, biomass, and landfill methane (Rowe and LaFleur 1992). Finally, several utilities are using photovoltaic systems as a resource (Solar Energy Research Institute 1991).

NONUTILITY SOURCES

Several utilities considered seriously the purchase of energy and capacity from other sources, including QFs and IPPs. Such resources can be obtained through direct negotiation or through bidding programs (Goldman et al. 1992). Union Electric (1990) included a section

Fig. 4. Sacramento Municipal Utility District's resource mix for 1991 and its planned mix for the year 2000. Note the large increases in the planned contributions from renewables and DSM programs.

on bulk power transactions in its IRP. This section discussed the results of a company survey of interconnected utilities "to determine their projections for the 1989-1998 period of capacity and demand." The survey results suggested that Union Electric might obtain as much as 6100 MW in 1989, declining to about 1300 MW in 1998.

Puget Power (1992) issued its first request for proposals in 1989. Contracts were subsequently signed for 153 MWa of supply projects plus 10 MWa of energy-efficiency projects. The company's current resource plan calls for 100 to 200 MWa in the late 1990s, based on responses to its second RFP, which was issued in September 1991.

The Niagara Mohawk (1991) plan discusses problems that can occur when a utility is required to purchase substantial amounts of nonutility generation. In New York, a state law required (until its repeal in 1992) utilities to pay a minimum of 6¢/kWh for energy. The company estimates that, by 1995 nonutility generation will account for 23% of total installed generating capacity. This amount of nondispatchable capacity may force the company to back down its own baseload generating units at night and during other low-load periods.

Increased competition among power providers and improved planning may appear inconsistent to some people. To the extent that utilities rely on markets to determine the prices, types, and amounts of new resources, some argue that careful planning is not needed. The Northwest Power Planning Council (Sheets 1989) offers a different viewpoint:

Bidding may be a useful tool for providing attractive new resources, but we do not believe it is a substitute for comprehensive utility planning. Utility planners must have good information on when new resources are needed and what resource characteristics will be most compatible with its existing system. They also need a benchmark to compare the cost of the proposals received with the alternatives that could be developed directly by the utility.

According to this perspective, completion of an integrated resource plan is a necessary prerequisite to the preparation of a request for proposals (RFP) to acquire resources competitively. Careful planning is needed to determine the types of resources that are needed, when these resources are needed, and the maximum prices that the utility can pay for such resources.

Bidding and resource planning can be coordinated. The utility first develops a long-term resource plan. Information from the resource plan is used to structure an RFP that specifies what types of demand and supply proposals will be acceptable to the utility. In other words, the values of avoided energy and capacity costs, year by year, are crucial outputs of the resource plan that are needed as inputs to bidding. Resources offered at costs below the utility's avoided costs are attractive; others are not. The utility then receives bids and uses the information gained from the bids and subsequent contract negotiations as input (e.g., on the amounts and costs of nonutility power likely to be available) to the next integrated resource plan.

The next competitive bid uses information from the latest resource plan as well as from the utility's experience with the first auction. Similarly, the next resource plan will use information from both prior auctions as well as the previous plan. This approach is essentially the one chosen by Puget Power (1992).

TRANSMISSION AND DISTRIBUTION

Utilities can improve T&D-system efficiencies by replacing components, such as transformers and conductors, with components having lower losses; modifying operating conditions, including lower voltage levels; and reconfiguring systems to, for example, reduce the distance between substations and their loads (Northwest Power Planning Council 1989). Unfortunately, most utilities do not include T&D improvements as a resource in their resource plans. Some utilities provide lengthy lists of existing and planned transmission facilities (e.g., showing voltage, type of structure, location, miles of line, and width of line); these numbers, absent strategic analysis, have little to do with resource planning.

Green Mountain Power's (1991) IRP plan does include analysis of the loss-reduction opportunities on the company's T&D system (Fig. 5). In addition to identifying the sources of these losses, the plan discusses several strategies for cost-effective loss reduction. PacifiCorp's (1992) plan shows T&D efficiency improvements that amount to 1.1% of annual sales and 2.4% of the winter peak by the year 2011.

Fig. 5. Energy and demand losses in the T&D system of Green Mountain Power.

Niagara Mohawk (1991) examined transmission in its IRP from a different perspective. Niagara Mohawk examined each of its 23 transmission subregions in terms of its ability to import or export power. This analysis helped to identify locations where new resources (e.g., nonutility generators or DSM programs) should be encouraged either because the system can accommodate the resources or because these resources might defer the need for transmission reinforcements. If the system is tight, then new resources should be assessed for the costs of transmission upgrades.

The Lower Colorado River Authority (LCRA 1992) examined the role of distributed generation, especially diesel generators and fuel cells, in part for their ability to defer T&D expansions:

A traditional life cycle cost analysis shows the gas turbine to be the least expensive option at a 15% usage level [capacity factor]. However, if the fuel cell benefits were to include delaying a substation upgrade for three years, the net costs would be comparable to a central station gas turbine. Other quantifiable benefits may include delaying transmission line upgrades or possibly avoiding a substation upgrade altogether.

Pacific Gas & Electric (Orans et al. 1992) analyzed the use of DSM programs to defer costly expansion of its distribution system in rapidly growing areas. It found that aggressive implementation of residential and commercial energy-efficiency programs could defer construction of a new substation and reconductoring of a local transmission line. These deferrals could cut total investment costs in its Delta district by one-third, from \$112 million to \$76 million. Seattle City Light (Lush 1992) is conducting a similar experiment to determine the T&D benefits of DSM programs, focusing on direct load control programs rather than the energy-efficiency programs that Pacific Gas & Electric emphasized.

ASSESSMENT OF OPTIONS

The analysis of many options in the resource integration phase (Chapter 5) is complicated and time consuming. Therefore, utilities should use a screening process to eliminate from integration those candidate resources that are clearly inferior to others.

The supply options discussed above should be screened for their construction characteristics (costs and time to license and build), operating characteristics (fixed and variable operating and maintenance costs, availability and likely capacity factors, environmental effects, and plant lifetime), and transmission additions required to connect the source to the utility's system. These supply alternative should be compared to each other with screening curves (Fig. 6) or other methods to identify those that provide capacity or energy at the lowest cost (in \$/kW or ¢/kWh). The more expensive options can then be dropped from consideration. However, utilities should not prematurely drop resources because they are not *the* least-cost options; what appears to be cost-ineffective during resource screening may, in the subsequent integration and uncertainty-analysis stages, turn out to be very attractive.

Fig. 6. Subset of the screening curves used by Carolina Power & Light (1989) to assess and select supply resources.

Potomac Electric (PEPCO 1992) considered 25 supply technologies in its screening process (Fig. 7). Each technology was scored on its commercial status, technical status, licensing and leadtime risks, cost risk, capital costs, and operating costs. The ratings for each resource on these six characteristics were used to develop an overall score for each resource, which then allowed the company to rank the resources. This approach goes beyond the simple screening shown in Fig. 6.

Compliance with the 1990 CAAA complicates analysis of resource options. The amendments, because of their performance (rather than prescriptive) orientation, allow a wide range of choices. Compliance options include fuel switching (both from high- to low-sulfur coal and from coal to other fuels), coal cleaning, postcombustion control technologies at existing power plants, emissions dispatching, and the purchase or sale of allowances (Centolella 1992). Increasingly, utility resource plans will reflect their approaches to compliance. For example, Duke Power's (1992) latest plan discusses, in general terms, its compliance alternatives; the company's next resource plan is likely to contain much more detail. The Wisconsin Public Service Commission (1992) recently ordered the Wisconsin utilities to include the probable costs of compliance with the CAAA in their next resource plans.

Fig. 7. Resource scoring and ranking results used by PEPCO to screen supply options.

ASSESSMENT OF DEMAND-SIDE RESOURCES

The utility should, in parallel with its assessment of supply options, conduct a thorough assessment of energy-efficiency, load-management, and fuel-switching resources. These DSM programs are, in later steps, compared with supply options to develop a portfolio that best meets customer needs. A key requirement here is that the utility assessment of DSM resources be comparable to and consistent with the assessment of supply resources.

A broad range of DSM resources should be considered. These programs should include all customer classes, all major end uses, and a variety of current and emerging technologies. DSM resources that are slightly more expensive than supply resources under baseline conditions should not be rejected at this point. These DSM options may later turn out to be attractive as the integration and uncertainty analyses proceed. For example, Wisconsin Electric (1991) screened DSM options with a benefit/cost ratio of 0.75:

[T]he lower cutoff point was chosen because it is possible that an option may be cost-effective after more information is gathered or because the option's positive externality impacts indicate that it should be implemented anyway.

Assessment of DSM options should begin with a review of the company's past and ongoing DSM programs. The discussion of each major program should include program description, annual utility budgets, program participation rates, estimated energy and load effects (and the basis for these estimates), and program cost-effectiveness. The estimated effects on electricity use should distinguish between net and total savings.* The utility should show what evaluations and market research support its knowledge about the process and performance of existing programs.

For example, Green Mountain Power (1991) showed estimates, by year, from 1990 through 2005, of the GWh and MW reductions caused by its existing and planned DSM programs (Fig. 8). Similarly, the Bonneville Power Administration (1991), in its assessment of future energy-efficiency programs, showed the effects of past DSM programs from 1982 through 1991.

* Net savings are those directly attributed to the program, while total savings include market-induced as well as program-induced effects (Hirst and Reed 1991).

Fig. 8. Summary of Green Mountain Power's (1991) resource plan showing the MW and GWh contributions from different resources, 1990 to 2005.

DSM POTENTIALS

The utility should next discuss new program possibilities, building on its existing programs and a comprehensive assessment of DSM resources in its service area. This assessment should consider the technical, economic, and market potentials for energy efficiency, load management, and fuel switching* for each customer class (Clinton and Sabo 1990); see Fig. 9. The technical potential is the amount of energy or demand that can be reduced if all equipment, buildings, and processes are replaced with the most efficient technologies available. This potential can be split into two parts: the savings that could be achieved if all systems were converted instantaneously and the savings that could be achieved if retiring systems were replaced with more efficient technologies. Economic potential is the portion of technical potential that is cost-effective (as discussed below). Market potential is that portion of the economic potential that utility DSM programs might reasonably capture. This analysis should also seek to identify how much of the potential will likely be captured because of normal market forces (see the discussion of load forecasts in Chapter 3).

Fig. 9. Schematic showing the differences among technical (both instantaneous and phased-in), economic, and market potentials for a utility DSM program.

*This analysis should consider opportunities to switch from electricity to other fuels (e.g., electric water heaters replaced with gas units). Fuel switching to electricity (e.g., use of electrotechnologies to replace gas-fired equipment in industrial processes) is part of load building, discussed later in this chapter.

Such assessments begin with a careful analysis of existing and projected electricity-use trends by customer class, end use, and technology (Fig. 10). As discussed above, the need for such information is one important reason to use end-use forecasting methods rather than econometric approaches. These assessments also require data on the current efficiencies of energy-using equipment, buildings, and industrial processes. For example, the Bonneville Power Administration collected data on the fraction of homes that had particular energy-efficient electric water heating options (Taylor, Ritland, and Pratt 1991); see Fig. 11. The results of such an assessment can be summarized in conservation and load-management supply curves, which show the amounts of resources available at various costs (in ¢/kWh and \$/kW), as shown in Fig. 12 for the U.S. residential sector (Kooimey et al. 1991).

New programs can include modifications of existing programs (e.g., to gain more participation from target markets or to change financial incentives) and initiation of new programs (new end uses, technologies, or market segments). DSM options (e.g., electric heat pumps, high-efficiency lighting systems, and industrial cogeneration) should be combined into program designs because that is what the utility delivers to its customers. It is not enough to analyze the costs and electricity savings of high-efficiency lights and motors for commercial buildings. The combination of these measures and the utility's delivery system (e.g., marketing approach and audit delivery) is what is relevant (Hill, Hirst, and Schweitzer 1991). The analysis should build on experience with current programs to develop estimates of administrative costs, program participation rates, and energy and load reductions. The utility should also review the experience of other utilities with similar programs.

Fig. 10. Contributions to 1990 summer peak by customer class and end use for Florida Power & Light (1990). These data show the importance of air conditioning in both residential and commercial buildings to summer peaks.

Fig. 11. Percentages of homes in the Pacific Northwest with energy-efficient water-heating options. Results are shown for homes built before 1978 and for homes that meet the region's Model Conservation Standards (MCS).

Fig. 12. U.S. residential supply curve for electric-energy efficiency. These results show a large technical potential at costs below those of new power plants.

SCREENING

Because the resource-integration process is complicated, the utility first needs to screen the candidate DSM technologies and programs to reduce these lists to manageable size. The California PUC and California Energy Commission (1987) developed standard tests that assess the economics of DSM programs from different perspectives. These perspectives (Table 2) include participating customers, nonparticipating customers (the rate-impact measure), utility revenue requirements, all customers (the total resource cost test), and society as a whole. The plan should clearly state which tests the utility used, how they are used for resource screening and selection, and the sensitivity of the results to the input assumptions. Assumptions concerning program costs, participation rates, and marginal energy and capacity costs are especially important. These marginal costs should reflect, in addition to the avoided generation costs, those associated with investments in T&D and CAAA compliance.

Table 2. Elements of the primary economic tests used to assess the benefits and costs of utility DSM programs from different perspectives

Perspective	Benefits	Costs
Participant	Reduction in electricity bill plus utility incentive	Direct costs of participation
Rate-impact measure	Avoided supply costs (production, transmission, and distribution) based on energy and load reductions	Utility program costs (including incentives to participants) plus net lost revenues caused by reduced sales
Utility (revenue requirements)	Same as above	Utility program costs (including incentives to participants)
Total resource cost	Same as above	Total program costs to the utility and participants (i.e., incremental measure costs plus utility administrative costs)
Societal	Same as above plus externality benefits, such as reduced pollution	Same as above

The rate-impact measure should not be used to screen DSM technologies or programs because it will (prematurely) eliminate almost all programs aimed at improving energy efficiency. This test is useful primarily in the resource-integration step, where it can identify the rate impacts of the total package of DSM programs.

Detroit Edison (1992) used the rate-impact measure to screen DSM programs and, as a consequence, selected options that cut demand at the time of system peaks rather than improve energy efficiency. Georgia Power (1992) on the other hand, used four of the five tests shown in Table 2 in screening its programs; it did not use the societal test, although it reported the air-pollution reductions attributable to planned DSM programs.

Hill, Hirst, and Schweitzer (1991) suggested a three-stage screening, program design, and integration process (Fig. 13). The first stage identifies and coarsely screens candidate DSM technologies. The second stage develops DSM programs that use combinations of those technologies that passed the initial screen. This step results in a set of DSM programs that are candidates for cost-effectiveness screening and resource integration. For each program, the utility should provide estimates of program costs (both to the utility and to participating customers), participation rates over time, and net and total energy and load effects. These programs are then screened, and those that remain are assessed, in the third stage, against supply options.

Fig. 13. DSM-technology screening, program screening, and resource integration.

If these programs are comprehensive (in terms of the measures offered and customer segments addressed), then they can be passed directly to resource integration. If, however, there are many small programs, each aimed at different end uses, technologies, and market segments, the utility should combine them into a few blocks (say four to eight). Each block would include several programs aimed at a common objective (San Diego Gas & Electric 1991). The blocks could differ by cost-effectiveness and by goal (e.g., cut summer peak vs improve overall energy efficiency). These aggregated program packages would then be used in resource integration. More than one implementation rate should be considered for each block to allow program deployment to better match changing system needs. For example, Niagara Mohawk (1991) considered three sets of penetration rates, called moderate, aggressive, and very aggressive, in the DSM blocks it created for integration.

LOAD-BUILDING PROGRAMS

The utility's IRP should also examine its load-building programs as well as those programs aimed at load reductions. It should report and analyze any programs it operates or plans to operate that would increase electricity consumption. Such programs could include incentive rates (price discounts for increased electricity use) or promotion of electricity-using technologies. This analysis should show the load-shape effects of this promotion and the effects on short-term and long-term consumption as well as the effects on environmental quality. In particular, the utility should show whether these programs reduce electricity prices to customers in the short term with no adverse long-term increases in electricity costs or prices (e.g., because construction of a new power plant must begin sooner or more pollution will be emitted than otherwise would occur). Finally, the utility should show how load building benefits participants (e.g., use of electrotechnologies that improve product quality and lower costs) and customers in general (e.g., electric systems that replace fossil-fuel systems and thereby lower primary energy use).

Not all utilities are explicit about their load-building efforts. One utility's resource plan noted the "substantial" contribution of its DSM programs to energy savings through 1989. Only in the Appendix to the report, however, was it made clear that more than half of these savings were from cogeneration (a source that most would not classify as DSM). The Appendix also showed that these "savings" were more than offset by increases in electricity use caused by load-building programs. Thus, the net effect of the company's DSM activities was to *increase* electricity use, rather than to decrease it as the company claimed in the body of its IRP report. Duke Power (1992), on the other hand, was clear about the effects of its load-building vs energy-efficiency programs (Fig. 14).

ELECTRICITY PRICING AS A RESOURCE

The level of electricity prices and the structure of the rate tariff [i.e., monthly customer charge, demand charge(s), and energy charge(s)] affect the amount and timing of customer electricity use. Therefore, the level of average prices can be considered a baseload

resource, and the structure of prices (especially demand and time-of-use charges) can be considered a peaking resource. However, most utilities do not treat pricing in their resource plan. PacifiCorp (1992) wrote:

The Company believes that integrated resource planning is not the appropriate forum for considering specific rate design changes. Rate design is determined by the Company and each state's regulatory authority. Evaluation of the Company's pricing structures should be considered as an implementation of the results of the [integrated resource] planning process. It would be very difficult for the Company to assure that it could achieve significant rate design changes. Therefore, it would not be appropriate to use possible consumption changes from rate design changes as a 'resource' ...

Niagara Mohawk (1991) did address retail pricing as a resource. Its analysis of pricing, however, dealt only with hourly pricing and interruptible rates and not with overall energy charges, treating pricing as only a peaking resource.

LCRA (1992) discussed pricing and the perverse effects of its prices on the distributors that buy from LCRA: "The current rate signal causes a difference in strategies and objectives between LCRA and the wholesale customers. It makes it difficult to develop DSM programs that fully meet the aims of both parties." Under current LCRA tariffs, a distributor could save almost \$9000 by shifting 1 MWh off the summer peak. A reduction in nonpeak consumption of 1 MWh could save the distributor only \$25. According to LCRA, "A strategy for wholesale customers that would reduce costs and increase revenues could be summarized as 'move the peak and sell kWh.'" LCRA notes that the practice implicitly encouraged by its pricing may be inconsistent with its long-term resource needs.

A key output of IRP is a set of avoided energy and capacity costs. Rate tariffs (especially the energy and demand charges) should be consistent with the utility's estimates of long-run avoided costs.

EFFECTS OF EXPERIENCE

Several utilities have found that as they gain experience with DSM programs, their estimates of the amount of such resources they can acquire increase. Thus, utilities should consider the possibility that their current estimates of DSM potential are too small.

Wisconsin Electric (1989) reviewed energy audits of commercial and industrial facilities. These audits had been conducted as part of their DSM program, which began in 1987. These audits identified new conservation and load-management opportunities that were unknown to the company at the time it had prepared its previous resource plan. By the year 2000, new programs intended to capture the additional DSM potential identified in these audits will likely cut peak demand by 289 MW in addition to the 167-MW reduction expected from existing programs. Similarly, Ontario Hydro (1992), responding to its experience as well as to pressure from government and the public, doubled its planned acquisition of DSM resources between its 1989 IRP and its 1992 update (Fig. 15).

Fig. 14. The expected effects of Duke Power's load-building and energy-efficiency programs, 1991 to 2000.

Fig. 15. Changes in the planned resource mix for Ontario Hydro between 1989 and 1992. DSM, nonutility generation, and life extension are expected to play much more important roles than was expected in 1989.

SUMMARY

The utility should document its data, assumptions, and analyses on DSM technologies and programs in a manner consistent with that used to report on supply alternatives. Such information includes program participation goals, program budgets, staff requirements, expected total and net energy and load-shape effects, and the expected lifetimes of these energy and load reductions. For each of its planned DSM programs, BC Hydro (1991) presented estimates of energy savings and peak-demand reduction for the year 2000 and program cost expressed in ¢/kWh. The relationships between new and existing programs and the load forecast should be explained clearly. To the maximum extent possible, the utility should use results of program evaluations to develop the estimates of performance for planned programs.

RESOURCE INTEGRATION

The next step in the IRP process is integration of the supply and demand resources that survived the screening process. This step involves specification of the criteria to use in assessing resource portfolios, development of alternative resource portfolios designed to address different objectives, analytical integration of resources, explicit treatment of uncertainty (discussed in Chapter 6), assurance that the results of the analysis are internally consistent, presentation of avoided energy and capacity costs, explicit consideration of reliability and reserve margins, candid treatment of the environmental costs of electricity production, and review of the results for internal consistency.

CRITERIA FOR RESOURCE AND PORTFOLIO SELECTION

The selection of resource portfolios (analogous to the screening and selection of individual options) can be based on many different criteria (e.g., minimize revenue requirements, capital costs, or average electricity prices; ensure adequate reserve margins and the ability to meet high load growth; maintain certain financial ratios; or reduce environmental effects of electricity production). The utility should clearly specify what criteria it used in selecting individual resources and choosing among alternative resource mixes.

For example, Carolina Power & Light (1989) used several economic, financial, strategic, and reliability factors in assessing resource portfolios; the utility assigned each attribute a numerical weight and used the weights to rank alternative plans. Kansas City Power & Light (1991) wanted to maintain certain financial ratios, including minimum levels of internal cash as a percent of construction expenditures (Fig. 16) and interest coverage. Public Service Company of New Hampshire (1990) used five figures of merit in assessing alternative resources and resource mixes: energy service costs (equivalent to the total resource cost test), utility revenue requirements, electricity prices, utility net income, and carbon dioxide emissions.

On the other hand, one utility noted that "Each [resource] option has different characteristics and implications. Therefore, they are all evaluated with respect to other criteria [in addition to cost-effectiveness], such as availability, public acceptability, socio-economic and environmental impacts, and transmission impacts." Unfortunately, this utility provided no information on how these different resources were ranked on these different factors and how these rankings were weighted.

Fig. 16. Historical and projected values of internal cash as a percentage of construction expenditures for Kansas City Power & Light (1991). The utility was clear about its need to maintain an A-level or better bond rating and assessed alternative plans against this and other financial criteria.

MULTIPLE RESOURCE PLANS TO MEET DIFFERENT OBJECTIVES

The utility should develop, analyze, and report the results on alternative resource portfolios designed to meet different goals. To illustrate, the utility could analyze portfolios intended to minimize revenue requirements, total resource costs, societal costs, electricity prices, utility capital costs, or utility use of oil. Comparisons among these portfolios will show clearly the types of tradeoffs that must be made among competing objectives.

Southern California Edison (SCE 1989) began its process with a forecast that assumed no DSM programs. The company then identified four alternative customer-service strategies; these paths emphasized energy conservation, managed demand, energy productivity, and marketing. SCE developed alternative resource plans, including both demand and supply options, to meet each load-growth path and assessed the cost and rate impacts of each path. Forecasted sales ranged from 75,000 to 90,000 GWh in 1998 across these four paths. Ultimately, the company selected the energy-productivity path as the preferred choice.

Niagara Mohawk (1991) developed different resource portfolios for three scenarios reflecting the need for different amounts of new resources. These scenarios represent

different assumptions on load growth and the amount of nonutility generation that the utility must use. DSM options were grouped into "moderate, aggressive, and very aggressive DSM blocks based on the economic merits of individual programs." These DSM blocks were combined with various supply options to meet future resource needs. Altogether, the utility analyzed two portfolios for the low-need scenario, five for the base-need scenario, and three for the high-need scenario.

LCRA (1991) tested eight resource plans, which included different amounts of the following resource options: two levels of DSM programs, 88-MW combustion turbines (CTs), 200-MW pulverized coal units, 224-MW combined-cycle units, and 251-MW integrated gasification combined-cycle units. Each resource mix was examined for high and low assumptions on load growth, natural gas prices, power-plant capital costs; and DSM costs. Results were reported for unit costs ($\text{\$/kWh}$); revenue requirements; capital costs; fuel costs; reliability; flexibility; and emissions of SO_2 , CO_2 , and NO_x .

The final step in resource planning is the comparison of different resource portfolios (based on the analysis discussed above, in following sections of this chapter, and in Chapter 6) and the selection of a preferred portfolio that the utility will acquire.

This preferred resource plan* is unlikely to be the "least cost" plan under any particular conditions. Rather, it will reflect a balance among competing interests, such as minimization of revenue requirements, electricity prices, and environmental impacts. As PEPCO (1992) noted, "the 'least-cost' resource mix may not necessarily be the one with the lowest expected cost when compared to all other feasible resource plans." Its preferred plan differed slightly from the base case, least-cost plan in that the preferred plan will acquire more DSM resources and defer by one year the additions of several gas-fired CTs and combined cycle units.

In a similar fashion, Duke Power (1992) developed its recommended plan based on its initial resource integration and subsequent uncertainty analysis. Duke's preferred plan deleted two small DSM programs of questionable technical and economic viability and added baseload power as two 600-MW units rather than one 1200-MW unit.

Reported results on a utility's preferred plan should include the annual MW and GWh contributions from different resources (see Fig. 8 above, showing Green Mountain Power's resource plan in terms of energy and capacity), revenue requirements (including capital costs, fuel costs, and other cost components), electricity prices, emissions, reserve margin and other measures of reliability, and measures of utility financial performance (e.g., interest coverage and percent of construction internally funded). The net present value of key economic factors, especially revenue requirements and total societal cost, should also be presented.

*Some utilities, including PacifiCorp, develop separate preferred plans for each load forecast. These alternatives are then used to create a single action plan (Chapter 7).

INTEGRATION METHODS

Utilities typically use one of two general approaches to assess alternative resource portfolios. One method involves mathematical optimization, in which a dynamic programming model automatically selects the mix of resource options that meets the stated objective function (typically the lowest net present value of revenue requirements over a stated planning horizon). The primary strength of these models is their ability to identify *the least-cost* mix of resources. However, these models are complicated and often difficult to run. Also, their solutions depend strongly on the constraints and assumptions that are input to the model.

The other approach uses a simulation model, for which the user must provide the resource mix to be tested. This approach allows for (indeed, requires) substantial interaction between the analyst and the model. On the other hand, one can never be sure that *the least-cost* mix of resources has been identified; therefore, substantial iteration and trial and error are required with this approach to identify suitable resource portfolios.

Both approaches often involve linkages among several planning models. In general, utilities use screening models to develop a short list of resources (see Chapters 3 and 4) that are then subjected to detailed analyses, both individually and in various combinations. These models include capacity expansion, production costing, and financial analysis as well as the load-forecasting models discussed in Chapter 2.

San Diego Gas & Electric (SDG&E 1992) used an integrated screening approach to assess 105 resource options. These options were screened against three sets of planning assumptions concerning future prices of natural gas and the costs of environmental externalities. The utility found that integrated screening is important because the rankings of some resources, especially DSM, vary across the three planning scenarios: "This variation in the quantity of DSM points to the need for an integrated planning approach when developing least cost plans under uncertainty."

The screening process and criteria have important effects on the final mix of resources chosen for integration. For example, PacifiCorp (1992) used an estimate of the cost of a coal plant (5.5 ¢/kWh) plus a 10% credit for conservation and other credits for T&D to screen DSM programs. After taking all DSM programs with a levelized cost less than this hurdle rate, supply resources were used to meet the remaining gap between projected demands and existing resources. This approach may bias resource-selection decisions. In this case, if supply options were available at lower costs, too many demand resources would have been chosen. On the other hand, if supply resources cost more than the hurdle rate, then too few demand resources would have been chosen. The use of a hurdle rate makes practical sense, but uncritical use of such a factor can lead to biased results.

Duke Power (1992) begins its integration process by preparing a reference supply-only resource plan. The load forecast used to develop this plan includes the effects of the

company's past and current DSM programs. This plan is developed with a detailed capacity-expansion model that produces the least-cost mix of supply options to meet future load growth consistent with the existing mix of power plants. Duke then adds each candidate DSM program to the resource mix to assess its cost-effectiveness relative to the optimized supply-only plan. Those DSM programs that are cost-effective are then combined into various packages, and the packages are tested against the supply-only plan. The final plan includes those DSM programs that are more cost-effective than the reference supply plan and those supply resources that are still cost-effective after addition of the DSM programs.

Other utilities, including Puget Power and SDG&E, test various combinations of demand and supply alternatives in the search for a preferred mix of resources. Rather than begin with an optimized supply plan, they combine demand and supply options from the beginning.

No matter what type of modeling approach a utility uses, it should not subtract the effects of DSM programs from the load forecast and then analyze supply options only, as some utilities do (top part of Fig. 17). Subtracting DSM-program effects from the forecast and using the resultant "net" forecast for resource planning eliminates DSM programs from all integrating analysis. This approach makes it difficult to assess alternative combinations of DSM programs and supply resources and the uncertainties and risk-reduction benefits of DSM programs (e.g., small unit size and short lead time). For example, one utility considered ten resource plans in its uncertainty analysis, including different types of coal- and gas-fired power plants. However, each of these ten plans included the same amount of DSM.

DSM resources should be treated in a fashion that is both substantively and analytically consistent with the treatment of supply resources. Demand and supply resources should compete head to head (bottom part of Fig. 17). The plan must show how the process integrates and coordinates within the utility key functions like load forecasting, DSM resources, supply resources, finances, rates, and the important feedbacks among these components (especially between rates and future loads).

The Wisconsin Public Service Commission (1992) wrote

In Advance Plan 6, the supply-side options were evaluated using an optimization analysis. The demand-side options were evaluated separately, on an avoided cost basis. The next logical step toward fully integrated plans is to expand the supply-side optimization analysis to incorporate both supply- and demand-side on an integrated basis. Wisconsin utilities have now developed the resources and tools to achieve this.

Fig. 17. Different approaches used to analytically integrate demand and supply resources. The top part shows the traditional approach, in which the effects of DSM programs on electricity use and demand are subtracted from the forecasts. The resulting net forecasts are then used to develop a supply-only plan. The bottom part shows an integrated approach, embodied in several integrated planning models; t refers to the year of analysis.

SDG&E (1991) developed a sophisticated process to integrate demand and supply resources. The company noted that:

This problem of unequal evaluation standards [comparisons against different estimates of short- and long-run marginal costs] for different classes of resources is avoided by using an integrated capacity expansion process, as implemented by SDG&E in this filing, in which DSM is evaluated as an explicit resource option during the ICEM [integrated cost-effectiveness methodology] process. In this framework, DSM competes directly against the lowest candidate resource additions - the long-run avoided cost benchmark.

A related benefit of this approach stems from the fact that after new resources are added to the system, avoided energy, capacity and emission costs may significantly change and therefore affect the valuation of subsequent resource additions. ... To account for these important factors, SDG&E in applying this integrated capacity expansion process re-estimates the (i) production cost savings, (ii) system emission impacts, and (iii) capacity values after each new resource addition. This is an important refinement which is lost when static short-run avoided costs are used to evaluate DSM programs - allowing a multitude of serious distortions to enter the evaluation process.

Hill (1991) compared three methods often used to integrate demand and supply resources: (1) a sequential approach in which DSM resources are selected first (e.g., Wisconsin Electric), (2) a sequential approach in which supply resources are selected first (e.g., Duke Power), and (3) a simultaneous approach in which supply and demand resources are chosen together (e.g., NEES). His results suggest that the simultaneous approach yields the resource mix with the lowest total cost. Thus, this approach is both theoretically appealing and practically important.

During the past few years, several computer models, some of which run on microcomputers, have been developed that perform the integration shown in the bottom part of Fig. 17 (Eto 1990). Examples include the Load Management Strategy Testing Model, Multiobjective Integrated Decision Analysis Model, Conservation Policy Analysis Model, and UPLAN. While these models can facilitate the integration process, potential users should be aware of the limitations of these models. First, these models often do not replace the existing, stand-alone models used by the utility. Consequently, they must be benchmarked to the stand-alone models. Second, the ability of these integrated models to represent load-shapes often outstrips the available data, which creates a reliance on defaults whose relevance to the particular utility must be scrutinized. Third, although feedback effects are included in some integrated models, the treatment of electricity-price changes on future demands is often primitive. Typically, load forecasts are inputs to the integrated model from a stand-alone forecasting model.

Analysis of CAAA-compliance options adds to the complexity of resource integration but does not change its conceptual basis. Clean-air compliance adds several new options,

including modification of existing plants to reduce SO₂ emissions, early retirement of plants, changes in fuel type at plants, expansion of DSM programs to reduce sulfur emissions, and purchase or sale of allowances. Each of these options must be included in the capacity expansion part of the model as well as in the production costing part.

INTERNAL CONSISTENCY

At the end of the integration process, utilities should compare the initial assumptions on future electricity prices used as inputs to the load forecast with the prices produced by the integration process. The utility may need to iterate through the process (i.e., develop new load forecasts and resource portfolios) if the two sets of prices differ materially. Thus, electricity prices play a key role in "closing the loop" between the load forecast and the results of the planning process. Ensuring consistency between the avoided costs used to screen resources and those that result from the IRP process may also require iteration of the analysis.

To ensure internal consistency, Potomac Electric Power (1992) developed an iterative method that it calls full-loop integration (Fig. 18). The process begins with a load forecast that does not include the effects of PEPCO's DSM programs. To assess DSM programs, PEPCO uses marginal costs based on the average of forecasted loads with and without DSM. The programs determined to be cost-effective against this initial estimate of avoided cost are subtracted from the initial load forecast to produce a net forecast. PEPCO then develops a least-cost supply plan to meet the remaining gap between growing loads and existing (including DSM) resources. This process (the inner loop in Fig. 18) of assessing DSM programs and constructing a least-cost supply plan to meet the net forecast is repeated until the initial and final values of marginal costs are the same. At this point, the process is expanded to include a new load forecast. This expanded process (the outer loop in Fig. 18) is repeated until the initial and final values of electricity prices are the same.

AVOIDED COSTS

Because avoided energy and capacity costs (for generation, transmission, and distribution) play a vital role in assessing resource cost-effectiveness, the utility should report its estimates of these costs on an annual basis for the entire analysis period. At least two sets of estimates should be presented, those used in the screening stage and those that are outputs from the integration stage. The first set of estimates is used to screen resources (Chapters 3 and 4), while the second set is used to structure RFPs for acquisition of nonutility supply and DSM resources.

Fig. 18. Potomac Electric Power Company's "full-loop integration" process ensures that the values of electricity prices and marginal costs are internally consistent.

Some utilities include only the costs of a CT in their avoided costs. Unless the utility has no plans to add baseload capacity any time during the planning period, this assumption understates avoided costs. In essence, this approach ignores the energy-related capital costs of a baseload plant (e.g., the difference in cost per kW of a baseload coal plant and a CT, \$500 to \$1000/kW). Utilities build baseload plants because they provide low-cost energy (¢/kWh); therefore, the extra capital cost of such a plant should be assigned to energy costs rather than to capacity costs. Ignoring these costs undervalues DSM programs aimed at improving energy efficiency.

Northeast Utilities (1992) reported year-by-year values of avoided energy and capacity costs in its resource plan (Fig. 19). Because of uncertainties about when the next power plant will be needed, avoided capacity costs were treated probabilistically. Although the expected online date of the next power plant is 2005, additional capacity might be needed as soon as 1996 or as late as 2011.

Avoided capacity costs have several components. Because different resources (especially location-specific DSM programs) affect these costs differently, utilities should be explicit about the details of avoided cost. Figure 20 shows, as an example, the avoided generation, T&D, and energy costs associated with two types of DSM programs. One program cuts demand by 1 kW for every hour of the year (equivalent to a baseload power plant with 100% capacity factor). The second program also cuts demand by 1 kW, but for only 900 hours during the summer peaking season (equivalent to a peaking unit with a capacity factor of 10%). The avoided costs associated with these two programs are quite

Fig. 19. Annual values for avoided energy and capacity costs for Northeast Utilities.

Fig. 20. Georgia Power's (1992) avoided costs for two hypothetical DSM programs.

different. These distinctions among the components of avoided costs need to be considered in assessing alternative resource options and in structuring RFPs.

RELIABILITY AND RESERVE MARGIN

To ensure that customers experience few outages (and that those that occur are of short duration), utilities maintain minimum reserve margins, typically 15 to 20%. Although the assumed minimum reserve margin (or equivalent reliability criterion) has a substantial effect on the amount of resources to be acquired, the basis for these reliability criteria are rarely considered in IRP.

Detroit Edison (1992) offers a notable exception. It based its reserve margin requirement on the usual one day in ten years loss-of-load expectation and analyzed its minimum reserve margin on the basis of the availability of its power plants (Fig. 21) and the expected reserve margins and system availabilities of surrounding utilities. On the basis of this analysis, the utility concluded that it needed a minimum reserve margin of 15% in 1995, dropping to less than 14% after the year 2000.

Utility resource plans should also show how improved maintenance of power plants and T&D systems might lower required reserve margins. Similarly, the links between reserve margins and the locations, types, and diversity of new resources should be explained. Such a discussion is especially important for dispersed resources, such as renewables and DSM.

Fig. 21. System availability for Detroit Edison, 1980-1990.

TIME PERIODS FOR ANALYSIS

The utility analysis of alternative resource mixes must be carried out far enough into the future (e.g., at least 30 years) to capture the end effects associated with long-lived resources, such as coal plants and DSM programs aimed at new construction. The plan should recognize the time horizons required for different aspects of resource planning: 2 to 3 years for the action plan, 20 years for resource planning, and 30 years or more for analysis of end effects.

ENVIRONMENTAL COSTS

Because electricity production, transmission, and distribution have substantial environmental effects, utility resource plans must address these impacts. Not surprisingly, utilities use different methods to assess these impacts. This variety of methods is, in part, a reflection of the different state regulatory requirements that utilities face.* The simplest approach is to characterize and describe qualitatively the environmental effects of different resource options. A somewhat more complicated approach is to rank and weight the individual air, water, and terrestrial impacts of individual options. Finally, some utilities quantify and monetize the emissions associated with resource options. This approach requires quantification of the emissions (e.g., X tons of sulfur dioxide emitted per million Btu of coal) and monetization of these emissions (e.g., Y \$ of environmental damage per ton of sulfur dioxide). These monetary values (typically expressed in ¢/kWh) reflect the damages imposed on society by the emissions from a particular resource.

A few utilities have specific environmental goals. For example, NEES (1991) committed "to continuously reduce the environmental impact of its electric service by reducing net air emissions including greenhouse gases from its operations by an estimated 45%" by the year 2000. The NEES (1992) resource plan shows the resources to be acquired and how they will help the utility meet the 45%-reduction goal.

PacifiCorp (1992) conducted a sensitivity analysis with respect to the external costs of different resources. Four sets of costs were tested for SO₂, NO_x, particulates, and CO₂, all expressed in \$/ton. For example, values of \$0, \$5, \$10, and \$30/ton of CO₂ were tested. Using these externality values in the selection of resources showed how different estimates of environmental costs affected the resource portfolio chosen, utility revenue requirements, and electricity price. As the environmental level (cost) increased, so did the amount of renewables and gas-fired generation. Except for environmental level 4, the revenues, prices, and even emissions differed only slightly (Table 3).

*As of mid-1992, 19 PUCs had adopted rules requiring utilities to consider explicitly environmental externalities (Arizona Corporation Commission 1992).

SDG&E (1991) examined several resource portfolios with environmental externality adders based on the values adopted in Nevada and the (higher) values for California's South Coast Air Quality Management District (Fig. 22).

Table 3. Results of PacifiCorp's analysis of the effects of different environmental-externality costs

Environmental level (cost)	Net present value of revenue (billion \$)	Electricity price in 2011 (1991-¢/kWh)	Percent increase in emissions to 2011		
			CO ₂	SO ₂	NO _x
1	31.33	4.51	32.2	12.4	-8.3
2	31.31	4.51	30.0	12.1	-12.0
3	31.31	4.52	29.0	12.7	-11.7
4	31.73	4.58	26.1	11.3	-12.6

Source: PacifiCorp (1992).

Fig. 22. Analysis of capital, operating, and environmental costs (equivalent to the societal test) conducted by SDG&E (1991). Although the direct (capital and operating) costs of the resource mixes decline in going from Case 1 to Case 5, the environmental costs do not.

Consumers Power (1992), as part of its scenario analysis, considered two global-warming cases. These scenarios included a tax on CO₂ (\$30/ton beginning in 2000) or a cap on CO₂ emissions (a requirement to reduce emissions to their 1990 level beginning in the year 2000). By 2007, the emissions-limit case included four times as much DSM as the base case, a 28% reduction in carbon emissions, and a 4% increase in revenue requirements from 1993 to 2007.

Because the estimates of monetized environmental costs vary so much, many utilities are reluctant to use this approach in resource planning. An alternative to monetization of environmental externalities is to conduct a tradeoff analysis. Andrews (1991) examined the New England Power Pool system from 1990 to 2010. His analysis shows the tradeoffs between revenue requirements and emissions for different resource portfolios (Fig. 23). His analysis suggests that use of low-sulfur fuels plus DSM programs reduces both costs and emissions. Fuel switching lowers emissions but not costs, while DSM lowers costs but not emissions. Together, the two types of resources operate synergistically.

In assessing alternative strategies to meet environmental regulations, utilities should also consider possible future environmental requirements. For example, Bernow (1992) examined the tradeoffs between different ways to comply with the CAAA and their effects on utility CO₂ emissions. His analysis showed that various strategies to reduce SO₂ emissions have very different effects on CO₂ emissions (Fig. 24).

Clearly, utilities can adopt different approaches and values to assessing the environmental effects of different resource portfolios. It is also clear that utilities cannot ignore these costs of producing electricity in resource planning.

Fig. 23. Tradeoffs between sulfur emissions and revenue requirements for various resource portfolios for the New England Power Pool (Andrews 1991). The solid curve shows the envelope of preferred solutions.

Fig. 24. Tradeoffs between reductions in sulfur emissions and carbon dioxide emissions for a midwestern utility.

UNCERTAINTY ANALYSIS

A thorough analysis of a variety of plausible future conditions and the options available to deal with them is essential to a good resource plan. Such an analysis would use one or more of the following techniques: scenario analysis, sensitivity analysis, portfolio analysis, probabilistic analysis, or worst-case analysis (Table 4) (Hirst and Schweitzer 1990). These techniques should be used to assess uncertainties about both the utility's external environment and factors at least partly under the utility's control.

Table 4. Analytical techniques used to treat uncertainty

Scenario	Alternative, internally consistent, futures are constructed, and then resource options are identified to meet each future. Best options can then be combined into a unified plan.
Sensitivity	Preferred plan (combination of options) is identified. Key factors are then varied to see how the plan responds to these variations.
Portfolio	Multiple plans are developed, each of which meets different corporate goals. Often, these plans are then subjected to sensitivity analysis.
Probabilistic	Probabilities are assigned to different values of key uncertain variables, and outcomes are identified that are associated with the different values of the key factors in combination. Results include the expected value and cumulative probability distribution for key outcomes, such as electricity price and revenue requirements.
Worst-case	Utility creates a plan to meet an extreme set of conditions (e.g., high load growth and high fuel prices) and later learns that it faces an entirely different set of conditions (e.g., low load growth and low fuel prices). The utility then adjusts its resource acquisitions to meet the newly perceived conditions.

Source: Hirst and Schweitzer (1990).

Uncertainties about the external environment include economic growth, inflation rates, fossil-fuel prices, regulation, and the price of sulfur allowances. The analysis should also consider uncertainties about the costs and performance of different demand and supply resources. The analysis should show how utility resource-acquisition *decisions* are affected

by these different assumptions and show the *effects* of these uncertainties and decisions on customer and utility costs. Differences among resources in unit size, construction time, capital cost, and operating performance should be considered for how they affect the uncertainties faced by utilities. The CAAA create additional uncertainties for utilities, including the cost and performance of scrubbers, the costs of different fuels, and the costs of sulfur allowances. The assumptions must be varied in ways that are internally consistent and plausible.

PacifiCorp (1992) developed different, scenario-specific mixes of CTs, renewable resources, DSM programs, cogeneration, and coal plants (Fig. 25). PacifiCorp's scenarios included, in addition to the medium-high forecast, electrification (leading to higher load growth), loss of major generating resources, high natural-gas prices, and a \$30/ton tax on CO₂. For each scenario, results were presented on the amounts of each resource acquired; utility operating revenues; average electricity prices; and emissions of sulfur dioxide, nitrogen oxides, and carbon dioxide.

NEES (1992) conducted probabilistic analyses as part of its IRP. Staff from various departments assessed the probabilities associated with the performance and online dates of the different demand and supply resources being considered. The company selected as a planning goal an 80% probability that, in the first five years (i.e., through 1996), planned resources will meet or exceed projected requirements. Over the next five years (to the year

Fig. 25. PacifiCorp's (1992) scenario analysis showing the amounts of different types of resources to be acquired for each scenario (between 1992 and 2011).

2001), the required probability was reduced to 50%. This analysis was especially appealing because it combined scenario and probability analyses to develop useful results (Fig. 26). Boston Edison (1990) conducted a similar probabilistic analysis to quantify the tradeoff between reliability and costs. Its results indicated that the 80% confidence level is appropriate for the first ten years of its resource plan.

While many utilities consider uncertainties about supply resources, few pay attention to uncertainties about DSM programs (in part, because the models that utilities use do not treat DSM as a resource; see Fig. 17). Uncertainties about the cost and performance of DSM programs or the potential benefits of their small unit size, short lead time, and load-following ability are rarely addressed (Hirst 1992).

NEES and the Northwest Power Planning Council offer rare examples of such analyses. NEES (1990) assessed the probability of achieving different levels of demand reductions because of its DSM. This analysis showed, as an example, that DSM programs have an 80% probability of reducing peak demand by at least 400 MW in 1995 and a 50% probability of cutting demand by at least 580 MW that year. However, the analysis did not examine the costs and benefits of resource portfolios that included more or fewer DSM programs.

Fig. 26. New England Electric System's probabilistic analysis, showing the probabilities that its resource capabilities will exceed that required. The company's goal is to be 80% confident that it can meet its requirement for the first five years, declining to 50% after ten years.

The Northwest Power Planning Council (1991) tested five alternative conservation-acquisition portfolios. The Council selected the "medium-high target because it increased cost only slightly more than a medium target, while at the same time substantially reducing future risk." The standard deviation of total resource costs was used as the measure of risk in this analysis.

Southern California Edison's (1991) San Onofree Nuclear Generation Station 1 (SONGS1) needed \$125 million of capital improvements to continue operating. To test the value of this investment, SCE analyzed 32 cases with different assumptions on the values of environmental externalities, future natural gas prices, DSM, the capacity factor of SONGS1, and the capital costs of extending the life of SONGS1 (Fig. 27). The utility's analysis suggested that the continued operation of SONGS1 would be cost-effective.

The California PUC directed SCE to expand its uncertainty analysis to show the effects of assuming a SONGS1 capacity factor of 44%, based on the low historical values of the plant's capacity factor. SCE analyzed cases with capacity factors of 44 and 50% (compared with the 60, 70, and 80% values used earlier). For both of these additional cases, the net benefits were generally negative. Ultimately, SCE decided to shut down the plant.

Fig. 27. Results of the uncertainty analysis conducted by Southern California Edison on the benefits of extending the lifetime of its San Onofree Nuclear Generating Station 1. Based on its initial assumptions concerning capacity factor, the continued operation of the plant was cost-effective. Based on assumed lower capacity factors, however, the plant was not cost-effective.

This uncertainty analysis illustrates three critical points about this part of IRP. First, the analysis should focus on key decisions that the utility will face during the next few years. A reasoned treatment of the key uncertainties that the utility can influence is far more valuable than an exhaustive treatment of all uncertainties with little regard for their importance. Second, the input assumptions must be reasonable and encompass a broad enough range to show the effects of uncertainties. Third, including nonutility parties in the uncertainty analysis can help with the first two issues.

A large utility in the south illustrates the reluctance of some utilities to examine publicly the critical decisions it faces. This utility had decided to build several hundred MW of CTs scheduled to come online in 1995 and 1996. Since the time of that decision, load growth had slowed because of a recession and because the company had started several ambitious DSM programs. Therefore, the company was uncertain whether to continue construction of the turbines (Fig. 28). On one hand, the company had received its air-quality permit, which required construction to begin within 18 months. Delaying construction beyond that time would create new uncertainties about the time required to gain a new air-quality permit and the possibility of more stringent requirements at that time. On the other hand, the utility's current load forecast (based on slow economic growth and the success of its DSM programs) suggested that it should delay construction. What to do? Unfortunately, the utility's resource plan was silent on this critical issue, robbing the PUC and others of the chance to contribute to a decision concerning continued construction of these units.

Union Electric's (1990) uncertainty analysis focused on the dates by which the company would have to decide to build certain types of power plants. These decision dates were tested against uncertainties related to load growth, acid-rain requirements, and oil-price changes (Fig. 29). Results showed that a decision on the next intermediate power plant could be delayed at least three years and possibly as long as 13 years. Decisions on the next peaking unit, however, could under high-growth conditions be required that year; under the other cases, that decision could also be postponed for up to six years.

Regardless of the types of uncertainty analysis conducted, the links between the results of these analyses and the utility's resource-acquisition decisions must be demonstrated. The uncertainty analysis should also demonstrate the robustness of the selected resource plan. For example, Georgia Power's (1992) risk assessment examined the possibility that a non-combustion turbine (something other than a peaking unit) would be needed before the year 2000. It examined uncertainties related to alternative financial, environmental, load-growth, fuel-cost, and generating-unit characteristics to assess these possibilities. The results, according to the company, "point overwhelmingly to combustion turbines as the generation additions for the mid-1990s," lending confidence to its decision to build several CTs this decade. The mix of resources selected should be able to withstand the shocks of different futures and should minimize the risks associated with various adverse outcomes (e.g., rapid increases in oil prices or a moratorium on nuclear power).

Fig. 28. Decision tree showing uncertainties and possible decisions concerning construction of CTs. The company must decide now whether to build or defer. If it defers construction, it can observe load growth and then use this new data later to decide whether to build or defer again. Deferral past 18 months risks higher costs and delays in getting a new air-quality permit.

Fig. 29. Results of Union Electric's analysis showing the effects of several uncertainties on the decision and in-service dates of peaking and intermediate power plants.

ACTION PLANS AND PROGRESS REPORTS

SHORT-TERM ACTION PLANS

The utility's action plan is, in many ways, the "bottom line" of the resource plan. Because it reflects the utility's commitments to specific actions, it may be the most important part of the plan. The action plan must be consistent with the long-term resource plan to assure that what is presented as appropriate for the long haul is actually implemented, and implemented in an efficient manner. If, for example, the long-term plan calls for acquisition of baseload power in ten years, the short-term plan should call for initial site selection, environmental assessment, and facility design. Alternatively, a short-term plan that includes marketing programs to boost off-peak sales might be inconsistent with a long-term need for additional baseload power.

The action plan should be specific and detailed. The reader should be able to judge the utility's commitment to different actions from this short-term plan. Specific tasks should be identified along with organizational assignments, milestones, and budgets. The action plan should present the utility's expected accomplishments during the next few years, including the number of participants and the reductions in annual energy use, summer peak, and winter peak for each DSM program.

Such detail serves two purposes within the utility. First, preparing the action plan necessarily involves those departments that are responsible for implementation, which encourages the planners and operators to work closely together. Thus, the action plan is more likely to be implementable than if it is developed by planners alone. Second, the detail provides a useful road map for its implementors.

The action plan can be used by PUCs to ensure that utility budgets and rate-case filings are consistent with the long-term resource plan.

The Portland General Electric (PGE 1990) action plan included nine tables showing actions planned for 1991 and 1992 to capture DSM lost opportunities by market segment, discretionary DSM resources by market segment, DSM R&D activities (e.g., technology assessment and pilot programs), T&D system actions, enhancements to existing utility-owned resources, acquisition of new supply resources, development of renewable resources, development of customer resources, and monitoring of key indicators (e.g., oil and gas prices). Each table included specific actions, timing, program impact, and estimated budget. For example, the table on new supply resources committed PGE to "implement a competitive bid solicitation to coincide with a projected need for power in 1996" with an estimated program impact of 200 MW and 160 MWa.

The PEPCO (1992) action plan, a separate chapter in its IRP, included estimates of participation and MW and MWh reductions for each DSM program, as well as planned program costs in both Maryland and the District of Columbia for 1992, 1993, 1994, and 1995. This chapter also showed the planned schedules for completion of several CTs and NUG projects. For example, one table showed the planned costs for each generating station year by year from 1992 through 1995.

The action plan should also discuss the data and analysis activities, such as model development, data collection, and resource assessments, needed to prepare for the next resource plan. Utilities should also include commitments to evaluations of their DSM programs in the action plan. Because many of the IRP topics were new for it, the LCRA (1991) action plan emphasized data collection and analytical techniques. The utility, for example, committed to the preparation of a "combustion turbine contingency plan" to help it decide when to begin construction of a CT and a comparable "demand-side 'fall back' plan." LCRA also committed to scenario analysis to assess different resource portfolios, improvements in its fossil-fuel price forecasts, and procedures to monitor and evaluate its DSM programs. Nevada Power's (1991) action plan is quite detailed on its plans to enhance inhouse IRP capabilities. This chapter shows for each year the costs of personnel, consulting and data acquisition, modeling software, hardware, training, and miscellaneous.

One utility's resource plan contained many positive statements about DSM, such as "systematic and fair consideration of supply- and demand-side options," "balance supply and demand using those options that most economically and efficiently meet energy needs and values of customers," and "78 potential [DSM] programs spanning all customer classes." The bottom line was a resource plan that included 4% DSM and 96% supply resources, hardly consistent with the rhetoric on DSM. This utility's action plan was only a few pages long and contained no specifics on budgets, milestones, or energy- and demand-reduction goals.

Both the utility and readers of the IRP report should recognize that not all the projects presented in the action plan will be completed as specified. As circumstances and opportunities change, the utility should respond accordingly. Thus, the action plan is the utility's plan as of a certain date. Because changes will occur in the utility's environment (e.g., local economic growth, fossil-fuel prices, environmental regulations, or experience with its DSM programs), the plan should indicate how, and under what circumstances, the utility will revise its action plan. In other words, the action plan states the utility's planned accomplishments more than its planned activities.

ANNUAL PROGRESS REPORTS

The utility should prepare annual progress reports that explain its activities in implementing the action plan during the past year. These interim reports should be prepared during the off years. For example, if a utility files long-term resource plans in 1993 and again in 1996, then progress reports should be filed in 1994 and 1995.

These progress reports should follow much the same format used in the short-term action plan, showing accomplishments in resource acquisition and in collection and analysis of additional data and development of improved analytical methods. These reports should also indicate when (and why) plans are changed. For example, Duke Power's (1991) progress report, explained why it had delayed the online dates for the first of several planned CTs.

Duke Power (1992) included in its IRP report a section entitled Major Developments Since the 1989 Plan, which summarized its recent rate cases, completion of a 1065-MW pumped-storage facility, initiation of construction of 1200-MW of CTs, initial responses to the 1990 CAAA, and problems with stress-corrosion cracks at its nuclear units.

PEPCO (1992) included a similar chapter, reporting on recent growth in peak demand, the performance of its DSM programs, recent agreements with NUGs, and federal and state regulatory changes since completion of the 1990 plan.

Puget Power (1992) included a chapter entitled Major Accomplishments, showing what it had achieved since completion of its 1989 IRP on conservation, supply-side alternatives, T&D, regional involvement, leading indicators and monitoring (collecting more and better data on important variables such as natural gas prices), and planning and evaluation (bidding, rate design, and public involvement). Appendix A to the plan is an 87-page discussion of the company's activities on each item in the 1989 IRP action plan.

The Ontario Hydro (1992) update of its 1989 plan shows that substantial changes can occur within a few years. Although the overall need for resources did not change between mid-1989 and early 1992, the utility's resource mix changed dramatically. The revised plan calls for much more DSM, nonutility generation, and life extension at existing plants and much less construction of utility-owned plants (Fig. 15).

PUBLIC PARTICIPATION

Because the interests of all stakeholders in a utility's resource plan are not identical, the ways in which these interests will be affected by utility actions will differ. Therefore, utilities should seek the advice of and inputs from different groups as they develop resource plans. In addition, utilities should report results for various resource plans along enough dimensions so that different groups can assess the plan's effects on them; see discussion in Chapter 5 on multiple resource plans.

Different interests implicitly weight different attributes of resource plans in different ways. These attributes include short- and long-term electricity prices and costs, shareholder earnings, reliability, power quality, pollution from electricity production, and other results of utility actions. For example, residential customers may be interested primarily in electricity bills, large industrial customers in electricity prices, utility shareholders in earnings, bondholders in interest coverage, nonutility generators and DSM providers in the fairness and consistency with which "their" resources were considered, and regulators in various outcomes, including emissions of pollutants.

Unfortunately, some utilities treat public involvement as one-way communication in which they "sell" their plan to others. But without two-way communication between the utility and its customers and interest groups, a plan is in danger of ignoring community needs. Equally important, a plan developed solely by utility personnel is likely to lack the breadth that outside perspectives can give to the process. Accordingly, the plan should present evidence that the utility sought ideas and advice from its customers and other interested parties. Energy experts from local universities, the state energy office, the PUC, environmental groups, and organizations representing industrial customers should be consulted as the plan is being developed. So too should trade allies, such as building contractors, appliance dealers and wholesalers, nonutility generators, and fuel suppliers.

Utilities in the Pacific Northwest, including Puget Power and PacifiCorp, invite nonutility experts, customers, and other interested stakeholders to participate in plan development and review. The PGE (1990) resource plan includes a separate chapter called Public Process, describing the company's Least-Cost Plan Advisory Group, which included 35 professionals from other utilities, the Oregon PUC, Northwest Power Planning Council, customer groups (including large industrial customers), and trade allies (an energy service company and the homebuilders association). The utility held six meetings with the group. The group also reviewed draft materials as the IRP was being developed. PGE also used another group, the Customer Advisory Panel, to gain outside perspectives on its planning process and resource portfolios. This group, which included 11 PGE customers from

different parts of the service area, met five times. Puget Power and PacifiCorp conducted public-participation processes similar to PGE's.

NEES has a Demand Side Advisory Board comprised of industrial customers, university professors, environmental groups, and utility management. Some utilities use collaborative working groups, especially for issues related to the planning and assessment of DSM programs (Raab and Schweitzer 1992). These collaboratives typically involve, in addition to the utility, environmental groups, the state's consumer advocate, the state energy office, PUC staff, and representatives of different customer groups (typically large industrial and low-income residential). These groups study and agree on appropriate approaches to different program-design and policy issues, including those shown in Table 5. For example, utilities in New England are working closely with the Conservation Law Foundation to design, implement, and evaluate DSM programs. Such public involvement might cause short-term delays for the utility, but is likely to serve long-range utility and societal interests.

Table 5. Spectrum of issues addressed by DSM collaboratives

Least difficult

- Identify potential DSM technologies
- Package DSM measures into programs
- Screen measures and programs for cost-effectiveness
- Design evaluation plans
- Select cost-effectiveness tests for screening
- Select annual budgets for DSM programs
- Design incentives to encourage utilities to run DSM programs
- Decide how to treat environmental externalities
- Decide whether and how to examine fuel switching

Most difficult

Source: Raab and Schweitzer (1992).

As a counterexample to the preceding efforts to gain new insights and perspectives, one utility, apparently not very interested in public participation, created an advisory panel, none of whose members had any knowledge of utility planning. As a consequence, the three meetings that the utility held with this group were devoted primarily to lectures from utility staff on the components of IRP. The relative inexperience of the panel members made it virtually impossible for them to offer any review of, or guidance on, the company's resource plan.

Individual groups will judge the acceptability of impacts resulting from a given plan themselves. The plan must provide sufficient information so that different groups can assess the costs and benefits to them of the utility's preferred plan and its alternatives. Wisconsin Electric (1989) presented results for three plans that differed in the company's DSM

programs. For each plan, estimates were given of annual revenue requirements, total (utility plus customer) costs, electricity prices, sulfur dioxide emissions, nitrogen oxide emissions, particulate emissions, ash production, and capital requirements. Such estimates should provide the information different groups need to assess roughly the benefits and costs of different resource-acquisition strategies. Thus, the economic and other criteria used to include specific resources must be clearly specified; the effects of these criteria on the selection of individual resource options must also be stated.

Northeast Utilities (1989), as part of its planning process, identified several "themes [that] are intended to reflect its interpretation of current public and corporate policy objectives, and are useful in helping decision makers compare alternative resource plans that emphasize different objectives." The company's themes included resource portfolios that emphasized energy efficiency in construction of new buildings, use of small-scale supply resources, and reductions in dependence on oil-fired generation.

It is unlikely that utility attention to the interests and concerns of different groups will eliminate controversy about utility actions. However, such attention will yield some areas of consensus (which should be presented in the planning report) and will more sharply define the areas where disagreements still exist.

Finally, the utility should document its responses to the comments offered by nonutility parties during plan development. One utility, which ran a comprehensive and extensive public-involvement process, nevertheless angered some of the participants. Because the utility provided no feedback on their comments, particularly the reasons why some were rejected, these participants felt that their inputs were largely ignored.

THE IRP REPORT

Although resource planning is an ongoing process, utilities should periodically publish formal reports on their plans. Depending on the need for resources and the speed with which the external environment is changing, once every two or three years seems appropriate.

The primary purpose of an IRP report is to help utility executives decide which resources to acquire, what amounts to acquire, and when to acquire those resources. The planning report documents the utility's decisions and helps the PUC and public to review and understand the basis for the utility's decisions. Thus, the report must be useful both within and outside the utility. The report provides a forum for the utility to present its vision of the future and how it plans to meet that future. The report provides utility data, assumptions, analyses, results, and plans to customers and regulators. For this information to be useful, the report should be easily understood by different groups and should point the reader to further information as needed.

The utility's plan should be well written and appropriately illustrated (with many tables and figures, such as those used in this report). Table 6 presents a suggested outline and organization for an IRP report. The writing style should be aimed at an audience of intelligent and interested people with modest technical backgrounds.

Preparing a document that serves the needs of different readers is difficult. Some utility plans are so detailed and complicated that only the most technically sophisticated readers can understand what the plan contains. At the other end of the scale, some utilities publish short, glossy documents that present only limited information on the resource plan. The lack of detail frustrates readers interested in how the utility developed its preferred plan. One utility, while genuinely interested in resource planning, produced only a short summary report; ample documentation existed within the utility, but only in the form of loose-leaf binders in the offices of planners and analysts.

The utility's plan might best be presented in more than one volume. Several utilities prepare three sets of documents: an executive summary, a plan, and one or more volumes of technical appendixes as necessary.

Table 6. Suggested outline for utility report on its integrated resource plan

Executive Summary (25 to 50 pages)

- Objectives of this IRP, including criteria for resource selection
- Resource options considered and those accepted
- Preferred resource portfolio and the basis for its selection
- Summary of short-term action plan

The Plan (75 to 200 pages)

- Overview and objectives of the plan
- Progress since completion of previous plan
- Long-term load forecasts
- Comparison of load growth with existing resources
- Demand-side resources
 - Past and current programs and their effects
 - Future potential and programs
- Supply resources
 - Existing resources
 - Potential new resources
- Resource integration
 - Methods used to screen resources
 - Criteria for resource selection
 - Assessment of alternative resource portfolios
 - Uncertainty analysis
 - Environmental analysis
- Preferred resource mix
- Short-term action plan
- Glossary
- References

Technical Appendix (no page limit; bound separately from plan)

The Executive Summary might include: (1) the objectives of the IRP and how the plan intends to achieve the objectives, (3) the specific supply and demand resource options considered, those that were chosen for inclusion in the resource plan, and how those selections are consistent with the objectives of the IRP, (4) an overview of the environmental impacts of the plan, (5) a summary risk assessment of the plan, and (6) a summary of the short-term action plan. The Northwest Power Planning Council (1991) published a 50-page summary, backed up by almost 1000 pages of details bound in two additional volumes.

The full report should discuss the goals of the utility's planning process, explain the process used to produce the plan, present load forecasts (both peak and annual energy), compare existing resources with future loads to identify the need for additional resources,

document the demand and supply resources considered, describe alternative resource portfolios, show the preferred long-term resource plan, and present the short-term actions to be taken in line with the long-term plan. The report should also explain the technical aspects of the planning process as described above.

Puget Power (1992) and Georgia Power (1992) prepared multivolume plans. Puget Power published a 90-page resource plan, backed by a separate volume with eight appendixes on status report since completion of the previous plan, business environment, existing resources, conservation potential, supply alternatives, transmission, public involvement, and detailed scenario results. Georgia Power's plan included a separate Executive Summary, a ~200-page plan, plus technical documentation bound separately.

The report should include references to other company publications, to reports from other utilities, and to the relevant literature on forecasts, supply resources, and demand resources. This list will help interested readers examine certain issues in greater detail and will also demonstrate the utility's knowledge of what is happening at other utilities, PUCs, EPRI, national laboratories, universities, and consulting firms.

Because the information to be presented is detailed and complicated, utilities should find effective and visual ways to show results. NEES (1991) and Green Mountain Power (1991), as examples, presented the key results of their long-term plan in a compact fashion (as shown in Fig. 8).

Important future decision points should be identified, and the use of monitoring procedures to provide input for those decisions should be explained. The most significant effects of choosing among the available options (in terms of capital and operating costs, resource availability, environmental effects, etc.) should be discussed. The report should also briefly describe the methods used to develop the plan, including uncertainty-analysis techniques. Finally, the plan should point the reader to more detailed documentation on each of the above topics. Placing this documentation in a technical appendix makes this information available to technical specialists without cluttering the utility's resource plan.

The Wisconsin Public Service Commission, in an effort to make the results of the utilities' plans more accessible to the public, adopted an innovative approach to interutility coordination and publications (Wisconsin Electric Utilities 1991). In Advance Plan 6, the utilities filed a joint state plan that met the requirements of the Commission. They also filed alternative plans to test Commission-specified uncertainties, as well as other plans the utilities wanted to file. These summary documents represent the top of the pyramid in Fig. 30, the A level.

Supporting these two summary, statewide documents are three more levels. The ten B documents briefly present each utility's plan (essentially an executive summary of 10 to 20 pages of the D documents). The C documents cover 12 different issues, including: how the utilities developed their plans, forecasts, conservation and load management, nonutility generation, cogeneration, renewables, power plants, transmission, use and cost sharing,

transmission interface study, environmental issues, and research and development. The D (most detailed) documents include the 10 individual utility plans plus 16 studies on individual issues. Except for the D documents, these reports are aimed at the general public.

The Wisconsin Public Service Commission, to increase public involvement, prepared a simple booklet, *The Advance Plan Process & You*, in early 1991. The booklet explains how people could get involved in reviewing utility plans and what the process from the March 1991 utility filings to the September 1992 Commission order entails. Other booklets in the Commission's public-document series dealt simply with power plants, electric lines, transmission planning, energy efficiency, electric and magnetic fields, global warming, renewable resources, cogeneration, and municipal utilities.

Fig. 30. The Wisconsin Public Service Commission required the utilities to file resource plans at various levels of detail. The A level includes documents that summarize, at the state level, the utility plans. The B level includes summaries of each utility's plans, and the D level includes the details of each plan. The C level discusses key resource-planning issues.

Fig. 31. Schematic developed by the Wisconsin Public Service Commission to show the number and type of power plants to be built in Wisconsin during the coming decade.

CONCLUSIONS

Integrated resource planning is a powerful and flexible way for utilities to plan for and manage the resources needed to provide their customers with desired energy services at a reasonable cost. IRP includes a broad array of supply and demand resources, explicit treatment of uncertainty, consideration of environmental costs as well as direct economic costs, and public involvement. Because of these features, IRP is likely to yield a better mix of resources and fewer controversies among the utility, its regulators, and the public than would traditional planning approaches.

By considering a large number and variety of resource options, IRP ensures that the plan adopted will be lower in cost, more environmentally benign, subject to fewer risks, and more acceptable to the public than would a plan that was developed entirely within the utility and that considered only a few supply options.

During the past few years, IRP has expanded along several dimensions. First, more utilities in more parts of the country are preparing and presenting integrated resource plans. Second, the technical quality of these plans is improving. Third, the plans are addressing additional important topics, such as fuel switching and bidding for resources. Finally, gas utilities are beginning to develop resource plans, building on the experiences of electric utilities.

While the overall quality of electric-utility resource plans has improved substantially during the past few years, the variation across utilities is substantial. Some utilities meet most of the criteria for a "good" IRP discussed in this report and presented in Table 7. Unfortunately some utility plans meet few of these criteria. The "inadequacy" of some utility plans is often more a function of the regulatory requirements or specific purposes for which the plan was produced rather than a failure of the utility. I hope that publication of these guidelines and the utility-specific examples that accompany each suggestion will stimulate discussions within utilities and regulatory commissions. These discussions will likely lead to further improvements in resource planning and more widespread applications of these planning enhancements.

Table 7. Checklist for a good integrated resource plan

Technical competence — positively affect utility decisions on resource acquisitions and regulatory approval thereof; ensure that decisions are based on thorough analysis of present and future conditions and of alternative resources

- Comprehensive and multiple load forecasts
 - Energy and peak loads
 - Clear relationships between forecasts and utility DSM programs
- Thorough consideration of supply options, including T&D options as well as life extension, repowering, and fuel switching of existing plants, purchased power (from utility and nonutility generators), renewable energy sources, and utility construction of power plants
- Thorough consideration of DSM options and programs
 - Examine existing DSM programs
 - Screen wide range of DSM options
 - Combine promising options into a few programs; estimate program costs, participation rates, and effects on annual energy use and peak demand
- Integration of demand and supply options
 - Consistent economic tests used to select resources for integration
 - Similar screening methods to yield broad and comprehensive lists of options
 - Head-to-head competition in integration and in uncertainty analysis; planning models must be capable of selecting and analyzing different combinations of both supply and demand options
 - Consistency between initial estimates of electricity prices and avoided costs and price and cost outputs from plan
 - Presentation of results for different integrated resource plans
- Thoughtful uncertainty analyses
 - Consider uncertainties about external factors and about resources
 - Develop alternative plans for different futures
 - Assess performance of preferred plan under different assumptions and show how uncertainty affects choice of preferred plan
- Full explanation of preferred plan and its close competitors
 - Explain resource-selection criteria
 - List key assumptions (e.g., inflation rate, debt/equity ratio, and reserve margin)
 - Show how plan addresses critical issues facing company
 - Present results for utility revenues, total costs, electricity prices, reliability, fuel and technology diversity, utility financial indicators, and environmental effects
- Use of appropriate time horizons: 2 to 3 years for action plan, 10 to 20 years for planning, and 20 to 40 years to account for end effects

Table 7. Checklist for a good integrated resource plan (continued)

Adequacy of short-term action plan — document utility's commitment to acquire the resources called for in the long-term plan and to collect and analyze additional data to improve planning process

- Show budgets, departments, and milestones for key actions
- Include future data-collection and analysis activities as well as resource acquisition
- Report progress since preparation of previous resource plan

Fairness of plan — provide information so that different interests can assess the plan from their own perspectives

- Adequate participation in plan development and review by local energy experts, representatives of different groups of customers, environmental groups, etc.
- Sufficient detail in report on effects of different plans, such as utility revenue requirements, total costs, electricity prices, environmental emissions, earnings, and interest coverage

Clarity of plan — adequately inform various groups about future electricity resource needs, resource alternatives, and the utility's preferred strategy

- Clear writing and ample use of graphs and tables
 - Comprehensible to different groups, including utility staff, investors, PUC, public interest groups, and customers
 - Clear presentation of critical issues facing utility, its preferred plan, the basis for its selection, and key resource-acquisition decisions to be made
 - Logical report structure: Executive Summary, Report, Technical Appendixes
-

ACKNOWLEDGMENTS

I thank the many utilities that provided me with copies of their resource plans. I also thank Martin Schweitzer, Evelin Yourstone, and Joseph Eto, the coauthors of the original ORNL report on which this one is based; this report follows closely the structure of the original report that they helped prepare. I thank David Berry, Jeremy Bloom, Chris Chouteau, Richard Clarke, Richard Collins, Stephen Connors, Nancy Esteb, David Engberg, Thomas Foreman, James Gallagher, Cheryl Harrington, Joseph Hipius, Nancy Korda, Jonathan Lowell, David Moskovitz, and Russell Tucker for reviewing a draft of this report. Their insightful comments helped me prepare a better final report. Fred O'Hara edited and proofread the report, and Ethel Schorn shepherded the final report through the ORNL clearance, printing, and distribution process.

REFERENCES

C. J. Andrews 1991, *The Marginality of Regulating Marginal Investments: Why We Need a Systemic Perspective on Environmental Externality Adders*, Energy Laboratory, MIT, Cambridge, MA, June.

Arizona Corporation Commission 1992, *Environmental Externalities Task Force, Report of Subcommittee 1, Monetization of Environmental Externalities*, Phoenix, AZ, May.

S. Bernow 1992, "Coordinating Clean Air Act Compliance with Integrated Resource Planning: The Role of Environmental Externalities," NRRI Workshop on Clean Air Act Compliance, Charlotte, NC, April 14.

Bonneville Power Administration 1991, *1992 Resource Program, Conservation Implementation Plan*, draft, Office of Energy Resources, Bonneville Power Administration, Portland, OR, September.

Boston Edison 1990, *Long-Range Integrated Resource Plan, 1990-2014*, Boston, MA, May.

BC Hydro 1991, *Electric Load Forecast, 1991/92-2011/12*, Vancouver, British Columbia, Canada.

California Public Utilities Commission and California Energy Commission 1987, *Standard Practice Manual, Economic Analysis of Demand-Side Management Programs*, P-400-87-006, San Francisco and Sacramento, CA, December.

Carolina Power & Light Company 1989, *CP&L Exhibits 1, 2 and 3, Before the North Carolina Utilities Commission*, Docket No. E-100, Sub 58, Raleigh, NC, April.

R. Cavanagh 1986, "Least-Cost Planning Imperatives for Electric Utilities and their Regulators," *The Harvard Environmental Law Review* 10(2).

P. A. Centolella 1992, "Can Improving Environmental Quality Become Profitable for Utilities in the 1990s: An Economic Perspective on Clean Air Act Compliance Planning and Incentive Regulation," Conference on Incentive Regulation, Arlington, VA, March 19-20.

Central Maine Power Company 1991, *Energy Resource Plan*, Augusta, ME, September.

J. M. Clinton and C. A. Sabo 1990, *A Guidebook for Conducting a Demand-Side Management Resource Assessment*, Barakat & Chamberlin, Inc., prepared for the North Carolina Alternative Energy Corp., Research Triangle Park, NC, September.

Consumers Power 1992, *1992 Integrated Resource Planning Report*, Jackson, MI.

Detroit Edison 1992, *Integrated Resource Plan 1992-2006*, Detroit, MI, May.

Duke Power Company 1991, *Least Cost Integrated Resource Planning 1991, Short-Term Action Plan*, Charlotte, NC, April.

Duke Power Company 1992, *Integrated Resource Plan 1992*, Charlotte, NC, April.

J. H. Eto 1990, "An Overview of Analysis Tools for Integrated Resource Planning," *Energy* 15(11), 969-977, November.

Florida Power & Light Company 1990, *Demand-Side Management Plan for the 90's*, Miami, FL, February.

A. Ford and J. Geinzer 1990, "Adding Uncertainty to Least-Cost Planning," *Energy Policy* 18(4), 331-339, May.

Georgia Power Company 1992, *1992 Integrated Resource Plan*, Atlanta, GA, January.

C. A. Goldman, J. F. Busch, E. P. Kahn, S. S. Stoft, and S. Cohen 1992, *Review of Integrated Resource Bidding at Niagara Mohawk*, LBL-31667, Lawrence Berkeley Laboratory, Berkeley, CA, May.

Green Mountain Power Corp. 1991, *Green Mountain Power Corporation Integrated Resource Plan*, So. Burlington, VT, October.

L. J. Hill 1991, *Comparison of Methods to Integrate DSM and Supply Resources in Electric-Utility Planning*, ORNL/CON-341, Oak Ridge National Laboratory, Oak Ridge, TN, December.

L. J. Hill, E. Hirst, and M. Schweitzer 1991, *Integrating Demand-Side Management Programs into the Resource Plans of U.S. Electric Utilities*, ORNL/CON-311, Oak Ridge National Laboratory Oak Ridge, TN, January.

E. Hirst 1988, "Meeting Future Electricity Needs," *Forum for Applied Research and Public Policy* 3(3), Fall.

E. Hirst 1992, *Effects of Utility DSM Programs on Risk*, ORNL/CON-346, Oak Ridge National Laboratory, Oak Ridge, TN, May.

- E. Hirst, M. Schweitzer, E. Yourstone, and J. Eto 1990, *Assessing Integrated Resource Plans Prepared by Electric Utilities*, ORNL/CON-298, Oak Ridge National Laboratory, Oak Ridge, TN, February.
- E. Hirst and M. Schweitzer 1990, "Electric-Utility Resource Planning and Decision-Making: The Importance of Uncertainty," *Risk Analysis* 10(1), 137-146.
- E. Hirst and C. Goldman 1991, "Creating the Future: Integrated Resource Planning for Electric Utilities," *Annual Review of Energy and the Environment* 16, 91-121.
- E. Hirst and J. Reed (editors) 1991, *Handbook of Evaluation of Utility DSM Programs*, ORNL/CON-336, Oak Ridge National Laboratory, Oak Ridge, TN, December.
- Kansas City Power & Light Company 1991, *KCPLAN 91, Integrated Resource Plan 1991-2010*, Kansas City, MO, September.
- J. G. Koomey et al. 1991, *The Potential for Electricity Efficiency Improvements in the U.S. Residential Sector*, LBL-30477, Lawrence Berkeley Laboratory, Berkeley, CA, July.
- Lower Colorado River Authority 1991, *1991 Integrated Electric Resource Plan*, Austin, TX, September.
- Lower Colorado River Authority 1992, *1992 Integrated Electric Resource Plan*, Austin, TX, October.
- S. Lush 1992, *Designing DSM for T&D Benefits*, IEEE DSM Program Planning & Evaluation Working Group, Seattle, WA, July 13.
- C. Mitchell 1992, "Integrated Resource Planning Survey: Where the States Stand," *The Electricity Journal* 5(4), 10-15, May.
- National Association of Regulatory Utility Commissioners 1988, *Least-Cost Utility Planning, A Handbook for Utility Commissioners*, Washington, DC.
- Nevada Power 1991, *1991 Resource Plan*, Las Vegas, NV.
- New England Electric System 1990, *Integrated Least Cost Resource Plan NEESPLAN 1990 Final Report*, Westborough, MA.
- New England Electric System 1991, *NEESPLAN 3, Environment, Economy, and Energy in the 1990s*, Westborough, MA, November.
- New England Electric System 1992, *Integrated Least Cost Resource Plan for the Fifteen Year Period 1992-2006*, Westborough, MA, April 30.

Niagara Mohawk Power Corp. 1991, *1991 Integrated Electric Resource Plan*, Syracuse, NY, September.

Northeast Utilities 1989, *1989 Forecast of Loads and Resources for 1989-1998*, Hartford, CT, March.

Northeast Utilities 1992, *1992 PSNH Integrated Least Cost Resource Plan*, Hartford, CT, April 30.

Northwest Power Planning Council 1989, *Transmission and Distribution Loss Reduction*, Staff Issue Paper 89-29, Portland, OR, October.

Northwest Power Planning Council 1991, *1991 Northwest Conservation and Electric Power Plan*, Portland, OR, April.

Ontario Hydro 1992, *Update 1992, Ontario Hydro's Plan to Serve Customers' Electricity Needs*, Toronto, Ontario, January.

R. Orans, C. K. Woo, J. N. Swisher, B. Wiersma, and B. Hori 1992, *Targeting DSM for Transmission and Distribution Benefits: A Case Study of PG&E's Delta District*, EPRI TR-100487, Energy and Environmental Economics and Pacific Gas and Electric Company, prepared for the Electric Power Research Institute, Palo Alto, CA, May.

PacifiCorp 1992, *Balanced Planning for Growth, Resource and Market Planning Program RAMPP-2*, Portland, OR, May.

Portland General Electric 1990, *The 1990 Integrated Resource Plan, A Least Cost Approach*, Portland, OR, October.

Potomac Electric Power Company 1992, *Integrated Least-Cost Resource Plan: 1992 Energy Plan*, Washington, DC, March.

Public Service Company of New Hampshire 1990, *Integrated Least Cost Resource Plan, 1989 edition*, Manchester, NH, May.

Public Service Company of New Mexico 1992, *Annual Report 1991*, Albuquerque, NM.

Puget Power 1992, *Integrated Resource Plan 1992-1993*, Bellevue, WA, April.

J. Raab and M. Schweitzer 1992, *Public Involvement in Integrated Resource Planning: A Study of Demand-Side Management Collaboratives*, ORNL/CON-344, Oak Ridge National Laboratory, Oak Ridge, TN, February.

J. W. Rowe and C. A. LaFleur 1992, "Environment, Economy, and Energy: Meeting the Multiple Challenges of the 1990s," *The Electricity Journal* 5(6), 42-49, July.

Sacramento Municipal Utility District 1991, *The Scoping Report of the Policy Committee on Power System Additions*, Sacramento, CA, November.

San Diego Gas & Electric Company 1991, *Resource Plan Compliance Report*, submitted to the California Public Utilities Commission, San Diego, CA, August.

San Diego Gas & Electric Company 1992, *Final Resource Case Analysis in the Matter of the 1992 Electricity Report (ER 92)*, San Diego, CA, June.

E. Sheets 1989, "Least-Cost Planning on a Regional Basis: A Case Study," *The Electricity Journal* 2(8), 36-47, October.

Solar Energy Research Institute 1991, *Photovoltaics: New Opportunities for Utilities*, DOE/CH-10093-113, Golden, CO, July; now the National Renewable Energy Laboratory.

Southern California Edison Company 1989, *Least-Cost Resource Planning*, Rosemead, CA, March.

Southern California Edison Company 1991, *Southern California Edison Company's (U 338-E) Energy Policy and Resource Plan for the Biennial Resource Plan Update*, OII-89-07-004, Rosemead, CA, August and October.

M. E. Taylor, K. G. Ritland, and R. G. Pratt 1991, *Hot Water Electric Energy Use in Single-Family Residences in the Pacific Northwest, Regional End-Use Metering Project (REMP)*, DOE/BP-13795-27, Bonneville Power Administration, Portland, OR, September.

Union Electric 1990, *Energy Resource Plan*, St. Louis, Mo, January.

Wisconsin Electric Power Company 1989, *Integrated Resource Plan in Support of the Concord Generating Station*, Milwaukee, WI, May.

Wisconsin Electric Power Company 1991, *Advance Plan 6, Technical Support Document D1, Supplemental Information*, Milwaukee, WI, March.

Wisconsin Electric Utilities 1991, *Advance Plan 6, Wisconsin Statewide Joint Plan A1*, filed with the Wisconsin Public Service Commission, Madison, WI, March.

Wisconsin Public Service Commission 1992, *Advance Plans for Construction of Facilities ... Findings of Fact, Conclusion of Law and Order*, Docket 05-EP-6, Madison, WI, September.

INTERNAL DISTRIBUTION

1. D. Bauer	21. R. Lee
2. V. D. Baxter	22. P. Leiby
3. L. Berry	23. J. M. MacDonald
4. D. S. Bjornstad	24. V. C. Mei
5. M. A. Brown	25. W. R. Mixon
6. R. S. Carlsmith	26. S. Purucker
7. F. C. Chen	27. D. E. Reichle
8. J. Christian	28. D. T. Rizy
9. G. Courville	29. M. Schweitzer
10. P. D. Fairchild	30. R. B. Shelton
11. W. Fulkerson	31. J. N. Stone
12. M. B. Gettings	32. J. Van Dyke
13. C. W. Hagan	33. J. M. Veigel (ORAU)
14. L. J. Hill	34. D. L. White
15. E. Hillsman	35. T. J. Wilbanks
16. E. Hirst	36. ORNL Patent Office
17. P. J. Hughes	37. Central Research Office
18. C. R. Kerley	38. Document Reference Section
19. J. O. Kolb	39. Laboratory Records (RC)
20. M. A. Kuliasha	40-42. Laboratory Records Dept.

EXTERNAL DISTRIBUTION

- 43. Bruce G. Buchanan, Computer Science Department, University of Pittsburgh, 206 Mineral Industries Building, Pittsburgh, PA 15260
- 44. Helen Ingram, Director, Udall Center for Studies in Public Policy, University of Arizona, 803/811 East First Street, Tucson, AZ 85719
- 45. Calvin MacCracken, President, Calmac Manufacturing Corporation, 101 West Sheffield Avenue, P. O. Box 710, Englewood, NJ 07631
- 46. Jacqueline B. Shrago, Director, Office of Technology Transfer, 405 Kirkland Hall, Vanderbilt University, Nashville, TN 37240
- 47. Martin Williams, Professor, Department of Economics, Northern Illinois University, DeKalb, IL 60115
- 48.-57. OSTI, U. S. Department of Energy, P. O. Box 62, Oak Ridge, Tennessee 37831
- 58. Office of Assistant Manager for Energy Research and Development, DOE/ORO, P. O. Box 2001 Oak Ridge, TN 37831-8600
- 59.-1000. External Energy Efficiency and Renewables Section Distribution Mailing List and extra copies to E.M. Schorn, 4500N, H-19A

END

DATE
FILMED

4 / 15 / 93