DISTRIBUTION SHEET

To	From	Page 1 of 1
DISTRIBUTION	East Systems Engineering	Date
Project Title/Work Order		EDT No. 136300
Operational Safety Requirements and Operating Specification Documentation Compliance Instrumentation Matrices 200 East Area Tank Farms.		ECN No. N/A

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
R. A. DODD	S5-05	X			
W. E. MEEUWSEN	S5-05	X			
G. R. TARDIFF	S5-05	X			
D. R. STORY	S5-13	X			
R. L. POWERS	S5-13	X			
K. A. WHITE	S5-13	X			
A. T. ALSTAD	S5-13	X			
R. S. NICHOLSON	S5-05	X			
S. R. PIERCE	S5-05	X			
M. S. TIFFANY	S5-05	X			

CENTRAL FILES: (2) and ORIGINAL	L8-04	X
O.S.T.I. (2)	L8-07	X

MASTER

06 DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

② Not 4.

Use as Original - 27. 3/1/95

MAR 01 1995 ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 136300

2. To: (Receiving Organization) Distribution		3. From: (Originating Organization) East Systems Engineering		4. Related EDT No.:	
5. Proj./Prog./Dept./Div.: Waste Management		6. Cog. Engr.: Katie A. White		7. Purchase Order No.:	
8. Originator Remarks: Key Words: Operational Safety Requirements. Operating Specification Documentation. Compliance. Instrumentation Matrices. 200 East Area Tank Farms.				9. Equip./Component No.:	
				10. System/Bldg./Facility: East Tank Farms	
				12. Major Assm. Dwg. No.:	
11. Receiver Remarks:				13. Permit/Permit Application No.:	
				14. Required Response Date:	

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	WHC-SD-WM-EL-003		0	OPERATIONAL SAFETY REQUIREMENTS AND OPERATING SPECIFICATION DOCUMENTATION COMPLIANCE INSTRUMENTATION MATRICES-200 EAST AREA TANK FARMS	N/A	A	1	1

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)		1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged	

(G)	(H)	17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)								(G)	(H)
Reason	Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	Reason	Disp.
1	1	Cog. Eng. K. A. White		2/23/95	55-05	R. L. Powers		2/21/95	55-13	1	1
1	1	Cog. Mgr. R. A. Dodd		2/23/95	55-05	A. T. Alstad		2/21/95	55-13	1	1
		QA				R. S. Nicholson		2/21/95	55-05	1	1
		Safety				S. R. Pierce		2/22/95	55-05	1	1
		Env.				H. S. Tiffany		2/21/95	55-05	1	1
1	1	W. E. Heeussen		2/21/95	55-05	W. F. ERBE		2-23-95			
1	1	G. R. Tardiff		2-17-95	55-05						

18. Signature of EDT Originator Date 2-23-95		19. Authorized Representative for Receiving Organization Date 2/23/95		20. Cognizant Manager Date 2/23/95		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	
---	--	--	--	---	--	---	--

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

RELEASE AUTHORIZATION

Document Number: WHC-SD-WM-EL-003, REV 0

Document Title: Operational Safety Requirements and Operating
Specification Documentation Compliance
Instrumentation Matrices - 200 East Area Tank Farms

Release Date: 2/27/95

**This document was reviewed following the
procedures described in WHC-CM-3-4 and is:**

APPROVED FOR PUBLIC RELEASE

WHC Information Release Administration Specialist:

Kara M. Broz

February 27, 1995

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy and microfiche. Printed in the United States of America. Available to the U.S. Department of Energy and its contractors from:

U.S. Department of Energy
Office of Scientific and Technical Information (OSTI)
P.O. Box 62
Oak Ridge, TN 37831
Telephone: (615) 576-8401

Available to the public from:

U.S. Department of Commerce
National Technical Information Service (NTIS)
5285 Port Royal Road
Springfield, VA 22161
Telephone: (703) 487-4650

96 DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

27.31/195

SUPPORTING DOCUMENT		1. Total Pages 267 267
2. Title Operational Safety Requirements and Operating Specification Documentation Compliance Instrumentation Matrices - 200 East Area Tank Farms	3. Number WHC-SD-WM-EL-003	4. Rev No. 0
5. Key Words Operational Safety Requirements. Operating Specification Documentation. Compliance. Instrumentation Matrices. 200 East Area Tank Farms	6. Author Name: David R. Story Signature East Systems Eng. Organization/Charge Code 70710/N1F6A	
7. Abstract This document contains information about matrices complied of instrumentation used to comply with the existing Operational Safety Requirements from Safety Analysis Reports and Operating Specification Documentation requirements for 200 East Area Tank Farms. These matrices contain the primary instrumentation needed to comply with each OSR and/or OSD requirement as well as any backup instrumentation that may be used should the primary device be out of service. The referenced matrices are provided as attachments to this document.		
8. RELEASE STAMP <div>OFFICIAL RELEASE 2 BY WHC DATE MAR 01 1995 </div>		

Operational Safety Requirements and
Operating Specification Documentation
Compliance Instrumentation
Matrices
-- 200 East Area Tank Farms --

David R. Story
East Tank Farms Systems Engineering

Prepared for the United States Department of Energy

Westinghouse Hanford Company
P. O. Box 1970
Richland, Wa. 99352

Operational Safety Requirements and
Operating Specification Documentation
Compliance Instrumentation
Matrices
-- 200 East Area Tank Farms --

Table of Contents

1.0	Abstract	1
2.0	Background	1
3.0	Basis	2
4.0	Description	2
5.0	Intended Use	2
6.0	Responsibilities	3
7.0	References	3

Table of Contents (Continued)

APPENDIX A: MATRIX, ER-311 CATCH TANK	1 page
APPENDIX B: MATRIX, 204-AR WASTE UNLOADING FACILITY	2 pages
APPENDIX C: MATRIX, 241-A FARM	2 pages
APPENDIX D: MATRIX, 241-A-702 AGING WASTE VENTILATION	5 pages
APPENDIX E: MATRIX, 241-AN FARM	46 pages
APPENDIX F: MATRIX, 241-AP FARM	72 pages
APPENDIX G: MATRIX, 241-AW FARM	47 pages
APPENDIX H: MATRIX, 241-AX FARM	1 page
APPENDIX I: MATRIX, 241-AY-101 TANK	11 pages
APPENDIX J: MATRIX, 241-AY-102 TANK	10 pages
APPENDIX K: MATRIX, 241-AZ-101 TANK.	14 pages
APPENDIX L: MATRIX, 241-AZ-102 TANK.	14 pages
APPENDIX M: MATRIX, 241-B FARM	6 pages
APPENDIX N: MATRIX, 241-BX FARM.	5 pages
APPENDIX O: MATRIX, 241-BY FARM.	7 pages
APPENDIX P: MATRIX, 241-C FARM	4 pages
APPENDIX Q: MATRIX, 244-A CATCH TANK	1 page
APPENDIX R: MATRIX, 244-AR FARM.	10 pages
APPENDIX S: MATRIX, 244-BX DCRT.	5 pages
APPENDIX T: MATRIX, 244-CR FARM	1 page
APPENDIX U: MATRIX, 296-C-5 VAULT VENTILATION 244-CR	2 pages
APPENDIX V: MATRIX, 296-P-16 PORT. EXHAUSTER	1 page

Operational Safety Requirements and
Operating Specification Documentation
Compliance Instrumentation
Matrices
-- 200 East Area Tank Farms --

1.0 Abstract

Matrices have been compiled of instrumentation used to comply with the existing Operational Safety Requirements (OSR) from Safety Analysis Reports and Operating Specification Documentation (OSD) requirements for 200 East Area Tank Farms. These matrices contain the primary instrumentation needed to comply with each OSR and/or OSD requirement as well as any backup instrumentation that may be used should the primary device be out of service. Should the primary and backup instrumentation be out of service, the Cognizant Engineer can identify an alternative means of detection. The referenced matrices are provided as attachments to this document.

2.0 Background

A portion of compliance with the applicable OSRs and/or OSDs is that the instrumentation specified in those documents are maintained and calibrated at the required frequencies. Routine surveillance is also required of some instrumentation for verification of compliance. In the event that a individual instrument is either out of service or overdue for calibration, an alternate instrument can be used to show compliance, providing that it is in calibration. The information contained within the attached matrices will provide users with an indication of the impact associated with loss of any OSR or OSD related instrumentation and potential backup OSR or OSD instrumentation which may be used. Alternate means of detection to those presented in the matrices may be identified by the Cognizant Engineer.

3.0 Basis

The attached matrices were developed by using the facility drawings and documents to identify which instruments located in the field would provide the information needed to comply with the OSR and/or OSD requirements on a requirement by requirement basis. Once the instruments were identified, the calibration recall database identification (loop/sequence number) was determined. This identification number was further cross referenced with the JCS identification number. All of the information contained in the matrices, besides the recall identification sequence and drawing numbers, is based on the OSR and OSD requirements, not on actual recall or surveillance frequencies.

4.0 Description

Included in the matrices and database is the following information:

- Facility / Tank
- Instrument identification (based on facility drawings/documents)
- OSD section used to show instrument compliance
- OSR section, if applicable
- Drawing used to identify the instrument
- CBRS identification sequence number / JCS identification number
- Instrument alarm setpoint(s)
- Process range limit(s) permitted
- Surveillance Frequency and Calibration / Functional Test Frequency

All of the information contained in the matrices and database, besides the recall identification sequence and drawing or document numbers, are based on the requirements, not on actual recall or surveillance frequencies.

NOTE: Omitted from this listing are the transfer system leak detectors. Leak detectors necessary to perform a transfer are identified in the transfer procedure during procedure development and are not routinely tested. It is required that they be functional during transfers through associated pits/lines.

5.0 Intended Use

The attached matrices were developed in determining the impacts associated with individual instrumentation failure, OSD and/or OSR compliance and provides bases for the preventative maintenance program for the identified instruments.

6.0 Responsibilities

East Tank Farm Plant Engineering is responsible for maintenance and routine updates to the matrices and any database associated with the matrices as needed.

7.0 References

OSD-T-151-00007
OSD-T-151-00008
OSD-T-151-00011
OSD-T-151-00013
OSD-T-151-00014
OSD-T-151-00015
OSD-T-151-00016
OSD-T-151-00017
OSD-T-151-00031
SD-WM-SAR-016
SD-HS-SAR-010
SD-WM-SAR-034
SD-WM-SAR-006
SD-WM-SAR-040

CATCH TANKS OSD MATRIX

WHC-SD-WM-EL-003
REV. 0
PAGE 1A of 1A

ER-311

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
ER-311	15.7.B.1.a	LIT-ER-311		71670	ER303-1 / ET-02184		80% MAX TK CAP	SR: N/A CR: N/A

WASTE UNLOADING FACILITY OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1B of 2B

204-AR

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
204-AR	8.2.4.1	LI-TK-1	5.3.2.4	70703	2R025-1 / ET-00759			SR: SHIFT CR: N/A
204-AR	8.2.4.1	LAS-TK-1A	5.3.2.4	70703	2R025-4 / ET-02401		1145 GALLONS	SR: N/A CR: SEMI-ANN
204-AR	8.2.4.1	LA-TK-1A	5.3.2.4	70703	2R025-5 / ET-01724			SR: N/A CR: N/A
204-AR	8.2.4.1	LAS-TK-1B		70703	2R025-2 / ET-02402			SR: N/A CR: N/A
204-AR	8.2.4.1	LA-TK-1B		70703	2R025-3 / ET-01824			SR: N/A CR: N/A
204-AR	8.2.4.1	SS-MOV-DS-4	5.3.2.4	70703	2R069-1 / ET-00443			SR: N/A CR: SEMI-ANN
204-AR	8.2.4.1	SS-MOV-21	5.3.2.4	70703	2R016-1 / ET-00451			SR: N/A CR: SEMI-ANN
204-AR	8.2.4.1	SS-MOV-3	5.3.2.4	70703	2R021-1 / ET-00393			SR: N/A CR: SEMI-ANN
204-AR	8.2.4.1	SS-MOV-12	5.3.2.4	70703	2R023-1 / ET-00405			SR: N/A CR: SEMI-ANN
204-AR	8.2.4.1	SS-MOV-2	5.3.2.4	70703	2R022-2 / ET-00422			SR: N/A CR: SEMI-ANN
204-AR	8.2.4.1	SS-WF-30	5.3.2.4	70703	2R022-1 / ET-02118			SR: N/A CR: SEMI-ANN
204-AR	8.3.1	DPIAS-1		70701	2R075-1 / ET-02417		≤ 5.9" WG	SR: SHIFT CR: N/A
204-AR	8.3.1	DPIAS-2		70701	2R076-1 / ET-02416		≤ 5.9" WG	SR: SHIFT CR: N/A
204-AR	8.3.1	DPI-5		70701	2R079-1 / ET-00657		≤ 5.9" WG	SR: SHIFT CR: N/A
204-AR	8.3.2.1	TIC-TK-1		70701	2R035-1 / ET-02338		≤ 230° F	SR: SHIFT CR: N/A
204-AR	8.3.2.2	TIC-TK-1		70701	2R035-1 / ↑		ΔT ≥ 5° F	SR: SHIFT CR: N/A
204-AR	8.3.3	CAM-RM-EXH-1	5.3.1-.3	70703	Y2R05-1 / ET-01561			SR: CONT. CR: 45-DAYS
204-AR	8.3.3	RR-EXH-1	5.3.1-.3	70703	2R033-1 / ET-02403			SR: CONT. CR: 45-DAYS
204-AR	8.3.3	RY-EXH-1	5.3.1-.3	70703	2R033-2 / ET-00603			SR: CONT. CR: 45-DAYS
204-AR	8.3.3	RA-EXH-1A	5.3.1-.3	70703	2R033-3 / ET-02000			SR: CONT. CR: 45-DAYS
204-AR	8.3.3	FS-1	5.3.1-.3	70703	2R137-1 / ET-04509			SR: N/A CR: N/A
204-AR	8.3.3	LVA-EXH-1	5.3.1-.3	70703	2R036-3 / ET-00228			SR: N/A CR: N/A

WASTE UNLOADING FACILITY OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2B of 2B

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
204-AR	8.3.3	MS-PVP-5A-1	5.3.1-.3	70703	2R140-1 / ET-04615			SR: N/A CR: N/A
204-AR	8.3.3	FIC-HVAC-1	5.3.1-.2	70703	2R121-1 / ET-01481			SR: N/A CR: N/A
204-AR	8.3.3	RECORD SAMPLE	5.3.1-.3	70703				SR: WEEKLY CR: N/A
204-AR	8.3.3	FI-RS-1	5.3.1-.3	70703	2R141-1 / ET-02571			SR: N/A CR: N/A
204-AR	8.3.3	FIQ-RS-1	5.3.1-.3	70703	2R142-1 / ET-02387			SR: N/A CR: N/A
204-AR	8.3.3	FS-2	5.3.1-.3	70703	2R143-1 / ET-04510			SR: N/A CR: N/A
204-AR	8.3.3	MS-PVP-5B-1	5.3.1-.3	70703	2R146-1 / ET-04628			SR: N/A CR: N/A

SINGLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1C of 2C

241-A

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	13.2.1.B	MAN. LIQUID LVL. TAPE		32671			360"	SR: N/A CR: N/A
101	13.2.1.B	LIQUID OBSRVATION WELL		93715				SR: N/A CR: N/A
101	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
101	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
101	13.2.4.A	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
102	13.2.1.B	LIT-102-A		36382	A0041-1 /ET-01372		360"	SR: N/A CR: N/A
102	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
102	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
102	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
103	13.2.1.B	LIT-103-A		36382	A0018-1 /ET-01370		360"	SR: N/A CR: N/A
103	13.2.1.B	LIQUID OBSRVATION WELL		93715				SR: N/A CR: N/A
103	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
103	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
103	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
104	13.2.1.B	MAN. LIQUID LVL TAPE		32671			360"	SR: N/A CR: N/A
104	13.2.1.E	THRMOCPL PROBE 2 EA.	11.4.2.1				300°F LCO=350°F	SR: N/A CR: N/A
104	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
104	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A

SINGLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2C of 2C

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	13.2.1.B	MAN. LIQUID LVL TAPE		32671			360"	SR: N/A CR: N/A
105	13.2.1.E	THRMOCPL PROBE 6 EA.	11.4.2.1	64535			300°F LCO=350°F	SR: N/A CR: N/A
105	13.2.1.F	PI-EXH-3	11.4.1.1	56142	A0222-1 /ET-00668		± 7 IN.WG.	SR: 1 DAY CR: N/A
105	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
105	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
106	13.2.1.B	LIT-106-A		36382	A0042-1 /ET-01371		360"	SR: N/A CR: N/A
106	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
106	13.2.1.F	PI-EXH-4	11.4.1.1	56142	A0221-1 /ET-01610		± 7 IN.WG.	SR: 1 DAY CR: N/A
106	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
106	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A

AGING WASTE VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10 of 50

241-A-702

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
702-A	16.2.1.A	PI-702-2	11.9	62895 sh2	2A003-2 / ET-04645		0", -10"	SR: SHIFT CR: N/A
702-A	16.2.1.A	PAS-702-3	11.9	62895 sh2	2A003-3 / ET-01084	≤ -5"		SR: N/A CR: N/A
702-A	16.2.1.A	PAS-702-4	11.9	62895 sh2	2A003-5 / ET-01090	≥ -1.5"		SR: N/A CR: N/A
702-A	16.2.1.A	PA-271-3	11.9	62895 sh3	2A003-4 / ET-01830			SR: N/A CR: N/A
702-A	16.2.1.A	PI-702-3	11.9	62895 sh2	2A034-3 / ET-04646		0", -50"	SR: SHIFT CR: N/A
702-A	16.2.1.A	PAS-702-1	11.9	62895 sh2	2A034-1 / ET-01042	≤ -15"		SR: N/A CR: N/A
702-A	16.2.1.A	PA-271-1	11.9	62895 sh3	2A034-2 / ET-02196			SR: N/A CR: N/A
702-A	16.2.2	DPI-702-1		62895 sh2	2A003-1 / ET-00638		≤ 1.0"	SR: SHIFT CR: N/A
702-A	16.2.2	DPI-702-6		62895 sh2	2A027-1 / ET-00834		≤ 1.0"	SR: SHIFT CR: N/A
702-A	16.2.2	DPIS-702-5		62895 sh2	2A027-2 / ET-00821		≤ 1.0"	SR: SHIFT CR: N/A
702-A	16.2.2	PA-271-2		62895 sh3	2A027-3 / ET-01895			SR: N/A CR: N/A
702-A	16.2.3	TDRC-415		56142 sh3	2A007-2 / ET-00866		ΔT ≤ 51° F	SR: SHIFT CR: N/A
702-A	16.2.3	TE-415-1		56142 sh3	2A007-3 / ET-00544			SR: N/A CR: N/A
702-A	16.2.3	TE-415-2		56142 sh3	2A007-4 / ET-00549			SR: N/A CR: N/A
702-A	16.2.3	TDRC-414		56142 sh3	2A012-2 / ET-02448		ΔT ≤ 51° F	SR: SHIFT CR: N/A
702-A	16.2.3	TE-414-1		56142 sh3				SR: N/A CR: N/A
702-A	16.2.3	TE-414-2		56142 sh3	2A012-3 / ET-00550			SR: N/A CR: N/A
702-A	16.2.3	TDRC-413		56142 sh3	2A016-2 / ET-03269		ΔT ≤ 51° F	SR: SHIFT CR: N/A
702-A	16.2.3	TE-413-1		56142 sh3				SR: N/A CR: N/A
702-A	16.2.3	TE-413-2		56142 sh3	2A016-3 / ET-00551			SR: N/A CR: N/A
702-A	16.2.3	TE-413-3		56142 sh3	2A006-5 / ET-00545			SR: N/A CR: N/A

AGING WASTE VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2D of 5D

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
702-A	16.2.3	TE-414-3		56142 sh3	2A006-4 / ET-00546			SR: N/A CR: N/A
702-A	16.2.3	SS-415		56142 sh3	2A006-2 / ET-00548			SR: N/A CR: N/A
702-A	16.2.3	TI-415		56142 sh3	2A006-1 / ET-00875		≤ 140° F	SR: SHIFT CR: N/A
702-A	16.2.3	TE-415-3		56142 sh3	2A006-3 / ET-00547			SR: N/A CR: N/A
702-A	16.2.4	CVT-271-1		62895 sh2	2A025-5 / ET-01187			SR: N/A CR: N/A
702-A	16.2.4	CVT-271-2		62895 sh2	2A025-2 / ET-01186			SR: N/A CR: N/A
702-A	16.2.4	CVT-702-1		62895 sh2	2A025-1 / ET-00597			SR: N/A CR: N/A
702-A	16.2.5.2.A	DPI-702-1A		62895 sh2	2A028-1 / ET-00646		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.A	DPI-702-2A		62895 sh2	2A029-1 / ET-00654		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.A	DPI-702-3A		62895 sh2	2A030-1 / ET-00656		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.A	DPI-702-4A		62895 sh2	2A031-1 / ET-00644		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.A	DPI-702-5A		62895 sh2	2A032-1 / ET-00639		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.A	DPI-702-6A		62895 sh2	2A033-1 / ET-00664		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.A	DPIS-PE-1		94719 sh4	2A060-A / ET-00827		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPI-702-1B		62895 sh2	2A028-2 / ET-00648		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPI-702-2B		62895 sh2	2A029-2 / ET-00653		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPI-702-3B		62895 sh2	2A030-2 / ET-00655		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPI-702-4B		62895 sh2	2A031-2 / ET-00647		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPI-702-5B		62895 sh2	2A032-2 / ET-00663		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPI-702-6B		62895 sh2	2A033-2 / ET-00669		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.B	DPIS-PE-2		94719 sh4	2A060-B / ET-00825		≤ 4.0"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-1A		62895 sh2	2A028-1 / ET-00646		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-2A		62895 sh2	2A029-1 / ET-00654		≤ 5.9"	SR: SHIFT CR: N/A

AGING WASTE VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3D of 5D

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
702-A	16.2.5.2.C	DPI-702-3A		62895 sh2	2A030-1 / ET-00656		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-4A		62895 sh2	2A031-1 / ET-00644		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-5A		62895 sh2	2A032-1 / ET-00639		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-6A		62895 sh2	2A033-1 / ET-00664		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-1B		62895 sh2	2A028-2 / ET-00648		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-2B		62895 sh2	2A029-2 / ET-00653		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-3B		62895 sh2	2A030-2 / ET-00655		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-4B		62895 sh2	2A031-2 / ET-00647		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-5B		62895 sh2	2A032-2 / ET-00663		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPI-702-6B		62895 sh2	2A033-2 / ET-00669		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPIS-PE-1		94719 sh4	2A060-A / ET-00827		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPIS-PE-2		94719 sh4	2A060-B / ET-00825		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.2.C	DPIS-PE-3		94719 sh4	2A060-C / ET-02412		≤ 5.9"	SR: SHIFT CR: N/A
702-A	16.2.5.3	TE-702-2		62895 sh2				SR: N/A CR: N/A
702-A	16.2.5.3	CVT-271-2		62895 sh2	2A025-2 / ET-01186			SR: N/A CR: N/A
702-A	16.2.5.3	TR-271-1 (BLU-E)		62895 sh2	2A024-2 / ET-00808		≤ 230° F	SR: N/A CR: N/A
702-A	16.2.5.3	TY-271-1		62895 sh2	2A025-6 / ET-02557			SR: N/A CR: N/A
702-A	16.2.5.3	TC-271-1		62895 sh2	2A025-4 / ET-02183		≤ 230° F	SR: N/A CR: N/A
702-A	16.2.5.3	CVT-702-1		62895 sh2	2A025-1 / ET-00597			SR: N/A CR: N/A
702-A	16.2.5.3	HTS-PE-1		94719 sh4	2A059-3 / ET-01141		≤ 230° F	SR: N/A CR: N/A
702-A	16.2.5.3	TI-PE-2		94719 sh4	2A059-2 / ET-04581		≤ 230° F	SR: N/A CR: N/A
702-A	16.2.6.B	RECORD SAMPLER	11.9	92516 sh4				SR: N/A CR: N/A
702-A	16.2.6.B	FI-RS-702-2	11.9	92516 sh4	2A053-1 / ET-01199			SR: N/A CR: N/A

AGING WASTE VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 40 of 50

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
702-A	16.2.6.B	FIQ-RS-702-2	11.9	92516 sh4	2A053-3 / ET-02388			SR: N/A CR: N/A
702-A	16.2.6.B	PI-RS-702-2	11.9	92516 sh4	2A053-4 / ET-04562			SR: N/A CR: N/A
702-A	16.2.6.B	FAS-RS-702-2	11.9	92516 sh4	2A053-5 / ET-01119			SR: N/A CR: N/A
702-A	16.2.6.B	RA-702-2	11.9	92516 sh4				SR: N/A CR: N/A
702-A	16.2.6.B	QQ-RS-702-2	11.9	92516 sh4	2A053-2 / ET-04632			SR: N/A CR: N/A
702-A	16.2.6.B	CAM	11.9	94719 sh4	Y2A04-1 / ET-01552			SR: N/A CR: N/A
702-A	16.2.6.B	PI-EXH-PE-2	11.9	94719 sh4	2A062-2 / ET-04664			SR: N/A CR: N/A
702-A	16.2.6.B	FAS-EXH-PE-2	11.9	94719 sh4	2A062-3 / ET-01114			SR: N/A CR: N/A
702-A	16.2.6.B	FI-EXH-PE-1	11.9	94719 sh4	2A061-1 / ET-01205			SR: N/A CR: N/A
702-A	16.2.6.B	FQI-EXH-PE-1	11.9	94719 sh4	2A061-2 / ET-02377			SR: N/A CR: N/A
702-A	16.2.6.B	PI-EXH-PE-1	11.9	94719 sh4	2A061-3 / ET-04662			SR: N/A CR: N/A
702-A	16.2.6.B	FAS-EXH-PE-1	11.9	94719 sh4	2A061-4 / ET-01113			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	RM-702-1	11.9	92516 sh4				SR: CONT CR: ANNUALLY
702-A	16.2.6 (C,D)	RR-702-1	11.9	92516 sh4	2A054-4 / ET-00917			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	FAS-CAM-702-1	11.9	92516 sh4	2A054-3 / ET-01116			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	PI-CAM-702-1	11.9	92516 sh4	2A054-2 / ET-04602			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	XA-702-1	11.9	92516 sh4				SR: N/A CR: N/A
702-A	16.2.6 (C,D)	RA-702-1-1	11.9	92516 sh4				SR: N/A CR: N/A
702-A	16.2.6 (C,D)	RA-702-1-2	11.9	92516 sh4	2A054-5 / ET-02194			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	UXA-702-1	11.9	92516 sh4	2A052-2 / ET-01995			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	CAM	11.9	94719 sh4	Y2A04-1 / ET-01552			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	PI-EXH-PE-2	11.9	94719 sh4	2A062-2 / ET-04664			SR: N/A CR: N/A
702-A	16.2.6 (C,D)	PI-EXH-PE-2	11.9	94719 sh4	2A062-3 / ET-01114			SR: N/A CR: N/A

AGING WASTE VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5D of 5D

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
702-A	16.2.6 (C,D)	RA-EXH-PE-1-2	11.9	94719 sh4				SR: N/A CR: N/A
702-A	16.2.6 (C,D)	UXA-EXH-PE-1	11.9	94719 sh4	2A057-2 / ET-01962			SR: N/A CR: N/A
702-A	16.2.7	HLL-417		56142 sh4	2A020-3 / ET-01627	132"		SR: N/A CR: N/A
702-A	16.2.7	WFA-417		56142 sh4	2A020-4 / ET-01755			SR: N/A CR: N/A
702-A	16.2.7	WFR-417		56142 sh4	2A020-2 / ET-00812			SR: N/A CR: N/A
702-A	16.2.7	WFT-417		56142 sh4	2A020-1 / ET-01155	132"	157"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 1E of 46E

241-AN

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.2.a	LE-101-1	11.5	71944	AN011-1 / ET-00583			SR: N/A CR: N/A
101	7.2.2.a	LIT-101-1	11.5	71944	AN011-2 / ET-01366		422", 6"	SR: DAILY CR: N/A
101	7.2.2.a	LE-101-2		71944	AN013-1 / ET-00238			SR: N/A CR: N/A
101	7.2.2.a	LAK-101-1		71944	AN013-2 / ET-00479	419"		SR: N/A CR: N/A
101	7.2.2.a	LA-101-1		71944	AN013-3 / ET-01748			SR: N/A CR: N/A
101	7.2.2.b	WFT-01C-1		71944	AN003-1 / ET-00968			SR: N/A CR: N/A
101	7.2.2.b	WFI-01C-1		71944	AN003-2 / ET-00733		≤ 66"	SR: N/A CR: N/A
101	7.2.2.b	WFT-01C-2		71944	AN002-1 / ET-00956			SR: N/A CR: N/A
101	7.2.2.b	WFAS-01C-1		71944	AN002-2 / ET-00997	36"		SR: N/A CR: N/A
101	7.2.2.b	WFA-01C-1		71944	AN002-3 / ET-01802			SR: N/A CR: N/A
101	7.2.2.b	FI-01C-1		71944	AN001-A / ET-02581			SR: N/A CR: N/A
101	7.2.2.b	FI-01C-3		71944	AN001-C / ET-02597			SR: N/A CR: N/A
101	7.2.5 (a,b,c,d)	PT-101-2	11.6	71944	AN005-1 / ET-00937		-6", 5"	SR: N/A CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PR-101-2	11.6	71944	AN005-2 / ET-00744			SR: CONT CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PT-101-1	11.6	71944	AN004-2 / ET-00957		-6", 5"	SR: N/A CR: ANNUALLY
101	7.2.5 (a,b)	PAS-101-1	11.6	71944	AN004-3 / ET-02506	-4"		SR: CONT CR: ANNUALLY
101	7.2.5 (a,b)	PAS-101-2	11.6	71944	AN005-3 / ET-02509	-0.25"		SR: CONT CR: ANNUALLY
101	7.2.5 (a,b)	PA-101-1	11.6	71944	AN004-4 / ET-01899			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 2E of 46E

101	7.2.5 (a,b)	PA-101-2	11.6	71944	AN005-4 / ET-02088			SR: N/A CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PR-101-1	11.6	71944	AN004-5 / ET-00736			SR: CONT CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PI-101-1	11.6	71944	AN435-1 / ET-02464			SR: N/A CR: ANNUALLY
101	7.2.5 (a,b)	HORN	11.6	71944				SR: N/A CR: ANNUALLY
101	7.2.5 (a,b,c,d)	FI-101-1	11.6	71944	AN004-1 / ET-02602			SR: N/A CR: N/A
101	7.2.5 (a,b,c,d)	DPI-101-1		71944				SR: N/A CR: N/A
101	7.2.5 (d)	PI-1		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-36		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-37		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-38		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-39		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-40		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-41		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-42		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-43		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-44		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-45		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-46		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-47		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-48		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 3E of 46E

101	7.2.6 (a,b,c)	TE-101-49		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-50		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-51		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-52		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-53		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	SS-101-1		71944				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TI-AN-1		71944	AN260-1 / ET-02435		212° F	SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-27		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-28		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-29		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-30		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-31		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-32		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-33		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-34		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-35		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-57		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-58		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-59		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-60		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

FL
WHC-SD-WM-003 REV. 0
PAGE 4E of 46E

101	7.2.7 (a,b,c)	TE-101-61		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-62		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-63		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-64		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-65		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-66		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-67		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-68		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-69		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-70		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-71		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-72		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-73		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-74		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-75		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-76		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-77		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-78		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-79		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-80		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 5E of 46E

101	7.2.7 (a,b,c)	TE-101-81		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-82		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-83		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-84		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-85		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-86		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-87		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-88		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-89		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-90		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-91		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-92		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-93		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-94		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-95		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-96		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-97		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-98		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-99		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-100		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 6E of 46E

101	7.2.7 (a,b,c)	TE-101-101		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	SS-101-3		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	SS-101-4		71944				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TI-AN-1		71944	AN260-1 / ET-02435		236° F	SR: N/A CR: N/A
101	7.2.9/31.2.2.2	LDE-101-2	11.4	71944	AN016-1 / ET-01517	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-2	11.4	71944	AN016-2 / ET-00168			SR: CONT CR: QUARTERLY
101	7.2.9	LDK-101-2	11.4	71944	AN016-4 / ET-00335			SR: N/A CR: QUARTERLY
101	7.2.9/31.2.2.2	LDE-101-3	11.4	71944	AN017-1 / ET-01519	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-3	11.4	71944	AN017-2 / ET-00067			SR: CONT CR: QUARTERLY
101	7.2.9	LDK-101-3	11.4	71944	AN017-4 / ET-00013			SR: N/A CR: QUARTERLY
101	7.2.9/31.2.2.2	LDE-101-4	11.4	71944	AN018-1 / ET-01518	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-4	11.4	71944	AN018-2 / ET-00291			SR: CONT CR: QUARTERLY
101	7.2.9	LDK-101-4	11.4	71944	AN018-4 / ET-00089			SR: N/A CR: QUARTERLY
101	7.2.9/31.2.2.2	LDA-101-1	11.4	71944	AN019-1 / ET-01806			SR: CONT CR: MONTHLY
101	7.2.9/31.2.2.2	RAN-EXH-101-1	11.4	71946	YAN04-1 / ET-01570			SR: CONT CR: MONTHLY
101	7.2.9	RA-EXH-101-1	11.4	71946	AN040-2 / ET-02051			SR: N/A CR: MONTHLY
101	7.2.9	RR-EXH-101	11.4	71946	AN040-4 / ET-00762			SR: CONT CR: MONTHLY
101	7.2.9	RA-EXH-101-2	11.4	71946	AN040-3 / ET-01908			SR: N/A CR: MONTHLY
101	7.3.1.A	DPI-9		71935	AN089-1 / ET-02369		≤ 5.9"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 7E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.2.a	LE-102-1	11.5	71944	AN143-1 / ET-00584			SR: N/A CR: N/A
102	7.2.2.a	LIT-102-1	11.5	71944	AN143-2 / ET-01360		422". 6"	SR: DAILY CR: N/A
102	7.2.2.a	LE-102-2		71944	AN145-1 / ET-00458			SR: N/A CR: N/A
102	7.2.2.a	LAK-102-1		71944	AN145-2 / ET-00044	419"		SR: N/A CR: N/A
102	7.2.2.a	LA-102-1		71944	AN145-3 / ET-01694			SR: N/A CR: N/A
102	7.2.2.b	WFT-02C-1		71944	AN138-1 / ET-00974			SR: N/A CR: N/A
102	7.2.2.b	WFI-02C-1		71944	AN138-2 / ET-00728		≤ 66"	SR: N/A CR: N/A
102	7.2.2.b	WFT-02C-2		71944	AN137-1 / ET-00932			SR: N/A CR: N/A
102	7.2.2.b	WFAS-02C-1		71944	AN137-2 / ET-01076	36"		SR: N/A CR: N/A
102	7.2.2.b	WFA-02C-1		71944	AN137-3 / ET-01983			SR: N/A CR: N/A
102	7.2.2.b	FI-02C-1		71944	AN136-A / ET-02596			SR: N/A CR: N/A
102	7.2.2.b	FI-02C-3		71944	AN136-C / ET-02580			SR: N/A CR: N/A
102	7.2.5 (a,b,c,d)	PT-102-2	11.6	71944	AN141-1 / ET-00940		-6". 5"	SR: N/A CR: ANNUALLY
102	7.2.5 (a,b,c,d)	PR-102-2	11.6	71944	AN141-2 / ET-00741			SR: CONT CR: ANNUALLY
102	7.2.5 (a,b,c,d)	PT-102-1	11.6	71944	AN140-2 / ET-00969		-6". 5"	SR: N/A CR: ANNUALLY
102	7.2.5 (a,b)	PAS-102-1	11.6	71944	AN140-3 / ET-02475	-4"		SR: CONT CR: ANNUALLY
102	7.2.5 (a,b)	PAS-102-2	11.6	71944	AN141-3 / ET-02511	-0.25"		SR: CONT CR: ANNUALLY
102	7.2.5 (a,b)	PA-102-1	11.6	71944	AN140-4 / ET-01709			SR: N/A CR: ANNUALLY
102	7.2.5 (a,b)	PA-102-2	11.6	71944	AN141-4 / ET-02079			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 8E of 46E

102	7.2.5 (a,b,c,d)	PR-102-1	11.6	71944	AN140-5 / ET-00739			SR: CONT CR: ANNUALLY
102	7.2.5 (a,b,c,d)	PI-102-1	11.6	71944	AN436-1 / ET-02460			SR: N/A CR: ANNUALLY
102	7.2.5 (a,b)	HORN	11.6	71944				SR: N/A CR: ANNUALLY
102	7.2.5 (a,b,c,d)	FI-102-1	11.6	71944	AN140-1 / ET-02618			SR: N/A CR: N/A
102	7.2.5 (a,b,c,d)	DPI-102-1		71944				SR: N/A CR: N/A
102	7.2.5 (d)	PI-2		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-36		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-37		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-38		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-39		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-40		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-41		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-42		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-43		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-44		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-45		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-46		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-47		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-48		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-49		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 9E of 46E

102	7.2.6 (a,b,c)	TE-102-50		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-51		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-52		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-53		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	SS-102-1		71944				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TI-AN-1		71944	AN260-1 / ET-02435		212° F	SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-27		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-28		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-29		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-30		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-31		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-32		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-33		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-34		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-35		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-57		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-58		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-59		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-60		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-61		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 10E of 46E

102	7.2.7 (a,b,c)	TE-102-62		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-63		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-64		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-65		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-66		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-67		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-68		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-69		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-70		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-71		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-72		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-73		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-74		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-75		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-76		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-77		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-78		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-79		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-80		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-81		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 11E of 46E

102	7.2.7 (a,b,c)	TE-102-82		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-83		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-84		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-85		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-86		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-87		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-88		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-89		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-90		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-91		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-92		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-93		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-94		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-95		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-96		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-97		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-98		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-99		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-100		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-101		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 12E of 46E

102	7.2.7 (a,b,c)	SS-102-3		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	SS-102-4		71944				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TI-AN-1		71944	AN260-1 / ET-02435		236° F	SR: N/A CR: N/A
102	7.2.9/31.2.2.2	LDE-102-2	11.4	71944	AN152-1 / ET-01598	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-2	11.4	71944	AN152-2 / ET-00264			SR: CONT CR: QUARTERLY
102	7.2.9	LDK-102-2	11.4	71944	AN152-4 / ET-00093			SR: N/A CR: QUARTERLY
102	7.2.9/31.2.2.2	LDE-102-3	11.4	71944	AN153-1 / ET-01599	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-3	11.4	71944	AN153-2 / ET-00384			SR: CONT CR: QUARTERLY
102	7.2.9	LDK-102-3	11.4	71944	AN153-4 / ET-00041			SR: N/A CR: QUARTERLY
102	7.2.9/31.2.2.2	LDE-102-4	11.4	71944	AN154-1 / ET-01600	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-4	11.4	71944	AN154-2 / ET-00378			SR: CONT CR: QUARTERLY
102	7.2.9	LDK-102-4	11.4	71944	AN154-4 / ET-00289			SR: N/A CR: QUARTERLY
102	7.2.9/31.2.2.2	LDA-102-1	11.4	71944	AN154-A / ET-01996			SR: CONT CR: MONTHLY
102	7.2.9/31.2.2.2	RAN-EXH-102-1	11.4	71946	YAN05-1 / ET-01574			SR: CONT CR: MONTHLY
102	7.2.9	RA-EXH-102-1	11.4	71946	AN042-3 / ET-02004			SR: N/A CR: MONTHLY
102	7.2.9	RR-EXH-102	11.4	71946	AN042-2 / ET-00765			SR: CONT CR: MONTHLY
102	7.2.9	RA-EXH-102-2	11.4	71946	AN042-4 / ET-01826			SR: N/A CR: MONTHLY
102	7.3.1.A	DPI-10		71935	AN093-1 / ET-02356		≤ 5.9"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 13E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.2.a	LE-103-1	11.5	71944	AN165-1 / ET-00504			SR: N/A CR: N/A
103	7.2.2.a	LIT-103-1	11.5	71944	AN165-2 / ET-01343		422", 6"	SR: DAILY CR: N/A
103	7.2.2.a	LE-103-2		71944	AN167-1 / ET-03097			SR: N/A CR: N/A
103	7.2.2.a	LAK-103-1		71944	AN167-2 / ET-00499	EQUIPMENT OUT	OF SERVICE	SR: N/A CR: N/A
103	7.2.2.a	LA-103-1		71944	AN167-3 / ET-00187			SR: N/A CR: N/A
103	7.2.2.b	WFT-03C-1		71944	AN157-1 / ET-00972			SR: N/A CR: N/A
103	7.2.2.b	WFI-03C-1		71944	AN157-2 / ET-02395		≤ 66"	SR: N/A CR: N/A
103	7.2.2.b	WFT-03C-2		71944	AN156-1 / ET-00982			SR: N/A CR: N/A
103	7.2.2.b	WFAS-03C-1		71944	AN156-2 / ET-01006	36"		SR: N/A CR: N/A
103	7.2.2.b	WFA-03C-1		71944	AN156-3 / ET-01893			SR: N/A CR: N/A
103	7.2.2.b	FI-03C-1		71944	AN155-A / ET-02584			SR: N/A CR: N/A
103	7.2.2.b	FI-03C-3		71944	AN155-C / ET-02592			SR: N/A CR: N/A
103	7.2.5 (a,b,c,d)	PT-103-2	11.6	71944	AN161-1 / ET-00976		-6", 5"	SR: N/A CR: ANNUALLY
103	7.2.5 (a,b,c,d)	PR-103-2	11.6	71944	AN161-2 / ET-00748			SR: CONT CR: ANNUALLY
103	7.2.5 (a,b,c,d)	PT-103-1	11.6	71944	AN160-2 / ET-00935		-6", 5"	SR: N/A CR: ANNUALLY
103	7.2.5 (a,b)	PAS-103-1	11.6	71944	AN160-3 / ET-02476	-4"		SR: CONT CR: ANNUALLY
103	7.2.5 (a,b)	PAS-103-2	11.6	71944	AN161-3 / ET-02510	-0.25"		SR: CONT CR: ANNUALLY
103	7.2.5 (a,b)	PA-103-1	11.6	71944	AN160-4 / ET-01685			SR: N/A CR: ANNUALLY
103	7.2.5 (a,b)	PA-103-2	11.6	71944	AN161-4 / ET-01757			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 14E of 46E

103	7.2.5 (a,b,c,d)	PR-103-1	11.6	71944	AN160-5 / ET-00735			SR: CONT CR: ANNUALLY
103	7.2.5 (a,b,c,d)	PI-103-1	11.6	71944	AN434-1 / ET-01677			SR: N/A CR: ANNUALLY
103	7.2.5 (a,b)	HORN	11.6	71944				SR: N/A CR: ANNUALLY
103	7.2.5 (a,b,c,d)	FI-103-1	11.6	71944	AN160-1 / ET-02619			SR: N/A CR: N/A
103	7.2.5 (a,b,c,d)	DPI-103-1		71944				SR: N/A CR: N/A
103	7.2.5 (d)	PI-3		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-36		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-37		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-38		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-39		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-40		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-41		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-42		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-43		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-44		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-45		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-46		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-47		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-48		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-49		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

FL
WHC-SD-WM-003 REV. 0
PAGE 15E of 46E

103	7.2.6 (a,b,c)	TE-103-50		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-51		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-52		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-53		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	SS-103-1		71944				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TI-AN-1		71944	AN260-1 / ET-02435		212° F	SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-27		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-28		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-29		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-30		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-31		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-32		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-33		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-34		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-35		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-57		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-58		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-59		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-60		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-61		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 16E of 46E

103	7.2.7 (a,b,c)	TE-103-62		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-63		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-64		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-65		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-66		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-67		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-68		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-69		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-70		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-71		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-72		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-73		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-74		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-75		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-76		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-77		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-78		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-79		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-80		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-81		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 17E of 46E

103	7.2.7 (a,b,c)	TE-103-82		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-83		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-84		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-85		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-86		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-87		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-88		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-89		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-90		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-91		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-92		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-93		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-94		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-95		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-96		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-97		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-98		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-99		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-100		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-101		71944				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

7EL
WHC-SD-WM-003 REV. 0
PAGE 18E of 46E

103	7.2.7 (a,b,c)	SS-103-3		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	SS-103-4		71944				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TI-AN-1		71944	AN260-1 / ET-02435		236° F	SR: N/A CR: N/A
103	7.2.9/31.2.2.2	LDE-103-2	11.4	71944	AN170-1 / ET-01597	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-2	11.4	71944	AN170-2 / ET-00308			SR: CONT CR: QUARTERLY
103	7.2.9	LDK-103-2	11.4	71944	AN170-4 / ET-00360			SR: N/A CR: QUARTERLY
103	7.2.9/31.2.2.2	LDE-103-3	11.4	71944	AN171-1 / ET-01596	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-3	11.4	71944	AN171-2 / ET-00205			SR: CONT CR: QUARTERLY
103	7.2.9	LDK-103-3	11.4	71944	AN171-4 / ET-00302			SR: N/A CR: QUARTERLY
103	7.2.9/31.2.2.2	LDE-103-4	11.4	71944	AN172-1 / ET-01595	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-4	11.4	71944	AN172-2 / ET-00056			SR: CONT CR: QUARTERLY
103	7.2.9	LDK-103-4	11.4	71944	AN172-4 / ET-00188			SR: N/A CR: QUARTERLY
103	7.2.9/31.2.2.2	LDA-103-1	11.4	71944	AN173-1 / ET-01984			SR: CONT CR: MONTHLY
103	7.2.9/31.2.2.2	RAN-EXH-103-1	11.4	71946	YAN06-1 / ET-01567			SR: CONT CR: MONTHLY
103	7.2.9	RA-EXH-103-1	11.4	71946	AN041-3 / ET-01794			SR: N/A CR: MONTHLY
103	7.2.9	RR-EXH-103	11.4	71946	AN041-2 / ET-00767			SR: CONT CR: MONTHLY
103	7.2.9	RA-EXH-103-2	11.4	71946	AN041-4 / ET-01870			SR: N/A CR: MONTHLY
103	7.3.1.A	DPI-11		71935	AN097-1 / ET-02368		≤ 5.9"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 19E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.2.a	LE-104-1	11.5	71945	AN065-1 / ET-00539			SR: N/A CR: N/A
104	7.2.2.a	LIT-104-1	11.5	71945	AN065-2 / ET-01358		422", 6"	SR: DAILY CR: N/A
104	7.2.2.a	LE-104-2		71945	AN067-1 / ET-03163			SR: N/A CR: N/A
104	7.2.2.a	LAK-104-1		71945	AN067-2 / ET-00489	EQUIPMENT OUT	OF SERVICE	SR: N/A CR: N/A
104	7.2.2.a	LA-104-1		71945	AN067-3 / ET-02003			SR: N/A CR: N/A
104	7.2.2.b	WFT-04C-1		71945	AN060-1 / ET-00980			SR: N/A CR: N/A
104	7.2.2.b	WFI-04C-1		71945	AN060-2 / ET-02397		≤ 66"	SR: N/A CR: N/A
104	7.2.2.b	WFT-04C-2		71945	AN059-1 / ET-00979			SR: N/A CR: N/A
104	7.2.2.b	WFAS-04C-1		71945	AN059-2 / ET-01085	36"		SR: N/A CR: N/A
104	7.2.2.b	WFA-04C-1		71945	AN059-3 / ET-01792			SR: N/A CR: N/A
104	7.2.2.b	FI-04C-1		71945	AN058-A / ET-02591			SR: N/A CR: N/A
104	7.2.2.b	FI-04C-3		71945	AN058-C / ET-02594			SR: N/A CR: N/A
104	7.2.5 (a,b,c,d)	PT-104-2	11.6	71945	AN064-1 / ET-00931		-6", 5"	SR: N/A CR: ANNUALLY
104	7.2.5 (a,b,c,d)	PR-104-2	11.6	71945	AN064-2 / ET-00750			SR: CONT CR: ANNUALLY
104	7.2.5 (a,b,c,d)	PT-104-1	11.6	71945	AN063-2 / ET-00964		-6", 5"	SR: N/A CR: ANNUALLY
104	7.2.5 (a,b)	PAS-104-1	11.6	71945	AN063-3 / ET-02505	-4"		SR: CONT CR: ANNUALLY
104	7.2.5 (a,b)	PAS-104-2	11.6	71945	AN064-3 / ET-02513	-0.25"		SR: CONT CR: ANNUALLY
104	7.2.5 (a,b)	PA-104-1	11.6	71945	AN063-4 / ET-01698			SR: N/A CR: ANNUALLY
104	7.2.5 (a,b)	PA-104-2	11.6	71945	AN064-4 / ET-01487			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 20E of 46E

104	7.2.5 (a,b,c,d)	PR-104-1	11.6	71945	AN063-5 / ET-00743			SR: CONT CR: ANNUALLY
104	7.2.5 (a,b,c,d)	PI-104-1	11.6	71945	AN437-1 / ET-02461			SR: N/A CR: ANNUALLY
104	7.2.5 (a,b)	HORN	11.6	71945				SR: N/A CR: ANNUALLY
104	7.2.5 (a,b,c,d)	FI-104-1	11.6	71945	AN063-1 / ET-02601			SR: N/A CR: N/A
104	7.2.5 (a,b,c,d)	DPI-104-1		71945				SR: N/A CR: N/A
104	7.2.5 (d)	PI-4		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-36		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-37		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-38		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-39		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-40		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-41		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-42		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-43		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-44		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-45		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-46		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-47		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-48		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-49		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 21E of 46E

104	7.2.6 (a,b,c)	TE-104-50		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-51		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-52		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-53		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	SS-104-1		71945				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		212° F	SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-27		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-28		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-29		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-30		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-31		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-32		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-33		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-34		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-35		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-57		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-58		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-59		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-60		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-61		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 22E of 46E

104	7.2.7 (a,b,c)	TE-104-62		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-63		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-64		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-65		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-66		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-67		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-68		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-69		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-70		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-71		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-72		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-73		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-74		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-75		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-76		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-77		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-78		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-79		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-80		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-81		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 23E of 46E

104	7.2.7 (a,b,c)	TE-104-82		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-83		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-84		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-85		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-86		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-87		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-88		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-89		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-90		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-91		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-92		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-93		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-94		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-95		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-96		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-97		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-98		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-99		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-100		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-101		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 24E of 46E

104	7.2.7 (a,b,c)	SS-104-3		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	SS-104-4		71945				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		236° F	SR: N/A CR: N/A
104	7.2.9/31.2.2.2	LDE-104-2	11.4	71945	AN073-1 / ET-01594	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-2	11.4	71945	AN073-2 / ET-00533			SR: CONT CR: QUARTERLY
104	7.2.9	LDK-104-2	11.4	71945	AN073-4 / ET-00514			SR: N/A CR: QUARTERLY
104	7.2.9/31.2.2.2	LDE-104-3	11.4	71945	AN074-1 / ET-01592	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-3	11.4	71945	AN074-2 / ET-00503			SR: CONT CR: QUARTERLY
104	7.2.9	LDK-104-3	11.4	71945	AN074-4 / ET-00478			SR: N/A CR: QUARTERLY
104	7.2.9/31.2.2.2	LDE-104-4	11.4	71945	AN075-1 / ET-01593	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-4	11.4	71945	AN075-2 / ET-00490			SR: CONT CR: QUARTERLY
104	7.2.9	LDK-104-4	11.4	71945	AN075-4 / ET-00483			SR: N/A CR: QUARTERLY
104	7.2.9/31.2.2.2	LDA-104-1	11.4	71945	AN076-1 / ET-01930			SR: CONT CR: MONTHLY
104	7.2.9/31.2.2.2	RAN-EXH-104-1	11.4	71946	YAN07-1 / ET-01571			SR: CONT CR: MONTHLY
104	7.2.9	RA-EXH-104-1	11.4	71946	AN285-2 / ET-02002			SR: N/A CR: MONTHLY
104	7.2.9	RR-EXH-104	11.4	71946	AN285-1 / ET-00766			SR: CONT CR: MONTHLY
104	7.2.9	RA-EXH-104-2	11.4	71946	AN285-3 / ET-01707			SR: N/A CR: MONTHLY
104	7.3.1.A	DPI-12		71935	AN109-2 / ET-02423		≤ 5.9"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 25E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.2.a	LE-105-1	11.5	71945	AN179-1 / ET-00585			SR: N/A CR: N/A
105	7.2.2.a	LIT-105-1	11.5	71945	AN179-2 / ET-01367		422", 6"	SR: DAILY CR: N/A
105	7.2.2.a	LE-105-2		71945	AN183-1 / ET-03099			SR: N/A CR: N/A
105	7.2.2.a	LAK-105-1		71945	AN183-2 / ET-00184	EQUIPMENT OUT	OF SERVICE	SR: N/A CR: N/A
105	7.2.2.a	LA-105-1		71945	AN183-3 / ET-01939			SR: N/A CR: N/A
105	7.2.2.b	WFT-05C-1		71945	AN176-1 / ET-00941			SR: N/A CR: N/A
105	7.2.2.b	WFI-05C-1		71945	AN176-2 / ET-02394		≤ 66"	SR: N/A CR: N/A
105	7.2.2.b	WFT-05C-2		71945	AN175-1 / ET-00978			SR: N/A CR: N/A
105	7.2.2.b	WFAS-05C-1		71945	AN175-2 / ET-01025	36"		SR: N/A CR: N/A
105	7.2.2.b	WFA-05C-1		71945	AN175-3 / ET-01717			SR: N/A CR: N/A
105	7.2.2.b	FI-05C-1		71945	AN174-A / ET-02583			SR: N/A CR: N/A
105	7.2.2.b	FI-05C-3		71945	AN174-C / ET-02589			SR: N/A CR: N/A
105	7.2.5 (a,b,c,d)	PT-105-2	11.6	71945	AN181-1 / ET-00949		-6", 5"	SR: N/A CR: ANNUALLY
105	7.2.5 (a,b,c,d)	PR-105-2	11.6	71945	AN181-2 / ET-00737			SR: CONT CR: ANNUALLY
105	7.2.5 (a,b,c,d)	PT-105-1	11.6	71945	AN180-2 / ET-00950		-6", 5"	SR: N/A CR: ANNUALLY
105	7.2.5 (a,b)	PAS-105-1	11.6	71945	AN180-3 / ET-02496	-4"		SR: CONT CR: ANNUALLY
105	7.2.5 (a,b)	PAS-105-2	11.6	71945	AN181-3 / ET-02508	-0.25"		SR: CONT CR: ANNUALLY
105	7.2.5 (a,b)	PA-105-1	11.6	71945	AN180-4 / ET-01887			SR: N/A CR: ANNAALLY
105	7.2.5 (a,b)	PA-105-2	11.6	71945	AN181-4 / ET-01885			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 26E of 46E

105	7.2.5 (a,b,c,d)	PR-105-1	11.6	71945	AN180-5 / ET-00749			SR: CONT CR: ANNUALLY
105	7.2.5 (a,b,c,d)	PI-105-1	11.6	71945	AN438-1 / ET-02465			SR: N/A CR: ANNUALLY
105	7.2.5 (a,b)	HORN	11.6	71945				SR: N/A CR: ANNUALLY
105	7.2.5 (a,b,c,d)	FI-105-1	11.6	71945	AN180-1 / ET-02617			SR: N/A CR: N/A
105	7.2.5 (a,b,c,d)	DPI-105-1		71945				SR: N/A CR: N/A
105	7.2.5 (d)	PI-5		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-36		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-37		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-38		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-39		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-40		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-41		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-42		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-43		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-44		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-45		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-46		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-47		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-48		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-49		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 27E of 46E

105	7.2.6 (a,b,c)	TE-105-50		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-51		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-52		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-53		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	SS-105-1		71945				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		212° F	SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-27		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-28		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-29		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-30		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-31		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-32		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-33		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-34		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-35		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-57		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-58		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-59		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-60		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-61		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 28E of 46E

105	7.2.7 (a,b,c)	TE-105-62		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-63		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-64		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-65		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-66		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-67		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-68		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-69		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-70		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-71		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-72		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-73		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-74		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-75		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-76		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-77		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-78		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-79		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-80		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-81		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WMC-SD-WM-003 REV. 0
PAGE 29E of 46E

105	7.2.7 (a,b,c)	TE-105-82		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-83		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-84		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-85		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-86		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-87		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-88		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-89		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-90		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-91		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-92		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-93		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-94		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-95		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-96		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-97		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-98		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-99		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-100		71945				SR: N/A	CR: N/A
105	7.2.7 (a,b,c)	TE-105-101		71945				SR: N/A	CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

EL
1
WHC-SD-WM-003 REV. 0
PAGE 30E of 46E

105	7.2.7 (a,b,c)	SS-105-3		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	SS-105-4		71945				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		236° F	SR: N/A CR: N/A
105	7.2.9/31.2.2.2	LDE-105-2	11.4	71945	AN189-1 / ET-01458	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-2	11.4	71945	AN189-2 / ET-00290			SR: CONT CR: QUARTERLY
105	7.2.9	LDK-105-2	11.4	71945	AN189-4 / ET-00101			SR: N/A CR: QUARTERLY
105	7.2.9/31.2.2.2	LDE-105-3	11.4	71945	AN190-1 / ET-01457	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-3	11.4	71945	AN190-2 / ET-00382			SR: CONT CR: QUARTERLY
105	7.2.9	LDK-105-3	11.4	71945	AN190-4 / ET-00313			SR: N/A CR: QUARTERLY
105	7.2.9/31.2.2.2	LDE-105-4	11.4	71945	AN191-1 / ET-01462	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-4	11.4	71945	AN191-2 / ET-00055			SR: CONT CR: QUARTERLY
105	7.2.9	LDK-105-4	11.4	71945	AN191-4 / ET-00312			SR: N/A CR: QUARTERLY
105	7.2.9/31.2.2.2	LDA-105-1	11.4	71945	AN192-1 / ET-01938			SR: CONT CR: MONTHLY
105	7.2.9/31.2.2.2	RAN-EXH-105-1	11.4	71946	YAN08-1 / ET-01555			SR: CONT CR: MONTHLY
105	7.2.9	RA-EXH-105-1	11.4	71946	AN286-2 / ET-02052			SR: N/A CR: MONTHLY
105	7.2.9	RR-EXH-105	11.4	71946	AN286-1 / ET-00763			SR: CONT CR: MONTHLY
105	7.2.9	RA-EXH-105-2	11.4	71946	AN286-3 / ET-01986			SR: N/A CR: MONTHLY
105	7.3.1.A	DPI-13		71935	AN113-2 / ET-02362		≤ 5.9"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 31E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.2.a	LE-106-1	11.5	71945	AN200-1 / ET-00586			SR: N/A CR: N/A
106	7.2.2.a	LIT-106-1	11.5	71945	AN200-2 / ET-01352		422", 6"	SR: N/A CR: N/A
106	7.2.2.a	LE-106-2		71945	AN205-1 / ET-00398			SR: N/A CR: N/A
106	7.2.2.a	LAK-106-1		71945	AN205-2 / ET-03158	419"		SR: N/A CR: N/A
106	7.2.2.a	LA-106-1		71945	AN205-3 / ET-01775			SR: N/A CR: N/A
106	7.2.2.b	WFT-06C-1		71945	AN195-1 / ET-00975			SR: N/A CR: N/A
106	7.2.2.b	WFI-06C-1		71945	AN195-2 / ET-02396		≤ 66"	SR: N/A CR: N/A
106	7.2.2.b	WFT-06C-2		71945	AN194-1 / ET-00966			SR: N/A CR: N/A
106	7.2.2.b	WFAS-06C-1		71945	AN194-2 / ET-01089	36"		SR: N/A CR: N/A
106	7.2.2.b	WFA-06C-1		71945	AN194-3 / ET-01820			SR: N/A CR: N/A
106	7.2.2.b	FI-06C-1		71945	AN193-A / ET-02599			SR: N/A CR: N/A
106	7.2.2.b	FI-06C-3		71945	AN193-C / ET-02595			SR: N/A CR: N/A
106	7.2.5 (a,b,c,d)	PT-106-2	11.6	71945	AN199-1 / ET-00984		-6", 5"	SR: N/A CR: ANNUALLY
106	7.2.5 (a,b,c,d)	PR-106-2	11.6	71945	AN199-2 / ET-00747			SR: CONT CR: ANNUALLY
106	7.2.5 (a,b,c,d)	PT-106-1	11.6	71945	AN198-2 / ET-00939		-6", 5"	SR: N/A CR: ANNUALLY
106	7.2.5 (a,b)	PAS-106-1	11.6	71945	AN198-3 / ET-02507	-4"		SR: CONT CR: ANNUALLY
106	7.2.5 (a,b)	PAS-106-2	11.6	71945	AN199-3 / ET-02512	-0.25"		SR: CONT CR: ANNUALLY
106	7.2.5 (a,b)	PA-106-1	11.6	71945	AN198-4 / ET-01704			SR: N/A CR: ANNUALLY
106	7.2.5 (a,b)	PA-106-2	11.6	71945	AN199-4 / ET-01781			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

W/C
1
WHC-SD-WM-003 REV. 0
PAGE 32E of 46E

106	7.2.5 (a,b,c,d)	PR-106-1	11.6	71945	AN198-5 / ET-00745			SR: CONT	CR: ANNUALLY
106	7.2.5 (a,b,c,d)	PI-106-1	11.6	71945	AN439-1 / ET-02462			SR: N/A	CR: ANNUALLY
106	7.2.5 (a,b)	HORN	11.6	71945				SR: N/A	CR: ANNUALLY
106	7.2.5 (a,b,c,d)	FI-106-1	11.6	71945	AN198-1 / ET-02600			SR: N/A	CR: N/A
106	7.2.5 (a,b,c,d)	DPI-106-1		71945				SR: N/A	CR: N/A
106	7.2.5 (d)	PI-6		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-36		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-37		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-38		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-39		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-40		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-41		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-42		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-43		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-44		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-45		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-46		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-47		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-48		71945				SR: N/A	CR: N/A
106	7.2.6 (a,b,c)	TE-106-49		71945				SR: N/A	CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 33E of 46E

106	7.2.6 (a,b,c)	TE-106-50		71945				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-51		71945				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-52		71945				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-53		71945				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	SS-106-1		71945				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		212° F	SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-27		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-28		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-29		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-30		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-31		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-32		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-33		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-34		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-35		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-57		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-58		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-59		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-60		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-61		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

7EL
WHC-SD-WM-003 REV. 0
PAGE 34E of 46E

106	7.2.7 (a,b,c)	TE-106-62		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-63		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-64		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-65		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-66		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-67		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-68		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-69		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-70		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-71		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-72		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-73		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-74		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-75		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-76		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-77		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-78		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-79		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-80		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-81		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 35E of 46E

106	7.2.7 (a,b,c)	TE-106-82		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-83		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-84		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-85		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-86		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-87		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-88		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-89		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-90		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-91		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-92		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-93		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-94		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-95		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-96		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-97		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-98		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-99		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-100		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-101		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 36E of 46E

106	7.2.7 (a,b,c)	SS-106-3		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	SS-106-4		71945				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		236° F	SR: N/A CR: N/A
106	7.2.9/31.2.2.2	LDE-106-2	11.4	71945	AN208-1 / ET-01603	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-2	11.4	71945	AN208-2 / ET-00218			SR: CONT CR: QUARTERLY
106	7.2.9	LDK-106-2	11.4	71945	AN208-4 / ET-00372			SR: N/A CR: QUARTERLY
106	7.2.9/31.2.2.2	LDE-106-3	11.4	71945	AN209-1 / ET-01601	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-3	11.4	71945	AN209-2 / ET-00009			SR: CONT CR: QUARTERLY
106	7.2.9	LDK-106-3	11.4	71945	AN209-4 / ET-00259			SR: N/A CR: QUARTERLY
106	7.2.9/31.2.2.2	LDE-106-4	11.4	71945	AN210-1 / ET-01602	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-4	11.4	71945	AN210-2 / ET-00054			SR: CONT CR: QUARTERLY
106	7.2.9	LDK-106-4	11.4	71945	AN210-4 / ET-00351			SR: N/A CR: QUARTERLY
106	7.2.9/31.2.2.2	LDA-106-1	11.4	71945	AN211-1 / ET-01854			SR: CONT CR: MONTHLY
106	7.2.9/31.2.2.2	RAN-EXH-106-1	11.4	71946	YAN09-1 / ET-01577			SR: CONT CR: MONTHLY
106	7.2.9	RA-EXH-106-1	11.4	71946	AN045-3 / ET-01915			SR: N/A CR: MONTHLY
106	7.2.9	RR-EXH-106	11.4	71946	AN045-2 / ET-00761			SR: CONT CR: MONTHLY
106	7.2.9	RA-EXH-106-2	11.4	71946	AN045-4 / ET-01972			SR: N/A CR: MONTHLY
106	7.3.1.A	DPI-14		71935	AN117-2 / ET-02350			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 37E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.2.a	LE-107-1	11.5	71945	AN219-1 / ET-00587			SR: N/A CR: N/A
107	7.2.2.a	LIT-107-1	11.5	71945	AN219-2 / ET-01369		422". 6"	SR: N/A CR: N/A
107	7.2.2.a	LE-107-2		71945	AN221-1 / ET-00407			SR: N/A CR: N/A
107	7.2.2.a	LAK-107-1		71945	AN221-2 / ET-00217	419"		SR: N/A CR: N/A
107	7.2.2.a	LA-107-1		71945	AN221-3 / ET-01997			SR: N/A CR: N/A
107	7.2.2.b	WFT-07C-1		71945	AN214-1 / ET-00938			SR: N/A CR: N/A
107	7.2.2.b	WFI-07C-1		71945	AN214-2 / ET-02393		≤ 66"	SR: N/A CR: N/A
107	7.2.2.b	WFT-07C-2		71945	AN213-1 / ET-00945			SR: N/A CR: N/A
107	7.2.2.b	WFAS-07C-1		71945	AN213-2 / ET-01016	36"		SR: N/A CR: N/A
107	7.2.2.b	WFA-07C-1		71945	AN213-3 / ET-01718			SR: N/A CR: N/A
107	7.2.2.b	FI-07C-1		71945	AN212-A / ET-02582			SR: N/A CR: N/A
107	7.2.2.b	FI-07C-3		71945	AN212-C / ET-02587			SR: N/A CR: N/A
107	7.2.5 (a,b,c,d)	PT-107-2	11.6	71945	AN218-1 / ET-00942		-6". 5"	SR: N/A CR: ANNUALLY
107	7.2.5 (a,b,c,d)	PR-107-2	11.6	71945	AN218-2 / ET-00753			SR: CONT CR: ANNUALLY
107	7.2.5 (a,b,c,d)	PT-107-1	11.6	71945	AN217-2 / ET-00965		-6". 5"	SR: N/A CR: ANNUALLY
107	7.2.5 (a,b)	PAS-107-1	11.6	71945	AN217-3 / ET-02494	-4"		SR: CONT CR: ANNUALLY
107	7.2.5 (a,b)	PAS-107-2	11.6	71945	AN218-3 / ET-02514	-0.25"		SR: CONT CR: ANNUALLY
107	7.2.5 (a,b)	PA-107-1	11.6	71945	AN217-4 / ET-01970			SR: N/A CR: ANNUALLY
107	7.2.5 (a,b)	PA-107-2	11.6	71945	AN218-4 / ET-01989			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WLC-SD-WM-003 REV. 0
PAGE 38E of 46E

107	7.2.5 (a,b,c,d)	PR-107-1	11.6	71945	AN217-5 / ET-00740			SR: CONT CR: ANNUALLY
107	7.2.5 (a,b,c,d)	PI-107-1	11.6	71945	AN440-1 / ET-02463			SR: N/A CR: ANNUALLY
107	7.2.5 (a,b)	HORN	11.6	71945				SR: N/A CR: ANNUALLY
107	7.2.5 (a,b,c,d)	FI-107-1	11.6	71945	AN217-1 / ET-02603			SR: N/A CR: N/A
107	7.2.5 (a,b,c,d)	DPI-107-1		71945				SR: N/A CR: N/A
107	7.2.5 (d)	PI-7		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-36		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-37		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-38		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-39		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-40		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-41		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-42		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-43		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-44		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-45		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-46		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-47		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-48		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-49		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 39E of 46E

107	7.2.6 (a,b,c)	TE-107-50		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-51		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-52		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-53		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	SS-107-1		71945				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		212° F	SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-27		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-28		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-29		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-30		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-31		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-32		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-33		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-34		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-35		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-57		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-58		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-59		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-60		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-61		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 40E of 46E

107	7.2.7 (a,b,c)	TE-107-62		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-63		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-64		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-65		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-66		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-67		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-68		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-69		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-70		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-71		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-72		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-73		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-74		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-75		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-76		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-77		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-78		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-79		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-80		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-81		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 41E of 46E

107	7.2.7 (a,b,c)	TE-107-82		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-83		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-84		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-85		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-86		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-87		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-88		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-89		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-90		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-91		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-92		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-93		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-94		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-95		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-96		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-97		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-98		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-99		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-100		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-101		71945				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

7 EL
WHC-SD-WM-003 REV. 0
PAGE 42E of 46E

107	7.2.7 (a,b,c)	SS-107-3		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	SS-107-4		71945				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TI-AN-2		71945	AN091-1 / ET-02434		236° F	SR: N/A CR: N/A
107	7.2.9/31.2.2.2	LDE-107-2	11.4	71945	AN227-1 / ET-01591	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
107	7.2.9	LDI-107-2	11.4	71945	AN227-2 / ET-00273			SR: CONT CR: QUARTERLY
107	7.2.9	LDK-107-2	11.4	71945	AN227-4 / ET-00144			SR: N/A CR: QUARTERLY
107	7.2.9/31.2.2.2	LDE-107-3	11.4	71945	AN228-1 / ET-01589	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
107	7.2.9	LDI-107-3	11.4	71945	AN228-2 / ET-00159			SR: CONT CR: QUARTERLY
107	7.2.9	LDK-107-3	11.4	71945	AN228-4 / ET-00307			SR: N/A CR: QUARTERLY
107	7.2.9/31.2.2.2	LDE-107-4	11.4	71945	AN229-1 / ET-01590	1/8"+3/8-1/8"		SR: N/A CR: QUARTERLY
107	7.2.9	LDI-107-4	11.4	71945	AN229-2 / ET-00050			SR: CONT CR: QUARTERLY
107	7.2.9	LDK-107-4	11.4	71945	AN229-4 / ET-00381			SR: N/A CR: QUARTERLY
107	7.2.9/31.2.2.2	LDA-107-1	11.4	71945	AN230-1 / ET-01979			SR: CONT CR: MONTHLY
107	7.2.9/31.2.2.2	RAN-EXH-107-1	11.4	71946	YAN10-1 / ET-01575			SR: CONT CR: MONTHLY
107	7.2.9	RA-EXH-107-1	11.4	71946	AN367-2 / ET-01843			SR: N/A CR: MONTHLY
107	7.2.9	RR-EXH-107	11.4	71946	AN367-1 / ET-00764			SR: CONT CR: MONTHLY
107	7.2.9	RA-EXH-107-2	11.4	71946	AN367-3 / ET-01741			SR: N/A CR: MONTHLY
107	7.3.1.A	DPI-15		71935	AN121-2 / ET-02355			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 43E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K1	7.3.1.A.1.a	DPIS-2		71935	AN105-2 / ET-00829		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.a	DPA-2		71935	AN105-3 / ET-01861			SR: N/A CR: N/A
K1	7.3.1.A.1.a	DPIS-5		71935	AN101-3 / ET-00833		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.a	DPA-5		71935	AN101-4 / ET-02008			SR: N/A CR: N/A
K1	7.3.1.A.1.b	DPIS-1		71935	AN105-1 / ET-00832		≤ 4.0"	SR: DAILY CR: N/A
K1	7.3.1.A.1.b	DPIS-4		71935	AN101-5 / ET-00828		≤ 4.0"	SR: DAILY CR: N/A
K1	7.3.1.B	TI-2		71935	AN107-1 / ET-02437		230° F	SR: N/A CR: N/A
K1	7.3.1.B	TI-8		71935	AN106-1 / ET-02627		230° F	SR: N/A CR: N/A
K1	7.3.1.B	TC-K1-1		71935	AN135-5 / ET-01463			SR: N/A CR: N/A
K1	7.3.1.B	TC-K1-2		71935	AN102-5 / ET-01497			SR: N/A CR: N/A
K1	7.3.1.D	TI-1		71935	AN108-1 / ET-02438			SR: DAILY CR: N/A
K1	7.3.1.D	TI-2		71935	AN107-1 / ET-02437			SR: DAILY CR: N/A
K1	7.3.1.D	TC-K1-1		71935	AN135-5 / ET-01463			SR: N/A CR: N/A
K1	7.3.1.D	TI-7		71935	AN103-1 / ET-02629			SR: DAILY CR: N/A
K1	7.3.1.D	TI-8		71935	AN106-1 / ET-02627			SR: DAILY CR: N/A
K1	7.3.1.D	TC-K1-2		71935	AN102-5 / ET-01497			SR: N/A CR: N/A
K1	7.3.1.E	RAN-EXH-K1-1		71946	YAN02-1 / ET-01557			SR: N/A CR: N/A
K1	7.3.1.E	PS-EXH-K1-1		71946	AN038-2 / ET-01107			SR: N/A CR: N/A
K1	7.3.1.E	PA-EXH-K1-1		71946	AN038-3 / ET-01948			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 44E of 46E

K1	7.3.1.E	RR-EXH-K1		71946	AN038-4 / ET-00768			SR: N/A CR: N/A
K1	7.3.1.E	RA-EXH-K1-1		71946	AN038-6 / ET-01793			SR: N/A CR: N/A
K1	7.3.1.E	RA-EXH-K1-2		71946	AN038-7 / ET-01869			SR: N/A CR: N/A
K1	7.3.1.E	FI-RS-K1		71946	AN039-2 / ET-01619			SR: N/A CR: N/A
K1	7.3.1.E	FQI-EXH-K1		71946	AN039-1 / ET-01625			SR: N/A CR: N/A
K1	7.3.1.E	PS-EXH-K1-2		71946	AN039-3 / ET-01109			SR: N/A CR: N/A
K1	7.3.1.E	PA-EXH-K1-2		71946	AN039-4 / ET-01847			SR: N/A CR: N/A
K1	7.3.1.E	RECORD SAMPLER		71946				SR: N/A CR: N/A
K1	7.3.2	see OSD 7.2.5 (a,c)						SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 45E of 46E

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K2	7.3.1.A.1.a	DPI-17		71935	AN127-1 / ET-02342		≤ 5.9"	SR: DAILY CR: N/A
K2	7.3.1.A.1.a	DPI-18		71935	AN132-2 / ET-02343		≤ 5.9"	SR: DAILY CR: N/A
K2	7.3.1.A.1.b	DPI-23		71935	AN127-2 / ET-01604		≤ 4.0"	SR: DAILY CR: N/A
K2	7.3.1.A.1.b	DPI-24		71935	AN132-1 / ET-01605		≤ 4.0"	SR: DAILY CR: N/A
K2	7.3.1.B	TI-4		71935	AN126-3 / ET-02439		230° F	SR: DAILY CR: N/A
K2	7.3.1.B	TI-6		71935	AN133-1 / ET-02436		230° F	SR: DAILY CR: N/A
K2	7.3.1.B	TC-2		71935	AN126-2 / ET-01516			SR: N/A CR: N/A
K2	7.3.1.B	TC-3		71935	AN133-2 / ET-01515			SR: N/A CR: N/A
K2	7.3.1.D	TI-4		71935	AN126-3 / ET-02439			SR: DAILY CR: N/A
K2	7.3.1.D	TI-6		71935	AN133-1 / ET-02436			SR: DAILY CR: N/A
K2	7.3.1.D	TC-2		71935	AN126-2 / ET-01516			SR: N/A CR: N/A
K2	7.3.1.D	TC-3		71935	AN133-2 / ET-01515			SR: N/A CR: N/A
K2	7.3.1.D	TI-3		71935	AN126-1 / ET-01211			SR: DAILY CR: N/A
K2	7.3.1.D	TI-5		71935	AN133-3 / ET-01213			SR: DAILY CR: N/A
K2	7.3.1.E	RR-EXH-K2		71946	AN038-5 / ET-00769			SR: N/A CR: N/A
K2	7.3.1.E	RA-EXH-K2-1		71946	AN231-4 / ET-02054			SR: N/A CR: N/A
K2	7.3.1.E	RA-EXH-K2-2		71946	AN231-5 / ET-01772			SR: N/A CR: N/A
K2	7.3.1.E	RAN-EXH-K2-1		71946	YAN03-1 / ET-01563			SR: N/A CR: N/A
K2	7.3.1.E	PS-EXH-K2-1		71946	AN231-2 / ET-02490			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-003 REV. 0
PAGE 46E of 46E

K2	7.3.1.E	PA-EXH-K2-1		71946	AN231-3 / ET-02053			SR: N/A	CR: N/A
K2	7.3.1.E	FI-RS-K2		71946	AN232-2 / ET-01617			SR: N/A	CR: N/A
K2	7.3.1.E	FQI-EXH-K2		71946	AN232-1 / ET-01616			SR: N/A	CR: N/A
K2	7.3.1.E	RECORD SAMPLER		71946				SR: N/A	CR: N/A
K2	7.3.1.E	PS-EXH-K2-2		71946	AN232-3 / ET-02491			SR: N/A	CR: N/A
K2	7.3.1.E	PA-EXH-K2-2		71946	AN232-4 / ET-01825			SR: N/A	CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0

page 1 F of 72 F

241-AP

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.2.a	LE-101-1	11.5	90487	AP102-1 / EE-00350			SR: N/A CR: N/A
101	7.2.2.a	LIT-101-1	11.5	90487	AP102-2 / EE-00794		422", 6"	SR: CONT CR: N/A
101	7.2.2.a	LE-101-3	11.5	90487	AP118-1 / EE-00271			SR: N/A CR: N/A
101	7.2.2.a	LI-101-1	11.5	90487	AP118-2 / EE-00922		422", 6"	SR: CONT CR: N/A
101	7.2.2.a	LE-101-2		90487	AP110-1 / EE-00202	419"		SR: N/A CR: N/A
101	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
101	7.2.2.a	LA-101-1		90487	AP110-2 / EE-01080			SR: N/A CR: N/A
101	7.2.2.a	LXA-101-1		90487	AP110-3 / EE-01081			SR: N/A CR: N/A
101	7.2.5.a	PT-101-1		90487	AP001-2 / EE-00641		5", -6"	SR: N/A CR: N/A
101	7.2.5.a	FI-101-1		90487	AP001-1 / EE-01967			SR: N/A CR: N/A
101	7.2.5.a	CVT-101		90487				SR: N/A CR: N/A
101	7.2.5.a	PR-101-1		90487	AP001-4 / EE-00525			SR: N/A CR: N/A
101	7.2.5.a	PAS-101-1		90487	AP001-6 / EE-00665	-0.25"		SR: N/A CR: N/A
101	7.2.5.a	PA-101-1		90487	AP001-8 / EE-01191			SR: N/A CR: N/A
101	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
101	7.2.5.a	PT-101-2		90487	AP001-3 / EE-00632		5", -6"	SR: N/A CR: N/A
101	7.2.5.a	PR-101-2		90487	AP001-5 / EE-00502			SR: N/A CR: N/A
101	7.2.5.a	PAS-101-2		90487	AP001-7 / EE-00667	-5"		SR: N/A CR: N/A
101	7.2.5.a	PA-101-2		90487	AP001-9 / EE-01185			SR: N/A CR: N/A
101	7.2.5.a	PA-A-2		90487	AP010-2 / EE/01110			SR: N/A CR: N/A
101	7.2.5.a	HORN		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 2 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.5.a	DPI-101-1		90514	AP073-1 / EE-02055		5", -6"	SR: N/A CR: N/A
101	7.2.5.b	PT-101-1	11.6	90487	AP001-2 / EE-00641		5", -6"	SR: N/A CR: ANNUALLY
101	7.2.5.b	FI-101-1	11.6	90487	AP001-1 / EE-01967			SR: N/A CR: N/A
101	7.2.5.b	CVT-101	11.6	90487				SR: N/A CR: ANNUALLY
101	7.2.5.b	PR-101-1	11.6	90487	AP001-4 / EE-00525			SR: N/A CR: ANNUALLY
101	7.2.5.b	PAS-101-1	11.6	90487	AP001-6 / EE-00665	-0.25"		SR: CONT CR: ANNUALLY
101	7.2.5.b	PA-101-1	11.6	90487	AP001-8 / EE-01191			SR: N/A CR: ANNUALLY
101	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
101	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
101	7.2.5.b	PT-101-2	11.6	90487	AP001-3 / EE-00632		5", -6"	SR: N/A CR: ANNUALLY
101	7.2.5.b	PR-101-2	11.6	90487	AP001-5 / EE-00502			SR: N/A CR: ANNUALLY
101	7.2.5.b	PAS-101-2	11.6	90487	AP001-7 / EE-00667	-5"		SR: CONT CR: ANNUALLY
101	7.2.5.b	PA-101-2	11.6	90487	AP001-9 / EE-01185			SR: N/A CR: ANNUALLY
101	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
101	7.2.5.b	DPI-101-1	11.6	90514	AP073-1 / EE-02055		5", -6"	SR: N/A CR: N/A
101	7.2.5.c	PT-101-1	11.6	90487	AP001-2 / EE-00641			SR: N/A CR: N/A
101	7.2.5.c	PR-101-1	11.6	90487	AP001-4 / EE-00525			SR: CONT CR: N/A
101	7.2.5.c	CVT-101	11.6	90487				SR: N/A CR: N/A
101	7.2.5.c	FI-101-1	11.6	90487	AP001-1 / EE-01967			SR: N/A CR: N/A
101	7.2.5.c	PT-101-2	11.6	90487	AP001-3 / EE-00632			SR: N/A CR: N/A
101	7.2.5.c	PR-101-2	11.6	90487	AP001-5 / EE-00502			SR: CONT CR: N/A
101	7.2.5.c (d)	PT-101-1		90487	AP001-2 / EE-00641		5", -6"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 3 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.5.c (d)	PR-101-1		90487	AP001-4 / EE-00525			SR: N/A CR: N/A
101	7.2.5.c (d)	CVT-101		90487				SR: N/A CR: N/A
101	7.2.5.c (d)	FI-101-1		90487	AP001-1 / EE-01967			SR: N/A CR: N/A
101	7.2.5.c (d)	PT-101-2		90487	AP001-3 / EE-00632		5", -6"	SR: N/A CR: N/A
101	7.2.5.c (d)	PR-101-2		90487	AP001-5 / EE-00502			SR: N/A CR: N/A
101	7.2.5.c (d)	DPI-101-2		90514	AP072-1 / EE-02044			SR: N/A CR: N/A
101	7.2.5.c (d)	DPI-101-1		90514	AP073-1 / EE-02055		5", -6"	SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-36		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-37		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-38		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-39		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-40		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-41		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-42		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-43		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-44		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-45		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-46		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-47		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-48		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-49		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-50		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 4 of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.6 (a,b,c)	TE-101-51		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-52		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-53		90487				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	MUX-101-1		90489				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		212° F	SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-27		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-28		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-29		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-30		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-31		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-32		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-33		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-34		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-35		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-54		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-55		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-56		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-57		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-58		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-59		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-60		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-61		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 5 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.7 (a,b,c)	TE-101-62		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-63		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-64		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-65		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-66		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-67		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-68		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-69		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-70		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-71		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-72		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-73		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-74		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-75		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-76		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-77		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-78		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-79		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-80		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-81		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-82		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-83		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 6 F of 22 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.7 (a,b,c)	TE-101-84		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-85		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-86		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-87		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-88		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-89		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-90		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-91		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-92		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-93		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-94		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-95		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-96		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-97		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-98		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-99		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-100		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-101		90487				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	MUX-101-1		90489				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	MUX-101-2		90489				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		236° F	SR: N/A CR: N/A
101	7.2.9	LDE-101-2	11.4	90487	AP125-1 / EE-00969			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 7 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.9	LDI-101-2	11.4	90487	AP125-2 / EE-00192			SR: CONT CR: QUARTERLY
101	7.2.9	LDK-101-2	11.4	90487	AP125-5			SR: N/A CR: QUARTERLY
101	7.2.9	LDIL-101-2	11.4	90487	AP125-6			SR: N/A CR: QUARTERLY
101	7.2.9	LDA-101-1	11.4	90487	AP125-4 / EE-01059			SR: N/A CR: MONTHLY
101	7.2.9	LDE-101-3	11.4	90487	AP126-1 / EE-00968			SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-3	11.4	90487	AP126-2 / EE-00161			SR: CONT CR: QUARTERLY
101	7.2.9	LDK-101-3	11.4	90487	AP126-4			SR: N/A CR: QUARTERLY
101	7.2.9	LDIL-101-3	11.4	90487	AP126-5			SR: N/A CR: QUARTERLY
101	7.2.9	LDE-101-4	11.4	90487	AP127-1 / EE-00967			SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-4	11.4	90487	AP127-2 / EE-00150			SR: CONT CR: QUARTERLY
101	7.2.9	LDK-101-4	11.4	90487	AP127-4			SR: N/A CR: QUARTERLY
101	7.2.9	LDIL-101-4	11.4	90487	AP127-5			SR: N/A CR: QUARTERLY
101	7.2.9	CAM-101-AP-1	11.4	90488	YAP04-1 / EE-00933			SR: CONT CR: MONTHLY
101	7.2.9	CVT-101-AP-1	11.4	90488	AP015-2 / EE-00371			SR: N/A CR: SEMI-ANN
101	7.2.9	RR-101-AP-1	11.4	90488	AP015-3 / EE-00509			SR: N/A CR: SEMI-ANN
101	7.2.9	RA-101-AP-1	11.4	90488	AP015-7 / EE-01104			SR: N/A CR: MONTHLY
101	7.2.9	RA-101-AP-2	11.4	90488	AP015-6 / EE-01051			SR: N/A CR: MONTHLY
101	7.2.9	RA-101-AP-3	11.4	90488	AP015-4 / EE-01128			SR: N/A CR: MONTHLY
101	7.2.9	RA-101-AP-4	11.4	90488	AP015-5 / EE-01050			SR: N/A CR: MONTHLY
101	7.2.9	RXA-101-AP-1	11.4	90488	AP015-8 / EE-01172			SR: N/A CR: MONTHLY
101	7.2.9	RXA-101-AP-2	11.4	90488	AP015-9 / EE-01168			SR: N/A CR: MONTHLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 8 F of 22 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
101	7.3.1.A.1	DPIS-7		90514	AP071-2 / EE-00472		≤ 5.9"	SR: DAILY CR: N/A
101	7.3.1.A.1	DPA-K2-7		90514	AP071-3 / EE-01120			SR: N/A CR: N/A
101	7.3.1.B	TI-10		90514	AP070-5 / EE-02023		≤ 230° F	SR: DAILY CR: N/A
101	7.3.1.D	TI-9		90514	AP070-4 / EE-02031			SR: DAILY CR: N/A
101	7.3.1.D	TI-10		90514	AP070-5 / EE-02023			SR: DAILY CR: N/A
101	7.3.1.D	TC-1		90514	AP070-1 / EE-00858		ΔT ≥ 5° F	SR: N/A CR: N/A
101	7.3.1.D	TA-1		90514	AP070-6 / EE-01041			SR: N/A CR: N/A
101	7.3.1.D	TA-K2-1		90514	AP070-7 / EE-01124			SR: N/A CR: N/A
101	31.2.2.2	LDE-101-2		90487	AP125-1 / EE-00969	1/8"+3/8-1/8"		SR: N/A CR: N/A
101	31.2.2.2	LDE-101-3		90487	AP126-1 / EE-00968	1/8"+3/8-1/8"		SR: N/A CR: N/A
101	31.2.2.2	LDE-101-4		90487	AP127-1 / EE-00967	1/8"+3/8-1/8"		SR: N/A CR: N/A
101	31.2.2.2	LDA-101-1		90487	AP125-4 / EE-01059			SR: CONT CR: N/A
101	31.2.2.2	CAM-101-AP-1		90488	YAP04-1 / EE-00933			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 9 F of 22 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.2.a	LE-102-1	11.5	90487	AP103-1 / EE-00352			SR: N/A CR: N/A
102	7.2.2.a	LIT-102-1	11.5	90487	AP103-2 / EE-00797		422", 6"	SR: N/A CR: N/A
102	7.2.2.a	LE-102-3	11.5	90487	AP119-1 / EE-00239			SR: N/A CR: N/A
102	7.2.2.a	LI-102-1	11.5	90487	AP119-2 / EE-00921		422", 6"	SR: N/A CR: N/A
102	7.2.2.a	LE-102-2		90487	AP111-1 / EE-00198	419"		SR: N/A CR: N/A
102	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
102	7.2.2.a	LA-102-1		90487	AP111-2 / EE-01086			SR: N/A CR: N/A
102	7.2.2.a	LXA-102-1		90487	AP111-3 / EE-01042			SR: N/A CR: N/A
102	7.2.5.a	DPI-102-1		90514	AP074-1 / EE-02057		5", -6"	SR: N/A CR: N/A
102	7.2.5.a	PT-102-1		90487	AP002-2 / EE-00639		5", -6"	SR: N/A CR: N/A
102	7.2.5.a	PR-102-1		90487	AP002-4 / EE-00521			SR: N/A CR: N/A
102	7.2.5.a	PAS-102-1		90487	AP002-6 / EE-00656	-0.25"		SR: N/A CR: N/A
102	7.2.5.a	PA-102-1		90487	AP002-8 / EE-01102			SR: N/A CR: N/A
102	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
102	7.2.5.a	FI-102-1		90487	AP002-1 / EE-01958			SR: N/A CR: N/A
102	7.2.5.a	CVT-102		90487				SR: N/A CR: N/A
102	7.2.5.a	PT-102-2		90487	AP002-3 / EE-00629		5", -6"	SR: N/A CR: N/A
102	7.2.5.a	PR-102-2		90487	AP002-5 / EE-00515			SR: N/A CR: N/A
102	7.2.5.a	PAS-102-2		90487	AP002-7 / EE-00651	-5"		SR: N/A CR: N/A
102	7.2.5.a	PA-102-2		90487	AP002-9 / EE-01015			SR: N/A CR: N/A
102	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 10 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.5.b	HORN		90487				SR: N/A CR: N/A
102	7.2.5.b	HORN	11.6	90487				SR: N/A CR: N/A
102	7.2.5.b	PT-102-1	11.6	90487	AP002-2 / EE-00639		5", -6"	SR: N/A CR: ANNUALLY
102	7.2.5.b	PR-102-1	11.6	90487	AP002-4 / EE-00521			SR: N/A CR: ANNUALLY
102	7.2.5.b	PAS-102-1	11.6	90487	AP002-6 / EE-00656	-0.25"		SR: CONT CR: ANNUALLY
102	7.2.5.b	PA-102-1	11.6	90487	AP002-8 / EE-01102			SR: N/A CR: ANNUALLY
102	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
102	7.2.5.b	FI-102-1	11.6	90487	AP002-1 / EE-01958			SR: N/A CR: N/A
102	7.2.5.b	CVT-102	11.6	90487				SR: N/A CR: ANNUALLY
102	7.2.5.b	PT-102-2	11.6	90487	AP002-3 / EE-00629		5", -6"	SR: N/A CR: ANNUALLY
102	7.2.5.b	PR-102-2	11.6	90487	AP002-5 / EE-00515			SR: N/A CR: ANNUALLY
102	7.2.5.b	PAS-102-2	11.6	90487	AP002-7 / EE-00651	-5"		SR: CONT CR: ANNUALLY
102	7.2.5.b	PA-102-2	11.6	90487	AP002-9 / EE-01015			SR: N/A CR: ANNUALLY
102	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
102	7.2.5.b	DPI-102-1	11.6	90514	AP074-1 / EE-02057		5", -6"	SR: N/A CR: N/A
102	7.2.5.c	PT-102-1	11.6	90487	AP002-2 / EE-00639			SR: N/A CR: N/A
102	7.2.5.c	PR-102-1	11.6	90487	AP002-4 / EE-00521			SR: CONT CR: N/A
102	7.2.5.c	FI-102-1	11.6	90487	AP002-1 / EE-01958			SR: N/A CR: N/A
102	7.2.5.c	CVT-102	11.6	90487				SR: N/A CR: N/A
102	7.2.5.c	PT-102-2	11.6	90487	AP002-3 / EE-00629			SR: N/A CR: N/A
102	7.2.5.c	PR-102-2	11.6	90487	AP002-5 / EE-00515			SR: CONT CR: N/A
102	7.2.5.c (d)	DPI-102-2		90514	AP075-1 / EE-02062			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 11 F of 22 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.5.c (d)	PT-102-1		90487	AP002-2 / EE-00639		5", -6"	SR: N/A CR: N/A
102	7.2.5.c (d)	PR-102-1		90487	AP002-4 / EE-00521			SR: N/A CR: N/A
102	7.2.5.c (d)	FI-102-1		90487	AP002-1 / EE-01958			SR: N/A CR: N/A
102	7.2.5.c (d)	CVT-102		90487				SR: N/A CR: N/A
102	7.2.5.c (d)	PT-102-2		90487	AP002-3 / EE-00629		5", -6"	SR: N/A CR: N/A
102	7.2.5.c (d)	PR-102-2		90487	AP002-5 / EE-00515			SR: N/A CR: N/A
102	7.2.5.c (d)	DPI-102-1		90514	AP074-1 / EE-02057		5", -6"	SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-36		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-37		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-38		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-39		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-40		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-41		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-42		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-43		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-44		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-45		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-46		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-47		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-48		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-49		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-50		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 12 F of 22 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.6 (a,b,c)	TE-102-51		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-52		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-53		90487				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	MUX-102-1		90489				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		212° F	SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-27		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-28		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-29		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-30		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-31		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-32		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-33		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-34		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-35		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-54		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-55		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-56		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-57		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-58		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-59		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-60		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-61		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 13 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.7 (a,b,c)	TE-102-62		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-63		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-64		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-65		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-66		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-67		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-68		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-69		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-70		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-71		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-72		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-73		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-74		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-75		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-76		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-77		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-78		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-79		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-80		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-81		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-82		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-83		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 14 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.7 (a,b,c)	TE-102-84		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-85		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-86		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-87		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-88		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-89		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-90		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-91		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-92		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-93		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-94		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-95		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-96		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-97		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-98		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-99		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-100		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-101		90487				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	MUX-102-1		90489				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	MUX-102-2		90489				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		236° F	SR: N/A CR: N/A
102	7.2.9	LDE-102-2	11.4	90487	AP128-1 / EE-00966			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 15 F of 22 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.9	LDI-102-2	11.4	90487	AP128-2 / EE-00169			SR: CONT CR: QUARTERLY
102	7.2.9	LDK-102-2	11.4	90487	AP128-5			SR: N/A CR: QUARTERLY
102	7.2.9	LDIL-102-2	11.4	90487	AP128-6			SR: N/A CR: QUARTERLY
102	7.2.9	LDA-102-1	11.4	90487	AP128-4 / EE-01082			SR: N/A CR: MONTHLY
102	7.2.9	LDE-102-3	11.4	90487	AP129-1 / EE-00965			SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-3	11.4	90487	AP129-2 / EE-00137			SR: CONT CR: QUARTERLY
102	7.2.9	LDK-102-3	11.4	90487	AP129-4			SR: N/A CR: QUARTERLY
102	7.2.9	LDIL-102-3	11.4	90487	AP129-5			SR: N/A CR: QUARTERLY
102	7.2.9	LDE-102-4	11.4	90487	AP130-1 / EE-00964			SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-4	11.4	90487	AP130-2 / EE-00122			SR: CONT CR: QUARTERLY
102	7.2.9	LDK-102-4	11.4	90487	AP130-4			SR: N/A CR: QUARTERLY
102	7.2.9	LDIL-102-4	11.4	90487	AP130-5			SR: N/A CR: QUARTERLY
102	7.2.9	CAM-102-AP-1	11.4	90488	YAP05-1 / EE-00944			SR: CONT CR: MONTHLY
102	7.2.9	CVT-102-AP-1	11.4	90488	AP016-2 / EE-00373			SR: N/A CR: SEMI-ANN
102	7.2.9	RR-102-AP-1	11.4	90488	AP016-3 / EE-00511			SR: N/A CR: SEMI-ANN
102	7.2.9	RA-102-AP-1	11.4	90488	AP016-7 / EE-01106			SR: N/A CR: MONTHLY
102	7.2.9	RA-102-AP-2	11.4	90488	AP016-6 / EE-01005			SR: N/A CR: MONTHLY
102	7.2.9	RA-102-AP-3	11.4	90488	AP016-4 / EE-01112			SR: N/A CR: MONTHLY
102	7.2.9	RA-102-AP-4	11.4	90488	AP016-5 / EE-01113			SR: N/A CR: MONTHLY
102	7.2.9	RXA-102-AP-1	11.4	90488	AP015-8 / EE-01049			SR: N/A CR: MONTHLY
102	7.2.9	RXA-102-AP-2	11.4	90488	AP015-9 / EE-01117			SR: N/A CR: MONTHLY
102	7.3.1.A.1	DPIS-7		90514	AP071-2 / EE-00472		≤ 5.9"	SR: DAILY CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 16F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.3.1.A.1	DPA-K2-7		90514	AP071-3 / EE-01120			SR: N/A CR: N/A
102	7.3.1.B	TI-10		90514	AP070-5 / EE-02023		$\leq 230^{\circ} \text{ F}$	SR: DAILY CR: N/A
102	7.3.1.D	TI-9		90514	AP070-4 / EE-02031			SR: DAILY CR: N/A
102	7.3.1.D	TI-10		90514	AP070-5 / EE-02023			SR: DAILY CR: N/A
102	7.3.1.D	TC-1		90514	AP070-1 / EE-00858		$\Delta T \geq 5^{\circ} \text{ F}$	SR: N/A CR: N/A
102	7.3.1.D	TA-1		90514	AP070-6 / EE-01041			SR: N/A CR: N/A
102	7.3.1.D	TA-K2-1		90514	AP070-7 / EE-01124			SR: N/A CR: N/A
102	31.2.2.2	LDE-102-2		90487	AP128-1 / EE-00966	1/8"+3/8-1/8"		SR: N/A CR: N/A
102	31.2.2.2	LDE-102-3		90487	AP129-1 / EE-00965	1/8"+3/8-1/8"		SR: N/A CR: N/A
102	31.2.2.2	LDE-102-4		90487	AP130-1 / EE-00964	1/8"+3/8-1/8"		SR: N/A CR: N/A
102	31.2.2.2	LDA-102-1		90487	AP128-4 / EE-01082			SR: CONT CR: N/A
102	31.2.2.2	CAM-102-AP-1		90488	YAP05-1 / EE-00944			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 17 of 27

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.2.a	LE-103-1	11.5	90487	AP104-1 / EE-00348			SR: N/A CR: N/A
103	7.2.2.a	LIT-103-1	11.5	90487	AP104-2 / EE-00790		422", 6"	SR: CONT CR: N/A
103	7.2.2.a	LE-103-3	11.5	90487	AP120-1 / EE-00213			SR: N/A CR: N/A
103	7.2.2.a	LI-103-1	11.5	90487	AP120-2 / EE-00329		422", 6"	SR: CONT CR: N/A
103	7.2.2.a	LE-103-2		90487	AP112-1 / EE-00231	419"		SR: N/A CR: N/A
103	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
103	7.2.2.a	LA-103-1		90487	AP112-2 / EE-01141			SR: N/A CR: N/A
103	7.2.2.a	LXA-103-1		90487	AP112-3 / EE-01154			SR: N/A CR: N/A
103	7.2.5.a	DPI-103-1		90514	AP078-1 / EE-02060		5", -6"	SR: N/A CR: N/A
103	7.2.5.a	PT-103-1		90487	AP003-2 / EE-00644		5", -6"	SR: N/A CR: N/A
103	7.2.5.a	PR-103-1		90487	AP003-4 / EE-00503			SR: N/A CR: N/A
103	7.2.5.a	PAS-103-1		90487	AP003-6 / EE-00652	-0.25"		SR: N/A CR: N/A
103	7.2.5.a	PA-103-1		90487	AP003-8 / EE-01031			SR: N/A CR: N/A
103	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
103	7.2.5.a	FI-103-1		90487	AP003-1 / EE-01952			SR: N/A CR: N/A
103	7.2.5.a	CVT-103		90487				SR: N/A CR: N/A
103	7.2.5.a	PT-103-2		90487	AP003-3 / EE-00638		5", -6"	SR: N/A CR: N/A
103	7.2.5.a	PR-103-2		90487	AP003-5 / EE-00522			SR: N/A CR: N/A
103	7.2.5.a	PAS-103-2		90487	AP003-7 / EE-00657	-5"		SR: N/A CR: N/A
103	7.2.5.a	PA-103-2		90487	AP003-9 / EE-01103			SR: N/A CR: N/A
103	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A
103	7.2.5.a	HORN		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 18 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
103	7.2.5.b	PT-103-1	11.6	90487	AP003-2 / EE-00644		5", -6"	SR: N/A CR: ANNUALLY
103	7.2.5.b	PR-103-1	11.6	90487	AP003-4 / EE-00503			SR: N/A CR: ANNUALLY
103	7.2.5.b	PAS-103-1	11.6	90487	AP003-6 / EE-00652	-0.25"		SR: CONT CR: ANNUALLY
103	7.2.5.b	PA-103-1	11.6	90487	AP003-8 / EE-01031			SR: N/A CR: ANNUALLY
103	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
103	7.2.5.b	FI-103-1	11.6	90487	AP003-1 / EE-01952			SR: N/A CR: N/A
103	7.2.5.b	CVT-103	11.6	90487				SR: N/A CR: ANNUALLY
103	7.2.5.b	PT-103-2	11.6	90487	AP003-3 / EE-00638		5", -6"	SR: N/A CR: ANNUALLY
103	7.2.5.b	PR-103-2	11.6	90487	AP003-5 / EE-00522			SR: N/A CR: ANNUALLY
103	7.2.5.b	PAS-103-2	11.6	90487	AP003-7 / EE-00657	-5"		SR: CONT CR: ANNUALLY
103	7.2.5.b	PA-103-2	11.6	90487	AP003-9 / EE-01103			SR: N/A CR: ANNUALLY
103	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
103	7.2.5.b	DPI-103-1	11.6	90487	AP078-1 / EE-02060		5", -6"	SR: N/A CR: N/A
103	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
103	7.2.5.c	PT-103-1	11.6	90487	AP003-2 / EE-00644			SR: N/A CR: N/A
103	7.2.5.c	PR-103-1	11.6	90487	AP003-4 / EE-00503			SR: CONT CR: N/A
103	7.2.5.c	FI-103-1	11.6	90487	AP003-1 / EE-01952			SR: N/A CR: N/A
103	7.2.5.c	CVT-103	11.6	90487				SR: N/A CR: N/A
103	7.2.5.c	PT-103-2	11.6	90487	AP003-3 / EE-00638			SR: N/A CR: N/A
103	7.2.5.c	PR-103-2	11.6	90487	AP003-5 / EE-00522			SR: CONT CR: N/A
103	7.2.5.c (d)	DPI-103-2		90514	AP079-2 / EE-02058			SR: N/A CR: N/A
103	7.2.5.c (d)	DPI-103-1		90514	AP078-1 / EE-02060		5", -6"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 19 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.5.c (d)	PT-103-1		90487	AP003-2 / EE-00644		5" -6"	SR: N/A CR: N/A
103	7.2.5.c (d)	PR-103-1		90487	AP003-4 / EE-00503			SR: N/A CR: N/A
103	7.2.5.c (d)	FI-103-1		90487	AP003-1 / EE-01952			SR: N/A CR: N/A
103	7.2.5.c (d)	CVT-103		90487				SR: N/A CR: N/A
103	7.2.5.c (d)	PT-103-2		90487	AP003-3 / EE-00638		5" -6"	SR: N/A CR: N/A
103	7.2.5.c (d)	PR-103-2		90487	AP003-5 / EE-00522			SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-36		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-37		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-38		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-39		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-40		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-41		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-42		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-43		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-44		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-45		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-46		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-47		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-48		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-49		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-50		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-51		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 20 of 24

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.6 (a,b,c)	TE-103-52		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-53		90487				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	MUX-103-1		90489				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		212° F	SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-27		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-28		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-29		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-30		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-31		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-32		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-33		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-34		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-35		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-54		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-55		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-56		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-57		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-58		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-59		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-60		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-61		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-62		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 21 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.7 (a,b,c)	TE-103-63		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-64		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-65		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-66		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-67		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-68		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-69		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-70		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-71		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-72		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-73		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-74		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-75		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-76		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-77		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-78		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-79		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-80		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-81		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-82		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-83		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-84		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 22 of 24

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.7 (a,b,c)	TE-103-85		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-86		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-87		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-88		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-89		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-90		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-91		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-92		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-93		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-94		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-95		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-96		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-97		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-98		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-99		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-100		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-101		90487				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	MUX-103-1		90489				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	MUX-103-2		90489				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		236° F	SR: N/A CR: N/A
103	7.2.9	LDE-103-2	11.4	90487	AP131-1 / EE-00963			SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-2	11.4	90487	AP131-2 / EE-00151			SR: CONT CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 23 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.9	LDK-103-2	11.4	90487	AP131-5			SR: N/A CR: QUARTERLY
103	7.2.9	LDIL-103-2	11.4	90487	AP131-6			SR: N/A CR: QUARTERLY
103	7.2.9	LDA-103-1	11.4	90487	AP131-4 / EE-00186			SR: N/A CR: MONTHLY
103	7.2.9	LDE-103-3	11.4	90487	AP132-1 / EE-00962			SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-3	11.4	90487	AP132-2 / EE-00170			SR: CONT CR: QUARTERLY
103	7.2.9	LDK-103-3	11.4	90487	AP132-4			SR: N/A CR: QUARTERLY
103	7.2.9	LDIL-103-3	11.4	90487	AP132-5			SR: N/A CR: QUARTERLY
103	7.2.9	LDE-103-4	11.4	90487	AP133-1 / EE-00977			SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-4	11.4	90487	AP133-2 / EE-00126			SR: CONT CR: QUARTERLY
103	7.2.9	LDK-103-4	11.4	90487	AP133-4			SR: N/A CR: QUARTERLY
103	7.2.9	LDIL-103-4	11.4	90487	AP133-5			SR: N/A CR: QUARTERLY
103	7.2.9	CAM-103-AP-1	11.4	90488	YAP06-1 / EE-00934			SR: CONT CR: MONTHLY
103	7.2.9	CVT-103-AP-1	11.4	90488	AP017-2 / EE-00379			SR: N/A CR: SEMI-ANN
103	7.2.9	RR-103-AP-1	11.4	90488	AP017-3 / EE-00533			SR: N/A CR: SEMI-ANN
103	7.2.9	RA-103-AP-1	11.4	90488	AP017-7 / EE-01263			SR: N/A CR: MONTHLY
103	7.2.9	RA-103-AP-2	11.4	90488	AP017-6 / EE-01251			SR: N/A CR: MONTHLY
103	7.2.9	RA-103-AP-3	11.4	90488	AP017-4 / EE-01196			SR: N/A CR: MONTHLY
103	7.2.9	RA-103-AP-4	11.4	90488	AP017-5 / EE-01180			SR: N/A CR: MONTHLY
103	7.2.9	RXA-103-AP-1	11.4	90488	AP017-8 / EE-01202			SR: N/A CR: MONTHLY
103	7.2.9	RXA-103-AP-2	11.4	90488	AP017-9 / EE-01258			SR: N/A CR: MONTHLY
103	7.3.1.A.1	DPIS-8		90514	AP077-2 / EE-00478		≤ 5.9"	SR: DAILY CR: N/A
103	7.3.1.A.1	DPA-K2-8		90514	AP077-3 / EE-01264			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 24F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
103	7.3.1.B	TI-12		90514	AP076-5 / EE-02024		$\leq 230^{\circ} \text{ F}$	SR: DAILY CR: N/A
103	7.3.1.D	TI-11		90514	AP076-4 / EE-02020			SR: DAILY CR: N/A
103	7.3.1.D	TI-12		90514	AP076-5 / EE-02024			SR: DAILY CR: N/A
103	7.3.1.D	TC-2		90514	AP076-1 / EE-00859		$\Delta T \geq 5^{\circ} \text{ F}$	SR: N/A CR: N/A
103	7.3.1.D	TA-2		90514	AP076-6 / EE-01037			SR: N/A CR: N/A
103	7.3.1.D	TA-K2-2		90514	AP076-7 / EE-01167			SR: N/A CR: N/A
103	31.2.2.2	LDE-103-2		90487	AP131-1 / EE-00963	1/8"+3/8-1/8"		SR: N/A CR: N/A
103	31.2.2.2	LDE-103-3		90487	AP132-1 / EE-00962	1/8"+3/8-1/8"		SR: N/A CR: N/A
103	31.2.2.2	LDE-103-4		90487	AP133-1 / EE-00977	1/8"+3/8-1/8"		SR: N/A CR: N/A
103	31.2.2.2	LDA-103-1		90487	AP131-4 / EE-00186			SR: CONT CR: N/A
103	31.2.2.2	CAM-103-AP-1		90488	YAP06-1 / EE-00934			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 25 of 25

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
03C LDP	7.2.2.b	FI-03C-1		90487	AP031-1 / EE-01951			SR: N/A CR: N/A
03C LDP	7.2.2.b	FI-03C-2		90487	AP031-3 / EE-01953			SR: N/A CR: N/A
03C LDP	7.2.2.b	FI-03C-3		90487	AP031-5 / EE-01945			SR: N/A CR: N/A
03C LDP	7.2.2.b	WFT-03C-1		90487	AP031-2 / EE-00627			SR: N/A CR: N/A
03C LDP	7.2.2.b	SGT-03C-1		90487	AP031-4 / EE-00631			SR: N/A CR: N/A
03C LDP	7.2.2.b	LY-03C-1		90487	AP031-A / EE-01344			SR: N/A CR: N/A
03C LDP	7.2.2.b	LI-03C-2		90487	AP031-C / EE-01429		≤ 55"	SR: N/A CR: N/A
03C LDP	7.2.2.b	LAS-03C-1		90487	AP031-D / EE-00660	36"		SR: N/A CR: N/A
03C LDP	7.2.2.b	LI-03C-1		90487	AP031-B / EE-00539		≤ 55"	SR: N/A CR: N/A
03C LDP	7.2.2.b	LA-03C-1		90487	AP031-E / EE-01184			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 26 of 22F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.2.a	LE-104-1	11.5	90487	AP105-1 / EE-00345			SR: N/A CR: N/A
104	7.2.2.a	LIT-104-1	11.5	90487	AP105-2 / EE-00791		422", 6"	SR: CONT CR: N/A
104	7.2.2.a	LE-104-3	11.5	90487	AP121-1 / EE-00268			SR: N/A CR: N/A
104	7.2.2.a	LI-104-1	11.5	90487	AP121-2 / EE-00330		422", 6"	SR: CONT CR: N/A
104	7.2.2.a	LE-104-2		90487	AP113-1 / EE-00262	419"		SR: N/A CR: N/A
104	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
104	7.2.2.a	LA-104-1		90487	AP113-2 / EE-01227			SR: N/A CR: N/A
104	7.2.2.a	LXA-104-1		90487	AP113-3 / EE-01269			SR: N/A CR: N/A
104	7.2.5.a	DPI-104-1		90514	AP080-1 / EE-02042		5", -6"	SR: N/A CR: N/A
104	7.2.5.a	PT-104-1		90487	AP004-2 / EE-00634		5", -6"	SR: N/A CR: N/A
104	7.2.5.a	PR-104-1		90487	AP004-4 / EE-00508			SR: N/A CR: N/A
104	7.2.5.a	PAS-104-1		90487	AP004-6 / EE-00662	-0.25"		SR: N/A CR: N/A
104	7.2.5.a	PA-104-1		90487	AP004-8 / EE-01162			SR: N/A CR: N/A
104	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
104	7.2.5.a	CVT-104		90487				SR: N/A CR: N/A
104	7.2.5.a	FI-104-1		90487	AP004-1 / EE-01944			SR: N/A CR: N/A
104	7.2.5.a	PT-104-2		90487	AP004-3 / EE-00635		5", -6"	SR: N/A CR: N/A
104	7.2.5.a	PR-104-2		90487	AP004-5 / EE-00524			SR: N/A CR: N/A
104	7.2.5.a	PAS-104-2		90487	AP004-7 / EE-00661	-5"		SR: N/A CR: N/A
104	7.2.5.a	PA-104-2		90487	AP004-9 / EE-01173			SR: N/A CR: N/A
104	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 27 of 27

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.5.a	HORN		90487				SR: N/A CR: N/A
104	7.2.5.b	PT-104-1	11.6	90487	AP004-2 / EE-00634		5", -6"	SR: N/A CR: ANNUALLY
104	7.2.5.b	PR-104-1	11.6	90487	AP004-4 / EE-00508			SR: N/A CR: ANNUALLY
104	7.2.5.b	PAS-104-1	11.6	90487	AP004-6 / EE-00662	-0.25"		SR: CONT CR: ANNUALLY
104	7.2.5.b	PA-104-1	11.6	90487	AP004-8 / EE-01162			SR: N/A CR: ANNUALLY
104	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
104	7.2.5.b	CVT-104	11.6	90487				SR: N/A CR: ANNUALLY
104	7.2.5.b	FI-104-1	11.6	90487	AP004-1 / EE-01944			SR: N/A CR: N/A
104	7.2.5.b	PT-104-2	11.6	90487	AP004-3 / EE-00635		5", -6"	SR: N/A CR: ANNUALLY
104	7.2.5.b	PR-104-2	11.6	90487	AP004-5 / EE-00524			SR: N/A CR: ANNUALLY
104	7.2.5.b	PAS-104-2	11.6	90487	AP004-7 / EE-00661	-5"		SR: CONT CR: ANNUALLY
104	7.2.5.b	PA-104-2	11.6	90487	AP004-9 / EE-01173			SR: N/A CR: ANNUALLY
104	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
104	7.2.5.b	DPI-104-1	11.6	90487	AP080-1 / EE-02042		5", -6"	SR: N/A CR: N/A
104	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
104	7.2.5.c	PT-104-1	11.6	90487	AP004-2 / EE-00634			SR: N/A CR: N/A
104	7.2.5.c	PR-104-1	11.6	90487	AP004-4 / EE-00508			SR: CONT CR: N/A
104	7.2.5.c	CVT-104	11.6	90487				SR: N/A CR: N/A
104	7.2.5.c	FI-104-1	11.6	90487	AP004-1 / EE-01944			SR: N/A CR: N/A
104	7.2.5.c	PT-104-2	11.6	90487	AP004-3 / EE-00635			SR: N/A CR: N/A
104	7.2.5.c	PR-104-2	11.6	90487	AP004-5 / EE-00524			SR: CONT CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 20 of 24

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.5.c (d)	DPI-104-2		90514	AP081-2 / EE-02047			SR: N/A CR: N/A
104	7.2.5.c (d)	DPI-104-1		90514	AP080-1 / EE-02042		5", -6"	SR: N/A CR: N/A
104	7.2.5.c (d)	PT-104-1		90487	AP004-2 / EE-00634		5", -6"	SR: N/A CR: N/A
104	7.2.5.c (d)	PR-104-1		90487	AP004-4 / EE-00508			SR: N/A CR: N/A
104	7.2.5.c (d)	CVT-104		90487				SR: N/A CR: N/A
104	7.2.5.c (d)	FI-104-1		90487	AP004-1 / EE-01944			SR: N/A CR: N/A
104	7.2.5.c (d)	PT-104-2		90487	AP004-3 / EE-00635		5", -6"	SR: N/A CR: N/A
104	7.2.5.c (d)	PR-104-2		90487	AP004-5 / EE-00524			SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-36		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-37		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-38		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-39		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-40		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-41		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-42		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-43		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-44		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-45		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-46		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-47		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-48		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-49		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 21 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.6 (a,b,c)	TE-104-50		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-51		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-52		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-53		90487				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	MUX-104-1		90489				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		212° F	SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-27		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-28		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-29		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-30		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-31		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-32		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-33		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-34		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-35		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-54		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-55		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-56		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-57		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-58		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-59		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-60		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 30 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.7 (a,b,c)	TE-104-61		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-62		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-63		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-64		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-65		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-66		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-67		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-68		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-69		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-70		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-71		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-72		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-73		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-74		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-75		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-76		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-77		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-78		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-79		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-80		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-81		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-82		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 1F of 2F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.7 (a,b,c)	TE-104-83		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-84		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-85		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-86		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-87		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-88		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-89		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-90		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-91		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-92		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-93		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-94		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-95		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-96		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-97		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-98		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-99		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-100		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-101		90487				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	MUX-104-1		90489				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	MUX-104-2		90489				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TDS-AP-1		90489	AP210-1 / EE-01311		236° F	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 22 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.9	LDE-104-2	11.4	90487	AP134-1 / EE-00961			SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-2	11.4	90487	AP134-2 / EE-00130			SR: CONT CR: QUARTERLY
104	7.2.9	LDK-104-2	11.4	90487	AP134-5			SR: N/A CR: QUARTERLY
104	7.2.9	LDIL-104-2	11.4	90487	AP134-6			SR: N/A CR: QUARTERLY
104	7.2.9	LDA-104-1	11.4	90487	AP134-4 / EE-01069			SR: N/A CR: MONTHLY
104	7.2.9	LDE-104-3	11.4	90487	AP135-1 / EE-00960			SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-3	11.4	90487	AP135-2 / EE-00163			SR: CONT CR: QUARTERLY
104	7.2.9	LDK-104-3	11.4	90487	AP135-4			SR: N/A CR: QUARTERLY
104	7.2.9	LDIL-104-3	11.4	90487	AP135-5			SR: N/A CR: QUARTERLY
104	7.2.9	LDE-104-4	11.4	90487	AP136-1 / EE-00959			SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-4	11.4	90487	AP136-2 / EE-00191			SR: N/A CR: QUARTERLY
104	7.2.9	LDK-104-4	11.4	90487	AP136-4			SR: N/A CR: QUARTERLY
104	7.2.9	LDIL-104-4	11.4	90487	AP136-5			SR: N/A CR: QUARTERLY
104	7.2.9	CAM-104-AP-1	11.4	90488	YAP07-1 / EE-00943			SR: CONT CR: MONTHLY
104	7.2.9	CVT-104-AP-1	11.4	90488	AP018-2 / EE-00375			SR: N/A CR: SEMI-ANN
104	7.2.9	RR-104-AP-1	11.4	90488	AP018-3 / EE-00523			SR: N/A CR: SEMI-ANN
104	7.2.9	RA-104-AP-1	11.4	90488	AP018-7 / EE-01187			SR: N/A CR: MONTHLY
104	7.2.9	RA-104-AP-2	11.4	90488	AP018-6 / EE-01054			SR: N/A CR: MONTHLY
104	7.2.9	RA-104-AP-3	11.4	90488	AP018-4 / EE-01002			SR: N/A CR: MONTHLY
104	7.2.9	RA-104-AP-4	11.4	90488	AP018-5 / EE-01126			SR: N/A CR: MONTHLY
104	7.2.9	RXA-104-AP-1	11.4	90488	AP018-8 / EE-01175			SR: N/A CR: MONTHLY
104	7.2.9	RXA-104-AP-2	11.4	90488	AP018-9 / EE-01177			SR: N/A CR: MONTHLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 33F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.3.1.A.1	DPIS-8		90514	AP077-2 / EE-00478		≤ 5.9"	SR: DAILY CR: N/A
104	7.3.1.A.1	DPA-K2-8		90514	AP077-3 / EE-01264			SR: N/A CR: N/A
104	7.3.1.B	TI-12		90514	AP076-5 / EE-02024		≤ 230° F	SR: DAILY CR: N/A
104	7.3.1.D	TI-11		90514	AP076-4 / EE-02020			SR: DAILY CR: N/A
104	7.3.1.D	TI-12		90514	AP076-5 / EE-02024			SR: DAILY CR: N/A
104	7.3.1.D	TC-2		90514	AP076-1 / EE-00859		ΔT ≥ 5° F	SR: N/A CR: N/A
104	7.3.1.D	TA-2		90514	AP076-6 / EE-01037			SR: N/A CR: N/A
104	7.3.1.D	TA-K2-2		90514	AP076-7 / EE-01167			SR: N/A CR: N/A
104	31.2.2.2	LDE-104-2		90487	AP134-1 / EE-00961	1/8"+3/8-1/8"		SR: N/A CR: N/A
104	31.2.2.2	LDE-104-3		90487	AP135-1 / EE-00960	1/8"+3/8-1/8"		SR: N/A CR: N/A
104	31.2.2.2	LDE-104-4		90487	AP136-1 / EE-00959	1/8"+3/8-1/8"		SR: N/A CR: N/A
104	31.2.2.2	LDA-104-1		94087	AP134-4 / EE-01069			SR: CONT CR: N/A
104	31.2.2.2	CAM-104-AP-1		90488	YAP07-1 / EE-00943			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 34F of 22F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.2.a	LE-105-1	11.5	90487	AP106-1 / EE-00346			SR: N/A CR: N/A
105	7.2.2.a	LIT-105-1	11.5	90487	AP106-2 / EE-00788		422", 6"	SR: N/A CR: N/A
105	7.2.2.a	LE-105-3	11.5	90487	AP112-1 / EE-00261			SR: N/A CR: N/A
105	7.2.2.a	LI-105-1	11.5	90487	AP122-2 / EE-00331		422", 6"	SR: N/A CR: N/A
105	7.2.2.a	LE-105-2		90487	AP114-1 / EE-00229	419"		SR: N/A CR: N/A
105	7.2.2.a	LDK-ENCLOSURE		90487				SR: N/A CR: N/A
105	7.2.2.a	LA-105-1		90487	AP114-2 / EE-01209			SR: N/A CR: N/A
105	7.2.2.a	LXA-105-1		90487	AP114-3 / EE-01233			SR: N/A CR: N/A
105	7.2.5.a	DPI-105-1		90514	AP087-1 / EE-02063		5", -6"	SR: N/A CR: N/A
105	7.2.5.a	PT-105-1		90487	AP005-2 / EE-00640		5", -6"	SR: N/A CR: N/A
105	7.2.5.a	PR-105-1		90487	AP005-4 / EE-00512			SR: N/A CR: N/A
105	7.2.5.a	PAS-105-1		90487	AP005-6 / EE-00650	-0.25"		SR: N/A CR: N/A
105	7.2.5.a	PA-105-1		90487	AP005-8 / EE-01012			SR: N/A CR: N/A
105	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
105	7.2.5.a	CVT-105		90487				SR: N/A CR: N/A
105	7.2.5.a	FI-105-1		90487	AP005-1 / EE-01961			SR: N/A CR: N/A
105	7.2.5.a	PT-105-2		90487	AP005-3 / EE-00633		5", -6"	SR: N/A CR: N/A
105	7.2.5.a	PR-105-2		90487	AP005-5 / EE-00520			SR: N/A CR: N/A
105	7.2.5.a	PAS-105-2		90487	AP005-7 / EE-00655	-5"		SR: N/A CR: N/A
105	7.2.5.a	PA-105-2		90487	AP005-9 / EE-01095			SR: N/A CR: N/A
105	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 55 of 75

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.5.a	HORN		90487				SR: N/A CR: N/A
105	7.2.5.b	PT-105-1	11.6	90487	AP005-2 / EE-00640		5", -6"	SR: N/A CR: ANNUALLY
105	7.2.5.b	PR-105-1	11.6	90487	AP005-4 / EE-00512			SR: N/A CR: ANNUALLY
105	7.2.5.b	PAS-105-1	11.6	90487	AP005-6 / EE-00650	-0.25"		SR: CONT CR: ANNUALLY
105	7.2.5.b	PA-105-1	11.6	90487	AP005-8 / EE-01012			SR: N/A CR: ANNUALLY
105	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
105	7.2.5.b	CVT-105	11.6	90487				SR: N/A CR: ANNUALLY
105	7.2.5.b	FI-105-1	11.6	90487	AP005-1 / EE-01961			SR: N/A CR: N/A
105	7.2.5.b	PT-105-2	11.6	90487	AP005-3 / EE-00633		5", -6"	SR: N/A CR: ANNUALLY
105	7.2.5.b	PR-105-2	11.6	90487	AP005-5 / EE-00520			SR: N/A CR: ANNUALLY
105	7.2.5.b	PAS-105-2	11.6	90487	AP005-7 / EE-00655	-5"		SR: CONT CR: ANNUALLY
105	7.2.5.b	PA-105-2	11.6	90487	AP005-9 / EE-01095			SR: N/A CR: ANNUALLY
105	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
105	7.2.5.b	DPI-105-1	11.6	90514	AP087-1 / EE-02063		5", -6"	SR: N/A CR: N/A
105	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
105	7.2.5.c	PT-105-1	11.6	90487	AP005-2 / EE-00640			SR: N/A CR: N/A
105	7.2.5.c	PR-105-1	11.6	90487	AP005-4 / EE-00512			SR: CONT CR: N/A
105	7.2.5.c	CVT-105	11.6	90487				SR: N/A CR: N/A
105	7.2.5.c	FI-105-1	11.6	90487	AP005-1 / EE-01961			SR: N/A CR: N/A
105	7.2.5.c	PT-105-2	11.6	90487	AP005-3 / EE-00633			SR: N/A CR: N/A
105	7.2.5.c	PR-105-2	11.6	90487	AP005-5 / EE-00520			SR: CONT CR: N/A
105	7.2.5.c (d)	DPI-105-2		90514	AP086-2 / EE-02052			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 6 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.5.c (d)	DPI-105-1		90514	AP087-1 / EE-02063		5", -6"	SR: N/A CR: N/A
105	7.2.5.c (d)	PT-105-1		90487	AP005-2 / EE-00640		5", -6"	SR: N/A CR: N/A
105	7.2.5.c (d)	PR-105-1		90487	AP005-4 / EE-00512			SR: N/A CR: N/A
105	7.2.5.c (d)	CVT-105		90487				SR: N/A CR: N/A
105	7.2.5.c (d)	FI-105-1		90487	AP005-1 / EE-01961			SR: N/A CR: N/A
105	7.2.5.c (d)	PT-105-2		90487	AP005-3 / EE-00633		5", -6"	SR: N/A CR: N/A
105	7.2.5.c (d)	PR-105-2		90487	AP005-5 / EE-00520			SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-36		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-37		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-38		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-39		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-40		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-41		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-42		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-43		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-44		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-45		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-46		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-47		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-48		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-49		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-50		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 7F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.6 (a,b,c)	TE-105-51		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-52		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-53		90487				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	MUX-105-1		90489				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		212° F	SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-27		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-28		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-29		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-30		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-31		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-32		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-33		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-34		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-35		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-54		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-55		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-56		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-57		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-58		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-59		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-60		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-61		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 3 of 24

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.7 (a,b,c)	TE-105-62		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-63		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-64		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-65		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-66		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-67		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-68		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-69		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-70		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-71		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-72		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-73		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-74		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-75		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-76		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-77		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-78		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-79		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-80		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-81		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-82		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-83		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 3 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.7 (a,b,c)	TE-105-84		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-85		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-86		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-87		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-88		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-89		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-90		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-91		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-92		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-93		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-94		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-95		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-96		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-97		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-98		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-99		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-100		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-101		90487				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	MUX-105-1		90489				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	MUX-105-2		90489				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		236° F	SR: N/A CR: N/A
105	7.2.9	LDE-105-2	11.4	90487	AP137-1 / EE-00958			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 40 of 42

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.9	LDI-105-2	11.4	90487	AP137-2 / EE-00174			SR: CONT CR: QUARTERLY
105	7.2.9	LDK-105-2	11.4	90487	AP137-5			SR: N/A CR: QUARTERLY
105	7.2.9	LDIL-105-2	11.4	90487	AP137-6			SR: N/A CR: QUARTERLY
105	7.2.9	LDA-105-1	11.4	90487	AP137-4 / EE-00121			SR: N/A CR: MONTHLY
105	7.2.9	LDE-105-3	11.4	90487	AP138-1 / EE-00957			SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-3	11.4	90487	AP138-2 / EE-00131			SR: CONT CR: QUARTERLY
105	7.2.9	LDK-105-3	11.4	90487	AP138-4			SR: N/A CR: QUARTERLY
105	7.2.9	LDIL-105-3	11.4	90487	AP138-5			SR: N/A CR: QUARTERLY
105	7.2.9	LDE-105-4	11.4	90487	AP139-1 / EE-00956			SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-4	11.4	90487	AP139-2 / EE-00146			SR: CONT CR: QUARTERLY
105	7.2.9	LDK-105-4	11.4	90487	AP139-4			SR: N/A CR: QUARTERLY
105	7.2.9	LDIL-105-4	11.4	90487	AP139-5			SR: N/A CR: QUARTERLY
105	7.2.9	CAM-105-AP-1	11.4	90488	YAP08-1 / EE-00930			SR: CONT CR: MONTHLY
105	7.2.9	CVT-105-AP-1	11.4	90488	AP019-2 / EE-00374			SR: N/A CR: SEMI-ANN
105	7.2.9	RR-105-AP-1	11.4	90488	AP019-3 / EE-00504			SR: N/A CR: SEMI-ANN
105	7.2.9	RA-105-AP-1	11.4	90488	AP019-7 / EE-01176			SR: N/A CR: MONTHLY
105	7.2.9	RA-105-AP-2	11.4	90488	AP019-6 / EE-01188			SR: N/A CR: MONTHLY
105	7.2.9	RA-105-AP-3	11.4	90488	AP019-4 / EE-01127			SR: N/A CR: MONTHLY
105	7.2.9	RA-105-AP-4	11.4	90488	AP019-5 / EE-01055			SR: N/A CR: MONTHLY
105	7.2.9	RXA-105-AP-1	11.4	90488	AP019-8 / EE-01178			SR: N/A CR: MONTHLY
105	7.2.9	RXA-105-AP-2	11.4	90488	AP019-9 / EE-01158			SR: N/A CR: MONTHLY
105	7.3.1.A.1	DPIS-9		90514	AP085-2 / EE-00468		≤ 5.9"	SR: DAILY CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 41 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.3.1.A.1	DPA-K2-9		90514	AP085-3 / EE-01095			SR: N/A CR: N/A
105	7.3.1.B	TI-13		90514	AP084-5 / EE-02028		$\leq 230^{\circ} \text{ F}$	SR: DAILY CR: N/A
105	7.3.1.D	TI-14		90514	AP084-4 / EE-02032			SR: DAILY CR: N/A
105	7.3.1.D	TI-13		90514	AP084-5 / EE-02028			SR: DAILY CR: N/A
105	7.3.1.D	TC-3		90514	AP084-1 / EE-00856		$\Delta T \geq 5^{\circ} \text{ F}$	SR: N/A CR: N/A
105	7.3.1.D	TA-3		90514	AP084-6 / EE-01232			SR: N/A CR: N/A
105	7.3.1.D	TA-K2-3		90514	AP084-7 / EE-01208			SR: N/A CR: N/A
105	31.2.2.2	LDE-105-2		90487	AP137-1 / EE-00958	1/8"+3/8-1/8"		SR: N/A CR: N/A
105	31.2.2.2	LDE-105-3		90487	AP138-1 / EE-00957	1/8"+3/8-1/8"		SR: N/A CR: N/A
105	31.2.2.2	LDE-105-4		90487	AP139-1 / EE-00956	1/8"+3/8-1/8"		SR: N/A CR: N/A
105	31.2.2.2	LDA-105-1		90487	AP137-4 / EE-00121			SR: CONT CR: N/A
105	31.2.2.2	CAM-105-AP-1		90488	YAP08-1 / EE-00930			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 42 of 42

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
05C LDP	7.2.2.b	FI-05C-1		90487	AP036-1 / EE-01948			SR: N/A CR: N/A
05C LDP	7.2.2.b	FI-05C-2		90487	AP036-3 / EE-01942			SR: N/A CR: N/A
05C LDP	7.2.2.b	FI-05C-3		90487	AP036-7 / EE-01955			SR: N/A CR: N/A
05C LDP	7.2.2.b	WFT-05C-1		90487	AP036-2 / EE-00636			SR: N/A CR: N/A
05C LDP	7.2.2.b	SGT-05C-1		90487	AP036-6 / EE-00643			SR: N/A CR: N/A
05C LDP	7.2.2.b	LY-05C-1		90487	AP036-A / EE-01345			SR: N/A CR: N/A
05C LDP	7.2.2.b	LI-05C-2		90487	AP036-C / EE-01428		≤ 55"	SR: N/A CR: N/A
05C LDP	7.2.2.b	LAS-05C-1		90487	AP172-2 / EE-00669	36"		SR: N/A CR: N/A
05C LDP	7.2.2.b	LI-05C-1		90487	AP036-B / EE-00538		≤ 55"	SR: N/A CR: N/A
05C LDP	7.2.2.b	LA-05C-1		90487	AP036-E / EE-01244			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 43F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.2.a	LE-106-1	11.5	90487	AP107-1 / EE-00351			SR: N/A CR: N/A
106	7.2.2.a	LIT-106-1	11.5	90487	AP107-2 / EE-00792		422", 6"	SR: CONT CR: N/A
106	7.2.2.a	LE-106-3	11.5	90487	AP123-1 / EE-00209			SR: N/A CR: N/A
106	7.2.2.a	LI-106-1	11.5	90487	AP123-2 / EE-00923		422", 6"	SR: CONT CR: N/A
106	7.2.2.a	LE-106-2		90487	AP115-1 / EE-00067	419"		SR: N/A CR: N/A
106	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
106	7.2.2.a	LA-106-1		90487	AP115-2 / EE-01016			SR: N/A CR: N/A
106	7.2.2.a	LXA-106-1		90487	AP115-3 / EE-01092			SR: N/A CR: N/A
106	7.2.5.a	DPI-106-1		90514	AP089-1 / EE-02051		5", -6"	SR: N/A CR: N/A
106	7.2.5.a	PT-106-1		90487	AP006-2 / EE-00628		5", -6"	SR: N/A CR: N/A
106	7.2.5.a	PR-106-1		90487	AP006-4 / EE-00531			SR: N/A CR: N/A
106	7.2.5.a	PAS-106-1		90487	AP006-6 / EE-00658	-0.25"		SR: N/A CR: N/A
106	7.2.5.a	PA-106-1		90487	AP006-9 / EE-01254			SR: N/A CR: N/A
106	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
106	7.2.5.a	CVT-106		90487				SR: N/A CR: N/A
106	7.2.5.a	FI-106-1		90487	AP006-1 / EE-01946			SR: N/A CR: N/A
106	7.2.5.a	PT-106-2		90487	AP006-3 / EE-00628		5", -6"	SR: N/A CR: N/A
106	7.2.5.a	PR-106-2		90487	AP006-5 / EE-00532			SR: N/A CR: N/A
106	7.2.5.a	PAS-106-2		90487	AP006-7 / EE-00666	-5"		SR: N/A CR: N/A
106	7.2.5.a	PA-106-2		90487	AP006-8 / EE-01243			SR: N/A CR: N/A
106	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A
106	7.2.5.a	HORN		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 44F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.5.b	PT-106-1	11.6	90487	AP006-2 / EE-00637		5", -6"	SR: N/A CR: ANNUALLY
106	7.2.5.b	PR-106-1	11.6	90487	AP006-4 / EE-00531			SR: N/A CR: ANNUALLY
106	7.2.5.b	PAS-106-1	11.6	90487	AP006-6 / EE-00658	-0.25"		SR: CONT. CR: ANNUALLY
106	7.2.5.b	PA-106-1	11.6	90487	AP006-9 / EE-01254			SR: N/A CR: ANNUALLY
106	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
106	7.2.5.b	CVT-106	11.6	90487				SR: N/A CR: ANNUALLY
106	7.2.5.b	FI-106-1	11.6	90487	AP006-1 / EE-01946			SR: N/A CR: N/A
106	7.2.5.b	FI-106-2	11.6	90487	AP006-3 / EE-00628		5", -6"	SR: N/A CR: ANNUALLY
106	7.2.5.b	PR-106-2	11.6	90487	AP006-5 / EE-00532			SR: N/A CR: ANNUALLY
106	7.2.5.b	PAS-106-2	11.6	90487	AP006-7 / EE-00666	-5"		SR: CONT. CR: ANNUALLY
106	7.2.5.b	PA-106-2	11.6	90487	AP006-8 / EE-01243			SR: N/A CR: ANNUALLY
106	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
106	7.2.5.b	DPI-106-1	11.6	90487	AP089-1 / EE-02051		5", -6"	SR: N/A CR: N/A
106	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
106	7.2.5.c	PT-106-1	11.6	90487	AP006-2 / EE-00637			SR: N/A CR: N/A
106	7.2.5.c	PR-106-1	11.6	90487	AP006-4 / EE-00531			SR: CONT CR: N/A
106	7.2.5.c	CVT-106	11.6	90487				SR: N/A CR: N/A
106	7.2.5.c	FI-106-1	11.6	90487	AP006-1 / EE-01946			SR: N/A CR: N/A
106	7.2.5.c	PT-106-2	11.6	90487	AP006-3 / EE-00628			SR: N/A CR: N/A
106	7.2.5.c	PR-106-2	11.6	90487	AP006-5 / EE-00532			SR: CONT CR: N/A
106	7.2.5.c (d)	DPI-106-2	11.6	90487	AP088-2 / EE-02048			SR: N/A CR: N/A
106	7.2.5.c (d)	DPI-106-1	11.6	90487	AP089-1 / EE-02051		5", -6"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 45F of 22F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.5.c (d)	PT-106-1		90487	AP006-2 / EE-00637		5", -6"	SR: N/A CR: N/A
106	7.2.5.c (d)	PR-106-1		90487	AP006-4 / EE-00531			SR: N/A CR: N/A
106	7.2.5.c (d)	CVT-106		90487				SR: N/A CR: N/A
106	7.2.5.c (d)	FI-106-1		90487	AP006-1 / EE-01946			SR: N/A CR: N/A
106	7.2.5.c (d)	PT-106-2		90487	AP006-3 / EE-00628		5", -6"	SR: N/A CR: N/A
106	7.2.5.c (d)	PR-106-2		90487	AP006-5 / EE-00532			SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-36		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-37		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-38		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-39		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-40		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-41		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-42		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-43		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-44		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-45		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-46		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-47		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-48		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-49		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-50		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 46 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.6 (a,b,c)	TE-106-51		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-52		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-53		90487				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	MUX-106-1		90489				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		212° F	SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-27		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-28		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-29		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-30		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-31		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-32		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-33		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-34		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-35		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-54		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-55		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-56		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-57		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-58		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-59		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-60		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-61		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 47F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.7 (a,b,c)	TE-106-62		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-63		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-64		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-65		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-66		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-67		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-68		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-69		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-70		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-71		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-72		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-73		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-74		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-75		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-76		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-77		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-78		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-79		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-80		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-81		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-82		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-83		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 18 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.7 (a,b,c)	TE-106-84		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-85		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-86		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-87		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-88		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-89		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-90		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-91		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-92		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-93		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-94		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-95		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-96		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-97		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-98		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-99		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-100		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-101		90487				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	MUX-106-1		90489				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	MUX-106-2		90489				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		236° F	SR: N/A CR: N/A
106	7.2.9	LDE-106-2	11.4	90487	AP140-1 / EE-00873			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 99 of 124

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
106	7.2.9	LDI-106-2	11.4	90487	AP140-2 / EE-00152			SR: CONT CR: QUARTERLY
106	7.2.9	LDK-106-2	11.4	90487	AP140-5			SR: N/A CR: QUARTERLY
106	7.2.9	LDIL-106-2	11.4	90487	AP140-6			SR: N/A CR: QUARTERLY
106	7.2.9	LDA-106-1	11.4	90487	AP140-4 / EE-01147			SR: N/A CR: MONTHLY
106	7.2.9	LDE-106-3	11.4	90487	AP141-1 / EE-00955			SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-3	11.4	90487	AP141-2 / EE-00177			SR: CONT CR: QUARTERLY
106	7.2.9	LDK-106-3	11.4	90487	AP141-4			SR: N/A CR: QUARTERLY
106	7.2.9	LDIL-106-3	11.4	90487	AP141-5			SR: N/A CR: QUARTERLY
106	7.2.9	LDE-106-4	11.4	90487	AP142-1 / EE-00954			SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-4	11.4	90487	AP142-2 / EE-00190			SR: CONT CR: QUARTERLY
106	7.2.9	LDK-106-4	11.4	90487	AP142-4			SR: N/A CR: QUARTERLY
106	7.2.9	LDIL-106-4	11.4	90487	AP145-5			SR: N/A CR: QUARTERLY
106	7.2.9	CAM-106-AP-1	11.4	90488	YAP09-1 / EE-00925			SR: CONT CR: MONTHLY
106	7.2.9	CVT-106-AP-1	11.4	90488	AP020-2 / EE-00377			SR: N/A CR: SEMI-ANN
106	7.2.9	RR-106-AP-1	11.4	90488	AP020-3 / EE-00513			SR: N/A CR: SEMI-ANN
106	7.2.9	RA-106-AP-1	11.4	90488	AP020-7 / EE-01048			SR: N/A CR: MONTHLY
106	7.2.9	RA-106-AP-2	11.4	90488	AP020-6 / EE-01116			SR: N/A CR: MONTHLY
106	7.2.9	RA-106-AP-3	11.4	90488	AP020-4 / EE-01105			SR: N/A CR: MONTHLY
106	7.2.9	RA-106-AP-4	11.4	90488	AP020-5 / EE-01024			SR: N/A CR: MONTHLY
106	7.2.9	RXA-106-AP-1	11.4	90488	AP020-8 / EE-01132			SR: N/A CR: MONTHLY
106	7.2.9	RXA-106-AP-2	11.4	90488	AP020-9 / EE-01027			SR: N/A CR: MONTHLY
106	7.3.1.A.1	DPIS-9		90514	AP085-2 / EE-00468		≤ 5.9"	SR: DAILY CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 50 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.3.1.A.1	DPA-K2-9		90514	AP085-3 / EE-01095			SR: N/A CR: N/A
106	7.3.1.B	TI-13		90514	AP084-5 / EE-02028		$\leq 230^{\circ} \text{ F}$	SR: DAILY CR: N/A
106	7.3.1.D	TI-14		90514	AP084-4 / EE-02032			SR: DAILY CR: N/A
106	7.3.1.D	TI-13		90514	AP084-5 / EE-02028			SR: DAILY CR: N/A
106	7.3.1.D	TC-3		90514	AP084-1 / EE-00856		$\Delta T \geq 5^{\circ} \text{ F}$	SR: N/A CR: N/A
106	7.3.1.D	TA-3		90514	AP084-6 / EE-01232			SR: N/A CR: N/A
106	7.3.1.D	TA-K2-3		90514	AP084-7 / EE-01208			SR: N/A CR: N/A
106	31.2.2.2	LDE-106-2		90487	AP140-1 / EE-00873	1/8"+3/8-1/8"		SR: N/A CR: N/A
106	31.2.2.2	LDE-106-3		90487	AP141-1 / EE-00955	1/8"+3/8-1/8"		SR: N/A CR: N/A
106	31.2.2.2	LDE-106-4		90487	AP142-1 / EE-00954	1/8"+3/8-1/8"		SR: N/A CR: N/A
106	31.2.2.2	LDA-106-1		90487	AP140-4 / EE-01147			SR: CONT CR: N/A
106	31.2.2.2	CAM-106-AP-1		90488	YAP09-1 / EE-00925			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 51 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.2.a	LE-107-1	11.5	90487	AP108-1 / EE-00347			SR: N/A CR: N/A
107	7.2.2.a	LIT-107-1	11.5	90487	AP108-2 / EE-00798		422", 6"	SR: CONT CR: N/A
107	7.2.2.a	LE-107-3	11.5	90487	AP124-1 / EE-00222			SR: N/A CR: N/A
107	7.2.2.a	LI-107-1	11.5	90487	AP124-2 / EE-00978		422", 6"	SR: CONT CR: N/A
107	7.2.2.a	LE-107-2		90487	AP116-1 / EE-00228	419"		SR: N/A CR: N/A
107	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
107	7.2.2.a	LA-107-1		90487	AP116-2 / EE-01066			SR: N/A CR: N/A
107	7.2.2.a	LXA-107-1		90487	AP116-3 / EE-01017			SR: N/A CR: N/A
107	7.2.5.a	DPI-107-1		90514	AP093-1 / EE-02045		5", -6"	SR: N/A CR: N/A
107	7.2.5.a	PT-107-1		90487	AP007-2 / EE-00642		5", -6"	SR: N/A CR: N/A
107	7.2.5.a	PR-107-1		90487	AP007-4 / EE-00526			SR: N/A CR: N/A
107	7.2.5.a	PAS-107-1		90487	AP007-6 / EE-00653	-0.25"		SR: N/A CR: N/A
107	7.2.5.a	PA-107-1		90487	AP007-8 / EE-00999			SR: N/A CR: N/A
107	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
107	7.2.5.a	CVT-107		90487				SR: N/A CR: N/A
107	7.2.5.a	FI-107-1		90487	AP007-1 / EE-01968			SR: N/A CR: N/A
107	7.2.5.a	PT-107-2		90487	AP007-3 / EE-00630		5", -6"	SR: N/A CR: N/A
107	7.2.5.a	PR-107-2		90487	AP007-5 / EE-00517			SR: N/A CR: N/A
107	7.2.5.a	PAS-107-2		90487	AP007-7 / EE-00668	-5"		SR: N/A CR: N/A
107	7.2.5.a	PA-107-2		90487	AP007-9 / EE-01122			SR: N/A CR: N/A
107	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A
107	7.2.5.a	HORN		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 5 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.5.b	PT-107-1	11.6	90487	AP007-2 / EE-00642		5", -6"	SR: N/A CR: ANNUALLY
107	7.2.5.b	PR-107-1	11.6	90487	AP007-4 / EE-00526			SR: N/A CR: ANNUALLY
107	7.2.5.b	PAS-107-1	11.6	90487	AP007-6 / EE-00653	-0.25"		SR: CONT CR: ANNUALLY
107	7.2.5.b	PA-107-1	11.6	90487	AP007-8 / EE-00999			SR: N/A CR: ANNUALLY
107	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
107	7.2.5.b	CVT-107	11.6	90487				SR: N/A CR: N/A
107	7.2.5.b	FI-107-1	11.6	90487	AP007-1 / EE-01968			SR: N/A CR: N/A
107	7.2.5.b	PT-107-2	11.6	90487	AP007-3 / EE-00630		5", -6"	SR: N/A CR: ANNUALLY
107	7.2.5.b	PR-107-2	11.6	90487	AP007-5 / EE-00517			SR: N/A CR: ANNUALLY
107	7.2.5.b	PAS-107-2	11.6	90487	AP007-7 / EE-00668	-5"		SR: CONT CR: ANNUALLY
107	7.2.5.b	PA-107-2	11.6	90487	AP007-9 / EE-01122			SR: N/A CR: ANNUALLY
107	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
107	7.2.5.b	DPI-107-1	11.6	90514	AP093-1 / EE-02045		5", -6"	SR: N/A CR: N/A
107	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
107	7.2.5.c	PT-107-1	11.6	90487	AP007-2 / EE-00642			SR: N/A CR: N/A
107	7.2.5.c	PR-107-1	11.6	90487	AP007-4 / EE-00526			SR: CONT CR: N/A
107	7.2.5.c	CVT-107	11.6	90487				SR: N/A CR: N/A
107	7.2.5.c	FI-107-1	11.6	90587	AP007-1 / EE-01968			SR: N/A CR: N/A
107	7.2.5.c	PT-107-2	11.6	90487	AP007-3 / EE-00630			SR: N/A CR: N/A
107	7.2.5.c	PR-107-2	11.6	90487	AP007-5 / EE-00517			SR: CONT CR: N/A
107	7.2.5.c (d)	DPI-107-2		90514	AP092-2 / EE-02053			SR: N/A CR: N/A
107	7.2.5.c (d)	DPI-107-1		90514	AP093-1 / EE-02045		5", -6"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 53 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.5.c (d)	PT-107-1		90487	AP007-2 / EE-00642		5", -6"	SR: N/A CR: N/A
107	7.2.5.c (d)	PR-107-1		90487	AP007-4 / EE-00526			SR: N/A CR: N/A
107	7.2.5.c (d)	CVT-107		90487				SR: N/A CR: N/A
107	7.2.5.c (d)	FI-107-1		90487	AP007-1 / EE-01968			SR: N/A CR: N/A
107	7.2.5.c (d)	PT-107-2		90487	AP007-3 / EE-00630		5", -6"	SR: N/A CR: N/A
107	7.2.5.c (d)	PR-107-2		90487	AP007-2 / EE-00517			SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-36		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-37		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-38		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-39		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-40		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-41		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-42		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-43		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-44		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-45		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-46		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-47		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-48		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-49		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-50		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 54 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.6 (a,b,c)	TE-107-51		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-52		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TE-107-53		90487				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	MUX-107-1		90489				SR: N/A CR: N/A
107	7.2.6 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		212° F	SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-27		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-28		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-29		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-30		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-31		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-32		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-33		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-34		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-35		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-54		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-55		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-56		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-57		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-58		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-59		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-60		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 55 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.7 (a,b,c)	TE-107-61		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-62		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-63		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-64		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-65		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-66		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-67		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-68		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-69		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-70		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-71		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-72		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-73		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-74		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-75		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-76		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-77		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-78		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-79		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-80		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-81		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX.

WHC-SD-WM-EL-003
Rev. 0
page 56 of 22F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.7 (a,b,c)	TE-107-82		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-83		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-84		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-85		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-86		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-87		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-88		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-89		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-90		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-91		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-92		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-93		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-94		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-95		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-96		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-97		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-98		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-99		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-100		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TE-107-101		90487				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	MUX-107-1		90489				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 57 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.7 (a,b,c)	MUX-107-2		90489				SR: N/A CR: N/A
107	7.2.7 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		236° F	SR: N/A CR: QUARTERLY
107	7.2.9	LDE-107-2	11.4	90487	AP143-1 / EE-00953			SR: N/A CR: QUARTERLY
107	7.2.9	LDI-107-2	11.4	90487	AP143-2 / EE-00136			SR: CONT CR: QUARTERLY
107	7.2.9	LDK-107-2	11.4	90487	AP143-5			SR: N/A CR: QUARTERLY
107	7.2.9	LDIL-107-2	11.4	90487	AP143-6			SR: N/A CR: QUARTERLY
107	7.2.9	LDA-107-1	11.4	90487	AP143-4 / EE-01076			SR: N/A CR: MONTHLY
107	7.2.9	LDE-107-3	11.4	90487	AP144-1 / EE-00952			SR: N/A CR: QUARTERLY
107	7.2.9	LDI-107-3	11.4	90487	AP144-2 / EE-00114			SR: CONT CR: QUARTERLY
107	7.2.9	LDK-107-3	11.4	90487	AP144-4			SR: N/A CR: QUARTERLY
107	7.2.9	LDIL-107-3	11.4	90487	AP144-5			SR: N/A CR: QUARTERLY
107	7.2.9	LDE-107-4	11.4	90487	AP145-1 / EE-00951			SR: N/A CR: QUARTERLY
107	7.2.9	LDI-107-4	11.4	90487	AP145-2 / EE-00157			SR: CONT CR: QUARTERLY
107	7.2.9	LDK-107-4	11.4	90487	AP145-4			SR: N/A CR: QUARTERLY
107	7.2.9	LDIL-107-4	11.4	90487	AP145-5			SR: N/A CR: QUARTERLY
107	7.2.9	CAM-107-AP-1	11.4	90488	YAP10-1 / EE-00926			SR: CONT CR: MONTHLY
107	7.2.9	CVT-107-AP-1	11.4	90488	AP021-2 / EE-00376			SR: N/A CR: SEMI-ANN
107	7.2.9	RR-107-AP-1	11.4	90488	AP021-3 / EE-00528			SR: N/A CR: SEMI-ANN
107	7.2.9	RA-107-AP-1	11.4	90488	AP021-7 / EE-01217			SR: N/A CR: MONTHLY
107	7.2.9	RA-107-AP-2	11.4	90488	AP021-6 / EE-01245			SR: N/A CR: MONTHLY
107	7.2.9	RA-107-AP-3	11.4	90488	AP021-4 / EE-01194			SR: N/A CR: MONTHLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 58 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	7.2.9	RA-107-AP-4	11.4	90488	AP021-5 / EE-01248			SR: N/A CR: MONTHLY
107	7.2.9	RXA-107-AP-1	11.4	90488	AP021-8 / EE-01135			SR: N/A CR: MONTHLY
107	7.2.9	RXA-107-AP-2	11.4	90488	AP021-9 / EE-01003			SR: N/A CR: MONTHLY
107	7.3.1.A.1	DPIS-10		90514	AP091-2 / EE-00469		≤ 5.9"	SR: DAILY CR: N/A
107	7.3.1.A.1	DPA-K2-10		90514	AP091-3 / EE-01022			SR: N/A CR: N/A
107	7.3.1.B	TI-15		90514	AP090-5 / EE-01978		≤ 230° F	SR: DAILY CR: N/A
107	7.3.1.D	TI-16		90514	AP090-4 / EE-02027			SR: DAILY CR: N/A
107	7.3.1.D	TI-15		90514	AP090-5 / EE-01978			SR: DAILY CR: N/A
107	7.3.1.D	TC-4		90514	AP090-1 / EE-00857		ΔT ≥ 5° F	SR: N/A CR: N/A
107	7.3.1.D	TA-4		90514	AP090-6 / EE-01257			SR: N/A CR: N/A
107	7.3.1.D	TA-K2-4		90514	AP090-7 / EE-01219			SR: N/A CR: N/A
107	31.2.2.2	LDE-107-2		90487	AP143-1 / EE-00953	1/8"+3/8-1/8"		SR: N/A CR: N/A
107	31.2.2.2	LDE-107-3		90487	AP144-1 / EE-00952	1/8"+3/8-1/8"		SR: N/A CR: N/A
107	31.2.2.2	LDE-107-4		90487	AP145-1 / EE-00951	1/8"+3/8-1/8"		SR: N/A CR: N/A
107	31.2.2.2	LDA-107-1		90487	AP143-4 / EE-01076			SR: CONT CR: N/A
107	31.2.2.2	CAM-107-AP-1		90488	YAP10-1 / EE-00926			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 59 of 22F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.2.a	LE-108-1	11.5	90487	AP109-1 / EE-00349			SR: N/A CR: N/A
108	7.2.2.a	LIT-108-1	11.5	90487	AP109-2 / EE-00801		422", 6"	SR: CONT CR: N/A
108	7.2.2.a	LE-108-3	11.5	90487	AP191-1 / EE-00286			SR: N/A CR: N/A
108	7.2.2.a	LI-108-1	11.5	90487	AP191-2 / EE-00979		422", 6"	SR: CONT CR: N/A
108	7.2.2.a	LE-108-2		90487	AP117-1 / EE-00233	419"		SR: N/A CR: N/A
108	7.2.2.a	LDK ENCLOSURE		90487				SR: N/A CR: N/A
108	7.2.2.a	LA-108-1		90487	AP117-2 / EE-01270			SR: N/A CR: N/A
108	7.2.2.a	LXA-108-1		90487	AP117-3 / EE-01210			SR: N/A CR: N/A
108	7.2.5.a	DPI-108-1		90514	AP095-1 / EE-02041		5", -6"	SR: N/A CR: N/A
108	7.2.5.a	PT-108-1		90487	AP008-1 / EE-00645		5", -6"	SR: N/A CR: N/A
108	7.2.5.a	PR-108-1		90487	AP008-4 / EE-00530			SR: N/A CR: N/A
108	7.2.5.a	PAS-108-1		90487	AP008-6 / EE-00663	-0.25"		SR: N/A CR: N/A
108	7.2.5.a	PA-108-1		90487	AP008-8 / EE-01240			SR: N/A CR: N/A
108	7.2.5.a	PA-A-1		90487	AP010-1 / EE-01266			SR: N/A CR: N/A
108	7.2.5.a	CVT-108		90487				SR: N/A CR: N/A
108	7.2.5.a	FI-108-1		90487	AP008-1 / EE-01963			SR: N/A CR: N/A
108	7.2.5.a	PT-108-2		90487	AP008-3 / EE-00646		5", -6"	SR: N/A CR: N/A
108	7.2.5.a	PR-108-2		90487	AP008-5 / EE-00527			SR: N/A CR: N/A
108	7.2.5.a	PAS-108-2		90487	AP008-7 / EE-00664	-5"		SR: N/A CR: N/A
108	7.2.5.a	PA-108-2		90487	AP008-9 / EE-01268			SR: N/A CR: N/A
108	7.2.5.a	PA-A-2		90487	AP010-2 / EE-01110			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 1 of 2

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.5.a	HORN		90487				SR: N/A CR: N/A
108	7.2.5.b	PT-108-1	11.6	90487	AP008-2 / EE-00645		5", -6"	SR: N/A CR: ANNUALLY
108	7.2.5.b	PR-108-1	11.6	90487	AP008-4 / EE-00530			SR: N/A CR: ANNUALLY
108	7.2.5.b	PAS-108-1	11.6	90487	AP008-6 / EE-00663	-0.25"		SR: CONT CR: ANNUALLY
108	7.2.5.b	PA-108-1	11.6	90487	AP008-8 / EE-01240			SR: N/A CR: ANNUALLY
108	7.2.5.b	PA-A-1	11.6	90487	AP010-1 / EE-01266			SR: N/A CR: ANNUALLY
108	7.2.5.b	CVT-108	11.6	90487				SR: N/A CR: ANNUALLY
108	7.2.5.b	FI-108-1	11.6	90487	AP008-1 / EE-01963			SR: N/A CR: N/A
108	7.2.5.b	PT-108-2	11.6	90487	AP008-2 / EE-00646		5", -6"	SR: N/A CR: ANNUALLY
108	7.2.5.b	PR-108-2	11.6	90487	AP008-5 / EE-00527			SR: N/A CR: ANNUALLY
108	7.2.5.b	PAS-108-2	11.6	90487	AP008-7 / EE-00664	-5"		SR: CONT CR: ANNUALLY
108	7.2.5.b	PA-108-2	11.6	90487	AP008-9 / EE-01268			SR: N/A CR: ANNUALLY
108	7.2.5.b	PA-A-2	11.6	90487	AP010-2 / EE-01110			SR: N/A CR: ANNUALLY
108	7.2.5.b	DPI-108-1	11.6	90514	AP095-1 / EE-02041		5", -6"	SR: N/A CR: N/A
108	7.2.5.b	HORN	11.6	90487				SR: N/A CR: ANNUALLY
108	7.2.5.c	PT-108-1	11.6	90487	AP008-2 / EE-00645			SR: N/A CR: N/A
108	7.2.5.c	PR-108-1	11.6	90487	AP008-4 / EE-00530			SR: CONT CR: N/A
108	7.2.5.c	CVT-108	11.6	90487				SR: N/A CR: N/A
108	7.2.5.c	FI-108-1	11.6	90487	AP008-1 / EE-01963			SR: N/A CR: N/A
108	7.2.5.c	PR-108-2	11.6	90487	AP008-5 / EE-00527			SR: N/A CR: N/A
108	7.2.5.c	PT-108-2	11.6	90487	AP008-3 / EE-00646		5", -6"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 11 of 22

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.5.c (d)	DPI-108-2		90514	AP094-2 / EE-02050			SR: N/A CR: N/A
108	7.2.5.c (d)	DPI-108-1		90514	AP095-1 / EE-02041		5", -6"	SR: N/A CR: N/A
108	7.2.5.c (d)	PT-108-1		90487	AP008-2 / EE-00645		5", -6"	SR: N/A CR: N/A
108	7.2.5.c (d)	PR-108-1		90487	AP008-4 / EE-00530			SR: N/A CR: N/A
108	7.2.5.c (d)	CVT-108		90487				SR: N/A CR: N/A
108	7.2.5.c (d)	FI-108-1		90487	AP008-1 / EE-01963			SR: N/A CR: N/A
108	7.2.5.c (d)	PT-108-2		90487	AP008-3 / EE-00646		5", -6"	SR: N/A CR: N/A
108	7.2.5.c (d)	PR-108-2		90487	AP008-5 / EE-00527			SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-36		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-37		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-38		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-39		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-40		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-41		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-42		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-43		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-44		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-45		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-46		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-47		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-48		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 2 of 2

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.6 (a,b,c)	TE-108-49		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-50		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-51		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-52		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TE-108-53		90487				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	MUX-108-1		90489				SR: N/A CR: N/A
108	7.2.6 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		212° F	SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-27		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-28		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-29		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-30		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-31		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-32		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-33		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-34		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-35		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-54		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-55		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-56		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-57		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-58		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003
Rev. 0
page 63 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.7 (a,b,c)	TE-108-59		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-60		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-61		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-62		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-63		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-64		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-65		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-66		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-67		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-68		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-69		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-70		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-71		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-72		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-73		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-74		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-75		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-76		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-77		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-78		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-79		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 44 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.7 (a,b,c)	TE-108-80		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-81		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-82		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-83		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-84		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-85		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-86		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-87		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-88		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-89		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-90		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-91		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-92		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-93		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-94		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-95		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-96		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-97		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-98		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-99		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TE-108-100		90487				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 5 of 25

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.7 (a,b,c)	TE-108-101		90487				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	MUX-108-1		90489				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	MUX-108-2		90489				SR: N/A CR: N/A
108	7.2.7 (a,b,c)	TDS-AP-2		90489	AP210-2 / EE-01310		236° F	SR: N/A CR: N/A
108	7.2.9	LDE-108-2	11.4	90487	AP146-1 / EE-00950			SR: N/A CR: QUARTERLY
108	7.2.9	LDI-108-2	11.4	90487	AP146-2 / EE-00180			SR: CONT CR: QUARTERLY
108	7.2.9	LDK-108-2	11.4	90487	AP146-5			SR: N/A CR: QUARTERLY
108	7.2.9	LDIL-108-2	11.4	90487	AP146-6			SR: N/A CR: QUARTERLY
108	7.2.9	LDA-108-1	11.4	90487	AP146-4 / EE-01228			SR: N/A CR: MONTHLY
108	7.2.9	LDE-108-3	11.4	90487	AP147-1 / EE-00949			SR: N/A CR: QUARTERLY
108	7.2.9	LDI-108-3	11.4	90487	AP147-2 / EE-00115			SR: CONT CR: QUARTERLY
108	7.2.9	LDK-108-3	11.4	90487	AP147-4			SR: N/A CR: QUARTERLY
108	7.2.9	LDIL-108-3	11.4	90487	AP147-5			SR: N/A CR: QUARTERLY
108	7.2.9	LDE-108-4	11.4	90487	AP148-1 / EE-00948			SR: N/A CR: QUARTERLY
108	7.2.9	LDI-108-4	11.4	90487	AP148-2 / EE-00158			SR: CONT CR: QUARTERLY
108	7.2.9	LDK-108-4	11.4	90487	AP148-4			SR: N/A CR: QUARTERLY
108	7.2.9	LDIL-108-4	11.4	90487	AP148-5			SR: N/A CR: QUARTERLY
108	7.2.9	CAM-108-AP-1	11.4	90488	YAP11-1 / EE-00931			SR: CONT CR: MONTHLY
108	7.2.9	CVT-108-AP-1	11.4	90488	AP022-2 / EE-00372			SR: N/A CR: SEMI-ANN
108	7.2.9	RR-108-AP-1	11.4	90488	AP022-3 / EE-00501			SR: N/A CR: SEMI-ANN
108	7.2.9	RA-108-AP-1	11.4	90488	AP022-7 / EE-01165			SR: N/A CR: MONTHLY

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 66 F of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	7.2.9	RA-108-AP-2	11.4	90488	AP022-6 / EE-01195			SR: N/A CR: MONTHLY
108	7.2.9	RA-108-AP-3	11.4	90488	AP022-4 / EE-01136			SR: N/A CR: MONTHLY
108	7.2.9	RA-108-AP-4	11.4	90488	AP022-5 / EE-01272			SR: N/A CR: MONTHLY
108	7.2.9	RXA-108-AP-1	11.4	90488	AP022-8 / EE-01170			SR: N/A CR: MONTHLY
108	7.2.9	RXA-108-AP-2	11.4	90488	AP022-9 / EE-01171			SR: N/A CR: MONTHLY
108	7.3.1.A.1	DPIS-10		90514	AP091-2 / EE-00469		≤ 5.9"	SR: DAILY CR: N/A
108	7.3.1.A.1	DPA-K2-10		90514	AP091-3 / EE-01022			SR: N/A CR: N/A
108	7.3.1.B	TI-15		90514	AP090-5 / EE-01978		≤ 230° F	SR: DAILY CR: N/A
108	7.3.1.D	TI-16		90514	AP090-4 / EE-02027			SR: DAILY CR: N/A
108	7.3.1.D	TI-15		90514	AP090-5 / EE-01978			SR: DAILY CR: N/A
108	7.3.1.D	TC-4		90514	AP090-1 / EE-00857		ΔT ≥ 5° F	SR: N/A CR: N/A
108	7.3.1.D	TA-4		90514	AP090-6 / EE-01232			SR: N/A CR: N/A
108	7.3.1.D	TA-K2-4		90514	AP090-7 / EE-01219			SR: N/A CR: N/A
108	31.2.2.2	LDE-108-2		90487	AP146-1 / EE-00950	1/8"+3/8-1/8"		SR: N/A CR: N/A
108	31.2.2.2	LDE-108-3		90487	AP147-1 / EE-00949	1/8"+3/8-1/8"		SR: N/A CR: N/A
108	31.2.2.2	LDE-108-4		90487	AP148-1 / EE-00948	1/8"+3/8-1/8"		SR: N/A CR: N/A
108	31.2.2.2	LDA-108-1		90487	AP146-4 / EE-01228			SR: CONT CR: N/A
108	31.2.2.2	CAM-108-AP-1		90488	YAP11-1 / EE-00931			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 67F of 72F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K1	7.3.1.A.1.a	DPIS-2		90514	AP058-3 / EE-00486		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.a	DPA-K1-2		90514	AP058-4 / EE-01207			SR: N/A CR: N/A
K1	7.3.1.A.1.a	DPIS-5		90514	AP059-3 / EE-00487		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.a	DPA-K1-5		90514	AP059-4 / EE-01262			SR: N/A CR: N/A
K1	7.3.1.A.1.b	DPIS-1		90514	AP058-5 / EE-00473		≤ 4.0"	SR: DAILY CR: N/A
K1	7.3.1.A.1.b	DPIS-4		90514	AP059-5 / EE-00484		≤ 4.0"	SR: DAILY CR: N/A
K1	7.3.1.A.1.c	DPIS-1		90514	AP058-5 / EE-00473		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.c	DPIS-4		90514	AP059-5 / EE-00484		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.c	DPIS-2		90514	AP058-3 / EE-00486		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.c	DPIS-5		90514	AP059-3 / EE-00487		≤ 5.9"	SR: DAILY CR: N/A
K1	7.3.1.B	HTS-1		90514	AP062-3 / EE-00246		≤ 230° F	SR: N/A CR: N/A
K1	7.3.1.B	HTS-2		90514	AP063-3 / EE-00327		≤ 230° F	SR: N/A CR: N/A
K1	7.3.1.B	TI-1		90514	AP060-1 / EE-02030			SR: N/A CR: N/A
K1	7.3.1.B	TI-2		90514	AP060-2 / EE-02017			SR: N/A CR: N/A
K1	7.3.1.B	TI-7		90514	AP061-1 / EE-02022			SR: N/A CR: N/A
K1	7.3.1.B	TI-8		90514	AP061-2 / EE-02019			SR: N/A CR: N/A
K1	7.3.1.B	TDC-K1-1		90514	AP062-1 / EE-01431			SR: N/A CR: N/A
K1	7.3.1.B	TDC-K1-2		90514	AP063-1 / EE-01430			SR: N/A CR: N/A
K1	7.3.1.D	HTS-1		90514	AP062-3 / EE-00246			SR: N/A CR: N/A
K1	7.3.1.D	TI-1		90514	AP060-1 / EE-02030			SR: DAILY CR: N/A
K1	7.3.1.D	TDC-K1-1		90514	AP062-1 / EE-01431		ΔT ≥ 5° F	SR: N/A CR: N/A
K1	7.3.1.D	HTS-2		90514	AP063-3 / EE-00327			SR: N/A CR: N/A
K1	7.3.1.D	TI-7		90514	AP061-1 / EE-02022			SR: DAILY CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 6 of 24

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K1	7.3.1.D	TI-2		90514	AP060-2 / EE-02017			SR: DAILY CR: N/A
K1	7.3.1.D	TI-8		90514	AP061-2 / EE-02019			SR: DAILY CR: N/A
K1	7.3.1.D	TDC-K1-2		90514	AP063-1 / EE-01430		$\Delta T \geq 5^{\circ} F$	SR: N/A CR: N/A
K1	7.3.1.E	FE-K1-2-1		90488	AP300-8 / EE-01668			SR: N/A CR: N/A
K1	7.3.1.E	FYT-K1-1-1		90488	AP300-1 / EE-00172			SR: N/A CR: N/A
K1	7.3.1.E	FR-K1-1-1		90488	AP300-2 / EE-00506			SR: N/A CR: N/A
K1	7.3.1.E	FQ-K1-1-1		90488	AP300-3 / EE-00381			SR: N/A CR: N/A
K1	7.3.1.E	FQI-K1-1-1		90488	AP300-4 / EE-02064			SR: N/A CR: N/A
K1	7.3.1.E	FAS-K1-1-1		90488	AP300-5 / EE-00654			SR: N/A CR: N/A
K1	7.3.1.E	FA-K1-1-1		90488	AP300-6 / EE-01019			SR: N/A CR: N/A
K1	7.3.1.E	FA-K1-1-2		90488	AP300-7 / EE-01017			SR: N/A CR: N/A
K1	7.3.1.E	RECORD SAMPLE		90488				SR: N/A CR: N/A
K1	7.3.1.E	FQI-K1-2-1		90488	AP302-1 / EE-01391			SR: N/A CR: N/A
K1	7.3.1.E	PI-K1-1		90488	AP303-1 / EE-02068			SR: N/A CR: N/A
K1	7.3.1.E	FAS-K1-2-1		90488	AP304-1 / EE-00614			SR: N/A CR: N/A
K1	7.3.1.E	FA-K1-2-1		90488	AP304-2 / EE-01163			SR: N/A CR: N/A
K1	7.3.1.E	FA-K1-2-2		90488	AP304-3 / EE-01161			SR: N/A CR: N/A
K1	7.3.1.E	CAM-K1-1		90488	YAP02-1 / EE-00938			SR: CONT CR: N/A
K1	7.3.1.E	CVT-K1-1		90488	AP305-1 / EE-00378			SR: N/A CR: N/A
K1	7.3.1.E	RR-K1-1-1		90488	AP305-2 / EE-00534			SR: N/A CR: N/A
K1	7.3.1.E	RXA-K1-1-1		90488	AP308-1 / EE-01078			SR: N/A CR: N/A
K1	7.3.1.E	RXA-K1-1-2		90488	AP308-2 / EE-01009			SR: N/A CR: N/A
K1	7.3.1.E	RA-K1-1-1		90488	AP306-1 / EE-01235			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 69 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K1	7.3.1.E	RA-K1-1-2		90488	AP306-2 / EE-01201			SR: N/A CR: N/A
K1	7.3.1.E	RA-K1-1-3		90488				SR: N/A CR: N/A
K1	7.3.1.E	RA-K1-1-4		90488	AP306-4 / EE-01230			SR: N/A CR: N/A
K1	7.3.1.E	FAS-K1-3-1		90488	AP307-1 / EE-00609			SR: N/A CR: N/A
K1	7.3.1.E	FA-K1-3-1		90488	AP307-2 / EE-01089			SR: N/A CR: N/A
K1	7.3.1.E	FA-K1-3-2		90488	AP307-3 / EE-01045			SR: N/A CR: N/A
K1	7.3.2	SEE OSD 7.2.5. b,c						SEE OSD 7.2.5. b,c

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 70 of 72 F

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K2	7.3.1.A.1.a	DPIS-19		90514	AP067-1 / EE-01419		$\leq 5.9"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.a	DPA-K2-19		90514	AP067-5 / EE-01000			SR: N/A CR: N/A
K2	7.3.1.A.1.a	DPIS-17		90514	AP064-2 / EE-01418		$\leq 5.9"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.a	DPA-K2-17		90514	AP064-4 / EE-01250			SR: N/A CR: N/A
K2	7.3.1.A.1.b	DPIS-20		90514	AP067-2 / EE-00470		$\leq 4.0"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.b	DPIS-18		90514	AP064-1 / EE-00475		$\leq 4.0"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.c	DPIS-19		90514	AP067-1 / EE-01419		$\leq 5.9"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.c	DPIS-20		90514	AP067-2 / EE-00470		$\leq 5.9"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.c	DPIS-17		90514	AP064-2 / EE-01418		$\leq 5.9"$	SR: DAILY CR: N/A
K2	7.3.1.A.1.c	DPIS-18		90514	AP064-1 / EE-00475		$\leq 5.9"$	SR: DAILY CR: N/A
K2	7.3.1.B	HTS-3		90514	AP068-3 / EE-00625		$\leq 230^{\circ} \text{ F}$	SR: N/A CR: N/A
K2	7.3.1.B	HTS-4		90514	AP065-3 / EE-01496		$\leq 230^{\circ} \text{ F}$	SR: N/A CR: N/A
K2	7.3.1.B	TI-5		90514	AP069-1 / EE-01977			SR: N/A CR: N/A
K2	7.3.1.B	TI-6		90514	AP069-2 / EE-02029			SR: N/A CR: N/A
K2	7.3.1.B	TI-3		90514	AP066-1 / EE-02025			SR: N/A CR: N/A
K2	7.3.1.B	TI-4		90514	AP066-2 / EE-02026			SR: N/A CR: N/A
K2	7.3.1.B	TDC-K2-1		90514	AP065-1 / EE-01432			SR: N/A CR: N/A
K2	7.3.1.B	TDC-K2-2		90514	AP068-1 / EE-01434			SR: N/A CR: N/A
K2	7.3.1.D	TI-5		90514	AP069-1 / EE-01977			SR: DAILY CR: N/A
K2	7.3.1.D	TDC-K2-2		90514	AP068-1 / EE-01434		$\Delta T \geq 5^{\circ} \text{ F}$	SR: N/A CR: N/A
K2	7.3.1.D	TI-3		90514	AP066-1 / EE-02025			SR: DAILY CR: N/A
K2	7.3.1.D	TI-6		90514	AP069-2 / EE-02029			SR: DAILY CR: N/A
K2	7.3.1.D	TI-4		90514	AP066-2 / EE-02026			SR: DAILY CR: N/A
K2	7.3.1.D	TDC-K2-1		90514	AP065-1 / EE-01432		$\Delta T \geq 5^{\circ} \text{ F}$	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

 WHC-SD-WM-EL-003
 Rev. 0
 page 71 of 72

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K2	7.3.1.E	FE-K2-2-1		90488	AP320-8 / EE-01762			SR: N/A CR: N/A
K2	7.3.1.E	FYT-K2-1-1		90488	AP320-1 / EE-00134			SR: N/A CR: N/A
K2	7.3.1.E	FR-K2-1-1		90488	AP320-2 / EE-00505			SR: N/A CR: N/A
K2	7.3.1.E	FQ-K2-1-1		90488	AP320-3 / EE-00380			SR: N/A CR: N/A
K2	7.3.1.E	FQI-K2-1-1		90488	AP320-4 / EE-02065			SR: N/A CR: N/A
K2	7.3.1.E	FAS-K2-1-1		90488	AP320-5 / EE-00659			SR: N/A CR: N/A
K2	7.3.1.E	FA-K2-1-1		90488	AP320-6 / EE-01149			SR: N/A CR: N/A
K2	7.3.1.E	FA-K2-1-2		90488	AP320-7 / EE-01140			SR: N/A CR: N/A
K2	7.3.1.E	RECORD SAMPLE		90488				SR: N/A CR: N/A
K2	7.3.1.E	FQI-K2-2-1		90488	AP322-1 / EE-01393			SR: N/A CR: N/A
K2	7.3.1.E	PI-K2-1		90488	AP323-1 / EE-02067			SR: N/A CR: N/A
K2	7.3.1.E	FAS-K2-2-1		90488	AP324-1 / EE-01495			SR: N/A CR: N/A
K2	7.3.1.E	FA-K2-2-1		90488	AP324-2 / EE-01260			SR: N/A CR: N/A
K2	7.3.1.E	FA-K2-2-2		90488	AP324-3 / EE-01215			SR: N/A CR: N/A
K2	7.3.1.E	CAM-K2-1		90488	YAP03-1 / EE-00940			SR: CONT CR: N/A
K2	7.3.1.E	CVT-K2-1		90488	AP325-1 / EE-00370			SR: N/A CR: N/A
K2	7.3.1.E	RR-K2-1-1		90488	AP325-2 / EE-00519			SR: N/A CR: N/A
K2	7.3.1.E	RXA-K2-1-1		90488	AP328-1 / EE-01142			SR: N/A CR: N/A
K2	7.3.1.E	RXA-K2-1-2		90488	AP328-2 / EE-01155			SR: N/A CR: N/A
K2	7.3.1.E	RA-K2-1-1		90488	AP326-1 / EE-00997			SR: N/A CR: N/A
K2	7.3.1.E	RA-K2-1-2		90488	AP326-2 / EE-00998			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003

Rev. 0

page 2 of 2

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K2	7.3.1.E	RA-K2-1-3		90488	AP326-3 / EE-01083			SR: N/A CR: N/A
K2	7.3.1.E	RA-K2-1-4		90488	AP326-4 / EE-01052			SR: N/A CR: N/A
K2	7.3.1.E	FAS-K2-3-1		90488	AP327-1 / EE-00613			SR: N/A CR: N/A
K2	7.3.1.E	FA-K2-3-1		90488	AP327-2 / EE-01026			SR: N/A CR: N/A
K2	7.3.1.E	FA-K2-3-2		90488	AP327-3 / EE-01152			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1G of 47G

241-AW

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.2.a	LE-101-1	11.5	70348	AW062-1 / EE-00712			SR: N/A CR: N/A
101	7.2.2.a	LIT-101-1	11.5	70348	AW062-2 / EE-00799		422", 6"	SR: DAILY CR: N/A
101	7.2.2.a	LE-101-2		70348	AW064-1 / EE-01605			SR: N/A CR: N/A
101	7.2.2.a	LAK-101-1		70348	AW064-2 / EE-00354	EQUIPMENT OUT	OF SERVICE	SR: N/A CR: N/A
101	7.2.2.a	LA-101-1		70348	AW064-3 / EE-01322			SR: N/A CR: N/A
101	7.2.2.a	LE-101-3		70348	AW074-1 / EE-00102			SR: N/A CR: N/A
101	7.2.2.a	LLI-101-3		70348	AW074-2 / EE-00103			SR: N/A CR: N/A
101	7.2.2.b	WFT-01C-1		70348	AW037-1 / EE-00566			SR: N/A CR: N/A
101	7.2.2.b	WFI-01C-1		70348	AW040-3 / EE-00488		≤66"	SR: N/A CR: N/A
101	7.2.2.b	WFT-01C-2		70348	AW040-1 / EE-00570			SR: N/A CR: N/A
101	7.2.2.b	WFAS-01C-1		70348	AW040-2 / EE-00587	36"		SR: N/A CR: N/A
101	7.2.2.b	WFA-01C-1		70348	AW040-4 / EE-00006			SR: N/A CR: N/A
101	7.2.2.b	FI-01C-1		70348	AW185-3 / EE-00699			SR: N/A CR: N/A
101	7.2.2.b	FI-01C-3		70348	AW185-5 / EE-00701			SR: N/A CR: N/A
101	7.2.5 (a,b,c,d)	PT-101-2	11.6	70348	AW049-1 / EE-00551		-6", 5"	SR: N/A CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PR-101-2	11.6	70348	AW049-2 / EE-00455			SR: "CONT" CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PT-101-1	11.6	70348	AW046-1 / EE-00555		-6", 5"	SR: N/A CR: ANNUALLY
101	7.2.5 (a,b)	PAS-101-1	11.6	70348	AW046-2 / EE-01470	-4"		SR: "CONT" CR: ANNUALLY
101	7.2.5 (a,b)	PAS-101-2	11.6	70348	AW046-3 / EE-01468	-0.25"		SR: "CONT" CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2G of 47G

101	7.2.5 (a,b)	PA-101-1	11.6	70348	AW046-5 / EE-00118			SR: N/A CR: ANNUALLY
101	7.2.5 (a,b)	PA-101-2	11.6	70348	AW046-6 / EE-00147			SR: N/A CR: ANNUALLY
101	7.2.5 (a,b,c,d)	PR-101-1	11.6	70348	AW046-4 / EE-00461			SR: "CONT" CR: ANNUALLY
101	7.2.5 (a,b)	HORN	11.6	70348				SR: N/A CR: ANNUALLY
101	7.2.5 (a,b,c,d)	FI-101-1	11.6	70348				SR: N/A CR: N/A
101	7.2.5 (a,b,c,d)	DPI-101-1		70348				SR: N/A CR: N/A
101	7.2.5 (d)	PI-1		70336	AW125-A / EE-00407			SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-36		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-37		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-38		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-39		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-40		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-41		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-42		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-43		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-44		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-45		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-46		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-47		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-48		70348				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-49		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

101	7.2.6 (a,b,c)	TE-101-50	70348					SR: N/A	CR: N/A
101	7.2.6 (a,b,c)	TE-101-51	70348					SR: N/A	CR: N/A
101	7.2.6 (a,b,c)	TE-101-52	70348					SR: N/A	CR: N/A
101	7.2.6 (a,b,c)	TE-101-53	70348					SR: N/A	CR: N/A
101	7.2.6 (a,b,c)	SS-101-1	70348					SR: N/A	CR: N/A
101	7.2.6 (a,b,c)	TI-AW-1	70348	AW271-1 / EE-00499			212° F	SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-27	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-28	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-29	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-30	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-31	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-32	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-33	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-34	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-35	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-54	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-55	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-56	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-57	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-58	70348					SR: N/A	CR: N/A
101	7.2.7 (a,b,c)	TE-101-59	70348					SR: N/A	CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4G of 47G

101	7.2.7 (a,b,c)	TE-101-60		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-61		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-62		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-63		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-64		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-65		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-66		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-67		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-68		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-69		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-70		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-71		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-72		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-73		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-74		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-75		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-76		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-77		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-78		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-79		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-80		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5G of 47G

101	7.2.7 (a,b,c)	TE-101-81		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-82		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-83		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-84		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-85		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-86		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-87		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-88		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-89		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-90		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-91		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-92		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-93		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-94		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-95		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-96		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-97		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-98		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-99		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-100		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-101		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6G of 47G

101	7.2.7 (a,b,c)	SS-101-3		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	SS-101-4		70348				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TI-AW-1		70348	AW271-1 / EE-00499		236° F	SR: N/A CR: N/A
101	7.2.9	LDE-101-2	11.4	70348	AW006-1 / EE-00891			SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-2	11.4	70348	AW006-2 / EE-00088			SR: "CONT" CR: QUARTERLY
101	7.2.9	LDK-101-2	11.4	70348	AW006-4 / EE-00086			SR: N/A CR: QUARTERLY
101	7.2.9	LDE-101-3	11.4	70348	AW007-1 / EE-00874			SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-3	11.4	70348	AW007-2 / EE-00069			SR: "CONT" CR: QUARTERLY
101	7.2.9	LDK-101-3	11.4	70348	AW007-4 / EE-00101			SR: N/A CR: QUARTERLY
101	7.2.9	LDE-101-4	11.4	70348	AW008-1 / EE-00875			SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-4	11.4	70348	AW008-2 / EE-00049			SR: "CONT" CR: QUARTERLY
101	7.2.9	LDK-101-4	11.4	70348	AW008-4 / EE-00061			SR: N/A CR: QUARTERLY
101	7.2.9	LDA-101-1	11.4	70348	AW006-5 / EE-00843			SR: N/A CR: MONTHLY
101	7.2.9	RAN-EXH-101-1	11.4	70351	YAW04-1 / EE-00947			SR: "CONT" CR: MONTHLY
101	7.2.9	RA-EXH-101-1	11.4	70351	AW259-4 / EE-01273			SR: N/A CR: MONTHLY
101	7.2.9	RR-EXH-101	11.4	70351	AW015-3 / EE-01416			SR: "CONT" CR: MONTHLY
101	7.2.9	RA-EXH-101-2	11.4	70351				SR: N/A CR: MONTHLY
101	7.2.9	CVT-EXH-101-1	11.4	70351	AW015-2 / EE-00369			SR: N/A CR: MONTHLY
101	7.3.1.A	DPI-8		70336	AW128-2 / EE-00397		≤ 5.9"	SR: N/A CR: N/A
101	31.2.2.2	LDE-101-2		70348	AW006-1 / EE-00891	1/8"+3/8-1/8"		SR: N/A CR: N/A
101	31.2.2.2	LDE-101-3		70348	AW007-1 / EE-00874	1/8"+3/8-1/8"		SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 7G of 47G

101	31.2.2.2	LDE-101-4		70348	AW008-1 / EE-00875	1/8"+3/8-1/8"		SR: N/A CR: N/A
101	31.2.2.2	LDA-101-1		70348	AW006-5 / EE-00843			SR: "CONT" CR: N/A
101	31.2.2.2	RAN-EXH-101-1		70351	YAW04-1 / EE-00947			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 8G of 47G

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.2.a	LE-102-1	11.5	70349	AW088-1 / EE-00713			SR: N/A CR: N/A
102	7.2.2.a	LIT-102-1	11.5	70349	AW088-2 / EE-00800		422", 6"	SR: DAILY CR: N/A
102	7.2.2.a	LE-102-2		70349	AW087-1 / EE-00091			SR: N/A CR: N/A
102	7.2.2.a	LAK-102-1		70349	AW087-2 / EE-00089	419"		SR: N/A CR: N/A
102	7.2.2.a	LA-102-1		70349	AW087-3 / EE-00854			SR: N/A CR: N/A
102	7.2.2.a	LE-102-3		70349	AW218-1 / EE-00090			SR: N/A CR: N/A
102	7.2.2.a	LLI-102-3		70349	AW218-2 / EE-00104			SR: N/A CR: N/A
102	7.2.2.b	WFT-02C-1		70349	AW052-1 / EE-00568			SR: N/A CR: N/A
102	7.2.2.b	WFI-02C-1		70349	AW052-3 / EE-00449		≤66"	SR: N/A CR: N/A
102	7.2.2.b	WFT-02C-2		70349	AW053-1 / EE-00564			SR: N/A CR: N/A
102	7.2.2.b	WFAS-02C-1		70349	AW053-2 / EE-00584	36"		SR: N/A CR: N/A
102	7.2.2.b	WFA-02C-1		70349	AW053-3 / EE-00007			SR: N/A CR: N/A
102	7.2.2.b	FI-02C-1		70349	AW181-3 / EE-00692			SR: N/A CR: N/A
102	7.2.2.b	FI-02C-3		70349	AW181-5 / EE-00694			SR: N/A CR: N/A
102	7.2.5 (a,b,c,d)	PT-102-2	11.6	70349	AW056-1 / EE-00554		-6", 5"	SR: N/A CR: ANNUALLY
102	7.2.5 (a,b,c,d)	PR-102-2	11.6	70349	AW056-2 / EE-00458			SR: "CONT" CR: ANNUALLY
102	7.2.5 (a,b,c,d)	PT-102-1	11.6	70349	AW055-1 / EE-00549		-6", 5"	SR: N/A CR: ANNUALLY
102	7.2.5 (a,b)	PAS-102-1	11.6	70349	AW055-2 / EE-01471	-4"		SR: "CONT" CR: ANNUALLY
102	7.2.5 (a,b)	PAS-102-2	11.6	70349	AW055-3 / EE-01475	-0.25"		SR: "CONT" CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 9G of 47G

102	7.2.5 (a,b)	PA-102-1	11.6	70349	AW055-5 / EE-00148			SR: N/A CR: ANNUALLY
102	7.2.5 (a,b)	PA-102-2	11.6	70349	AW055-6 / EE-00193			SR: N/A CR: ANNUALLY
102	7.2.5 (a,b,c,d)	PR-102-1	11.6	70349	AW055-4 / EE-00454			SR: "CONT" CR: ANNUALLY
102	7.2.5 (a,b)	HORN	11.6	70349				SR: N/A CR: ANNUALLY
102	7.2.5 (a,b,c,d)	FI-102-1	11.6	70349				SR: N/A CR: N/A
102	7.2.5 (a,b,c,d)	DPI-102-1		70349				SR: N/A CR: N/A
102	7.2.5 (d)	PI-2		70336	AW129-A / EE-00396			SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-36		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-37		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-38		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-39		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-40		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-41		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-42		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-43		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-44		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-45		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-46		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-47		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-48		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-49		70349				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10G of 47G

102	7.2.6 (a,b,c)	TE-102-50		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-51		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-52		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-53		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	SS-102-1		70349				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TI-AW-1		70349	AW271-1 / EE-00499		212° F	SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-27		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-28		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-29		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-30		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-31		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-32		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-33		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-34		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-35		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-54		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-55		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-56		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-57		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-58		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-59		70349				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 11G of 47G

102	7.2.7 (a,b,c)	TE-102-60		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-61		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-62		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-63		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-64		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-65		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-66		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-67		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-68		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-69		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-70		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-71		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-72		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-73		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-74		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-75		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-76		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-77		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-78		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-79		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-80		70349				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 12G of 47G

102	7.2.7 (a,b,c)	TE-102-81		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-82		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-83		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-84		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-85		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-86		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-87		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-88		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-89		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-90		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-91		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-92		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-93		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-94		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-95		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-96		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-97		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-98		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-99		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-100		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-101		70349				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 13G of 47G

102	7.2.7 (a,b,c)	SS-102-3		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	SS-102-4		70349				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TI-AW-1		70349	AW271-1 / EE-00499		236° F	SR: N/A CR: N/A
102	7.2.9	LDE-102-2	11.4	70349	AW028-1 / EE-00907			SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-2	11.4	70349	AW028-2 / EE-00055			SR: "CONT" CR: QUARTERLY
102	7.2.9	LDK-102-2	11.4	70349	AW028-4 / EE-00058			SR: N/A CR: QUARTERLY
102	7.2.9	LDE-102-3	11.4	70349	AW029-1 / EE-00881			SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-3	11.4	70349	AW029-2 / EE-00087			SR: "CONT" CR: QUARTERLY
102	7.2.9	LDK-102-3	11.4	70349	AW029-4 / EE-00070			SR: N/A CR: QUARTERLY
102	7.2.9	LDE-102-4	11.4	70349	AW030-1 / EE-00882			SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-4	11.4	70349	AW030-2 / EE-00063			SR: "CONT" CR: QUARTERLY
102	7.2.9	LDK-102-4	11.4	70349	AW030-4 / EE-00053			SR: N/A CR: QUARTERLY
102	7.2.9	LDA-102-1	11.4	70349	AW028-5 / EE-00840			SR: N/A CR: MONTHLY
102	7.2.9	RAN-EXH-102-1	11.4	70351	YAW05-1 / EE-00932			SR: "CONT" CR: MONTHLY
102	7.2.9	RA-EXH-102-1	11.4	70351	AW260-3 / EE-01352			SR: N/A CR: MONTHLY
102	7.2.9	RR-EXH-102	11.4	70351	AW016-3 / EE-01413			SR: "CONT" CR: MONTHLY
102	7.2.9	RA-EXH-102-2	11.4	70351	AW260-2 / EE-01350			SR: N/A CR: MONTHLY
102	7.2.9	CVT-EXH-102-1	11.4	70351	AW016-2 / EE-00368			SR: N/A CR: MONTHLY
102	7.3.1.A	DPI-9		70336	AW132-Z / EE-00406		≤ 5.9"	SR: N/A CR: N/A
102	31.2.2.2	LDE-102-2		70349	AW028-1 / EE-00907	1/8"+3/8-1/8"		SR: N/A CR: N/A
102	31.2.2.2	LDE-102-3		70349	AW029-1 / EE-00881	1/8"+3/8-1/8"		SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 14G of 47G

102	31.2.2.2	LDE-102-4		70349	AW030-1 / EE-00882	1/8"+3/8-1/8"		SR: N/A CR: N/A
102	31.2.2.2	LDA-102-1		70349	AW028-5 / EE-00840			SR: "CONT" CR: N/A
102	31.2.2.2	RAN-EXH-102-1		70351	YAW05-1 / EE-00932		≤5.9"	SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 156 of 476

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	7.2.2.a	LE-103-1	11.5	70348	AW094-1 / EE-00715			SR: N/A CR: N/A
103	7.2.2.a	LIT-103-1	11.5	70348	AW094-2 / EE-00792		422", 6"	SR: DAILY CR: N/A
103	7.2.2.a	LE-103-2		70348	AW098-1 / EE-00056			SR: N/A CR: N/A
103	7.2.2.a	LAK-103-1		70348	AW098-2 / EE-00072	419"		SR: N/A CR: N/A
103	7.2.2.a	LA-103-1		70348	AW098-3 / EE-00819			SR: N/A CR: N/A
103	7.2.2.a	LE-103-3		70348	AW219-1 / EE-00100			SR: N/A CR: N/A
103	7.2.2.a	LLI-103-3		70348	AW219-2 / EE-00105			SR: N/A CR: N/A
103	7.2.2.b	WFT-03C-1		70348	AW038-1 / EE-00563			SR: N/A CR: N/A
103	7.2.2.b	WFI-03C-1		70348	AW041-3 / EE-00445		≤66"	SR: N/A CR: N/A
103	7.2.2.b	WFT-03C-2		70348	AW041-1 / EE-00553			SR: N/A CR: N/A
103	7.2.2.b	WFAS-03C-1		70348	AW041-2 / EE-00574	36"		SR: N/A CR: N/A
103	7.2.2.b	WFA-03C-1		70348	AW041-4 / EE-00001			SR: N/A CR: N/A
103	7.2.2.b	FI-03C-1		70348	AW177-3 / EE-00689			SR: N/A CR: N/A
103	7.2.2.b	FI-03C-3		70348	AW177-5 / EE-00691			SR: N/A CR: N/A
103	7.2.5 (a,b,c,d)	PT-103-2	11.6	70348	AW050-1 / EE-00550		-6", 5"	SR: N/A CR: ANNUALLY
103	7.2.5 (a,b,c,d)	PR-103-2	11.6	70348	AW050-2 / EE-00456			SR: "CONT" CR: ANNUALLY
103	7.2.5 (a,b,c,d)	PT-103-1	11.6	70348	AW047-1 / EE-00562		-6", 5"	SR: N/A CR: ANNUALLY
103	7.2.5 (a,b)	PAS-103-1	11.6	70348	AW047-2 / EE-01473	-4"		SR: "CONT" CR: ANNUALLY
103	7.2.5 (a,b)	PAS-103-2	11.6	70348	AW047-3 / EE-01478	-0.25"		SR: "CONT" CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 16G of 47G

103	7.2.5 (a,b)	PA-103-1	11.6	70348	AW047-5 / EE-01265			SR: N/A CR: ANNUALLY
103	7.2.5 (a,b)	PA-103-2	11.6	70348	AW047-6 / EE-00184			SR: N/A CR: ANNUALLY
103	7.2.5 (a,b,c,d)	PR-103-1	11.6	70348	AW047-4 / EE-00463			SR: "CONT" CR: ANNUALLY
103	7.2.5 (a,b)	HORN	11.6	70348				SR: N/A CR: ANNUALLY
103	7.2.5 (a,b,c,d)	FI-103-1	11.6	70348				SR: N/A CR: N/A
103	7.2.5 (a,b,c,d)	DPI-103-1		70348				SR: N/A CR: N/A
103	7.2.5 (d)	PI-3		70336	AW125-B / EE-00405			SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-36		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-37		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-38		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-39		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-40		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-41		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-42		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-43		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-44		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-45		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-46		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-47		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-48		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-49		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 17G of 47G

103	7.2.6 (a,b,c)	TE-103-50		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-51		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-52		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TE-103-53		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	SS-103-1		70348				SR: N/A CR: N/A
103	7.2.6 (a,b,c)	TI-AW-1		70348	AW271-1 / EE-00499		212° F	SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-27		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-28		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-29		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-30		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-31		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-32		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-33		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-34		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-35		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-54		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-55		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-56		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-57		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-58		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-59		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 18G of 47G

103	7.2.7 (a,b,c)	TE-103-60		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-61		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-62		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-63		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-64		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-65		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-66		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-67		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-68		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-69		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-70		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-71		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-72		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-73		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-74		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-75		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-76		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-77		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-78		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-79		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-80		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 19G of 47G

103	7.2.7 (a,b,c)	TE-103-81		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-82		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-83		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-84		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-85		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-86		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-87		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-88		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-89		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-90		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-91		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-92		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-93		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-94		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-95		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-96		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-97		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-98		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-99		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-100		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TE-103-101		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 20G of 47G

103	7.2.7 (a,b,c)	SS-103-3		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	SS-103-4		70348				SR: N/A CR: N/A
103	7.2.7 (a,b,c)	TI-AW-1		70348	AW271-1 / EE-00499		236° F	SR: N/A CR: N/A
103	7.2.9	LDE-103-2	11.4	70348	AW009-1 / EE-00876			SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-2	11.4	70348	AW009-2 / EE-00060			SR: "CONT" CR: QUARTERLY
103	7.2.9	LDK-103-2	11.4	70348	AW009-4 / EE-00081			SR: N/A CR: QUARTERLY
103	7.2.9	LDE-103-3	11.4	70348	AW010-1 / EE-00877			SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-3	11.4	70348	AW010-2 / EE-00099			SR: "CONT" CR: QUARTERLY
103	7.2.9	LDK-103-3	11.4	70348	AW010-4 / EE-00097			SR: N/A CR: QUARTERLY
103	7.2.9	LDE-103-4	11.4	70348	AW011-1 / EE-00878			SR: N/A CR: QUARTERLY
103	7.2.9	LDI-103-4	11.4	70348	AW011-2 / EE-00054			SR: "CONT" CR: QUARTERLY
103	7.2.9	LDK-103-4	11.4	70348	AW011-4 / EE-00064			SR: N/A CR: QUARTERLY
103	7.2.9	LDA-103-1	11.4	70348	AW009-5 / EE-00820			SR: N/A CR: MONTHLY
103	7.2.9	RAN-EXH-103-1	11.4	70351	YAW06-1 / EE-00929			SR: "CONT" CR: MONTHLY
103	7.2.9	RA-EXH-103-1	11.4	70351	AW261-3 / EE-01353			SR: N/A CR: MONTHLY
103	7.2.9	RR-EXH-103	11.4	70351	AW017-3 / EE-01414			SR: "CONT" CR: MONTHLY
103	7.2.9	RA-EXH-103-2	11.4	70351	AW261-2 / EE-01274			SR: N/A CR: MONTHLY
103	7.2.9	CVT-EXH-103-1	11.4	70351	AW017-2 / EE-00362			SR: N/A CR: MONTHLY
103	7.3.1.A	DPI-10		70336	AW136-2 / EE-00392		≤ 5.9"	SR: N/A CR: N/A
103	31.2.2.2	LDE-103-2		70348	AW009-1 / EE-00876	1/8"+3/8-1/8"		SR: N/A CR: N/A
103	31.2.2.2	LDE-103-3		70348	AW010-1 / EE-00877	1/8"+3/8-1/8"		SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 21G of 47G

103	31.2.2.2	LDE-103-4		70348	AW011-1 / EE-00878	1/8"+3/8-1/8"		SR: N/A CR: N/A
103	31.2.2.2	LDA-103-1		70348	AE009-5 / EE-00820			SR: "CONT" CR: N/A
103	31.2.2.2	RAN-EXH-103-1		70351	YAW06-1 / EE-00929			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 22G of 47G

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
104	7.2.2.a	LE-104-1	11.5	70348	AW095-1 / EE-00717			SR: N/A CR: N/A
104	7.2.2.a	LIT-104-1	11.5	70348	AW095-2 / EE-00796		422", 6"	SR: DAILY CR: N/A
104	7.2.2.a	LE-104-2		70348	AW099-1 / EE-00073			SR: N/A CR: N/A
104	7.2.2.a	LAK-104-1		70348	AW099-2 / EE-00062	419"		SR: N/A CR: N/A
104	7.2.2.a	LA-104-1		70348	AW099-3 / EE-01321			SR: N/A CR: N/A
104	7.2.2.a	LE-104-3		70348	AW220-1 / EE-00057			SR: N/A CR: N/A
104	7.2.2.a	LLI-104-3		70348	AW220-2 / EE-00106			SR: N/A CR: N/A
104	7.2.2.b	WFT-04C-1		70348	AW039-1 / EE-00558			SR: N/A CR: N/A
104	7.2.2.b	WFI-04C-1		70348	AW042-3 / EE-00446		≤66"	SR: N/A CR: N/A
104	7.2.2.b	WFT-04C-2		70348	AW042-1 / EE-00545			SR: N/A CR: N/A
104	7.2.2.b	WFAS-04C-1		70348	AW042-2 / EE-00588	36"		SR: N/A CR: N/A
104	7.2.2.b	WFA-04C-1		70348	AW042-4 / EE-00003			SR: N/A CR: N/A
104	7.2.2.b	FI-04C-1		70348	AW178-3 / EE-00688			SR: N/A CR: N/A
104	7.2.2.b	FI-04C-3		70348	AW178-5 / EE-00698			SR: N/A CR: N/A
104	7.2.5 (a,b,c,d)	PT-104-2	11.6	70348	AW051-1 / EE-00546		-6", 5"	SR: N/A CR: ANNUALLY
104	7.2.5 (a,b,c,d)	PR-104-2	11.6	70348	AW051-2 / EE-00464			SR: "CONT" CR: ANNUALLY
104	7.2.5 (a,b,c,d)	PT-104-1	11.6	70348	AW048-1 / EE-00552		-6", 5"	SR: N/A CR: ANNUALLY
104	7.2.5 (a,b)	PAS-104-1	11.6	70348	AW048-2 / EE-01474	-4"		SR: "CONT" CR: ANNUALLY
104	7.2.5 (a,b)	PAS-104-2	11.6	70348	AW048-3 / EE-01477	-0.25"		SR: "CONT" CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 23G of 47G

104	7.2.5 (a,b)	PA-104-1	11.6	70348	AW048-5 / EE-01121			SR: N/A CR: ANNUALLY
104	7.2.5 (a,b)	PA-104-2	11.6	70348	AW048-6 / EE-01058			SR: N/A CR: ANNUALLY
104	7.2.5 (a,b,c,d)	PR-104-1	11.6	70348	AW048-4 / EE-00453			SR: "CONT" CR: ANNUALLY
104	7.2.5 (a,b)	HORN	11.6	70348				SR: N/A CR: ANNUALLY
104	7.2.5 (a,b,c,d)	FI-104-1	11.6	70348				SR: N/A CR: N/A
104	7.2.5 (a,b,c,d)	DPI-104-1		70348				SR: N/A CR: N/A
104	7.2.5 (d)	PI-4		70336	AW129-B / EE-00393			SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-36		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-37		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-38		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-39		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-40		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-41		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-42		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-43		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-44		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-45		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-46		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-47		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-48		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-49		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 24G of 47G

104	7.2.6 (a,b,c)	TE-104-50		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-51		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-52		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TE-104-53		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	SS-104-1		70348				SR: N/A CR: N/A
104	7.2.6 (a,b,c)	TI-AW-2		70348	AW272-1 / EE-00498		212° F	SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-27		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-28		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-29		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-30		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-31		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-32		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-33		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-34		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-35		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-54		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-55		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-56		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-57		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-58		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-59		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 25G of 47G

104	7.2.7 (a,b,c)	TE-104-60		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-61		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-62		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-63		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-64		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-65		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-66		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-67		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-68		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-69		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-70		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-71		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-72		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-73		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-74		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-75		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-76		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-77		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-78		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-79		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-80		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 26G of 47G

104	7.2.7 (a,b,c)	TE-104-81		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-82		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-83		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-84		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-85		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-86		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-87		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-88		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-89		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-90		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-91		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-92		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-93		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-94		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-95		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-96		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-97		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-98		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-99		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-100		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TE-104-101		70348				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 27G of 47G

104	7.2.7 (a,b,c)	SS-104-3		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	SS-104-4		70348				SR: N/A CR: N/A
104	7.2.7 (a,b,c)	TI-AW-2		70348	AW272-1 / EE-00498		236° F	SR: N/A CR: N/A
104	7.2.9	LDE-104-2	11.4	70348	AW012-1 / EE-00893			SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-2	11.4	70348	AW012-2 / EE-00085			SR: "CONT" CR: QUARTERLY
104	7.2.9	LDK-104-2	11.4	70348	AW012-4 / EE-00076			SR: N/A CR: QUARTERLY
104	7.2.9	LDE-104-3	11.4	70348	AW013-1 / EE-00879			SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-3	11.4	70348	AW013-2 / EE-00052			SR: "CONT" CR: QUARTERLY
104	7.2.9	LDK-104-3	11.4	70348	AW013-4 / EE-00095			SR: N/A CR: QUARTERLY
104	7.2.9	LDE-104-4	11.4	70348	AW014-1 / EE-00880			SR: N/A CR: QUARTERLY
104	7.2.9	LDI-104-4	11.4	70348	AW014-2 / EE-00092			SR: "CONT" CR: QUARTERLY
104	7.2.9	LDK-104-4	11.4	70348	AW014-4 / EE-00084			SR: N/A CR: QUARTERLY
104	7.2.9	LDA-104-1	11.4	70348	AW012-5 / EE-00818			SR: N/A CR: MONTHLY
104	7.2.9	RAN-EXH-104-1	11.4	70351	YAW07-1 / EE-00946			SR: "CONT" CR: MONTHLY
104	7.2.9	RA-EXH-104-1	11.4	70351	AW262-3 / EE-01226			SR: N/A CR: MONTHLY
104	7.2.9	RR-EXH-104	11.4	70351	AW018-3 / EE-01409			SR: "CONT" CR: MONTHLY
104	7.2.9	RA-EXH-104-2	11.4	70351	AW262-2 / EE-01216			SR: N/A CR: MONTHLY
104	7.2.9	CVT-EXH-104-1	11.4	70351	AW018-2 / EE-00363			SR: N/A CR: MONTHLY
104	7.3.1.A	DPI-11		70336	AW140-2 / EE-00415		≤ 5.9"	SR: N/A CR: N/A
104	31.2.2.2	LDE-104-2		70348	AW012-1 / EE-00893	1/8"+3/8-1/8"		SR: N/A CR: N/A
104	31.2.2.2	LDE-104-3		70348	AW013-1 / EE-00879	1/8"+3/8-1/8"		SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 28G of 47G

104	31.2.2.2	LDE-104-4		70348	AW014-1 / EE-00880	1/8"+3/8-1/8"		SR: N/A CR: N/A
104	31.2.2.2	LDA-104-1		70348	AW012-5 / EE-00818			SR: "CONT" CR: N/A
104	7.3.1.A	RAN-EXH-104-1		70351	YAW07-1 / EE-00946			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 29G of 47G

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	7.2.2.a	LE-105-1	11.5	70350	AW117-1 / EE-00716			SR: N/A CR: N/A
105	7.2.2.a	LIT-105-1	11.5	70350	AW117-2 / EE-00789		422", 6"	SR: DAILY CR: N/A
105	7.2.2.a	LE-105-2		70350	AW121-1 / EE-00075			SR: N/A CR: N/A
105	7.2.2.a	LAK-105-1		70350	AW121-2 / EE-00051	419"		SR: N/A CR: N/A
105	7.2.2.a	LA-105-1		70350	AW121-3 / EE-00855			SR: N/A CR: N/A
105	7.2.2.a	LE-105-3		70350	AW221-1 / EE-00066			SR: N/A CR: N/A
105	7.2.2.a	LLI-105-3		70350	AW221-2 / EE-00107			SR: N/A CR: N/A
105	7.2.2.b	WFT-05C-1		70350	AW107-1 / EE-00569			SR: N/A CR: N/A
105	7.2.2.b	WFI-05C-1		70350	AW107-3 / EE-00451		≤66"	SR: N/A CR: N/A
105	7.2.2.b	WFT-05C-2		70350	AW105-1 / EE-00556			SR: N/A CR: N/A
105	7.2.2.b	WFAS-05C-1		70350	AW105-2 / EE-00580	36"		SR: N/A CR: N/A
105	7.2.2.b	WFA-05C-1		70350	AW105-3 / EE-00005			SR: N/A CR: N/A
105	7.2.2.b	FI-05C-1		70350	AW179-3 / EE-00700			SR: N/A CR: N/A
105	7.2.2.b	FI-05C-3		70350	AW179-5 / EE-00706			SR: N/A CR: N/A
105	7.2.5 (a,b,c,d)	PT-105-2	11.6	70350	AW111-1 / EE-00567		-6", 5"	SR: N/A CR: ANNUALLY
105	7.2.5 (a,b,c,d)	PR-105-2	11.6	70350	AW111-2 / EE-00469			SR: "CONT" CR: ANNUALLY
105	7.2.5 (a,b,c,d)	PT-105-1	11.6	70350	AW109-1 / EE-00560		-6", 5"	SR: N/A CR: ANNUALLY
105	7.2.5 (a,b)	PAS-105-1	11.6	70350	AW109-2 / EE-01469	-4"		SR: "CONT" CR: ANNUALLY
105	7.2.5 (a,b)	PAS-105-2	11.6	70350	AW109-3 / EE-01476	-0.25"		SR: "CONT" CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 30G of 47G

105	7.2.5 (a,b)	PA-105-1	11.6	70350	AW109-5 / EE-00149			SR: N/A CR: ANNAALLY
105	7.2.5 (a,b)	PA-105-2	11.6	70350	AW109-6 / EE-00117			SR: N/A CR: ANNUALLY
105	7.2.5 (a,b,c,d)	PR-105-1	11.6	70350	AW109-4 / EE-00457			SR: "CONT" CR: ANNUALLY
105	7.2.5 (a,b)	HORN	11.6	70350				SR: N/A CR: ANNUALLY
105	7.2.5 (a,b,c,d)	FI-105-1	11.6	70350				SR: N/A CR: N/A
105	7.2.5 (a,b,c,d)	DPI-105-1		70350				SR: N/A CR: N/A
105	7.2.5 (d)	PI-5		70336	AW125-C / EE-00408			SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-36		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-37		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-38		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-39		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-40		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-41		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-42		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-43		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-44		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-45		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-46		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-47		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-48		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-49		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 31G of 47G

105	7.2.6 (a,b,c)	TE-105-50		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-51		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-52		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TE-105-53		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	SS-105-1		70350				SR: N/A CR: N/A
105	7.2.6 (a,b,c)	TI-AW-2		70350	AW272-1 / EE-00498		212° F	SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-27		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-28		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-29		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-30		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-31		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-32		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-33		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-34		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-35		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-54		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-55		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-56		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-57		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-58		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-59		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 32G of 47G

105	7.2.7 (a,b,c)	TE-105-60		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-61		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-62		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-63		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-64		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-65		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-66		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-67		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-68		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-69		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-70		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-71		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-72		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-73		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-74		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-75		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-76		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-77		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-78		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-79		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-80		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 33G of 47G

105	7.2.7 (a,b,c)	TE-105-81		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-82		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-83		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-84		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-85		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-86		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-87		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-88		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-89		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-90		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-91		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-92		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-93		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-94		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-95		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-96		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-97		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-98		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-99		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-100		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TE-105-101		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 34G of 47G

105	7.2.7 (a,b,c)	SS-105-3		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	SS-105-4		70350				SR: N/A CR: N/A
105	7.2.7 (a,b,c)	TI-AW-2		70350	AW272-1 / EE-00498		236° F	SR: N/A CR: N/A
105	7.2.9	LDE-105-2	11.4	70350	AW031-1 / EE-00883			SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-2	11.4	70350	AW031-2 / EE-00080			SR: "CONT" CR: QUARTERLY
105	7.2.9	LDK-105-2	11.4	70350	AW031-4 / EE-00082			SR: N/A CR: QUARTERLY
105	7.2.9	LDE-105-3	11.4	70350	AW032-1 / EE-00884			SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-3	11.4	70350	AW032-2 / EE-00083			SR: "CONT" CR: QUARTERLY
105	7.2.9	LDK-105-3	11.4	70350	AW032-4 / EE-00096			SR: N/A CR: QUARTERLY
105	7.2.9	LDE-105-4	11.4	70350	AW033-1 / EE-00885			SR: N/A CR: QUARTERLY
105	7.2.9	LDI-105-4	11.4	70350	AW033-2 / EE-00098			SR: "CONT" CR: QUARTERLY
105	7.2.9	LDK-105-4	11.4	70350	AW033-4 / EE-00071			SR: N/A CR: QUARTERLY
105	7.2.9	LDA-105-1	11.4	70350	AW031-5 / EE-00827			SR: N/A CR: MONTHLY
105	7.2.9	RAN-EXH-105-1	11.4	70351	YAW08-1 / EE-00928			SR: "CONT" CR: MONTHLY
105	7.2.9	RA-EXH-105-1	11.4	70351	AW263-3 / EE-00993			SR: N/A CR: MONTHLY
105	7.2.9	RR-EXH-105	11.4	70351	AW019-3 / EE-01411			SR: "CONT" CR: MONTHLY
105	7.2.9	RA-EXH-105-2	11.4	70351	AW263-2 / EE-01096			SR: N/A CR: MONTHLY
105	7.2.9	CVT-EXH-105-1	11.4	70351	AW019-2 / EE-00365			SR: N/A CR: MONTHLY
105	7.3.1.A	DPI-12		70336	AW144-2 / EE-00389		≤ 5.9"	SR: N/A CR: N/A
105	31.2.2.2	LDE-105-2		70350	AW031-1 / EE-00883	1/8"+3/8-1/8"		SR: N/A CR: N/A
105	31.2.2.2	LDE-105-3		70350	AW032-1 / EE-00884	1/8"+3/8-1/8"		SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

105	31.2.2.2	LDE-105-4	70350	AW033-1 / EE-00885	1/8"+3/8-1/8"	SR: N/A	CR: N/A
105	31.2.2.2	LDA-105-1	70350	AW031-5 / EE-00827		SR: "CONT"	CR: N/A
105	31.2.2.2	RAN-EXH-105-1	70351	YAW08-1 / EE-00928		SR: N/A	CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 36G of 47G

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
106	7.2.2.a	LE-106-1	11.5	70350	AW118-1 / EE-00714			SR: N/A CR: N/A
106	7.2.2.a	LIT-106-1	11.5	70350	AW118-2 / EE-00793		422", 6"	SR: N/A CR: N/A
106	7.2.2.a	LE-106-2		70350	AW122-1 / EE-00050			SR: N/A CR: N/A
106	7.2.2.a	LAK-106-1		70350	AW122-2 / EE-00078	419"		SR: N/A CR: N/A
106	7.2.2.a	LA-106-1		70350	AW122-3 / EE-00829			SR: N/A CR: N/A
106	7.2.2.a	LE-106-3		70350	AW222-1 / EE-00059			SR: N/A CR: N/A
106	7.2.2.a	LLI-106-3		70350	AW222-2 / EE-00108			SR: N/A CR: N/A
106	7.2.2.b	WFT-06C-1		70350	AW108-1 / EE-00559			SR: N/A CR: N/A
106	7.2.2.b	WFI-06C-1		70350	AW108-3 / EE-00444		≤66"	SR: N/A CR: N/A
106	7.2.2.b	WFT-06C-2		70350	AW106-1 / EE-00561			SR: N/A CR: N/A
106	7.2.2.b	WFAS-06C-1		70350	AW106-2 / EE-00578	36"		SR: N/A CR: N/A
106	7.2.2.b	WFA-06C-1		70350	AW106-3 / EE-00002			SR: N/A CR: N/A
106	7.2.2.b	FI-06C-1		70350	AW180-3 / EE-00690			SR: N/A CR: N/A
106	7.2.2.b	FI-06C-3		70350	AW180-5 / EE-00683			SR: N/A CR: N/A
106	7.2.5 (a,b,c,d)	PT-106-2	11.6	70350	AW112-1 / EE-00571		-6", 5"	SR: N/A CR: ANNUALLY
106	7.2.5 (a,b,c,d)	PR-106-2	11.6	70350	AW112-2 / EE-00459			SR: "CONT" CR: ANNUALLY
106	7.2.5 (a,b,c,d)	PT-106-1	11.6	70350	AW110-1 / EE-00547		-6", 5"	SR: N/A CR: ANNUALLY
106	7.2.5 (a,b)	PAS-106-1	11.6	70350	AW110-2 / EE-01472	-4"		SR: "CONT" CR: ANNUALLY
106	7.2.5 (a,b)	PAS-106-2	11.6	70350	AW110-3 / EE-01479	-0.25"		SR: "CONT" CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 37G of 47G

106	7.2.5 (a,b)	PA-106-1	11.6	70350	AW110-5 / EE-00165			SR: N/A CR: ANNUALLY
106	7.2.5 (a,b)	PA-106-2	11.6	70350	AW110-6 / EE-00162			SR: N/A CR: ANNUALLY
106	7.2.5 (a,b,c,d)	PR-106-1	11.6	70350	AW110-4 / EE-00460			SR: "CONT" CR: ANNUALLY
106	7.2.5 (a,b)	HORN	11.6	70350				SR: N/A CR: ANNUALLY
106	7.2.5 (a,b,c,d)	FI-106-1	11.6	70350				SR: N/A CR: N/A
106	7.2.5 (a,b,c,d)	DPI-106-1		70350				SR: N/A CR: N/A
106	7.2.5 (d)	PI-6		70336	AW129-C / EE-00399			SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-36		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-37		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-38		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-39		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-40		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-41		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-42		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-43		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-44		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-45		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-46		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-47		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-48		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-49		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 38G of 47G

106	7.2.6 (a,b,c)	TE-106-50		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-51		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-52		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TE-106-53		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	SS-106-1		70350				SR: N/A CR: N/A
106	7.2.6 (a,b,c)	TI-AW-2		70350	AW272-1 / EE-00498		212° F	SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-27		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-28		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-29		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-30		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-31		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-32		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-33		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-34		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-35		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-54		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-55		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-56		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-57		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-58		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-59		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 39G of 47G

106	7.2.7 (a,b,c)	TE-106-60		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-61		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-62		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-63		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-64		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-65		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-66		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-67		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-68		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-69		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-70		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-71		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-72		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-73		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-74		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-75		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-76		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-77		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-78		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-79		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-80		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 40G of 47G

106	7.2.7 (a,b,c)	TE-106-81		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-82		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-83		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-84		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-85		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-86		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-87		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-88		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-89		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-90		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-91		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-92		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-93		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-94		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-95		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-96		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-97		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-98		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-99		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-100		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TE-106-101		70350				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 41G of 47G

106	7.2.7 (a,b,c)	SS-106-3		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	SS-106-4		70350				SR: N/A CR: N/A
106	7.2.7 (a,b,c)	TI-AW-2		70350	AW272-1 / EE-00498		236° F	SR: N/A CR: N/A
106	7.2.9	LDE-106-2	11.4	70350	AW034-1 / EE-00888			SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-2	11.4	70350	AW034-2 / EE-00094			SR: "CONT" CR: QUARTERLY
106	7.2.9	LDK-106-2	11.4	70350	AW034-3 / EE-01752			SR: N/A CR: QUARTERLY
106	7.2.9	LDE-106-3	11.4	70350	AW035-1 / EE-00887			SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-3	11.4	70350	AW035-2 / EE-00077			SR: "CONT" CR: QUARTERLY
106	7.2.9	LDK-106-3	11.4	70350	AW035-4 / EE-00074			SR: N/A CR: QUARTERLY
106	7.2.9	LDE-106-4	11.4	70350	AW036-1 / EE-00886			SR: N/A CR: QUARTERLY
106	7.2.9	LDI-106-4	11.4	70350	AW036-2 / EE-00079			SR: "CONT" CR: QUARTERLY
106	7.2.9	LDK-106-4	11.4	70350	AW036-4 / EE-00093			SR: N/A CR: QUARTERLY
106	7.2.9	LDA-106-1	11.4	70350	AW034-5 / EE-00837			SR: N/A CR: MONTHLY
106	7.2.9	RAN-EXH-106-1	11.4	70351	YAW09-1 / EE-00935			SR: "CONT" CR: MONTHLY
106	7.2.9	RA-EXH-106-1	11.4	70351	AW264-3 / EE-01275			SR: N/A CR: MONTHLY
106	7.2.9	RR-EXH-106	11.4	70351	AW020-3 / EE-01410			SR: "CONT" CR: MONTHLY
106	7.2.9	RA-EXH-106-2	11.4	70351	AW264-2 / EE-01193			SR: N/A CR: MONTHLY
106	7.2.9	CVT-EXH-106-1	11.4	70351	AW020-2 / EE-00364			SR: N/A CR: MONTHLY
106	7.3.1.A	DPI-13		70336	AW148-2 / EE-00414		≤ 5.9"	SR: N/A CR: N/A
106	31.2.2.2	LDE-106-2		70350	AW034-1 / EE-00888	1/8"+3/8-1/8"		SR: N/A CR: N/A
106	31.2.2.2	LDE-106-3		70350	AW035-1 / EE-00887	1/8"+3/8-1/8"		SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

106	31.2.2.2	LDE-106-4		70350	AW036-1 / EE-00886	1/8"+3/8-1/8"	SR: N/A	CR: N/A
106	31.2.2.2	LDA-106-1		70350	AW034-5 / EE-00887		SR: "CONT"	CR: N/A
106	31.2.2.2	RAN-EXH-106-1		70351	YAW09-1 / EE-00935		SR: N/A	CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 43G of 47G

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K1	7.3.1.A.1.a	DPIS-2		90905	AW150-5 / EE-00474		≤5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.a	DPIS-5		90905	AW155-2 / EE-00479		≤5.9"	SR: DAILY CR: N/A
K1	7.3.1.A.1.b	DPIS-1		90905	AW150-3 / EE-00482		≤4.0"	SR: DAILY CR: N/A
K1	7.3.1.A.1.b	DPIS-4		90905	AW156-1 / EE-00476		≤4.0"	SR: DAILY CR: N/A
K1	7.3.1.A	DPA-1		90905				SR: N/A CR: N/A
K1	7.3.1.A	DPA-6		90905				SR: N/A CR: N/A
K1	7.3.1.B	TI-2		90905	AW151-1 / EE-01587		230° F	SR: N/A CR: N/A
K1	7.3.1.B	TI-8		90905	AW156-2 / EE-00917		230° F	SR: N/A CR: N/A
K1	7.3.1.B	DTC-K1-2-1		90905	AW153-5 / EE-00500			SR: N/A CR: N/A
K1	7.3.1.B	DTA-K1-2-1		90905	AW153-7 / EE-02076			SR: N/A CR: N/A
K1	7.3.1.B	DTC-K1-2-2		90905	AW158-5 / EE-00282			SR: N/A CR: N/A
K1	7.3.1.B	DTA-K1-2-2		90905	AW158-7 / EE-01427			SR: N/A CR: N/A
K1	7.3.1.D	TI-1		90905	AW152-1 / EE-01586			SR: DAILY CR: N/A
K1	7.3.1.D	TI-2		90905	AW151-1 / EE-01587			SR: DAILY CR: N/A
K1	7.3.1.D	DTC-K1-2-1		90905	AW153-5 / EE-00500			SR: N/A CR: N/A
K1	7.3.1.D	DTA-K1-2-1		90905	AW153-7 / EE-02076			SR: N/A CR: N/A
K1	7.3.1.D	TI-7		90905	AW157-1 / EE-01585			SR: DAILY CR: N/A
K1	7.3.1.D	TI-8		90905	AW156-2 / EE-00917			SR: DAILY CR: N/A
K1	7.3.1.D	DTC-K1-2-2		90905	AW158-5 / EE-00282			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 44G of 47G

K1	7.3.1.D	DTA-K1-2-2		90905	AW158-7 / EE-01427			SR: N/A CR: N/A
K1	7.3.1.E	RAN-EXH-K1-1		74896	YAW02-1 / EE-00942			SR: N/A CR: N/A
K1	7.3.1.E	FAS-EXH-K1-2		74896	AW021-P / EE-00610			SR: N/A CR: N/A
K1	7.3.1.E	FA-EXH-K1-2		74896				SR: N/A CR: N/A
K1	7.3.1.E	CVT-EXH-K1-1		74896	AW021-3 / EE-00367			SR: N/A CR: N/A
K1	7.3.1.E	RR-EXH-K1-1		74896	AW021-4 / EE-01415			SR: N/A CR: N/A
K1	7.3.1.E	RA-EXH-K1-1		74896				SR: N/A CR: N/A
K1	7.3.1.E	XA-EXH-K1-A-1		74896				SR: N/A CR: N/A
K1	7.3.1.E	RA-EXH-K1-3		74896				SR: N/A CR: N/A
K1	7.3.1.E	XA-EXH-K1-A-2		74896				SR: N/A CR: N/A
K1	7.3.1.E	RA-EXH-K1-2		74896				SR: N/A CR: N/A
K1	7.3.1.E	XA-EXH-K1-1		74896				SR: N/A CR: N/A
K1	7.3.1.E	FI-EXH-K1-1		74896	AW021-A / EE-00696			SR: N/A CR: N/A
K1	7.3.1.E	FQI-EXH-K1-1		74896	AW021-B / EE-01392			SR: N/A CR: N/A
K1	7.3.1.E	FAS-EXH-K1-1		74896	AW021-M / EE-00612			SR: N/A CR: N/A
K1	7.3.1.E	FA-EXH-K1-1		74896				SR: N/A CR: N/A
K1	7.3.1.E	PI-EXH-K1-1		74896	AW021-C / EE-02094			SR: N/A CR: N/A
K1	7.3.1.E	PI-EXH-K1-2		74896	AW021-L / EE-02096			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 45G of 47G

K1	7.3.1.E	RECORD SAMPLER		74896				SR: N/A CR: N/A
K1	7.3.2	see OSD 7.2.5 (a,c)						SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 46G of 47G

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
K2	7.3.1.A.1.a	DPI-15		74336	AW126-1 / EE-00391		≤5.9"	SR: DAILY CR: N/A
K2	7.3.1.A.1.a	DPI-22		74336	AW138-2 / EE-00388		≤5.9"	SR: DAILY CR: N/A
K2	7.3.1.A.1.b	DPI-16		74336	AW138-1 / EE-00403		≤4.0"	SR: DAILY CR: N/A
K2	7.3.1.A.1.b	DPI-21		74336	AW126-2 / EE-00398		≤4.0"	SR: DAILY CR: N/A
K2	7.3.1.B	TI-4		74336	AW130-3 / EE-01588		230° F	SR: DAILY CR: N/A
K2	7.3.1.B	TI-6		74336	AW141-3 / EE-00721		230° F	SR: DAILY CR: N/A
K2	7.3.1.B	TC-2		74336	AW130-1 / EE-01761			SR: N/A CR: N/A
K2	7.3.1.B	TC-3		74336	AW141-1 / EE-00217			SR: N/A CR: N/A
K2	7.3.1.D	TI-4		74336	AW130-3 / EE-01588			SR: DAILY CR: N/A
K2	7.3.1.D	TI-6		74336	AW141-3 / EE-00721			SR: DAILY CR: N/A
K2	7.3.1.D	TC-2		74336	AW130-1 / EE-01761			SR: N/A CR: N/A
K2	7.3.1.D	TC-3		74336	AW141-1 / EE-00217			SR: N/A CR: N/A
K2	7.3.1.D	TI-3		74336	AW130-2 / EE-01312			SR: DAILY CR: N/A
K2	7.3.1.D	TI-5		74336	AW141-2 / EE-00720			SR: DAILY CR: N/A
K2	7.3.1.E	CVT-EXH-K2-1		74897	AW022-3 / EE-00366			SR: N/A CR: N/A
K2	7.3.1.E	RR-EXH-K2		74897	AW022-4 / EE-01412			SR: N/A CR: N/A
K2	7.3.1.E	RA-EXH-K2		74897				SR: N/A CR: N/A
K2	7.3.1.E	FA-EXH-K2		74897				SR: N/A CR: N/A
K2	7.3.1.E	RAN-EXH-K2-1		74897	YAW03-1 / EE-00924			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 47G of 47G

K2	7.3.1.E	FAS-EXH-K2-2		74897	AW022-M / EE-00622			SR: N/A	CR: N/A
K2	7.3.1.E	FA-EXH-K2-2		74897				SR: N/A	CR: N/A
K2	7.3.1.E	XA-EXH-K2-2		74897				SR: N/A	CR: N/A
K2	7.3.1.E	FI-EXH-K2-1		74897	AW022-A / EE-00687			SR: N/A	CR: N/A
K2	7.3.1.E	FQI-EXH-K2-1		74897	AW022-B / EE-01390			SR: N/A	CR: N/A
K2	7.3.1.E	FAS-EXH-K2-1		74897	AW022-D / EE-00617			SR: N/A	CR: N/A
K2	7.3.1.E	FA-EXH-K2-1		74897				SR: N/A	CR: N/A
K2	7.3.1.E	RA-EXH-K2-2		74897				SR: N/A	CR: N/A
K2	7.3.1.E	RECORD SAMPLER		74897				SR: N/A	CR: N/A
K2	7.3.1.E	PI-EXH-K2-1		74897	AW022-C / EE-02093			SR: N/A	CR: N/A
K2	7.3.1.E	PI-EXH-K2-2		74897	AW022-L / EE-02095			SR: N/A	CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1H of 1H

241-AX

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	13.2.1.B	LIT-101-AX		36382	AX179-1 / ET-01375		360"	SR: N/A CR: N/A
101	13.2.1.B	LIQUID OBSRVATION WELL		93715				SR: N/A CR: N/A
101	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
101	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG		SR: 10 DAYS CR: N/A
101	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
102	13.2.1.B	MAN. TAPE-LIQUID LVL		95331			360"	SR: N/A CR: N/A
102	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
102	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
102	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
103	13.2.1.B	LIT-103-AX		36382	AX180-1 / ET-01374		360"	SR: N/A CR: N/A
103	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	90342			300°F LCO=350°F	SR: 25 DAYS CR: N/A
103	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG		SR: 10 DAYS CR: N/A
103	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
104	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			360"	SR: N/A CR: N/A
104	13.2.1.E	THERMOCOUPLE TREE	11.4.2.1	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
104	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG		SR: 10 DAYS CR: N/A
104	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 11 of 111

241-AY-101

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.2.a	LIAS-101-1	11.13	64400 sh5	AY068-3 / ET-00455	360"		SR: N/A CR: SEMI-ANN
101	7.2.2.a	LLE-101-1	11.13	64400 sh5	AY068-1 / ET-00477			SR: N/A CR: SEMI-ANN
101	7.2.2.a	LLK-101-1	11.13	64400 sh5				SR: N/A CR: SEMI-ANN
101	7.2.2.a	LLA-101-1	11.13	64400 sh5	AY068-4 / ET-01943			SR: N/A CR: SEMI-ANN
101	7.2.2.a	LLI-101-2	11.13	64400 sh5	AY071-2 / ET-00388		364", 64"	SR: DAILY CR: SEMI-ANN
101	7.2.2.a	LLE-101-2	11.13	64400 sh5	AY071-1 / ET-00516			SR: N/A CR: SEMI-ANN
101	7.2.2.a	LIT-101-AY	11.13	64400 sh4	AY085-1 / ET-01357		364", 64"	SR: DAILY CR: SEMI-ANN
101	7.2.2.b	WFT-101A-1		64400 sh5	AY046-1 / ET-01168			SR: N/A CR: N/A
101	7.2.2.b	WFT-101A		64400 sh5	AY047-1 / ET-01171			SR: N/A CR: N/A
101	7.2.2.b	SGT-101A		64400 sh3	AY048-1 / ET-01166			SR: N/A CR: N/A
101	7.2.2.b	SGI-101A-1		64400 sh3	AY048-2 / ET-00848			SR: N/A CR: N/A
101	7.2.2.b	FI-101A-26		64400 sh3	AY049-1 / ET-04715			SR: N/A CR: N/A
101	7.2.2.b	FI-101A-27		64400 sh3	AY049-2 / ET-04717			SR: N/A CR: N/A
101	7.2.2.b	FI-101A-28		64400 sh3	AY049-3 / ET-04769			SR: N/A CR: N/A
101	7.2.2.b	WFI-101A-1		64400 sh3	AY047-2 / ET-00841		≤ 79"	SR: N/A CR: N/A
101	7.2.2.b	WFR-101		64400 sh3	AY047-3 / ET-00784			SR: N/A CR: N/A
101	7.2.2.b	WFAS-101A-1		64400 sh3	AY046-2 / ET-01058	36"		SR: N/A CR: N/A
101	7.2.2.b	WFA-101A-1		64400 sh3	AY046-3 / ET-01964			SR: N/A CR: N/A
101	7.2.2.c	WFT-101B	11.8	64400 sh3	AY092-1 / ET-01170			SR: N/A CR: N/A
101	7.2.2.c	SGT-101-B	11.8	64400 sh3	AY094-1 / ET-01169			SR: N/A CR: N/A
101	7.2.2.c	SGI-101B-1	11.8	64400 sh3	AY094-2 / ET-00840			SR: N/A CR: N/A
101	7.2.2.c	FI-101B-26	11.8	64400 sh3	AY093-1 / ET-04701			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2I of 11I

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.2.c	FI-101B-27	11.8	64400 sh3	AY093-2 / ET-04710			SR: N/A CR: N/A
101	7.2.2.c	FI-101B-28	11.8	64400 sh3	AY093-3 / ET-04757			SR: N/A CR: N/A
101	7.2.2.c	WFI-101B-1	11.8	64400 sh3	AY092-2 / ET-00846			SR: N/A CR: N/A
101	7.2.2.c	WFAS-101B-1	11.8	64400 sh3	AY092-3 / ET-01073		≤ 408"	SR: N/A CR: N/A
101	7.2.2.c	WFA-101B	11.8	64400 sh3	AY092-4 / ET-02011			SR: N/A CR: N/A
101	7.2.3	LLI-101-2	11.4	64400 sh5	AY071-2 / ET-00388		≥ 0"	SR: CONT CR: N/A
101	7.2.3	LLE-101-2	11.4	64400 sh5	AY071-1 / ET-00516			SR: N/A CR: N/A
101	7.2.3	LIT-101-AY	11.4	64400 sh4	AY085-1 / ET-01357		≥ 0"	SR: CONT CR: N/A
101	7.2.3	PT-101-1	11.4	64400 sh5	AY063-1 / ET-01164			SR: N/A CR: ANNUALLY
101	7.2.3	PAS-101-2	11.4	64400 sh5	AY063-3 / ET-01030			SR: CONT CR: ANNUALLY
101	7.2.3	PA-101-2	11.4	64400 sh5	AY063-4 / ET-01838			SR: CONT CR: ANNUALLY
101	7.2.3	PR-101-1	11.4	64400 sh6	AY064-2 / ET-00783			SR: CONT CR: ANNUALLY
101	7.2.3	PT-101-2	11.4	64400 sh5	AY064-1 / ET-01163			SR: N/A CR: ANNUALLY
101	7.2.3	PR-101-2	11.4	64400 sh6	AY063-2 / ET-00796			SR: CONT CR: ANNUALLY
101	7.2.5.a	FI-101-25		64400 sh5	AY065-1 / ET-04703			SR: N/A CR: N/A
101	7.2.5.a	PT-101-1		64400 sh5	AY063-1 / ET-01164		5", -6"	SR: N/A CR: N/A
101	7.2.5.a	PT-101-2		64400 sh5	AY064-1 / ET-01163		5", -6"	SR: N/A CR: N/A
101	7.2.5.a	PAS-101-1		64400 sh5	AY064-3 / ET-01001	-0.25"		SR: N/A CR: N/A
101	7.2.5.a	PAS-101-2		64400 sh5	AY063-3 / ET-01030	-3"		SR: N/A CR: N/A
101	7.2.5.a	PA-101-1		64400 sh5	AY064-4 / ET-02023			SR: N/A CR: N/A
101	7.2.5.a	PA-101-2		64400 sh5	AY063-4 / ET-01838			SR: N/A CR: N/A
101	7.2.5.a	PR-101-1		64400 sh6	AY064-2 / ET-00783			SR: N/A CR: N/A
101	7.2.5.a	PR-101-2		64400 sh6	AY063-2 / ET-00796			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3I of 11I

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.5.a	PI-TK-101-AY		64400 sh4	AY164-1 / ET-01679		5", -6"	SR: N/A CR: N/A
101	7.2.5.b	PT-101-1	11.7	64400 sh5	AY063-1 / ET-01164			SR: N/A CR: ANNUALLY
101	7.2.5.b	PAS-101-1	11.7	64400 sh5	AY064-3 / ET-01001	-0.25"		SR: CONT CR: ANNUALLY
101	7.2.5.b	PAS-101-2	11.7	64400 sh5	AY063-3 / ET-01030	-3"		SR: CONT CR: ANNUALLY
101	7.2.5.b	PA-101-1	11.7	64400 sh5	AY064-4 / ET-02023			SR: N/A CR: ANNUALLY
101	7.2.5.b	PA-101-2	11.7	64400 sh5	AY063-4 / ET-01838			SR: N/A CR: ANNUALLY
101	7.2.5.b	PR-101-1	11.7	64400 sh6	AY064-2 / ET-00783			SR: N/A CR: ANNUALLY
101	7.2.5.b	PR-101-2	11.7	64400 sh6	AY063-2 / ET-00796			SR: N/A CR: ANNUALLY
101	7.2.5.b	HORN	11.7	64400 sh5				SR: N/A CR: ANNUALLY
101	7.2.5.b	PI-TK-101-AY	11.7	64400 sh4	AY164-1 / ET-01679			SR: N/A CR: N/A
101	7.2.5.c	PT-101-1	11.7	64400 sh5	AY063-1 / ET-01164			SR: N/A CR: N/A
101	7.2.5.c	PT-101-1	11.7	64400 sh5	AY064-1 / ET-01163			SR: N/A CR: N/A
101	7.2.5.c	PR-101-1	11.7	64400 sh5	AY064-2 / ET-00783			SR: CONT CR: N/A
101	7.2.5.c	PR-101-2	11.7	64400 sh5	AY063-2 / ET-00796			SR: CONT CR: N/A
101	7.2.5.c	PAS-101-1	11.7	64400 sh5	AY064-3 / ET-01001			SR: N/A CR: N/A
101	7.2.5.c	PAS-101-2	11.7	64400 sh5	AY063-3 / ET-01030			SR: N/A CR: N/A
101	7.2.5.c	PA-101-1	11.7	64400 sh5	AY064-4 / ET-02023			SR: N/A CR: N/A
101	7.2.5.c	PA-101-2	11.7	64400 sh5	AY063-4 / ET-01838			SR: N/A CR: N/A
101	7.2.5.c	PI-TK-101-AY	11.7	64400 sh4	AY164-1 / ET-01679			SR: N/A CR: N/A
101	7.2.5.c (d)	PT-101-1		64400 sh5	AY063-1 / ET-01164			SR: N/A CR: N/A
101	7.2.5.c (d)	PT-101-2		64400 sh5	AY064-1 / ET-01163			SR: N/A CR: N/A
101	7.2.5.c (d)	PR-101-1		64400 sh5	AY064-2 / ET-00783			SR: N/A CR: N/A
101	7.2.5.c (d)	PR-101-2		64400 sh5	AY063-2 / ET-00796			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 41 of 111

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.5.c (d)	PI-TK-101-AY		64400 sh4	AY164-1 / ET-01679			SR: N/A CR: N/A
101	7.2.5.c (d)	PI-K1-101-AY		64400 sh4	AY150-1 / ET-04647		-20", (PTP +6)"	SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-38		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-39		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-40		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-41		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-42		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-43		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-44		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-45		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-46		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-47		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-48		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-49		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-50		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-51		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-52		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-53		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-54		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-55		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-56		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-57		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-58		64400 sh5				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5I of 11I

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.6 (a,b,c)	TE-101-59		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-60		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-61		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-62		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-63		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-64		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-65		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-66		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-67		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-68		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-69		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-70		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-71		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-72		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-73		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	TE-101-74		64400 sh5				SR: N/A CR: N/A
101	7.2.6 (a,b,c)	DATA LOGGER		64400 sh4			260° F	SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-29		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-30		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-31		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-32		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-33		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-34		64400 sh4				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6I of 11I

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.7 (a,b,c)	TE-101-35		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-36		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-37		64400 sh4				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	DATA LOGGER		64400 sh5			350° F	SR: MONTHLY CR: N/A
101	7.2.7 (a,b,c)	TE-101-82		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-83		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-84		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-85		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-86		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-87		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-88		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-89		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-90		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-91		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-92		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-93		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-94		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-95		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-96		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-97		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-98		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-99		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-100		64400 sh5				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 7I of 11I

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.7 (a,b,c)	TE-101-101		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-102		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-103		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-104		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	TE-101-105		64400 sh5				SR: N/A CR: N/A
101	7.2.7 (a,b,c)	DATA LOGGER		64400 sh5			240° F	SR: MONTHLY CR: N/A
101	7.2.9	LDI-101-1	11.6	64400 sh4	AY090-2 / ET-00059			SR: N/A CR: QUARTERLY
101	7.2.9	LDK-101-17	11.6	64400 sh4	AY090-3 / ET-00020			SR: N/A CR: QUARTERLY
101	7.2.9	LDE-101-1A	11.6	64400 sh4	AY086-2 / ET-05298			SR: N/A CR: N/A
101	7.2.9	LDE-101-2A	11.6	64400 sh4	AY086-3 / ET-05168			SR: N/A CR: N/A
101	7.2.9	LDE-101-3A	11.6	64400 sh4	AY086-4 / ET-05152			SR: N/A CR: N/A
101	7.2.9	LDE-101-4A	11.6	64400 sh4	AY086-5 / ET-05255			SR: N/A CR: N/A
101	7.2.9	LDE-101-5A	11.6	64400 sh4	AY086-6 / ET-05230			SR: N/A CR: N/A
101	7.2.9	LDE-101-6A	11.6	64400 sh4	AY086-7 / ET-05231			SR: N/A CR: N/A
101	7.2.9	LDE-101-7A	11.6	64400 sh4	AY086-8 / ET-05294			SR: N/A CR: N/A
101	7.2.9	LDE-101-8A	11.6	64400 sh4	AY086-9 / ET-05320			SR: N/A CR: N/A
101	7.2.9	LDE-101-9A	11.6	64400 sh4	AY086-A / ET-05178			SR: N/A CR: N/A
101	7.2.9	LDE-101-10A	11.6	64400 sh4	AY086-B / ET-05239			SR: N/A CR: N/A
101	7.2.9	LDE-101-11A	11.6	64400 sh4	AY086-C / ET-05281			SR: N/A CR: N/A
101	7.2.9	LDE-101-12A	11.6	64400 sh4	AY086-D / ET-05275			SR: N/A CR: N/A
101	7.2.9	LDE-101-13A	11.6	64400 sh4	AY086-E / ET-05195			SR: N/A CR: N/A
101	7.2.9	LDE-101-14A	11.6	64400 sh4	AY086-F / ET-05229			SR: N/A CR: N/A
101	7.2.9	LDE-101-15A	11.6	64400 sh4	AY086-G / ET-05256			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 8I of 11I

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.9	LDE-101-16A	11.6	64400 sh4	AY086-H / ET-05257			SR: N/A CR: N/A
101	7.2.9	LDE-101-17A	11.6	64400 sh4	AY086-I / ET-05139			SR: N/A CR: N/A
101	7.2.9	LDE-101-1B	11.6	64400 sh4	AY087-2 / ET-05147			SR: N/A CR: N/A
101	7.2.9	LDE-101-2B	11.6	64400 sh4	AY087-3 / ET-05167			SR: N/A CR: N/A
101	7.2.9	LDE-101-3B	11.6	64400 sh4	AY087-4 / ET-05318			SR: N/A CR: N/A
101	7.2.9	LDE-101-4B	11.6	64400 sh4	AY087-5 / ET-05307			SR: N/A CR: N/A
101	7.2.9	LDE-101-5B	11.6	64400 sh4	AY087-6 / ET-05280			SR: N/A CR: N/A
101	7.2.9	LDE-101-6B	11.6	64400 sh4	AY087-7 / ET-05336			SR: N/A CR: N/A
101	7.2.9	LDE-101-7B	11.6	64400 sh4	AY087-8 / ET-05144			SR: N/A CR: N/A
101	7.2.9	LDE-101-8B	11.6	64400 sh4	AY087-9 / ET-05145			SR: N/A CR: N/A
101	7.2.9	LDE-101-9B	11.6	64400 sh4	AY087-A / ET-05238			SR: N/A CR: N/A
101	7.2.9	LDE-101-10B	11.6	64400 sh4	AY087-B / ET-05284			SR: N/A CR: N/A
101	7.2.9	LDE-101-11B	11.6	64400 sh4	AY087-C / ET-05206			SR: N/A CR: N/A
101	7.2.9	LDE-101-12B	11.6	64400 sh4	AY087-D / ET-05194			SR: N/A CR: N/A
101	7.2.9	LDE-101-13B	11.6	64400 sh4	AY087-E / ET-05226			SR: N/A CR: N/A
101	7.2.9	LDE-101-14B	11.6	64400 sh4	AY087-F / ET-05321			SR: N/A CR: N/A
101	7.2.9	LDE-101-15B	11.6	64400 sh4	AY087-G / ET-05306			SR: N/A CR: N/A
101	7.2.9	LDE-101-16B	11.6	64400 sh4	AY087-H / ET-05214			SR: N/A CR: N/A
101	7.2.9	LDE-101-17B	11.6	64400 sh4	AY087-I / ET-05138			SR: N/A CR: N/A
101	7.2.9	LDE-101-1C	11.6	64400 sh4	AY089-2 / ET-05173			SR: N/A CR: N/A
101	7.2.9	LDE-101-2C	11.6	64400 sh4	AY089-3 / ET-05142			SR: N/A CR: N/A
101	7.2.9	LDE-101-3C	11.6	64400 sh4	AY089-4 / ET-05176			SR: N/A CR: N/A
101	7.2.9	LDE-101-4C	11.6	64400 sh4	AY089-5 / ET-05237			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 91 of 111

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.9	LDE-101-5C	11.6	64400 sh4	AY089-6 / ET-05279			SR: N/A CR: N/A
101	7.2.9	LDE-101-6C	11.6	64400 sh4	AY089-7 / ET-05180			SR: N/A CR: N/A
101	7.2.9	LDE-101-7C	11.6	64400 sh4	AY089-8 / ET-05181			SR: N/A CR: N/A
101	7.2.9	LDE-101-8C	11.6	64400 sh4	AY089-9 / ET-05199			SR: N/A CR: N/A
101	7.2.9	LDE-101-9C	11.6	64400 sh4	AY089-A / ET-05215			SR: N/A CR: N/A
101	7.2.9	LDE-101-10C	11.6	64400 sh4	AY089-B / ET-05259			SR: N/A CR: N/A
101	7.2.9	LDE-101-11C	11.6	64400 sh4	AY089-C / ET-05295			SR: N/A CR: N/A
101	7.2.9	LDE-101-12C	11.6	64400 sh4	AY089-D / ET-05170			SR: N/A CR: N/A
101	7.2.9	LDE-101-13C	11.6	64400 sh4	AY089-E / ET-05311			SR: N/A CR: N/A
101	7.2.9	LDE-101-14C	11.6	64400 sh4	AY089-F / ET-05171			SR: N/A CR: N/A
101	7.2.9	LDE-101-15C	11.6	64400 sh4	AY089-G / ET-05235			SR: N/A CR: N/A
101	7.2.9	LDE-101-16C	11.6	64400 sh4	AY089-H / ET-05301			SR: N/A CR: N/A
101	7.2.9	LDE-101-17C	11.6	64400 sh4	AY089-I / ET-05140			SR: N/A CR: N/A
101	7.2.9	SS-101-A	11.6	64400 sh4	AY086-1 / ET-01292			SR: N/A CR: QUARTERLY
101	7.2.9	SS-101-B	11.6	64400 sh4	AY087-1 / ET-01294			SR: N/A CR: QUARTERLY
101	7.2.9	SS-101-C	11.6	64400 sh4	AY089-1 / ET-01295			SR: N/A CR: QUARTERLY
101	7.2.9	LDK-101-A,B,C	11.6	64400 sh4	AY090-4 / ET-00368			SR: N/A CR: QUARTERLY
101	7.2.9	LDI-101-2	11.6	64400 sh4	AY090-5 / ET-00268			SR: CONT CR: QUARTERLY
101	7.2.9	LDA-101-1	11.6	64400 sh4	AY090-6 / ET-01808			SR: N/A CR: QUARTERLY
101	7.2.9	CAM-101-AY	11.6	92066	YAY01-1 / ET-01569			SR: CONT CR: MONTHLY
101	7.2.9	RR-101-AY	11.6	92066				SR: N/A CR: MONTHLY
101	7.2.9	RA-101-AY	11.6	92066	AY120-B / ET-01971			SR: N/A CR: MONTHLY
101	7.2.9	QQ-CAM-101-AY	11.6	92066	AY120-4 / ET-02117			SR: N/A CR: MONTHLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 101 of 111

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	7.2.9	UXA-101-AY	11.6	92066	AY120-3 / ET-01690			SR: N/A CR: MONTHLY
101	7.2.9	PS-CAM-101-AY	11.6	92066	AY120-2 / ET-01057			SR: N/A CR: MONTHLY
101	7.2.10	LDE-101-20		64400 sh5	AY075-1 / ET-01269			SR: N/A CR: N/A
101	7.2.10	LDK-101-20		64400 sh5	AY075-2 / ET-00114			SR: N/A CR: N/A
101	7.2.10	LDA-101-20		64400 sh5	AY075-3 / ET-01801			SR: N/A CR: N/A
101	16.3.1	LLI-101-2		64400 sh5	AY071-2 / ET-00388		≥ 64"	SR: N/A CR: N/A
101	16.3.1	LLE-101-2		64400 sh5	AY071-1 / ET-00516			SR: N/A CR: N/A
101	16.3.1	LIT-101-AY		64400 sh4	AY085-1 / ET-01357		≥ 64"	SR: N/A CR: N/A
101	16.3.2.2.A	PI-K1-1-3	11.9	92066	AY122-1 / ET-02365		≤ 5.9"	SR: SHIFT CR: N/A
101	16.3.2.2.B	PI-K1-1-4	11.9	92066	AY123-1 / ET-02341		≤ 4.0"	SR: SHIFT CR: N/A
101	16.3.2.2.C	PI-K1-1-3	11.9	92066	AY122-1 / ET-02365		≤ 5.9"	SR: SHIFT CR: N/A
101	16.3.2.2.C	PI-K1-1-4	11.9	92066	AY123-1 / ET-02341		≤ 5.9"	SR: SHIFT CR: N/A
101	16.3.3.B	RECORD SAMPLER	11.9	93374 sh2				SR: N/A CR: N/A
101	16.3.3.B	FI-RS-101-AY	11.9	93374 sh2	AY148-1 / ET-02570			SR: N/A CR: N/A
101	16.3.3.B	FIQ-RS-101-AY	11.9	93374 sh2	AY152-1 / ET-02382			SR: N/A CR: N/A
101	16.3.3.B	PI-RS-101-AY	11.9	93374 sh2	AY154-1 / ET-02420			SR: N/A CR: N/A
101	16.3.3.B	FAS-RS-101-AY	11.9	93374 sh2	AY158-1 / ET-02523			SR: N/A CR: N/A
101	16.3.3.B	FA-RS-101-AY-1	11.9	93374 sh2				SR: N/A CR: N/A
101	16.3.3.B	FA-RS-101-AY-2	11.9	93374 sh2				SR: N/A CR: N/A
101	16.3.3.B	QQ-RS-101-AY	11.9	93374 sh2	AY157-1 / ET-04845			SR: N/A CR: N/A
101	16.3.3 (C,D)	CAM-101-AY	11.9	92066	YAY01-1 / ET-01569			SR: CONT CR: ANNUALLY
101	16.3.3 (C,D)	RR-101-AY	11.9	92066				SR: N/A CR: N/A
101	16.3.3 (C,D)	PS-CAM-101-AY	11.9	92066	AY120-2 / ET-01057			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 111 of 111

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	16.3.3 (C,D)	QQ-CAM-101-AY	11.9	92066	AY120-4 / ET-02117			SR: N/A CR: N/A
101	16.3.3 (C,D)	RA-101-AY	11.9	92066	AY120-B / ET-01971			SR: N/A CR: N/A
101	16.3.3 (C,D)	UXA-101-AY	11.9	92066	AY120-3 / ET-01690			SR: N/A CR: N/A
101								

NOTE - Instrumentation that pertains to OSR 11.5 is currently not applicable to AY farm since AY farm is not designated as aging waste. Even though OSD-T-151-00017 states that it is only applicable to tanks currently designated as aging waste, the specifications listed above are the same as listed in OSD-T-151-00007. Therefore, OSD-T-151-00017 was used.

** - Backup instrument that is used when the primary instrument is out of service or is giving questionable data.

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1J of 10J

241-AY-102

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.2.a	LIAS-102-1	11.13	64400 sh8	AY019-2 / ET-02741	360"		SR: N/A CR: SEMI-ANN
102	7.2.2.a	LLE-102-1	11.13	64400 sh8	AY019-1 / ET-00474			SR: N/A CR: SEMI-ANN
102	7.2.2.a	LLK-102-1	11.13	64400 sh8	AY019-3 / ET-00419			SR: N/A CR: SEMI-ANN
102	7.2.2.a	LLA-102-1	11.13	64400 sh8	AY019-4 / ET-01882			SR: N/A CR: SEMI-ANN
102	7.2.2.a	LLI-102-2	11.13	64400 sh8	AY021-2 / ET-00075		364", 64"	SR: DAILY CR: SEMI-ANN
102	7.2.2.a	LLE-102-2	11.13	64400 sh8	AY021-1 / ET-00277			SR: N/A CR: SEMI-ANN
102	7.2.2.a	LIT-102-AY	11.13	64400 sh7	AY040-1 / ET-01359		364", 64"	SR: DAILY CR: SEMI-ANN
102	7.2.2.b	WFT-102-1		64400 sh8	AY001-1 / ET-01165			SR: N/A CR: N/A
102	7.2.2.b	WFT-102		64400 sh8	AY002-1 / ET-01173			SR: N/A CR: N/A
102	7.2.2.b	FI-102-26		64400 sh8	AY004-1 / ET-04721			SR: N/A CR: N/A
102	7.2.2.b	FI-102-27		64400 sh8	AY004-2 / ET-04718			SR: N/A CR: N/A
102	7.2.2.b	FI-102-28		64400 sh8	AY004-3 / ET-04723			SR: N/A CR: N/A
102	7.2.2.b	WFI-102 (IS XMR #)		64400 sh8	AY002-2 / ET-00856		≤ 79"	SR: N/A CR: N/A
102	7.2.2.b	WFA(R)-102 (IS XMR #)		64400 sh8	AY002-3 / ET-00793			SR: N/A CR: N/A
102	7.2.2.b	WFAS-102-1		64400 sh8	AY001-2 / ET-01014	36"		SR: N/A CR: N/A
102	7.2.2.b	WFA-102-1		64400 sh8	AY001-3 / ET-02007			SR: N/A CR: N/A
102	7.2.2.b	FI-102-25		64400 sh8	AY018-1 / ET-04748			SR: N/A CR: N/A
102	7.2.3	LLI-102-2	11.4	64400 sh8	AY021-2 / ET-00075		≥ 0"	SR: CONT CR: N/A
102	7.2.3	LLE-102-2	11.4	64400 sh8	AY021-1 / ET-00277			SR: N/A CR: N/A
102	7.2.3	LIT-102-AY	11.4	64400 sh7	AY040-1 / ET-01359		≥ 0"	SR: CONT CR: N/A
102	7.2.3	PT-102-1	11.4	64400 sh8	AY015-1 / ET-01172			SR: N/A CR: ANNUALLY
102	7.2.3	PAS-102-2	11.4	64400 sh8	AY014-3 / ET-01008			SR: CONT CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.3	PA-102-2	11.4	64400 sh8	AY014-4 / ET-01919			SR: CONT CR: ANNUALLY
102	7.2.3	PR-102-1	11.4	64400 sh8	AY015-2 / ET-00792			SR: CONT CR: ANNUALLY
102	7.2.3	PT-102-1	11.4	64400 sh8	AY014-1 / ET-01167			SR: N/A CR: ANNUALLY
102	7.2.3	PR-102-2	11.4	64400 sh8	AY014-2 / ET-00782			SR: CONT CR: ANNUALLY
102	7.2.5.a	PT-102-1		64400 sh8	AY015-1 / ET-01172		5", -6"	SR: N/A CR: N/A
102	7.2.5.a	PT-102-2		64400 sh8	AY014-1 / ET-01167		5", -6"	SR: N/A CR: N/A
102	7.2.5.a	PAS-102-1		64400 sh8	AY015-3 / ET-01088	-0.25"		SR: N/A CR: N/A
102	7.2.5.a	PAS-102-2		64400 sh8	AY014-3 / ET-01008	-3"		SR: N/A CR: N/A
102	7.2.5.a	PA-102-1		64400 sh8	AY015-4 / ET-01800			SR: N/A CR: N/A
102	7.2.5.a	PA-102-2		64400 sh8	AY014-4 / ET-01919			SR: N/A CR: N/A
102	7.2.5.a	PR-102-1		64400 sh8	AY015-2 / ET-00792			SR: N/A CR: N/A
102	7.2.5.a	PR-102-2		64400 sh8	AY014-2 / ET-00782			SR: N/A CR: N/A
102	7.2.5.a	PI-TK-102-AY		64400 sh7	AY165-1 / ET-02375		5", -6"	SR: N/A CR: N/A
102	7.2.5.b	PT-102-1	11.7	64400 sh8	AY015-1 / ET-01172		5", -6"	SR: N/A CR: ANNUALLY
102	7.2.5.b	PAS-102-1	11.7	64400 sh8	AY015-3 / ET-01088	-0.25"		SR: CONT CR: ANNUALLY
102	7.2.5.b	PAS-102-2	11.7	64400 sh8	AY014-3 / ET-01008	-3"		SR: CONT CR: ANNUALLY
102	7.2.5.b	PA-102-1	11.7	64400 sh8	AY015-4 / ET-01800			SR: N/A CR: ANNUALLY
102	7.2.5.b	PA-102-2	11.7	64400 sh8	AY014-4 / ET-01919			SR: N/A CR: ANNUALLY
102	7.2.5.b	PR-102-1	11.7	64400 sh8	AY015-2 / ET-00792			SR: N/A CR: ANNUALLY
102	7.2.5.b	HORN	11.7	64400 sh8				SR: N/A CR: ANNUALLY
102	7.2.5.b	PI-TK-102-AY	11.7	64400 sh7	AY165-1 / ET-02375		5", -6"	SR: N/A CR: N/A
102	7.2.5.c	PT-102-1	11.7	64400 sh8	AY015-1 / ET-01172			SR: N/A CR: N/A
102	7.2.5.c	PT-102-2	11.7	64400 sh8	AY014-1 / ET-01167			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.5.c	PR-102-1	11.7	64400 sh8	AY015-2 / ET-00792			SR: CONT CR: N/A
102	7.2.5.c	PR-102-2	11.7	64400 sh8	AY014-2 / ET-00782			SR: CONT CR: N/A
102	7.2.5.c	PAS-102-1	11.7	64400 sh8	AY015-3 / ET-01088			SR: N/A CR: N/A
102	7.2.5.c	PAS-102-2	11.7	64400 sh8	AY014-3 / ET-01008			SR: N/A CR: N/A
102	7.2.5.c	PA-102-1	11.7	64400 sh8	AY015-4 / ET-01800			SR: N/A CR: N/A
102	7.2.5.c	PA-102-2	11.7	64400 sh8	AY014-4 / ET-01919			SR: N/A CR: N/A
102	7.2.5.c	PI-TK-102-AY	11.7	64400 sh7	AY165-1 / ET-02375			SR: N/A CR: N/A
102	7.2.5.c (d)	PT-102-1		64400 sh8	AY015-1 / ET-01172		5", -6"	SR: N/A CR: N/A
102	7.2.5.c (d)	PT-102-2		64400 sh8	AY014-1 / ET-01167		5", -6"	SR: N/A CR: N/A
102	7.2.5.c (d)	PR-102-1		64400 sh8	AY015-2 / ET-00792			SR: N/A CR: N/A
102	7.2.5.c (d)	PR-102-2		64400 sh8	AY014-2 / ET-00782			SR: N/A CR: N/A
102	7.2.5.c (d)	PI-TK-102-AY		64400 sh7	AY165-1 / ET-02375		5", -6"	SR: N/A CR: N/A
102	7.2.5.c (d)	PI-K2-102-AY		64400 sh7	AY151-1 / ET-04912		-20" , (PTP +6)"	SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-38		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-39		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-40		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-41		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-42		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-43		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-44		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-45		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-46		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-47		64400 sh8				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.6 (a,b,c)	TE-102-48		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-49		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-50		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-51		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-52		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-53		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-54		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-55		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-56		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-57		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-58		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-59		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-60		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-61		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-62		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-63		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-64		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-65		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-66		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-67		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-68		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-69		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-70		64400 sh8				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.6 (a,b,c)	TE-102-71		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-72		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-73		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	TE-102-74		64400 sh8				SR: N/A CR: N/A
102	7.2.6 (a,b,c)	DATA LOGGER		64400 sh8			260° F	SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-29		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-30		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-31		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-32		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-33		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-34		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-35		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-36		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-37		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	DATA LOGGER		64400 sh7			350° F	SR: MONTHLY CR: N/A
102	7.2.7 (a,b,c)	TE-102-82		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-83		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-84		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-85		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-86		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-87		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-88		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-89		64400 sh7				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.7 (a,b,c)	TE-102-90		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-91		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-92		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	TE-102-93		64400 sh7				SR: N/A CR: N/A
102	7.2.7 (a,b,c)	DATA LOGGER		64400 sh7			240° F	SR: MONTHLY CR: N/A
102	7.2.9	LI-102-1	11.6	64400 sh7	AY044-2 / ET-00196			SR: N/A CR: QUARTERLY
102	7.2.9	LDK-102-17	11.6	64400 sh7	AY044-3 / ET-00232			SR: N/A CR: QUARTERLY
102	7.2.9	LDE-102-1A	11.6	64400 sh7	AY042-2 / ET-05191			SR: N/A CR: N/A
102	7.2.9	LDE-102-2A	11.6	64400 sh7	AY042-3 / ET-05221			SR: N/A CR: N/A
102	7.2.9	LDE-102-3A	11.6	64400 sh7	AY042-4 / ET-05222			SR: N/A CR: N/A
102	7.2.9	LDE-102-4A	11.6	64400 sh7	AY042-5 / ET-05258			SR: N/A CR: N/A
102	7.2.9	LDE-102-5A	11.6	64400 sh7	AY042-6 / ET-05305			SR: N/A CR: N/A
102	7.2.9	LDE-102-6A	11.6	64400 sh7	AY042-7 / ET-05227			SR: N/A CR: N/A
102	7.2.9	LDE-102-7A	11.6	64400 sh7	AY042-8 / ET-05149			SR: N/A CR: N/A
102	7.2.9	LDE-102-8A	11.6	64400 sh7	AY042-9 / ET-05172			SR: N/A CR: N/A
102	7.2.9	LDE-102-9A	11.6	64400 sh7	AY042-A / ET-05312			SR: N/A CR: N/A
102	7.2.9	LDE-102-10A	11.6	64400 sh7	AY042-B / ET-05303			SR: N/A CR: N/A
102	7.2.9	LDE-102-11A	11.6	64400 sh7	AY042-C / ET-05154			SR: N/A CR: N/A
102	7.2.9	LDE-102-12A	11.6	64400 sh7	AY042-D / ET-05334			SR: N/A CR: N/A
102	7.2.9	LDE-102-13A	11.6	64400 sh7	AY042-E / ET-05335			SR: N/A CR: N/A
102	7.2.9	LDE-102-14A	11.6	64400 sh7	AY042-F / ET-05146			SR: N/A CR: N/A
102	7.2.9	LDE-102-15A	11.6	64400 sh7	AY042-G / ET-05236			SR: N/A CR: N/A
102	7.2.9	LDE-102-16A	11.6	64400 sh7	AY042-H / ET-05272			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 7J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.9	LDE-102-17A	11.6	64400 sh7	AY042-I / ET-05193			SR: N/A CR: N/A
102	7.2.9	LDE-102-1B	11.6	64400 sh7	AY043-2 / ET-05228			SR: N/A CR: N/A
102	7.2.9	LDE-102-2B	11.6	64400 sh7	AY043-3 / ET-05333			SR: N/A CR: N/A
102	7.2.9	LDE-102-3B	11.6	64400 sh7	AY043-4 / ET-05304			SR: N/A CR: N/A
102	7.2.9	LDE-102-4B	11.6	64400 sh7	AY043-5 / ET-05213			SR: N/A CR: N/A
102	7.2.9	LDE-102-5B	11.6	64400 sh7	AY043-6 / ET-05299			SR: N/A CR: N/A
102	7.2.9	LDE-102-6B	11.6	64400 sh7	AY043-7 / ET-05225			SR: N/A CR: N/A
102	7.2.9	LDE-102-7B	11.6	64400 sh7	AY043-8 / ET-05224			SR: N/A CR: N/A
102	7.2.9	LDE-102-8B	11.6	64400 sh7	AY043-9 / ET-05337			SR: N/A CR: N/A
102	7.2.9	LDE-102-9B	11.6	64400 sh7	AY043-A / ET-05310			SR: N/A CR: N/A
102	7.2.9	LDE-102-10B	11.6	64400 sh7	AY043-B / ET-05296			SR: N/A CR: N/A
102	7.2.9	LDE-102-11B	11.6	64400 sh7	AY043-C / ET-05317			SR: N/A CR: N/A
102	7.2.9	LDE-102-12B	11.6	64400 sh7	AY043-D / ET-05169			SR: N/A CR: N/A
102	7.2.9	LDE-102-13B	11.6	64400 sh7	AY043-E / ET-05151			SR: N/A CR: N/A
102	7.2.9	LDE-102-14B	11.6	64400 sh7	AY043-F / ET-05261			SR: N/A CR: N/A
102	7.2.9	LDE-102-15B	11.6	64400 sh7	AY043-G / ET-05262			SR: N/A CR: N/A
102	7.2.9	LDE-102-16B	11.6	64400 sh7	AY043-H / ET-05265			SR: N/A CR: N/A
102	7.2.9	LDE-102-17B	11.6	64400 sh7	AY043-I / ET-05207			SR: N/A CR: N/A
102	7.2.9	LDE-102-1C	11.6	64400 sh7	AY041-2 / ET-05267			SR: N/A CR: N/A
102	7.2.9	LDE-102-2C	11.6	64400 sh7	AY041-3 / ET-05205			SR: N/A CR: N/A
102	7.2.9	LDE-102-3C	11.6	64400 sh7	AY041-4 / ET-05192			SR: N/A CR: N/A
102	7.2.9	LDE-102-4C	11.6	64400 sh7	AY041-5 / ET-05196			SR: N/A CR: N/A
102	7.2.9	LDE-102-5C	11.6	64400 sh7	AY041-6 / ET-05245			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 8J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.9	LDE-102-6C	11.6	64400 sh7	AY041-7 / ET-05300			SR: N/A CR: N/A
102	7.2.9	LDE-102-7C	11.6	64400 sh7	AY041-8 / ET-05208			SR: N/A CR: N/A
102	7.2.9	LDE-102-8C	11.6	64400 sh7	AY041-9 / ET-05175			SR: N/A CR: N/A
102	7.2.9	LDE-102-9C	11.6	64400 sh7	AY041-A / ET-05158			SR: N/A CR: N/A
102	7.2.9	LDE-102-10C	11.6	64400 sh7	AY041-B / ET-05331			SR: N/A CR: N/A
102	7.2.9	LDE-102-11C	11.6	64400 sh7	AY041-C / ET-05332			SR: N/A CR: N/A
102	7.2.9	LDE-102-12C	11.6	64400 sh7	AY041-D / ET-05271			SR: N/A CR: N/A
102	7.2.9	LDE-102-13C	11.6	64400 sh7	AY041-E / ET-05174			SR: N/A CR: N/A
102	7.2.9	LDE-102-14C	11.6	64400 sh7	AY041-F / ET-05308			SR: N/A CR: N/A
102	7.2.9	LDE-102-15C	11.6	64400 sh7	AY041-G / ET-05177			SR: N/A CR: N/A
102	7.2.9	LDE-102-16C	11.6	64400 sh7	AY041-H / ET-05242			SR: N/A CR: N/A
102	7.2.9	LDE-102-17C	11.6	64400 sh7	AY041-I / ET-05278			SR: N/A CR: N/A
102	7.2.9	SS-102-A	11.6	64400 sh7	AY042-1 / ET-01299			SR: N/A CR: QUARTERLY
102	7.2.9	SS-102-B	11.6	64400 sh7	AY043-1 / ET-01297			SR: N/A CR: QUARTERLY
102	7.2.9	SS-102-C	11.6	64400 sh7	AY041-1 / ET-01302			SR: N/A CR: QUARTERLY
102	7.2.9	LDK-102-1	11.6	64400 sh7	AY044-4 / ET-00349			SR: N/A CR: QUARTERLY
102	7.2.9	LDI-102-2	11.6	64400 sh7	AY044-5 / ET-00145			SR: CONT CR: QUARTERLY
102	7.2.9	LDA-102-1	11.6	64400 sh7	AY044-6 / ET-01750			SR: N/A CR: QUARTERLY
102	7.2.9	CAM-102-AY	11.6	92066	YAY03-1 / ET-01558			SR: CONT CR: MONTHLY
102	7.2.9	RR-102-AY	11.6	92066				SR: N/A CR: MONTHLY
102	7.2.9	RA-102-AY	11.6	92066	AY131-B / ET-01911			SR: N/A CR: MONTHLY
102	7.2.9	QQ-CAM-102-AY	11.6	92066	AY131-4 / ET-01531			SR: N/A CR: MONTHLY
102	7.2.9	UXA-102-AY	11.6	92066	AY131-3 / ET-01840			SR: N/A CR: MONTHLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 9J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	7.2.9	PS-CAM-102-AY	11.6	92066	AY131-2 / ET-01072			SR: N/A CR: MONTHLY
102	7.2.10	LDE-102-20		64400 sh7	AY027-1 / ET-01216			SR: N/A CR: N/A
102	7.2.10	LDK-102-20		64400 sh7	AY027-2 / ET-00171			SR: N/A CR: N/A
102	7.2.10	LDA-102-20		64400 sh7	AY027-3 / ET-02057			SR: N/A CR: N/A
102	7.2.10	LDE-102-22		64400 sh6	AY033-1 / ET-01215			SR: N/A CR: N/A
102	7.2.10	LDK-102-22		64400 sh6	AY033-2 / ET-00199			SR: N/A CR: N/A
102	7.2.10	LDA-102-22		64400 sh6	AY033-3 / ET-01968			SR: N/A CR: N/A
102	7.2.10	LDE-SL-504		64400 sh6	AY036-1 / ET-03785			SR: N/A CR: N/A
102	7.2.10	LDK-SL-504		94028	AY036-2 / ET-00148			SR: N/A CR: N/A
102	7.2.10	LDA-SL-504		94028	AY036-3 / ET-02085			SR: N/A CR: N/A
102	16.3.1	LIAS-102-2		64400 sh8	AY021-2 / ET-00075		≥ 64"	SR: N/A CR: N/A
102	16.3.1	LLE-102-2		64400 sh8	AY021-1 / ET-00277			SR: N/A CR: N/A
102	16.3.1	LIT-102-AY		64400 sh7	AY040-1 / ET-01359		≥ 64"	SR: N/A CR: N/A
102	16.3.2.2.A	PI-K2-1-3	11.9	92066	AY133-1 / ET-01529		≤ 5.9"	SR: SHIFT CR: N/A
102	16.3.2.2.B	PI-K2-1-4	11.9	92066	AY134-1 / ET-02366		≤ 4.0"	SR: SHIFT CR: N/A
102	16.3.2.2.C	PI-K2-1-3	11.9	92066	AY133-1 / ET-01529		≤ 5.9"	SR: SHIFT CR: N/A
102	16.3.2.2.C	PI-K2-1-4	11.9	92066	AY134-1 / ET-02366		≤ 5.9"	SR: SHIFT CR: N/A
102	16.3.3.B	RECORD SAMPLER	11.9	93374 sh2				SR: N/A CR: N/A
102	16.3.3.B	FI-RS-102-AY	11.9	93374 sh2	AY149-1 / ET-01203			SR: N/A CR: N/A
102	16.3.3.B	FIQ-RS-102-AY	11.9	93374 sh2	AY153-1 / ET-02386			SR: N/A CR: N/A
102	16.3.3.B	PI-RS-102-AY	11.9	93374 sh2	AY155-1 / ET-02418			SR: N/A CR: N/A
102	16.3.3.B	FAS-RS-102-AY	11.9	93374 sh2	AY159-1 / ET-02523			SR: N/A CR: N/A
102	16.3.3.B	FA-RS-102-AY-1	11.9	93374 sh2				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10J of 10J

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	16.3.3.B	FA-RS-102-AY-2	11.9	93374 sh2				SR: N/A CR: N/A
102	16.3.3.B	QQ-RS-102-AY	11.9	93374 sh2	AY156-1 / ET-04841			SR: N/A CR: N/A
102	16.3.3 (C,D)	CAM-102-AY	11.9	92066	YAY03-1 / ET-01558			SR: CONT CR: ANNUALLY
102	16.3.3 (C,D)	RR-102-AY	11.9	92066				SR: N/A CR: N/A
102	16.3.3 (C,D)	PS-CAM-102-AY	11.9	92066	AY131-2 / ET-01072			SR: N/A CR: N/A
102	16.3.3 (C,D)	QQ-CAM-102-AY	11.9	92066	AY131-4 / ET-01531			SR: N/A CR: N/A
102	16.3.3 (C,D)	RA-102-AY	11.9	92066	AY131-B / ET-01911			SR: N/A CR: N/A
102	16.3.3 (C,D)	UXA-102-AY	11.9	92066	AY131-3 / ET-01840			SR: N/A CR: N/A

** - Backup instrument that is used when the primary instrument is out of service or is giving questionable data.

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1K of 14K

241-AZ-101

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
101	17.2.1.1	LLI-101-2	11.13	68335 sh7	AZ124-2 / ET-00373		364", 64"	SR: DAILY CR: SEMI-ANN
101	17.2.1.1	LLE-101-2	11.13	68335 sh7	AZ124-1 / ET-00083			SR: N/A CR: SEMI-ANN
101	17.2.1.1	LIT-101-AZ	11.13	68335 sh7	AZ096-2 / ET-01354		364", 64"	SR: N/A CR: SEMI-ANN
101	17.2.1.1	LIAS-101-1	11.13	68335 sh7	AZ123-2 / ET-00455	360"		SR: DAILY CR: SEMI-ANN
101	17.2.1.1	LLE-101-1	11.13	68335 sh7	AZ123-1 / ET-00198			SR: N/A CR: SEMI-ANN
101	17.2.1.1	LLK-101-1	11.13	68335 sh6	AZ123-3 / ET-00397			SR: N/A CR: SEMI-ANN
101	17.2.1.1	LLA-101-1	11.13	68335 sh6	AZ123-4 / ET-01747			SR: CONT CR: SEMI-ANN
101	17.2.1.2.A	WFT-101-1		68335 sh6	AZ129-1 / ET-00947			SR: N/A CR: N/A
101	17.2.1.2.A	WFI-101-1		68335 sh6	AZ129-2 / ET-00854		≤ 74"	SR: N/A CR: N/A
101	17.2.1.2.A	WFT-101-2		68335 sh6	AZ128-1 / ET-00961			SR: N/A CR: N/A
101	17.2.1.2.A	WFAS-101-1		68335 sh6	AZ128-2 / ET-01002	30"		SR: N/A CR: N/A
101	17.2.1.2.A	WFA-101-1		68335 sh6	AZ128-3 / ET-01903			SR: N/A CR: N/A
101	17.2.1.2.B	WFT-101/102-1		68335 sh2	AZ040-1 / ET-00970			SR: N/A CR: N/A
101	17.2.1.2.B	WFI-101/102-1		68335 sh2	AZ040-2 / ET-00849		≤ 408"	SR: N/A CR: N/A
101	17.2.1.2.B	WFT-101/102-2		68335 sh2	AZ042-1 / ET-00951			SR: N/A CR: N/A
101	17.2.1.2.B	WFAS-101/102-1		68335 sh2	AZ042-2 / ET-00998	30"		SR: N/A CR: N/A
101	17.2.1.2.B	WFA-101/102-1		68335 sh2	AZ042-3 / ET-02081			SR: N/A CR: N/A
101	17.2.2	SS-101-A	11.6	68335 sh6	AZ110-1 / ET-01246			SR: N/A CR: QUARTERLY
101	17.2.2	SS-101-B	11.6	68335 sh6	AZ111-1 / ET-01293			SR: N/A CR: QUARTERLY
101	17.2.2	SS-101-C	11.6	68335 sh6	AZ112-1 / ET-01296			SR: N/A CR: QUARTERLY
101	17.2.2	LDI-101-1	11.6	68335 sh6	AZ120-4 / ET-00141			SR: N/A CR: MONTHLY
101	17.2.2	LDK-101-1	11.6	68335 sh6	AZ120-3 / ET-00113			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.2	LDA-101-1A	11.6	68335 sh6	AZ120-5 / ET-01813			SR: N/A CR: MONTHLY
101	17.2.2	LI-101-1	11.6	68335 sh6	AZ120-2 / ET-00284			SR: N/A CR: QUARTERLY
101	17.2.2	LDE-101-1	11.6	68335 sh6	AZ120-1 / ET-03763			SR: N/A CR: N/A
101	17.2.2	LDE-101-1A	11.6	68335 sh6	AZ110-2 / ET-05163			SR: N/A CR: N/A
101	17.2.2	LDE-101-2A	11.6	68335 sh7	AZ110-3 / ET-05141			SR: N/A CR: N/A
101	17.2.2	LDE-101-3A	11.6	68335 sh7	AZ110-4 / ET-05248			SR: N/A CR: N/A
101	17.2.2	LDE-101-4A	11.6	68335 sh7	AZ110-5 / ET-05266			SR: N/A CR: N/A
101	17.2.2	LDE-101-5A	11.6	68335 sh7	AZ110-6 / ET-05187			SR: N/A CR: N/A
101	17.2.2	LDE-101-6A	11.6	68335 sh7	AZ110-7 / ET-05200			SR: N/A CR: N/A
101	17.2.2	LDE-101-7A	11.6	68335 sh7	AZ110-8 / ET-05201			SR: N/A CR: N/A
101	17.2.2	LDE-101-8A	11.6	68335 sh7	AZ110-9 / ET-05210			SR: N/A CR: N/A
101	17.2.2	LDE-101-9A	11.6	68335 sh7	AZ110-A / ET-05328			SR: N/A CR: N/A
101	17.2.2	LDE-101-10	11.6	68335 sh7	AZ110-B / ET-05134			SR: N/A CR: N/A
101	17.2.2	LDE-101-11A	11.6	68335 sh7	AZ110-C / ET-05211			SR: N/A CR: N/A
101	17.2.2	LDE-101-12A	11.6	68335 sh7	AZ110-D / ET-05326			SR: N/A CR: N/A
101	17.2.2	LDE-101-13A	11.6	68335 sh7	AZ110-E / ET-05195			SR: N/A CR: N/A
101	17.2.2	LDE-101-14A	11.6	68335 sh7	AZ110-F / ET-05246			SR: N/A CR: N/A
101	17.2.2	LDE-101-15A	11.6	68335 sh7	AZ110-G / ET-05283			SR: N/A CR: N/A
101	17.2.2	LDE-101-16A	11.6	68335 sh7	AZ110-H / ET-05323			SR: N/A CR: N/A
101	17.2.2	LDE-101-17A	11.6	68335 sh7	AZ110-I / ET-05324			SR: N/A CR: N/A
101	17.2.2	LDE-101-18	11.6	68335 sh7	AZ111-2 / ET-05322			SR: N/A CR: N/A
101	17.2.2	LDE-101-2B	11.6	68335 sh7	AZ111-3 / ET-05243			SR: N/A CR: N/A
101	17.2.2	LDE-101-3B	11.6	68335 sh7	AZ111-4 / ET-05270			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.2	LDE-101-4B	11.6	68335 sh7	AZ111-5 / ET-05197			SR: N/A CR: N/A
101	17.2.2	LDE-101-5B	11.6	68335 sh7	AZ111-6 / ET-05133			SR: N/A CR: N/A
101	17.2.2	LDE-101-6B	11.6	68335 sh7	AZ111-7 / ET-05336			SR: N/A CR: N/A
101	17.2.2	LDE-101-7B	11.6	68335 sh7	AZ111-8 / ET-05247			SR: N/A CR: N/A
101	17.2.2	LDE-101-8B	11.6	68335 sh7	AZ111-9 / ET-05135			SR: N/A CR: N/A
101	17.2.2	LDE-101-9B	11.6	68335 sh7	AZ111-A / ET-05297			SR: N/A CR: N/A
101	17.2.2	LDE-101-10B	11.6	68335 sh7	AZ111-B / ET-05209			SR: N/A CR: N/A
101	17.2.2	LDE-101-11B	11.6	68335 sh7	AZ111-C / ET-05150			SR: N/A CR: N/A
101	17.2.2	LDE-101-12B	11.6	68335 sh7	AZ111-D / ET-05132			SR: N/A CR: N/A
101	17.2.2	LDE-101-13B	11.6	68335 sh7	AZ111-E / ET-05234			SR: N/A CR: N/A
101	17.2.2	LDE-101-14B	11.6	68335 sh7	AZ111-F / ET-05285			SR: N/A CR: N/A
101	17.2.2	LDE-101-15B	11.6	68335 sh7	AZ111-G / ET-05316			SR: N/A CR: N/A
101	17.2.2	LDE-101-16B	11.6	68335 sh7	AZ111-H / ET-05164			SR: N/A CR: N/A
101	17.2.2	LDE-101-17B	11.6	68335 sh7	AZ111-I / ET-05240			SR: N/A CR: N/A
101	17.2.2	LDE-101-1C	11.6	68335 sh7	AZ112-2 / ET-05314			SR: N/A CR: N/A
101	17.2.2	LDE-101-2C	11.6	68335 sh7	AZ112-3 / ET-05268			SR: N/A CR: N/A
101	17.2.2	LDE-101-3C	11.6	68335 sh7	AZ112-4 / ET-05189			SR: N/A CR: N/A
101	17.2.2	LDE-101-4C	11.6	68335 sh7	AZ112-5 / ET-05202			SR: N/A CR: N/A
101	17.2.2	LDE-101-5C	11.6	68335 sh7	AZ112-6 / ET-05263			SR: N/A CR: N/A
101	17.2.2	LDE-101-6C	11.6	68335 sh7	AZ112-7 / ET-05251			SR: N/A CR: N/A
101	17.2.2	LDE-101-7C	11.6	68335 sh7	AZ112-8 / ET-05292			SR: N/A CR: N/A
101	17.2.2	LDE-101-8C	11.6	68335 sh7	AZ112-9 / ET-05166			SR: N/A CR: N/A
101	17.2.2	LDE-101-9C	11.6	68335 sh7	AZ112-A / ET-05148			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.2	LDE-101-10C	11.6	68335 sh7	AZ112-B / ET-05260			SR: N/A CR: N/A
101	17.2.2	LDE-101-11C	11.6	68335 sh7	AZ112-C / ET-05215			SR: N/A CR: N/A
101	17.2.2	LDE-101-12C	11.6	68335 sh7	AZ112-D / ET-05269			SR: N/A CR: N/A
101	17.2.2	LDE-101-13C	11.6	68335 sh7	AZ112-E / ET-05190			SR: N/A CR: N/A
101	17.2.2	LDE-101-14C	11.6	68335 sh7	AZ112-F / ET-05203			SR: N/A CR: N/A
101	17.2.2	LDE-101-15C	11.6	68335 sh7	AZ112-G / ET-05264			SR: N/A CR: N/A
101	17.2.2	LDE-101-16C	11.6	68335 sh7	AZ112-H / ET-05252			SR: N/A CR: N/A
101	17.2.2	LDE-101-17C	11.6	68335 sh7	AZ112-I / ET-05293			SR: N/A CR: N/A
101	17.2.2	CAM-101-AZ	11.6	92964	YAZ02-1 / ET-01553			SR: N/A CR: MONTHLY
101	17.2.2	RR-101-AZ	11.6	92964				SR: N/A CR: MONTHLY
101	17.2.2	RA-101-AZ	11.6	92964	AZ029-3 / ET-02073			SR: N/A CR: MONTHLY
101	17.2.2	PS-CAM-1-101-AZ	11.6	92964	AZ029-2 / ET-01147			SR: N/A CR: MONTHLY
101	17.2.2	QQ-CAM-101-AZ	11.6	92964	AZ029-1 / ET-02114			SR: N/A CR: MONTHLY
101	17.2.3	LIT-101-AZ	11.4	68335 sh7	AZ096-2 / ET-01354		744", 0"	SR: DAILY CR: N/A
101	17.2.3	LLE-101-2	11.4	68335 sh7	AZ124-1 / ET-00083			SR: N/A CR: N/A
101	17.2.3	LLI-101-1	11.4	68335 sh7	AZ124-2 / ET-00373		744", 0"	SR: DAILY CR: N/A
101	17.2.3	PT-101-1	11.4	68335 sh6	AZ104-1 / ET-00988			SR: N/A CR: ANNUALLY
101	17.2.3	PT-101-2	11.4	68335 sh6	AZ103-1 / ET-00983			SR: N/A CR: ANNUALLY
101	17.2.3	PR-101-1	11.4	68335 sh6	AZ104-2 / ET-00738			SR: CONT CR: N/A
101	17.2.3	PR-101-2	11.4	68335 sh6	AZ103-2 / ET-00752			SR: CONT CR: N/A
101	17.2.3	PI-TK-101-AZ	11.4	68335 sh6	AZ099-1 / ET-00667			SR: N/A CR: N/A
101	17.2.6.A	TE-101-25	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.A	TE-101-26	11.15	68335 sh7				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV: 0
PAGE 5K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.6.A	DATA LOGGER	11.15	68335 sh7			≤ 380° F	SR: DAILY CR: N/A
101	17.2.6.B	TE-101-1	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-2	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-3	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-4	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-5	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-6	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-7	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-8	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-9	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-10	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-11	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-12	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-13	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-14	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-15	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-16	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-17	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-18	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-19	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-20	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-21	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-22	11.15	68335 sh7				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.6.B	TE-101-23	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	TE-101-24	11.15	68335 sh7				SR: N/A CR: N/A
101	17.2.6.B	DATA LOGGER	11.15	68335 sh7			≤ 400° F	SR: DAILY CR: N/A
101	17.2.7.A	TE-101-28		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-29		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-30		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-31		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-32		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-33		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-34		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-35		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-36		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-86		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-87		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-88		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-89		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-90		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-91		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-92		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-93		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-94		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-95		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	TE-101-96		68335 sh7				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 7K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.7.A	TE-101-97		68335 sh7				SR: N/A CR: N/A
101	17.2.7.A	DATA LOGGER		68335 sh7			≤ 350° F	SR: MONTHLY CR: N/A
101	17.2.7.B	TE-101-74		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-75		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-76		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-77		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-78		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-79		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-80		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-81		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-82		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-83		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-84		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	TE-101-85		68335 sh7				SR: N/A CR: N/A
101	17.2.7.B	DATA LOGGER		68335 sh7			≤ 240° F	SR: MONTHLY CR: N/A
101	17.2.7.C	TE-101-74		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-75		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-76		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-77		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-78		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-79		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-80		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-81		68335 sh7				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 8K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.2.7.C	TE-101-82		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-83		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-84		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-85		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-86		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-87		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-88		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-89		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-90		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-91		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-92		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-93		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-94		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-95		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-96		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	TE-101-97		68335 sh7				SR: N/A CR: N/A
101	17.2.7.C	DATA LOGGER		68335 sh7			≤ 18° F/ft	SR: MONTHLY CR: N/A
101	17.3.1	LDE-101-18	11.8	68335 sh7	AZ139-1 / ET-01248			SR: N/A CR: PRESTARTUP
101	17.3.1	LDK-101-18	11.8	68335 sh6	AZ139-2 / ET-00036			SR: N/A CR: QUARTERLY
101	17.3.1	LDK-101-18B	11.8	68335 sh6	AZ139-3 / ET-00375			SR: N/A CR: QUARTERLY
101	17.3.1	LDA-101-18	11.8	68335 sh6	AZ139-4 / ET-01966			SR: N/A CR: MONTHLY
101	17.3.1	LDE-101-19	11.8	68335 sh7	AZ125-1 / ET-01278			SR: N/A CR: PRESTARTUP
101	17.3.1	LDK-101-19	11.8	68335 sh6	AZ125-2 / ET-00274			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 9K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.3.1	LDK-101-19B	11.8	68335 sh6	AZ125-3 / ET-00281			SR: N/A CR: QUARTERLY
101	17.3.1	LDA-101-19	11.8	68335 sh6	AZ125-4 / ET-01761			SR: N/A CR: MONTHLY
101	17.3.1	LDE-101-20	11.8	68335 sh7	AZ126-1 / ET-01261			SR: N/A CR: PRESTARTUP
101	17.3.1	LDK-101-20A	11.8	68335 sh6	AZ126-2 / ET-00251			SR: N/A CR: QUARTERLY
101	17.3.1	LDK-101-20B	11.8	68335 sh6	AZ126-3 / ET-00325			SR: N/A CR: QUARTERLY
101	17.3.1	LDA-101-20A	11.8	68335 sh6	AZ126-4 / ET-01837			SR: N/A CR: MONTHLY
101	17.3.1	LDE-101-24	11.8	68335 sh6	AZ105-1 / ET-01274			SR: N/A CR: PRESTARTUP
101	17.3.1	LDK-101-24	11.8	68335 sh6	AZ105-2 / ET-00358			SR: N/A CR: QUARTERLY
101	17.3.1	LDA-101-24A	11.8	68335 sh6	AZ105-3 / ET-01725			SR: N/A CR: MONTHLY
101	17.3.1	LDE-4507-1	11.8	68335 sh7	AZ122-1 / ET-03923			SR: N/A CR: PRESTARTUP
101	17.3.1	LDE-4508-1	11.8	68335 sh7	AZ121-1 / ET-01245			SR: N/A CR: PRESTARTUP
101	17.3.1	LDA-4507/4508	11.8	68335 sh6				SR: N/A CR: MONTHLY
101	17.3.1	WFT-101/102-2	11.8	68335 sh2	AZ042-1 / ET-00951			SR: N/A CR: SEMI-ANN
101	17.3.1	WFAS-101/102-1	11.8	68335 sh2	AZ042-2 / ET-00998			SR: N/A CR: SEMI-ANN
101	17.3.1	WFA-101/102-1	11.8	68335 sh2	AZ042-3 / ET-02081			SR: N/A CR: SEMI-ANN
101	17.3.1	WFT-101/102-1	11.8	68335 sh2	AZ040-1 / ET-00970			SR: N/A CR: N/A
101	17.3.1	WFI-101/102-1	11.8	68335 sh2	AZ040-2 / ET-00849			SR: N/A CR: N/A
101	17.3.1	RE-101/102-1	11.8	68335 sh2	AZ088-1 / ET-00581			SR: N/A CR: N/A
101	17.3.1	PAD-101/102-1	11.8	68335 sh2	AZ088-2 / ET-02302			SR: N/A CR: N/A
101	17.3.1	CRM-101/102-1	11.8	68335 sh2	AZ088-3 / ET-02281			SR: N/A CR: N/A
101	17.3.1	RA-101/102	11.8	68335 sh2	AZ088-4 / ET-01936			SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-37		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-38		68335 sh6				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.4.1.2.c	TE-101-39		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-40		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-41		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-42		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-43		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-44		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-45		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-46		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-47		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-48		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-49		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-50		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-51		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-52		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-53		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-54		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-55		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-56		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-57		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	TE-101-58		68335 sh6				SR: N/A CR: N/A
101	17.4.1.2.c	DATA LOGGER		68335 sh6			$\Delta T \leq 30^{\circ} F$	SR: N/A CR: N/A
101	17.4.5.A	TE-101-59		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	TE-101-60		68335 sh6				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 11K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.4.5.A	TE-101-62		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	TE-101-63		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	TE-101-65		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	TE-101-66		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	TE-101-68		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	TE-101-69		68335 sh6				SR: N/A CR: N/A
101	17.4.5.A	DATA LOGGER		68335 sh6			≤ 260° F	SR: N/A CR: N/A
101	17.4.5.B	TE-101-61		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	TE-101-64		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	TE-101-67		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	TE-101-70		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	TE-101-71		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	TE-101-72		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	TE-101-73		68335 sh6				SR: N/A CR: N/A
101	17.4.5.B	DATA LOGGER		68335 sh6			≤ 400° F	SR: N/A CR: N/A
101	17.4.5.C	TE-101-37		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-38		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-39		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-40		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-41		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-42		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-43		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-44		68335 sh6				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 12K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.4.5.C	TE-101-45		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-46		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-47		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-48		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-49		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-50		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-51		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-52		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-53		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-54		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-55		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-56		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-57		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-58		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-59		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-60		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-61		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-62		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-63		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-64		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-65		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-66		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-67		68335 sh6				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 13K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.4.5.C	TE-101-68		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-69		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	TE-101-70		68335 sh6				SR: N/A CR: N/A
101	17.4.5.C	DATA LOGGER		68335 sh6				SR: N/A CR: N/A
101	17.4.6	FI-101-1	11.5	68335 sh5	AZ101-1 / ET-01549			SR: SHIFT CR: N/A
101	17.4.6	FI-101-2	11.5	68335 sh5	AZ101-2 / ET-05053			SR: SHIFT CR: N/A
101	17.4.6	FI-101-3	11.5	68335 sh5	AZ101-3 / ET-05120			SR: SHIFT CR: N/A
101	17.4.6	FI-101-4	11.5	68335 sh5	AZ101-4 / ET-05089			SR: SHIFT CR: N/A
101	17.4.6	FI-101-5	11.5	68335 sh5	AZ101-5 / ET-05096			SR: SHIFT CR: N/A
101	17.4.6	FI-101-6	11.5	68335 sh5	AZ101-6 / ET-05066			SR: SHIFT CR: N/A
101	17.4.6	FI-101-7	11.5	68335 sh5	AZ101-7 / ET-05067			SR: SHIFT CR: N/A
101	17.4.6	FI-101-8	11.5	68335 sh5	AZ101-8 / ET-05084			SR: SHIFT CR: N/A
101	17.4.6	FI-101-9	11.5	68335 sh5	AZ101-9 / ET-05087			SR: SHIFT CR: N/A
101	17.4.6	FI-101-10	11.5	68335 sh5	AZ101-A / ET-05129			SR: SHIFT CR: N/A
101	17.4.6	FI-101-11	11.5	68335 sh5	AZ101-B / ET-05103			SR: SHIFT CR: N/A
101	17.4.6	FI-101-12	11.5	68335 sh5	AZ101-C / ET-05078			SR: SHIFT CR: N/A
101	17.4.6	FI-101-13	11.5	68335 sh5	AZ101-D / ET-05127			SR: SHIFT CR: N/A
101	17.4.6	FI-101-14	11.5	68335 sh5	AZ101-E / ET-05116			SR: SHIFT CR: N/A
101	17.4.6	FI-101-15	11.5	68335 sh5	AZ101-F / ET-05088			SR: SHIFT CR: N/A
101	17.4.6	FI-101-16	11.5	68335 sh5	AZ101-G / ET-05100			SR: SHIFT CR: N/A
101	17.4.6	FI-101-17	11.5	68335 sh5	AZ101-H / ET-05101			SR: SHIFT CR: N/A
101	17.4.6	FI-101-18	11.5	68335 sh5	AZ101-I / ET-05052			SR: SHIFT CR: N/A
101	17.4.6	FI-101-19	11.5	68335 sh5	AZ101-J / ET-05049			SR: SHIFT CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 14K of 14K

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	17.4.6	FI-101-20	11.5	68335 sh5	AZ101-K / ET-05131			SR: SHIFT CR: N/A
101	17.4.6	FI-101-21	11.5	68335 sh5	AZ101-L / ET-05098			SR: SHIFT CR: N/A
101	17.4.6	FI-101-22	11.5	68335 sh5	AZ101-M / ET-05099			SR: SHIFT CR: N/A
101	17.4.6	FIT-101-1	11.5	68335 sh5	AZ109-1 / ET-02529		≥ 50scfm	SR: SHIFT CA: ANNUALLY
101	17.4.6	FAS-101-1	11.5	68335 sh6	AZ109-7 / ET-00994	< 60scfm		SR: N/A CR: ANNUALLY
101	17.4.6	FR-101-1	11.5	68335 sh6	AZ109-2 / ET-00754			SR: N/A CR: ANNUALLY
101	17.4.6	MS-101-AZ-1	11.5	68335 sh6	AZ109-6 / ET-02109			SR: N/A CR: ANNUALLY
101	17.4.6	TDK-101-AZ-1	11.5	68335 sh6	AZ109-4 / ET-00015			SR: N/A CR: ANNUALLY
101	17.4.6	TDK-101-AZ-2	11.5	68335 sh6	AZ109-5 / ET-00431			SR: N/A CR: ANNUALLY
101	17.4.6	KFS-101-AZ-1	11.5	68335 sh6	AZ109-3 / ET-00147			SR: N/A CR: ANNUALLY
101	17.4.6	FA-101-1	11.5	68335 sh6	AZ109-8 / ET-02001			SR: N/A CR: ANNUALLY
101	17.4.7	PT-101-1	11.7	68335 sh6	AZ104-1 / ET-00988			SR: N/A CR: ANNUALLY
101	17.4.7	PT-101-2	11.7	68335 sh6	AZ103-1 / ET-00983			SR: N/A CR: ANNUALLY
101	17.4.7	PR-101-1	11.7	68335 sh6	AZ104-2 / ET-00738			SR: CONT CR: ANNUALLY
101	17.4.7	PR-101-2	11.7	68335 sh6	AZ103-2 / ET-00752			SR: CONT CR: ANNUALLY
101	17.4.7	PAS-101-1	11.7	68335 sh6	AZ104-3 / ET-01046	< -0.1"		SR: N/A CR: ANNUALLY
101	17.4.7	PA-101-1	11.7	68335 sh6	AZ104-6 / ET-01944			SR: N/A CR: ANNUALLY
101	17.4.7	ANN-LS	11.7	68335 sh6				SR: N/A CR: ANNUALLY
101	17.4.7	HORN ALARM (LS-1)	11.7	68335 sh6				SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1L of 14L

241-AZ-102

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.1.1	LLI-102-2	11.13	68335 sh3	AZ051-2 / ET-00254		364", 64"	SR: DAILY CR: SEMI-ANN
102	17.2.1.1	LLE-102-2	11.13	68335 sh3	AZ051-1 / ET-00219			SR: N/A CR: SEMI-ANN
102	17.2.1.1	LIT-102-AZ	11.13	68335 sh3	AZ085-2 / ET-01355		364", 64"	SR: N/A CR: SEMI-ANN
102	17.2.1.1	LIAS-102-1	11.13	68335 sh3	AZ044-2 / ET-03587	360"		SR: DAILY CR: SEMI-ANN
102	17.2.1.1	LLE-102-1	11.13	68335 sh3	AZ044-1 / ET-00095			SR: N/A CR: SEMI-ANN
102	17.2.1.1	LLK-102-1	11.13	68335 sh2	AZ044-3 / ET-00447			SR: N/A CR: SEMI-ANN
102	17.2.1.1	LLA-102-1	11.13	68335 sh2	AZ044-4 / ET-02044			SR: CONT CR: SEMI-ANN
102	17.2.1.2.A	WFT-102-1		68335 sh2	AZ041-1 / ET-00952			SR: N/A CR: N/A
102	17.2.1.2.A	WFI-102-1		68335 sh2	AZ041-2 / ET-00853		≤ 74"	SR: N/A CR: N/A
102	17.2.1.2.A	WFT-102-2		68335 sh2	AZ043-1 / ET-01133			SR: N/A CR: N/A
102	17.2.1.2.A	WFAS-102-1		68335 sh2	AZ043-2 / ET-01050	30"		SR: N/A CR: N/A
102	17.2.1.2.A	WFA-102-1		68335 sh2	AZ043-3 / ET-02050			SR: N/A CR: N/A
102	17.2.2	SS-102-A	11.6	68335 sh2	AZ091-1 / ET-01300			SR: N/A CR: QUARTERLY
102	17.2.2	SS-102-B	11.6	68335 sh2	AZ090-1 / ET-01298			SR: N/A CR: QUARTERLY
102	17.2.2	SS-102-C	11.6	68335 sh2	AZ092-1 / ET-01301			SR: N/A CR: QUARTERLY
102	17.2.2	LDI-102-1	11.6	68335 sh2				SR: N/A CR: MONTHLY
102	17.2.2	LDK-102-1	11.6	68335 sh2	AZ208-2 / ET-03762			SR: N/A CR: QUARTERLY
102	17.2.2	LDA-102-1A	11.6	68335 sh2	AZ208-4 / ET-03067			SR: N/A CR: MONTHLY
102	17.2.2	LI-102-1	11.6	68335 sh2	AZ208-3 / ET-02983			SR: N/A CR: QUARTERLY
102	17.2.2	LDE-102-1	11.6	68335 sh2	AZ208-1 / ET-04071			SR: N/A CR: N/A
102	17.2.2	LDE-102-1A	11.6	68335 sh3	AZ091-2 / ET-05287			SR: N/A CR: N/A
102	17.2.2	LDE-102-2A	11.6	68335 sh3	AZ091-3 / ET-05183			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.2	LDE-102-3A	11.6	68335 sh3	AZ091-4 / ET-05184			SR: N/A CR: N/A
102	17.2.2	LDE-102-4A	11.6	68335 sh3	AZ091-5 / ET-05188			SR: N/A CR: N/A
102	17.2.2	LDE-102-5A	11.6	68335 sh3	AZ091-6 / ET-05179			SR: N/A CR: N/A
102	17.2.2	LDE-102-6A	11.6	68335 sh3	AZ091-7 / ET-05250			SR: N/A CR: N/A
102	17.2.2	LDE-102-7A	11.6	68335 sh3	AZ091-8 / ET-05302			SR: N/A CR: N/A
102	17.2.2	LDE-102-8A	11.6	68335 sh3	AZ091-9 / ET-05212			SR: N/A CR: N/A
102	17.2.2	LDE-102-9A	11.6	68335 sh3	AZ091-A / ET-05223			SR: N/A CR: N/A
102	17.2.2	LDE-102-10A	11.6	68335 sh3	AZ091-B / ET-05330			SR: N/A CR: N/A
102	17.2.2	LDE-102-11A	11.6	68335 sh3	AZ091-C / ET-05232			SR: N/A CR: N/A
102	17.2.2	LDE-102-12A	11.6	68335 sh3	AZ091-D / ET-05290			SR: N/A CR: N/A
102	17.2.2	LDE-102-13A	11.6	68335 sh3	AZ091-E / ET-05291			SR: N/A CR: N/A
102	17.2.2	LDE-102-14A	11.6	68335 sh3	AZ091-F / ET-05319			SR: N/A CR: N/A
102	17.2.2	LDE-102-15A	11.6	68335 sh3	AZ091-G / ET-05159			SR: N/A CR: N/A
102	17.2.2	LDE-102-16A	11.6	68335 sh3	AZ091-H / ET-05153			SR: N/A CR: N/A
102	17.2.2	LDE-102-17A	11.6	68335 sh3	AZ091-I / ET-05249			SR: N/A CR: N/A
102	17.2.2	LDE-102-1B	11.6	68335 sh3	AZ090-2 / ET-05313			SR: N/A CR: N/A
102	17.2.2	LDE-102-2B	11.6	68335 sh3	AZ090-3 / ET-05329			SR: N/A CR: N/A
102	17.2.2	LDE-102-3B	11.6	68335 sh3	AZ090-4 / ET-05277			SR: N/A CR: N/A
102	17.2.2	LDE-102-4B	11.6	68335 sh3	AZ090-5 / ET-05276			SR: N/A CR: N/A
102	17.2.2	LDE-102-5B	11.6	68335 sh3	AZ090-6 / ET-05198			SR: N/A CR: N/A
102	17.2.2	LDE-102-6B	11.6	68335 sh3	AZ090-7 / ET-05185			SR: N/A CR: N/A
102	17.2.2	LDE-102-7B	11.6	68335 sh3	AZ090-8 / ET-05233			SR: N/A CR: N/A
102	17.2.2	LDE-102-8B	11.6	68335 sh3	AZ090-9 / ET-05286			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.2	LDE-102-9B	11.6	68335 sh3	AZ090-A / ET-05289			SR: N/A CR: N/A
102	17.2.2	LDE-102-10B	11.6	68335 sh3	AZ090-B / ET-05218			SR: N/A CR: N/A
102	17.2.2	LDE-102-11B	11.6	68335 sh3	AZ090-C / ET-05219			SR: N/A CR: N/A
102	17.2.2	LDE-102-12B	11.6	68335 sh3	AZ090-D / ET-05155			SR: N/A CR: N/A
102	17.2.2	LDE-102-13B	11.6	68335 sh3	AZ090-E / ET-05244			SR: N/A CR: N/A
102	17.2.2	LDE-102-14B	11.6	68335 sh3	AZ090-F / ET-05274			SR: N/A CR: N/A
102	17.2.2	LDE-102-15B	11.6	68335 sh3	AZ090-G / ET-05327			SR: N/A CR: N/A
102	17.2.2	LDE-102-16B	11.6	68335 sh3	AZ090-H / ET-05143			SR: N/A CR: N/A
102	17.2.2	LDE-102-17B	11.6	68335 sh3	AZ090-I / ET-05165			SR: N/A CR: N/A
102	17.2.2	LDE-102-1C	11.6	68335 sh3	AZ092-2 / ET-05186			SR: N/A CR: N/A
102	17.2.2	LDE-102-2C	11.6	68335 sh3	AZ092-3 / ET-05204			SR: N/A CR: N/A
102	17.2.2	LDE-102-3C	11.6	68335 sh3	AZ092-4 / ET-05182			SR: N/A CR: N/A
102	17.2.2	LDE-102-4C	11.6	68335 sh3	AZ092-5 / ET-05253			SR: N/A CR: N/A
102	17.2.2	LDE-102-5C	11.6	68335 sh3	AZ092-6 / ET-05254			SR: N/A CR: N/A
102	17.2.2	LDE-102-6C	11.6	68335 sh3	AZ092-7 / ET-05288			SR: N/A CR: N/A
102	17.2.2	LDE-102-7C	11.6	68335 sh3	AZ092-8 / ET-05220			SR: N/A CR: N/A
102	17.2.2	LDE-102-8C	11.6	68335 sh3	AZ092-9 / ET-05216			SR: N/A CR: N/A
102	17.2.2	LDE-102-9C	11.6	68335 sh3	AZ092-A / ET-05157			SR: N/A CR: N/A
102	17.2.2	LDE-102-10C	11.6	68335 sh3	AZ092-B / ET-05325			SR: N/A CR: N/A
102	17.2.2	LDE-102-11C	11.6	68335 sh3	AZ092-C / ET-05282			SR: N/A CR: N/A
102	17.2.2	LDE-102-12C	11.6	68335 sh3	AZ092-D / ET-05160			SR: N/A CR: N/A
102	17.2.2	LDE-102-13C	11.6	68335 sh3	AZ092-E / ET-05309			SR: N/A CR: N/A
102	17.2.2	LDE-102-14C	11.6	68335 sh3	AZ092-F / ET-05161			SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
102	17.2.2	LDE-102-15C	11.6	68335 sh3	AZ092-G / ET-05162			SR: N/A CR: N/A
102	17.2.2	LDE-102-16C	11.6	68335 sh3	AZ092-H / ET-05241			SR: N/A CR: N/A
102	17.2.2	LDE-102-17C	11.6	68335 sh3	AZ092-I / ET-05273			SR: N/A CR: N/A
102	17.2.2	CAM-102-AZ	11.6	92964	YAZ03-1 / ET-01573			SR: N/A CR: MONTHLY
102	17.2.2	RR-102-AZ	11.6	92964				SR: N/A CR: MONTHLY
102	17.2.2	RA-102-AZ	11.6	92964	AZ015-3 / ET-01721			SR: N/A CR: MONTHLY
102	17.2.2	PS-CAM-1-102-AZ	11.6	92964	AZ015-2 / ET-01146			SR: N/A CR: MONTHLY
102	17.2.2	QQ-CAM-102-AZ	11.6	92964	AZ015-1 / ET-04856			SR: N/A CR: MONTHLY
102	17.2.3	LIT-102-AZ	11.4	68335 sh3	AZ085-2 / ET-01355		744", 0"	SR: DAILY CR: N/A
102	17.2.3	LLE-102-2	11.4	68335 sh3	AZ051-1 / ET-00219			SR: N/A CR: N/A
102	17.2.3	LLI-102-2	11.4	68335 sh3	AZ051-2 / ET-00254		744", 0"	SR: DAILY CR: N/A
102	17.2.3	PT-102-1	11.4	68335 sh2	AZ077-1 / ET-00971			SR: N/A CR: ANNUALLY
102	17.2.3	PT-102-2	11.4	68335 sh2	AZ074-1 / ET-01135			SR: N/A CR: ANNUALLY
102	17.2.3	PR-102-1	11.4	68335 sh2	AZ077-2 / ET-00742			SR: CONT CR: N/A
102	17.2.3	PR-102-2	11.4	68335 sh2	AZ074-2 / ET-00746			SR: CONT CR: N/A
102	17.2.3	PI-TK-102-AZ	11.4	68335 sh3	AZ201-1 / ET-00666			SR: N/A CR: N/A
102	17.2.6.A	TE-102-25	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.A	TE-102-26	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.A	DATA LOGGER	11.15	68335 sh3			≤ 380° F	SR: DAILY CR: N/A
102	17.2.6.B	TE-102-1	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-2	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-3	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-4	11.15	68335 sh3				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.6.B	TE-102-5	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-6	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-7	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-8	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-9	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-10	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-11	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-12	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-13	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-14	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-15	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-16	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-17	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-18	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-19	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-20	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-21	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-22	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-23	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	TE-102-24	11.15	68335 sh3				SR: N/A CR: N/A
102	17.2.6.B	DATA LOGGER	11.15	68335 sh3			≤ 400° F	SR: DAILY CR: N/A
102	17.2.7.A	TE-102-28		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-29		68335 sh3				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.7.A	TE-102-30		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-31		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-32		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-33		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-34		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-35		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-36		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-86		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-87		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-88		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-89		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-90		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-91		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-92		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-93		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-94		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-95		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-96		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	TE-102-97		68335 sh3				SR: N/A CR: N/A
102	17.2.7.A	DATA LOGGER		68335 sh3			≤ 350° F	SR: MONTHLY CR: N/A
102	17.2.7.B	TE-102-74		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-75		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-76		68335 sh3				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 7L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.7.B	TE-102-77		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-78		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-79		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-80		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-81		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-82		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-83		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-84		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	TE-102-85		68335 sh3				SR: N/A CR: N/A
102	17.2.7.B	DATA LOGGER		68335 sh3			≤ 240° F	SR: MONTHLY CR: N/A
102	17.2.7.C	TE-102-74		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-75		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-76		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-77		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-78		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-79		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-80		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-81		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-82		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-83		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-84		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-85		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-86		68335 sh3				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 8L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.2.7.C	TE-102-87		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-88		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-89		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-90		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-91		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-92		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-93		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-94		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-95		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-96		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	TE-102-97		68335 sh3				SR: N/A CR: N/A
102	17.2.7.C	DATA LOGGER		68335 sh3			≤ 18° F/ft	SR: MONTHLY CR: N/A
102	17.3.1	LDE-102-18	11.8	68335 sh3	AZ055-1 / ET-01281			SR: N/A CR: PRESTARTUP
102	17.3.1	LDK-102-18	11.8	68335 sh2	AZ055-2 / ET-00309			SR: N/A CR: QUARTERLY
102	17.3.1	LDK-102-18B	11.8	68335 sh2	AZ055-3 / ET-00292			SR: N/A CR: QUARTERLY
102	17.3.1	LDA-102-18	11.8	68335 sh2	AZ055-4 / ET-02071			SR: N/A CR: MONTHLY
102	17.3.1	LDE-102-19	11.8	68335 sh3	AZ053-1 / ET-01272			SR: N/A CR: PRESTARTUP
102	17.3.1	LDK-102-19	11.8	68335 sh2	AZ053-2 / ET-00304			SR: N/A CR: QUARTERLY
102	17.3.1	LDK-102-19B	11.8	68335 sh2	AZ053-3 / ET-00305			SR: N/A CR: QUARTERLY
102	17.3.1	LDA-102-19	11.8	68335 sh2	AZ053-4 / ET-01831			SR: N/A CR: MONTHLY
102	17.3.1	LDE-102-20	11.8	68335 sh3	AZ047-1 / ET-01247			SR: N/A CR: PRESTARTUP
102	17.3.1	LDK-102-20A	11.8	68335 sh2	AZ047-2 / ET-00012			SR: N/A CR: QUARTERLY
102	17.3.1	LDK-102-20B	11.8	68335 sh2	AZ047-3 / ET-00049			SR: N/A CR: QUARTERLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 9L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.3.1	LDA-102-20A	11.8	68335 sh2	AZ047-4 / ET-01877			SR: N/A CR: MONTHLY
102	17.3.1	LDE-102-24	11.8	68335 sh2	AZ052-1 / ET-01250			SR: N/A CR: PRESTARTUP
102	17.3.1	LDK-102-24	11.8	68335 sh2	AZ052-2 / ET-00106			SR: N/A CR: QUARTERLY
102	17.3.1	LDA-102-24A	11.8	68335 sh2	AZ052-3 / ET-01864			SR: N/A CR: MONTHLY
102	17.4.1.2.c	TE-102-37		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-38		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-39		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-40		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-41		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-42		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-43		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-44		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-45		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-46		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-47		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-48		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-49		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-50		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-51		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-52		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-53		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-54		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-55		68335 sh2				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.4.1.2.c	TE-102-56		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-57		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	TE-102-58		68335 sh2				SR: N/A CR: N/A
102	17.4.1.2.c	DATA LOGGER		68335 sh2			$\Delta T \leq 30^{\circ} \text{ F}$	SR: N/A CR: N/A
102	17.4.5.A	TE-102-59		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-60		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-62		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-63		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-65		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-66		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-68		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	TE-102-69		68335 sh2				SR: N/A CR: N/A
102	17.4.5.A	DATA LOGGER		68335 sh2			$\leq 260^{\circ} \text{ F}$	SR: N/A CR: N/A
102	17.4.5.B	TE-102-61		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	TE-102-64		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	TE-102-67		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	TE-102-70		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	TE-102-71		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	TE-102-72		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	TE-102-73		68335 sh2				SR: N/A CR: N/A
102	17.4.5.B	DATA LOGGER		68335 sh2			$\leq 400^{\circ} \text{ F}$	SR: N/A CR: N/A
102	17.4.5.C	TE-102-37		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-38		68335 sh2				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 11L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.4.5.C	TE-102-39		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-40		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-41		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-42		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-43		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-44		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-45		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-46		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-47		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-48		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-49		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-50		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-51		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-52		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-53		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-54		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-55		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-56		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-57		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-58		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-59		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-60		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-61		68335 sh2				SR: N/A CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 12L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPPOINT	LIMIT	FREQUENCY
102	17.4.5.C	TE-102-62		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-63		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-64		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-65		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-66		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-67		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-68		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-69		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	TE-102-70		68335 sh2				SR: N/A CR: N/A
102	17.4.5.C	DATA LOGGER		68335 sh2				SR: N/A CR: N/A
102	17.4.6	FI-102-1	11.5	68335 sh5	AZ068-1 / ET-01620			SR: SHIFT CR: N/A
102	17.4.6	FI-102-2	11.5	68335 sh5	AZ068-2 / ET-05104			SR: SHIFT CR: N/A
102	17.4.6	FI-102-3	11.5	68335 sh5	AZ068-3 / ET-05072			SR: SHIFT CR: N/A
102	17.4.6	FI-102-4	11.5	68335 sh5	AZ068-4 / ET-05063			SR: SHIFT CR: N/A
102	17.4.6	FI-102-5	11.5	68335 sh5	AZ068-5 / ET-05060			SR: SHIFT CR: N/A
102	17.4.6	FI-102-6	11.5	68335 sh5	AZ068-6 / ET-05061			SR: SHIFT CR: N/A
102	17.4.6	FI-102-7	11.5	68335 sh5	AZ068-7 / ET-05117			SR: SHIFT CR: N/A
102	17.4.6	FI-102-8	11.5	68335 sh5	AZ068-8 / ET-05110			SR: SHIFT CR: N/A
102	17.4.6	FI-102-9	11.5	68335 sh5	AZ068-9 / ET-05076			SR: SHIFT CR: N/A
102	17.4.6	FI-102-10	11.5	68335 sh5	AZ068-A / ET-05082			SR: SHIFT CR: N/A
102	17.4.6	FI-102-11	11.5	68335 sh5	AZ068-B / ET-05080			SR: SHIFT CR: N/A
102	17.4.6	FI-102-12	11.5	68335 sh5	AZ068-C / ET-05085			SR: SHIFT CR: N/A
102	17.4.6	FI-102-13	11.5	68335 sh5	AZ068-D / ET-05105			SR: SHIFT CR: N/A

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 13L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.4.6	FI-102-14	11.5	68335 sh5	AZ068-E / ET-05125			SR: SHIFT CR: N/A
102	17.4.6	FI-102-15	11.5	68335 sh5	AZ068-F / ET-05054			SR: SHIFT CR: N/A
102	17.4.6	FI-102-16	11.5	68335 sh5	AZ068-G / ET-05055			SR: SHIFT CR: N/A
102	17.4.6	FI-102-17	11.5	68335 sh5	AZ068-H / ET-05121			SR: SHIFT CR: N/A
102	17.4.6	FI-102-18	11.5	68335 sh5	AZ068-I / ET-05126			SR: SHIFT CR: N/A
102	17.4.6	FI-102-19	11.5	68335 sh5	AZ068-J / ET-05097			SR: SHIFT CR: N/A
102	17.4.6	FI-102-20	11.5	68335 sh5	AZ068-K / ET-05062			SR: SHIFT CR: N/A
102	17.4.6	FI-102-21	11.5	68335 sh5	AZ068-L / ET-05075			SR: SHIFT CR: N/A
102	17.4.6	FI-102-22	11.5	68335 sh5	AZ068-M / ET-05064			SR: SHIFT CR: N/A
102	17.4.6	FIT-102-1	11.5	68335 sh5	AZ069-1 / ET-02528		≥ 50scfm	SR: SHIFT CA: ANNUALLY
102	17.4.6	FAS-102-1	11.5	68335 sh2	AZ069-7 / ET-01053	< 60scfm		SR: N/A CR: ANNUALLY
102	17.4.6	FR-102-1	11.5	68335 sh2	AZ069-2 / ET-00751			SR: N/A CR: ANNUALLY
102	17.4.6	MS-102-AZ-1	11.5	68335 sh2	AZ069-6 / ET-04863			SR: N/A CR: ANNUALLY
102	17.4.6	TDK-102-AZ-1	11.5	68335 sh2	AZ069-4 / ET-00158			SR: N/A CR: ANNUALLY
102	17.4.6	TDK-102-AZ-2	11.5	68335 sh2	AZ069-5 / ET-00140			SR: N/A CR: ANNUALLY
102	17.4.6	KFS-102-AZ-1	11.5	68335 sh2	AZ069-3 / ET-02101			SR: N/A CR: ANNUALLY
102	17.4.6	FA-102-1	11.5	68335 sh2	AZ069-8 / ET-01961			SR: N/A CR: ANNUALLY
102	17.4.7	PT-102-1	11.7	68335 sh2	AZ077-1 / ET-00971			SR: N/A CR: ANNUALLY
102	17.4.7	PT-102-2	11.7	68335 sh2	AZ074-1 / ET-01135			SR: N/A CR: ANNUALLY
102	17.4.7	PR-102-1	11.7	68335 sh2	AZ077-2 / ET-00742			SR: CONT CR: ANNUALLY
102	17.4.7	PR-102-2	11.7	68335 sh2	AZ074-2 / ET-00746			SR: CONT CR: ANNUALLY
102	17.4.7	PAS-102-1	11.7	68335 sh2	AZ077-3 / ET-02478	< -0.1"		SR: N/A CR: ANNUALLY
102	17.4.7	PA-102-1	11.7	68335 sh2	AZ077-6 / ET-01993			SR: N/A CR: ANNUALLY

DOUBLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 14L of 14L

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
102	17.4.7	ANN-LS	11.7	68335 sh2				SR: N/A CR: ANNUALLY
102	17.4.7	HORN ALARM (LS-1)	11.7	68335 sh2				SR: N/A CR: ANNUALLY

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1M of 6M

241-B

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	13.2.1.B	LIT-101-B		37851	B0169-1 /ET-01376		185"	SR: N/A CR: N/A
102	13.2.1.B	LIT-102-B		37851	B0163-1 /ET-01347		185"	SR: N/A CR: N/A
103	13.2.1.B	LIT-103-B		37851	B0164-1 /ET-01373		185"	SR: N/A CR: N/A
104	13.2.1.B	LIQ LVL TAPE 104-B		SDRETI053			185"	SR: N/A CR: N/A
105	13.2.1.B	LIQ LVL TAPE 105-B		SDRETI053			185"	SR: N/A CR: N/A
106	13.2.1.B	LIT-106-B		37851	B0165-1 /ET-01362		185"	SR: N/A CR: N/A
107	13.2.1.B	LIQ LVL TAPE 107-B		SDRETI053			185"	SR: N/A CR: N/A
108	13.2.1.B	LIT-108-B		37851	B0166-1 /ET-03723		185"	SR: N/A CR: N/A
109	13.2.1.B	LIQ LVL TAPE 109-B		SDRETI053			185"	SR: N/A CR: N/A
110	13.2.1.B	LIQ LVL TAPE 110-B		SDRETI053			185"	SR: N/A CR: N/A
111	13.2.1.B	LIT-111-B		37851	B0167-1 /ET-03722		185"	SR: N/A CR: N/A
112	13.2.1.B	LIT-112-B		37851	B0168-1 /ET-01349		185"	SR: N/A CR: N/A
201	13.2.1.B	LIQ LVL TAPE 201-B		SDRETI053			280"	SR: N/A CR: N/A
202	13.2.1.B	LIQ LVL TAPE 202-B		SDRETI053			280"	SR: N/A CR: N/A
203	13.2.1.B	LIQ LVL TAPE 203-B		SDRETI053			280"	SR: N/A CR: N/A
204	13.2.1.B	LIQ LVL TAPE 204-B		SDRETI053			280"	SR: N/A CR: N/A
101	13.2.1.E	TANK-B-101 TE R #9	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
102	13.2.1.E	TANK-B-102 TE R #4	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
103	13.2.1.E	TANK-B-103 TE R #4	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
104	13.2.1.E	TANK-B-104 TE R #5	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
105	13.2.1.E	TANK-B-105 TE R #4	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
106	13.2.1.E	TANK-B-106 TE R #4	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2M of 6M

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	13.2.1.E	TANK-B-107 TE R #3	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
108	13.2.1.E	TANK-B-108 TE R #5	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
109	13.2.1.E	TANK-B-109 TE R #1	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
110	13.2.1.E	TANK-B-110 TE R #8	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
111	13.2.1.E	TANK-B-111 TE R #8	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
112	13.2.1.E	TANK-B-112 TE R #1	11.4.2.1	37851			300° F LCO=350°	SR: N/A CR: N/A
201	13.2.1.E	TANK-B-201 TE R #1	11.4.2.1	SDRETI053			300° F LCO=350°	SR: N/A CR: N/A
202	13.2.1.E	TANK-B-202 TE R #1	11.4.2.1	SDRETI053			300° F LCO=350°	SR: N/A CR: N/A
203	13.2.1.E	TANK-B-203 TE R #1	11.4.2.1	SDRETI053			300° F LCO=350°	SR: N/A CR: N/A
204	13.2.1.E	TANK-B-204 TE R #1	11.4.2.1	SDRETI053			300° F LCO=350°	SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-B-1		38385	B0162-1 /ET-00323			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-B-1		38385	B0162-2 /ET-04303			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-B-1		38385	B0162-3 /ET-01711			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-B-2		38385	B0161-1 /ET-00369			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-B-2		38385	B0161-2 /ET-04306			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-B-2		38385	B0161-3 /ET-01951			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-B-3		38385	B0160-1 /ET-00380			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-B-3		38385	B0160-2 /ET-04307			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-B-3		38385	B0160-3 /ET-02022			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-B-4		38385	B0159-1 /ET-00115			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-B-4		38385	B0159-2 /ET-04304			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-B-4		38385	B0159-3 /ET-01799			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-B-5		38385	B0158-1 /ET-00241			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3M of 6M

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101-112	13.2.4.A	RAMP-241-B-5		38385	B0158-2 /ET-04305			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-B-5		38385	B0158-3 /ET-00288			SR: N/A CR: N/A
101-112	13.2.4.A	RR-241-B-1		38385	B0160-4 /ET-00803			SR: N/A CR: N/A
101-112	13.2.4.A	K-RAT-39A		70880	B0021-1 /ET-04172			SR: N/A CR: N/A
101-112	13.2.4.A	KRLD-39A		70880	B0021-2 /ET-04169			SR: N/A CR: N/A
101-112	13.2.4.A	RA-39A		70880	B0021-3 /ET-04015			SR: N/A CR: N/A
101-112	13.2.4.B	LDA-241B-1		70880	B0002-5 /ET-04088			SR: N/A CR: N/A
101-112	13.2.4.B	LDA-241B-2		70880	B0002-C /ET-04126			SR: N/A CR: N/A
103	13.2.4.B	LDE-241B-103		70880	B0002-1 /ET-02652			SR: N/A CR: N/A
103	13.2.4.B	LDK-241B-103-1		70880	B0002-2 /ET-02782			SR: N/A CR: N/A
103	13.2.4.B	MS-241B-103-1		70880	B0002-3 /ET-03534			SR: N/A CR: N/A
103	13.2.4.B	MS-241B-103-2		70880				SR: N/A CR: N/A
103	13.2.4.B	MS-241B-103-3		70880				SR: N/A CR: N/A
103	13.2.4.B	LDK-241B-103-2		70880	B0002-A /ET-02791			SR: N/A CR: N/A
103	13.2.4.B	MSA-241B-103-1		70880	B0022-1 /ET-04017			SR: N/A CR: N/A
104	13.2.4.B	LDE-241B-104		70880	B0029-1 /ET-03912			SR: N/A CR: N/A
104	13.2.4.B	LDK-241B-104-1		70880	B0029-2 /ET-02815			SR: N/A CR: N/A
104	13.2.4.B	LDK-241B-104-2		70880	B0029-4 /ET-02805			SR: N/A CR: N/A
104	13.2.4.B	MS-241B-104-1		70880				SR: N/A CR: N/A
104	13.2.4.B	MS-241B-104-2		70880				SR: N/A CR: N/A
104	13.2.4.B	MS-241B-104-3		70880				SR: N/A CR: N/A
104	13.2.4.B	MSA-241B-104-1		70880	B0041-1 /ET-04028			SR: N/A CR: N/A
105	13.2.4.B	LDE-241B-105		70880				SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4M of 6M

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	13.2.4.B	LDK-241B-105-1		70880	B0044-2 /ET-02727			SR: N/A CR: N/A
105	13.2.4.B	LDK-241B-105-2		70880	B0044-A /ET-03012			SR: N/A CR: N/A
105	13.2.4.B	MS-241B-105-1		70880				SR: N/A CR: N/A
105	13.2.4.B	MS-241B-105-2		70880				SR: N/A CR: N/A
105	13.2.4.B	MS-241B-105-3		70880				SR: N/A CR: N/A
105	13.2.4.B	MSA-241B-105-1		70880	B0055-1 /ET-04112			SR: N/A CR: N/A
106	13.2.4.B	LDE-241B-106		70880	B0058-1 /ET-03898			SR: N/A CR: N/A
106	13.2.4.B	LDK-241B-106-1		70880	B0058-2 /ET-03003			SR: N/A CR: N/A
106	13.2.4.B	LDK-241B-106-2		70880	B0058-A /ET-02997			SR: N/A CR: N/A
106	13.2.4.B	MS-241B-106-1		70880				SR: N/A CR: N/A
106	13.2.4.B	MS-241B-106-2		70880				SR: N/A CR: N/A
106	13.2.4.B	MS-241B-106-3		70880				SR: N/A CR: N/A
106	13.2.4.B	MSA-241B-106-1		70880	B0070-1 /ET-04032			SR: N/A CR: N/A
107	13.2.4.B	LDE-241B-107		70880	B0073-1 /ET-03901			SR: N/A CR: N/A
107	13.2.4.B	LDK-241B-107-1		70880	B0073-2 /ET-02901			SR: N/A CR: N/A
107	13.2.4.B	LDK-241B-107-2		70880	B0073-A /ET-02915			SR: N/A CR: N/A
107	13.2.4.B	MS-241B-107-1		70880				SR: N/A CR: N/A
107	13.2.4.B	MS-241B-107-2		70880				SR: N/A CR: N/A
107	13.2.4.B	MS-241B-107-3		70880				SR: N/A CR: N/A
107	13.2.4.B	MSA-241B-107-1		70880	B0085-1 /ET-03997			SR: N/A CR: N/A
108	13.2.4.B	LDE-241B-108		70880	B0088-1 /ET-03921			SR: N/A CR: N/A
108	13.2.4.B	LDK-241B-108-1		70880	B0088-2 /ET-02749			SR: N/A CR: N/A
108	13.2.4.B	LDK-241B-108-2		70880	B0088-A /ET-02750			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5M of 6M

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
108	13.2.4.B	MS-241B-108-1		70880				SR: N/A CR: N/A
108	13.2.4.B	MS-241B-108-2		70880				SR: N/A CR: N/A
108	13.2.4.B	MS-241B-108-3		70880				SR: N/A CR: N/A
108	13.2.4.B	MSA-241B-108-1		70880	B0100-1 /ET-04014			SR: N/A CR: N/A
109	13.2.4.B	LDE-241B-109		70880	B0103-1 /ET-03902			SR: N/A CR: N/A
109	13.2.4.B	LDK-241B-109-1		70880	B0103-2 /ET-02809			SR: N/A CR: N/A
109	13.2.4.B	LDK-241B-109-2		70880	B0103-A /ET-03065			SR: N/A CR: N/A
109	13.2.4.B	MS-241B-109-1		70880				SR: N/A CR: N/A
109	13.2.4.B	MS-241B-109-2		70880				SR: N/A CR: N/A
109	13.2.4.B	MS-241B-109-3		70880				SR: N/A CR: N/A
109	13.2.4.B	MSA-241B-109-1		70880	B0115-1 /ET-04051			SR: N/A CR: N/A
110	13.2.4.B	LDE-241B-110		70880	B0118-1 /ET-03896			SR: N/A CR: N/A
110	13.2.4.B	LDK-241B-110-1		70880	B0118-2 /ET-02850			SR: N/A CR: N/A
110	13.2.4.B	LDK-241B-110-2		70880	B0118-A /ET-03059			SR: N/A CR: N/A
110	13.2.4.B	MS-241B-110-1		70880				SR: N/A CR: N/A
110	13.2.4.B	MS-241B-110-2		70880				SR: N/A CR: N/A
110	13.2.4.B	MS-241B-110-3		70880				SR: N/A CR: N/A
110	13.2.4.B	MSA-241B-110		70880	B0130-1 /ET-04089			SR: N/A CR: N/A
111	13.2.4.B	LDE-241B-111		70880	B0133-1 /ET-03911			SR: N/A CR: N/A
111	13.2.4.B	LDK-241B-111-1		70880	B0133-2 /ET-02985			SR: N/A CR: N/A
111	13.2.4.B	LDK-241B-111-2		70880	B0133-A /ET-02821			SR: N/A CR: N/A
111	13.2.4.B	MS-241B-111-1		70880				SR: N/A CR: N/A
111	13.2.4.B	MS-241B-111-2		70880				SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6M of 6M

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
111	13.2.4.B	MS-241B-111-3		70880				SR: N/A CR: N/A
111	13.2.4.B	MSA-241B-111		70880	80145-1 /ET-04027			SR: N/A CR: N/A
112	13.2.4.B	LDE-241B-112		70880				SR: N/A CR: N/A
112	13.2.4.B	LDK-241B-112-1		70880				SR: N/A CR: N/A
112	13.2.4.B	LDK-241B-112-2		70880				SR: N/A CR: N/A
112	13.2.4.B	MS-241B-112-1		70880				SR: N/A CR: N/A
112	13.2.4.B	MS-241B-112-2		70880				SR: N/A CR: N/A
112	13.2.4.B	MS-241B-112-3		70880				SR: N/A CR: N/A
112	13.2.4.B	MSA-241B-112		70880				SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1N of 5N

241-BX

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	13.2.1.B	LIQ LVL TAPE 101-BX		SDRETI053			185"	SR: N/A CR: N/A
102	13.2.1.B	LIQ LVL TAPE 102-BX		SDRETI053			185"	SR: N/A CR: N/A
103	13.2.1.B	LIT-103-BX		37852	BX121-1 / ET-01345		185"	SR: N/A CR: N/A
104	13.2.1.B	LIT-104-BX		37852	BX122-1 / ET-03721		185"	SR: N/A CR: N/A
105	13.2.1.B	LIT-105-BX		37852	BX123-1 / ET-01377		185"	SR: N/A CR: N/A
106	13.2.1.B	LIT-106-BX		37852	BX124-1 / ET-01356		185"	SR: N/A CR: N/A
106	13.2.1.B	LIQ LVL TAPE 106-BX		SRRETI053			185"	SR: N/A CR: N/A
107	13.2.1.B	LIT-107-BX		37852	BX125-1 / ET-01363		185"	SR: N/A CR: N/A
108	13.2.1.B	LIT-108-BX		37852	BX126-1 / ET-03720		185"	SR: N/A CR: N/A
108	13.2.1.B	LIQ LVL TAPE 108-BX		SDRETI053			185"	SR: N/A CR: N/A
109	13.2.1.B	LIT-109-BX		37852	BX127-1 / ET-01351		185"	SR: N/A CR: N/A
110	13.2.1.B	LIQ LVL TAPE 110-BX		SRRETI053			185"	SR: N/A CR: N/A
111	13.2.1.B	LIQ LVL TAPE 111-BX		SDRETI053			185"	SR: N/A CR: N/A
112	13.2.1.B	LIT-112-BX		37852	BX128-1 / ET-01365		185"	SR: N/A CR: N/A
101	13.2.1.E	TANK-BX-101 TE R #2	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
102	13.2.1.E	TANK-BX-102 TE R #1	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
102	13.2.1.E	TANK-BX-102 TE R #8	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
103	13.2.1.E	TANK-BX-103 TE R #1	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
104	13.2.1.E	TANK-BX-104 TE R #2	11.4.2.1	73315			300°F LCO=350°	SR: N/A CR: N/A
105	13.2.1.E	TANK-BX-105 TE R #7	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
106	13.2.1.E	TNK-BX-106 T-TREE R #1	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
106	13.2.1.E	TNK-BX-106 T-TREE R #7	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2N of 5N

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	13.2.1.E	TANK-BX-107 TE R #4	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
108	13.2.1.E	TANK-BX-108 TE R #5	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
109	13.2.1.E	TNK-BX-109 T-TREE R #3	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
109	13.2.1.E	TNK-BX-109 T-TREE R #5	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
110	13.2.1.E	TANK-BX-110 TE R #1	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
111	13.2.1.E	TANK-BX-111 TE R #1	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
112	13.2.1.E	TANK-BX-112 TE R #1	11.4.2.1	37852			300°F LCO=350°	SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-BX-1		38385	BX120-1 / ET-00249			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-BX-1		38385	BX120-2 / ET-01441			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-BX-1		38385	BX120-3 / ET-01977			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-BX-2		38385	BX119-1 / ET-00138			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-BX-2		38385	BX119-2 / ET-01440			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-BX-2		38385	BX119-3 / ET-01884			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-BX-3		38385	BX118-1 / ET-00135			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-BX-3		38385	BX118-2 / ET-01439			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-BX-3		38385	BX118-3 / ET-01963			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-BX-4		38385	BX117-1 / ET-00285			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-BX-4		38385	BX117-2 / ET-01438			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-BX-4		38385	BX117-3 / ET-00362			SR: N/A CR: N/A
101-112	13.2.4.A	RE-241-BX-5		38385	BX116-1 / ET-00173			SR: N/A CR: N/A
101-112	13.2.4.A	RAMP-241-BX-5		38385	BX116-2 / ET-01442			SR: N/A CR: N/A
101-112	13.2.4.A	RAL-241-BX-5		38385	BX116-3 / ET-01926			SR: N/A CR: N/A
101-112	13.2.4.A	RR-241-B-1		38385	B0160-4 / ET-00803			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3N of 5N

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101-112	13.2.4.A	K-RAT-39A		70880	B0021-1 / ET-04172			SR: N/A CR: N/A
101-112	13.2.4.A	KRLD-39A		70880	B0021-2 / ET-04169			SR: N/A CR: N/A
101-112	13.2.4.A	RA-39A		70880	B0021-3 / ET-04015			SR: N/A CR: N/A
101-112	13.2.4.B	LDA-241BX-1		70880	BX002-6 / ET-04118			SR: N/A CR: N/A
101-112	13.2.4.B	LDA-241BX-2		70880	BX002-D / ET-04073			SR: N/A CR: N/A
104	13.2.4.B	LDE-241BX-104		70880	BX002-1 / ET-03919			SR: N/A CR: N/A
104	13.2.4.B	LDK-241BX-104-1		70880	BX002-2 / ET-02802			SR: N/A CR: N/A
104	13.2.4.B	LDK-241BX-104-2		70880	BX002-A / ET-02677			SR: N/A CR: N/A
104	13.2.4.B	MS-241BX-104-1		70880	BX002-3 / ET-03502			SR: N/A CR: N/A
104	13.2.4.B	MS-241BX-104-2		70880	BX002-B / ET-03513			SR: N/A CR: N/A
104	13.2.4.B	MS-241BX-104-3		70880	BX002-4 / ET-03440			SR: N/A CR: N/A
104	13.2.4.B	MSA-241BX-104-1		70880	BX022-1 / ET-04044			SR: N/A CR: N/A
107	13.2.4.B	LDE-241BX-107		70880	BX029-1 / ET-01303			SR: N/A CR: N/A
107	13.2.4.B	LDK-241BX-107-1		70880	BX029-2 / ET-03166			SR: N/A CR: N/A
107	13.2.4.B	LDK-241BX-107-2		70880	BX029-A / ET-03172			SR: N/A CR: N/A
107	13.2.4.B	MS-241BX-107-1		70880	BX029-3 / ET-03537			SR: N/A CR: N/A
107	13.2.4.B	MS-241BX-107-2		70880	BX029-B / ET-03506			SR: N/A CR: N/A
107	13.2.4.B	MS-241BX-107-3		70880	BX029-4 / ET-03547			SR: N/A CR: N/A
107	13.2.4.B	MSA-241BX-107-1		70880	BX041-1 / ET-04087			SR: N/A CR: N/A
109	13.2.4.B	LDE-241BX-109		70880	BX044-1 / ET-01307			SR: N/A CR: N/A
109	13.2.4.B	LDK-241BX-109-1		70880	BX044-2 / ET-03168			SR: N/A CR: N/A
109	13.2.4.B	LDK-241BX-109-2		70880	BX044-A / ET-03157			SR: N/A CR: N/A
109	13.2.4.B	MS-241BX-109-1		70880	BX044-3 / ET-03437			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4N of 5N

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
109	13.2.4.B	MS-241BX-109-2		70880	BX044-B / ET-03517			SR: N/A CR: N/A
109	13.2.4.B	MS-241BX-109-3		70880	BX044-4 / ET-03499			SR: N/A CR: N/A
109	13.2.4.B	MSA-241BX-109-1		70880	BX056-1 / ET-01681			SR: N/A CR: N/A
110	13.2.4.B	LDE-241BX-110		70880	BX059-1 / ET-01304			SR: N/A CR: N/A
110	13.2.4.B	LDK-241BX-110-1		70880	BX059-2 / ET-03151			SR: N/A CR: N/A
110	13.2.4.B	LDK-241BX-110-2		70880	BX059-A / ET-03160			SR: N/A CR: N/A
110	13.2.4.B	MS-241BX-110-1		70880	BX059-3 / ET-03564			SR: N/A CR: N/A
110	13.2.4.B	MS-241BX-110-2		70880	BX059-B / ET-03442			SR: N/A CR: N/A
110	13.2.4.B	MS-241BX-110-3		70880	BX059-4 / ET-03558			SR: N/A CR: N/A
110	13.2.4.B	MSA-241BX-110		70880	BX071-1 / ET-03999			SR: N/A CR: N/A
111	13.2.4.B	LDE-241BX-111		70880	BX074-1 / ET-01305			SR: N/A CR: N/A
111	13.2.4.B	LDK-241BX-111-1		70880	BX074-2 / ET-03175			SR: N/A CR: N/A
111	13.2.4.B	LDK-241BX-111-2		70880	BX074-A / ET-03164			SR: N/A CR: N/A
111	13.2.4.B	MS-241BX-111-1		70880	BX074-3 / ET-03568			SR: N/A CR: N/A
111	13.2.4.B	MS-241BX-111-2		70880	BX074-B / ET-03515			SR: N/A CR: N/A
111	13.2.4.B	MS-241BX-111-3		70880	BX074-4 / ET-03556			SR: N/A CR: N/A
111	13.2.4.B	MSA-241BX-111		70880	BX086-1 / ET-04100			SR: N/A CR: N/A
112	13.2.4.B	LDE-241BX-112		70880	BX089-1 / ET-01306			SR: N/A CR: N/A
112	13.2.4.B	LDK-241BX-112-1		70880	BX089-2 / ET-03156			SR: N/A CR: N/A
112	13.2.4.B	LDK-241BX-112-2		70880	BX089-A / ET-03167			SR: N/A CR: N/A
112	13.2.4.B	MS-241BX-112-1		70880	BX089-3 / ET-03505			SR: N/A CR: N/A
112	13.2.4.B	MS-241BX-112-2		70880	BX089-B / ET-03563			SR: N/A CR: N/A
112	13.2.4.B	MS-241BX-112-3		70880	BX089-4 / ET-03438			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5N of 5N

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
112	13.2.4.B	MSA-241BX-112		70880	BX101-1 /			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10 of 70

241-BY

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	13.2.1.B	LIQUID OBSRV WELL R-9A		73251			185"	SR: N/A CR: N/A
101	13.2.1.B	MANUAL TAPE R-10C		73251			185"	SR: N/A CR: N/A
101	13.2.1.E	TEMP. PROBE R-1	11.4.2.1	73251			300°F	SR: N/A CR: N/A
101	13.2.1.E	THERMOCOUPLE TREE R-5	11.4.2.1	73251			300°F	SR: N/A CR: N/A
101	13.2.4.A	LDE-241BY-101		70880	BY002-1 / ET-03899			SR: N/A CR: N/A
101	13.2.4.A	LDK-241BY-101-1		70880	BY002-2 / ET-02829			SR: N/A CR: N/A
101	13.2.4.A	LDK-241BY-101-2		70880	BY002-A / ET-02867			SR: N/A CR: N/A
101	13.2.4.A	MS-241BY-101-1		70880	BY002-3 / ET-03522			SR: N/A CR: N/A
101	13.2.4.A	MS-241BY-101-2		70880	BY002-B / ET-03467			SR: N/A CR: N/A
101	13.2.4.A	MS-241BY-101-3		70880	BY002-4 / ET-03530			SR: N/A CR: N/A
101	13.2.4.A	MSA-241BY-101-1		70880	BY021-1 / ET-03990			SR: N/A CR: N/A
102	13.2.1.B	LIQUID LEVEL REEL R-5		73244			185"	SR: N/A CR: N/A
102	13.2.4.A	LDE-241BY-102		70880	BY029-1 / ET-01219			SR: N/A CR: N/A
102	13.2.4.A	LDK-241BY-102-1		70880	BY029-2 / ET-00463			SR: N/A CR: N/A
102	13.2.4.A	LDK-241BY-102-2		70880	BY029-A / ET-00464			SR: N/A CR: N/A
102	13.2.4.A	MS-241BY-102-1		70880	BY029-3 / ET-03572			SR: N/A CR: N/A
102	13.2.4.A	MS-241BY-102-2		70880				SR: N/A CR: N/A
102	13.2.4.A	MS-241BY-102-3		70880	BY029-4 / ET-03541			SR: N/A CR: N/A
102	13.2.4.A	MSA-241BY-102-1		70880	BY041-1 / ET-04085			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 20 of 70

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
103	13.2.1.B	LIQUID LEVEL REEL R-5		73246			185"	SR: N/A CR: N/A
103	13.2.1.B	LIQUID OBSRV WELL R-10A		73246			185"	SR: N/A CR: N/A
103	13.2.1.E	TEMPERATURE PROBE R-1	11.4.2.1	73246			300°F	SR: N/A CR: N/A
103	13.2.4.A	LDE-241BY-103		70880	BY044-1 / ET-03757			SR: N/A CR: N/A
103	13.2.4.A	LDK-241BY-103-1		70880	BY044-2 / ET-03149			SR: N/A CR: N/A
103	13.2.4.A	LDK-241BY-103-2		70880	BY044-A / ET-03148			SR: N/A CR: N/A
103	13.2.4.A	MS-241BY-103-1		70880	BY044-3 / ET-03455			SR: N/A CR: N/A
103	13.2.4.A	MS-241BY-103-2		70880	BY044-B / ET-03491			SR: N/A CR: N/A
103	13.2.4.A	MS-241BY-103-3		70880	BY044-4 / ET-03481			SR: N/A CR: N/A
103	13.2.4.A	MSA-241BY-103-1		70880	BY056-1 / ET-03988			SR: N/A CR: N/A
104	13.2.1.B	LIQUID LEVEL REEL R-5		73252			185"	SR: N/A CR: N/A
104	13.2.1.B	LIQUID OBSRV WELL R-10C		73252			185"	SR: N/A CR: N/A
104	13.2.1.E	T-COUPLE TREE R-1	11.4.2.1	73252			300°F	SR: N/A CR: N/A
104	13.2.1.E	T-COUPLE TREE R-10B	11.4.2.1	73252			300°F	SR: N/A CR: N/A
104	13.2.4.A	LDE-241BY-104		70880	BY059-1 / ET-03900			SR: N/A CR: N/A
104	13.2.4.A	LDK-241BY-104-1		70880	BY059-2 / ET-02797			SR: N/A CR: N/A
104	13.2.4.A	LDK-241BY-104-2		70880	BY059-A / ET-02945			SR: N/A CR: N/A
104	13.2.4.A	MS-241BY-104-1		70880	BY059-3 / ET-03543			SR: N/A CR: N/A
104	13.2.4.A	MS-241BY-104-2		70880	BY059-B / ET-03470			SR: N/A CR: N/A
104	13.2.4.A	MS-241BY-104-3		70880	BY059-4 / ET-03492			SR: N/A CR: N/A
104	13.2.4.A	MSA-241BY-104-1		70880	BY071-1 / ET-03992			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 30 of 70

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	13.2.1.B	LIQUID LEVEL REEL R-5		73247			185"	SR: N/A CR: N/A
105	13.2.1.B	LIQUID OBSRV WELL R-10A		73247			185"	SR: N/A CR: N/A
105	13.2.1.E	T-COUPLE TREE R-1	11.4.2.1	73247			300°F	SR: N/A CR: N/A
105	13.2.1.E	TEMP. PROBE R-10C	11.4.2.1	SDWMTI553			300°F	SR: N/A CR: N/A
105	13.2.4.A	LDE-241BY-105		70880	BY074-1 / ET-01466			SR: N/A CR: N/A
105	13.2.4.A	LDK-241BY-105-1		70880	BY074-2 / ET-00469			SR: N/A CR: N/A
105	13.2.4.A	LDK-241BY-105-2		70880	BY074-A / ET-00467			SR: N/A CR: N/A
105	13.2.4.A	MS-241BY-105-1		70880	BY074-3 / ET-03528			SR: N/A CR: N/A
105	13.2.4.A	MS-241BY-105-2		70880	BY074-B / ET-03571			SR: N/A CR: N/A
105	13.2.4.A	MS-241BY-105-3		70880	BY074-4 / ET-03536			SR: N/A CR: N/A
105	13.2.4.A	MSA-241BY-105-1		70880	BY086-1 / ET-04022			SR: N/A CR: N/A
106	13.2.1.B	LIQUID LEVEL REEL R-5		73248			185"	SR: N/A CR: N/A
106	13.2.1.B	LIQUID OBSRV WELL R-10B		73248			185"	SR: N/A CR: N/A
106	13.2.1.E	T-COUPLE TREE R-1	11.4.2.1	73248			300°F	SR: N/A CR: N/A
106	13.2.4.A	LDE-241BY-106		70880	BY089-1 / ET-01467			SR: N/A CR: N/A
106	13.2.4.A	LDK-241BY-106-1		70880	BY089-2 / ET-00470			SR: N/A CR: N/A
106	13.2.4.A	LDK-241BY-106-2		70880	BY089-A / ET-00468			SR: N/A CR: N/A
106	13.2.4.A	MS-241BY-106-1		70880	BY089-3 / ET-03476			SR: N/A CR: N/A
106	13.2.4.A	MS-241BY-106-2		70880	BY089-B / ET-03488			SR: N/A CR: N/A
106	13.2.4.A	MS-241BY-106-3		70880	BY089-4 / ET-03461			SR: N/A CR: N/A
106	13.2.4.A	MSA-241BY-106-1		70880	BY101-1 / ET-04024			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 40 of 70

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
107	13.2.1.B	LIQUID LEVEL REEL R-4		73249			185"	SR: N/A CR: N/A
107	13.2.1.B	LIQUID OBSERV WELL R-7		73249			185"	SR: N/A CR: N/A
107	13.2.1.E	TEMPERATURE PROBE R-1	11.4.2.1	73249			300°F	SR: N/A CR: N/A
108	13.2.1.B	LIQUID LEVEL REEL R-4		73250			185"	SR: N/A CR: N/A
108	13.2.1.E	TEMPERATURE PROBE R-8	11.4.2.1	73250			300°F	SR: N/A CR: N/A
108	13.2.4.A	LDE-241BY-108		70880	BY104-1 / ET-03754			SR: N/A CR: N/A
108	13.2.4.A	LDK-241BY-108-1		70880	BY104-2 / ET-03050			SR: N/A CR: N/A
108	13.2.4.A	LDK-241BY-108-2		70880	BY104-A / ET-02913			SR: N/A CR: N/A
108	13.2.4.A	MS-241BY-108-1		70880	BY104-3 / ET-03451			SR: N/A CR: N/A
108	13.2.4.A	MS-241BY-108-2		70880	BY104-B / ET-03539			SR: N/A CR: N/A
108	13.2.4.A	MS-241BY-108-3		70880	BY104-4 / ET-03468			SR: N/A CR: N/A
108	13.2.4.A	MSA-241BY-108-1		70880	BY116-1 / ET-04079			SR: N/A CR: N/A
109	13.2.1.B	LIT-109-BY		73253	BY022-1 / ET-01344		185"	SR: N/A CR: N/A
109	13.2.1.B	LIQUID OBSERV WELL R-12B		73253			185"	SR: N/A CR: N/A
109	13.2.4.A	LDE-241BY-109		70880	BY119-1 / ET-01465			SR: N/A CR: N/A
109	13.2.4.A	LDK-241BY-109-1		70880	BY119-2 / ET-00465			SR: N/A CR: N/A
109	13.2.4.A	LDK-241BY-109-2		70880	BY119-A / ET-00466			SR: N/A CR: N/A
109	13.2.4.A	MS-241BY-109-1		70880	BY119-3 / ET-03441			SR: N/A CR: N/A
109	13.2.4.A	MS-241BY-109-2		70880				SR: N/A CR: N/A
109	13.2.4.A	MS-241BY-109-3		70880	BY119-4 / ET-03482			SR: N/A CR: N/A
109	13.2.4.A	MSA-241BY-109-1		70880	BY131-1 / ET-03984			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 50 of 70

[illegible]

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 60 of 70

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
111	13.2.1.B	LIQUID OBSRV. WELL R-1		73255			185"	SR: N/A CR: N/A
111	13.2.1.B	LIQUID LEVEL REEL R-15		73255			185"	SR: N/A CR: N/A
111	13.2.1.E	TEMPERATURE PROBE R-14	11.4.2.1	SDRETI053			300°F	SR: N/A CR: N/A
111	13.2.4.A	LDE-241BY-111		70880	BY149-1 / ET-03755			SR: N/A CR: N/A
111	13.2.4.A	LDK-241BY-111-1		70880	BY149-2 / ET-02916			SR: N/A CR: N/A
111	13.2.4.A	LDK-241BY-111-2		70880	BY149-A / ET-02887			SR: N/A CR: N/A
111	13.2.4.A	MS-241BY-111-1		70880	BY149-3 / ET-03544			SR: N/A CR: N/A
111	13.2.4.A	MS-241BY-111-2		70880	BY149-B / ET-03429			SR: N/A CR: N/A
111	13.2.4.A	MS-241BY-111-3		70880	BY149-4 / ET-03457			SR: N/A CR: N/A
111	13.2.4.A	MSA-241BY-111-1		70880	BY161-1 / ET-04057			SR: N/A CR: N/A
112	13.2.1.B	LIQUID OBSRV. WELL R-15		73256			185"	SR: N/A CR: N/A
112	13.2.1.B	LIQUID LEVEL REEL R-19		73256			185"	SR: N/A CR: N/A
112	13.2.1.E	T-COUPLE TREE R-5	11.4.2.1	SDRETI053			300°F	SR: N/A CR: N/A
112	13.2.4.A	LDE-241BY-112		70880	BY164-1 / ET-03753			SR: N/A CR: N/A
112	13.2.4.A	LDK-241BY-112-1		70880	BY164-2 / ET-02930			SR: N/A CR: N/A
112	13.2.4.A	LDK-241BY-112-2		70880	BY164-A / ET-02885			SR: N/A CR: N/A
112	13.2.4.A	MS-241BY-112-1		70880	BY164-3 / ET-03557			SR: N/A CR: N/A
112	13.2.4.A	MS-241BY-112-2		70880	BY164-B / ET-03575			SR: N/A CR: N/A
112	13.2.4.A	MS-241BY-112-3		70880	BY164-4 / ET-03521			SR: N/A CR: N/A
112	13.2.4.A	MSA-241BY-112-1		70880	BY176-1 / ET-04060			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 70 of 70

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101-112	13.2.4.A	LDA-241BY-1		70880	BY002-5 / ET-04093			SR: N/A CR: N/A
101-112	13.2.4.A	LDA-241BY-2		70880	BY002-C / ET-04091			SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1P of 4P

241-C

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
101	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			185"	SR: N/A CR: N/A
101	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
101	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
101	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
102	13.2.1.B	LIT-102-C		36382	C0012-1 / ET-01378		185"	SR: N/A CR: N/A
102	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
102	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
102	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
103	13.2.1.B	LIT-103-C		36382	C0013-1 / ET-01346		185"	SR: N/A CR: N/A
103	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	90342			300°F LCO=350°F	SR: 25 DAYS CR: N/A
103	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
103	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
104	13.2.1.B	LIT-104-C		36382	C0014-1 / ET-01364		185"	SR: N/A CR: N/A
104	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
104	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
104	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2P of 4P

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
105	13.2.1.B	LIT-105-C		36382	C0015-1 / ET-01348		185"	SR: N/A CR: N/A
105	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	90342			300°F LCO=350°F	SR: 25 DAYS CR: N/A
105	13.2.1.F	PI-EXCH-3	11.4.1.1	73450	C0010-1 / ET-01607		-9 IN.WG.	SR: 24 HRS. CR: N/A
105	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
106	13.2.1.B	LIT-106-C		36382	C0016-1 / ET-01368		185"	SR: N/A CR: N/A
106	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	90342			300°F LCO=350°F	SR: 25 DAYS CR: N/A
106	13.2.1.F	PI-EXCH-4	11.4.1.1	73450	C0011-1 / ET-02361		-9 IN.WG.	SR: 24 HR. CR: N/A
106	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
107	13.2.1.B	LIT-107-C		36382	C0017-1 / ET-02616		185"	SR: N/A CR: N/A
107	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	90342			300°F LCO=350°F	SR: 25 DAYS CR: N/A
107	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
107	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
108	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			185"	SR: N/A CR: N/A
108	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	83312			300°F LCO=350°F	SR: 25 DAYS CR: N/A
108	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
108	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3P of 4P

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
109	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			185"	SR: N/A CR: N/A
109	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	99138			300°F LCO=350°F	SR: 25 DAYS CR: N/A
109	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
109	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
110	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			185"	SR: N/A CR: N/A
110	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
110	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
110	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
111	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			185"	SR: N/A CR: N/A
111	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
111	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
111	13.2.4.B	DRYWELL LEAK DETECTION						SR: N/A CR: N/A
112	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			185"	SR: N/A CR: N/A
112	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	99138			300°F LCO=350°F	SR: 25 DAYS CR: N/A
112	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
112	13.2.4.B	DRYWELL LEAK DETECTION	11.4.3					SR: N/A CR: N/A
201	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			280"	SR: N/A CR: N/A
201	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
201	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A

SINGLE-SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4P of 4P

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
202	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			280"	SR: N/A CR: N/A
202	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
202	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
203	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			280"	SR: N/A CR: N/A
203	13.2.1.E	THERMOCOUPLE TREE	11.4.1.2	34304			300°F LCO=350°F	SR: 25 DAYS CR: N/A
203	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A
204	13.2.1.B	MAN. TAPE-LIQUID LVL		32671			280"	SR: N/A CR: N/A
204	13.2.1.F	BRTHR FLTR OIL SEAL LP	11.4.1.1	90718		± 7 IN.WG.		SR: 10 DAYS CR: N/A

CATCH TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1Q of 1Q

244-A

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
244-A	15.7.B.1.a	WFT-TK		38217	4A008-1 / ET-02568			SR: N/A CR: N/A
244-A	15.7.B.1.a	WFR-TK		38217				SR: N/A CR: N/A
244-A	7.2.10	LDE-PP	11.7	38217	4A017-1 / ET-01234			SR: N/A CR: START-UP
244-A	7.2.10	LDAS-PP	11.7	38217	4A017-2 / ET-00462			SR: N/A CR: N/A
244-A	7.2.10	LDA-PP	11.7	38217				SR: N/A CR: N/A
244-A	31.2.3.1	WFT-A		38217	4A005-1 / ET-02470			SR: N/A CR: N/A
244-A	31.2.3.1	WFAS-A		38217				SR: N/A CR: N/A
244-A	31.2.3.1	WFI-A		38217				SR: N/A CR: N/A
244-A	31.2.3.1	WFAH-A		38217				SR: CONT CR: N/A
244-A	31.2.3.1	K-WFAS-A		38217				SR: N/A CR: N/A
244-A	31.3.3.2	WFT-A		38217	4A005-1 / ET-02470			SR: N/A CR: N/A
244-A	31.3.3.2	WFAS-A		38217				SR: N/A CR: N/A
244-A	31.3.3.2	WFI-A		38217			>1.0"	SR: 36hrs CR: N/A
244-A	31.3.3.2	WFAH-A		38217				SR: CONT CR: N/A
244-A	31.3.3.2	K-WFAS-A		38217				SR: N/A CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1R of 10R

244-AR

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001	14.2.1.B	WFT-001-1		79949	AR049-1 / ET-00958			SR: N/A CR: N/A
001	14.2.1.B	WFR-001-1		79949	AR049-2 / ET-00772		40990 GAL.	SR: DAILY CR: N/A
001	14.2.1.B	WFAS-001-1		79949	AR049-3 / ET-01000			SR: N/A CR: N/A
001	14.2.1.B	WFA-001-1		79949	AR049-5 / ET-01691			SR: N/A CR: N/A
001	14.2.1.B	SGT-001-1		79949	AR050-2 / ET-01127			SR: N/A CR: N/A
001	14.2.1.B	SGR-001-1		79949	AR050-1 / ET-00795		40990 GAL.	SR: DAILY CR: N/A
001	14.2.1.C	PT-001		79949	AR186-1 / ET-03420			SR: N/A CR: N/A
001	14.2.1.C	PR-001		79949	AR184-1 / ET-03230		0" to -7" H2O	SR: DAILY CR: N/A
001	14.2.1.D	TE-001		79949	AR052-1 / ET-00177			SR: N/A CR: N/A
001	14.2.1.D	CVT-001		79949	AR052-3 / ET-03592			SR: N/A CR: N/A
001	14.2.1.D	TAS-001		79949	AR052-4 / ET-03601	80° C		SR: N/A CR: N/A
001	14.2.1.D	TA-001		79949	AR052-5 / ET-04106			SR: N/A CR: N/A
001	14.2.1.D	TR-001		79949	AR052-2 / ET-03234		≤ 90° C	SR: DAILY CR: N/A
002	14.2.1.B	WFT-002-1		79949	AR042-2 / ET-00953			SR: N/A CR: N/A
002	14.2.1.B	WFR-002-1		79949	AR042-1 / ET-00777		41266 GAL.	SR: DAILY CR: N/A
002	14.2.1.B	WFAS-002-1		79949	AR042-3 / ET-01101			SR: N/A CR: N/A
002	14.2.1.B	WFA-002-1		79949	AR042-5 / ET-04062			SR: N/A CR: N/A
002	14.2.1.B	SGT-002-1		79949	AR043-1 / ET-01126			SR: N/A CR: N/A
002	14.2.1.B	SGR-002-1		79949	AR043-2 / ET-00778		41266 GAL.	SR: DAILY CR: N/A
002	14.2.1.B	WFT-002-50		79949	AR251-1 / ET-03415			SR: N/A CR: N/A
002	14.2.1.B	WFR-002-50		79949	AR251-2 / ET-03238		41266 GAL.	SR: DAILY CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
002	14.2.1.B	SGT-002-50		79949	/			SR: N/A CR: N/A
002	14.2.1.B	SGR-002-50		79949	/		41266 GAL.	SR: DAILY CR: N/A
002	14.2.1.C	PT-002		79949	AR185-1 / ET-00944			SR: N/A CR: N/A
002	14.2.1.C	PR-002		79949	AR183-1 / ET-00785		0" to -7" H2O	SR: DAILY CR: N/A
002	14.2.1.D	TE-002		79949	AR044-1 / ET-00390			SR: N/A CR: N/A
002	14.2.1.D	CVT-002-2		79949	AR044-3 / ET-01140			SR: N/A CR: N/A
002	14.2.1.D	TAS-002		79949	AR044-4 / ET-01180	80° C		SR: N/A CR: N/A
002	14.2.1.D	TA-002		79949	AR044-5 / ET-04011			SR: N/A CR: N/A
002	14.2.1.D	TR-002		79949	AR044-2 / ET-00775		≤ 90° C	SR: DAILY CR: N/A
003	14.2.1.B	WFT-003-1		79949	AR033-2 / ET-00967			SR: N/A CR: N/A
003	14.2.1.B	WFR-003-1		79949	AR033-1 / ET-00791		4553 GAL.	SR: DAILY CR: N/A
003	14.2.1.B	WFAS-003-1		79949	AR033-3 / ET-01098			SR: N/A CR: N/A
003	14.2.1.B	WFA-003-1		79949	AR033-5 / ET-04002			SR: N/A CR: N/A
003	14.2.1.B	SGT-003-1		79949	AR034-2 / ET-01124			SR: N/A CR: N/A
003	14.2.1.B	SGR-003-1		79949	AR034-1 / ET-00790		4553 GAL.	SR: DAILY CR: N/A
003	14.2.1.C	PT-003		79949	AR182-1 / ET-00933			SR: N/A CR: N/A
003	14.2.1.C	PR-003		79949	AR181-1 / ET-00794		0" to -7" H2O	SR: DAILY CR: N/A
003	14.2.1.D	TE-003		79949	AR035-1 / ET-00087			SR: N/A CR: N/A
003	14.2.1.D	CVT-003		79949	AR035-3 / ET-01139			SR: N/A CR: N/A
003	14.2.1.D	TAS-003		79949	AR035-4 / ET-01181	80° C		SR: N/A CR: N/A
003	14.2.1.D	TA-003		79949	AR035-5 / ET-04116			SR: N/A CR: N/A
003	14.2.1.D	TR-003		79949	AR035-2 / ET-00771		≤ 90° C	SR: DAILY CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
004	14.2.1.B	WFT-004-1		79949	AR025-2 / ET-00985			SR: N/A CR: N/A
004	14.2.1.B	WFR-004-1		79949	AR025-1 / ET-00798		4472 GAL.	SR: DAILY CR: N/A
004	14.2.1.B	WFAS-004-1		79949	AR025-3 / ET-01080			SR: N/A CR: N/A
004	14.2.1.B	WFA-004-1		79949	AR025-5 / ET-00120			SR: N/A CR: N/A
004	14.2.1.B	SGT-004-1		79949	AR026-2 / ET-01125			SR: N/A CR: N/A
004	14.2.1.B	SGR-004-1		79949	AR026-1 / ET-00797		4472 GAL.	SR: DAILY CR: N/A
004	14.2.1.C	PT-004		79949	AR031-1 / ET-00936			SR: N/A CR: N/A
004	14.2.1.C	PR-004		79949	AR180-1 / ET-00776		0" to -7" H2O	SR: DAILY CR: N/A
004	14.2.1.D	TE-004		79949	AR027-1 / ET-00163			SR: N/A CR: N/A
004	14.2.1.D	CVT-004		79949	AR027-3 / ET-01132			SR: N/A CR: N/A
004	14.2.1.D	TAS-004		79949	AR027-4 / ET-01026	80° C		SR: N/A CR: N/A
004	14.2.1.D	TA-004		79949	AR027-5 / ET-00343			SR: N/A CR: N/A
004	14.2.1.D	TR-004		79949	AR027-2 / ET-00774		≤ 90° C	SR: DAILY CR: N/A
001-004	14.2.1.C	PT-V1		63940	AR085-3 / ET-03422			SR: N/A CR: N/A
001-004	14.2.1.C	PIC-V1		63940	AR085-2 / ET-01651		≥ -6" H2O	SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPT-007-1		63940	AR076-4 / ET-03607			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPR-007-1		63940	AR076-3 / ET-03240		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.1	DPAS-007-3		63940	AR074-3 / ET-01094	3.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPAS-007-7		63940	AR076-5 / ET-03580	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPA-007-1		63940	AR076-6 / ET-04000			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPI-1-1-2		94009	AR303-1 / ET-04352		≤ 5.9" WG	SR: DAILY CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.1.a.1	DPSH-1-1-2		94009	AR303-3 / ET-01044	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-1-1-2A		94009	AR303-5 / ET-01889			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPI-2-1-2		94009	AR295-1 / ET-04350		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.1	DPSH-2-1-2		94009	AR295-2 / ET-01081	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-2-1-2A		94009	AR295-5 / ET-01827			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPI-3-1-2		94009	AR296-1 / ET-04345		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.1	DPSH-3-1-2		94009	AR296-2 / ET-01034	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-3-1-2A		94009	AR296-5 / ET-02039			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPI-4-1-2		94009	AR298-1 / ET-04348		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.1	DPSH-4-1-2		94009	AR298-2 / ET-01068	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-4-1-2A		94009	AR298-5 / ET-01815			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPI-5-1-2		94009	AR300-1 / ET-04344		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.1	DPSH-5-1-2		94009	AR300-2 / ET-01037	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-5-1-2A		94009	AR300-5 / ET-01937			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	DPI-6-1-2		94009	AR292-1 / ET-04355		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.1	DPSH-6-1-2		94009	AR292-2 / ET-01092	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-6-1-2A		94009	AR292-5 / ET-01858			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	MS-5		94009	AR311-1 / ET-00452			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	K-2		94009	AR311-5 / ET-00047			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	KY-2		94009				SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PL-2		94009	AR311-7 / ET-01879			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.1	PA-1		94009	AR311-8 / ET-01998			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPT-007-2		63940	AR075-2 / ET-00963			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPR-007-2		63940	AR075-3 / ET-00787		≤ 4.0" WG	SR: DAILY CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.1.a.2	DPAS-007-2		63940	AR075-4 / ET-01027	3.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPAS-007-8		63940	AR075-5 / ET-01093	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPA-007-2		63940	AR075-6 / ET-01871			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPT-007-3		63940	AR074-1 / ET-00955			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPR-007-3		63940	AR074-2 / ET-00805		≤ 4.0" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.2	DPAS-007-1		63940	AR076-4 / ET-03607	3.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPAS-007-9		63940	AR074-4 / ET-01096	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPA-007-3		63940	AR074-5 / ET-01743			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPI-1-2-3		94009	AR297-1 / ET-04346		≤ 4.0" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.2	DPSH-1-2-3		94009	AR297-2 / ET-03490	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-1-2-3A		94009	AR297-5 / ET-01764			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPI-2-2-3		94009	AR294-1 / ET-04351		≤ 4.0" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.2	DPSH-2-2-3		94009	AR294-2 / ET-01003	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-2-2-3A		94009	AR294-5 / ET-01770			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPI-3-2-3		94009	AR302-1 / ET-04353		≤ 4.0" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.2	DPSH-3-2-3		94009	AR302-2 / ET-01005	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-3-2-3A		94009	AR302-5 / ET-01892			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPI-4-2-3		94009	AR299-1 / ET-04349		≤ 4.0" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.2	DPSH-4-2-3		94009	AR299-2 / ET-00993	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-4-2-3A		94009	AR299-5 / ET-01992			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPI-5-2-3		94009	AR301-1 / ET-04347		≤ 4.0" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.2	DPSH-5-2-3		94009	AR301-2 / ET-01075	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-5-2-3A		94009	AR301-5 / ET-02083			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	DPI-6-2-3		94009	AR293-1 / ET-04354		≤ 4.0" WG	SR: DAILY CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 6R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.1.a.2	DPSH-6-2-3		94009	AR293-2 / ET-01049	≤ 4.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-6-2-3A		94009	AR293-5 / ET-01697			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	MS-5		94009	AR311-1 / ET-00452			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	K-2		94009	AR311-5 / ET-00047			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	KY-2		94009				SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PL-2		94009	AR311-7 / ET-01879			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.2	PA-1		94009	AR311-8 / ET-01998			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPT-007-1		63940	AR076-4 / ET-03607			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPT-007-2		63940	AR075-2 / ET-00963			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPT-007-3		63940	AR074-1 / ET-00955			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPR-007-1		63940	AR076-3 / ET-03240		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPR-007-2		63940	AR075-3 / ET-00787		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPR-007-3		63940	AR074-2 / ET-00805		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPAS-007-1		63940	AR076-4 / ET-03607	3.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPAS-007-2		63940	AR075-4 / ET-01027	3.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPAS-007-3		63940	AR074-3 / ET-01094	3.0" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPAS-007-7		63940	AR076-5 / ET-03580	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPA-007-1		63940	AR076-6 / ET-04000			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPAS-007-8		63940	AR075-5 / ET-01093	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPA-007-2		63940	AR075-6 / ET-01871			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPAS-007-9		63940	AR074-4 / ET-01096	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPA-007-3		63940	AR074-5 / ET-01743			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-1-1-2		94009	AR303-1 / ET-04352		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-1-1-2		94009	AR303-2 / ET-01021	≤ 5.9" WG		SR: N/A CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 7R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.1.a.3	PL-1-1-2A		94009	AR303-5 / ET-01889			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-1-2-3		94009	AR297-1 / ET-04346		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-1-2-3		94009	AR297-2 / ET-03490	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-1-2-3A		94009	AR297-5 / ET-01764			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-2-1-2		94009	AR295-1 / ET-04350		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-2-1-2		94009	AR295-2 / ET-01081	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-2-1-2A		94009	AR295-5 / ET-01827			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-2-2-3		94009	AR294-1 / ET-04351		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-2-2-3		94009	AR294-2 / ET-01003	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-2-2-3A		94009	AR294-5 / ET-01770			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-3-1-2		94009	AR296-1 / ET-04345		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-3-1-2		94009	AR296-2 / ET-01034	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-3-1-2A		94009	AR296-5 / ET-02039			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-3-2-3		94009	AR302-1 / ET-04353		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-3-2-3		94009	AR302-2 / ET-01005	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-3-2-3A		94009	AR302-5 / ET-01892			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-4-1-2		94009	AR298-1 / ET-04348		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-4-1-2		94009	AR298-2 / ET-01068	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-4-1-2A		94009	AR298-5 / ET-01815			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-4-2-3		94009	AR299-1 / ET-04349		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-4-2-3		94009	AR299-2 / ET-00993	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-4-2-3A		94009	AR299-5 / ET-01992			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-5-1-2		94009	AR300-1 / ET-04344		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-5-1-2		94009	AR300-2 / ET-01037	≤ 5.9" WG		SR: N/A CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 8R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.1.a.3	PL-5-1-2A		94009	AR300-5 / ET-01937			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-5-2-3		94009	AR301-1 / ET-04347		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-5-2-3		94009	AR301-2 / ET-01075	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-5-2-3A		94009	AR301-5 / ET-02083			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-6-1-2		94009	AR292-1 / ET-04355		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-6-1-2		94009	AR292-2 / ET-01092	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-6-1-2A		94009	AR292-5 / ET-01858			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	DPI-6-2-3		94009	AR293-1 / ET-04354		≤ 5.9" WG	SR: DAILY CR: N/A
001-004	14.2.2.A.1.a.3	DPSH-6-2-3		94009	AR293-2 / ET-01049	≤ 5.9" WG		SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-6-2-3A		94009	AR293-5 / ET-01697			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	MS-5		94009	AR311-1 / ET-00452			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	K-2		94009	AR311-5 / ET-00047			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	KY-2		94009				SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PL-2		94009	AR311-7 / ET-01879			SR: N/A CR: N/A
001-004	14.2.2.A.1.a.3	PA-1		94009	AR311-8 / ET-01998			SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TE-006-2		63940				SR: N/A CR: N/A
001-004	14.2.2.A.1.b	CVT-006-2		63940	AR081-1 / ET-00531			SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TAS-006-1		63940	AR081-3 / ET-03599	110° C (230° F)		SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TA-006-1		63940	AR081-5 / ET-04063			SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TRC-006-2		63940	AR081-2 / ET-03244		≤ 110°C (230°F)	SR: DAILY CR: N/A
001-004	14.2.2.A.1.b	TT-1		94009	AR121-1 / ET-02868			SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TR-1-A		94009	AR307-2 / ET-03255			SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TSH-1-A		94009	AR307-4 / ET-03603	≤ 110°C (230°F)		SR: N/A CR: N/A
001-004	14.2.2.A.1.b	TR-1-B		94009	AR307-5 / ET-03427		≤ 110°C (230°F)	SR: DAILY CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 9R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.1.b	K-4		94009	AR309-5 / ET-00311			SR: N/A CR: N/A
001-004	14.2.2.A.1.b	XA-1		94009	AR309-8 / ET-01797			SR: N/A CR: N/A
001-004	14.2.2.A.2	CAM-VV-1		92484	YAR03-1 / ET-01582			SR: N/A CR: N/A
001-004	14.2.2.A.2	RR-VV-1		92484	AR234-1 / ET-02406			SR: N/A CR: N/A
001-004	14.2.2.A.2	XA-VV-2		92484				SR: N/A CR: N/A
001-004	14.2.2.A.2	RA-VV-1		92484				SR: N/A CR: N/A
001-004	14.2.2.A.2	RA-VV-2		92484				SR: N/A CR: N/A
001-004	14.2.2.A.2	FA-VV-1		92484				SR: N/A CR: N/A
001-004	14.2.2.A.2	FAS-VV-1		92484	AR246-1 / ET-02525			SR: N/A CR: N/A
001-004	14.2.2.A.2	PI-VV-1		92484	AR218-1 / ET-04415			SR: N/A CR: N/A
001-004	14.2.2.A.2	RECRD SAMPLE FLTR VV-1		92484				SR: N/A CR: N/A
001-004	14.2.2.A.2	FI-VV-2		92484	AR243-1 / ET-02569			SR: N/A CR: N/A
001-004	14.2.2.A.2	FQI-VV-1		92484	AR248-1 / ET-04317			SR: N/A CR: N/A
001-004	14.2.2.A.2	FAS-VV-2		92484	AR245-1 / ET-02521			SR: N/A CR: N/A
001-004	14.2.2.A.2	PI-VV-2		92484	AR219-1 / ET-04381			SR: N/A CR: N/A
001-004	14.2.2.A.2	FA-VV-2		92484				SR: N/A CR: N/A
001-004	14.2.2.A.2	XA-VV-1		92484				SR: N/A CR: N/A
001-004	14.2.2.A.3	RE-SM-1		99111	AR065-1 / ET-02777			SR: N/A CR: N/A
001-004	14.2.2.A.3	CRM-CWM-1		99125	AR238-2 / ET-04298			SR: N/A CR: N/A
001-004	14.2.2.A.3	FA-SM-1		99111	AR167-2 / ET-04046			SR: N/A CR: N/A
001-004	14.2.2.A.3	RA-SM-1		99111	AR065-S / ET-03994			SR: N/A CR: N/A
001-004	14.2.2.A.3	RR/FR-CWM-1		99111				SR: N/A CR: N/A
001-004	14.2.2.A.3	FIAS-SM-1		99111	AR167-1 / ET-03508			SR: N/A CR: N/A
001-004	14.2.2.A.3	AILS-SM-1		99111				SR: N/A CR: N/A

DOUBLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 10R of 10R

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
001-004	14.2.2.A.3	IL-SC-1		99111				SR: N/A CR: N/A
001-004	14.2.2.A.3	TI-E4-4-1		99111	AR169-1 / ET-04283			SR: N/A CR: N/A
001-004	14.2.2.A.3	TI-E4-13-1		99111	AR170-1 / ET-04286			SR: N/A CR: N/A
001-004	14.2.2.A.3	ALS-1		99111				SR: N/A CR: N/A
001-004	14.2.2.B	Project B-462-A						

DOUBLE CONTAINED RECEIVER TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1S of 5S

244-BX

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
244-BX	11.2.B.1	WFT-244-BX-1		73797	4B001-1 / ET-00919			SR: N/A CR: N/A
244-BX	11.2.B.1	WFR-244-BX-1		73797	4B001-2 / ET-02332		144"	SR: DAILY CR: N/A
244-BX	11.2.B.1	SGT-244-BX-1		73797	4B002-1 / ET-01154			SR: N/A CR: N/A
244-BX	11.2.B.1	SGR-244-BX-1		73797	4B002-2 / ET-00630		144"	SR: DAILY CR: N/A
244-BX	11.2.B.1	LY-244-BX-1		73797	4B013-1 / ET-02469			SR: N/A CR: N/A
244-BX	11.2.B.1	LAS-244-BX-1		73797	4B013-3 / ET-02330			SR: N/A CR: N/A
244-BX	11.2.B.1	LR-244-BX-1		73797	4B013-2 / ET-02331		144"	SR: DAILY CR: N/A
244-BX	11.2.B.1	LA-244-BX-1		73797	4B013-5 / ET-01955			SR: N/A CR: N/A
244-BX	11.2.B.1	LA-244-BX-1A		73797	4B013-4 / ET-01921			SR: N/A CR: N/A
244-BX	11.2.B.1	HLE-244-BX-2		73797	4B068-1 / ET-00118			SR: N/A CR: N/A
244-BX	11.2.B.1	HLS-244-BX-2		73797	4B068-2 / ET-01626			SR: N/A CR: N/A
244-BX	11.2.B.1	HLA-244-BX-2		73797	ON HOLD SEE --	ECN 194936--	NCR 051147	SR: N/A CR: N/A
244-BX	11.2.B.1	FI-1		73797	4B042-1 / ET-02575			SR: N/A CR: N/A
244-BX	11.2.B.1	FI-2		73797	4B043-1 / ET-02576			SR: N/A CR: N/A
244-BX	11.2.B.1	FI-3		73797	4B044-1 / ET-02577			SR: N/A CR: N/A
244-BX	11.2.B.1	FI-7		73797	4B048-1 / ET-05034			SR: N/A CR: N/A
244-BX	11.2.B.2	LLE-244-BX-1		73797	4B056-1 / ET-00322			SR: N/A CR: N/A
244-BX	11.2.B.2	LLI-244-BX-1		73797	4B056-2 / ET-01643		18"	SR: N/A CR: N/A
244-BX	11.2.B.2	FI-8		73797	4B049-1 / ET-02578			SR: N/A CR: N/A
244-BX	11.2.B.2	LDE-SP		73797	4B053-1 / ET-01321			SR: N/A CR: N/A
244-BX	11.2.B.2	LDK-SP-1		73797	4B053-2 / ET-00077		18"	SR: N/A CR: N/A

DOUBLE CONTAINED RECEIVER TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2S of 5S

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
244-BX	11.2.B.2	LDK-SP-2		73797	4B053-3 / ET-00092		18"	SR: N/A CR: N/A
244-BX	11.2.B.2	MS-SP		73797	4B053-4 / ET-04627			SR: N/A CR: N/A
244-BX	11.2.B.2	LDA-2		73797	4B058-2 / ET-01907			SR: N/A CR: N/A
244-BX	11.2.B.2	LDA-2A		73797	4B058-1 / ET-01906			SR: N/A CR: N/A
244-BX	11.2.B.2	LDA-3		73797	4B057-2 / ET-02060			SR: N/A CR: N/A
244-BX	11.2.B.2	LDA-3A		73797	4B057-1 / ET-01753			SR: N/A CR: N/A
244-BX	11.2.C	WFT-244-BX-1		73797	4B001-1 / ET-00919			SR: N/A CR: N/A
244-BX	11.2.C	WFR-244-BX-1		73797	4B001-2 / ET-02332		259" H2O	SR: N/A CR: N/A
244-BX	11.2.C	SGT-244-BX-1		73797	4B002-1 / ET-01154			SR: N/A CR: N/A
244-BX	11.2.C	SGR-244-BX-1		73797	4B002-2 / ET-00630		259" H2O	SR: N/A CR: N/A
244-BX	11.2.C	LY-244-BX-1		73797	4B013-1 / ET-02469			SR: N/A CR: N/A
244-BX	11.2.C	LAS-244-BX-1		73797	4B013-3 / ET-02330			SR: N/A CR: N/A
244-BX	11.2.C	LR-244-BX-1		73797	4B013-2 / ET-02331		259" H2O	SR: N/A CR: N/A
244-BX	11.2.C	LA-244-BX-1		73797	4B013-5 / ET-01955			SR: N/A CR: N/A
244-BX	11.2.C	LA-244-BX-1A		73797	4B013-4 / ET-01921			SR: N/A CR: N/A
244-BX	11.2.C	HLE-244-BX-2		73797	4B068-1 / ET-00118			SR: N/A CR: N/A
244-BX	11.2.C	HLS-244-BX-2		73797	4B068-2 / ET-01626			SR: N/A CR: N/A
244-BX	11.2.C	HLA-244-BX-2		73797				SR: N/A CR: N/A
244-BX	11.2.C	FI-1		73797	4B042-1 / ET-02575			SR: N/A CR: N/A
244-BX	11.2.C	FI-2		73797	4B043-1 / ET-02576			SR: N/A CR: N/A
244-BX	11.2.C	FI-3		73797	4B044-1 / ET-02577			SR: N/A CR: N/A
244-BX	11.2.C	FI-7		73797	4B048-1 / ET-05034			SR: N/A CR: N/A

DOUBLE CONTAINED RECEIVER TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 3S of 5S

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
244-BX	11.2.F	TR-244-BX-1		73797	4B003-3 / ET-00627		200° F	SR: N/A CR: N/A
244-BX	11.2.F	TT-244-BX-1		73797	4B003-2 / ET-00922			SR: N/A CR: N/A
244-BX	11.2.F	TE-244-BX-1		73797	4B003-1 / ET-00234			SR: N/A CR: N/A
244-BX	11.3.A.1	DPI-244-BX-1		73797	4B031-2 / ET-02419		≤ 4.0" WG	SR: N/A CR: N/A
244-BX	11.3.A.1	DPI-244-BX-2		73797	4B031-1 / ET-00844		≤ 4.0" WG	SR: N/A CR: N/A
244-BX	11.3.A.2	DPIC-6		73797	4B034-4 / ET-00822		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.2	DPIC-7		73797	4B034-5 / ET-00823		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.2	DPIC-8		73797	4B034-6 / ET-00820		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.2	DPA-1		73797	4B034-8 / ET-01708			SR: N/A CR: N/A
244-BX	11.3.A.2	DPA-1A		73797	4B034-7 / ET-02027			SR: N/A CR: N/A
244-BX	11.3.A.3	DPIC-3		73797	4B034-1 / ET-00836		≤ 4.0" WG	SR: N/A CR: N/A
244-BX	11.3.A.3	DPIC-4		73797	4B034-2 / ET-00835		≤ 4.0" WG	SR: N/A CR: N/A
244-BX	11.3.A.3	DPIC-5		73797	4B034-3 / ET-00824		≤ 4.0" WG	SR: N/A CR: N/A
244-BX	11.3.A.4	DPIC-3		73797	4B034-1 / ET-00836		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.4	DPIC-4		73797	4B034-2 / ET-00835		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.4	DPIC-5		73797	4B034-3 / ET-00824		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.4	DPIC-6		73797	4B034-4 / ET-00822		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.4	DPIC-7		73797	4B034-5 / ET-00823		≤ 5.9" WG	SR: N/A CR: N/A
244-BX	11.3.A.4	DPIC-8		73797	4B034-6 / ET-00820		≤ 5.9" WG	SR: N/A CR: N/A

DOUBLE CONTAINED RECEIVER TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 4S of 5S

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
244-BX	11.3.A.4	DPA-1		73797	4B034-8 / ET-01708			SR: N/A CR: N/A
244-BX	11.3.A.4	DPA-1A		73797	4B034-7 / ET-02027			SR: N/A CR: N/A
244-BX	11.3.C	RM-244-BX-2		73797	YBX01-1 / ET-01564			SR: N/A CR: N/A
244-BX	11.3.C	CVT-244-BX-4		73797	4B016-1 / ET-00925			SR: N/A CR: N/A
244-BX	11.3.C	SS-244-BX-2		73797	4B070-1 / ET-00442			SR: N/A CR: N/A
244-BX	11.3.C	RA-244-BX-2		73797	4B073-2 / ET-01745			SR: N/A CR: N/A
244-BX	11.3.C	RA-244-BX-2A		73797	4B073-1 / ET-02037			SR: N/A CR: N/A
244-BX	11.3.C	RA-244-BX-4		73797	4B083-2 / ET-01954			SR: N/A CR: N/A
244-BX	11.3.C	RA-244-BX-4A		73797	4B083-1 / ET-01857			SR: N/A CR: N/A
244-BX	11.3.C	RR-244-BX-2		73797	4B016-2 / ET-00628			SR: N/A CR: N/A
244-BX	11.3.C	RECORD FILTER F-4		73797				SR: N/A CR: N/A
244-BX	11.3.D.2	RM-244-BX-1		73797	YBX02-1 / ET-01580			SR: N/A CR: N/A
244-BX	11.3.D.2	SS-244-BX-1		73797	4B071-1 / ET-00412			SR: N/A CR: N/A
244-BX	11.3.D.2	CVT-244-BX-3		73797	4B017-1 / ET-00924			SR: N/A CR: N/A
244-BX	11.3.D.2	RR-244-BX-1		73797	4B017-2 / ET-00629			SR: N/A CR: N/A
244-BX	11.3.D.2	RM-244-BX-2		73797	YBX01-1 / ET-01564			SR: N/A CR: N/A
244-BX	11.3.D.2	SS-244-BX-2		73797	4B070-1 / ET-00442			SR: N/A CR: N/A
244-BX	11.3.D.2	CVT-244-BX-4		73797	4B016-1 / ET-00925			SR: N/A CR: N/A
244-BX	11.3.D.2	RR-244-BX-2		73797	4B016-2 / ET-00628			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-1		73797	4B072-2 / ET-02036			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-1A		73797	4B072-1 / ET-02018			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-2		73797	4B073-2 / ET-01745			SR: N/A CR: N/A

DOUBLE CONTAINED RECEIVER TANKS OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 5S of 5S

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
244-BX	11.3.D.2	RA-244-BX-2A		73797	4B073-1 / ET-02037			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-3		73797	4B071-2 / ET-01834			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-3A		73797	4B071-3 / ET-01856			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-4		73797	4B083-2 / ET-01954			SR: N/A CR: N/A
244-BX	11.3.D.2	RA-244-BX-4A		73797	4B083-1 / ET-01857			SR: N/A CR: N/A
244-BX	11.3.D.2	RECORD FILTER F-4		73797				SR: WEEKLY CR: N/A
244-BX	11.3.E	TR-244-BX-1		73797	4B003-3 / ET-00627		≥ 140°F	SR: N/A CR: N/A
244-BX	11.3.E	TT-244-BX-1		73797	4B003-2 / ET-00922			SR: N/A CR: N/A
244-BX	11.3.E	TE-244-BX-1		73797	4B003-1 / ET-00234			SR: N/A CR: N/A

SINGLE SHELL TANKS OSD MATRIX

WHC-SD-WM-EE-003
REV. 0
PAGE 1T of 1T

244-CR

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
CR-003	11.2.B.1	CR-003 TANK MAN. TAPE		33944			168"	SR: DAILY CR: N/A
CR-003	11.2.B.2	CR-003 SUMP LEVEL		33944			12"	SR: N/A CR: N/A
CR-003	11.2.C.1	CR-003 TANK LIQ. LVL.		33944			302 IN. WG.	SR: N/A CR: N/A
CR-003	11.2.E.1	PI-003-1		33944	CR040-1 / ET-02724		MAX 5", MIN -6"	SR: N/A CR: N/A
CR-003	11.2.F.1	CR-003 TANK TEMPRATURE		33944			200° F	SR: N/A CR: N/A
CR-003	15.2.B.1.a.2	CR-003 TANK MAN. TAPE		33944			13500 gal.	SR: DAILY CR: N/A
CR-011	11.2.E.1	CR-011 TANK PRESSURE					MAX 5", MIN -6"	SR: N/A CR: N/A
CR-011	11.2.F.1	CR-011 TANK TEMPRATURE		33944			200° F	SR: N/A CR: N/A
CR-011	15.2.B.1.a.1	CR-011 TANK MANOMETER		33944			45000 gal.	SR: DAILY CR: N/A

244-CR VAULT VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 1U of 2U

296-C-5

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
296-C-5	11.3.A.2	DPI-1		33279	CR101-1 / ET-00643		≤ 5.9" WG	SR: N/A CR: N/A
296-C-5	11.3.A.3	DPI-2		33279	CR102-1 / ET-00650		≤ 4.0" WG	SR: N/A CR: N/A
296-C-5	11.3.A.4	DPI-3		33279	CR103-1 / ET-00660		≤ 5.9" WG	SR: N/A CR: N/A
296-C-5	11.3.C	RR-296-C-5		92519	CR082-1 / ET-02456			SR: N/A CR: N/A
296-C-5	11.3.C	CAM		92489				SR: N/A CR: N/A
296-C-5	11.3.C	FAS-RS-1		92519	CR087-1 / ET-01118			SR: N/A CR: N/A
296-C-5	11.3.C	FC-RS-1		92519	CR088-1 / ET-02276			SR: N/A CR: N/A
296-C-5	11.3.C	FAS-CAM-2		92519	CR085-1 / ET-01120			SR: N/A CR: N/A
296-C-5	11.3.C	FC-CAM-2		92519	CR086-1 / ET-02277			SR: N/A CR: N/A
296-C-5	11.3.C	RECORD SAMPLE FILTER		92519				SR: N/A CR: N/A
296-C-5	11.3.D.2	RR-296-C-5		92519	CR082-1 / ET-02456			SR: N/A CR: N/A
296-C-5	11.3.D.2	CAM		92489				SR: N/A CR: N/A
296-C-5	11.3.D.2	FAS-RS-1		92519	CR087-1 / ET-01118			SR: N/A CR: N/A
296-C-5	11.3.D.2	FC-RS-1		92519	CR088-1 / ET-02276			SR: N/A CR: N/A
296-C-5	11.3.D.2	FAS-CAM-2		92519	CR085-1 / ET-01120			SR: N/A CR: N/A
296-C-5	11.3.D.2	FC-CAM-2		92519	CR086-1 / ET-02277			SR: N/A CR: N/A
296-C-5	11.3.D.2	RECORD SAMPLE FILTER		92519				SR: WEEKLY CR: N/A
296-C-5	15.2.B.3.a	DPI-1		33279	CR101-1 / ET-00643		≤ 5.9" WG	SR: DAILY CR: N/A
296-C-5	15.2.B.3.a	DPI-2		33279	CR102-1 / ET-00650		≤ 4.0" WG	SR: DAILY CR: N/A
296-C-5	15.2.B.3.a	DPI-3		33279	CR103-1 / ET-00660		≤ 5.9" WG	SR: DAILY CR: N/A
296-C-5	15.2.B.3.d	PI-003-1		33944	CR040-1 / ET-02724		NEGATIVE	SR: DAILY CR: N/A

244-CR VAULT VENTILATION OSD MATRIX

WHC-SD-WM-EL-003 REV. 0
PAGE 2U of 2U

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
296-C-5	15.2.B.3.d	PI-003-2		33944	CR044-1 / ET-03936		NEGATIVE	SR: DAILY CR: N/A
296-C-5	15.2.B.3.d	PI-002-1		33944	CR027-1 / ET-03066		NEGATIVE	SR: DAILY CR: N/A
296-C-5	15.2.B.3.d	PI-002-2		33944	CR028-1 / ET-03943		NEGATIVE	SR: DAILY CR: N/A
296-C-5	15.2.B.4	RR-296-C-5		92519	CR082-1 / ET-02456			SR: N/A CR: N/A
296-C-5	15.2.B.4	CAM		92489				SR: N/A CR: N/A
296-C-5	15.2.B.4	FAS-RS-1		92519	CR087-1 / ET-01118			SR: N/A CR: N/A
296-C-5	15.2.B.4	FC-RS-1		92519	CR088-1 / ET-02276			SR: N/A CR: N/A
296-C-5	15.2.B.4	FAS-CAM-2		92519	CR085-1 / ET-01120			SR: N/A CR: N/A
296-C-5	15.2.B.4	FC-CAM-2		92519	CR086-1 / ET-02277			SR: N/A CR: N/A
296-C-5	15.2.B.4	RECORD SAMPLE FILTER		92519				SR: WEEKLY CR: N/A

TANKS C-105/C-106 PORTABLE EXHAUSTER OSD MATRIX

WHC-SD-WM-EL-003

REV. 0

PAGE 1V of 1V

296-P-16

TANK/FACILITY	OSD	INSTRUMENT	OSR	DRAWINGS	CBRS/JCS	SETPOINT	LIMIT	FREQUENCY
PORT. EXHR.	13.2.2.B	CAM-1		95267				SR: N/A CR: MONTHLY
PORT. EXHR.	13.2.2.B	RA-ASI-1-1		95267				SR: N/A CR: MONTHLY
PORT. EXHR.	13.2.2.B	RA-ASI		95267				SR: N/A CR: MONTHLY
PORT. EXHR.	13.2.2.B	FC-CAM-2		95267	P1625-1 / ET-01613			SR: N/A CR: N/A
PORT. EXHR.	13.2.2.B	FAS-CAM-2		95267	P1624-1 / ET-02524			SR: N/A CR: N/A
PORT. EXHR.	13.2.2.B	RECORD SAMPLE FILTER		95267				SR: WEEKLY CR: N/A
PORT. EXHR.	13.2.2.B	FC-RS-1		95267	P1629-1 / ET-01612			SR: N/A CR: N/A
PORT. EXHR.	13.2.2.B	FAS-RS-1		95267	P1628-1 / ET-02527			SR: N/A CR: N/A
PORT. EXHR.	13.2.2.E	CAM-1		95267				SR: N/A CR: N/A
PORT. EXHR.	13.2.2.E	FA-ASI		95267				SR: N/A CR: N/A
PORT. EXHR.	13.2.2.E	FA-ASI-1		95267				SR: N/A CR: N/A
PORT. EXHR.	13.2.2.F.1	DPI-1-EXH-2		74566	P1637-2 / ET-05041		≤5.9", ≥.05"WG	SR: N/A CR: N/A
PORT. EXHR.	13.2.2.F.2	DPI-1-EXH-1		74566	P1633-1 / ET-04793		≤4.0", ≥.05"WG	SR: N/A CR: N/A
PORT. EXHR.	13.2.2.F.3	DPI-1-EXH-2		74566	P1637-2 / ET-05041		≤5.9", ≥.05"WG	SR: N/A CR: N/A
PORT. EXHR.	13.2.2.F.3	DPI-1-EXH-1		74566	P1633-1 / ET-04793		≤5.9", ≥.05"WG	SR: N/A CR: N/A
PORT. EXHR.	13.2.2.G	TI-1-EXH-2		35769	P1621-1 / ET-04886		≤ 200° F	SR: N/A CR: N/A
PORT. EXHR.	15.5.B.1.a.1	DPI-1-EXH-2		74566	P1637-2 / ET-05041		≤ 5.9 IN. WG.	SR: N/A CR: N/A
PORT. EXHR.	15.5.B.1.a.2	DPI-1-EXH-1		74566	P1633-1 / ET-04793		≤ 4.0 IN. WG.	SR: N/A CR: N/A
PORT. EXHR.	15.5.B.1.a.3	DPI-1-EXH-2		74566	P1637-2 / ET-05041		≤ 5.9 IN. WG.	SR: N/A CR: N/A
PORT. EXHR.	15.5.B.1.a.3	DPI-1-EXH-1		74566	P1633-1 / ET-04793		≤ 5.9 IN. WG.	SR: N/A CR: N/A
PORT. EXHR.	15.5.B.1.b	TI-1-EXH-2		35769	P1621-1 / ET-04886		≤ 230°F	SR: DAILY CR: N/A
PORT. EXHR.	15.5.B.1.b	TC-EXH-1		35769	P1623-1 / ET-04882	180°F		SR: N/A CR: N/A