HW--82428

DE93 008589

DECLASSIFIED
HANFORD LABORATORIES
MONTHLY ACTIVITIES REPORT
MAY 1964

Received by OSTT

NOV 23 1992

JUNE 15, 1964

HANFORD ATOMIC PRODUCTS OPERATION
RICHLAND, WASHINGTON

GENERAL **ELECTRIC** **MASTER**

DISTRIBUTION RESTRICTED TO U.S. ONLY

DECLASSIFIED

HW-62428

This document consists
of 173 pages. Copy No. [redacted]
of [redacted] copies. Series [redacted]

DECLASSIFIED

HANFORD LABORATORIES
MONTHLY ACTIVITIES REPORT

MAY 1964

Classification Canceled (Change to
DECLASSIFIED)

By Authority of CG-PB-2
Robert Item-62792
J. A. Wells-9992
B. Cleaver-9-9-42

Compiled by
Section Managers

June 15, 1964

HANFORD ATOMIC PRODUCTS OPERATION
RICHLAND, WASHINGTON

PRELIMINARY REPORT

This report was prepared only for use within General Electric Company in the course of work under Atomic Energy Commission Contract AT(45-1)-1350. Any views or opinions expressed in the report are those of the author only.

Route To	P. R. No.	Location	Route Date	Signature and Date
AE-000				

DECLASSIFIED

DISTRIBUTIONCopy Number

1	W. E. Johnson
2	H. M. Parker
3	F. W. Albaugh
4	C. A. Bennett
5	F. E. Crever, GEAPD
6	I. H. Dearnley
7	W. E. Foust
8	P. F. Gast
9	A. R. Keene
10	H. A. Kornberg
11	J. V. McMaster
12	D. S. Parsley
13	R. S. Paul
14	W. H. Reas
15	W. D. Richmond
16	F. W. Woodfield
17 - 20	Atomic Energy Commission, Richland Operations Office Attn: J. E. Travis
21 - 23	F. P. Baranowski, Director, Division of Production Washington 25, D. C.
24	Savannah River Operations Office, Aiken, South Carolina
25	300 Files
26	Record Center

TABLE OF CONTENTS

	<u>Page</u>
Force Report and Personnel Status Changes	iv
General Summary	
Manager, H. M. Parker	v through xxvii
Reactor and Fuels Laboratory	
Manager, F. W. Albaugh	A-1 through A-38
Physics and Instruments Laboratory	
Manager, R. S. Paul	B-1 through B-37
Chemical Laboratory	
Manager, W. H. Reas	C-1 through C-15
Biology Laboratory	
Manager, H. A. Kornberg	D-1 through D-12
Applied Mathematics Operation	
Manager, C. A. Bennett	E-1 through E-4
Programming Operation	
Manager, F. W. Woodfield	F-1 through F-10
Radiation Protection Operation	
Manager, A. R. Keene	G-1 through G-10
Finance and Administration Operation	
Acting Manager, D. S. Parsley	H-1 through H-14
Test Reactor and Auxiliaries Operation	
Manager, W. D. Richmond	I-1 through I-5
Invention Report	J-1

Table I - Hanford Laboratories Force Report

Date: May 31, 1964

	<u>At Beginning of Month</u>		<u>At Close of Month</u>		<u>Total</u>
	<u>Exempt</u>	<u>Salaried</u>	<u>Exempt</u>	<u>Salaried</u>	
Chemical Laboratory	150	121	152	124	276
Reactor & Fuels Laboratory	210	194	211	196	407
Physics & Instruments Laboratory	111	81	116	77	193
Biology Laboratory	44	64	44	63	107
Applied Mathematics Operation	22	6	20	6	26
Radiation Protection Operation	44	95	44	90	134
Finance & Administration Operation	132	116	129	116	245
Programming Operation	22	5	22	5	27
Test Reactor & Auxiliaries Operation	63	309	63	309	372
General	<u>3</u>	<u>5</u>	<u>3</u>	<u>5</u>	<u>8</u>
TOTAL	<u>801</u>	<u>996</u>	<u>804</u>	<u>991</u>	<u>1795</u>

UNCLASSIFIED

14

HM-82428

UNCLASSIFIED

BUDGET AND COST SUMMARY

May operating costs totaled \$2,561,000, or a decrease of \$344,000 from the previous month. Fiscal year-to-date costs are \$29,475,000, or 88% of the \$33,571,000 control budget.

Hanford Laboratories' research and development costs for May compared to last month and the current control budget are shown below:

(Dollars in thousands)	<u>COST</u>				<u>% Spent</u>
	<u>Current Month</u>	<u>Previous Month</u>	<u>To Date</u>	<u>Budget</u>	
<u>HL Programs</u>					
02	\$ 105	\$ 101	\$ 962	\$ 1 180	81
03	--	4	249	250	100
04	1 006	1 307	12 671	14 085	90
05	111	135	1 276	1 438	89
06	275	296	2 983	3 352	89
08	64	31	251	290	87
	<u>1 561</u>	<u>1 874</u>	<u>18 392</u>	<u>20 595</u>	<u>89</u>
<u>Sponsored by</u>					
NRD	116	105	1 654	1 798	92
IPD	31	23	451	481	94
CPD	160	158	1 572	1 819	86
Total	<u>\$1 868</u>	<u>\$2 160</u>	<u>\$22 069</u>	<u>\$24 693</u>	<u>89%</u>

RESEARCH AND DEVELOPMENT

1. Reactor and Fuels

Examination of the irradiated uranium in N-Reactor assemblies by electron microscopy is continuing in an endeavor to differentiate between the contributions of grain boundary tearing and fission gas swelling.

Two fluted single tube fuel elements in the ETR have achieved an exposure of 2200 Mwd/ton at an operating fuel temperature of 550 C.

Studies of uranium alloys containing iron, silicon, aluminum, or zirconium is continuing. Property studies of these alloys have shown that iron-aluminum additions greatly retard the crystallization of cold worked uranium.

DECLASSIFIED

DECLASSIFIED

Examination of target elements irradiated in high pressure loops has shown unexpected bonding between the outer Zircaloy sheath and the internal aluminum can. This bonding would interfere with postirradiation decanning and might cause tritium pickup in the Zircaloy can.

Aluminum-lithium billets have been received for the fabrication of a 45-column charge of coproducer elements for N-Reactor. Fabrication of the charge of target elements has been initiated.

Preliminary studies of lithium containing glasses have shown that the glass composition incurs extensive cracking during cooling. The composition appears to have little promise as a target material.

The required arc melting, coextrusion, end closure brazing, and thermocouple brazing have been completed on 12 thorium-uranium crud probes. These probes will be used in the N-Reactor during fuel ascension.

Improved hot heading techniques and welding conditions have been used in the fabrication of 20 outer tubes for N-Reactor elements. Destructive examination of selected pieces is in progress.

A brief study of the effect of UO_2 dispersion in iron has shown that the strength of the dispersed product is double that of the base iron at 800 C.

Beryllium-zirconium wire, 0.025 in. in diameter, has been produced by drawing. The wire stock will be used in a modified braze closure technique.

The multipurpose capsule containing lithium-bearing target materials and zirconium oxidation-hydriding experiments has accumulated 48 days of exposure. It will be discharged for postirradiation examination during the next reactor outage.

Corrosion tests on aluminum exposed as a rotating disk to pH adjusted 300 Area water revealed a decrease in pitting as pH was increased.

Crack propagation tests, made at two different crack initiating slot lengths in KER Loop 1 Zircaloy tubing after 3 yr of in-reactor service, show no change in brittle fracture characteristics.

Borescope examination of an out-of-reactor Zircaloy-2 process tube test section operating at N-Reactor coolant conditions revealed numerous fretting marks of unknown depth on the interior surface where the N-Reactor fuel element supports and tubular spacer projections contacted the tube wall. External vibration (peak-to-peak amplitude 3.5 mils) had been applied to this test section during operation.

Transient heat transfer experiments were performed to determine the consequences following a rupture of an inlet connector feeding a single fuel column at N-Reactor. It was concluded that if the flow-adjusting valve in the inlet connector remained open, no significant increase in the fuel temperature would occur, even if the reactor scram was delayed for as much as 25 sec. However, if the valve closed because of the action of the reversed flow, a temperature rise would occur if the scram was delayed more than 1.5 sec and could increase 500 F for a scram delay time of 5 sec.

A second experiment in the graphite-zirconium compatibility loop disclosed a rate of graphite oxidation of 3×10^{-7} g/g/hr for shielded samples, thereby confirming the results of the first experiment.

The presence of mercury introduced from a vacuum system was found to have no effect on the radiation-induced reaction of carbon monoxide and water vapor.

Long-term irradiation of N-Reactor graphite continues satisfactorily.

Three 19-rod assemblies were fabricated for the PRTR.

The first 20 PRCF mixed oxide rods were completed.

Prototypic segments of EBWR fuel rods have reached 4500 Mwd/ton exposure at rod powers to 35 kw/ft. Performance is excellent.

The entire PRTR fuel loading was inspected and found to be in excellent condition.

The second generation shim control assembly has operated continuously during the report period with no mechanical faults.

DECLASSIFIED

DECLASSIFIED

The vibration level of PRTR inlet jumpers 1354 and 1963 were generally constant throughout the recent 23-day operating period. Several instances were noted in which the amplitudes associated with both channels changed abruptly and simultaneously, but attempts to correlate these changes with known operating conditions have been unsuccessful.

Analyses of the Doppler delay problem were extended to include fuel typical of fast oxide breeders. Time constants were derived which indicate Doppler safety in uniform mechanically mixed fuels is attainable for a wide range of reactor types.

Corrosion rates of aluminum-clad fuel elements exposed to pH 7 deionized water at 260 C outlet temperature in C-1 Loop varied uniformly from 3 mils/mo at the upstream end to 14 mils/mo at the downstream end, based on weight losses before cleaning. Corrosion of A-288 and KYZ alloys was slightly less than for X-8001.

Corrosion tests show aluminum to be compatible with a 10 ppm solution of boric acid. This work is being done in support of a potential shim concept.

New pressure tube inspection equipment was installed and operated for the first time. Of the 15 process tubes examined with this equipment, 5 were approaching the minimum allowable gas gap between the pressure and aluminum shroud tube. In general, equipment operation was good.

Remote nondestructive examination of flaws on the inside of PRTR pressure tube 5690 by eddy current techniques confirmed opinions based on normal monitoring inspection that the flaw was a blister. It is located 7 ft, 11 in. from the flange and is about 0.040 in. deep.

No reactions between PuN and graphite were detected after heating PuN in a graphite holder for 1 hr at 1725 C in nitrogen.

ThN was prepared by arc melting thorium metal under 1 atm of nitrogen.

A specimen of UN-20 wt% PuN was irradiated to 9400 Mwd/ton exposure and returned to Hanford from the MTR for radiometallurgical examination

Radiochemical data show significantly high concentrations of Cs¹³⁷ and Sr⁹⁰ in the free uranium phase of irradiated UO₂ fuel elements.

Initial tests of the image intensifier system with the electron microscope demonstrated that considerable increases in image brightness are obtainable.

Tungsten-to-tungsten-UO₂ cermet bonding has been enhanced by using thin metal films to initiate diffusion.

Impaction of dry, ball milled (65 hr) UO₂ and PuO₂ powders produced a homogeneous fuel element.

A thoria element containing 1000 ppm nitrate is being irradiated. Centerline fuel temperature in the thoria element reached 1080 C after two MTR cycles.

A general swelling capsule controlled at 700 C (1292 F), containing high purity uranium specimens of varying specimen geometry, reached its goal exposure and was discharged. A capsule controlled at 400 C (752 F) was charged.

Optical and electron metallography is complete on specimens of U + 400 ppm Fe + 640 ppm Al and U + 140 ppm Fe + 95 ppm Si which were irradiated to 0.11 at. % burnup at 535 C (995 F). In this capsule the Fe-Al alloy specimens were vastly superior in swelling resistance to the Fe-Si alloy specimens.

Metallography is complete on the as-extruded high purity uranium specimen irradiated to 0.11 at. % burnup at 575 C (1067 F). Extreme porosity was noted commensurate with the large density decrease that was observed.

Annealed AISI 304 stainless steel currently being tested in-reactor at 20,000 psi and 500 C (932 F) is creeping so slowly that creep rate at this time cannot be determined. No increase in rate has been observed during the short periods of reactor outage.

Several tensile specimens of nickel base alloys irradiated at about 580 C (1076 F) and 740 C (1364 F) to an exposure of 5×10^{19} nvt (E > 1 Mev)

DECLASSIFIED

were tested at room temperature. Initial results of these data for Inconel 625 show a substantial loss in strength and ductility at the higher irradiation temperatures.

Tensile tests were performed on specimens irradiated at 50 C (122 F), 290 C (554 F), and 750 C (1382 F). Changes in the mechanical properties of AISI 348 stainless steel amount to only a 2 or 3% increase in strength, but the total elongation is decreased in some cases by as much as 10 to 15%.

Zircaloy-2 taken from a "basket" tube exposed in the M-3 position of the ETR water loop for 80 days to 260 C (500 F) and a maximum fast flux of 1.5×10^{13} revealed a weight gain four times greater than would be expected from a similar out-of-reactor exposure.

Long-term irradiation of EGCR graphite continues satisfactorily.

Samples of four graphites designed to determine the effect of sample size on radiation induced contraction were charged into a Hanford reactor test facility.

Measurement of samples of isotropic graphite after an exposure of 1.13×10^{21} nvt at 620 C disclosed smaller contraction rates than observed for CSF graphite.

Analysis of thermal expansion coefficients for graphites at temperatures ranging from 1370 to 2700 C suggests that pores formed during the graphitization process are of greater significance than microcracks that formed during the cooling process.

Measurement of graphites that were impregnated with furfuryl alcohol and regraphitized showed an expansion in the transverse direction in the last irradiation interval.

Pyrolytic graphite on continued irradiation at 600 C continues to show an expansion in the c-direction and a contraction in the a-direction.

The second irradiation capsule with boronated graphite samples continues to operate satisfactorily. A buildup of helium produced by the (n, α)

reaction has been noted. Analysis of the samples from the first irradiation disclosed lithium contents of 0.35 to 0.40%.

An increase of compressive strength of 2000 to 2500 psi was found for boronated graphite samples irradiated to 10^{20} nvt.

Thermal conductivity was measured on irradiated and unirradiated boronated graphite samples. Significant finding was a 6- to 8-fold reduction in thermal conductivity after irradiation.

A series of boronated graphite samples was charged in the ETR with the objective of irradiating to 10^{21} nvt ($E > 0.18$ Mev).

Three tubular Th-U fuel elements being irradiated in the ETR have now achieved an exposure of 7100 Mwd/ton. The irradiation is continuing.

Capsule irradiation of uranium containing submicron uranium carbide particles has achieved a goal exposure of 0.3 at.% burnup. Two additional capsules will be charged in the next ETR shutdown.

Heat transfer experiments were completed for the comparison of boiling burnout data between horizontal and vertical positioning of 19-rod fuel bundles. Using a 6.3 ft long electrically heated test section, it was found that the burnout data were identical for the two positions, except at very low flow rates. For a flow of 500,000 lb/hr-ft², the burnout heat fluxes were 25% greater for vertical positioning of the test section because of less stratification of the steam-water coolant.

Single crystals of molybdenum that were deformed after irradiation have been sectioned in certain crystallographic directions and thinned for electron microscopy. A replication technique has been developed and applied to the study of slip traces on irradiated molybdenum bend specimens.

Lattice parameters of irradiated single crystals of molybdenum containing 15 ppm and 450 ppm carbon as intentional impurity have been determined.

DECLASSIFIED

DECLASSIFIED

A paper entitled "Quench-Hardening in Polycrystalline Nickel" is being prepared for publication. Briefly, the results show that a high super-saturation of vacancies may be retained in nickel by quenching, and these vacancies form large aggregates upon annealing.

The lattice parameter of high purity rhenium foils, which were annealed in preparation for irradiation experiments, have been determined by a special technique using a single crystal orienter. The foils being studied do not lend themselves to line breadth measurements.

The investigation of the steady state creep characteristics of the six allotropes of high purity plutonium is essentially complete. The most notable of the anomalies is the significantly higher creep rate of the beta phase after $\alpha \rightarrow \beta$ transformation than after $\alpha \rightarrow \beta \rightarrow \gamma \rightarrow \beta$ transformations.

X-ray diffraction studies indicate that a randomly oriented, fine-grained alpha plutonium structure can only be produced by quenching from the epsilon phase, about 600 C (1112 F). A specimen so quenched has provided the necessary absorption data to permit corrections to be applied to the pole figure goniometer data. The study of texturing in plutonium can now proceed. The goniometer is also being employed in the further investigation of the columnar grained structure developed by the transformation of beta to alpha under slight pressures. The previously reported alignment of the 020 plane perpendicular to the direction of applied stress has been confirmed.

Project CAH-136 was approved. This \$150,000 project is to provide additional offices, lunchroom, and locker room facilities in 327 Building and will make available laboratory space currently in use as offices.

An additional 260 EBWR rods were completed for physics tests.

In the screening of materials for the HTLTR, materials were exposed to a nitrogen gas graphite environment at 1200 C for 840 hr. Initial results indicate that a UO_2 -Ni reaction had occurred and the Hastelloy-B underwent extensive carburization with attendant loss in ductility.

Design studies of fuel element fabrication from W-UO₂ fuel plates are in progress. Interlocked "egg crate" structure and longitudinally corrugated fuel plates spaced by twisted ribbons are currently under consideration.

Studies of coprecipitated W-UO₂ have shown that discoloration in the reduced product is apparently not caused by contamination. The densified product is metallic in appearance and shows no evidence of a third phase.

In the studies of extruded tungsten honeycombs, a Zirconia coated thin steel liner has been successfully used in the extrusion container. The liner prevents damage to the container when extrusion temperatures in the 1200-2000 C range are employed.

A niobium clad, UO₂-30 vol% Nb cermet was irradiated to 0.34×10^{20} fissions/cc at 905 w/cm rod power.

Continued experiments with thermal cycling of UO₂-W in high and low pressure hydrogen have emphasized the important role of impurities in effecting cermet weight loss.

Three irradiation tests of UO₂-80 wt% W cermet fuel plates were conducted in static hydrogen atmosphere at temperatures to greater than 2650 C.

A current design study of stacking cermet honeycomb grids in a fuel channel involves three tungsten support rods, fixed at the downstream end, with slip guides at the coolant entrance to accommodate axial thermal expansion.

Electron microscopy of NASA-3-M cermets revealed significant differences in size and concentration of inclusions.

Photomicrographs of a Nupac W-UO₂ grid clad with vapor deposited tungsten by an offsite vendor indicated good adhesion and uniformity of the tungsten cladding.

DECLASSIFIED

DECLASSIFIED

Molybdenum mandrels are being coated with tungsten metal by two techniques—vapor deposition and flame plating—for subsequent transferral to honeycomb grids by the Nupac technique.

Sintering of an 80 vol% W- UO_2 cermet grid in hydrogen for 12 hr at 1750 C increased the density from 95.8 to 97.5% TD.

The process of forming 2-in. diameter Al-20 wt% Pu billets for subsequent machining of 0.020-in. wafers was improved by extruding billets prior to machining.

Vibrational compaction techniques were successfully developed for the fabrication of MgO insulated heating elements.

2. Physics and Instruments

A preamplifier is being developed for the N-Reactor low-level neutron flux monitor to overcome temperature limitations evident with the installed equipment.

Analog simulations studies of N-Reactor were completed for the 10% of rated power. Results indicated a need to add the derivative or rate mode of control to certain controllers. Circuits were designed to achieve this in a practical manner. A simulation of cold water injection was also completed.

Criticality experiments for nuclear safety guidance were continued with $\text{Pu}(\text{NO}_3)_4$ solutions in an 11.5-in. -diameter sphere reflected with concrete. Critical concentrations in the 12.95 liter vessel were in the range of 80 to 260 g Pu/l, depending on the nitrate concentration.

A paper of some interest to reactor safety applications was received from Dr. R. W. Albrecht (consultant to Critical Mass Laboratory). The paper is entitled, "The Use of Delayed Neutron Reactor Noise Spectrum for Sub-critical Reactivity Measurement." A method is described for determining reactivity independent of knowledge of the value of the prompt neutron lifetime.

A three-region lattice Monte Carlo code has been written to obtain more definitive answers to criticality problems involving enriched uranium rods in uranium solution (typical problem of dissolving fuel elements).

Orderly progress continued on development of improved nondestructive testers for production fuels. For N-Reactor fuels this included process testing of a cap-to-core bond test for the Chevron end cap and an X-ray fluorescence test for uranium surface contamination, laboratory development of an ultrasonic test to differentiate fuel with different heat treatment, and checks of ultrasonic tests for irradiated fuel examination. Work for AlSi fuels included improvement of the irradiated fuel testers, correlation studies with a new outside-in bond test, and a study of the feasibility for testing hot die sized components for eccentricity before assembly.

Measurements were made of the neutron total cross sections from 2.5- to 15-Mev of bromine, oxygen, nitrogen, and deuterium.

The cause of some internal inconsistencies in data obtained on the scattering law for H_2O at 95 C was identified and corrected results were obtained.

The new scintillation-type ion detector and ion pulse-counting system was put into routine operation on the Isotopic Analysis Program mass spectrometer.

Phoenix reactor studies have been expanded to include combinations of burnable poisons and combinations of uranium and plutonium fuels. The studies of mixtures of burnable poisons are the furthest advanced and show very favorable reactivity effects.

Measurements in the PRCF of the film void coefficient with EBWR fuel were completed. In addition, measurements were made of the worth of a cylindrical void in an empty fuel channel.

A draft of a preliminary hazards report for the HTLTR has been prepared for comment. Work on the large mockup for testing prototype

DECLASSIFIED

components has been resumed. An initial design for the control rod and safety sheet prototypes has been prepared, and the actuating mechanisms for these are being constructed.

The critical numbers of EBWR fuel rods for all of the proposed lattice spacings in the approach-to-critical facility have been calculated.

In response to a EURATOM-funded request from Vallecitos Atomic Laboratory, consultation services were provided to assist Vallecitos in modifying Hanford's multienergy transport codes (Program S) to obtain as additional output a leakage-preserving diffusion coefficient.

Cross sections from the Hanford RBU library are being used in evaluation of the regenerating type neutron flux detectors. The rough draft of the final report on this concept is well under way. The necessary U^{234} was received for use in the regenerating detector chambers being fabricated by GE-APED; the chamber design was received and accepted.

A new chamber construction was developed for the beta current in-core neutron flux detectors, and an experimental program was initiated to evaluate various cable configurations in an attempt to alleviate the cable noise difficulties.

Encouraging results were obtained in a second microwave neutron flux monitor test at KW-Reactor. A He^3 filled capsule was used in the cavity for the single-ended test apparatus. The temperature rise problem, which adversely affected the first test, was solved by adequate cooling. Further tests are planned.

The separation of signals resulting from internal and external tube wall irregularities was demonstrated using the multiparameter eddy current tubing tester. An air-core tuned transformer with a rotating secondary winding was assembled together with drive motor for insertion into N-Reactor process tubes.

[REDACTED]

A computer program to give frequency spectrum information for ultrasonic pulses has been written and tested. The needed input data were obtained using a sampling oscilloscope and recorder to measure amplitude information of the pulse.

Further studies were conducted to determine the influence of hydride content and other material variables on eddy current tests. In the absence of hydrogen, no change in resistivity levels was noted when Zircaloy samples were heat treated for 50 hr at 400 C.

Steel samples are being fatigued for use in tests to determine the effectiveness of eddy current techniques and ultrasonic critical angle measurements in determining fatigue condition in metals.

Fabrication and checkout of the final AEC/AECL sheath tubing tester were completed. No appreciable change in tester performance was measured over a 2-wk period of testing. Approximately 200 tubes which had been previously tested and passed by commercially available equipment were retested at the prototype station. Many flaws which had been undetected by the commercial equipment were located by the Hanford developed tester.

Ultrasonic wall thickness measurements of prototype isotope containment cells were performed on both filled and empty cells. Preliminary feasibility studies indicate that ultrasonic and eddy current methods will be applicable to determining other structural and thermal properties of the finished cell.

The results of last month's uranium mine study were presented at the Hanford Symposium on Inhaled Radioactive Particles and Gases. Experts at the symposium said the results were what other methods of study had led them to expect, but the experiment was of great value because it established what actually did happen in people.

Correlation of plutonium X-ray counting with plutonium body burdens of dogs continued along with applications of the counter to excreta analysis and to chemical analysis.

DECLASSIFIED

[REDACTED]

DECLASSIFIED

Final analysis of the Pm^{147} calorimetric half-life measurements gave excellent agreement with results from Mound Laboratory. An experiment with calorimeters established the region of validity of the theoretical analysis we have been using.

Results of the planned field release of I^{131} over the Hanford atmospheric dispersion field grid last year during a temperature inversion show a deposition rate of 1 cm/sec on rye grass, consistent with the value currently used for environmental hazards analyses here. This finding is in close agreement with values determined from particulate zinc sulfide tracer studies.

Excellent laboratory test results were achieved, during two atmospheric inversions, with the alpha energy analysis air monitor slated for use in the Biology Inhalation Laboratory. In addition, fabrication and testing were completed on a smoke inhalation control instrument for animals, which was developed to automatically control air and smoke inhalation in animal biological studies.

An analog computer model was developed and demonstrated for the study of the uptake of a radioisotope parent and its daughter in various parts of the body. Provision was made for inhalation, ingestion, skin contamination, and injection into the blood of arbitrary quantities of the parent and daughter radioisotopes.

Considerable progress was achieved in tests on the experimental face mask monitor for use at the HAPO Laundry Facility. The lucite detector light pipe was completed and with the use of an anthracene scintillation material, a Pm^{147} detection sensitivity of 10 to 20 nCi was obtained.

The temperature comparators to be used as out-of-limits detectors at the KW-Reactor creep capsule test facility were received and circuitry was designed and built to integrate them into the system. The circuitry includes high-low set-point dials, deviation indication, trip indication, calibration jacks, and regulated supply. The complete unit was calibrated and checked out for installation.

The ANN (aluminum nitrate nonohydrate) recovery process model was programmed for iterative solution on an analog computer.

A magnetic particle inspection was conducted on the weld bevels of the head and shell of N-Reactor Steam Generator 4A to insure metal integrity before making the butt weld. Radiography for weld integrity and code compliance was conducted on the ammonium and lithium hydroxide lines in the 184 Building, 100-N Area, the Rupture Loop, HX-1 System, and NPC 212 in "A" cell at PRTR.

Instrumentation was developed and operated to enable the successful measurement of the electrical resistivity as a function of density during α - β phase transformation in plutonium. Results show that the resistivity and density changes during the phase transformation occur at the same time and in equal percentages.

Ultrasonic leak detection was successfully applied to the detection of leaks in 234-5 Building glove boxes in which a negative pressure is maintained.

3. Chemistry

Tests on a mockup of the main Purex ventilation filter show promise that the materials causing high pressure drop can be removed with a water wash.

"Run-away" exothermic reactions of nitric acid equilibrated anion exchange resin confined in engineering-scale, simulated contactors did not begin at testing temperatures of 110 C or less.

A process for purifying a strontium "crude" by extracting calcium and cerium from the strontium was demonstrated using CSREX solvents.

The generally encouraging results from tests of immersion heaters for in-tank waste solidification have led to plans for a full-scale test in 200-East tank.

DECLASSIFIED

DECLASSIFIED

xx

HW-82428

[REDACTED]

In addition to the improved (adherent, low-porosity) nickel plate achieved with a H_2SO_4 -HCl etch (vice a H_3PO_4 -HCl etch) pretreatment, this approach reduces by 60% the amount of uranium that must be sacrificed in the etching step.

Purification of the technetium (approximately 1 kg) recovered by CPD has progressed to an ammonium pertechnetate in which residual activity has been reduced to less than 10^{-4} that of the technetium and total metallic impurities are less than the spectroscopic detection limit of 50 ppm.

Use of a low-sodium feed has allowed a thoria product suitable for the sol-gel process to be produced by radiant heat spray calcination of a thorium nitrate solution.

Strontium recoveries exceeding 95% have been obtained in hot cell experiments with actual Purex waste tank sludge. Use of sodium carbonate (vice organic compounds) to accomplish needed complexation of iron was fully satisfactory.

Initial experiments showed promise for a new direct radiochemical counting method allowing Cs^{137} to be counted without separation from other fission products. Such an approach may allow fuel burnup analysis without the necessity for chemical separations.

Two partially successful salt cycle electrodepositions were completed with irradiated material. Mixed oxides were produced with 0.6 to 1.0 wt% plutonium although oxygen/uranium ratios were higher than desirable.

The cold semiworks continuous melter and spray calciner for waste solidification studies were coupled and operated with "glass" forming Redox wastes. The basic operability of the combined unit was adequately demonstrated. This technique will allow continuous operation of the spray calciner without shut-down for removal of a batch product collection container.

A hot cell calcination run dispelled concern that sampling inefficiencies may have distorted ruthenium off-gas decontamination data in earlier runs.

[REDACTED]

The experiment showed the sampling techniques used in earlier runs to be quite efficient and the data therefore valid.

Measurements of fallout radionuclides suggest that Na^{22} was generated in considerable quantity in atmospheric tests beginning in 1961 but that the major injection of Cs^{134} into the atmosphere must have occurred before these tests. Multidimensional analysis allows a total of 12 fallout radionuclides to be measured by direct counting of air filter samples. Radionuclides currently being measured are Be^7 , Na^{22} , Mn^{54} , Co^{60} , Y^{88} , Zr-Nb^{95} , Ru^{106} , Sb^{124} , Sb^{125} , Cs^{134} , Cs^{137} , and Ce^{144} ; Be^7 , Sb^{124} , and Sb^{125} were not previously measured.

Progress has been made in evaluating, and amending where necessary, bioassay procedures for uranium, plutonium in soil, and cerium. This is work especially requested by DBM to obtain accreditation of analytical procedures to be recommended to AEC licensees.

A new computer code (ISOGEN) developed for calculating radioisotope generation and decay proved faster than the current code (ALCHEMY) for this purpose and capable of 0.1% accuracy in almost all cases with a maximum error of 0.2%.

Referee measurements at Mound Laboratory of Pm^{147} decay energy checked previous Hanford values closely, yielding a value of 0.3330 w/g. The half-life of Pm^{147} determined from calorimetric measurement of decay heat and therefore not dependent on gravimetric or radiochemical measurements, is 2.620 ± 0.005 yr.

A 50% increased loading of Duolite C-3 resin with cesium from Redox diluted waste was demonstrated on a laboratory scale.

Laboratory tests indicate that Linde AW-400 and AW-500 zeolites, having the same bonding agent, differ in physical stability, the AW-500 being superior. The reason for this difference is not yet known.

New equations were found to correlate experimental soils data that improve and simplify the solution of one-dimensional, transient partially-saturated flow systems.

DECLASSIFIED

DECLASSIFIED

4. Biology

The Hanford Symposium on Inhaled Radioactive Particles and Gases was held May 4, 5, and 6, 1964 in Richland, Washington. Total registration was 270 of which 157 were from offsite. Fifteen of the 157 offsite registrants were from foreign countries.

There were 42 contributed papers, 35 of these papers were presented orally, and 7 were read by title. Five papers were contributed by personnel of Hanford Laboratories. All papers will be published in the Symposium Proceedings which will appear as Volume 10, Number 12 of Health Physics in December 1964.

Thirty-day exposures of fish to reactor effluent at concentrations as high as 6% caused no increase in mortality above controls when the water was cooled to river temperatures.

River fish were found to have an immunity mechanism for protection against columnaris. The response can be artificially induced in the laboratory.

The LD₅₀ of a technetium compound was determined and found to be quite high, indicating that chemical toxicity is the limiting factor.

Uptake of I¹³¹ through pig skin was found to be about 2%. The iodine on pig skin can be removed by washing with soap and water.

The resorption of bile salts from the lumen of the rat's intestine was found to be markedly decreased by X-irradiation. This is unlike the situation for glucose following radiation of the GI tract. Glucose continues to be absorbed to a greater degree than bile salts.

The number of Canada geese nesting in the Hanford Reservation dropped 21% below that of last year and 33% below that of the preceding 11 years' average. Fertility of the eggs, however, remained high.

Dead plankton were found to absorb Sc⁴⁶ and Cr⁵¹ as actively as live plankton. Zn⁶⁵, however, was absorbed more by live than by dead plankton, indicating that a biological process for this element occurs.

5. Programming

Extremely high priced uranium ore (over \$100/kg) should not be required before the year 2025, based on a current new look at projected nuclear capacity and associated uranium requirements.

Minimum total fuel costs for power-only N-Reactor operation have been calculated for a variety of fueling systems. Slightly-enriched metallic uranium fuel yields the lowest fuel cost of all the cases studied.

A simplified method of assessing Doppler broadening effects has been incorporated in the MELEAGER-ALTHAEA routine.

TECHNICAL AND OTHER SERVICES

There was one new plutonium case confirmed by special bioassay analysis during the month. This case resulted from inhalation following release of airborne contamination from a hood in the Plutonium Purification and Fabrication Building (234-5). The deposition was estimated to be 3% of the maximum permissible body burden (MPBB, plutonium with bone as a reference, is 0.04 μCi).

The total number of individuals who have received a detectable internal plutonium deposition at Hanford is 344, of which 247 are currently employed.

An HL maintenance employee received an exposure in excess of the Hanford Operational Control of 1 rem per badge period as a result of work at the Plutonium Recycle Test Reactor Facility (309). Special processing of the employee's film badge dosimeter worn during the period April 24 through May 22, 1964 indicates a whole body penetrating dose of 1.1 rem. Bioassay samples analyzed for tritium indicate an additional whole body exposure of 0.2 rem during this period. The employee's accumulated exposure, including the above, does not exceed any permissible limit.

DECLASSIFIED

DECLASSIFIED

Seven magnetic tapes have been produced for testing the numerically controlled rotary contour gage following its conversion.

A FORTRAN language program to unfold an observed two-dimensional particle size distribution into its three-dimensional counterpart has been completed.

A report on the computer program for testing orthorhombic crystals is being prepared and will be issued soon. A paper on the general problem of crystal indexing has been prepared and submitted for publication.

Digital computer methods for estimating rate constants for a set of chemical reactions are being compared with a similar scheme using an analog computer.

Statistical analysis of experimental data concerned with the effectiveness of DFAB and DTPA in preventing the deposition of plutonium was completed.

SUPPORTING FUNCTIONS

Plutonium Recycle Test Reactor output for May was 84 Mwd. A summary of the fuel irradiation program as of May 31, 1964, follows:

	<u>Al-Pu</u>		<u>UO₂</u>		<u>PuO₂-UO₂</u>		<u>Other</u>		<u>Program Totals</u>	
	<u>No.</u>	<u>Mwd</u>	<u>No.</u>	<u>Mwd</u>	<u>No.</u>	<u>Mwd</u>	<u>No.</u>	<u>Mwd</u>	<u>No.</u>	<u>Mwd</u>
In-Core	0		7	1 474.4	78	12 214.7			85	13 689.1
Maximum				295.4		289.9				
Average				210.6		156.6				
In Basin	7	569.9	25	2 720.1	33	2 426.7			65	5 716.7
Buried							1	7.3	1	7.3
Chemical										
Processing	68	5 465.8	35	1 965.8					103	7 431.6
Program										
Totals	75	6 035.7	67	6 160.3	111	14 641.4	1	7.3	254	26 844.7

Note: (Mwd/Element)x 20 = Mwd/ton_U for UO₂ and PuO₂-UO₂.

The major portion of the month was devoted to containment vessel leak rate tests and maintenance. The measured leakage rate was less than 1% at a test pressure of 14-1/2 psig on the containment vessel. The performance of the tests required that the reactor be totally discharged of fuel. The primary system was drained to permit repair and modification work.

A total of 173 reactor outage hours were charged to repair work. Main items were:

Containment vessel leak repairs	101 hr
HX-5 fitting repairs	53 hr

Estimated heavy water loss and indicated helium loss for May were 627 lb and 39,056 scf, respectively.

Plutonium Recycle Critical Facility experiments with EBWR fuel continued. Data were taken for void and substitution measurements and for flux distribution and spectrum studies. An outage was taken beginning May 8 for miscellaneous modifications and inspections including changes to the EBWR core lattice plates. This outage, concurrent with PRTR containment testing work, lasted through month-end.

The Rupture Loop in the Fuel Element Rupture Test Facility has been restored to the loop status. A dummy decontamination run was completed without difficulty.

Within the program for Chemical Processing of Spent PRTR Fuels, the Commission was given a list of 12 defective, low exposure, 1.0% PuO₂-UO₂ fuel elements to determine their ultimate disposal.

Total productive time in Technical Shops Operation for the period was 22,849 hr. Distribution of time was as follows:

	<u>Man Hours</u>	<u>% of Total</u>
N-Reactor Department	2 128	9.3
Irradiation Processing Department	3 958	17.3
Chemical Processing Department	482	2.1
Hanford Laboratories	16 281	71.3
Hanford Utilities and Purchasing Operation	--	--

DECLASSIFIED

DECLASSIFIED

xxvi

HW-82428

Total productive time in Laboratory Maintenance Operation was 17,100 hr of 19,000 hr potentially available. Of the total productive time, 89% was expended in support of Hanford Laboratories components, with the remaining 11% directed toward providing service for other HAPO organizations. Manpower utilization (in hours) for May was as follows:

A. Shop Work	1 800
B. Maintenance	6 800
1. Preventive Maintenance	2 900
2. Emergency or Unscheduled Maintenance	1 400
3. Normal Scheduled Maintenance	2 500
C. R&D Assistance	8 500

The heavy water inventory at the end of May 1964 showed a loss of 1025 lb valued at \$14,176 for the PRTR. Heavy water scrap generated during the month amounted to 398 lb, resulting in a \$537 charge to operating cost. Heavy water accumulated at May 31, for return to SROO, amounted to 18,359 lb valued at \$229,027.

Arrangements were completed to ship 52 drums of heavy water scrap valued at \$214,456 to SROO on or about June 15, 1964.

During the month, the 3201 and 3201-A Buildings in the 3000 Area, consisting of a wood frame (27,733 sq ft) and a concrete block (165 sq ft), were transferred to Hanford Laboratories by the RLOO-AEC. These buildings, with a first cost of \$237,257 and a net book value of \$119,307, were the former Post and 5th AA Group Headquarters.

Cumulative data of Hanford visitations:

	Number of Visitors	
	In May	Since June 13, 1962
Visitors Center	1 779	67 808
Plant Tours	442	--

DECLASSIFIED

HAPO professional recruiting activity for May:

	<u>Plant Visits</u>	<u>Offers Extended</u>	<u>Offers Accepted</u>	<u>Offers Rejected</u>	<u>Offers Open</u>
Ph.D.	15	11	3	2	8
BS/MS (Direct Placement)	0	4	5	0	2
BS/MS (Program)	0	0	2	12	5

Seven Technical Graduates were placed on permanent assignment. Two new members were added to the roll, leaving a total of 45 program members on the roll.

Authorized funds for nine active projects total \$7,725,000. The total estimated cost of these projects is \$10,652,000. Expenditures through April 30, 1964 were \$3,125,000.

Manager, Hanford Laboratories

HM Parker:JEB:dh

DECLASSIFIED

A-1

REACTOR AND FUELS LABORATORY MONTHLY REPORT

MAY 1964

TECHNICAL ACTIVITIES

A. FISSIONABLE MATERIALS - 02 PROGRAM

1. Metallic Fuel Development

N-Reactor Fuel Evaluation. Fuel swelling in N-Reactor fuel components as determined by density measurements in the Radiometallurgy facility agree well with data obtained from post-irradiation measurements made in the KE Basin. Porosity in the fuel of an irradiated NIE (1.17% ΔV) has not been resolved at magnification to 1000X. Examination at higher magnification by electron microscopy is in progress. Porosity in the fuel of an irradiated NOE (3.64% ΔV) is apparent at 1000X after a deep cathodic etch. Higher magnification (3000-10,000X) electron microscopy of the uranium fuel shows small grain boundary tears in the swirled or hashed microstructure of the uranium but does not reveal a significant amount of fine spherical or regular porosity such as might be obtained by agglomeration of fission gases.

Fluted Fuel Element Irradiation. Two N-single tube fuel elements with fluted outer surfaces have completed 11 cycles of irradiation in the ETR pressurized loop for an accumulated exposure of approximately 2200 Mwd/ton. These elements operate with a maximum specific power of 140 kw/ft and a corresponding fuel temperature of 550 C. Swelling data have not as yet been obtained for the eleventh irradiation cycle. A volume increase of 1.6% was measured for these elements after 10 reactor cycles.

Alternate Uranium Compositions. Studies are in progress to evaluate uranium-base alloys in terms of fuel element fabrication, corrosion behavior and irradiation performance.

Four vacuum induction melted alloys were extruded into rods approximately two inches in diameter for subsequent fabrication of U + 400 Fe into coextrusion billets of arc melt electrodes. Coextrusion billets are to be made from alloys containing (in ppm) U + 25 Si + 800 Al + 500 C and U + 260 Fe + 130 Si + 100 Al + 500 C. Arc melt electrodes will be made from alloys containing U + 400 Fe + 25 Si + 800 Si + 500 C, U + 175 Fe + 85 Si + 100 Al + 500 C, and U + 800 Si + 500 C. An alloy with a nominal composition of U + 2 wt% Zr + 350 C is being prepared

for a second arc melting prior to being fabricated into a co-extrusion billet. An alloy of nominal composition U + 400 Si + 800 Al + 500 C has been added to the study on the basis of improved hot hardness and favorable precipitate distribution obtained in studies carried out by Nuclear Metals Inc.

Metallurgy of Uranium Alloys Studies are in progress to determine the effects of altered fuel compositions upon fuel element fabrication, corrosion behavior, and irradiation swelling resistance.

Additional hot hardness or creep penetration data were obtained from samples of single tube fuel elements (1.790 inch OD x 0.975 inch ID) fabricated from standard N-fuel composition and an alloy containing 400 ppm Fe and 800 ppm Al. Meyer hardness values at 300 and 400 C in 4-hour tests with 600-pound loads for these materials in several different conditions have been obtained. The Fe-Al containing material is harder than the standard Fe-Si at all conditions; both materials are softest in the coextruded condition (longest high alpha temperature); both materials are harder beta heat treated and slightly harder in the braze heat affected region that had been in the gamma phase. Creep tests at 400 C and 600 pounds load have been run to 72 hours and indicate approximately the same rate of deformation for the two materials in the beta heat treated condition. These tests are continuing to longer times.

The recovery and recrystallization temperature ranges of these two materials, high purity dingot uranium, and coextruded UC dispersion fuel are being determined from samples annealed after identical cold working histories. These data are not complete, but results thus far indicate an increase of at least 250 C in temperature for complete recrystallization between the high purity dingot and Fe-Al containing material. Microhardness and metallography are being used.

Target Element Development Examination of target elements irradiated in KER Loop 2 continued in Radiometallurgy. Areas of bonding between the Zircaloy-4 and C-64 Al alloy cans have been observed in two of the target elements. This unexpected bonding was discovered in the process of trying to remove the Zircaloy-4 cans from these elements. Previously, the cans of similar target elements have been removed with no difficulty and no evidence of reaction. Photomicrographs of selected cross sections show a diffusion zone approximately 0.0005 inch wide between the Zircaloy-4 and Al alloy cans. Sections of the Zircaloy-4 cans from these regions will be analyzed for tritium to establish whether or not the bonding has resulted in enhanced tritium mobility.

DECLASSIFIED

DECLASSIFIED

A-3

HW-82428

Additional target elements are being prepared for irradiation evaluation of alternate target materials. These elements will have cores of Mg-14 wt% Li alloy, LiAlO_2 , Li_2SiO_3 , and these compounds dispersed in aluminum.

Co-producer Target Elements. Work has begun on a 45-column charge of co-producer elements for N-Reactor. Metallurgy Development Operation has the responsibility for the fabrication of the target cores. Most of the components are now on site and inspection has begun. Components have been ordered for Chemistry Research Operation to allow lithium isotopic analysis by atomic absorption using a flame spectrophotometer. Once this unit is in operation, isotopic analyses will be as easy to obtain as total lithium by flame photometry. Current scheduling calls for complete delivery of the material to N-Fuels Engineering by August 10, 1964.

Target Element Experiments. Hazards considerations give incentive to the development of target elements with increased melting points. Preliminary experiments were run to check the feasibility of making elements from lithium glass. A literature search showed that up to 18% Li_2O could be added to the ordinary soda-lime glass formula. Accordingly, some LiOH (available locally) was converted to Li_2O by heating at 800 C in inert gas, and the resulting oxide was added to pulverized soda-lime glass to the extent of about 5%. This mixture was melted in a porcelain boat at 1000 C and then slowly cooled. It was found that differential contraction had caused the glass body to crack finely. This effect points up the likelihood of similar cracking behavior during irradiation even though the technology and equipment for casting glass elements were fully developed. Thus, it appears that efforts to develop metallic or cermet targets may be more fruitful than those dealing with the development of glass elements.

A long life constant power heat source has been coextruded into stock for fuel element fabrication. The material consists of a Th - 1-1/2 wt% (fully enriched) U - 1 wt% Zr alloy fuel annulus, 0.240 inch thick, with an 0.467 inch diameter core of Zircaloy-2. The assembly has a Zircaloy-2 cladding 0.029 inch thick.

The results of six readings taken on a traveling micrometer microscope on a center section show excellent dimensional uniformity of thorium-Zircaloy-2 coextrusions.

Thorium Crud Probes. End closure brazing and thermocouple brazing have been completed on 12 thorium alloy, Zircaloy-2 clad crud probes. Radiograph tests showed complete bonding and complete braze filling

of the end closures. Three elements will not be used because of minor defects, but all elements are being autoclave tested.

Hot Heading N-Outer Fuel: Twenty-eight, 4-1/2 inch lengths of N-Reactor outer elements were hot headed for use in further welding development work on the hot headed bonded closure. The heading dies used had small 25° starting lips on the OD and ID of the dies to start the cladding across the shoulders and prevent the cladding from folding below the shoulders. After the heading a subsequent operation was performed to remove the chamfer produced by the starting lips on the heading dies. This will allow projection welding closer to the outer edge of the shoulders, thus reducing the crevice at the junction between the cap and element.

Twenty N-Reactor outer hot headed pieces, four inches long, were closed by resistance projection welding at the U.S. Army, Rocky Mountain Arsenal. No evaluation has been done as the pieces are still in transit. Fifteen pieces used the standard four-ring projection cap previously used. Five were welded with a photograph finish cap which, if successful, would reduce the cost of fabricating caps.

The external appearance of the pieces is better than any which have been done previously. Machine setting has been revised somewhat. The major change being an increase in forging pressure to 30,000 lbs. Metallographic and other examination will proceed as soon as the pieces are returned.

Corrosion of Braze Alloys: The second pass of the Forton Program, CORAN, for corrosion analysis, has been placed in operation. This pass will sort the data and write the new tape with appropriate range scales. It is possible to plot weight change vs time, normalized neutral light vs time, weight change vs composition at any given time, and various combinations of time, light, and weight change data. Three methods of plotting the data are used, namely, points, line and continuous mode. Less than three minutes per plot is required for this program, resulting in a report quality graph.

Dispersion Strengthening of Iron with UO₂: Some work has been carried out to study the effect of finely dispersed UO₂ on the tensile properties of iron at elevated temperature. The UO₂ dispersion was achieved by coprecipitation of ferric hydroxide - ammonium diuranate by addition of ammonium hydroxide to an aqueous solution of the nitrate salts. The resulting flocculant precipitate was dried, calcined in air at 700 C, then reduced with dry hydrogen at 700-900 C. The as-reduced powders were isostatically compacted

DECLASSIFIED

DECLASSIFIED

A-5

HW-82428

at 30,000 psi into right cylinders approximately 0.8" diameter x 2" long. The density increased from about 40% TD to 70-75% TD after compaction. Small billets were machined from compacted cylinders and canned in a thick mild steel jacket. The billets were induction heated to 1050-1100 C, then extruded into a rod at a 9:1 reduction ratio.

The Fe data were obtained from pure iron powder prepared the same as the coprecipitated material.

Observations and conclusions derived from tensile data are:

1. Addition of up to 2% UO_2 does not seriously reduce room temperature ductility.
2. All three materials exhibited yield point behavior in room temperature tests.
3. The room temperature strength of the pure iron powder product is comparable with literature values for ingot iron.
4. Increased room temperature strength was about 15% for the 1% UO_2 material and 35% for the 2% UO_2 material.
5. At 800 C, the strength of both the 1% and 2% UO_2 material was approximately double that of the pure iron.

Metallography of the as-extruded material at magnification up to 1500X revealed the following information:

1. The pure iron powder had rather massive inclusions that stringered during extrusion, probably resulting from incomplete reduction.
2. The 1% UO_2 and 2% UO_2 material had some massive inclusions but to a much lesser extent than the pure iron and the 2% material had less than the 1% material.
3. Increasing UO_2 content caused reduction of grain size in the iron. Average grain size of the iron in the three materials was 0.025 mm for the pure iron, 0.019 mm for the 1% UO_2 material and 0.013 mm for the 2% UO_2 material.
4. Particle size of the UO_2 is 1 to 5 microns. This is an order of magnitude larger than previously coprecipitated material produced by similar techniques.
5. Distribution of the UO_2 appears fairly uniform and no voids were observed in the iron matrix.

Normal uranium has been cold drawn from approximately 3/16" diameter rod down to 3.7-mil diameter wire. Fiber strength tests are being made on the 13 sizes ranging from 3. mils to 10.6 mils.

A similar test is being made on Zr-2 clad uranium which has been swaged and drawn down from approximately 1/2 inch in diameter to 20 mils in diameter. However, unlike the bare uranium, four stress relief anneals were made on the way down. The last anneal was at a diameter of 43 mils. The anneals were necessitated by the Zr-2 cladding and not the uranium. Excessive cold work on the cladding caused it to flake and peel.

Sixty feet of 25-mil Be-Zr wire has been drawn from a cast ingot approximately 1/2 inch in diameter. The ingot was vacuum sealed in a stainless steel (304) tube, then swaged to size at 800 C. One rejacketing operation was required before completion.

2. Corrosion and Water Quality Studies

Corrosion of Zirconium in Heated Crevices. Testing of two additional internally heated, Zircaloy-2 clad crevice corrosion samples in pH 10 ammoniated coolant was completed. A total of five samples have now been tested at heat fluxes up to 6×10^5 Btu/hr-ft², temperatures to 600 F, and exposures to 136 days. Metallographic examination of the crevices formed by the sample surfaces and the suitcase-handle supports revealed only slight corrosion (0 to 0.2-mil penetration) compared to the severe corrosion (up to 7 mils) obtained under similar conditions in lithiated coolant. No further testing of this type is scheduled for ammoniated coolants; however, additional tests have been initiated in lithiated coolant.

Testing of NH₄OH in KER Loops. Operation of the KER-1, 2 and 3 Loops at pH 10 with ammoniated coolant was continued. In general, the coolant quality was satisfactory during this period, and there were no significant changes in NH₄OH decomposition rates or dissolved gas concentrations from those reported previously.

The KSE-5 fuel elements discharged from KER-1 after exposure for one month to pH 10 ammoniated coolant at 150 C were examined visually. All eight elements had a brownish film deposited on the black ZrO₂ surface; however, four of the elements had large areas - 1/3 to 1/2 of the surface - where there was no apparent deposit. These deposits appear much darker than the usual reddish-brown films observed - possibly because the film is thinner and "shading" occurs from the black ZrO₂ film underneath.

DECLASSIFIED

DECLASSIFIED

A-7

HW-8242

The tests in the KER-2 and 3 Loops are scheduled for completion by June 30, while KER-1 will continue operation to about September 30, 1964. The next phase of testing in KER-1 will involve addition of H₂ gas to maintain a residual concentration of about 20 cm³/Kg (STP) in the coolant.

N-Reactor Steam Generator Tubing. A sample of N-Reactor steam generator tubing with a pinhole leak was discharged after five months of exposure to 300 C, pH 10 ammoniated water on the primary system side and an air atmosphere on the secondary side. Visual examination and leak rate measurements indicated the defect area did not increase in size during the test. A deposit of white solids (1/16" thick x 1/2" diameter) formed on the tube OD at the leak area. Metallographic examination of the leak area is being conducted to check for wire drawing or caustic embrittlement attack.

Examination of some tubing samples after a two-week pressure test (300 C, 3000 psi) indicated that the intergranular attack had been reactivated. Further examinations are being made to determine if this effect is typical of other tubes, and a comparison is being made with samples that have not been pressure tested.

N-Reactor Fretting Corrosion Tests. Examination of the N-Reactor process tube test section of TF-7 with a borescope revealed numerous fretting marks. The depth of these marks could not be estimated from these measurements. The marks were formed where the fuel element and tubular spacer supports contacted the tube wall. External vibration (peak-to-peak amplitude up to 3.5 mils) at the calculated natural resonance frequency of the fuel elements was applied to the test section during operation. The test section is supported at each end and vibration is applied near the mid-point. The test section had not been borescoped previously, so it is not known at what point in time these marks actually occurred. Borescoping will become an integral part of each future test.

Testing of two N-Reactor target elements in TF-7 continued during the month. No new fretting marks were observed on the fuel elements.

N-Reactor Analytical Instrumentation. Laboratory testing of an on-line process gas chromatograph similar to those installed at N-Reactor has been completed. The analyzer is capable of simultaneously monitoring H₂, O₂, and N₂ dissolved in water. Hydrogen can be detected at concentrations at least as low as 0.05 cm³/Kg (STP) of water. Reproducibility is within $\pm 10\%$ in the 0-20 cm³/Kg range. Sensitivity for dissolved O₂ and N₂ is lower. The instrument is now ready for installation in the KER Loop sampling system.

Chemonuclear Studies. Installation of the single-pass chemonuclear facility was completed, and the test program to study formation of hydrazine from ammonia was initiated. No results are available to date.

Corrosion of Copper in Ammoniated Coolant. Tests are in progress to determine the corrosion resistance of copper and copper alloys to ammoniated coolants and the vapors released from these coolants. No stress cracking of samples exposed under N-Reactor secondary system conditions has occurred during the first month of testing. Testing in vapors contacting coolant under primary system conditions is just getting under way.

Operation of Dual Purpose In-Reactor Capsule. The multipurpose capsule in K-East Reactor continues to operate satisfactorily. The exposure was 38 days as of May 18, 1964. The zirconium oxidation and hydriding experiment in the capsule is operating at 400 C (752 F) in a simulated N-Reactor pile atmosphere. The aluminum-lithium target experiment has operated at 356-380 C (673-716 F) on reactor heat and at 300 and 325 C (572 and 617 F) on electrical heat with the reactor down. The experimental lithium aluminate target is operating at 85-90 C (185-194 F); the temperature of the lithium aluminate-cermet target is not monitored, but the temperature is likely below the lithium aluminate target temperature. Following discharge at the next reactor outage, the capsule containing all the above mentioned experiments will be retrieved for post-irradiation examination in Radiometallurgy.

Corrosion of Aluminum - Rotating Disk Method. In recent tests in 300 Area water at low pH and 98-99 C (208-210 F), pitting was induced within six days at pH 3.2 and within 10 days at pH 4.0. At pH 6.8-7.0, no pitting was observed after six days at 98-99 C. Weight loss data indicate a large increase in rate (100 times) when the pH was lowered from 4.0 to 3.2. On disks exposed at low pH there is no evidence of film formation. On disks exposed in the range pH 7-9, a dark film is formed.

Pressure Bonding Autoclave. The vendor completed the performance test and the equipment was shipped on May 13, 1964. Minor Construction started construction of the underground autoclave enclosure on May 14. The structure should be completed before July 1, 1964.

3. Gas-Atmosphere Studies

Graphite-Zirconium Compatibility Loop Experiment. A second experiment in the loop has been completed under conditions similar to the

DECLASSIFIED

DECLASSIFIED

A-9

HW-82028

first (ref. HW-82001 A). Duration of the run was 387 hours and water concentration was 990 ± 100 ppm.

The rates of reaction were quite similar to those of the first test. Interior samples, 3/8 to 2-inch from the surface, had rates of about 3×10^{-7} g/g/hr. Rates of surface samples were a factor of 10 higher. The rate of oxidation decreased with distance from the surface, a trend not observed in the first test because the extent of burnoff was too low. The surface samples again had higher rates at the front of the bar.

A test is currently in progress with water vapor at 300 ppm and with an addition of 1000 ppm each of H_2 and CO .

Radiolysis of Carbon Monoxide-Water Vapor Mixtures. From experiments on the radiation-induced reaction of carbon monoxide-water vapor mixtures prepared on vacuum systems having mercury present and absent, it was concluded that mercury so introduced has no effect on the experimental results.

4. Process Tube Development

Fracture Studies. A burst test and two slot type brittle fracture tests have been performed at room temperature on specimens from KER Loop 1 after three years of exposure in-reactor. The burst test showed a gain in ultimate strength of about 15% due to irradiation. However, the brittle fracture data at slow lengths of 3/4-inch and 2 inches fell almost exactly on the curve for unirradiated material. This would indicate that irradiation has little effect on brittle fracture characteristics.

5. Thermal Hydraulic Studies

Transient Heat Transfer Experiments for N-Reactor. Laboratory experiments investigating loss-of-coolant accidents for N-Reactor fuel tubes were continued. In these tests the changes in flow, pressures, and temperatures were investigated following the simulation of a rupture of an inlet connector to a single process tube.

In the first experiment the flow-adjustment valve in the inlet connector was set for normal operation and was maintained open during a reverse-flow transient. In this experiment full power was maintained for about 25 seconds after the transient began. During this period slight temperature rises (20-60 F) in the fuel column model were observed as hot water from the outlet piping and storage tank reached the model. No increases indicative of film boiling were noted.

In the next two experiments the flow-adjustment valve was allowed to close to the normal stop position when reverse flow began. In one of these tests an automatic scram was set for 1.5 seconds after the "connector failure." In the other test the scram was delayed until the fuel model temperatures began to rise rapidly. With the automatic scram (1.5 seconds after start of transient), there was no noticeable increase in the surface temperatures of the model. With the delayed scram, temperatures at various positions began to rise two to four seconds after the valve actuation. About 5.25 seconds after the valve actuation, the scram circuit was tripped and the temperature excursions were terminated. Maximum indicated temperature increases were 500 to 600 F, up to a maximum value of about 1200 F.

Quenching of an N- Reactor Fuel Column. A quench of a long simulated fuel column (not prototypical of an N-Reactor fuel column) was performed by admitting cold water at constant pressure to a test section which was at an initial temperature of 1500 F. Heat transfer conditions during the quench were determined by measuring test section pressures, temperatures, and inlet flow. The information will be used to check the analytical procedures presently being used to obtain steam release rates in the N-Reactor when fuel elements are quenched after an inadvertent interruption of emergency cooling.

Based on test data and observations, the following results and conclusions were made.

1. About three seconds after admitting cold water to the test section, flow and pressure oscillations occurred at a 1.5- to 2-second period. Pressures ranged from about 200- to 400-psi and flows from 0- to about 30-gpm. The oscillations stopped when all liquid flow was established at about 28 seconds.
2. Test section outlet pressures showed a gradual rise to a maximum of 190 psi with negligible oscillation.
3. Test section surface temperature oscillations occurred with the pressure and flow oscillations. The amplitudes of the oscillations were generally from 100 F to 200 F and were less pronounced toward the outlet end.
4. The increase in steam velocity toward the outlet of the test section tended to increase the steam-cooling effect in the film boiling region. The transition temperature from film to nucleate boiling also decreased as the outlet was approached, indicating that "fog cooling" was probably the mode of cooling.

DECLASSIFIED

DECLASSIFIED

A-11

HW-82428

5. The period of oscillation obtained from the experiments was found to be close to the natural frequency of the system. It appeared that the driving forces from boiling, which were coupled to the flow, caused the system to oscillate at its natural frequency.
6. It seems possible that pressure and flow oscillations in N-Reactor could occur during such a quench. Contributing to this condition would be the large downstream piping volume and the oscillating supply pressure resulting from hydraulic instability between the multitude of parallel flow channels.

The results of this study were reported in HW-82177.

Hydraulic Tests for Present Production Reactors. Hydraulic tests were performed to investigate the scrams which have been experienced at KE-Reactor during startup of the reactor following process tube charging-discharging operations. Since similar incidents had previously occurred at C-Reactor, and since it was determined that some of the trips may have been caused by Panellit pressure surges with flow seating of the fuel column against the rear nozzle cap, the pressure response characteristics during flow seating of 38 KVN self-supported fuel elements in the K Zircaloy-2 tube were investigated.

The most noteworthy of the results obtained indicated that in a straight uniform tube, natural seating of the fuel column against the rear cap will occur at a flow rate of approximately 33 gpm at 18 C water temperature and 38 gpm at 110 C water temperature. The ΔP across the fuel column is approximately equal in both cases indicating that static friction and consequently tube-to-fuel contact conditions govern the flow rate required to seat a charge in a straight uniform tube. The reactor Panellit trip limits will not be exceeded under these tube and flow conditions provided the uncharged distance is less than 10 inches; over 10 inches a trip may occur. However, as demonstrated in the laboratory, if the fuel column is delayed in its movement downstream during a flow increase (either from excessive tube bends and surface roughness or from protrusions or obstructions in the tube or rear nozzle), a Panellit trip can occur at a flow rate of 38 gpm and a charging distance of two inches. Precautions which might be taken to aid in the reduction of further seating trips might include increasing the flow rate through the process tubes to seat the charges before startup, examining tubes for bends and surface roughness and checking nozzle inserts over the outlet port for proper assembly and placement.

6. Shielding Studies

N-Reactor Shield Evaluation. Reactor shield evaluation work during May has included (1) the N-2 shield plug irradiation, (2) preparation for the N-3 shield plug irradiation, (3) analysis of N-1 and N-2 shield plug data, and (4) measurement of radiation streaming through N-Reactor steam vent shield penetrations.

Thermal and epithermal flux and gamma ray dose distributions have been calculated through the N-Reactor reflector by analysis of foils irradiated during the N-1 hot physics test. A summary report is being prepared.

A measurement of neutron and gamma ray intensity and angular distribution was completed for the N-Reactor steam vent shield penetrations. Results of this study and a review of the proposed steam vent shielding are presented in detail in HW-82366.

7. Graphite Studies

N-Reactor Graphite Irradiations. Both capsules, H-4-4 and H-5-4, currently under irradiation in the long-term irradiation program for N-Reactor graphite are functioning satisfactorily. The H-4-4 capsule is in the fourth cycle in the GETR and the H-5-4 capsule is in the second cycle.

B. WEAPONS - 03 PROGRAM

Research and development in the field of plutonium metallurgy continued in support of the Hanford 234-5 Building Operations and weapons development programs of the University of California Lawrence Radiation Laboratory (Project Whitney). Details of these activities are reported separately via distribution lists appropriate to weapons development work.

DECLASSIFIED

C. REACTOR DEVELOPMENT - 04 PROGRAM

1. Plutonium Recycle Program

Fuels Development

PRTR Fuel Fabrication. Two swaged and one vibrationally compacted PRTR fuel elements were fabricated. Oil and water analyses show that the outgas cycle for PRTR fuel can be shortened from an overnight treatment to one hour at a minimum temperature of 250 C.

Gas content is now routinely measured by vacuum extraction at 1000 C, using techniques developed in cooperation with the Chemical Laboratory.

The entire PRTR fuel loading was examined in the basin. The general condition of the elements, several of which have been exposed to greater than 500 Mwd/ton, continues to be excellent. A broken circumferential band on one element was the only physical damage noted on the 85 elements. An increased incidence of local corrosion was observed on the higher exposure elements, including crevice corrosion under some of the circumferential bands.

An incrementally loaded swage compacted, UO_2 -0.5 wt% PuO_2 , PRTR fuel element (FE-5168) was discharged at an exposure of 5120 Mwd/ton after a 27-day continuous operating period with leak indications. Post-irradiation examination revealed no measurable rod swelling associated with the centrally located defect. Twenty-five psig pressurization of the failed fuel section with helium was required to produce a small bubble stream similar to that observed in the basin at discharge.

PRCF Fuel Fabrication. Twenty rods were vibrationally compacted. Finished weights of these rods were generally within the desired range, although the vibration time was long for some of the rods due to the low (97.3% TD) density in some of the starting material.

Irradiation Testing of EBWR Prototypic Fuel Rods. Twenty-six short lengths of EBWR rods containing vibrationally compacted, impacted UO_2 -1.5 wt% PuO_2 fuel are being irradiated in the MTR. Exposures range to 1.2×10^{20} fissions/cm³ (4500 Mwd/ton UO_2 or 18% of goal). Four have prototypic fission gas plenums. Six additional capsules (half with plenums) have been discharged.

Examination of one etched UO_2 -1.5 wt% PuO_2 specimen (GEH-14-519) revealed grain growth over 75% of the cross sectional area. Rod

power is estimated to have been 1150 w/cm (35 kw/ft); the Zircaloy cladding (1.07 cm OD) surface heat flux, 337 w/cm² (1,070,000 Btu/hr-ft²); and the exposure, 0.6×10^{20} fissions/cm³. Fourteen percent of the krypton plus xenon was released from specimen GEH-14-518. Rod power is estimated to have been 378 w/cm (12 kw/ft), the Zircaloy surface heat flux, 112 w/cm² (354,000 Btu/hr-ft²), and the exposure 0.4×10^{20} fissions/cm³.

Two UO₂-2.5 wt% PuO₂ capsules are being examined after irradiation to approximately 1.6×10^{20} fissions/cm³ (5600 Mwd/ton UO₂). One companion specimen, discharged earlier and containing impacted fuel, was evaluated on the basis of the recently received flux monitoring wire results. Ten percent of the krypton plus xenon was released in a companion specimen (impacted fuel) at a rod power of 508 w/cm (16 kw/ft), a Zircaloy (1.07 cm OD) surface heat flux of 151 w/cm² (478,000 Btu/hr-ft²), and during exposure to 0.38×10^{20} fissions/cm³ (1390 Mwd/ton UO₂).

Corrosion and Water Quality Studies

Corrosion of Aluminum in Boric Acid Solutions. An aluminum sample is being corroded in a 10 ppm solution of boric acid (a potential shim material). The sample has sufficient heat transfer to cause localized boiling at the argon solution interface. Weight gains over a period of 40 days do not indicate any severe corrosion; however, metallurgical sectioning will be done to evaluate localized corrosion if any.

Plutonium Oxide Dissolution. Tests (discussed last month) were conducted to measure the dissolution rate of PuO₂ powder in each of two solutions:

- (1) 0.25 M EDTA, 0.75 M NH₄OH, 0.5 M N₂H₄ at 95-100 C for one hour;
- (2) 2.3 g/l oxalic acid, 45 ml/l H₂O₂, 32 g/l sodium oxalate, 11 ml/l peracetic acid at 95-100 C for one hour;

using 50 ml aliquots of solution and about 5 mg samples of PuO₂. Visual examination indicated that both solutions successfully dissolved the PuO₂; however, analytical results indicated that less than 0.1% of the Pu added was dissolved in the solution. Since the solutions were not analyzed until four weeks after the tests were run, it is possible that some Pu precipitated or deposited from the solutions prior to analysis. The test with the first solution will be repeated and analyses will be performed immediately

to check the "aging" effect. A material balance will also be performed on the dissolved, particulate, and deposited Pu present in the reaction flask.

PRTR Coolant Quality Instrumentation. A review of the feasibility and desirability of automating PRTR coolant quality control analyses was completed. It is technically feasible to automate nearly all of these analyses using commercially available equipment; however, only a portion need to be automated. Recommendations resulting from this study were transmitted to Technical Planning Operation for review.

Reactor Components Development

Pressure Tube Monitoring. New inspection equipment was installed and operated for the first time. Of the 15 process tubes examined with this equipment, five were approaching the minimum allowable gas gap between the pressure and aluminum shroud tube. In general, equipment operation was good. Two safety limit switches must be relocated and the clearance between the radiation shield plug and the access opening in the inner rotating shield should be increased for easier and speedier operation.

PRTR Pressure Tubes. Remote nondestructive examination of flaws on the inside of PRTR Zircaloy-2 pressure tube number 5690 was performed with the tube in a vertical position, but under water, in the PRTR storage basin. Position control of the eddy current sensor on the end of a long pole was coarse because it was done by hand. A flaw, 7 feet, 11 inches from the flange, was the largest found in the tube. The eddy current data indicate that it is less than 5/8 inch long, less than 1/4 inch wide, and may be as deep as 0.040 inch. Also, there may be a surface crack in the area. These data tend to confirm suspicions that this flaw is like a blister.

Second Generation Mechanical Shim Rod for PRTR. The second generation shim control assembly has operated continuously during the month with no evidence of mechanical faults. Tests will be continued until the end of the fiscal year at which time the rod will be set aside for eventual acquisition by PRTR Operations.

Fretting Corrosion Investigation. The PRTR in-reactor vibration monitor of inlet jumpers 1354 and 1653 continued until May 2, at which time the reactor was shut down for an extended outage. The indicated vibration readings were generally constant throughout the preceding 23-day operating period. Several instances were noted in which the amplitudes associated with both channels changed abruptly and simultaneously. The first variation was observed as a 5% decrease

from the original 4.0-mil amplitude noted on 1653. The second variation was observed as a further decrease of the same magnitude. The third variation was an increase to approximately the original level and the fourth variation was a 50% decrease to about 2 mils peak-to-peak. Cause of these step changes has been investigated thoroughly but has not been satisfactorily explained.

Specifications and a test procedure were established in cooperation with the designer to isolate the developmental problems associated with the instrumented fuel element. It appears that the coils and lead wire are apparently causing observed inconsistencies.

Fuel Re-use. Developmental plans and drawings of the liquid sodium facility are 85% complete. Design of the sodium loop proper is essentially complete. Drawings are being completed for the loop enclosure, fuel removal station, and cleanup containers.

Design Analysis

Nuclear Safety of Mixed PuO₂-UO₂ Fuels. Previous calculations of delayed Doppler effect in mixed oxide fuels have been extended to include fuel enrichments typical of fast oxide breeders. Results indicate time constants for transfer of heat from PuO₂ to the bulk fuel which are less than 100 microseconds for a uniform dispersion of 20 micron PuO₂ particles. For time constants equal to the prompt period, the effectiveness of Doppler feedback was found to be greater than 90%. It thus appears that Doppler safety in mechanically mixed oxide fuels can be attained for a wide range of reactor types.

2. Plutonium Ceramic Fuels Research

Irradiation of UN-20 wt% PuN Capsules. The first of three UN-20 wt% PuN irradiation test specimens was returned from the MTR to Hanford for radiometallurgical examination. This capsule was irradiated at a flux of 1.5×10^{14} n_v (thermal) for three MTR cycles. Surface heat flux was 235 watts/cm² (745,000 Btu/hr-ft²), and the calculated exposure on the fuel is 2.54×10^{20} fissions/cm³ (9410 Mwd/ton). Two other capsules are being exposed under identical reactor conditions for six and 16 cycles.

PuN-PuO_{2-x} Phase Relationships. X-ray diffraction analyses show that PuO_{2-x} present as an impurity phase (10 vol%) in PuN does not appear to react with the PuN at 1500 C in nitrogen.

PuN-C Compatibility Studies. No reactions between PuN and graphite were detected visually or by x-ray diffraction after heating a PuN pellet in a graphite holder for one hour at 1725 C in nitrogen.

PuN-ZrN Phase Studies. A PuN-50 vol% ZrN pellet (mixed powders) was held at 2000 C in a vacuum for 5-1/2 hours. The PuN volatilized prior to any detectable reaction with the ZrN.

ThN Synthesis. ThN was prepared by arc melting thorium metal under one atmosphere of nitrogen. Metallographic examinations are being carried out to determine whether or not free thorium exists at the ThN grain boundaries.

PuS-W Cermet. A reaction between plutonium hydride and tungsten sulfide proceeds at 1200 C under vacuum to form Pu_2S_3 and W. Other phases were also present as impurities. The desired product is a PuS-W cermet.

3. Ceramic (Uranium) Fuels Research

Fission Product Concentration in Metallic Inclusions. Preliminary radiochemical data from HCl leaching of irradiated UO_2 fuel show significantly high concentrations of Cs-137 and Sr-90 in the uranium inclusions. The Cs-137 and Sr-90 concentrations in the leach solution were 1000 and 10 times greater, respectively, than the average concentrations in UO_2 .

Pneumatic Impaction of UO_2 Uranium dioxide powders prepared by a variety of processes are being tested for compactibility by high-energy-rate pneumatic impaction. Uranium dioxide prepared from UF_6 by a production process at GE-APED was impacted to 93% TD at 1180 C and 132,000 psi impact pressure (approximately 1/2 the pressure routinely attainable with tool steel dies). This density is comparable to that obtained under similar conditions using other types of UO_2 which were compactible to 99% TD at higher pressures.

Depleted UO_2 prepared from metallic uranium will be blended with PuO_2 and pneumatically impacted for use as fuel for a portion of the EBWR fuel loading. Recent impaction experiments have not yet defined the conditions necessary for impaction of this type of UO_2 to the desired density of 10.80 g/cc. Maximum density obtained was 10.56 g/cc (96.3% TD). Ballmilling the UO_2 before impaction did not result in higher impacted density. Additional experiments are in preparation to determine the effect of variations in the O/U ratio of the powder on the impacted density.

Image Intensifier for Electron Microscopy. Initial tests of the Image Orthicon image intensifier system with the electron microscope were encouraging. Considerably higher image brightness was attainable on the monitor screen than was apparent on the microscope screen, although background noise made image focusing difficult under minimum illumination conditions.

Thoria Irradiation Studies. Centerline fuel temperature in an irradiated thoria element reached 1080 C at the end of two MTR cycles. Approval was obtained to complete the third cycle of irradiation after failure of the thermocouple during reactor startup.

Fuel Preparation Studies. Autoradiographic studies of impacted, ball milled UO_2 -20 wt% PuO_2 powders show a remarkably uniform plutonium alpha track distribution. The starting material was -325 mesh UO_2 and PuO_2 powders which were dry ball milled for 65 hours to obtain the desired homogeneity.

UO_2 -Niobium Cermet Irradiation. A niobium clad, UO_2 -30 vol% Nb cermet was irradiated to 0.34×10^{20} fissions/cc (1170 Mwd/t_{fuel}) at 905 w/cm (900,000 Btu/hr-ft² on clad surface rod power. Maximum center temperature was approximately 1350 C. Post-irradiation examination revealed sintering only in the center of the 0.950 cm (0.375 inch) diameter impacted fuel pellets. Niobium significantly increased the thermal conductivity of the fuel even though the metal appeared to be the dispersed phase.

An improved capsule comprising three stacked plates in a non-gold-plated sheath was designed and is being fabricated. The capsule will be instrumented so that plate temperatures to 2800 C can be accurately measured. This capsule will allow the central plate to remain at a constant, high (~ 2800 C) temperature during short term (~ 4-hour) irradiations in a static hydrogen atmosphere.

4. Basic Swelling Studies

Irradiation Program

A general swelling capsule controlled at 700 C (1292 F), containing high purity uranium specimens of varying specimen geometry, reached its goal exposure and was discharged. A capsule controlled at 400 C (752 F) was charged.

The prototype high pressure irradiation capsule has been completely assembled and is currently undergoing ex-reactor tests to establish the functional and operational characteristics of the design.

Post-Irradiation Examination

Optical and electron metallography is complete on specimens of U + 400 Fe + 640 Al and U + 140 Fe + 95 Si which were irradiated to 0.11 at% B.U. at 535 C (995 F). In this capsule the Fe-Al alloy specimens were vastly superior in swelling resistance to the Fe-Si alloy specimens. For both alloys those samples which had received a gamma anneal behaved somewhat superior to those which received the normal beta heat treatment.

Metallography is complete on the as-extruded high purity U specimen irradiated to 0.11 at% B.U. at 575 C (1067 F). Extreme porosity was noted commensurate with the large density decrease which was observed.

5. Irradiation Damage to Reactor Metals

Alloy Selection

Corrosion and oxidation tests of 10 nickel base alloys are continuing as part of a program to evaluate the applicability of these alloys as nuclear structural materials. Oxidation tests were completed by the Chemical Metallurgy personnel on specimens exposed for 100, 200, and 300 hours to 15 mm Hg water vapor in helium at 1500 F (816 C). This completes the series of tests for these alloys. The test data will be compared to similar data for specimens run at 1700 F (927 C) and 1900 F (1038 C).

In-Reactor Measurement of Mechanical Properties

An in-reactor creep capsule containing annealed 304 stainless steel was charged in the reactor. When steady state reactor operation is attained, an in-reactor creep test at 30,000 psi stress and 500 C (932 F) will be started.

Annealed 304 stainless steel currently being tested in-reactor at 20,000 psi and 500 C is creeping so slowly that creep rate at this time cannot be determined. No increase in rate has been observed during the short periods of reactor outage.

Irradiation Effects in Structural Materials

Several tensile specimens of nickel base alloys irradiated at about 580 C (1076 F) and 740 C (1364 F) to an exposure of 5×10^{19} nvt (E > 1 Mev) were tested at room temperature. Initial results of these data for Inconel 625 show a substantial loss in strength and ductility at the higher irradiation temperatures.

Tensile tests were performed on specimens irradiated at 50 C (122 F), 290 C (554 F), and 750 C (1382 F). Room temperature tests were conducted on specimens irradiated at each temperature. Tests were conducted at 300 C (570 F) on stainless steel specimens irradiated in the G-7 hot water loop and on unirradiated specimens exposed in the out-of-reactor loop as well as specimens in the as-fabricated condition. Changes in the mechanical properties of AISI 348 stainless steel amount to only a 2 or 3% increase in strength, but the total elongation is decreased in some cases by as much as 10 to 15%. Room temperature tests on AISI 348 and 406 stainless steel specimens irradiated at 750 C (1382 F) show that prior cold work effects are completely removed.

A low cycle fatigue test was conducted on an age-hardened nickel alloy specimen to test stability of specimen geometry and overall performance of the mechanical fatigue system. Except for two minor modifications, the basic alignment system functioned as anticipated. Stress amplitude is measured by means of the Instron load weighing circuitry. Plastic strain amplitude is measured with a unique diametral extensometer. Extensometer readout capability is 2 microinches of diameter change. The hourglass-shaped test specimen proved to be dimensionally stable within the range of strains anticipated for proposed low cycle fatigue studies on reactor structural materials.

Environmental Effects

The predominant thickness of fragments of oxide adhering to a small sample of Zr-2 taken from a "basket" tube exposed in the ETR M-3 position for 80 days at 260 C (500 F) and a maximum fast flux of 1.5×10^{13} was estimated at 0.07 mil or 29 mg/dm², about four times greater than might normally be expected out-of-reactor. Corrosion, flux intensity, and water temperature are lower than for G-7 loop exposure.

Examination of Zr-2 process tube, fuel element jacket, and element support material exposed in the KERR facility indicates from zero to a several-fold increase in corrosion rates under in-reactor conditions.

Hydrogen Addition to ETR G-7 Loop Coolant

Fabrication of a special G-7 loop irradiated test rack was completed for use during the coming series of tests designed to probe the effect of hydrogen injection and lowered oxygen concentration in loop water on the behavior of materials. The design of a special

hydrogen injection and samples system was completed and forwarded to Idaho Falls for approval prior to fabrication.

ATR Gas Loop Studies

High Temperature Piping. Dye penetrant inspection of the welded pipe for the model loop showed one section of Haynes-25 pipe with numerous pits in the weld on the inner surface, and a crack 1/2 inch long in the weld at one end. A spare length of seamless pipe, which showed no indications on a similar test, will be used in the loop. Because of the questionable integrity of the weld, the seamless section of pipe was installed in the model loop. The remaining sections of pipe had a few minor pits that were considered acceptable.

Welded test specimens of Haynes-25, Hastelloy-X, 316 SS, and 347 SS welded in various combinations were thermal cycled. The test specimens of Hastelloy-X and Haynes-25 were thermal cycled 20 times between room temperature and 2000 F (1093 C). Samples that included any of the stainless steels were cycled only to 1400 F. Examination of the photomicrographs from these samples showed very little effect of the thermal treatment. There was noted a slight increase in the amount of precipitation, but no microcracks were seen in either the weld metal or the heat affected zone.

Alloy Selection. To determine the effects of 500 F (260 C) air upon the mechanical properties of refractory metal alloys, tensile specimens and oxidation coupons of TZM, Cb, Ta, Ta-10W, and C6-1Zr were exposed to atmospheric and dry air for 14 days. No significant differences in oxidation rates were found based upon weight gain measurements. Tensile tests have been completed and indicate that for certain alloys significant differences occur in the strength properties of the materials. These differences occur primarily in the tantalum material where higher yield strengths and lower percent uniform elongation values were recorded for the specimens exposed to atmospheric "wet" air. The properties of the other materials were not significantly different for the two cases tested. Some evidence of the thermal treatment was seen when the properties were compared to those in the as-received condition.

Mechanical Properties of Haynes Alloy 25. The design of the ATR and model helium high temperature loops has created a need for Haynes Alloy 25 stress rupture data at temperatures between 1800 F (982 C) and 2200 F (1205 C) and exposure times of 10,000 hours. Data of this type are expensive to obtain and, more importantly, it

requires more time than is presently available. Extensive investigations into methods of extrapolating the available experimental data to the desired conditions have shown a modified Dorn type correlation yields good results.

Environmental Effects. Specimens of both fully annealed and stress relieved molybdenum sheet made from arc cast material and of both fully annealed and as-received TZM alloy (Mo-0.08 wt% Zr-0.5 wt% Ti) sheet were oxidized at 5×10^{-4} mm Hg pressure of air at 1000 C (1832 F). At the end of 8850 minutes (6 days, 3.5 hrs), corrosion results for the metals in the order listed above were 0.009, 0.011, 0.025, and 0.61 mil, as calculated from weight gain and sample area.

These experiments have been extended for an additional week and are still in progress. Although there is a considerable difference in the results obtained for the four samples, they all show a very low rate of metal attack compared with 0.59 mil penetration for stress relieved and fully annealed molybdenum in 6256 minutes at 5×10^{-3} mm Hg pressure of air at 1000 C, previously reported.

6. Gas-Cooled Reactor Studies

EGCR Graphite Irradiation. The eighth capsule, H-3-8, in the series of long-term irradiations of EGCR graphite continues to operate satisfactorily in the second GETR cycle.

Effect of Sample Size on Graphite Contraction. It has been found that the rate of radiation-induced contraction is higher in large samples of graphite than in small samples. To obtain more information on this poorly understood phenomenon, samples of CSF, CSGBF, TSGBF, and TSX graphites were recently charged into the 3A test hole in KE-Reactor. Two bars of each type were cut into various sized cylinders, quarter-rounds, slabs, and blocks having both perpendicular and parallel orientations relative to the extrusion axis. The smaller samples were mounted in compartments cut in graphite sample carriers.

The samples were annealed and then measured before irradiation. There were approximately 1238 points of measurement in this experiment. After an exposure of approximately 1500 Mwd/At at 650 C, the samples will be remeasured and then recharged into the reactor.

Isotropic-Graphite Irradiations. The radiation-induced length changes of samples of isotropic graphites are being measured in order to evaluate these materials for various nuclear applications. Several variations of Speer Carbon Company's Grade 901 isotropic

graphite were recently discharged after an exposure of 1.13×10^{21} nvt, $E > 0.18$ Mev (9420 Mwd/At_k) at 600 C. CSF nuclear graphite samples were included for comparison.

The contraction behavior of the isotropic graphites compares favorably with that of CSF graphite. In no instances are the parallel contractions of isotropic graphites as great as the parallel CSF graphite contraction. In the perpendicular directions, contraction of isotropic graphites is, in most instances, significantly less than the corresponding contraction of CSF graphite.

7. Graphite Radiation Damage Studies

Thermal Expansion of Molded Graphite. A considerable variation in the radiation-induced dimensional changes in molded graphites graphitized at different temperatures in the 1370 to 2700 C range has been observed. To help understand these differences, the thermal expansion coefficients have been measured over the temperature range of 25 to 1200 C. Analysis of the data in terms of Simmon's¹ and Sutton and Howard's² equations disclosed that there was no significant difference in the accommodation factors between the two models because of the small crystallite a-spacing changes. Using Simmon's model the constants associated with the a-spacing terms were factors into accommodation and orientation factors.

The accommodation factors calculated for the ranges of 25-120, 120-315, 405-660, 660-890, and 890-1110 C were much higher (about 0.6) for the graphite made at the lowest temperature of 1370 C than for the other graphites (0.45) but were relatively constant for graphitizations above 1800 C.

It has been suggested² that the differences in this factor are due to microcracks that develop between layer planes during cooling from the graphitization temperature. If so, the accommodation factor of the 1800 C sample should approach that of the 1370 C sample at 1800 C because the pores should be closing; yet the results give no indication that this will occur. Furthermore, the theory predicts a decrease in the accommodation factor with higher graphitization temperatures which is not evident in these tests. It is more probable, perhaps, that pores are formed during the

¹J. H. W. Simmons, AERE-R3883 (1961).

²A. L. Sutton, V. C. Howard, J Nucl Materials, 7 (1962) 58.

graphitization process between 1370 C and 1800 C, because of the release of gases during the process and the development of more perfect crystallites as graphitization progresses. Micro-cracks are observed to form during cooling from the graphitization temperature, however, and could account for some of the observed rapid increase in accommodation factors with temperatures at the lower temperatures (< 800 C).

Effect of Impregnation on High Temperature Contraction of Graphite. The fifth irradiation of TSX and HLM-85 graphites to which, respectively, 5 and 4% impregnant carbon had been added as furfuryl alcohol were completed in a continuing study aimed at determining the effect of impregnation on dimensional stability. The irradiation temperature is about 1000 C and the total exposure to date is estimated at 3.5 to 5×10^{21} nvt, $E > 0.18$ Mev. Although the control TSX sample continued to contract slightly during the last irradiation interval (net contraction, 0.61%), the impregnated samples heat treated to 900 and 2650 C, respectively, expanded. The sample heat treated at 2900 C showed no change.

Contraction in the direction parallel to the extrusion axis continues at a rate from 15 to 30% greater than for the controls and now ranges from 1.0 to 2.3% total contraction. An exception is the material heat treated to 900 C which behaves similarly to the unimpregnated control material. Although many processes are probably occurring, the results suggest that the carbon from the impregnant is contracting at a much faster rate than the base graphite and is materially affecting the reaction of the base graphite toward radiation.

Irradiation of Pyrolytic Graphite. A maximum exposure of 9.1×10^{20} nvt, $E > 0.18$ Mev (7520 Mwd/At_k) at 600 C has been accumulated after a second irradiation of pyrolytic-graphite specimens which were deposited at 2200 C. These samples had previously been irradiated to 1.6×10^{20} nvt (1330 Mwd/At). A total expansion of 1.51% was noted in the c direction and a contraction of 0.55 and 0.60% in the a directions. These changes follow the trends reported earlier. The results will be published in Nuclear Science and Engineering.

8. Boronated-Graphite Studies

2-C Irradiation Tests. The second capsule (2C-2) of the long-term irradiation continues to function satisfactorily, with only a slight difference in the temperatures of two high temperature sections. The difference is possibly due to burnout of boron in

the previously irradiated samples of one section. A pressure increase due to the generation of free helium in the capsule from the (n, α) reaction has been noted, amounting to a 13% increase in gas content of the capsule.

An irradiation experiment at 230 C (450 F) containing 14 samples was successfully concluded at an exposure of 10^{19} nvt E > 0.18 Mev. Another experiment for a goal exposure of 10^{19} nvt at 120 C is in progress.

Chemical analyses of the samples exposed in the first irradiation (2C-1) show quite uniform lithium formation rates which are consistent with results of a previous, shorter irradiation. The lithium content of the samples ranged from 0.35 to 0.40%.

Mechanical property tests have been completed for unirradiated samples of boronated graphite and also for the samples irradiated in the 2C-1 experiment. Values of maximum compressive strength, strain energy to failure, and strain to failure were calculated from the test data.

Comparison before and after irradiation shows that the maximum compressive strength for a particular orientation and boron concentration is increased by 2000 to 2500 psi by irradiation to 1×10^{20} nvt. At the same time the total strain to failure decreases to about 75% of the original value. No change in strain energy to failure and no effect of temperature in the 370-482 C range was observed.

Thermal Conductivity of Boronated Graphite. The thermal conductivity was measured on 16 wafers cut from the 2C-1 test samples. The results are summarized as follows:

1. Measured thermal conductivities for unirradiated transverse samples ranged from 0.129 cal/sec-cm- $^{\circ}$ C for 7 wt% "grey" to 0.205 for 5 wt% "black". Corresponding irradiated samples ranged from 0.022 to 0.028. Parallel control samples ranged from 0.137 to 0.287, respectively, irradiated, from 0.023 to 0.043.
2. The ratio of the longitudinal to transverse thermal conductivities for all "black" material both before and after irradiation to about 10^{20} nvt, E > 0.18 Mev, was about 1.5; for the "grey", 1.1.
3. An increase in boron content from nominally 5 to 7 wt% results in a decrease in thermal conductivity of about

one-third for both "black" and "grey" unirradiated material. After irradiation the decrease is only about 15% for the same materials.

4. Irradiation to this exposure results in a reduction of thermal conductivity in all cases by a factor of six to eight. No difference in behavior is seen between the "black" and "grey" materials; however, a slightly smaller change may be associated with higher boron content.
5. In the range 25 to 430 C a slight positive temperature dependence of thermal conductivity was found for irradiated boronated graphites in contrast to the unirradiated material which showed a slight negative dependence.

ETR Irradiation Tests. A group of seven capsules, containing 20 Fermi-reactor boronated graphite samples, was charged into the ETR core during the cycle 63 shutdown in April. Two samples in one of the capsules contained thermocouples to calibrate the sample temperature range during exposure. All seven capsules were positioned in similar flux environments, having advertised fluxes ranging from approximately 2.2 to 3.2×10^{14} nv (E > 0.18 Mev). The goal exposure is 10^{21} nvt (E > 0.18 Mev).

The radiation damage data in the relatively hard ETR neutron flux will be used to augment other data obtained in softer spectra, as well as provide initial information on gross graphite damage at design exposures for the Fermi reactor.

9. Metallic Fuel Development

Irradiation of Thorium-Uranium Fuel Elements. The irradiation of three tubular Zircaloy-2 clad thorium - 2.5 wt% uranium - 1.0 wt% zirconium fuel elements continued in the ETR-P7 loop. The fuel elements are currently operating at a maximum temperature of 520 C, a surface heat flux of 62 cal/sec-cm² (8.3×10^5 Btu/hr-ft²), and a specific power of 57 watts/gm (174 kw/ft). The integrated exposure is 2.4×10^{20} fissions/cm³ (7100 Mwd/ton). At an exposure of 6200 Mwd/ton the fuel had undergone a volume increase of 0.8%.

Irradiation Testing of Metallic Uranium with Submicron Uranium Carbide Dispersions. The irradiation performance of fuel rods produced from chill-cast uranium shot is being evaluated in the ETR. Of the three irradiation test capsules, two contain fuel rods identical in uranium composition, but with one having a uranium

carbide size of 2-5 microns produced from arc-melted uranium and the other a uranium carbide particle size of less than 0.5 micron produced from the uranium shot. The third capsule contains two fuel rods with the fine carbide.

One capsule has achieved goal exposure of 0.3 at% burnup in the ETR at a maximum fuel operating temperature of 550 C. The other two capsules are scheduled for charging during the next ETR shut-down and will be located in a higher flux region in order to attain a maximum fuel temperature of 600-625 C.

Dispersed Phase Thorium Alloys. Thorium base alloys with 2.5 or 5.0 wt% U and 2 or 5 wt% Zr containing aluminum or beryllium additions (500 to 2000 ppm) in the form of arc melted buttons were machined to fit the 1-1/4 inch diameter and 3/8 inch high cavity of a stainless steel compact and were sealed by electron beam welding. The compacts were heated to 775 C and hammer forged to approximately 2/3 reduction in height. Further rolling was done from 750 C preheat for a 70% reduction. Thirty-two buttons representing all alloy compositions were satisfactorily fabricated in this manner. Samples are being prepared from this sheet for heat treatment and structure studies.

10. Aluminum Corrosion and Alloy Development

The aluminum-clad fuel elements discharged from C-1 Loop after 25 days exposure at 260 C outlet temperature and neutral pH (see previous report) were weighed and measured with the corrosion product film intact. The calculated corrosion rate increased uniformly with position (3 mils/mc upstream to 14 mils/mc downstream) in the process tube. The corrosion rates of the A-288 and KYZ alloys were only slightly less than for X-8001. These elements will be cleaned and re-examined.

Fuel charge C-1-4 has accumulated 18 days of exposure at 260 C outlet temperature and pH 4.5 (H_3PO_4). Operating conditions have been nonstandard during much of this period due to reactor scrams and problems with the makeup water purification system. The loop was dumped to process water on two occasions. This fuel charge is scheduled for discharge at the end of June 1964.

11. USAEC-AECL Cooperative Program on Development of Heavy Water Moderated Power Reactors

Boiling Burnout Experiments with 19-Rod Bundles. Heat transfer experiments were completed to compare boiling burnout data for horizontal and vertical positioning of 19-rod fuel bundles. A total of

15 burnout points were obtained in this report period for vertical positioning of the test section.

The test section used was made up of 12 rods of Inconel tubes, 6.3 feet long. A spacing of 0.5 inches was maintained between rods with a wire wound on the outer surface around 12 of the rods. The test section was installed in a 3.25-inch pressure tube and operated at 1000 psig.

Analysis of the data has not been completed, however, the nominal values of the boiling burnout coefficients show little, if any, difference between the boiling burnout heat fluxes obtained in either the vertical or horizontal positions except at a flow rate of 500,000 lb/hr-ft² where vertical operation increases the burnout heat flux by as much as 10%.

During these experiments special tests were made to determine if the ac ripple from the output of the milliammeter caused temperature measurement errors due to induction heating in the copper plugs in which the thermocouples were embedded. To check on this possibility, four runs in the current series of tests were duplicated using the motor generator power source which had no ac ripple. A preliminary analysis of the rod temperatures obtained with the two power sources indicated only a small temperature error exists with the rectifier power source.

12. Advanced Reactor Concepts

Segmented Fast Reactor (SFR): Criticality and power distribution calculations for the two SFR cores selected for detailed analysis are being carried out. Multigroup calculations have been completed for core III and input data prepared for core IV. Work on the reactor building and plant was continued.

13. Critical Flow at High Pressures and Temperatures

Equipment preparation was completed to investigate the critical flow of steam-water mixtures from pipes with fittings such as tees and elbows at the end. This flow configuration is important since in many cases the bending moments on the pipes maximize at such fittings, and there is an increased possibility of a rupture occurring due to the much higher stresses at these points. Although much theoretical and experimental information is available regarding the critical flow of two-phase mixtures from uniform flow passages, it is questionable whether any of this information is applicable to the case where the flow passage has a fitting

at the discharge end. The flow pattern at the discharge of the flow passage has been shown to be an important variable in the critical flow process. Since the fluid turbulence induced by the fitting and centrifugal forces caused by the change of flow direction can disturb these flow patterns, it is not reasonable to expect that a correlation developed for a straight flow passage will apply to a pipe with a fitting at the end. This apparatus was arranged to investigate the effects of simple pipe fittings such as weld tees and elbow on the critical flow process of low enthalpy (<450 Btu/lb) steam-water mixtures. The first test section in place is a 12-inch length of 1/2-inch schedule 40 pipe with a welding elbow at the discharge end. The pressure distribution along the test section is determined by numerous static pressure taps distributed along the length. The critical pressure will be determined by the "rise of back-pressure" method developed in the work reported in HW-56946. This critical pressure will be used to determine the applicability of existing theoretical methods to the prediction of critical flow rates from fittings. An attempt will be made to develop a data correlation based upon some pressure upstream of the fitting.

D. DIVISION OF RESEARCH - 05 PROGRAM

1. Radiation Effects on Metals

This program is directed toward establishing the combined effect of impurities and neutron irradiation on the properties and structure of specific metals, and deducing from thermally activated recovery processes how the damage state can be altered. Present studies involve single and polycrystalline specimens of molybdenum, nickel, and rhenium.

Single crystals of molybdenum which were deformed after irradiation have been sectioned in certain crystallographic directions and thinned for electron microscopy. Analyses of the process of deformation in these specimens containing defects formed by the irradiation are in progress. A replication technique has been developed and applied to the study of slip traces on irradiated molybdenum bend specimens.

Lattice parameters of irradiated single crystals of molybdenum containing 15 ppm and 450 ppm carbon as intentional impurity have been determined.

A paper entitled "Quench Hardening in Polycrystalline Nickel" is being prepared for publication. Briefly, the results show that a high supersaturation of vacancies may be retained in nickel by

quenching, and these vacancies form large aggregates upon annealing. The work on quenched nickel has been extended to include a study of the temperature and strain rate dependence of the flow stress.

The lattice parameter of high purity rhenium foils, which were annealed in preparation for irradiation experiments, have been determined by a special technique which utilizes a single crystal orienter. The foils being studied do not lend themselves to line breadth measurements.

2. Plutonium Physical Metallurgy

The objective of this program is to determine some of the basic physical metallurgical properties of high purity plutonium and to establish the effect of certain specific alloying additions on those properties.

The investigation of the steady state creep characteristics of the six allotropes of high purity plutonium is essentially complete. A few very long time tests and further study of certain anomalies are still in progress. The most notable of the anomalies is the significantly higher creep rate of the beta phase after $\alpha \rightarrow \beta$ transformation than after $\alpha \rightarrow \beta \rightarrow \gamma \rightarrow \beta$ transformations.

The nitric acid-methanol alternating current etching technique developed at LASL has been utilized for bright field etching of alpha plutonium. This technique reveals the grain boundaries quite well and shows promise as a means for producing a surface which can be replicated for electron microscopy.

X-ray diffraction studies indicate that a randomly oriented, fine-grained alpha plutonium structure can only be produced by quenching from the epsilon phase, about 600 C (1112 F). A specimen so quenched has provided the necessary absorption data to permit corrections to be applied to the pole figure goniometer data. The study of texturing in plutonium can now proceed. The goniometer is also being employed in the further investigation of the columnar grained structure developed by the transformation of beta to alpha under slight pressures. The previously reported alignment of the 020 plane perpendicular to the direction of applied stress has been confirmed.

E. CUSTOMER WORK

1. Radiometallurgy Laboratory

The results of routine examinations and measurements are, or will be, reported as part of the sponsoring research and development programs. During the period April 29 to May 27, 1964, Radiometallurgy Laboratory output included:

Metallography samples processed	70
Photomosaics	16
Autoradiographs	37
Replicas (for electron microscopy)	37
Burnup dissolutions	19
Fission gas sample collections	12
Vacuum induction furnace runs	31
Decladding dissolutions	24
Tensile tests	17
Rockwell hardness tests	16
Density determinations	28
X-ray analyses	6
Negatives processed	589

X-ray analyses were completed and data reported on three samples of $\text{UO}_2\text{-ThO}_2$ and one sample of $\text{PuO}_2\text{-ThO}_2$ from General Electric Company - VAL, Pleasanton, California (APED P.O. 205-78394-G). This work was completed in approximately one-half the estimated time for slightly more than one-half the estimated cost.

A \$150,000 project (CAH-136) was approved to provide additional office and locker room space at 327 Building. This project will consolidate and relocate offices from process space, thereby freeing such space for process work.

Methods

Cathodic Etching. A simplified cathodic etching bell jar was designed and fabricated at one-third the cost of previous models. A new anode made from an 80% tungsten, 20% silver alloy was fabricated and is being tested. Taller etcher chimneys have proven effective in eliminating metal deposition on the etcher bell jar. Both of these changes have been made in an effort to reduce re-deposition of material on the specimen cathodic etching operations.

Radioactive Waste Handling. An engineering study is being prepared to determine the economics and technical feasibility of various methods for the removal and disposal of solid radioactive wastes.

Equipment

Annealing Furnace. The annealing furnace was received from the vendor after repair and modification. Mockup of the furnace is in progress and testing of the control and recording equipment with a vendor representative is planned this month.

High Temperature Tensile Testing Machine. Cold tests were run on the new high temperature tensile testing machine, and results showed that the open front grips caused bending of the sample during testing. To eliminate the problem, a new type grip was designed and is being fabricated. This new grip is expected to eliminate bending and also be much more adaptable to a wide variety of sample shapes. A 440/220 volt transformer was ordered to furnish power for operation of the furnace.

Remote Belt Sander. Fabrication of the belt sander sample holding device was completed and tests of the holder and coolant dispensing system were successful.

"E" Cell Metallographic Facilities. The modified research metallograph was received and installation of remote controls is in progress. Fabrication of the X-Y metallograph manipulator was completed.

Strain Gage Spot Welding Equipment. A cost estimate was prepared for equipment to spot weld strain gages on tubes to monitor strain during hydrostatic burst testing. The lathe in "F" cell will be used to hold the tubes and position the welding electrode.

2. Metallography Laboratories

Routine Metallography Laboratories activities will be reported as part of the sponsoring research and development component's work; however, items of unusual interest or representing departures from routine operations will be reported here.

During the report month 465 samples were processed, a total of 978 macrographs and micrographs taken, 1774 negatives printed, and 5861 prints processed.

Prior to installation of the new vacuum cathodic etcher, numerous attempts to cathodically etch and interpret the results of such samples as uranium with additions of iron and silicon or iron and aluminum were only partially successful. This month some of these same samples were again polished and cathodically etched with resultant success never achieved previously. This success can only

DECLASSIFIED

A-33

HW-82428

be attributed to new design features and refinements incorporated into the new etcher.

3. High Temperature Lattice Test Reactor

The 1/2-inch OD heating element was removed from the small mockup. Corrosion of the graphite heating element and surrounding core block was evident at selected locations. The sliding collet and tapered split-ring connections were in excellent condition after more than 1100 hours at temperatures of approximately 1000 C.

Brick installation of the large mockup is approximately 60% complete.

Fabrication of actuator assemblies for the horizontal and vertical rods was completed.

4. EBWR Fuel Elements

EBWR Fuel Fabrication. Two hundred and sixty EBWR fuel rods were transferred on schedule to Experimental Reactor Operations for approach-to-critical tests. These, plus the 550 from the PRCF, will exceed the 800 required for the next two lattice spacings of the approach-to-critical series of tests. Efficiency of the overall fuel fabrication process has continued to improve.

Bids were received for a new lot of EBWR fuel rod cladding tubing from a different vendor. Delivery is scheduled in 8-10 weeks. Bids were also received for additional PRTR fuel rod swageable tubing.

5. NASA Fuel Development

NASA Cermet Work. A UO_2 -80 wt% W cermet fuel plate was successfully irradiated in a static hydrogen atmosphere at a surface temperature greater than 2650 C. A 1" x 1" x 0.035" plate was suspended in an internally gold-plated stainless steel capsule that initially contained purified hydrogen at ~17 psia (cold). One hour irradiation of the capsule in a Hanford production reactor "snout" facility caused melting of niobium and molybdenum wires attached to the plate. Tantalum wires remained unchanged. It is unlikely that the >2650 C surface temperatures were maintained throughout the irradiation period. Tungsten that gradually vaporized from the surface of the plate condensed on and blackened the highly polished gold surface so that heat loss rates were increased.

A second, similar capsule (also irradiated with a static hydrogen atmosphere) contained a fuel plate suspended inside two nested tungsten boxes which acted as thermal radiation shields. The inner

surface of the stainless steel capsule was polished but not gold-plated so that the plate reached approximately 2400 C (near the melting point of niobium). Again, tungsten was deposited in the inner surface of the capsules but probably did not seriously affect the plate temperature.

In a third capsule, identical to the first, the plate was jarred from its mounting during pre-irradiation handling so that it was in contact with the capsule wall during the irradiation. This caused no adverse effect except that the plate operated at a much lower temperature than the other two.

Uranium dioxide-tungsten cermets prepared for NASA by 3M Company showed wide differences in fuel loss on cycling at NASA. Electron microscopy has revealed a significantly higher concentration of inclusions (0.1 micron and 0.3 micron diameter in low- and high-loss specimens, respectively)--possibly carbide or other material resulting from the special process used in fabrication of these cermets. Examination of the material is continuing by reflection electron microscopy.

Continued experiments with thermal cycling of $\text{UO}_2\text{-W}$ cermets in high and low pressure hydrogen have emphasized the important role of impurities in affecting cermet weight loss. At one atmosphere pressure of purified 100% $\text{H}_2\text{-Ar}$, but in the presence of small concentrations of oxygen or water vapor, the loss rate is very low. At 1000 psi the cermet behavior is even more sensitive to gas purity. In purified 100% H_2 very high weight losses occurred (60% of the UO_2 after 25 cycles), and cermet specimens began to break apart after as few as 10 cycles. However, with small amounts of water vapor or oxygen the loss rate was substantially lower at high pressure than at atmospheric pressure in both 100% $\text{H}_2\text{-Ar}$ mixture.

Investigations are in progress to determine both the basic role of H_2O or oxygen in inhibiting weight loss, and the mechanism for increased weight loss in purified H_2 at high pressures.

NASA Grids Fabrication. Photomicrographs of a Nupac tungsten- UO_2 grid clad with vapor deposited tungsten by an offsite vendor indicated good adhesion and uniformity of the tungsten cladding. The irregular substrate of the cermet may have had some beneficial effects on the grain structure of the vapor deposited coating. High temperature cycling tests are in progress to compare the vapor deposited clad cermet with unclad cermets.

DECLASSIFIED

DECLASSIFIED

A-35

HW 80178

Molybdenum mandrels are being coated with tungsten metal by two techniques--vapor deposition and flame plating--for subsequent transferral to honeycomb grids by the Nupac technique. Visual examination of a 9-hole grid coated by tungsten, transferred from vapor deposited tungsten on molybdenum mandrels by the Nupac technique, indicated satisfactory results.

Dye penetrant testing and x-ray analysis of the tool holder used in ultrasonically machining 61 hexagonal holes in tungsten-UO₂ cermet revealed suspected cracks which caused severely decreased drilling rates.

Sintering of an 80 vol% W-UO₂ cermet grid in hydrogen for 12 hours at 1750 C increased the density from 95.8 to 97.5% TD. The grid had been fabricated at the relatively low impaction pressure of 230,000 psi.

Several special NASA cermet discs of 20 and 40 vol% UO₂-tungsten were fabricated by pneumatic impaction.

A technique was developed for fabricating hexagonal refractory metal bars from round rod by pneumatic impaction. The process is especially applicable in the fabrication of small quantities of odd sized hexagonal bars required for fabricating cermet grid shapes.

NASA Fuel Element Design. Design studies were started on fuel elements for the water moderated reactor concept being evaluated by NASA Lewis Research Center. A design is being sought which will permit fabrication of the fuel element from tungsten-UO₂ fuel plate stock. Work at Lewis Research Center and GE-ANP has indicated that the optimum structure will have the shortest possible unsupported span for the fueled plates. This consideration has led to the following design concepts which are currently under study:

1. An interlocked "egg-crate" structure of fuel plates in combination with twisted ribbons of fueled tungsten strip.
2. Longitudinally corrugated fuel plates spaced by twisted ribbons.
3. Stacking cermet honeycomb grids in a fuel channel using three tungsten support rods, fixed at the downstream end, with slip guides at the coolant entrance to accommodate axial thermal expansion.

These concepts offer an approximation of the structurally desirable honeycomb cross section and provide for some radial fuel distribution. The feasibility of these and other designs based on the use of fueled plate is largely dependent on the fabrication state of the art, primarily joining; therefore, assemblies which can be keyed together or which lend themselves to beneficial use of diffusion bonding are being examined.

Submicron Dispersion of UO_2 in Tungsten. Calcination and reduction of coprecipitated powders has not yet resulted in a completely predictable product. Powders that exhibited an olive drab color after hydrogen reduction at 1000 C were further treated with hydrogen at 1700-1800 C for 12 hours. As a result, a metallic color was obtained. Examination of specimens prepared by high energy rate compaction of both the discolored material and the same material after the higher temperature treatment revealed both to be metallic in nature and showed that appreciable agglomeration of the UO_2 had occurred during the high temperature treatment. Since no third phase was observed in the compacted specimen using discolored material, it is felt the difficulties observed is primarily a color phenomenon.

A second relatively large batch, approximately 250 grams, of W - 20 vol% UO_2 powder has been prepared. Although it also exhibits discoloration after reduction, it will be used in the initial studies in the evaluation of stringering during extrusion and to evaluate the effect of cold work and recrystallization upon the UO_2 particle size and distribution.

Work has been initiated to precipitate two to three kilograms of W - 20 vol% UO_2 powder for evaluation by Lewis Laboratories. Calcination and reduction of this material will be carried out after the current discoloration difficulties have been resolved.

ZrO₂ Coated Extrusion Liner. A thin H-21 steel liner with the ID coated with ZrO₂ by the Rokide process proved satisfactory in extruding two 304 stainless steel billets heated to 1250 C. These two extrusions were made to determine the effect of the high extrusion forces on a ZrO₂ ceramic liner and thus the feasibility of using a ceramic liner for the extrusion of W-Mo composite billets. Previous extrusions of W-Mo composite billets heated to 1800 C have a tendency to erode the inner surface of the steel liners.

The thin liner was used in the 3-1/2 inch container and the ceramic showed no tendency to crack or flake off. The liner was readily removed after completion of the run and showed approximately 3-mil

DECLASSIFIED

swell on the OD in the high pressure area. The ID of the ceramic expanded 6 mils in the high pressure area of which 3 mils was probably due to compaction of the 8-12% porosity in the coating and 3 mils from the expansion of the steel sleeve. The porous surface indicates that a generous coating of lubricant must be applied initially to the ID of the ceramic liner to prevent the billet material from keying to the porous surface and fill the small holes for subsequent runs.

Compatibility of Structural Materials with the HTLTR Environment. The evaluation of materials from the 840-hour exposure test in a simulated reactor environment of nitrogen gas-graphite at 1200 C continued. Initial results indicate that in this long-term exposure a reaction occurred between UO_2 and nickel in the presence of the reactor atmosphere which resulted in a low melting alloy of nickel. Hastelloy B underwent extensive carburization with attendant loss in ductility.

6. Other Customer Work

Boiling Burnout Studies for the Advanced Test Reactor (ATR). Calculations and graphs were prepared to show the hydraulic supply-demand characteristics of the 189-D heat transfer apparatus as arranged for the ATR tests for Phillips Petroleum Company. The results of the analysis show that the pressure drop supplied to the electrically heated model of the ATR fuel element will be nearly constant as the hydraulic resistance of the test section changes due to local or bulk boiling. A flow reduction of 50% through the test section will only result in about 9% increase in available pressure drop.

Calculations were also performed to determine the transverse temperature and surface heat flux distributions in the ATR plate-type fuel elements and fuel support structure.

A finite-difference calculational technique in conjunction with the computer code STHTP-001 was used. A contact coefficient of $10,000 \text{ Btu}/(\text{hr})(\text{ft}^2)(^\circ\text{F})$ between the fuel element and supports and a coolant film coefficient of $17,000 \text{ Btu}/(\text{hr})(\text{ft}^2)(^\circ\text{F})$ was assumed. The existence of reduced film coefficients in the corners of the rectangular coolant passage was recognized and appropriate modifications of local thermal resistances in the corners were made. Gamma heating amounting to 5% of the total heat generated was assumed to occur in the cladding and supports.

The results showed that little redistribution of the heat by internal conduction occurred in the fuel element. Peak local-to-

mean heat flux ratios up to 1.6 were calculated. Heat fluxes from the fuel support structure to the coolant passage edge were found to be 63% of the average channel heat flux. These high heat fluxes at the edge of the coolant passage could possibly affect the boiling burnout heat flux of this fuel configuration adversely.

Phoenix Fuel. The process of forming 2-inch diameter Al - 20 wt% Pu billets for subsequent machining of 0.020-inch wafers was improved by extruding billets prior to machining. The extruded structure machines much more consistently than the cast structure.

Magnesium Oxide Insulated Heating Elements. Vibrational compaction techniques were developed for the fabrication of MgO containing elements. Magnesium oxide was compacted to bulk densities of approximately 84.5% TD in 0.22-inch ID tubes containing helical heating elements. The particle size distribution and the pitch of the helix were adjusted to fit a unique theoretical model derived by Applied Mathematics Operation for the packing of particles. Achievement of this density (equal to that of production Calrods) demonstrates the validity of the model and further illustrates the applicability of the process to complex (but potentially more efficient) fuel element designs. One of the rods was resistance heated through the internal wire for a total of 86 hours at an input power of 1250-1400 watts, and at a surface temperature of approximately 830 C.

Thoria Program. Process equipment and hoods, used to process approximately four tons of thoria in the third quarter FY-64, were loaned to the Production Fuels Section, IPD, for their use in fabricating two tons of thoria fuel elements during June 1964. Limited development work will continue on new and improved processes and fuel element design modifications. Assistance will be provided to production personnel as required.

Manager, Reactor and Fuels Laboratory

FW Albaugh:kb

PHYSICS AND INSTRUMENTS LABORATORYMONTHLY REPORTMAY 1964FISSIONABLE MATERIALS - O2 PROGRAMREACTORN-Reactor Lattice Parameter and Spectral Measurements at Startup

In January, fuel elements containing detector pins of Pu-Al, U-235-Al, fuel enrichment uranium, depleted uranium, Lu, Eu, Au, and Cu both bare and cadmium covered were irradiated in N-Reactor at room temperature. In April a set of similarly instrumented fuel elements were irradiated in N-Reactor at an elevated temperature. The data from these irradiations are being analyzed to determine P , C_0 , ϵ , the neutron temperature and the r -value of the epithermal flux.

In order to properly account for effective mass differences between pins, normalizing irradiations have been carried out in the PCTR. The effective mass corrections for the January irradiation are complete and are being incorporated with the N-Reactor experimental data. The effective mass corrections for the April irradiation are being calculated. Samples of the Pu-Al, U-235-Al, fuel, and depleted pins are being analyzed on the mass spectrometer. Correction factors will be needed to account for the self-shielding in the Au and Lu pins. An experiment was conducted to determine the correlation between pin and foil correction factors. The cadmium ratio of a 20 mil diameter gold pin and 10 mil thick gold foil irradiated in the same spectra were the same within one percent. Thus, gold foil data available in the literature may be used to correct an experimental cadmium ratio to a dilute cadmium ratio. The problem of self-shielding in Lu is still under investigation.

Instrumentation

Good progress was made on preamplifier development for the N Reactor low-level neutron monitoring system. Test results were promising for a hybrid vacuum tube and solid state preamplifier unit planned for use with the neutron fission counters.

Conclusions reached in a review of the proposed entry-way shielding for the gas loop of the Advanced Test Reactor appeared to be acceptable to the contractor (Babcock and Wilcox). The review indicated proper shielding could

UNCLASSIFIED

be determined by calculations and that no experimental mockup would be necessary.

Technical calculations were provided to Reactor Design Analysis, NRD, regarding a proposed cooling system for the N Reactor exhaust air filter system.

Continued technical assistance was provided on the use of gamma spectrometry methods to determine the cooling age of irradiated reactor fuel. The spectrometry tests are being conducted at C Reactor storage basin and the results achieved appear to be excellent. The project is being carried out in cooperation with Reactor Design, IFD.

System Studies

The N Reactor analog simulation was modified to permit studies at 10 percent of rated power level and computer runs were made using various combinations of equipment in the primary and secondary loops. The typical arrangement was four primary pumps, eight steam generators, and four dump condensers. The 100 percent of design runs have typically used five primary pumps, ten steam generators, and 16 dump condensers. The low power simulations included reactor scram, setpoint changes of the main steam header pressure, and the differential pressure between the main steam header and the condensate header.

The EASE 1132 computer was patched to simulate the primary loop hydraulic system with two separate turbine pump models. The purpose of the simulation was to determine reactor power level and outlet temperature excursions to be expected during one and two-pump drop off at 10 percent of design power conditions.

New pressure drop versus flow data obtained under actual operating conditions at the N Reactor were used to compute corrected coefficients for the primary loop simulation model. The change in coefficients had negligible effect on the control system stability and resulted in closer agreement between simulated and actual operating pump speeds.

The first over-all N Reactor simulation nomenclature list was compiled and punched on IBM cards; a different card is used for each symbol. Therefore, changes can be made at any time by simply adding, deleting, or changing cards in the deck. Quick, inexpensive nomenclature lists are printed out by the IBM equipment. The present list requires about 400 cards.

A simulation study of cold water injection into the N Reactor was completed. The basic equations and values used for the constants of the simulation were published in HW-81778 entitled "Cold Water Injection Analog Computer Study."

SEPARATIONSCritical Experiments with Plutonium Solutions

Critical experiments for nuclear safety guidance were continued with $\text{Pu}(\text{NO}_3)_4$ solutions in an 11.5-in. diameter sphere reflected with concrete. Critical concentrations in the 12.95 liter vessel were in the range of 80 to 260 g Pu/l, depending on the nitrate concentration. In addition to critical mass determinations, neutron flux distributions were measured throughout the critical assembly for determining the extrapolation length of the concrete reflector and the critical or material buckling of the Pu solutions.

Analyses of data from gold foil irradiations that were made throughout the spherical core and its concrete reflector, with the vessel critical at two different Pu concentrations, have shown some interesting differences between concrete and water reflectors. In the case of the water reflector (critical concentration of Pu in core ~ 250 g Pu/l), the thermal flux was found to have a maximum value about one inch from the surface of the vessel, where the thermal flux peak was $\sim$ eight times the value at the sphere center. In the concrete-reflected sphere, which was critical at nearly the same concentration (~ 225 g Pu/l), only a slight increase in thermal flux was observed in the reflector where the value was about 0.8 that at the sphere center; this ratio is ten times less than that for the water-reflected core. For a more thermal system (critical concentration of ~ 80 g Pu/l) there was no observed maximum of thermal flux in the reflector. The extrapolation lengths and reflector savings in each case were about equivalent to that of water.

One may attribute these results to the higher albedo for concrete. The concrete returns more neutrons to the core, but their worth is less since the neutrons have higher energies than if reflected from water. Although fewer neutrons are returned from the water reflector, those which are have a more thermal spectrum and a higher worth since the slow neutrons are more readily captured in the fissile core material. Thus, although the number of neutrons being returned to the core is different in the two cases, the reflector savings of water and concrete are nearly equivalent.

Reactor Noise and Reactivity Measurements

A paper of some interest in regard to reactor safety applications has been received from Dr. R. W. Albrecht of the University of Washington (consultant to Critical Mass Laboratory). The paper is entitled, "The Use of Delayed Neutron Reactor Noise Spectrum for Subcritical Reactivity Measurement." It is shown that for nuclear reactors with prompt neutron lifetimes

shorter than 10^{-4} seconds, it is feasible to measure subcritical reactivity independent of knowledge of the value of the prompt neutron lifetime. This is accomplished by analysis of the relative magnitude of the reactor noise density spectrum at two frequencies: one of which is chosen to include delayed neutron effects and one of which is dominated by prompt neutron effects.

The neutron lifetimes in typical graphite-uranium lattices such as at Hanford are longer than 10^{-4} sec. and thus this method would not be applicable to these systems, nor would it be applicable to a D_2O moderated lattice. However, the method is ideally suited for the plutonium reactor systems under study at the Critical Mass Laboratory where the neutron lifetimes are of the order of 10^{-6} sec.

Of course, the reactivity can always be determined from a measurement of reactor noise if the neutron lifetime has previously been determined.

Monte Carlo Code for Lattices

A difficult technical problem, but one which is important in processing reactor fuels, involves the criticality of enriched uranium fuel elements in an aqueous uranium solution (problem of uranium dissolution). A three-region lattice Monte Carlo code has been written to obtain more definitive answers to such problems. Sample cases are currently being run to check the code.

Contribution of N-Flight Collision to the Fast Effect in Lattices

The fast fission factor (ϵ) for a heterogeneous array is usually based on the assumption that any first flight collision with material other than uranium will reduce the neutron energy below the fission threshold in U^{238} . Thus, the calculation is based primarily on first flight collisions. A method has now been derived that accounts for the contributions to the fast effect from neutrons which have undergone n collisions. Calculations have been made for water and graphite moderated lattices. In a typical NFR type lattice, the computed fast effect is about one percent larger when based on n -flight collisions; and for a close packed uranium rod-water lattice, an increase in ϵ of as much as 5% has been computed.

Critical Mass Laboratory Instrumentation

Two modifications were made to the noise analysis system at the Critical Mass Laboratory. A traverse mechanism was added which will be used to position the thermal neutron detector so that an optimum count rate may be maintained in taking noise data. The traverse mechanism will also be used

to study detector efficiency and the effect it has in determining the break frequency in noise analysis. A simple circuit modification was made to the count rate meter to change its maximum linear range from 3×10^6 cpm to about 10^7 cpm.

Consulting Services on Nuclear Safety--Criticality Hazards

1. Nuclear Safety in HL

Nuclear safety specification K-2 was issued for PRTR to cover the transportation and storage of Mark I fuel elements containing natural or depleted uranium.

2. Nuclear Safety in CPD

The work of the Hazards Review Committee for the Americium-241 recovery facility was completed and a final report issued--HW-81868, "CPD Hazard Evaluation of Am²⁴¹ Recovery Facility," D. E. Braden, C. L. Brown, B. F. Judson, and C. W. Nilsen. There is no criticality hazard in handling the Am²⁴¹ itself; however, the plutonium encountered in the recovery process must be controlled. The principal problems are those of contamination control and radiation exposure in handling.

Comments on the nuclear safety aspects of using water to fight fires in CPD facilities were submitted to Advance Technical Planning, CPD. The report (HW-82254) subsequently issued by ATP divides CPD into four categories according to criticality hazard. The method of fighting fires depends on the criticality hazard at each location and on the degree to which fire fighting activities might cause a nuclear chain reaction.

A report was issued covering the recent criticality review of the plutonium processing facilities in CPD. The criticality review committee was composed of four specialists in nuclear safety; three members from HL and one from IPD.

Separations Instrumentation and System Studies

All laboratory testing was satisfactorily completed on the solid state portable gamma spectrometer instrument, which was developed for plutonium monitoring in hoods and glove boxes in the 234-5 Building. The instrument was taken to the field and is being applied to the measurement problems.

Specific sample vials of plutonium in solution are being obtained from CPD to permit further testing of the detectors developed for use in the Pu-239 liquid sample counting system.

The ANN (Aluminum Nitrate Nono Hydrate) recovery process was programmed for iterative solution on the EASE 2133 analog computer. The system, under study by Research and Engineering, CFD, consists of a series of stirred vessels in which fresh feed is introduced to the first vessel and the overflow of each vessel is fed to succeeding vessels. After a prescribed period of time the feed is discontinued, the vessels are chilled to crystallize the ANN, and fresh water is used to backwash for a fixed interval of time the original liquid from the vessel. This process is repeated until the ANN concentration in the last beaker is stabilized. The problem parameters include the number of vessels used, and the times used for the feed and backwash cycles. About 3,000 complete solutions to the problem were obtained in two days of analog computer operation.

METALLURGY - Nondestructive Testing

N Fuel Testing

1. Fuel Element End Closure Testing

The cap to core bonding test for the "Chevron" end cap has been set up in the engineering pilot plant. This test utilizes the loss of signal technique to indicate an unbond. Efforts to eliminate the use of an internal probe for the inside bond were unsuccessful. The test has been turned over to N Fuels Engineering who will perform the evaluations on experimental extrusions with Testing Methods Engineering support.

2. Fuel Element Beta Heat Treatment Test

An investigation is under way to develop a technique for inspection of N fuels to determine whether they are properly heat treated and quenched and also the number of times a piece was heat treated. The fuel elements are heat treated each time a fuel is reworked (because of reject areas). Since the grain structure is changed each time, the number of heat treatments allowed is limited. Some samples of the various types--numbers of heat treatments--were obtained and a standard 5 megacycle pulse-echo test was used to determine the grain structure changes. The results of this test show good resolution between as-extruded fuels, single beta heat treated fuels with normal quench, and air quenched fuels. Differentiation of the number of heat treatments was rather borderline and more work would be done to make this a production type test. Metallographic work for correlation and determination of the grain structure in these samples also is being done.

3. Fuel Element Clad Thickness Testing

A method of measuring the clad thickness around the region of the end cap is needed for the N fuels program. It is possible to obtain a thin cladding region around the end cap area because of the production operation. Standard nondestructive testing techniques do not appear feasible for this measurement. Neither the acoustic nor the electrical impedance change between the Zircaloy-2 cladding and the beryllium-Zircaloy bond material are sufficient to cause appreciable signal difference. Samples are being obtained having thin clad at the cap end. A possible approach to this problem will be the use of boundary waves in an attempt to determine the difference due to the different structure in the two materials. This will be investigated.

4. Uranium Enrichment Testing

The enrichment tester is still being run by N Fuels Quality Control. They are testing all process billets and taking replicate measurements on the standards. A maintenance manual and report is being prepared.

5. X-Ray Fluorescence Test Development

Evaluation tests on the X-ray fluorescence tests for measuring the uranium contamination at the end braze region are proceeding. This work is being done under a FWR designed to evaluate the test, correlate it with the other means of surface contamination measurement, determine what problems still need correction, and to determine the throughput capacity of the equipment. A stability problem has been resolved by use of a line voltage regulator. Working standards have been developed and tested using neutron fission track measurements for correlation. Improvements were made during the month in testing time by switching changes. Also, changes are being made to reduce X-ray leakage around the equipment.

The new standards have checked out quite closely and from these the detection sensitivity has been determined. It appears that a contamination level of 5000 ppm uranium in a volume of $0.25 \times 10^{-3} \text{ in}^3$ of the braze region can be detected. Repeatability tests and correlations with autoradiography, alpha counting and neutron fission track counting methods also show very good results thus far.

6. Uranium Surface Contamination Testing

The alpha surface contamination testers are still being used in production testing, although maintenance problems exist. A principal diffi-

culty is contaminated test heads. Pre-tested test heads, adequate spare parts, and additional phototubes are now on hand and should minimize this problem. Additional emphasis on training of the maintenance men is expected to improve instrument usage time also.

7. Irradiated Fuel Testing

The instruction manual for the post irradiation testing equipment now installed in KE basin was completed and distributed.

Collection of the final data for the UT-10 prototype station in KE Area was started. In the most recent fuel element discharge on January 23, 1964, 27 assemblies were discharged from two loops. Four outer tubes from one of these loops have been tested. Records were taken of all test results; however, no flaws were detected in any of the samples tested. Tests were run on internal, external and cap-core bond tests and longitudinal and transverse flaw core tests. For the core testing several frequencies and test techniques were used to determine the optimum tests. The $2\frac{1}{2}$ megacycle channel worked best although no core flaws were detected with any of the methods.

A new UT-10B fuel tester being fabricated for installation at N Reactor will incorporate improved manipulators and mechanical equipment.

The electronic system of existing equipment now installed at KW will be modified and used at the N facility. A continuous readout clad thickness test will be developed and added to the UT-10B station during 1965. It is planned to use an eddy current type test similar to the one presently used in the N Fuels clad thickness tester in 333 Building.

N Reactor Testing

Zircaloy Hydride Detection

Work on the fabrication of the ultrasonic rotating probe for hydride detection is approximately 80 percent complete. Plans are to continue development of the two probes separately, keeping in mind the possibility of combining them after the preliminary evaluations are complete.

Fast pulse circuitry to be used in the ultrasonic hydride test has been under development and is proceeding well. The use of hybrid muvistor-transistor circuits appears very promising in terms of reliability, simplicity, and stability. Designs have been placed with Technical Shops for construction of the first prototype circuits in module forms.

AlSi Fuel Testing1. Irradiated Fuel Testing

Final tests on the ten irradiated "K" type fuels were not completed due to scheduling problems and failure of the electronic oscilloscope used for crystal alignment. The bond test transducers were completely checked out in the laboratory and the parameters measured. Optimum water path was determined and this will be used in the final test.

2. Bond Test Development

Correlation work is continuing on the ultrasonic outside-in bond test with inner clad results compared with autoradiography. The results continue to look favorable. Tests are being run on the effect of transducer parameters and more crystals have been received from the supplier to evaluate the effect of various crystals on the test results. Work is also being done on amplifier and preamplifier coupling problems. Circuitry development for the prototype equipment is proceeding well; first stages are completed and ready for instrument shop fabrication. Work is being started on a new amplifier for the system.

3. Hot Die Sized Fuel Testing

New drawings were completed for the end bond transducers and transducer holders and the drawings are now up to date for the Hot Die Sized Tester. The final draft of the tester manual is being typed.

IPD Production Fuels Engineering has requested an investigation of the feasibility of testing hot die sized component eccentricity. A proposal for a through transmission eddy current system was completed.

NEUTRON CROSS SECTION PROGRAMScattering Law Measurements for H₂O at 95°C

The causes of internal discrepancies in the measurements of the scattering law for H₂O at 95°C seem to have been identified. The latest effect which was identified was an unanticipated [0003] reflection in the beryllium crystal analyzer. (This reflection appears as a "3/2-order" reflection when the [0002] crystal planes are being used.) This reflection is forbidden but can occur at discrete crystal orientations by multiple internal Bragg diffractions. Corrected results are now being obtained for those previous measurements where the effect was significant.

Scattering Law for Polystyrene

A technique has been developed for preparing samples of polystyrene which are free of strain or polymer orientation. No samples have yet been prepared in final form for scattering law measurements.

Time-of-Flight Spectroscopy for Slow Neutrons

Development of components for the measurement of slow-neutron inelastic scattering by time-of-flight has continued. A crystal rotor for use with spherical- or plate-shaped monochromating crystals was completed. The mechanical chopper was also completed except for the slit system. Both rotors were operated under test with satisfactory speed and phase stability.

Fast-Neutron Cross Sections

Another series of 2.5- to 15-MeV total cross section measurements was completed during the month. Measurements were made on samples of bromine, oxygen, nitrogen, and deuterium. Only a minor fraction of the planned measurements were completed because of failure of the ion source of the Van de Graaff. The processing of the data obtained in these measurements has not yet been completed. The data obtained in a measurement series performed in February have now been processed and evaluated. The results of measurements on 18 samples were satisfactory while poor results were obtained for samples of Tm, Eu, Pb, and Cr⁵³.

REACTOR DEVELOPMENT - O4 PROGRAMPLUTONIUM RECYCLE PROGRAMPhoenix Fuel Program1. Plutonium-Burnable Poison Systems

Very favorable reactivity effects are achieved by using mixtures of burnable poisons in plutonium burners. A calculation for a Mark-I reactor using a mixture of Sm-149 (1134 gms) and B-10 (207 gms) has recently been completed. A reactivity decrease of ~3% occurs in about 6500 FPH. A burnable poison mixture richer in Sm-149 would lead to further reactivity-time improvements.

2. Medium Enrichment Reactors

Burnup calculation for several isotopic compositions of Pu have been carried out for cores containing 10% of a mixture of PuO₂ and UO₂,

40% zirconium, and 50% H₂O. The ratio of PuO₂ to UO₂ was varied for each Pu composition to produce an initial k_{∞} of 1.30. It appears that the fertile U-238 does not have an appreciable effect on the reactor lifetime. However, no attempt has yet been made to optimize the systems. Additional calculations, holding the U-238 content constant, are planned to isolate the U-238 effect.

3. Plutonium-U-235 Systems

U-235 boosted Pu burners might be of interest if the Pu-240 production from Pu-239 can be minimized without undue reductions in the Pu-241 production. Since reactors of this type employ two distinct fissile materials whose relative concentrations change throughout the reactor life, it is of interest to examine the effect of the fission spectrum on reactivity. k_{eff} for a typical Mark I reactor loaded with 50% U-235 and 50% exposed Pu was determined for two fission spectra. Using a U-235 fission spectrum, $k_{eff} = 1.2036$, and with a Pu-239 fission spectrum, $k_{eff} = 1.2027$. It is concluded, that a single fission spectrum can be used for Pu-U-235 reactor survey calculations.

4. Pu-240 Doppler Coefficient Calculations

In Pu burners the Doppler coefficient due to Pu-240 can be of importance to reactor control and safety. The Pu-240 coefficient has been calculated as a function of FPH for a typical Mark I core loaded with 50/31 plutonium. The coefficient is of the order of $-1 \times 10^{-5} \Delta\rho/^{\circ}\text{F}$ over the entire life cycle.

5. Comparison of One- and Three-Region Burnup Calculations

In most of the burnup calculations for Phoenix cores carried out to date, the core loading is uniformly depleted at each time step and the effective multiplication factor is determined by means of a one-dimensional diffusion calculation. A rough check on this approach has been obtained by comparing a one- and three-region burnup calculation for a typical Mark-I core loaded with 80/20 plutonium. The k_{eff} vs. FPH curve is affected very little. At ~ 7000 FPH the discrepancy is only $\sim .003 \Delta k$. The power distributions do diverge quite a bit, particularly at higher FPH values.

6. MTR Plutonium Loading Analysis

Work has resumed on computations of the physics statics for MTR cycle 108. This was an experiment performed in 1958 utilizing an

all plutonium loading in the MTR. Previous efforts on the project may be found in the monthly report for October, 1963. Agreement with experiment has been improved by incorporating a more detailed reflector specification into the two-dimensional reactor model. Further improvement is expected from the use of plutonium cross sections based on a recent review by Sher.

Plutonium-Aluminum Light Water Critical Measurements in the PRCF

Drawings for future PRCF experiments in H₂O moderator were reviewed and approved. The experiments will be conducted with 1.8 w/o Pu-Al fuel elements on an 0.80-inch lattice spacing.

Pile Oscillator PRCF

The mechanical parts of the oscillator have been assembled. The drive motor would not operate smoothly from the pulsed D.C. power supply built for it. A variable D.C. power supply will be fabricated.

Pu-Al - Light Water Experiments in the PCTR

An experiment on a plastic-moderated U-235 lattice is being planned as a prototype for later experiments with Pu. The uranium experiment will serve several purposes:

1. Delineate the operating problems of controlling the contamination expected in the handling of the unclad Pu-Al fuel disks.
2. Provide a check of calculational methods and parameters to be used in predicting the properties of the Pu lattice.
3. Serve as a proving ground for hardware and experimental techniques to be used in the Pu experiments.
4. Provide useful integral data on light water U-235 systems. Present plans include determination of critical poison concentration for H/U-235 ratios of ~ 200 (atom/atom) and ~ 1000 (atom/atom) and for various H/Pu ratios.

The test core for the PCTR will consist of a hexagonal array of 61 aluminum fuel cans (~ 2 " in diameter by ~ 12 " long). Each can will contain a stack of fuel and borated polyethylene disks. The U-Al disks, which are from the VSTR(PPA), contain 33 w/o uranium (~ 93.5 w/o U-235 enriched). The Pu-Al disks, which are being made by Advance Fuels Development, contain ~ 20 w/o plutonium with three different Pu-240 concentrations:

~8 w/o, ~16 w/o, and ~25 w/o. Preparation of specifications for the borated polyethylene disks is now in progress. Prototype fuel cans have been fabricated and appear satisfactory.

PRTR Irradiation Experiments

The relative activities of all Co-Al wires and pins which have been irradiated in the PRTR on Pu-Al fuel elements 3051, 5092, and 5095 have been measured. The counting instrument has been calibrated with a secondary standard which has been irradiated and counted at the MTR. In addition, three pins which have been irradiated in the PRTR have been calibrated with standards at Hanford. The Co-Al wires must be weighed before the analysis can be completed.

Specific Power Increase in the PRTR

Consideration is being given to increasing the specific power of the PRTR by reducing the number of fuel clusters from 85 to 55, and decreasing their length from 88 inches to 60 inches. This would significantly decrease the time intervals between experimental burnup data points.

A study is under way to determine the enrichment of $\text{PuO}_2\text{-UO}_2$ fuel elements to provide sufficient excess reactivity and reactivity lifetime for such a loading. Calculations of effective multiplication factors, k_{eff} , have been made using HFN with cross sections generated from THERMOS, GAM-I, and TEMPEST. The results for a cold-clean reactor loading of 2 w/o and 1 w/o enrichments are $k_{\text{eff}} = 1.229$ and $k_{\text{eff}} = 1.194$, respectively.

An earlier calculation using ALTHAEA-MELEAGER predicted $k_{\text{eff}} = 1.164$ for an enrichment of 2 w/o. A part of this discrepancy is due to an unrealistically large axial buckling used in the ALTHAEA calculation. As a check on the validity of the HFN result, however, the two-zone (UO_2 and Pu-Al) critical approach made during initial startup has been mocked up and is being studied. The accuracy with which ALTHAEA tracks reactivity as a function of exposure is currently being checked by an HFN calculation at 5600 Mwd/t using the isotopic concentrations calculated by ALTHAEA. An independent check of burnup characteristics of the core is being made with ZODIAC.

In the course of the present study, a set of four-group cell cross section sets for various types of fuel elements used in the PRTR have been generated by the codes described above.

Code Development1. CLERK C

The CLERK code, HW-75521, has recently been revised to permit more flexibility. The new version will be available only as a part of the ZODIAC code not as a separate program. The improvements listed here are in addition to those already specified in the "ZODIAC User's Manual 03-30-64," HW-81302. The number of permissible energy groups and isotopes has been increased to 20. The flow at the isotopic burnup chain is completely input controlled. Burnup branches considered are as follows:

1. Any isotope is capture coupled to any two other isotopes. The ratio between the two daughters is an input.
2. Any isotope may have up to five fission yield daughters. The fission yield fractions are input.
3. Any isotope may decay to any other isotope. The half life is an input.

The input LISTIN locations for these changes will be available in the new ZODIAC manual.

2. Physics Chain

An informal report, HW-80968, entitled, "User's Manual for RBN and CLAX Chain," was issued containing detailed instructions for input preparation for the codes present on these two chains.

3. RBU Output Processing

Subroutines were written for the code PLOTGX to allow partial processing of the RBU output tape. The Monte Carlo fluxes are averaged over the energy macro group and are plotted as a function of energy. The Monte Carlo cross sections are converted to barns from barns-power-ev.

RBU Application

The plutonium aqueous homogeneous spherical critical experiment 12-1 run using the RBU Monte Carlo was analyzed further and compared to the results obtained from the RBU diffusion code. The spatial distribution of the flux is markedly different for the two codes. This discrepancy has not been fully explained. The energy distribution of the flux averaged over the

core was compared with the energy distribution obtained from a SPECTRUM case for the core. There was a close agreement between the two. Anisotropic scattering by nitrogen and oxygen were ignored in this run. The necessary anisotropic scattering data were obtained and processed for addition to the Hanford Basic Library for these isotopes.

Isotopic Analysis of PRTR Samples

Isotopic analyses were provided on 27 plutonium samples of PRTR-irradiated fuel elements in support of the Plutonium Recycle Program. Of these, 15 were macrodrill samples from UO₂ element No. 1006, 4 were macrodrill samples from UO₂ element No. 1101, 3 were macrodrill samples from Al-Ni-Pu element No. 5111, and 5 were burnup samples from Al-Ni-Pu element No. 5109.

Isotopic analyses were completed and reported on the following fuel elements: UO₂ No. 1006 - Macrodrill Samples (HW-81047), UO₂ No. 1101 - Macrodrill Samples (HW-81064), and Al-Ni-Pu No. 5111 - Macrodrill Samples (HW-82367).

Instrumentation and System Studies

Laboratory testing was continued on various selected multiplier phototubes for possible use in the PRTR fuel element rupture monitoring system. To date, no phototube has been tested that shows appreciably improved stability performance over the original detectors.

Data received from PRTR indicate that five times as much Rb-88 as Cs-138 occurs in the exhaust air from PRTR. This is of direct interest in the development of an adequate exhaust air monitoring system since Rb-88 is primarily a beta emitter with only about 13 percent of the disintegrations providing a gamma. Thus, the detection sensitivity requirements are considerably more difficult to meet than for the case originally envisioned. The required detection limit is 5×10^{-6} $\mu\text{Ci/cc}$ for the exhaust air stream.

The eddy current motion analyzer which was developed for use in studying the fuel assembly vibrations which have been encountered in the PRTR is undergoing operational testing in the loop in the 314 Building. An excessive amount of balance point drift was observed during elevated temperature operation up to 500°F. It appears that this drift originates from the instrumented fuel element and tests are being conducted to determine the characteristics of the swaged lead wires in the eddy current coils. Preliminary tests indicate that the temperature effect on the leakage resistance and capacitance of the lead wires vary widely between the two samples that have been tested.

EBWR EXPERIMENT PROGRAMPRCF Experiments with EBWR Fuel

The measurements to determine the film void coefficient were completed during the month. Also, the worth of a cylindrical void in an empty fuel channel was measured.

The film void was formed by placing a fuel rod inside a dry Lucite tube with Lucite spacers to center the fuel rod in the tube. The annulus forming the film void was 0.080 inch thick forming a void equal to 29% of the cell volume and 43% of the moderator volume. The volume weighted average worth was 0.164 mk per film void with the value of the film void in the central fuel channel worth 1.57 times the volume weighted average. The cylindrical void was formed by displacing water from an empty fuel channel with a sealed Lucite tube with an I.D. of 0.585 inch. The volume weighted average worth was 0.2767 mk per void. The worth of the cylindrical void in the central fuel channel was 1.40 times the volume weighted average.

The data obtained from the moderator sensitivity measurements are being analyzed. The analysis will provide information regarding moderator worth and reactivity coefficients, and will also give a value for the migration area.

Preliminary plans are being made for the fabrication of special poison rods the worths of which will be measured in the PRCF to determine the effectiveness of various control rod materials.

Materials are being tested for producing voids in the PRCF. The first material tested was a plastic foam. The void fraction was sufficiently stable as a function of time. It was rejected because it was too poisonous when compared to H₂O in the PCTR.

Two copper wires for flux traverses, and bare and cadmium covered copper and lutetium pins for spectrum measurements were irradiated in the PRCF-EBWR core. The counting of both detector types is nearly completed. The program APDAC is being used for analysis of the copper data. The lutetium data will be analyzed using LULU.

Critical Approach Loadings

The calculations of the critical number of EBWR fuel rods for all of the proposed lattice spacings in the approach-to-critical facility are completed. The calculational method is the same as previously reported with the exception of using Sher cross sections for Pu-239. The use of Sher's

data yields results which are less than a 4% error in critical mass for all measured lattice spacings.

EBWR Core Criticals (PuO₂-UO₂) Zone

A determination of the cold-clean multiplication as well as the multiplication at various burnup steps (cold moderator) has been made using Sher data. The results of using Sher data as compared to Leonard for Pu-239 move the curve of k_{eff} vs. core radius down by roughly 2.5% in multiplication.

HIGH TEMPERATURE REACTOR PHYSICS PROGRAM

Measurement of the attenuation of RaBe source neutrons through a stack of insulating brick and graphite indicate that the HTLTR fast neutron source, of strength 10^{10} sec^{-1} and located beneath the reactor, would provide a thermal neutron flux of $30 \text{ cm}^{-2} \text{ sec}^{-1}$ at the detector on top even when no multiplication takes place in the reactor. A minimum flux of this value can be measured with ionization chambers of existing design that are readily available. An additional factor of two increase in intensity could be achieved by placing either the source or detector in a recess in the thermal insulation, but this is not now considered necessary.

A draft of a preliminary hazards report for the HTLTR has been prepared for comment. It will appear as HW-82372.

For prototype design purposes some calculations of control rod worth in the HTLTR have been made. The rods are to be of the shutter type consisting of an inner set of cylinders, alternately of fuel and borated graphite, and an outer set alternately of fuel and graphite. Parameters considered are the dimensions, material compositions, and ambient temperature of the moderator into which the rods are inserted. The kinetics analysis in the hazards report requires the worth of each rod to be between 35 and 70 cents. The compositions and dimensions of the cylinders have been selected so that a rod worth will fall within these limits for at least one of its two positions in the reactor. It may be necessary to construct the rod so that it can be assembled with borated graphite cylinders containing various concentrations of boron.

The results of prototype and materials testing work were reviewed at a general meeting. In summary, the small mockup, in which 4' long graphite heating elements surrounded by graphite and insulation are tested, has proved the general operability of a low voltage heating system. In this system the heating rods would pass unsupported through the main body of

the reactor. It has been shown that evacuation of the mockup and, therefore, of the reactor, is necessary for adequate purging. A collet type design for the electrical connections to the heater has been devised and tested, and has been adopted in the reactor design. Work on the larger mockup has been resumed after a four-month stoppage. It is to contain a 10' x 2' x 2' graphite core in which prototype components are to be tested. The tests will run concurrently with reactor design and throughout the construction period. An initial design for the control rod and safety sheet prototypes has been prepared and construction of actuating mechanisms for them has been started. The initial materials tests in nitrogen at 1200 C have served to point out TD nickel, nickel, and Hastelloy B as suitable metals for use in the HTRE. Molybdenum may be suitable as a thermocouple sheathing material. Inconel 600 and some stainless steels may be used in the brick insulation regions within the reactor envelope. Stainless steels in contact with graphite and alloys containing chromium were not suitable. Granular B₄C showed a strong reaction with nickel although none with TD nickel and none with either when compacted. BN gives off vapors which have a corrosive action on nickel.

NEUTRON FLUX MONITORS

Hanford cross section data, taken from the RBU basic library tape by the GANDS program, are now being used in the evaluation of the plutonium regenerating detectors. These cross sections are significantly different than cross sections published by Westcott and others; however, the end results of the calculations are not appreciably affected, indicating the various sets of cross sections are internally consistent. The MIN of INT program was rerun to determine the optimum composition which should have been used in the test and to determine the behavior which should have been achieved by the material actually used. The agreement between the calculated and experimental results is slightly better than with the Westcott cross sections. It is still not clear how an error analysis should be handled; this is being discussed with Mathematical Analysis, HL. A rough draft of the final report on this phase of the project is well under way and should be completed soon.

Discussions were held with the offsite fabricator regarding improvement in the neutron to *gamma* sensitivity to be effected in the two uranium-234 regenerating detector chambers. In addition, the proposed mechanical design was reviewed and approved. The necessary U-234 was received and measurements were conducted to determine the amount and isotopic composition of the uranium. An adequate quantity of U-235 was obtained for enrichment to the desired composition, and the exact composition of the required material was determined by MIN of INT calculations using Hanford RBU cross section data. Background information was prepared for use by

Irradiation Testing, IPD, in writing the necessary development test procedure for chamber irradiation. Progress was achieved on the design of equipment necessary for chamber installation and testing.

An experimental program was initiated for evaluation of coaxial cable noise generation, as applicable to the beta current in-core neutron flux detector chambers. Consideration of the problem indicated that very small cables might alleviate the difficulty of noise generation, and an experiment was proposed to determine the effects of conductor size, sheath size, and type of insulation. Representative cable specifications were prepared for acquisition of a family of cables. It is possible that a 2-wire cable may provide a means of nullifying a portion of the induced background or noise currents. It is imperative that the cable noise problem be rectified before detector performance measurements can be conducted.

A second in-reactor test was made at the KW Reactor Snout Facility on the microwave neutron flux monitor system. The test apparatus used a He-3 filled quartz capsule in the single-ended system. The temperature difficulties, as encountered in the first test, were overcome through the use of 360° heat sinking for the cavity. This limited the measured temperature increase to 20 C. A positive frequency shift was achieved. A third test was planned using a modified cavity in a coupling mode. Arrangements are being made with Irradiation Testing, IPD, for a long-term irradiation test that will include operation through both a reactor startup and shutdown.

NONDESTRUCTIVE TESTING RESEARCH

Electromagnetic Testing

The separation of signals due to internal and external tube wall irregularities was demonstrated using the multiparameter eddy current tubing tester which is being developed. Using the differentially wound probe coil assembly the tester was operated at 6 Kc and 200 Kc and adjusted to distinguish a 0.025 inch deep by 1/8 inch diameter hole on the inside wall of a N Reactor process tube from a hole drilled from the outside to within 0.015 inch of the inside surface. The I.D. hole gave a signal only on one channel and the O.D. hole gave an indication only on a second channel, whereas, a hole through the wall gave indications on both the I.D. and O.D. channels. Incomplete separation of signals due to deep holes (0.150 inch) drilled from the inside wall was noted, with the undesired signals on the O.D. channel being one-third of the amplitude of those on the I.D. channel. The cause of this inadequate separation is believed to be due to the nonlinear relationship between test specimen parameter values and eddy current test coil impedance. The multiparameter tester in its present form operates on a linear algebraic principle, and does not correct for

existing nonlinearities. Several techniques for reducing the nonlinear effects are being considered for increasing the ranges over which the parameters may be separated.

The application of air-cored tuned transformers for use with the multi-parameter eddy current tubing tester is being explored. Such a transformer with a rotating secondary winding was assembled complete with an electric motor drive for insertion into laboratory samples of N Reactor process tubes. The assembly was operated at 100 Kc using a one-fourth inch diameter eddy current test coil mounted in a ferrite cup core. The rotational speed is adjustable from about 30 to 150 rpm. A drilled hole one-sixteenth inch diameter extending to within 0.023 inch of the inner surface, and a drilled one-eighth inch diameter extending to within 0.040 inch of the inner surface were both readily detected. At higher sensitivities spurious signals associated with probe rotation and probe wobble are observed. Several techniques which are available will be applied to further reduce the magnitude of these undesired signals.

During laboratory tests some apparently anomalous eddy current signals were obtained with small differentially connected tangent coils as they approached the end of a standard notch. The signals obtained caused the bridge output voltage locus to make a small loop pattern just as it started to form the beginning of the typical Figure 8 pattern of the Model 1004 tester. Tests with several different coil arrangements using the Vector Impedance Plotter, showed that these loops result from the cusp-like impedance loci of a single coil as it passes each end of the notch. The loops are not always observed, being at times masked by probe wobble signals.

As an aid in adjusting the multiparameter tubing tester, a probe positioner was fabricated which passes the probe by flaw standards machined in the wall of a Zircaloy process tube. This automatic scanning arrangement will be used in instrument evaluation and adjustment.

A heavy copper wire (1/8 inch diameter) model of the vector signal patterns (Lissajou figures) obtained for nine different tubing test conditions with the Model 1004 Eddy Current Tubing Tester was made. This model will be used in future displays and as an educational aid when the tester is transferred to field testing operation.

A prototype of the Model 1004 tester was assembled for display at the Third International Conference for Peaceful Uses of Atomic Energy in Geneva, Switzerland. Several features were incorporated in this unit to display the novel characteristics of the tester.

Fundamental Ultrasonic Studies

Analytical work to describe ultrasonic wave propagation in the presence of attenuation was resumed after several months' delay. A wave model has been developed which appears to adequately explain the propagation between two semi-infinite attenuating media at a single frequency. If it could be assumed that attenuation in both media varies linearly with frequency, analytical solutions for the case of pulses composed of a spectrum of frequencies also appear possible. However, for most materials attenuation varies with frequency in a nonlinear manner. Though some experiments have shown that the attenuation is nearly linear over a range of frequencies, there is an effective low frequency cutoff which precludes analytical solution. A numerical treatment which gives the approximate behavior of pulses is therefore necessary.

Experiments are being conducted to obtain pulse frequency spectra and attenuation coefficients needed for the analytical work. A computer program was written to provide pulse frequency analysis and tested with a number of typical ultrasonic pulse shapes. To provide the needed input data it was necessary to accurately measure pulse amplitude as a function of time. This was accomplished by adapting a sampling oscilloscope and an X-Y recorder for graphically plotting the amplitude of an ultrasonic signal. A very long, narrow-band pulse was included as a check of the program. The pulse frequency was accurately measured in the laboratory and this value agreed to within one percent of the computer output center frequency value. Other checks have also indicated that the program is accurate.

In addition to providing the modulus of the frequency spectra, which is the usual electronic spectrum analyzer display, the real and imaginary spectral elements are also given by the program. Both the real and imaginary components are needed in the analytical work and this information would be difficult to obtain by electronic spectrum analyzer methods. However, the electronic analyzer is convenient and does provide useful displays if suitable pulse gating can be obtained. Laboratory gate designs have not been successful and a commercial unit has been ordered for evaluation. Plug-in type spectrum analyzers to extend beyond the frequency range of existing equipment have also been ordered.

Three samples of aluminum and Zircaloy-2 presumed to have different grain sizes have been measured for longitudinal wave attenuation. Analysis of the data is not complete but from preliminary observations there appears to be very little difference between the three Zircaloy-2 samples. The aluminum samples, however, showed greater differences. Representative samples are being examined for grain size and distribution.

Small steel wire and strip samples of varying size were fabricated for use in wave diffraction measurements in water. Also, two methods of producing small imperfections for diffraction studies in solids appear feasible. One method is to produce small air filled cavities of various sizes and shapes in glass. Cavity dimensions could easily be measured for these test samples. A second method is to use the vacuum hot press technique to form bonds between two identical metal samples. Though the metallurgical interface is essentially removed, the effects on ultrasonic wave propagation are unknown. If the interface is sufficiently transparent to ultrasound it appears feasible to produce a variety of imperfections surrounded by material which appears homogeneous to ultrasound. Both of these possibilities to produce imperfections for diffraction studies are being explored.

Zircaloy-2 Hydride Detection

The eddy current method for detecting hydride in Zircaloy-2 has been successfully demonstrated and is now ready for engineering development of a prototype for in-reactor testing of process tubes. Further studies of the influence of hydride content and other material variables on the eddy current test are being made. Eddy current mapping of the resistivity of two sections of N Reactor process tubing revealed uniform but different resistivities for the sections. Metallographic analysis revealed that the sample with the higher resistivity had a higher concentration of small black areas (believed to be second phase intermetallics of nickel, chromium and iron) in the microstructure.

To demonstrate that hydriding is the primary mechanism of resistivity changes, eddy current maps were made on two samples before and after heat treatment in a vacuum at 400°C for 50 hours. In the absence of hydrogen, no change in average resistivity levels was noted.

Heat Transfer Testing

The theory for a thermal transducer using steady-state sinusoidal excitation has been derived for the plane-wave heat flow case. Practical methods that might be used for producing the sinusoidal excitation are being studied. Also under consideration are transducers using step-function excitation.

Thermographic phosphor has been obtained for use in basic thermal testing studies. Initial tests showed that differences in the thermal diffusivities of lucite, dense phenolic, and quartz can readily be detected by the rate of advance of a thermal step, as indicated by a strip of the phosphor on the samples. The thermal step was produced by a heated brass sheet placed on one of the samples.

Fatigue and Residual Stress Detection

Bars from two types of steel were fatigued in four point bending for use in fatigue detection studies. Eddy current equipment being developed for these studies makes use of the ultra-stable circuit techniques developed previously. In-place eddy current tests on Inconel-X cylindrical samples during low-cycle tensile fatigue tests are also being implemented. Initial tests on probe coils fabricated for the cylindrical samples showed that improvements would be required to eliminate the effects of changes in temperature and sample diameter.

Temperature measurements on the bar samples gradually increased to about 400°C as the sample was fatigued to approximately 95 percent of failure. A more rapid increase was then observed, reaching 475°C at the time of failure. Such a temperature change is typical for samples undergoing rapid fatigue.

Visible surface cracks observed near the time of failure would be detectable by eddy current techniques. Special eddy current probes are currently being developed to determine if such cracks occur and are detectable early in the fatigue process.

Fatigue samples are being prepared to determine if critical angle ultrasonic measurements may be used to determine fatigue condition in metals. Since fatigue life is difficult to determine for metals having unknown history, a group of samples previously tested with critical angle methods are being fatigued with varying loads and number of cycles. This information will be used to accurately determine the percent fatigue for the test samples being prepared.

Detection and Imaging of Ultrasonic Energy

A study was made of the possibilities of using a continuous wave helium-neon gas laser in the detection of ultrasonic energy. By admitting water to the intra-cavity region of the laser, it should be possible to modulate the laser output with an ultrasonic beam and detect ultrasonic beam energies of 1.4×10^{-8} watt cm^{-2} . The study is summarized in Physical Measurements Memo PM 64-4 and an invention report is being prepared.

A recent development in optics may be useful in making ultrasonic images visible. Using coherent light, it has been possible to reconstruct images of objects without the use of lenses. The images are high quality, distortion-free, three-dimensional reconstructions of the object. It appears possible to convert an ultrasonic field into an equivalent light field, thus providing a means of imaging ultrasonic fields. A Physical

Measurements Memo, PM 64-5, and an invention report were written to describe the technique of ultrasonic imaging with a laser.

Nondestructive Testing for Isotope Containment Cells

Ultrasonic wall thickness measurements of prototype isotope containment cells were performed on several units. The thickness of the 0.1 inch wall is measured to a 5 mil accuracy on the side wall and ends of the right cylinder. No measurements were performed on the corners. The same ultrasonic thickness measurements were also made on several empty cells. Thickness profile maps of these units were then prepared. Comparison of the ultrasonic signals obtained from the empty cells to those obtained from the full cells show a change in the ultrasonic properties of the wall and bonding between the wall and filler have occurred in the loaded cells.

Based on the ultrasonic testing experience gained on prototype containment cells to date, a basic general purpose test instrument is being designed. As the full requirements for the ultrasonic tests become known circuits can be added to provide the desired information.

Preliminary feasibility studies on techniques to determine physical and thermal properties of the assembled cell have been conducted. Emissivity independent infrared thermal testing methods previously developed appear applicable to this problem. Infrared tests can be used to determine the uniformity of power emission from the outer cladding surface. Thermal and ultrasonic testing techniques appear applicable to the determination of 1) thermal diffusivity of the fuel core in the assembled cell, 2) residual stresses remaining in the cladding after assembly, 3) uniformity of core heat generation, 4) heat conductance of the cladding material, 5) state (liquid or solid) of core center, 6) internal pressure buildup in cell, and 7) density and grain size indications.

USAEC/AECL COOPERATIVE PROGRAM

Nondestructive Testing of Sheath Tubing

Fabrication and checkout of the final sheath tubing tester were completed. Several minor modifications of the mechanical system were incorporated along with additional electrical controls for added system versatility. By actuating a switch all the mechanical functions necessary for unloading tested tubing and loading untested tubing are accomplished. The operator now only needs to transfer the tubing from its container to the tester and then back again after completion of the ultrasonic test. These operator functions could be performed with a minimum amount of additional mechanics making the entire test station automated.

Stability tests of the system were completed. Following a fifteen minute warm-up period each day the notch standards were measured at two-hour intervals during regular production testing of Zircaloy tubing. Over a two-week period no appreciable change in tester performance was measured and no adjustments were required on the unit. Normal variations in power line voltage and room temperature occurred during this time.

Tests on the system susceptibility to radio frequency noise generated by motors or relays were also completed. When maximum amplifier gain is required these signals occasionally are passed through the gate producing false indications. A portion of this noise is picked up through the main power line while the remainder is picked up by the coaxial cable connecting the tester to transducer. Double shield cable is being purchased and radio frequency suppressors are being inserted into the main power line to minimize the effect of noise.

The tester was also prepared for exhibition at the Third International Conference on the Peaceful Uses of Atomic Energy at Geneva, Switzerland. Graphical displays posters showing principles of the tests operation were prepared and auxiliary controls were added for the exhibit. By actuating a button a short length of tubing with both axial and circumferential notches will be tested. The return signal amplitudes from the one, two and three mil notches will be recorded to show the system sensitivity and linearity.

Approximately two hundred tubes which had been previously tested with commercial instruments were retested by the prototype test station. Although this tubing was certified by the commercial instruments to have no flaws of greater than 3 mils in depth, many deeper short flaws were detected with the thin wall tubing tester.

To meet another testing need, the tester was set up to measure the depth of penetration of a fuel element end closure weld. The 3/16 inch diameter focused transducer was aligned to generate shear waves which were reflected when the weld did not penetrate the wall thickness. The amplitude of return signal was thus proportional to the unwelded area.

BIOLOGY AND MEDICINE - O6 PROGRAM

Atmospheric Physics

Summarization and analysis of air exposure and deposition data obtained during the Iodine-131 release experiment, July, 1963, were completed. Deposition velocities of the Iodine-131 on rye grass plots located 200 meters from the source were found to average one centimeter per second.

This value is consistent with the value currently used for hazard analyses for stable atmospheric conditions. The Iodine-131 was found to be in several physical and chemical forms as indicated by the portion trapped in various portions of the sampling train. Approximately 10% was found on a membrane filter at the sampler face, 70-80% was absorbed on silver-plated copper turnings located behind the membrane filter, and the remaining fraction was absorbed on charcoal traps. Deposition and air exposure data showed that 10-15% of the initial vapor was absorbed on atmospheric particles. The air exposure and deposition values agreed well with those obtained using zinc sulfide particulate tracer.

In studies of the area enclosed within various dosage isopleths, as determined from field test data, it was found that the choice of wind speed for the analysis was particularly critical. Accounting for the spatial variation of wind speed relative to the transport of the plume improved the data correlations but in different ways for stable and unstable meteorological conditions. During stable conditions, the greatest effect appeared to be the change of wind speed with height, while during unstable conditions the change in wind speed along the trajectory appeared to be more significant. The importance of reliable wind measurements downrange during the meso-scale dispersion experiments is very evident from these results.

Radiological Physics

Results of last month's uranium mine study were presented at the Hanford Symposium on Inhaled Radioactive Particles and Gases. These show that almost all of the radon-daughter radioactivity inhaled by a person is retained in the body, most (about 75%) is deposited in the lower respiratory tract, and is not appreciably translocated before the activity decays away. Most of the radioactivity was attached to dust particles less than 0.1 micron in size, regardless of the particle size distribution in the mine atmosphere. The activity of the radium in the dust was small compared with that of the radon daughters. Experts at the symposium said the results were what other methods of study had led them to expect, but the experiment was of great value because it established what actually did happen in people.

A dog that had been counted with the plutonium X-ray counter died and was assayed for plutonium. The results permit a correlation between count rate and body burden. They also indicate that the minimum detectable amount of plutonium in dogs is 3 to 9 nCi depending on what statistical criteria are employed. The plutonium counter was also successfully put to two new uses: Rat feces gave high enough counting rates to permit assay of their plutonium content; this method avoids the chemical separation required in alpha-counting. Radiological Chemistry used the counter

to establish that residues from steps in the chemical analysis of soil samples actually did not contain any plutonium.

The final analysis for the half-life of Pm^{147} gave 2.620 ± 0.005 years. The specific powers of the two samples were 0.3332 ± 0.0005 and 0.3325 ± 0.0007 watts per gram. Measurements made at Mound Laboratory were within 0.1% of these results.

Measurements made to study the characteristics of small calorimeters gave time constants from 1.6 to 14.3 minutes and sensitivities between 6 and 50°C per watt. The time constant proved to be proportional to the sensitivity for time constants longer than 6 minutes. One of the purposes of this experiment was to determine where the proportionality failed.

Instrumentation and System Studies

Several miniature and subminiature GM tubes were received for testing application to the I-131 thyroid dose measurement channel of the experimental animal physiological function and dose telemetry system. Testing was initiated on the detectors.

Fabrication of the animal smoke inhalation control system was nearly completed. The instrumentation will be employed to automatically control air and smoke inhalation in animal biological studies. The necessary modified animal face masks are being prepared by Biology Laboratory personnel.

Investigations were continued in an effort to effect operational improvement of the Biology Laboratory dog counting system. Effort to date has been concentrated on the selection and arrangement of the scintillation detectors to achieve adequate sensitivity, stability, and appropriate spatial resolution. Both 3-inch and 5-inch phototubes were employed in tests. In addition, the mechanical design for a revised scanning mechanism was completed in rough draft form.

Excellent laboratory test results were achieved during two atmospheric inversions on the alpha energy analysis air monitor developed for use during Biology Laboratory radionuclide inhalation experiments. Minor difficulties, which had occurred in one of the commercial scalers, were resolved, and the monitor is now ready for field use.

Fabrication progress was achieved on the Biology Laboratory portable spectrometer monitor, which will be used in field experiments. Most of the required components have been received and printed circuit board layout was nearly completed.

Specific wide band amplifiers were ordered for use in the pulse shape discrimination instrument being developed for use in Radiological Physics dosimetry experiments. Circuit techniques are being developed to considerably reduce background noise, especially at low keV levels, to permit adequate detection of radionuclides, such as Fe-55. Fast tunnel diode discriminators are being employed at present in bench tests.

Circuit development was continued for the peak pulse reader instrument, which is being developed to provide an accurate readout from the pulse ion chamber reading instrument of Radiological Physics. A solid state digital voltmeter was received for possible application to the project.

Preamplifier improvements were developed for, and incorporated in, the experimental plutonium counter-analyzer system of Radiological Physics.

Circuitry development was completed for a special drinking water monitor for measurement of beta-gamma emitting radionuclides in potable water. Preamplifier, amplifier, and appropriate readout circuits were developed.

Detector development work was initiated on an instrument capable of measurement of both neutron and gamma dose rates in mixed neutron-gamma radiation fields.

An analog computer model was developed and demonstrated for the study of the uptake of a radioisotope parent and its daughter in various parts of the body. Provisions were included to observe concentration in the lungs, stomach, small intestine, large upper intestine, large lower intestine, skin, blood, kidney, thyroid, milk, bone, muscle, and other organs simultaneously. Provision is included for inhalation, ingestion, skin contamination, and injection into the blood of arbitrary quantities of the parent and daughter radioisotopes. Demonstration runs were completed which included single and multiple injections of combinations of parent and daughter isotopes of Te^{131} - I^{131} and Te^{132} - I^{132} . Single intake and multiple intake studies were completed. Multiple intake studies included those with constant rate of input of radioactivity, and decaying input of radioactivity. Effects were observed for cows and for men with the various conditions of uptake. The simulation can be used for other isotopes and for other animals. The change-over requires a change in the coefficient potentiometers which define the characteristics of the animal or man being studied. The results were presented at a Biology seminar where much interest was shown in the general approach and the application of the analog computer to this type of study.

WASHINGTON DESIGNATED PROGRAMIsotopic Analysis Program

Isotopic analyses were provided on program samples during the month in accordance with current schedules.

The program mass spectrometer equipped with the new scintillation-type ion detector and an ion-counting system was put into routine operation during the month. Performance studies of the instrument will continue, however.

The magnet-sweep coil of the mass spectrometer became shorted to the magnet pole faces and had to be replaced. A new coil was wound on a Lucite form and potted with epoxy resin to prevent flexing during rapid field-switching. The new coil is presently being installed.

Delivery of acceptable alumina parts for a vacuum-lock sample changer for the mass spectrometer has been scheduled by the vendor for mid-June.

Modifications to the ion-optical test bench are in the design stage.

EXPERIMENTAL REACTOR PHYSICS FACILITIESPCTR Operation

The PCTR was operated on an intermittent basis during the month. There were no unscheduled shutdowns. Six sets of foils were irradiated for normalization purposes. A group of NPR fuel elements was irradiated with mica fission fragment detectors attached to detect the presence of uranium in the welds. The PCTR was operated twice for the University of Washington Graduate Center. An experiment was partially completed to measure the epithermal cross section of zirconium.

TTR Operation

The TTR was operated on an intermittent basis during the month. There was one unscheduled shutdown due to electronic failure.

The reactivity loss associated with loss of water from a fuel column was measured. The removal of 200 mil of water from one tube caused a loss of 14.67 cents in reactivity. The removal of 200 mil of water from an adjacent tube resulted in a 14.72 cents decrease in reactivity.

Subcritical Facility

The experiment with the 0.93 inch lattice and EBWR fuel was completed during the month and the 0.60 inch lattice with EBWR fuel measurements was started.

COMPUTER FACILITIES

A work order was processed for installation of the experimental digital control computer at the 321 Building. The work includes signal and electrical wiring, terminal board installation, and water and drain facilities for the air conditioner.

The analog computer utilization was as follows:

<u>EASE 1132</u>	<u>EASE 2133</u>	
147	127	Hours Up Time
21	22	Hours Scheduled Downtime
---	<u>19</u>	Hours Unscheduled Downtime
168	168	Hours Total

Problems considered during the month were:

1. N Reactor Cold Water Injection.
2. N Reactor.
3. TTR (Thermal Test Reactor).
4. ANN Recovery (CPD).
5. Radioisotope Disposition in Animals.

The new analog computer is in full operation; however, the problem of synchronization between the iterative control units has not been corrected. The manufacturer has been contacted and has agreed to correct the problem.

CUSTOMER WORKWeather Forecasting and Meteorological Services

Meteorological and climatological services included 1) summarization and interpretation of wind measurement from the reactor areas toward the Wahluke Slope for HL, 2) consultation on dispersion and deposition calculations applicable to the Wahluke Slope for HL, and 3) meteorological support for aircraft sampling to HL.

A climatological summary for the Hanford area for the period 1912-1963 was completed. The mid-May forecast of Columbia River Temperatures and Flood Crests predicts substantially greater flow rates and lower temperatures this year than last.

Meteorological services, viz., weather forecasts and observations, and climatological services were provided to plant operations and management personnel on a routine basis.

Weather Summary

<u>Type of Forecast</u>	<u>Number Made</u>	<u>% Reliability</u>
8-Hour Production	93	84.0
24-Hour General	62	83.3
Special	173	89.6

The long dry period continued with only 0.04-in. precipitation recorded during the month. This raised the January-May total to 0.56-in., which is far below any previously recorded amount for the period.

May temperatures averaged below normal with near freezing readings reported on two days.

Mass Spectrometry

Isotopic analyses were provided on 10 uranium samples in support of the U^{236} buildup study of IPD Research and Engineering. Isotopic analyses were also provided on 3 uranium samples in support of the Plutonium Regenerating Detector Experiment of Nucleonics Instrumentation. Four additional analyses of NBS plutonium standard sample 948 were performed.

A report (HW-81507) was issued on 14 previously completed uranium isotopic analyses in support of the Enrichment Test II of Testing Methods Engineering.

Transport Theory Consultation Work

In response to a EURATOM-funded request from Vallecitos Atomic Laboratory, two man-weeks of Theoretical Physics consultation services were provided to assist Vallecitos in modifying Hanford's machine analysis of multi-energy transport theory (GE-HL Program S) to obtain as additional output a leakage-preserving diffusive smear of the transport field. The work progressed to satisfactory completion a bit ahead of schedule and well within allocated funding.

Instrumentation and System Studies

Considerable progress was achieved on the experimental face mask monitor being developed for use at the BAPO Laundry Facility. The Lucite light pipe, in the general shape of a head, was completed. The masks will be laid over the scintillator-covered light pipe for the measurements. Tests with properly crushed anthracene scintillation material indicate that detection can be achieved for Em-147 (a soft beta emitter) in the range of 10 to 20 nCi amounts.

An accurate one-minute timer instrument, which employs all solid state circuitry, was developed for use by meteorologists during balloon-tracking experiments. The small battery-operated instrument provides an audible signal once per minute.

Design work was initiated on a new aerial monitoring instrument, to be carried by project aircraft, for the determination of radionuclides on the ground throughout Hanford. The project was undertaken for Regional Monitoring, HL, and will include a large scintillation detector, solid state circuitry, and suitable readout and recording.

The Control Data Corporation temperature comparators to be used as out-of-limits detectors at the 100-KW creep capsule test facility arrived this month. Circuitry was designed and built to integrate the comparators into the system. The circuitry included high-low setpoint dials, deviation indication, trip indication, calibration jacks, and regulated power supply. The complete unit was calibrated and checked out and will be installed shortly.

Design work was begun on a digital temperature programmer to be used by Physical Metallurgy for temperature cycling a stored energy calorimeter. The programmer will introduce ramp function temperature inputs to the calorimeter at selectable rates.

Purchase specifications are being written for a shaft position encoding system to be used by Reactor Metals Research on the creep program. The new system will be installed at the FRER.

The Reactor and Fuels Laboratory is constructing a high temperature gas loop for evaluating the effects of high temperatures on various materials. An analog computer simulation for the system is in progress and most of the basic equations have been derived.

The new sense amplifiers for the 400 channel analyzer for the Van de Graff Laboratory were built and installed in order to provide more reliable opera-

tion of the memory system under more extreme temperature conditions. A paper tape punch was installed on the analyzer which allows numerical as well as coded information to be punched out on paper tape.

Instrumentation system planning continued for work planned under the Containment Systems Experiment. No problems have yet appeared that are insurmountable. A conventional instrumentation system will not be suitable. A data acquisition system such as used for missile launch will be required.

Scoping work on the facility to inspect waste storage tanks in support of the Waste Solidification Development Operation continued. Efforts during May were on the wall thickness and internal pressure measurements. A bench mockup of an 8" diameter 304 stainless steel tank has been fabricated and is being used to evaluate pulse echo and resonant ultrasonic methods of wall thickness measurement at temperatures of 400°C. Tests conducted indicate that 1/2" diameter flat transducers provide adequate coupling with only small amounts of water at room temperature using a resonant system. A turntable rotating sample is being assembled. A novel pressure gauge has been designed to measure both positive and negative pressure inside the tank, without compromising tank integrity. The sketches have been submitted to the Waste Solidification Development Operation for review and comment.

Optics

A Pan Bore camera is being developed which will photograph in one picture the complete inner surface of an N Reactor fuel element. The picture will be continuous and undistorted. During the month, the 24-inch probe bore-scope used on this camera was fabricated and assembled. An aluminized steel ball works well as an objective lens for this application. It provides a view of the inner circumference of a tube such that the field viewed is approximately at right angles to the line of sight. The only image area lost is that covered by the two 0.018 inch diameter electrical leads. These are so located as to coincide with the region of film overlap where some image would be lost, anyway.

The O-ring friction drive originally planned for use in transporting both film and camera proved inadequate. The unit was redesigned to use gears.

The characteristics of commercially available zoom lenses were reviewed and a lens suitable for use with the Redox crane periscope was found. A recommendation was made for the installation of the zoom lens and sketches showing the manner of mounting on the crane periscope was furnished.

During the four-week period included in this report, the following shop work was performed:

1. Thirty-four (34) glass bearings were fabricated for CPD.
2. An underwater periscope was repaired at 105-F Building.
3. A laser head was modified.
4. Parts for the camera to photograph resistance temperature detector units were fabricated.
5. Four rods of waste containment glass were fabricated and polished.
6. A sighting mirror stadimeter was modified.
7. A metallograph was serviced.
8. Two hundred fifty-six (256) stainless steel rods were coated with aluminum for Advanced Fuels Development.
9. A thermistor temperature detector probe was fabricated for PRTR.
10. Four non-darkening lenses were fabricated for a KE underwater periscope.
11. A notch punch instrument was modified for Physical Measurements.
12. Numerous small machining and glass cutting jobs were performed.

Physical Testing

Weld bevels on the head and shell of N-Reactor Steam Generator 4A were magnetic particle inspected prior to making the head to shell butt weld. Magnetic particle inspection was also performed on all crane and hoist equipment in 327 Building, 300 Area, to determine the safety condition of the critical components and to aid in preventative maintenance. Radiography for weld integrity and code compliance was conducted on the Ammonium and Lithium Hydroxide lines in the 184 Building, 100-N Area, the Rupture Loop, HX-1 System, and NPC 212 in "A" cell at PRTR. New stainless steel tubing for the D-14 Vessel Tube Bundles was radiographically and fluorescent penetrant inspected prior to rolling of the coils. The tubing was rejected and better quality is required before fabrication may continue. Fluorescent penetrant examination was conducted on the E, D, F type vertical control rods being fabricated by plant forces in the 189-F Building, 100-F Area.

Engineering assistance in the development and operation of instrumentation has resulted in the successful completion of a program to measure the electrical resistivity as a function of density during alpha to beta phase transformation in plutonium. The electrical resistivity and density, during an alpha to beta phase transformation, were recorded simultaneously. The weight changes were recorded by observing the beam deflection of Mettler single-pan balance. The resistance changes were made using the volt-ammeter principle. This method eliminated error due to external resistance and resistance changes in the measuring circuitry. The experiment has been

completed and the results show that the resistivity and density changes during the phase transformation occur at the same time and in equal percentages.

Five mil chromel and alumel wire have been successfully welded to an inconel strip. A 16 microfarad capacitor bank charged to 500 volts was used as the energy source. Due to the high resistivity of the fine thermocouple wire, it was learned that higher energies were required for a good weld when connecting to a long length of wire. Shorter lengths are desirable and produce better welds.

Ultrasonic translator leak detection was successfully applied to the detection of leaks into glove boxes maintaining a negative pressure. The Dry-Air systems of the 234-5 Building were scanned with the ultrasonic translator. The detected leaks were repaired or tagged for future maintenance.

Examination of remote energy source fuel cells to measure wall and end thickness variations continued with examination of five cells. Two of the five cells were examined prior to loading with no variations in wall thickness noted. The other three cells were examined after loading and were found to have variations which could be caused by the contour and rough O.D. surface of the piece. The test measures wall thickness within $\pm .005$ inches.

A pulse echo ultrasonic test was made to test the bond integrity of zirconium and caps welded to LCO-N fuel element end closures. Several fuel elements were fabricated using different welding techniques. The elements were tested to determine bond integrity of each prior to destructive analysis.

Three tantalum tubes, two of 0.250 inch O.D. by 0.020 inch wall and one of 1.030 inch O.D. by 0.015 inch wall, were ultrasonically tested to study any test problems encountered. The small diameter tubes were tested satisfactorily; the large tube was not, due to a noisy ultrasonic background. Metallographic examination revealed numerous defects in the grain boundaries of the material.

All of the 3,798 tubing ends from heat exchanger 4A were checked for identification of the heat treat numbers. The numbers were listed as to the row in which they were located and recorded in code form on heat exchanger data sheets. The data sheets were used to determine if the corrosion pattern of the heat exchanger tubes correlated with the heat treatment process. No correlation was in evidence. The examination of intergranular corrosion patterns in heat exchanger 4A was made with selection of

ten tubes containing eddy current indications extending through the bend and at least eight feet on each side of the bend. Eddy current traces were run to show locations of tube supports and spots of intergranular corrosion. The tube sections were fluorescent penetrant tested and all indications recorded.

Zircaloy-2 samples, fabricated with known quantities of uranium, were tested by the fission fragment track method. The samples are standards for determining the sensitivity levels in alpha counter and X-ray fluorescence tests. The track density method proved to be a valuable tool for measuring the uranium content in the samples and illustrating the variation of uranium concentrations within each sample.

Radiography of 160 EBWR fuel rod ends were made for taking direct measurements of distance between end of core material and the inside face of the cap. The information is used to determine if each fuel rod contains the required amount of fuel material prior to off-site shipment.

An eddy current test was completed on one PRTR process tube which had developed an I.D. blister. The blister was located and plotted for circumferential and longitudinal position, length, width and an estimated depth. Locating and taking measurements of defects in these tubes has proven to be practicable.

The eddy current test equipment was adapted to test the condition of the molybdenum heater elements from the high temperature gas loop that had been damaged in shipment. Cracks in the elements could be located from a distance of one-quarter inch.

INSTRUMENT EVALUATION

A total of four, of the first seven offsite fabricated, combined alpha-beta-gamma scintillation and solid state circuitry hand and shoe counters are now in regular, satisfactory plant service. The other three are ready for delivery.

Three other hand and shoe counters, which were fabricated offsite by a different company, are being tested. The quality of these units appears to be inferior to the quality of the seven units tested earlier. All ten were made to the same HAP0 specifications and detailed blueprints.

One pre-production Juno portable radiation survey instrument was evaluated and accepted.

Acceptance tests were completed on 12 high range CP-TP survey instruments. These will be used in the HAPC emergency monitoring kits.

An experimental logarithmic and linear response scintillation area radiation monitor was recalibrated for use in the 325 Building. Maintenance instructions were prepared.

RS Paul

Manager

PHYSICS AND INSTRUMENTS LABORATORY

RS Paul:mcs

DECLASSIFIED

C-1

JUL 82 128

CHEMICAL LABORATORY
RESEARCH AND ENGINEERING

FISSIONABLE MATERIALS - 02 PROGRAM

IRRADIATION PROCESSES

Uranium Metal Surface Studies

Laboratory studies of procedures for preparing uranium metal surfaces for electroplating with nickel have continued, with further investigation of the effects of the use of H_2SO_4 -HCl solutions for the anodic etch step in place of H_3PO_4 -HCl solutions. Polarization curves were run in a variety of nickel plating baths, using uranium cathodes given the two different etch pretreatments. The results of these measurements give further evidence that the advantage found with the H_2SO_4 -HCl etch solution lies in the fact that it leaves a thin protective film on the uranium which allows an even plating action and serves as a base for an adherent, minimum-porosity coat. In another experimental series, the dependence of nickel plate porosity upon anodic current density in the anodic etch step (in H_2SO_4 -HCl) was investigated. Anodization at a current density of 59 ma/cm² for four minutes was found to give as good results as any conditions studied, although it is felt that comparable results can be achieved at any practical current density, provided the right corresponding etch time is used.

Besides the improvement in nickel plate porosity achieved through the use of the H_2SO_4 -HCl etch, an added benefit lies in a great reduction in the amount of uranium which has to be removed in the surface pretreatment. Calculation of uranium losses during a four-minute etch in 6 M H_2SO_4 -0.32 M HCl at 59 ma/cm² showed them to be 60 percent lower than during the standard H_3PO_4 -HCl etch.

SEPARATIONS PROCESSES

Thoria Dissolution Studies

Thoria which was prepared by the sol-gel process dissolved less rapidly in the nitric acid-hydrofluoric acid-aluminum nitrate dissolvent proposed for Redox use than did thoria which had not been gelled following denitration. The difference in dissolution rates is about a factor of two although these differences are modified somewhat if the thoria has also been pneumatically impacted or pelletized.

Scrap Recovery Flowsheets

Final mini-mixer-settler runs to test and optimize flowsheet conditions proposed for 234-5 Building processing of scrap containing plutonium, uranium and thorium were completed. Desired specifications for uranium were easily met. Other analytical data on the runs are not yet available.

Purex Ventilation Filter Problem

A period of high pressure drop across the Purex ventilation filter occurred recently as a result of a gray crust containing large quantities of ammonium nitrate. An experimental program was undertaken to study crust formation and water washing of the filter. During the program, the experimental filter was loaded incrementally with a "dust" composed of Fe_2O_3 , NH_4NO_3 , and sand. Whenever the relative humidity of the inlet air was increased above about 60 percent, the pressure drop across the filter decreased, the dust shrank down, and wet patches of liquified NH_4NO_3 developed on the dust. Upon drying a hard brown crust developed, but no significant increase in pressure drop occurred. This indicates that high humidity can be used to reduce pressure drop across the filter. During a drying cycle after a limited water wash of the brown crust, a hard white crust of NH_4NO_3 crystals developed and a pressure drop increase of about 3 inches of water occurred. This suggests that considerable NH_4NO_3 liquification is required to produce a sudden pressure drop increase during a drying cycle. Additional water washing successfully removed the crust and reduced the pressure drop to near the initial start-up value.

Ion Exchange Hazards Test

Testing of anion exchange resin thermal-chemical stability on a 4-inch pipe diameter scale is clarifying the conditions required for safe anion exchange contactor operation. No run-away exothermal reactions have been observed at exterior temperatures of 110 C or less. No charred beads have been produced in tests with damp resin confined by 730 psi rupture discs. Unconfined resin equilibrated and damp with 7 M nitric acid is not inflammable.

Plutonium Slag and Crucible Dissolver

A modified design of the plastic-lined slag and crucible dissolver for the Plutonium Reclamation Facility has been completed. This unit provides additional surge capacity plus recirculation paths to increase the relatively slow phases of the dissolution. It should minimize the pressure surges experienced because of the rapid reaction of the canned slag and crucible materials.

DECLASSIFIED

DECLASSIFIED

Technetium Processing

The 90 liters of technetium product resulting from ion-exchange purification were denitrated with formaldehyde and concentrated to a volume of 4.5 liters (ca. 200 g technetium/liter). The concentrated product was filtered to remove a trace of silica and the technetium then precipitated batch-wise as ammonium pertechnetate (NH_4TcO_4). Precipitation, filtration, and washing of the pertechnetate were carried out at reduced temperature (ca. 2 C) to minimize losses, the pertechnetate crystals (1540 grams) dried in a vacuum oven (80 C at 8" Hg), ground to a powder and weighed. The radiochemical purity is greater than 99.99 percent on an activity basis and metallic impurities are less than 50 ppm (spectroscopic limit of detection). A suitable furnace is being installed in a hood for hydrogen reduction to metal. The final metal product should be available by July.

Spray Calcination of Thorium Nitrate

The production of very pure thoria, low in nitrate and moisture content, by radiant heat spray calcination was reported several months ago (HW-80560 C). Although the powder was very suitable for either cold pressing or for pneumatic impaction, it appeared not suitable for the sol-gel process since a stable sol was not obtained when it was dispersed in water. It has been recently found that the thorium nitrate feed solution used in the experiments also does not form a sol when steam denitrated - due to high sodium impurity. Another spray calcination has accordingly been made, but with pure thorium nitrate. A stable gel resulted. Additional spray calcination runs will be made to optimize conditions.

Polonium Studies

Studies have begun to explore the feasibility of separation of polonium from bismuth by sublimation. Thermobalance studies showed no weight change (hence no evidence for Bi_2O_5 formation) when Bi_2O_3 was heated under 5 mm Hg oxygen pressure to 850 C. A small weight loss was observed when the sample was heated slowly from 710 C to 798 C at a total pressure of 10^{-5} mm Hg. From this weight change a value of approximately 10^{-4} mm Hg was estimated for the vapor pressure of bismuth oxide in this temperature range, using several rough approximations. Equilibrium was evidently not obtained in initial transpiration experiments using argon as the carrier gas in that a varying Bi/Ar ratio was observed. From the data obtained a limit of 10^{-3} to 10^{-4} mm Hg can be placed on the bismuth oxide vapor pressure at 800 C.

The addition of 1.3 w/o Ce metal to bismuth containing polonium resulted in concentration of 81 percent of the Po-210 in five percent of the bismuth. This was demonstrated by an experiment, described earlier, and it was assumed that segregation of cerium bismuthide and consequent carrying of cerium polonide was responsible for the separation. This has now been confirmed by cerium analyses of these samples. It is found that the cerium and Po-210 concentration profiles are very similar. Throughout the bulk of the ingot the average cerium concentration was 0.7 w/o and the Po-210 concentration was 3×10^6 d/m/g. At the top end, on the other hand, the cerium concentration was 9.8 w/o and the Po-210 concentration was 1.18×10^8 d/m/g.

Disposal to Ground

A new well sampling and analysis program, now in preparation, will include routine monitoring of piezometer tubes already in place and those to be installed in the near future. Information gained from analysis of the piezometer tube samples will provide a more precise three-dimensional picture of ground water contamination patterns.

Information on core-drilling techniques and costs, and in-hole investigation techniques is being assembled in connection with a possible exploratory program to determine the feasibility of storing aged high-level wastes in deep basalt (bedrock) formations locally. A proposed (joint HL-CPD) investigation program is expected to be firmed up by early July.

WASTE MANAGEMENT AND FISSION PRODUCT RECOVERY

Cesium Removal from Redox Alkaline Waste

Waste solution from the Redox 115-SX tank diluted with three parts of water was passed through a column of Duolite C-3 resin. One percent breakthrough occurred after the passage of 29 column volumes of diluted waste (7 column volumes of undiluted waste). This is about a 50 percent increase in volume to breakthrough over previous runs with the same waste. The resin used in the latest run had been sodium based by recycling acid and caustic several times; in previous runs the resin had been contacted with changes of caustic for several hours each. Work is continuing on firming up flowsheet conditions.

Physical Stability of Synthetic Zeolites

Laboratory tests were conducted to determine the amount of fines produced when synthetic zeolites are shaken with water. Ten-gram samples of dust free, 20 x 50 mesh zeolite were vigorously shaken with 50 ml of water for 4 hours on a wrist-action shaker. The zeolite was then wet

DECLASSIFIED

DECLASSIFIED

C-5

HW-82428

sieved, and the water and fines passing a 100 mesh sieve were collected. The waste was evaporated and the weight of fines determined. The percent fines determined for Linde AW-500, 4A, 13X and AW-400 were 6, 14, 20 and 62, respectively. The reason for the large difference in physical stability between AW-400 and AW-500 is not known at present. The bonding agent for these two zeolites is the same. Results of these tests will be useful in establishing methods of improving the physical stability of the synthetic zeolites.

CSREX Solvent Stability Studies

The rate of destruction or inactivation of BAMBP in CSREX process solvent (BAMBP-D2EHPA-Soltrol) during coincident irradiation and contact with process aqueous solutions was not changed by substitution of sulfate for nitrate in the aqueous feed (LAF) and strip (LCX) solutions. Nitrate concentration does not appear to be a controlling factor in the destruction mechanism.

Strontium Purification by CSREX Solvent Extraction

A process for purifying a strontium "crude", such as might be produced by the CSREX process in the Waste Management Program, was demonstrated. The successful procedure involved extracting calcium and cerium away from the strontium. The "crude" was adjusted to 1 M hydroxyacetic acid, pH 3. A scrub column using 1 M hydroxyacetic acid at pH 1.8 was supplied to reflux any extracted strontium back to the extraction column. Calcium, strontium and cesium DF's were >1000, 830 and >15, respectively.

Strontium Lead Sulfate Carrier Precipitation

Two hydroclones, 0.6 and 1.5-inch diameter, were unsuccessfully tested for their ability to separate a lead carbonate precipitate from its supernatant solution. The poor separation was attributed to the sub-micron size of the precipitate particles. Undisturbed settling rates are much higher than would be expected with sub-micron particles and are attributed to coagulation of the precipitate.

The use of hydroclones is not recommended at this time, however, simple settling and decantation should prove satisfactory. About 97 percent of the strontium was accounted for in one run through the complete precipitation dissolution cycle using only decantation through two drums in series to separate the precipitate from the supernate.

Ion Exchange Recovery of Cesium from Alkaline Wastes

A study of the operating parameters (kinetics and scale-up factors) for the ion exchange removal of cesium from a synthetic Purex alkaline supernatant waste with a zeolite, AW-500, resin was conducted. A 2-in. diameter variable height column was used. Nine test runs were conducted over the range of 3 to 40 column volumes per hour and 0.25 to 2.0 gal/min/ft. Although additional data are being sought, ± 10 percent prediction of break-through under practical conditions is now possible.

Waste Packaging

Experimental investigation of radiation-induced recombination of hydrogen and oxygen in H_2-O_2 zeolite systems was continued with encouraging results. Hydrogen conversion rates of 1.7 percent per hour were observed in the presence of dry Linde 4A zeolite, at a gamma dose rate of 7.8×10^5 r/hr. Further studies are planned, using zeolites of different water content. The results of the tests will be of use in predicting the behavior of incompletely dehydrated zeolites loaded with radioactive materials.

In-Tank Solidification

Bench and pilot scale testing of the immersion heating method for in-tank solidification continued. Previously reported difficulties with solids deposition in the vapor space above the circulator have been overcome by relocation of the condensate reflux line. Approximately 1000 hours operation have been accumulated on each of several heater designs and solution compositions, with no scaling of the heat transfer surfaces. One of the bench-scale tests is being conducted in a gamma field of 20,000 r/hr.

The generally encouraging results from this series of tests has led to the initiation of plans for a test using full scale heating elements in a 200-E area tank containing intermediate-level wastes.

Purex Tank Sludge Studies

Hot cell studies continued with a sample of Purex 103A sludge. Partial analytical results have been obtained from the first run (performed last month) and a second run has been performed. Results appear very promising, at least from the standpoint of strontium removal and recovery, with over-all strontium recovery, through the lead sulfate precipitation step, duplicating previous laboratory experience and exceeding 95 percent. It is particularly noteworthy that the use of Na_2CO_3 (vice organic reagents) to complex iron (cf. Invention Report HW-79286) was fully as successful as with "cold" solutions.

DECLASSIFIED

DECLASSIFIED

C-7

HW-82428

REACTOR DEVELOPMENT - 04 PROGRAM

PLUTONIUM RECYCLE PROGRAM

Salt Cycle Process

Equilibrium Constant for the Reaction $UO_2 + UO_2Cl_2 = UO_2Cl$ - A rigorous derivation for calculation of the equilibrium constant for the reaction $UO_2 + UO_2Cl_2 = UO_2Cl$ from electrochemical data was made. The constant was found to be 1.2×10^{-2} at 713 C in the NaCl-KCl melt. This value is not greatly different from that previously reported, but is considerably more reliable.

Engineering Development - Two electrolyses were performed since the last reporting period. The first was run at 40 amps while sparging with 2.7 l/min O_2 and 0.3 l/min Cl_2 for 39 hours. An 8-pound deposit was obtained having a plutonium content of 1.6 weight percent, corresponding to a plutonium enrichment factor of 1.3. The oxygen to uranium ratio was 2.07. The deposit, unsuitable for recycle material, was reoxidized and returned to the salt bath with some additional U_3O_8 . The second electrolysis run under identical conditions for 60 hours produced an 8.5 pound deposit with large dendritic crystals on one side of the cathode indicating that one anode may have been disconnected. The plutonium content of the deposit was 0.6 corresponding to a plutonium enrichment factor of 1.1 and the oxygen to uranium ratio was 2.1. In each of the above mentioned cases, the HCl gas was left on for several hours after the start of the electrolyses and could possibly account for the high oxygen to uranium ratios.

Dissolution of PRTR UO_2 - PuO_2 Fuels

The most promising procedure yet found for Redox dissolution of PRTR UO_2 - PuO_2 fuels involves Zirflex decladding; exposing the core material for two hours at 80 C to 11 M HNO_3 -0.1 M HF; butting the core dissolver to 0.3 M $Al(NO_3)_3$ and holding at boiling for one-half to one hour. This procedure has been shown to dissolve completely sections of non-irradiated and irradiated (2000 Mwd/t) incrementally loaded, swaged, 0.5 percent PuO_2 fuels and non-irradiated, pneumatically impacted, swaged 1 percent PuO_2 fuel. Of major concern is corrosion of heat exchanger coils during core exposure at 80 C without aluminum present. Redox personnel are currently evaluating other means of supplying heat to the dissolver.

Burnup Measurements

A new direct instrumental method for the precise measurement of Cs-137 in the normal radionuclide mixture obtained from fuel element dissolution has

been devised. The method involves counting the sample in a 4π geometry with a beta detector while viewing the sample with a NaI(Tl) detector for normal gamma-ray spectrometry. The Cs-137 decay involves emission of a beta particle to give Ba-137 (2.6 min) which in turn decays by isomeric transition to stable Ba-137. Since all the other long-lived gamma-ray emitting fission products decay by prompt beta-gamma coincidence, Cs-137 can be selectively measured by a beta-gamma anti-coincidence measurement of the gamma-ray spectrum. Discrimination against other fission products by this technique is thus directly related to the efficiency with which the beta particles are measured. To date, the best obtained beta counting efficiencies for the major interfering radionuclides Zr-95-Nb-95 and Ru-106 have been 95 and 98 percent, respectively. This was obtained by liquid scintillation counting of the beta particles. This reduces the interference from Zr-95-Nb-95 and Ru-106 in the measurement of Cs-137 by factors of 20 and 50, respectively, and allows the direct precise counting of Cs-137 in a two-year old fission product mixture.

RADIOACTIVE RESIDUE PROCESSING DEVELOPMENT

Hot Cell Calcination Studies

One full-level spray calcination run was made to test the reliability of the sampling techniques (Millipore membrane filters) used for analytical purposes in previous runs. It had been suggested that a major fraction of the ruthenium might have passed through these filters, resulting in deceptively high ruthenium decontamination factors. For this run, which used Purex waste with added sulfate and sugar (50 g/l), each membrane filter was backed up with a (reputedly) highly efficient absorber of shredded polyethylene. Very little (less than ten percent and generally less than one percent) of the off-gas ruthenium passed through the membrane filters and collected on the polyethylene. Conclusions regarding ruthenium behavior, drawn from previous runs are thus apparently confirmed, and dismantling of in-cell equipment (not needed for continuous glass making) will soon begin.

A second pot was sectioned and examined during the month. This was from Run 22 which employed Redox waste with borate addition. The glass was uniform in appearance and appeared identical to that produced in "cold" runs. A few dime-sized white spots on the surface (which autoradiography showed to be less radioactive than the bulk of the glass) are probably excess boric oxide driven out during melt down. Samples of the glass were taken for analysis and solubility measurements.

DECLASSIFIED

DECLASSIFIED

C-9

HW-82428

Glass Composition Studies

A program (based on statistical design) is underway to define the effect of composition and fission product content on the properties of phosphate glasses. Measurements are being made of phosphate loss on drying and melting, drip temperature, sulfate retention, and solubility. Corrosion of candidate container material is also being examined.

Cold Semiworks Spray Calciner-Melter

During the month, the continuous melter was coupled to the 18-in. spray calciner and the combination successfully operated. Initial runs were made with a simulated Redox waste containing either boro-silicate or boro-phosphate additives. The boro-phosphate modified feeds foamed badly and limited operating rates. The boro-silicate modified feeds exhibited very little foaming.

Phosphate Glass Process Studies

Effects of varying feed composition on the operability of the waste concentrator (first step in the BNL phosphate glass process) and on product composition are being studied. Simulated Purex process wastes are concentrated in a laboratory-scale (250 ml working capacity) continuous concentrator. Feed stability, tendency to gel, density, viscosity and nitrate concentration in the bottoms are observed as a function of feed composition, ratio of phosphate to metal ion equivalents in the feed and boiling point of the concentrator bottoms.

CONTAINMENT SYSTEMS EXPERIMENT

Major Facilities and Equipment

The contract for the containment vessel, including the dry well and wet wells, was awarded to the Chicago Bridge & Iron Company. Completion of the vessel is scheduled for March 31, 1965. Bid opening on the reactor simulator vessel was postponed an additional week, to May 22, at the request of vendors.

All principal scope flowsheets except the vacuum sampling system were completed, approved and issued to Vitro Engineering for detail design. Scope drawings for the vacuum sampling system and the laboratory arrangement are in preparation.

Modifications to T-Plant are on schedule. Demolition of the pillar and beam in Cells 1 and 2 was started, and an opening was made in the shielding wall between these cells and the head-end area.

Aerosol Generation

To provide design data for the May-pack samplers to be used for CLE, various components are being tested for iodine and particulate removal. With a methylene blue-uranine aerosol, 0.23 μ MMD, the following removals on Cu were measured:

Particle Removal on Iodine Adsorbers

<u>Flow,</u> <u>ft/min</u>	<u>Wt. % Particles Removed, 0.23 μ MMD</u>	
	<u>3 layers</u> <u>Cu screen</u>	<u>2" long Cu</u> <u>ribbon bed</u>
82	0.14	0.45
260	0.11	0.42

These data indicate low retention of particles in the iodine adsorbers, which is desirable. The work will continue to evaluate iodine retention on particle filters.

DECLASSIFIED

DECLASSIFIED

C-11

HW-82428

BIOLOGY AND MEDICINE - 06 PROGRAM

TERRESTRIAL ECOLOGY - EARTH SCIENCES

Hydrology and Geology

The range of grid spacings for use in the digital solution of very large ground water flow systems was examined. Results of closed form solutions for an area comparable in size to the Hanford project indicate that a 40- to 50-foot spacing in depth is realistic. The same work provided estimates of the errors associated with the larger grid spacings that may be used in the horizontal directions.

New equations were found which fit experimental soils data much better than those formerly used. The method has been finalized for using these equations in the computer to internally calculate the diffusivity as a function of saturation; thus, the necessity for graphically handling the input data is eliminated. These results are now being applied to the solution of one-dimensional, transient partially-saturated flow systems.

Contractor direct labor costs and time required to modify (install piezometer tubes) wells closely approaches estimates for those wells. An appraisal of methods used indicates that cable-tool drills, modified with rotary-table attachments and mud pumps for circulation of drilling mud, appear preferable to pure rotary equipment because of their greater versatility and adaptability. Modification and rehabilitation of the first five of ten wells on Subcontract No. JAJ-197-A have proceeded on schedule.

RADIOLOGICAL AND HEALTH CHEMISTRY

Radiation Chemistry

Investigation of the mechanism of radiation induced erythrocyte hemolysis was continued. Wursters Blue, which is a stable cationic free radical, was synthesized and its relative reaction rates with protein constituents and red blood cells were compared with those of the hydroxyl radical. Wursters Blue was found to have an entirely different pattern of discrimination in its reactions with amino acids and was less toxic to red blood cells than hydroxyl radicals. It may therefore prove to be a good protective agent for red blood cells.

The ESR spectrum of the (PNA) paranitroaniline radical produced by passing a sodium hydroxide solution of PNA through the Co-60 irradiator was re-examined for the possible presence of hydroxy substituted PNA. The spectrum obtained in this laboratory agreed with the spectrum of an

electrochemically produced ESR radical spectrum and a calculated spectrum. This indicated that a large percent of the PNA radicals (probably greater than 90 percent) has no hydroxy substitution.

ATMOSPHERIC RADIOACTIVITY AND FALLOUT

Aerosol Sampling Study

Initial measurements of sampling errors were made at a wind speed of 30 mph after the fan drive in the test loop was changed to permit the higher flow. The impaction efficiency of 2-in. filters in standard holders was found to be 0.0006, 0.002 and 0.006 for 3, 4 and 6 micron ZnS particles, respectively. The efficiencies noted are surprisingly similar to those obtained for a much lower windspeed, 2.7 mph. Non-uniformity of deposit, electrostatic effects and removal of particles from the filter at the higher windspeed are suggested as possible causes for the experiment not showing a higher efficiency in every case at the higher speeds. An examination of the filters held in the 30 mph wind stream showed deposition patterns which reflected the influence of the filter holder geometry, filter support media, and filter surface flatness. The observations gave strong indications of the sampling difficulties to be resolved at higher air speeds.

Aerosol Generation and Characterization

The study of generators for single size particles was reactivated. Uranine-methylene blue particles 2 to 10 microns in diameter were consistently generated with the spinning disc instrument. Particles smaller than 2 microns were irregular in shape. An electrical charge detector was designed to characterize the electrical properties of the aerosols produced in these and other experiments.

Fallout Studies

Measurements of the radionuclides Na-22, Cs-134 and Cs-137 have been made in tissue samples from Alaskan caribou taken before and after the above-ground atomic test series which began in late 1961. The ratio of Na-22 to Cs-137 in the samples taken after the tests (July 1963) were 4 to 20 times higher than those taken prior to the tests. During this same period the ratio of Cs-134 to Cs-137 decreased by a factor of 4. In concentration units the Na-22 was also an order of magnitude higher in the mid-1963 samples than the 1961 samples. This would suggest that during the test series considerable amounts of Na-22 were generated. It would also indicate that the major injection of Cs-134 into the atmosphere occurred in tests prior to those which began with the 1961 Russian tests.

DECLASSIFIED

DECLASSIFIED

C-13

HW-82428

Analysis of a sample of elk tissue from an animal taken from the Olympic Peninsula (Quinault, Washington) by the Biology Operation showed concentrations of Na-22, Cs-134 and Cs-137 which were of the same level as those observed in the Alaskan caribou.

The number of fallout radionuclides which can now be measured directly in air filter samples by direct counting with the multidimensional analyzer has been extended to 12. The radionuclides presently being measured are Be-7, Na-22, Mn-54, Co-60, Y-88, Zr-95-Nb-95, Ru-106, Sb-124, Sb-125, Cs-134, Cs-137 and Ce-144. Be-7, Sb-124 and Sb-125 were not previously measured. The radionuclides Be-7 and Na-22 are continuously produced by cosmic ray interaction with the atmosphere. The radionuclides Mn-54, Co-60, Y-88, Sb-124 and Cs-134 are neutron activation products while the remainder are fission products. Measurements of this radionuclide spectrum on air filters collected during the past test period and during this year will provide information for answering questions of relative fallout rates, mechanisms and atmospheric circulation.

Analytical Procedures

An evaluation of the National Bureau of Standards bioassay procedure for uranium showed that although it was rapid and quantitative it did not produce a final product which was suitable for alpha energy analysis. However, application of the electrodeposition technique of Whitson and Kwasnoshi as the final step provided an excellent source for energy analysis. Application of this electrodeposition step will be recommended where alpha energy analysis is required.

A procedure for the Pu analysis of Nevada Test Site soil was devised which includes the complete solubilization of the sample and provides a yield of 75-85 percent. The procedure involves fusing a two-gram sample with five grams of Na_2CO_3 , leaching the Na_2CO_3 from the melt with warm water, dissolving the residue in 7.2 N HNO_3 and collecting the Pu on a Dowex 1 x 2 (NO_3) column. The Pu is removed from the column with dilute HCl-HF for counting or electrodeposition.

The two radiocerium procedures which were recommended for evaluation by the ad hoc committee have been tested. The ceric iodate procedure is satisfactory in both yield and decontamination but is extremely long. The hexone extraction procedure which was designed for small samples of liquid wastes is not satisfactory for large water or bioassay samples. A recently reported rapid extraction procedure using Bis-2 diethylhexyl orthophosphoric acid appears satisfactory for large water samples and is being tested for various bioassay and soil sample analyses.

Tracers for Atmospheric Dispersion Tests

A unique liquid scintillation counting method was devised for the measurement of the Xe-133 which is being considered as an atmospheric tracer. The gas, along with carrier xenon, is frozen out from a vacuum train at liquid nitrogen temperature onto a liquid scintillator in a quartz vial. The vial is then sealed off and warmed to room temperature. The Xe-133 dissolves in the liquid scintillator and is measured with near 100 percent efficiency.

ISOTOPES DEVELOPMENT - OS PROGRAM

Radiochemical Calculations

The computer code (Isogen) for calculating radioisotope generation and decay, described in previous monthly reports was compared with the GE-III program Alchemy, which is reported to be the fastest available code for these calculations. The new code was ten times faster, with accuracy of 0.1 percent in almost all cases and maximum error of 0.2 percent. Isogen also provides accurate results for cases involving many successive decays, while Alchemy loses accuracy in these cases. Because of the great time advantage of Isogen, it is being modified to accept the same input data as Alchemy, thus allowing it to fit into existing computer programs. A formal report on the program is being written, along with a journal article on the mathematics involved.

Promethium-147 Calorimetry

Statistical treatment of the calorimetry results obtained in the Hanford calorimeter with two capsules of highly purified promethium and comparison with recent referee determinations at Mound Laboratory were completed and show excellent agreement. The mean Hanford value is 0.3329 and the mean of the two Mound determinations 0.3330 watt/gram. A value of 0.333 watts/gram can accordingly be considered a firm value. The half-life determined by calorimetric measurement of decay rate is 2.620 ± 0.005 years. This is an absolute value based on the rate of decrease in heat output as a function of time and is not dependent on gravimetric or radiochemical measurements.

Heat Source Compounds

Laboratory synthesis of compounds in sufficient quantity for pneumatic impaction continued. Reaction of H_2S with SrCO_3 in a tube furnace at 750 C was found a preferable process for preparation of SrS , compared to the previously reported use of elemental sulfur admixed with SrCO_3 .

DECLASSIFIED

DECLASSIFIED

C-15

HW-82428

The advantage of H_2S is that very little condensation of sulfur occurs at the tube exit. Strontium hydride preparation is proceeding. A sufficient quantity is being prepared both for trial pneumatic impaction and for preparation of strontium silicide. Efforts to prepare metallic neodymium by calcium reduction (I_2 booster) of NdF_3 have been unsuccessful, apparently because the furnace used will not reach the necessary temperature. Lithium will be tried as a replacement for calcium.

W. H. Reas

Manager
Chemical Laboratory

WH Reas:cf

BIOLOGY LABORATORY

A. ORGANIZATION AND PERSONNEL

No significant changes occurred.

General

The Hanford Symposium on Inhaled Radioactive Particles and Gases was held May 4, 5, and 6, 1964 in Richland, Washington. Total registration was 270 of which 157 were from off site. Fifteen of the 157 off-site registrants were from foreign countries.

There were 42 contributed papers, 35 of these papers were presented orally, and 7 were read by title. Five papers were contributed by personnel of Hanford Laboratories. All papers will be published in the Symposium Proceedings which will appear as Volume 10, Number 12 of Health Physics in December 1964.

B. TECHNICAL ACTIVITIES

FISSIONABLE MATERIALS - O2 PROGRAM

Reactor Effluent Monitoring

Comparisons between the mortalities of groups of young chinook salmon being reared in regular reactor effluent and effluent cooled to river temperatures emphasize the importance of the interaction of water temperature and chemical toxicity. Fish in regular effluent concentrations of 0, 2, 4, and 6% for 30 days show 1, 1, 4.8, and 8.2% mortality, respectively. The increase in mortality with higher concentrations is evident, but fish reared in effluent cooled to river temperatures show a mortality of about 1% in all test concentrations.

Columnaris

Columnaris antibody was found present in all fish which had been exposed to the disease and can be induced artificially by injection of columnaris organisms killed with formalin.

No columnaris infection was found among 100 fish from Ice Harbor Dam and 75 fish from Horn Rapids on the Yakima River sampled at the end of April.

BIOLOGY AND MEDICINE - O6 PROGRAM

METABOLISM, TOXICITY, AND TRANSFER OF RADIOACTIVE MATERIALS

Zinc

Past work on trout force-fed a single dose of Zn^{65} showed surprisingly high concentrations retained in the GI tract. To determine if a different

mode of administration would yield a similar result, five trout were intravenously injected with 53 μC Zn^{65} and killed 10 days later. On the average the body burden was 38 μC , 23% was in the GI tract. High concentrations were found in the stomach, pyloric caeca, and hind-gut (1.0, 0.79, and 1.0 $\mu\text{C/g}$ wet tissue, respectively). Ten days after a trout ingests a single dose of Zn^{65} , it will have about 25% of the dose; intravenous administration resulted in a retention of about 72%.

Zinc-Cadmium

Twenty-four lactating ewes received a single intravenous injection of Zn^{65} and $\text{Cd}^{115\text{m}}$ containing different amounts of stable Zn to detect the effect of stable zinc on the plasma-to-milk transfer of the two radioisotopes. A constant fraction of the administered dose appeared in the milk at each sampling period in spite of the fact that the plasma levels of both Zn^{65} and $\text{Cd}^{115\text{m}}$ were progressively elevated for the first 24-48 hours with increasing amounts of administered stable Zn, suggesting that whole plasma concentration of Zn is not proportional to that particular compartment responsible for transfer into milk.

Zn^{65} and $\text{Cd}^{115\text{m}}$ were injected into the mammary gland via the teat canal of eight lactating ewes when the udder was filled with milk to measure the milk-to-plasma transfers. The removal of $\text{Cd}^{115\text{m}}$ was more rapid than Zn^{65} . The amount of stable zinc injected simultaneously had no effect on the rate of transfer for either element.

Technetium

Results from a limited number of rats indicate a low toxicity for technetium-99 administered as $\text{NaTc}^{99}\text{O}_4$. The $\text{LD}_{50/30}$ for intravenous injection is of the order of 180 mg/kg. This is clearly a case of chemical toxicity.

Iodine

The belly skins of five young miniature swine were smeared with aqueous solutions containing 15% I^{131} (as the iodide) and 85% I_2^{131} .

Various treatments of the skin area two hours after exposure were compared on the basis of peak thyroid activity (% of initial skin deposition) with an untreated pig which had a 2% uptake.

Vigorous washing of the exposed area with water removed at least 50% of the activity while the use of soap with water removed 95% of the radioiodine. There was no apparent benefit from applying dilute silver nitrate prior to washing with water or soap and water. Although washing of the exposed area removed a large amount of the deposited radioiodine and reduced the total I^{131} thyroid uptake, there is a suggestion that rubbing and washing enhances thyroid uptake of the radioiodine not removed from the site.

Higher thyroid uptakes have been reported in man from similar skin exposures but only when much more carrier was used. These results indicate that skin contamination with ^{131}I is not a serious hazard to the individual, especially if the contaminated area is thoroughly washed with soap and water.

Inhalation Studies

Further studies of the metabolism of lung tissue indicates that α -glycerol phosphate does not increase fatty acid synthesis in our mitochondria system as often is the case with the liver fatty acid synthesizing system.

The dog that died 3-3/4 years after exposure to $\text{Pu}^{239}\text{O}_2$ (March 1964 monthly report) had the following distribution of Pu^{239} in the tissues:

<u>Tissue</u>	<u>Distribution of Pu</u>		<u>Concentration nc/g</u>
	<u>μc</u>	<u>% of body burden</u>	
Lung	0.47	52	3.1
Bronchial & mediastinal lymph node	0.31	38 (includes 3% from thoracic trimmings)	270
Liver	0.049	5.5	0.13
Bone	0.026	2.9	0.032
All other tissues		1.6	-
Axillary lymph node			0.87
Thyroid			0.78
Trachea			0.46
Cervical lymph node			0.39
Gr. mesenteric lymph node			0.30
Popliteal lymph node			0.27
Prescapular lymph node			0.25
Sclera of eye			0.12
Mandibular lymph node			0.084
Total body burden	0.89		

Amount deposited in alveoli initially - 4.0 μc
 Concentration in alveoli initially - 0.047 $\mu\text{c/g}$
 Concentration in lung at death - 0.0056 $\mu\text{g/g}$ (normal lung weight)
 Average radiation dose to the lung - 10,000 rads.

Rats will shortly be exposed to uranium ore dust on a chronic schedule during the next two months, to further test for trends away from equilibrium of daughter isotopes.

Gastrointestinal Radiation Injury

The effect of partial-body irradiation on the absorption of bile salts from the intestine was studied by exposing the abdomen of rats to 1500 r of X-ray. Absorption decreased by 15% during the first two days post exposure, 55% at 3 days, and 65% at 5 days. Secretion of bile salts by the liver remained normal for the first 3 days but increased 15% at 5 days post-exposure despite the appearance of gross pathological changes in the liver. This is no doubt an effort by the liver to compensate for the decreased absorption. The decreased absorption of bile salts coupled with their increased secretion must obviously result in an elevated bile salt level in the irradiated intestine. Previous studies had indicated that certain features of the intestinal radiation syndrome are greatly aggravated by the presence of bile salts. The failure of bile salt absorption to recover during the 5-day period following irradiation is unlike the situation with sugar, which is also actively absorbed.

Secondary Disease

Leukocytic infiltrations increased two- to three-fold 3 days after bone marrow administration to mice that were not irradiated. X-irradiation diminished infiltrations, suggesting that the appearance of infiltrations is a host response.

Rumen Cannulation

To obtain representative samples of rumen ingesta an improved technic of rumen cannulation is being developed. The construction of this type cannula promotes a tight seal and early healing. (This type of cannula has been reported adaptable to other portions of the GI tract.) The diameter of the first model of cannula was considered too small to permit representative samplings of rumen ingesta. Two of them were, however, placed in two ewes to develop the surgical approach and determine the animals' tolerance to the material. Larger cannuli are being fabricated and will be implanted when completed. These animals will be used for checking the relationship between the radionuclide (e.g., Cs) concentration of the feed and the rumen content (e.g., for evaluating radioecology studies).

Microbiology

In further tests to define the specific portion of the tryptophan pool which moves into protein, Neurospora was grown in medium supplemented with tritium-labeled tryptophan and C-14-labeled indole. In this case the ratio of C-14 to tritium for any fraction of tryptophan isolated from the mycelium measures the relative amount of bio-synthesized tryptophan in that fraction. Ratios observed in the tryptophan associated with the microsomes are clearly different from those observed in either the acid soluble pool or in the wash from the microsomes. This strengthens the conclusion that the tryptophan being synthesized in protein is associated with the microsomes and by this association differs from the remainder of the tryptophan pool.

Terrestrial Ecology

There has been a noted absence of young seedlings among the greasewood plants at Rattlesnake Springs. It appeared possible that reproduction of greasewood might be totally by asexual reproduction rather than by seeds. Although many seeds are normally eaten out by activities of insect larvae, some 300 seeds were carefully selected as being intact and free from incursions by insects. Of these 300 seeds only two germinated and produced seedlings. The reasons for the low germination are not apparent.

The 1964 survey of nesting Canada geese within HAPCO boundaries was completed. A total of 167 nests was studied representing 21% fewer than last year and 33% fewer than the preceding 11 years' average. About 680 goslings were produced, the least since studies began in 1953, and 20% below the 11-year average. Fertility of adults based on examination of eggs in completed nests was 98%. This fertility is fully as great as found by other investigators in non-Hanford areas.

Ringbill and California gulls began nesting in the Coyote Rapids and Ringold colonies. A census of these nests has been initiated.

Equipment was fabricated to enable banding of cliff swallows nesting on the bluffs along the Columbia River. Banding operations have started and are continuing as weather permits. The migration pattern of these birds is of interest in understanding the processes of dispersion of radionuclides from the Hanford area. These birds eat insects which hatch directly from the river and therefore are tagged with the isotopes typical of the reactor effluent.

Columbia River Limnology

Difficulties in counting the gamma emitters in plankton were overcome and for March the average concentrations of Zn^{65} , Sc^{46} , and P^{32} were 69, 13, and 78 nc/g organic matter, respectively. Comparable values for April were 27, 4, and 13, all decreased because of greater dilution. It is interesting to note that concentrations of these isotopes increased during April in the periphyton but decreased in plankton. Periphyton is clearly living actively reproducing material, whereas plankton is floating material which may have lost some of its biological capabilities.

Preliminary results of a study to differentiate between the adsorption and absorption of radionuclides by net plankton revealed the following: six times as much Zn^{65} was sorbed by live plankton as compared to killed plankton, whereas Sc^{46} and Cr^{51} were sorbed in equal amounts on the live and dead material. Since Zn^{65} is generally believed to be biologically active and Sc^{46} and Cr^{51} not, this indicates that most of the zinc routinely measured in the plankton is biologically absorbed. These are preliminary data taken from two samples and processing of the remaining 19 will increase our certainty of this assumption.

As part of a study to evaluate the extent of fish movement within the local rivers, fish were collected at Ice Harbor Dam on the Snake River. Samples were provided by the Fish and Wildlife Service who are currently doing a study of the downstream migrating chinook salmon and steelhead trout. Fish were also taken from the Yakima River near Horn Rapids. Only two samples out of a total of 31 from the Snake River had concentrations of Zn^{65} above the detectable limit of the counter. These fish were mostly juveniles. The majority of Yakima River fish, however, had levels of Zn^{65} appreciably above background, indicating that they probably had been exposed to reactor effluent in the Columbia River. Pooled samples of GI tract and of eyes were prepared from the Horn Rapids fish. Data are as follows:

<u>Species</u>	<u>Zn^{65}/g wet wt (pc)</u>	
	<u>GI Tract</u>	<u>Eyes</u>
Whitefish	120 (29)*	252 (29)*
Chiselmouth	150 (13)*	961 (19)*
F.S. Sucker	200 (4)*	584 (4)*
C.S. Sucker	Bkgd. (2)*	Bkgd. (2)*
Squawfish	Bkgd. (1)*	60.2
Black bullhead	---	Bkgd. (1)*
Channel catfish	Bkgd. (1)*	201 (1)*

* Number of samples.

The relatively high concentrations of Zn^{65} in the eyes of chiselmouths were apparent in these samples as they had been in earlier collections from the Columbia River near Priest Rapids. The ratio Zn^{65} eye/ Zn^{65} GI tract was about two in the whitefish and fine scale suckers, but approximately six in the chiselmouths.

Special Techniques

Continued efforts to lessen the time required for autoradiography show that use of polaroid land film type 57 gives better resolution but lower contrast than polarscope film type 410. Exposure time needed for the type 57 is about 400 times less than that of NTB plate. In addition to the presently used ZnS scintillator, five other types of scintillators were tested but all were inferior to the ZnS.

This technique is being considered as a means of increasing the efficiency of the bioassay lab by reducing the numbers of urine plates that have to be examined microscopically for the presence of alpha tracks. It is hoped that the ZnS technique will provide a means of screening the samples so that those with less than a minimum of apparent activity will not have to be examined under the microscope.

To develop a method of studying particulate deposition and dislodgement, glass beads of 18 to 40 microns in diameter moving at a velocity of 3 to 4 miles per hour were photographed, using a high intensity light beam placed at right angles to the camera. The glass beads are being used to simulate a fallout solid particle approaching a surface such as a leaf or ground. This technique has potential application to any problem in which there is a need for evaluation of the process of particle deposition at a surface.

Manager
BIOLOGY LABORATORY

HA Kornberg:es

TECHNICAL INTERCHANGE DATA
BIOLOGY LABORATORYI. Speeches Presented

a. Papers Presented at Society Meetings and Symposia

O'Brien, R. T. Effects of deuterium oxide on attainable growth of Saccharomyces cerevisiae. American Society of Microbiology, Washington, D.C. May 3, 1964.

Symposium on Inhaled Radioactive Particles and Gases, Hanford Laboratories, General Electric Company, Richland, Washington, May 4-6, 1964:

Park, J. F., W. J. Clarke, and W. J. Bair. Chronic effects of inhaled plutonium in dogs.

Stuart, E. O., H. W. Casey, and W. J. Bair. Acute and chronic effects of inhaled $Ce^{140}O_2$ in dogs.

Tombropoulos, E. G. Review of therapeutic procedures for removal of inhaled radioactive materials.

Engel, S. (read by W. J. Clarke). Comparative anatomy and pulmonary air-cleansing mechanisms in man and certain experimental animals.

McClellan, R. O. Metabolism of some SNAP radionuclides in miniature swine. Aerospace Medical Association Meeting, Miami Beach, Florida, May 11-14, 1964.

Park, J. F., W. J. Bair, and W. J. Clarke. Chronic toxicity of inhaled plutonium in dogs. Radiation Research Society, Miami Beach, Florida, May 18-20, 1964.

Erdman, H. E. Dominant lethal proportions modified by X-radiation, temperatures, and conabitation in single- and mixed-species populations of flour beetles, Tribolium confusum and T. castaneum. Radiation Research Society, Miami Beach, Florida, May 18-20, 1964.

McClellan, R. O. Endotoxin-induced leukocyte response of miniature swine ingesting Sr^{90} daily. Radiation Research Society, Miami Beach, Florida, May 18-20, 1964.

Sullivan, M. F. Measurement of intestinal damage from neutrons, X rays or nitrogen mustard treatment. Radiation Research Society, Miami Beach, Florida, May 18-20, 1964.

b. Seminars (Off-Site and Local)

Sullivan, M. F. Effect of radiation on the intestine. University of Washington, Seattle, Washington. May 7, 1964.

Bair, W. J. Inhalation of radioactive particles. University of Washington Radiological Sciences, Seattle, Washington. May 28, 1964.

c. Seminars (Biology)

Harvey, R. A., Physics and Instruments Laboratory, Hanford Laboratories, Use of analog computers in Biology. May 13, 1964.

Todd, Paul, Donner Laboratory, University of California, Berkeley, California. The relative biological effectiveness of heavy ion radiation in tissue culture cells. May 15, 1964.

Hackett, P. L. Comparison of copper and radiation toxicity. May 20, 1964.

McClanahan, B. J. Zinc and cadmium interrelationships in rats. May 20, 1964.

d. Miscellaneous

Stuart, B. O. Radiation biology. Members of the Health Physics Certification Refresher Course, Richland, Washington. May 26, 1964.

II. Articles Published

a. HW Documents

None

b. Open Literature

Ballou, J. E. 1964. Distribution and retention of plutonium-239 and neptunium-237 in the rat. Radiation Research 22:81-94.

Palmer, H. E., W. C. Hanson, B. I. Griffin, D. M. Fleming. 1964. Radioactivity measurements in Alaskan Eskimos in 1963. Science 144: 859-860.

McClellan, R. O. and L. K. Bustad. Toxicity of significant radionuclides in large animals. Annals N. Y. Acad. Sci. III, Art. 2: 793-811 (1964).

McClellan, R. O., G. S. Vogt, R. E. Kane and F. F. Hahn. Endotoxin-induced leukocyte response of miniature swine ingesting Sr⁹⁰ daily. (Abstr.) Radiation Research 22: 213 (1964).

McClellan, R. O., W. J. Clarke, and G. S. Vogt. Acute toxicity of Sr⁹⁰ in miniature swine. (Abstr.) Toxicology and Applied Pharmacology 6: 353 (1964).

UNCLASSIFIED

b. Open Literature (continued)

Watson, D. G., W. C. Hanson, and J. J. Davis. Strontium-90 in plants and animals of Arctic Alaska, 1959. Science 134:1005-1009.

III. Visits and Visitors

a. Visits to Hanford

Dr. Leroy F. Erickson, Department of Animal Care, University of Oregon Medical School, Portland, discussed research with L. K. Bustad and H. A. Ragan, May 1, 1964.

Participants of Symposium on Inhaled Radioactive Particles and Gases (about 60) from various laboratories toured Biology. May 6, 1964.

R. Goodrich, Lovelace Foundation, Albuquerque, N.M., visited the counting room facilities and discussed techniques with A. C. Case, May 7, 1964.

S. R. Bernard, Oak Ridge National Laboratory, Oak Ridge, Tennessee. Discuss inhalation research with W. J. Bair, May 7, 1964.

J. H. Sherrod, Lovelace Foundation, Albuquerque, N.M. Discuss inhalation research with W. J. Bair, and group, May 7, 1964.

K. Stewart, Aldermaston, Berks., England, and W. G. Marley, UKAEA, Harwell, England discussed inhalation research with Inhalation Toxicology group, May 7, 1964.

S. M. Sanders, Jr., EI duPont Company, Savannah River Plant, Aiken, S.C. discussed inhalation research with Inhalation Toxicology group, May 7.

I. Schmidtke, Medizinische Univ., Berlin, Germany. Discuss inhalation research, May 7, 1964.

P. Thieblemont, Centre D'Etudes Nucleaires, De Fontenay-Aux-Roses, France. Discuss inhalation research with E. G. Tombropoulos and others. May 7.

12 Washington State University graduate students from Pullman, Wash. toured Biology facilities on May 8.

Approximately 70 members of the Business and Professional Women's Club (Northwest Convention held in Richland) toured Biology, May 14.

Dr. George Denniston, University of Washington Medical School, Seattle, Washington, discussed research and gave a lecture on May 11.

Dr. Paul Todd, Donner Laboratory, University of California, Berkeley, California, presented a seminar and toured facilities with E. M. Uyeki on May 15.

a. Visits to Hanford (continued)

Approximately 50 members of League of Women Voters (State Council meeting) toured Biology on May 19, 1964.

Dr. David G. Doherty, Oak Ridge National Laboratory, Oak Ridge, discussed inhalation studies with J. Park. May 22, 1964.

b. Visits Off-Site

- 5/4-7 - L. Eberhardt and D. Watson collected samples at Yakima, Aberdeen-Quinault.
- 5/4-6 - M. P. Fujihara discussed research with Dr. W. Klontz, Western Fish Disease Lab, Seattle.
- 5/3-11 - R. T. O'Brien attended the Am. Society of Microbiology in Wash. D.C. and discussed research at Seton Hall University in Newark, New Jersey.
- 5/6 - L. Haverfield discussed manuscript with Wyatt Cone at Prosser.
- 5/11-12 - H. A. Kornberg attended Bio-Med Meeting in Oak Ridge and presented and 5/14 a seminar at Battelle Memorial Institute in Columbus, Ohio.
- 5/10-25 - R. O. McClellan presented papers at the Aerospace Med. Assoc. Mtg. and Radiation Research Society Meeting in Miami, Fla; discussed research at University of Florida, Oak Ridge National Laboratory and UT-AEC Project, Oak Ridge.
- 5/21-23 - L. K. Bustad attended the isotope conference and discussed research at University of Washington, Seattle, Wash.
- 5/14-16 - C. Cushing and W. Rickard collected fallout samples in the Blue Mountains near Dayton.
- 5/14-16 - L. Eberhardt attended a meeting at Rand Corporation - TAB Program - ecological aspects.
- 5/16-21 - W. J. Bair presented a paper at the Radiation Research Society Meeting, Miami Beach, Florida.
- 5/16-21 - H. E. Erdman presented a paper at the Radiation Research Society Meeting, Miami Beach, Florida.
- 5/18-21 - F. P. Hungate attended the Radiation Research Society Meeting in Miami Beach, Fla. and discussed research at Duke University in Durham, North Carolina.
- 5/25 - W. H. Rickard and K. Price attended thesis guidance committee meeting in Pullman, Washington.
- 5/27 - C. Cushing and D. Watson collected samples in Blue Mtns.
- 5/25-28 - L. Eberhardt discussed research at Universities in Columbus, Ohio and Minneapolis.
- 5/26 - V. G. Horstman inspected feed at Hermiston, Oregon.
- 5/28 - W. Rickard and K. Price collected fallout samples in Cascades.
- 5/28 - W. J. Bair presented a seminar to the Spring Quarter Class of Radiological Sciences at the University of Washington.

IV. Achievements

None

V. Honors and Recognitions

None

VI. Professional Group or Organization Assignments

None

APPLIED MATHEMATICS OPERATION
MONTHLY REPORT - MAY, 1964

ORGANIZATION AND PERSONNEL

J. A. Figg terminated on May 1st to be married.

H. D. Huber was deactivated because of illness. The date of his return is indefinite at this time.

E. C. Nebel, MTP Trainee, transferred on May 26th to his next assignment in the Audio Products Department, General Electric Company, Decatur, Illinois.

ACTIVITIES FOR OTHER HAPO COMPONENTS

N-Reactor Department

A procedure was empirically determined for measuring cladding thickness of fuel elements on a sampling (11 percent) basis rather than the previous 100 percent inspection scheme.

Irradiation Processing Department

A series of tests to determine the effects of can-sleeve preheat time and the total submerge time in canning four different fuel element types are being analyzed. The yield variables are the external and internal UE-1 and UT-4 bond integrity measurements.

Averages and standard deviations have been used to describe the distribution of the preirradiation weights and dimensions of AlSi and hot-die-sizing fuel elements in production test IP-665A.

Work is continuing on the analysis of PT-572 to characterize weight loss and dimensional distortion effects according to support heights of self-supported fuel elements.

Some previous work on rupture rates and confidence limits is being updated.

Information Systems work continues. Final criteria for exception reporting for 100 B-C reactor maintenance program was received and is being incorporated into the system program. Reactor Outage Information System reports for 100-H were revised and sent to H-Area management. A request was received to expand system to provide analysis of craft requirements.

Chemical Processing Department

A discussion was held with interested personnel on the correct techniques and the limitations inherent in a proposed test of radioactive waste containers.

Business Planning and Transfer Operation

The Information and Decision Model of Major Hanford Production Units was completed. The Model stresses the AEC integration problem arising from plant segmentation. Work on the economy of the Tri-City Area continues, laying a basis for 1965-67 projections.

ACTIVITIES WITHIN HANFORD LABORATORIES

2000 Program

C Column Computer Control

Two functional subroutines were completed for the GE-412 Computer which will be used to control the operation of the C-column. Documentation of the subroutines is now in progress.

Ground Water Models

A double precision EDPM program was completed which determines soil permeability in a three-dimensional flow system for which both a potential and stream function are assumed known.

3000 Program

Numerical Control of δ - ω

Clearance problems between the tool holder and the rough stock before working forced the preparation of another magnetic tape which programs the operation in an alternative manner.

Numerical Control of Rotary Contour Gauges

Seven magnetic tapes have been produced for the purpose of testing the numerically controlled rotary contour gauge as soon as it has been converted.

4000 Program

Radiation Damage to Fissionable Materials

The FORTRAN language program SALTY to unfold an observed two-dimensional particle size distribution into its three-dimensional counterpart was completely programmed and has progressed to the late debugging stages. Final check of the calculation method is in progress using test cases.

Sonic Transmission in Visco-elastic Media

A set of instructions has been prepared describing the input to the spectral distribution EDPM program. This program has been placed in the EDPO library for direct use by the customer.

DECLASSIFIED

DECLASSIFIED

5000 Program

Computation and Statistical Analysis

Work continued on the calculation of the power function of the Poisson index statistic used to check stability of counting instruments. Card output features and improvements in the precision of the calculations have been added to the basic power function computation program and are currently being debugged. Work continued on the power function calculation program assuming a random denominator in the index.

Specifications of the new multidimensional gamma ray spectra maintenance program (MUL) were completed and programming by EDPO people has started. Programming to translate data for input to the system has been debugged.

An analysis of experimental data was completed to obtain an interval estimate of the half-life of promethium-147.

Actinite Element Research

A paper on crystal indexing has been prepared and submitted for publication in Acta Crystallographica.

A report on the orthorhombic indexing program is in preparation and will be issued soon.

6000 Program

Ecological Models

Work continued on the diffusion model development program with several computer subroutines written and others begun.

Biology

Assistance was given in the development of a simple mathematical model to describe the incidence of lung cancer from inhaled radioactive particles.

The statistical analysis of data from an experiment to determine the effectiveness of DFAB and DTPA in preventing the deposition of plutonium in the liver, kidney, femur and spleen of the rat was completed.

Statistical analysis of data from a study to investigate the acute and chronic effects of inhaled $\text{Ce}^{144}\text{O}_2$ in dogs continued.

A computer program was written to calculate the moles per sample of an isotope when two isotopes are present.

Work is continuing on the programs of fitting density distributions to observed particle sizes.

A study was initiated of the current sampling techniques employed in environmental radiation monitoring.

Other

As a member of the Task Force to investigate possible machine configurations which would satisfy the present and future digital computer needs of HL, W. L. Nicholson visited International Business Machines, Poughkeepsie, New York, Digital Equipment Corporation, Maynard, Massachusetts and Control Data Corporation, Minneapolis, Minnesota. The task force is evaluating information learned from manufacturers and will issue a report discussing tentative computer system configurations suggested by these manufacturers.

Computation of particle sizes and size fractions aided in the successful fabrication of a "Calrod" heating element by the vibrational compactification technique.

General

Work is continuing in determining whether there is a relationship between welding techniques and corrosion.

The 7090 program specifications were submitted for the mass spectrometer propagated error model.

An investigation into an appropriate testing procedure layout for evaluating strength of graphite was started.

The EDPM program which simulates various chemical reactions which affect and modify the initial composition and concentrations in a reactor atmosphere, is being extensively modified. When complete it will be capable of analyzing a far greater variety of situations.

Carl A. Bennett

Manager
Applied Mathematics

CA Bennett:bsh

DECLASSIFIED

PROGRAMMINGREACTOR PROGRAM - 04 PROGRAMPLUTONIUM UTILIZATION PROGRAMYUKON - Uranium Conservation Code

Hand calculations were performed for two projections of the growth of installed nuclear power capacity. The first projection (based on the USAEC Report to the President 1962), shows a relatively slow growth curve for the immediate future, but one which accelerates to a six-year doubling rate after the year 2000. The second projection is based on faster growth in the immediate future, but slows to an eight-year doubling time after 2000. The two resulting curves for nuclear electrical capacity cross in the year 2000. For both projections, thermal reactors were assumed to produce plutonium inventories for fast breeder reactors. Once they were introduced, the fast breeders were assumed to be expanded into each projection as rapidly as plutonium inventories would allow. Three assumed introduction dates were used for breeders; 1975, 1985, and the far distant future (that is, not introduced at all).

Although the hand calculations have not yet been verified in detail by machine calculations, they indicate that extremely high priced uranium ore (over \$100/kg) will not be required until after 2025 for either projection, even if the present reserves of low priced ores do not increase and even if no breeders are built. Meanwhile, simulations of improved thermal reactors are being prepared for more detailed calculations and debugging of the YUKON code.

Production Reactor Power Conversion

In cooperation with Irradiation Processing Department personnel, capital cost estimates for "bare bones" power conversion expenditures are being obtained. Two power recovery schemes are being considered: (1) the use of a series boiler secondary and single pass primary system with a recuperative heat exchanger, and (2) a flash steam system. In the first system, the reactor coolant is used as a heat source to a series of secondary boilers which feed low pressure turbines. The remaining heat is extracted from the coolant in the recuperative exchanger which heats the reactor inlet to about 180°F and cools the exit stream before rejection to the river. The second system flashes the reactor coolant with fog spray nozzles. The coolant passes through steam separators to turbines. The turbine exhaust is cooled by submerged condensers in the river. The liquid portion of the reactor coolant returns to the recuperative exchange. The advantage of this system is the great simplicity of the equipment involved.

Fuel Costs in the NPR

At the request of the N-Reactor Department, a study was made to determine the minimum total fuel cost obtainable for a variety of fueling systems in N-Reactor for power only operations. The fuels investigated and the minimum fuel costs obtained are tabulated in Table I. The JASON-MELEAGER-QUICK Chain program was used to simulate the NPR for these various fueling systems, and to obtain the desired fuel cost information.

Two values of fuel element fabrication and separations cost were used to obtain the values listed in the table. For the systems employing metallic fuel, a \$5.50/lb fuel element fabrication and a \$6.05/lb separations charge were used, while values of \$20.12/lb fuel element fabrication and \$9.88/lb separations charge were used for the oxide fuels. The values listed under backup exposure and backup enrichment are obtained when the reactor is operated to obtain a fuel cost one tenth (0.1) of a mill higher than the fuel cost at minimum.

From the listed values of minimum total fuel cost, the fuel that yields the lowest fuel cost is slightly-enriched metallic uranium. The advantage of this fuel results from the lower enrichment necessary to operate the reactor coupled with the lower jacketing and separations charges associated with metallic fuel. The drawback of this fuel is its lack of durability and rapid dissolution upon rupture to water.

Code Development

Interest has been expressed in the direct linkage of the JASON lattice parameter code to the SUPERCASE-MELEAGER case generating code. The purpose of this communication between links on the chain is to provide the SUPERCASE program with the proper lattice parameters before it begins to generate MELEAGER cases. There are two ways to transfer thermal utilization data from JASON to MELEAGER: (1) to transfer thermal utilization as f , and (2) to transfer a macroscopic nonfuel absorption cross section, SNF. In the past if Option (2) were used, JASON calculated a flux and volume weighted value of SNF and the flux depression factors for a given enrichment. It then transferred these values to MELEAGER case generator along with the other necessary input to MELEAGER. Then in the MELEAGER calculation of f , from Option (2), the value of the flux depression was used that JASON had provided. This resulted in a double correction and yielded incorrect values of f in MELEAGER.

TABLE I

Fuel Type	Enrichment Method	Data at Mathematical Minimum Cost			Data at 0.1 Mill/Kwh Above Minimum Cost		
		Fuel Cost Mills/Kwh	Fissile Enrichment %	Exposure Mwd/ton	Fuel Cost Mills/Kwh	Fissile Enrichment %	Exposure Mwd/ton
Uranium Metal	U ²³⁵ Tap Cascade	0.541	0.892	12,100	0.541	0.852	9,100
Uranium Metal 0.8 Density	U ²³⁵ Tap Cascade	0.639	1.059	13,000	0.739	0.906	8,200
Uranium Metal	Plutonium (1) 93-7	Mixed in Depleted Uranium (3)	0.731	0.921	12,000	0.831	0.742
Uranium Metal	Plutonium (2) 76-18-5-1	Mixed in Depleted Uranium	0.710	0.912	11,700	0.810	0.751
Thorium Metal	U ²³⁵ Mixed - 90% U ²³⁵ in Thorium	1.580	2.601	21,500	1.680		13,100
Thorium Metal	U ²³³ Mixed in Thorium	1.449	2.432	22,600	1.449	2.063	13,300
Thorium Metal	Plutonium 93-7	Mixed in Thorium	1.236	2.028	15,000	1.336	1.578
Thorium Metal	Plutonium 76-18-5-1	Mixed in Thorium	1.222	2.038	14,900	1.322	1.613
UO ₂	U ²³⁵ Tap Cascade	1.180	1.591	21,600	1.280		13,800
UO ₂	Plutonium 93-7	Mixed in Depleted Uranium	1.254	1.747	24,900	1.354	15,000
(1) 93-7 Plutonium is 93% Pu ^{239-7%} Pu ²⁴⁴ .							
(2) 76-18-5-1 Plutonium is 76% Pu ^{239-18%} Pu ^{240-5%} Pu ^{241-1%} Pu ²⁴² .							
(3) Depleted Uranium Composition (0.38 wt % U ²³⁵).							

(Continued)

7

UNCLASSIFIED

TABLE 1 (Cont'd)

HW-82428

Fuel Type	Enrichment Material	Enrichment Method	Data at Mathematical Minimum Cost			Data at 0.1 Mill/Kwh Above Minimum Cost			Fuel Cost at 4000 Mwd/ton
			Fuel Cost Mills/Kwhe	Enrichment %	Exposure Mwd/ton	Fuel Cost Mills/Kwhe	Enrichment %	Exposure Mwd/ton	
UO ₂	Plutonium 76-18-5-1	Mixed in Depleted Uranium	1.212	1.739	25,500	1.312	1.193	15,000	----
ThO ₂	U ²³⁵	Mixed - 90% U ²³⁵ in Thorium	1.756	3.144	31,000	1.856	2.625	20,100	----
ThO ₂	U ²³³	Mixed in Thorium	1.515	2.932	32,400	1.615	2.408	20,700	----
ThO ₂	Plutonium 93-7	Mixed in Thorium	1.498	2.849	25,700	1.598	2.143	15,800	----
ThO ₂	Plutonium 76-18-5-1	Mixed in Thorium	1.465	2.746	25,400	1.565	2.124	15,600	----
50-50 Vol. UO ₂ -ThO ₂	U ²³⁵ in UO ₂	Tap Cascade	1.400	2.536 ⁽⁴⁾	28,400	1.500	2.070	18,000	----
50-50 Vol. UO ₂ -ThO ₂	Plutonium 93-7	Mixed in Depleted Uranium	1.173	2.898	36,233	1.273	2.017	21,183	----
50-50 Vol. UO ₂ -ThO ₂	Plutonium 76-18-5-1	Mixed in Depleted Uranium	1.134	2.868	36,463	1.234	2.010	21,413	----
75-25 Vol. ThO ₂ Uranium Metal	U ²³⁵	Tap Cascade	1.529	2.458 ⁽⁵⁾	26,300	1.629	2.049	17,200	----

(4) The percentage enrichment figure for this and the following cases includes the thorium content.

(5) Since this enrichment includes the thorium content, it appears that a system high in curium should be studied.

To alleviate this problem, two corrections were made to the LASON program: (1) the flux weighting was removed in the calculation of SNF, and (2) the flux depression factors were determined using two values of enrichment so that fitted values were obtained. As of this date, the codes are still being debugged but some of the preliminary results have been most promising. Most studies using the chain have employed Option (1) and have not encountered this problem.

Code Work and Data Processing

HW-79951, Fuel Cycle Analysis Chained Computer Program Guide is being updated to contain the latest QUICK program.

The small reactors study has been processed using the latest QUICK program. Data formerly plotted by hand from QUICK data can now be plotted on the Benson-Lehner mechanical plotter using a new QUICK subroutine called STUDY. STUDY can be adapted to extract and plot any data from QUICK.

A new subroutine named "FIZIQ" is being written to replace the present "PHYSIC", a QUICK subroutine. The change will result in tabulations of all isotopes for initial and final conditions in terms of spatial concentrations in the fuel and as enrichments in bred fuel.

A revised chain users guide has been printed incorporating the new MELEAGER, QUICK and PREP Code controls.

ALIHAEA

Coding has been completed and partly debugged to compute Doppler broadening of the shielded resonances. Shielding of the resonances in ALIHAEA is computed as follows:

$$RI = \frac{RI_0}{\sqrt{1 + \frac{(Y)(Z)}{SCA}}} \quad (1)$$

Where

RI = effective resonance integral

RI₀ = dilute resonance integral

Y = isotopic concentration

Z = empirical value (approximately the maximum cross section figure of the first resonance)

SCA = potential scattering of the fuel plus the effective hydraulic radius of the fuel

The values of Z previously used were obtained empirically from resonance escape probability measurements in the case of U^{238} and Th^{232} and by selecting a value from BNL 235 for other isotopes. To reflect Doppler broadening effect a method of adjusting Z with fuel temperature is being developed.

Variation of the effective height of any resonance as a function of absorber temperature is described by the Doppler broadening or Psi function. This function has been evaluated and tabulated in KAPL 1241 and WAPD-SR 506. Machine evaluation involves solution of partially convergent series equations using different forms depending on the resonance parameters. Either form is too time consuming for use in a survey code so the tabulated data were plotted and an analytical expression derived that is capable of rapid machine evaluation using existing subroutines. This analytical expression is:

$$Z = \frac{Z_0}{1 + CE(1 - \exp - 2BI^{1/4}) T^{1/4}} \quad (2)$$

Where

Z = cross section of nucleus at rest for neutrons of resonant energy

T = absolute temperature degrees Kelvin

C = an empirical constant

B = a constant derived from resonance parameters

The value of Z_0 may be computed from the resonance parameters on the RBU tape as follows:

$$Z_0 = \frac{(2.62 \times 10^6)(g) \Gamma_n \Gamma_a}{E_0 \Gamma^2} \quad (3)$$

g = a statistical weight

Γ_n = the neutron width in electron volts

Γ_a = the capture plus fission width in electron volts

Γ = the total width ($\Gamma_n + \Gamma_a$) in electron volts

E_0 = the energy at the resonance

This method of calculating Z_0 produces Z values which are 12% high for Th and 21% low for U based on resonance escape probability measurements. An alternate calculation method is based on the known value of Z at a given temperature and Equation 2. The latter method is used to establish the ALTHAEA Library for all isotopes with established values of Z . The method employing Expression 3 is used for the other isotopes (currently only Pa^{233}).

The value of B for Equation 2 may be calculated from resonance parameters on the RBU tape as follows:

$$B = \sqrt{\frac{4}{\Gamma}} \sqrt{\frac{E_0 K}{A}} \quad (4)$$

Where

K = the Boltzmann constant

A = atomic weight of the nucleus

When values of Z can be calculated from measurements at a second temperature for the isotopes empirical values for B could be derived from Equation 2 rather than using Equation 4.

The value of C required to fit the complete range of the tabulated value of the Ψ function varies from 0.96 to 1.07 as shown in Figure 1. The code provides for three constants which are the coefficients of a second order polynomial in T for the definition of C when the availability of data warrant the refinement. However, the new library will contain a constant value of 1.0 for C since it provides values of Z within 2% of tabulated values for all isotopes up to 1000°C. B values as computed from the RBU tape data will be used. Z_0 values have been selected such that the computed Z will be the same as previously used if a fuel temperature of 20° is used.

FIGURE 1

REQUIRED VALUE OF EMPIRICAL CONSTANT

Coding modifications have been included in the zero-dimensional subroutines to compute reactivity coefficients per degree of fuel temperature and per degree of moderator temperature. The moderator temperature coefficient is not computed unless a nonzero temperature coefficient of SDFM (slowing down power per unit fuel volume) is given as input. This provision was made to remind the user of the code that the change in moderator effectiveness with temperature is often more important than the change in moderator temperature per se.

Two new cross section libraries have been made up using the latest RBU data. The fourth order polynomials used to fit the data are quite accurate for most isotopes. The exceptions are isotopes which have major resonances near the cutoff energy (arbitrary dividing line between thermal and epithermal group Pu²³⁹-Pu²⁴¹ and Am²⁴¹ are typically problems). The low temperature tape is used more frequently and must be more accurate so an upper limit of 600° was selected. Thermal cross section errors are all less than 0.1%. Resonance integral errors for the three isotopes most difficult to fit are given in Table II. The high temperature tape is to be used up to 1300° and an overlap down to 500° was provided. Good representation of the data was again found for most isotopes. Thermal cross section errors were all less than 0.1%. Resonance integral errors were less than 0.5% except for the same three isotopes listed in Table II. Errors for these isotopes can be reduced if the overlap is decreased or eliminated, or if the upper limit is decreased. The high temperature tape will be subdivided into two libraries if detailed studies are to be made at high temperatures.

TABLE II

RESONANCE INTEGRAL FITTING ERRORS

<u>Isotope</u>	<u>0-600°C</u>	<u>500-1300°C</u>
Pu ²³⁹	0.17%	4.0%
Pu ²⁴¹	0.7%	0.5%
Am ²⁴¹	0.3%	5.0%

Nuclear Safety Activities

The annual independent audit of Chemical Processing Department's critical mass control practices was completed. Hazards review was completed of the shipment of plutonium hood sweepings (HW-82284). Similar work reviewing the hazards of shipment of americium is in progress.

UNCLASSIFIED

F-10

HW-82428

A preliminary safeguards analysis of the High Temperature Lattice Test Reactor (HW-82372) is in an advanced state of preparation. The work was informally reviewed with an AEC-Washington DHD representative.

An approach-to-critical device was deactivated when continued operation was determined to be not clearly within the regulations of the AEC. Specific approval of AEC-RLCO was obtained and operations resumed under Hanford Laboratories Nuclear Safety Specifications No. 6 and Addendum No. 1.

J. W. Woodfield
Manager-Programming

FW Woodfield:ch

UNCLASSIFIED

RADIATION PROTECTION OPERATION
REPORT FOR THE MONTH OF MAY 1964

A. ORGANIZATION AND PERSONNEL

Lena R. Smith retired effective the end of the month from Radiological Development and Calibrations. Myrtle O. Wendland transferred from External Dosimetry to Environmental Studies and Evaluation effective 5/18/64. C. L. Wheadon passed away on 5/4/64. Sharon A. Hodgins, Secretary to External Dosimetry, transferred to N-Reactor Department on 5/11/64.

B. ACTIVITIES

Occupational Exposure Experience

There was one new plutonium case confirmed by special bioassay analysis during the month. This case resulted from inhalation following release of airborne contamination from a hood in the Plutonium Purification and Fabrication Building (234-5). The deposition was estimated to be 3% of the maximum permissible body burden (MPBB, plutonium with bone as a reference, is 0.04 μCi).

The total number of individuals who have received a detectable internal plutonium deposition at Hanford is 344, of which 247 are currently employed.

In May, there were three incidents involving six employees which required special bioassay sampling for plutonium analysis. The following is a brief description of the more significant incidents:

A CPD process operator received a plutonium oxide contaminated injury on 5-1-64 while working at the Plutonium Purification and Fabrication Building (234-5). The employee cut his right index finger while handling plutonium turning fragments. The wound was contaminated to 10,000 d/m and a check of blood smears showed 2,000 d/m. Examination of the finger, using the plutonium wound counter, indicated $1.6 \times 10^{-2} \mu\text{Ci}$. After excision at GE First Aid, a recount indicated less than the $1 \times 10^{-4} \mu\text{Ci}$ detection limit of the wound counter. The employee is a previous deposition case (3% of the MPBB for plutonium).

A CPD operator received a plutonium oxide contaminated injury on 5-13-64 while working at the Plutonium Purification and Fabrication Building (234-5). The employee was attempting to separate plutonium turnings when his right thumb received

a small cut. The wound area was contaminated to 20,000 d/m and a check of blood smears showed 1,000 d/m. Examination of the thumb, using the plutonium wound counter, indicated 1×10^{-2} μCi . After excision at GE First Aid, a recount indicated 4×10^{-4} μCi . The employee is a previous deposition case (3% of the MPBB for plutonium).

Four CPD operators were exposed to airborne concentrations up to 4×10^{-12} $\mu\text{CiPu/cc}$ in the Plutonium Purification and Fabrication Building (234-5) due to failure of a seal on a hood in which they were working. Nasal contamination up to 250 d/m as indicated by smears was successfully removed.

In addition to the incidents involving plutonium, there were four incidents involving six persons that required evaluation for possible intake of other radioisotopes. None of these incidents resulted in any significant deposition.

There were two items of special interest involving exposure of employees from external sources. These are summarized below:

An HL employee received skin and clothing contamination while working in the Radiometallurgy Building (327). This resulted in doses to localized skin areas of 1.5 and 1.4 rads.

An HL maintenance employee received an exposure in excess of the Hanford Operational Control of 1 rem per badge period as a result of work at the Plutonium Recycle Test Reactor Facility (309). Special processing of the employee's film badge dosimeter worn during the period 4-24-64 through 5-22-64 indicates a whole body penetrating dose of 1.1 rem. Bioassay samples analyzed for tritium indicate an additional whole body exposure of 0.2 rem during this period. The employee's accumulated exposure, including the above, does not exceed any permissible limit.

A CWS exhaust filter from A Cell of the Radiometallurgy Building (327) which had a maximum dose rate of 80 R/hr, was removed and buried at the 200 Wye Burial Ground without incident. This was accomplished by using a box with 2-inch lead walls especially designed for the operation. The radiation level was reduced to 250 mR/hr after the filter was placed in the lead box. Air contamination up to 3.6×10^{-9} $\mu\text{Ci FP/cc}$ occurred as a result of the filter removal.

PRTR was shut down on May 2 in preparation of pressure testing the containment vessel to 15 Psi. The maximum airborne tritium

concentration measured during the pressure testing of the vessel which started on May 9, was 3.5×10^{-4} $\mu\text{Ci/cc}$. Although personnel entries were carefully controlled, bioassay results for those personnel who had made entries averaged 20 to 40 $\mu\text{Ci/l}$. The maximum bioassay result detected was 85 $\mu\text{Ci/l}$ which represents an infinity dose of approximately 730 mrems.

On May 28, 1964 the monthly-quarterly film badge dosimeter system was put into effect. About 15 percent of Hanford employees will remain on a monthly badge exchange frequency and the remaining 85 percent will have their dosimeters processed quarterly. An annual penetrating exposure of less than one rem was the criterion for quarterly film badge exchange.

Instruments employing coincidence counting techniques for analysis of air sample filters were installed in the 100-F and 200-E counting rooms. This change eliminated the waiting period previously necessary to permit decay of naturally occurring alpha emitters before the amount of plutonium on a filter could be determined.

An inventory of all Hanford Laboratories' radiation generating machines in the 100-200 Areas was completed.

Two false criticality alarms occurred simultaneously in the 303 Area facilities on 5-19-64 resulting in evacuation of the entire 300 Area. The false alarms were apparently caused by a power failure that lasted for an estimated 15 seconds. As a result of the incident, a thorough review is being made of the location of criticality detectors, the 300 Area Emergency Plan is being reviewed, and increased emphasis is being placed on training for emergency events.

No environmental contamination of special significance was found during May. There were, however, two kinds of unusual releases to the atmosphere. One of these involved I^{131} emissions from the Radiometallurgy Building (327) that increased to a maximum of 0.2 curie during the last week of the month (gaskets were found to be missing around charcoal filters); the other involved an emission of about 70 millicuries of Sr^{90} from the Hct Semiworks in the 200-E Area on May 12.

The average concentration of fallout materials in the air of the Pacific Northwest was 2 pc β/m^3 during May. Averages for March and April were respectively 1 and 1.5 pc β/m^3 . Because of the special interest in the Wahluke Slope at this time, sixty plots of ground were surveyed for contaminants. No contamination was found.

Studies and Improvements

Progress toward the installation of integrated water samplers at 107 Basin outlets includes the following: (1) Approvals were obtained on a Minor Design Change, and the sampling heads were fabricated for 100-K Area; (2) Approval of design and scheduled installation during the next outage at 100-B Area; and (3) Approval of design and scheduled installation during the next outage at 100-D Area. Some preliminary work is already in progress.

An integrated sampler for the collection of raw river water at Pasco was started up this month. The sampling equipment is similar to that being used at our other installation -- solenoid valve and timer. The same equipment was installed at The Dalles and Bonneville Dams this month. The samples at the dams are changed on a weekly frequency by Corps of Engineers personnel and shipped to Hanford for evaluation.

The Industrial Hygiene Operation is preparing a document showing areas along the plant shore with ground water springs showing nitrate ion concentrations higher than expected. Although the measured river water concentrations (a maximum of 0.4 ppm) are not of concern as a drinking water hazard, routine sampling and analysis for nitrate ion in river water above and below plant was started to determine the increase due to Hanford operations. The downstream sampling point is the Richland Water Plant.

The air sampler at Meacham, Oregon, was taken out of service. This is a part of the RPO planned realignment of air sampling locations.

Definition of the data processing program (EMA) for environmental monitoring is nearing completion. The listing of codes and literal interpretation for all environmental samples and sampling locations was completed; however, some minor revisions will be necessary for clarification.

Fabrication of the G.I. tract dose monitor was begun by Technical Shops. Arrangements were made to set up this unit at the Richland Water Plant. The studies conducted in the Biophysics Building (329) over the past month indicated that the G.I. tract dose monitor results agreed with the radioanalysis results to within a few percent. Further calibration and comparisons between this direct reading dose rate measurement and the radioanalysis system for estimating G.I. tract dose from water supplies are continuing.

A series of Van de Graaff accelerator experiments were conducted to compare the performance of a 12" polyethylene sphere and the Hanford 9" polyethylene cylinder when used with a BF₃ tube and the Hanford portable neutron dose rate monitor. The larger sphere provides a slight improvement in energy response for neutrons above 1 Mev. The

Hanford cylinder provides improved performance for neutron energies below 1 Mev. Based on the tests conducted to date, there are no technical reasons for changing the moderator system used on this instrument. The additional weight of the 12 inch sphere bargains against its general use on portable instruments.

Studies were conducted to determine the cause of some reported "erratic response" of the BF₃ instruments in the field. Some meter fluctuations resulting from switching transients were observed. These can be eliminated by changes to be made in the meter switching circuit. Two instruments examined this month were found defective due to malfunctioning BF₃ tubes. The tubes were replaced, and the instruments were returned to service.

A prototype sampler for collecting a seven-day water sample from the Columbia River was designed and fabricated. The unit features a sampling system for collecting water from a submerged river position at a uniform rate over periods up to seven days. No external power is required for the operation of the sampler. Sample intake is controlled by pressure differentials and orifices.

A system to permit the addition of waste disposal containers to an underground cavern and to prevent the escape of any associated contamination was designed. A prototype funnel which opens when the weight of the disposal container is added to the funnel permits the container to fall into the cavern while providing a nearly airtight seal at all times. The use of this prototype equipment has proven highly beneficial as a contamination control device. Earth backfills to cover loose contamination are now required only at the end of each workday rather than following each burial trip. This equipment has provided economies in waste disposal and provided improved radiation protection practices at the disposal site. Some studies are still in progress to further advance the prototype design and to devise a fully operational system of this type.

Several sets of thermoluminescent dosimeters were exposed to neutrons from the positive ion accelerator. Approximate exposures were 1 rem of fast neutrons of energies; 0.38, 0.58, 0.77, 0.96 and 1.53 Mev. If the background reading is not subtracted, all but one of the dosimeter sets gives a logical result. The readings vary between 5 and 10 reader units for a 1 rem exposure dose with no apparent extra sensitivity to a particular energy neutron; thus, the neutron energy response is relatively flat over the energy range studied.

A number of "respirable dust" sampling heads were received. These samplers made by the UNICO Company remove the large particles in a small cyclone before the rest of the particulate material is collected on a filter. These samplers will be used in special studies at various plant locations.

Tests on the operation of surface barrier diodes for air sample analysis continued. The 4.5 square centimeter detector showed about a 10 percent geometry when counting a plutonium source. Counting of an air sample from 231 Building collected on H-70 paper indicated good resolution of the plutonium although almost half of the alpha pulses were degraded and appeared in lower channels in the analyzer. The Americium build-up in the sample was readily observed.

A prototype CP type instrument with an approximate 20 cc ionization chamber was assembled and is being tested and evaluated. This instrument will provide improved capability for measuring dose rates at close approaches, within a few inches, for most radiation sources encountered at Hanford. The angular dependence calibration factors at close approach to large area beta and gamma sources are now being measured. A small number of these instruments are planned for the portable instrument pool. They will be available for special purpose applications at the completion of these evaluation tests.

One hundred new CP meters have passed GE inspection and were shipped to the Hanford plant. These CP meters will replace an older model CP which is difficult and expensive to maintain. Twelve new high-range (0-5000 R/hr) dose rate instruments were received, accepted, calibrated and are now in the portable instrument pool. Eighty percent of the GM instruments were modified to provide increased battery life.

Research Studies

Effect of Reactor Effluent on the Quality of Columbia River Water (02)

Characterization of the changes in Columbia River water temperature between Priest Rapids and Pasco for this season of the year continued with the routine collection and reduction of temperature and meteorological data. Several traverses were made to map temperature pattern on cross sections of the river at selected points. Temperature measurements were also made in and below the effluent bubbles at each reactor area.

Mechanisms of Environmental Exposure (02)

Dietary and whole body counting data are being processed for application to a computer program to seek significant correlations. Initial studies will concentrate on Zn^{65} exposure pathways, but data processing is being handled to permit application to additional future studies. Whole body counting measurements of Na^{24} , K^{40} , Zn^{65} , Cs^{137} , and unaccounted for fractions will be included in the data file. Dietary information in the file will include quantity estimates and sources for consumption of fresh meat, milk, water, fresh vegetables, sea food, and locally-caught fish.

Nuclear Facilities Monitoring Guide (04)

A description of the requirements and objectives of effluent and environmental monitoring was completed. Progress on writing the Guide was informally discussed by telephone with Walter Belter, Division of Reactor Development, and arrangements were concluded for obtaining pertinent information from five power reactor facilities.

C. RELATIONS

There were two minor injuries, and one security violation during the month.

One new suggestion was received, one evaluated, and none adopted. One suggestion was rejected, and five are still outstanding.

The personnel at the Central Fire Station were given three hours of training in emergency monitoring. A radiation orientation talk was presented to Biology personnel.

Radiation orientation and other radiation monitoring training was provided. Two AEC couriers were provided field training.

Three final examination sessions were held for personnel attending the Radiation Monitor Refresher Course. Twenty-eight persons attended, making a total of 36 who were examined. All were from Hanford Laboratories. The examination papers are being reviewed and graded.

A one-day training session was presented for nine employees of the Oregon State Board of Health. The training included general contamination control techniques, alpha and beta-gamma contamination surveys, and special controls used in handling plutonium.

D. SIGNIFICANT REPORTS

HW-SA-3525 - "Neutron Spectrum Measurements at Hanford Work Locations" by G. W. R. Endres, May 15, 1964, for presentation at the Health Physics Society Meeting, June 15-18, Cincinnati, Ohio.

HW-SA-3526 - "The Status of New Personnel Neutron Dosimetry Development" by C. M. Unruh, May 15, 1964, for presentation at the Health Physics Society Meeting, June 15-18, Cincinnati, Ohio.

HW-80892 4 - "Radiological Status of the Hanford Environs for April, 1964", by R. F. Foster, May 18, 1964.

External Exposure Above Permissible LimitsMay1964

Whole Body Penetrating
Whole Body Skin
Extremity

2
0
0

2
1
1

Hanford Pocket Dosimeters

Dosimeters Processed

5,589

20,582

Hanford Beta-Gamma Film Badge Dosimeters

Film Processed

9,333

48,811

Results - 100-300 mrad

114

758

Results - 300-500 mrad

8

88

Results - Over 500 mrad

2

27

Lost Results

0

37

Average Dose Per Film Packet - mrad (ow)
mr (s)

5.4
6.9

6.9
39.9

Hanford Neutron Film Badge DosimetersSlow Neutron

Film Processed

225

3,780

Results - 50-100 mrem

0

24

Results - 100-300 mrem

0

29

Results - Over 300 mrem

0

5

Lost Results

0

5

Fast Neutron

Film Processed

592

2,359

Results - 50-100 mrem

30

64

Results - 100-300 mrem

24

188

Results - Over 300 mrem

1

4

Lost Results

0

3

Hand Checks

Checks Taken - alpha
beta-gamma

37,359
48,919

182,557
275,068

Skin Contamination

Plutonium

23

93

Fission Products

40

255

Uranium

2

8

Tritium

0

0

Thorium

0

0

Whole Body Counter

<u>Subject</u>	<u>Number of Examinations</u>			
	<u>747-A WBC</u>	<u>1964</u>	<u>Mobile WBC</u>	<u>1964</u>
GE Employees				
Regular	22	190	50	510
Incident Cases	17*	56	1	5
Terminations	27	56	0	0
New Hires	12	104	0	0
Special Studies	10	37	0	10
Non-Employees	103	464	51	525

*All of these are recounts

Bioassay

<u>Analysis</u>	<u>Current Reporting Limit</u>	<u>Results Above Reporting Limit</u>		<u>Samples Assayed</u>	
		<u>May</u>	<u>1964</u>	<u>May</u>	<u>1964</u>
Plutonium	2.2×10^{-8} $\mu\text{c/sam.}$	48	392	532	2837
Fission Prod.	3.1×10^{-5} $\mu\text{c/sam.}$	0	0	0	0
Strontium	3.1×10^{-5} $\mu\text{c/sam.}$	0	11	0	60
Tritium	5.0 $\mu\text{c/l}$	376	785	457	1210
Uranium	0.14 $\mu\text{gm/l}$	0	0	159	858
Special Studies		0	0	19	164

Calibrations

<u>Portable Instruments</u>	<u>Number of Units Calibrated</u>	
	<u>May</u>	<u>1964</u>
CP Meter	1056	5419
Juno	285	1339
GM	519	2639
Other	235	1191
Audits	105	523
Total	2200	11,111

Personnel Meters

Beta-gamma film	972	3722
Rings	90	435
Other Film	231	1290
Total	1293	5447
Miscellaneous Special Services	69	1022
Total Number of Calibrations	3562	17,580

Environmental Monitoring

<u>Samples</u>	<u>May</u>	<u>1964</u>
Air		
Filters	323	1623
Scrubbers	212	1167
Water		
Raw	38	207
Sanitary	101	404
Process	34	115
Vegetation	148	485
Test Wells	109	1338
Fish	73	579
Food Products	52	223
Beef Thyroids	52	209
Waterfowl	6	77

Measurements

Control Plots	73	283
Aerial Monitoring	1	8
Ionization Chambers	260	1185

Manager
RADIATION PROTECTION

FINANCE AND ADMINISTRATIONACCOUNTINGCost Accounting

A number of budget adjustments were made within Hanford Laboratories to re-direct funds between sections to improve utilization of available FY 1964 funds.

Hanford Laboratories' Equipment requirements for all programs for the remainder of FY 1964 were reviewed in May, and as a result, a transfer of \$20,000 of 02 Program funds was made to HUPO for special equipment purchases.

A research and development proposal entitled, "Irradiation of Fe-Al Stabilized Uranium Fuel Elements," was transmitted to RLOO-AEC as a result of indicated interest by the Division of Reactor Development of Washington-AEC. The proposal requests \$50,000 in FY 1965 and \$25,000 in FY 1966.

Special accounting codes were established during May for the activities described below:

- .5E - Examination of Heat Exchanger Tubes at the Rural Cooperative Power Association Facility at Elk River, Minnesota - \$3,000 has been authorized for this work.
- .5F - Fabrication of Depleted Uranium Rods for Frankfort Arsenal - \$3,075 has been authorized for the fabrication of 100 depleted uranium rods.
- .5G - Sale of AlSi 406 Rod and Tube Material to Aktiebolaget Atomenergi - \$402 has been authorized to cover cost of material and packaging for shipment to Stockholm, Sweden.
- .2E - Double Crystal X-ray Spectrometer Work for APED - \$2,400 has been authorized to perform X-ray diffraction analysis on four metallography samples.
- .2G - Consulting Services for APED - \$3,000 has been authorized for consulting services on the Transport Equivalent Diffusion Theory.

General Accounting

Following is the status of letters requesting AEC concurrence in proposed actions:

AT-339 - PRTR Fuel Fabrication Movie Approved 5-6-64

AT-347 - Participation in Standardizing Activities - To AEC 5-20-64
American Society for Testing and Materials -
Task Group E-2/VI - Roy Ko

AT-348 - Panel of Experts - Food and Agriculture To AEC 5-28-64
Organization of the United Nations -
R. F. Foster

Modification No. 28 to Appendix B was signed by the AEC on May 5, 1964. This provides the same travel allowances for college professors working at Hanford on summer assignments, whether or not they are connected with the recruiting program.

The following revised OPGs were issued during the month of May:

<u>OPG No.</u>	<u>Title</u>
22.3.1	Approval Authorizations
3.1.1	Vacation Plan

Hanford Laboratories' net material investment at May 1, 1964 totaled \$27.5 million as detailed below:

	(In thousands)
SS Material	\$ 25 925
Reactor & Other Special Materials	1 294
Spare Parts	370
Yttrium	26
Subtotal	<u>27 615</u>
Reserve: Spare Parts	\$87
Yttrium	<u>26</u>
	<u>(113)</u>
Net Inventory Investment	<u>\$ 27 502</u>

The cumulative value of nuclear material consumed in research by Hanford Laboratories during FY 1964 (at May 1, 1964) is as follows:

02 Program	\$ 82 826
03 Program	291 519
04 Program	<u>463 053</u>
Total	<u>\$837 398</u>

The status of Hanford Laboratories' heavy water inventory at May 31, 1964 is as follows:

	<u>Current Month</u>		<u>FY to Date</u>	
	<u>Pounds</u>	<u>Value</u>	<u>Pounds</u>	<u>Value</u>
Beginning Balance	54 708	\$732 314	29 774	\$ 400 600
Acquisitions			54 890	755 988
Scrap Returns			(19 091)	(240 940)
Consumption -1)				
PRTR Loss	(1 025)	(14 176)	(11 610)	(160 072)
Scrap		(537)		(33 548)
PRCF Loss			(245)	(3 369)
Scrap				(574)
All Others (Loss)			(35)	(484)
Ending Balance	<u>53 683</u>	<u>\$717 601</u>	<u>53 683</u>	<u>\$ 717 601 -2)</u>

(1- Consumption - scrap reflects value loss only.

(2 - Includes 18,359 pounds of heavy water scrap valued at \$229,027.

Arrangements were completed to ship 52 drums of heavy water scrap to SROO on or about June 15, 1964. The scrap valued at \$214,456 will be billed to SROO the day of shipment.

Savannah River Operations Office provided a new price list of heavy water as of May 1, 1964. The price per pound is now \$20.08, including \$13.72 fund and \$6.36 nonfund, representing an increase of \$.17 per pound fund and an increase of \$.09 per pound in the nonfund portion. Price allowance for scrap returned has also been reduced, which resulted in an additional charge of \$2,162 to operating cost, based on the April 30, 1964 scrap inventory.

During the month, the 3201 and 3201-A Buildings in the 3000 Area, consisting of a wood frame (27,733 sq. ft.) and a concrete block (165 sq. ft.), were transferred to Hanford Laboratories by the RLOO-AEC. These buildings, with a first cost of \$237,257 and a net book value of \$119,307, were the former Post and 5th AA Group Headquarters.

Nuclear Materials Operation advised us of the forthcoming Survey 21, Part 4, which will consist of verification of HAPO inventories of plutonium (including Wine) and deuterium as of the end of June 1964. A team consisting of RLOO-AEC personnel and a member of Nuclear Materials Operation will witness the physical inventory performed by custodians.

Permission was received from RLOO-AEC to ship 2,118 grams of clean platinum scrap to the New York Operations Office for reclaiming and credit. This resulted in a reduction of \$5,879 in the platinum inventory.

Laboratory Storage Pool activity is summarized as follows:

	<u>Current Month</u>		<u>FY to Date</u>	
	<u>Quantity</u>	<u>Value</u>	<u>Quantity</u>	<u>Value</u>
Beginning Balance	1 907	\$1 556 967	1 480	\$ 811 520
Items Received	192	86 957	1 945	1 312 659
Items Reclaimed by Custodians	(2)	(584)	(199)	(93 719)
Equipment Transfers	(23)	(10 256)	(341)	(143 710)
Items Disposed by PDR	(26)	(1 448)	(176)	(13 264)
Items Disposed by Excessing	(190)	(109 137)	(851)	(350 987)
Ending Balance	<u>1 858</u>	<u>\$1 522 499</u>	<u>1 858</u>	<u>\$1 522 499 -1)</u>

(1- Includes 180 items valued at \$117,905 on loan at May 31, 1964.

	<u>Current Month</u>		<u>FY to Date</u>	
	<u>Quantity</u>	<u>Value</u>	<u>Quantity</u>	<u>Value</u>
Loans & Transfers in Lieu of Purchases				
Loans	176	\$ 81 683	1 023	\$ 426 590
Transfers	<u>23</u>	<u>10 256</u>	<u>341</u>	<u>143 710</u>
Total	<u>199</u>	<u>\$ 91 939</u>	<u>1 364</u>	<u>\$ 570 300</u>
Operating Costs (4-30-64)		<u>\$ 1 360</u>		<u>\$ 14 634</u>

The value of material and equipment in custody of the Laboratory Storage Pool at May 31, 1964 totaled \$2.5 million as detailed below:

Equipment	\$1 522 499
Reactor & Other Special Materials	311 819
SS Material	154 800
Other Material	<u>502 729</u>
Total	<u>\$2 491 847</u>

A physical completion notice was issued on project CGH-999, Plutonium Recycle Critical Facility Conversion to Light Water.

The following contracts were processed during the month:

CA-430 Franklin L. Badgley
 CA-439 Consolidated Edison Company
 CA-440 Bechtel Corporation
 CA-441 Pacific Gas & Electric
 CA-443 James G. Knudsen
 CA-444 R. Wells Moulton
 SA-344 Background Music System
 SA-345 Department of Game, State of Washington

Personnel Accounting

L. R. Smith, M. R. Wolford, and W. J. Wakeford retired effective June 1, 1964.

The following patent awards were made during May:

L. A. Bray	HWIR 1674	Strontium Recovery from Acidified Hanford Sludge.
P. R. Rushbrook	HWIR 1565	Incorporation of Zeolites into Vitreous Bodies.
H. V. Herndon	HWIR 1082	An Electrical Mechanical Follower, Strainer or Creep Gauge.

Personnel statistics follow:

<u>Employee Changes</u>	<u>Total</u>	<u>Exempt</u>	<u>Nonexempt</u>
Employees at beginning of month	1 797	801	996
Additions and transfers in	18	9	9
Removals and transfers out	<u>20</u>	<u>6</u>	<u>14</u>
Employees on payroll at end of month	<u>1 795</u>	<u>804</u>	<u>991</u>
<u>Overtime Payments During Month</u>	<u>May</u>		<u>April</u>
Exempt	\$ 3 751		\$ 2 950
Nonexempt	<u>22 371</u>		<u>12 025</u>
Total	<u>\$26 122</u>		<u>\$14 975</u>

Gross Payroll Paid During Month

	<u>May</u>	<u>April</u>
Exempt	\$ 795 560	\$ 802 397
Nonexempt	<u>584 109</u>	<u>570 864</u>
Total	<u>\$1 379 669</u>	<u>\$1 373 261</u>

Participation in Employee Benefit Plans at Month End

	<u>May</u>		<u>April</u>	
	<u>Number</u>	<u>Percent</u>	<u>Number</u>	<u>Percent</u>
Pension	1 627	99.6	1 618	99.5
Insurance Plan - Personal	392		405	
- Dependent	1 391	99.9	1 392	99.9
U. S. Savings Bonds				
Stock Bonus Plan	147	36.3	150	37.0
Savings Plan	69	3.8	66	3.7
Savings and Security Plan	1 232	88.4	1 240	88.8
Good Neighbor Fund	1 287	72.8	1 291	71.7

Insurance Claims

	<u>Number</u>	<u>Amount</u>	<u>Number</u>	<u>Amount</u>
<u>Employee Benefits</u>				
Life Insurance	0	\$ -0-	0	\$ -0-
Weekly Sickness & Accident	11	1 004	12	957
Comprehensive Medical	60	4 201	74	4 976
<u>Dependent Benefits</u>				
Comprehensive Medical	<u>150</u>	<u>13 811</u>	<u>141</u>	<u>13 922</u>
Total	<u>221</u>	<u>\$19 016</u>	<u>227</u>	<u>\$19 855</u>

General

There were no reports of inventions or discovery during the month.

Technical interchange information - none.

TECHNICAL ADMINISTRATION

Requisitions for 26 nonexempt employees were filled; 14 remain to be filled.

Suggestion Plan activity:

Suggestions received	36
Suggestions adopted	12
Suggestions rejected	16
Suggestions in process	112

Visitors Center activity:

May attendance	1 779
Average attendance per day open	66
Cumulative attendance since 6-13-62	67 808
Conducted groups	15 (totaling 442 people)

Plant tour activity:

	<u>Number</u>	<u>Total</u>
General public relations tours	12	416
Special tours	4	65

Overall recruiting results for May are as follows:

Offers extended	15
Offers accepted	10
Offers rejected	14
Added to roll	3

Advanced Degree - Fifteen Ph.D. applicants visited HAPO for employment interviews. Eleven offers were extended; three acceptances and two rejections were received. Eight offers are currently open.

BS/MS (Direct Placement) - Four offers were extended. Five acceptances and no rejections were received. There are two offers currently open.

BS/MS (Program) - No offers were extended. Two offers were accepted and 12 rejected. Five offers are currently open.

Technical Graduate Program - Seven Technical Graduates were placed on permanent assignment. Two new members were added to the roll and none terminated from the roll. Current Program numbers 45.

FACILITIES ENGINEERING

At month end, Facilities Engineering Operation was responsible for nine active projects having total authorized funds in the amount of \$7,725,000. The total estimated cost of these projects is \$10,652,000. Expenditures through April 30, 1964 were \$3,125,000.

The following summarizes project activity in May:

Authorized projects at month end ----- 9

New projects authorized ----- 2
CAH-136, Services Addition - 327 Building
CAH-137, Temporary Physical Sciences Center

Projects completed ----- 1
CGH-999, PRCF Conversion to Light Water - At the
request of AEC, the Physical Completion Notice on
this project was distributed, and the project is
now officially closed out.

New projects submitted to the AEC ----- 1
CAH-146, Atmospheric Physics Building

New projects awaiting AEC approval ----- 5
CAH-114, Critical Mass Laboratory Addition
CAH-123, Laboratory Fire Protection System
CAH-126, Waste Transport System
CAH-128, Heat Transfer Apparatus for Model Studies
CAH-146, Atmospheric Physics Building

Project proposals being prepared ----- 3
308 Building Addition
Geological and Hydrological Wells - FY 1964
Variable Spectrum Test Reactor

The status of active projects follows:

CAH-916 - Fuels Recycle Pilot Plant - Construction is 55 percent complete compared to a scheduled 41 percent.

The 150 foot exhaust stack has been constructed. Roof decking is being placed over the Cold Canyon. It was necessary to remove all the red lead primer from the lower 25 feet of structural steel in order to apply the Amercoat coatings. Several sections of metallurgical cell metal wall liners have been installed. All of the floor to the hot pilot cells area has been poured. The tank vaults have been poured, and the stainless steel liners are being installed. Ventilation ductwork and electrical wiring are being installed throughout the building.

CAH-962 - Low Level Radiochemistry Building

Construction is 4 percent complete and is on schedule. Two-thirds of the concrete basement walls and footings have been poured. A temporary tie-in to the 300 Area substation was made to provide construction power.

CAH-977 - Facilities for Radioactive Inhalation Studies - No action is being taken on this project until the plan to relocate the Biology Laboratory has been resolved.

CAH-982 - Addition to Radionuclide Facilities - 141-C Building - No action is being taken on this project until the plan to relocate the Biology Laboratory has been resolved.

CAH-100 - High Temperature Lattice Test Reactor - A design schedule was approved by the Commission on May 1, 1964. The Commission reports detailed design is 73 percent complete compared to a scheduled 60 percent. The Commission's May 15, 1964 target date for completion of Phase I design was not met.

A total of 75 Title II design drawings has been received for comment.

The Commission reassigned design responsibility for the vertical safety rods and horizontal control rods from Vitro Engineering Company to the General Electric Company. The Company presented to Vitro and Commission representatives a review of research and development activities being conducted in support of the HTLTR project.

CAH-114 - Critical Mass Laboratory Addition - The project proposal requesting authorization of this project is still awaiting Washington-AEC approval.

CAH-116 - PRTR Decontamination and D2O Cleanup - Detailed design is about 54 percent complete compared to a scheduled 94 percent. Five detailed design drawings have been issued for our information.

CAH-119 - PRTR Storage Basin and Experimental Facilities Modifications - Detailed design is about 72 percent complete compared to a scheduled 92 percent. The Commission has requested J. A. Jones to submit a tentative construction schedule on the assumption J. A. Jones will perform the basin construction and subcontract the building addition. The Commission is preparing the project proposal revision to include the underwater handling equipment.

CAH-123 - Laboratory Fire Protection System - No action was taken by the Commission.

CAH-126 - Waste Transport System - No action was taken by the Commission.

CAH-128 - Heat Transfer Apparatus for Model Studies - 185-D Building - The Commission indicated an intent to return the project proposal unapproved. It has not been received.

CAH-136 - Service Addition - 327 Building - The design criteria and project proposal were approved on May 18, 1964 and May 21, 1964, respectively.

CAH-137 - Temporary Physical Sciences Center - The Commission issued a directive dated May 14, 1964 authorizing this project. The accompanying contingency maintenance request was also approved.

CAH-146 - Atmospheric Physics Building - The project proposal was transmitted to the Commission on May 18, 1964. No action has been taken on it.

Engineering Services and Plant Engineering

Engineering work was performed in support of design and construction on active projects, project proposals, preliminary planning and design criteria for new projects. Principal work items included: (1) field consultation and review of vendor drawings for Project CAH-916, FRPP; (2) engineering consultation on Vitro design of CAH-100, HTLTR and review of instrumentation drawings and procurement specifications; (3) preparation of design criteria for a vacuum deaerator for PRTR cooling tower water; (4) preparation of scope and estimate for controlled temperature at standards laboratory (3717-B); and (5) analysis of paper waste disintegrator for use in 300 Area.

Facility planning and budget study work included: (1) completion of a formal report on the Biology Facility Relocation to 300 Area; (2) completion of a study of single building plan for certain laboratories proposed in FY 1966 budget; and (3) preparation of budget facility descriptions for Biology Laboratory, Additional Radiometallurgy Facilities and Variable Spectrum Test Reactor.

Engineering and consulting work was provided to research and development personnel as requested. Major work items included: (1) engineering assistance in providing a decontamination glove box, a transfer glove box and means for transferring plutonium bearing specimens to and from an electron microscope in 325 building without contamination spread; (2) engineering assistance to delineate scope of service piping for 324 building waste calcination; (3) consultation on instrumentation on several high pressure loops in the 314 building; (4) preparation of specifications for instrument and electrical components for 314 gas loop; (5) preparation of a conceptual design for an access port to 324 building cell; (6) engineering of the core for the second loading of the critical facilities in PRTR and preparation of scope design for the third core; and (7) analysis of power source required for 1,000 M ampere welder in 308 building.

Plant engineering work during the month included: (1) study of use of 314 building space; (2) analysis and engineering of modifications to criticality alarm systems to improve reliability; (3) analysis of 306 civil defense

alarm system to obtain manual operation within the building; (4) analysis of 326 monorail and engineering of modifications; (5) sketch of piping arrangement for 308 condensate disposal; (6) analysis and consideration of reduction of sound level at rear face of 325 cell; and (7) analysis of cooling water flow for 306 building arc melt furnace.

Emergency engineering service and miscellaneous consultation was provided on: (1) installation of temporary constant voltage power to NMR room in 325 building; (2) assistance on installation of 325 emergency generator; and (3) structural engineering assistance on installation of monorail in 328 building.

Consulting service for other departments included: (1) assistance to CPD in hazards evaluation study for Projects CAC-945 and CAC-970; and (2) instrumentation consultation to CPD on the Americium Recovery Facility, the 234-5 building dry air system controls and the Fab Oil Prototype Facility.

Pressure Systems

Engineering of a high pressure hydrogen purifier was completed during the month. Fabrication and initial operation will be followed.

Assistance was provided to Chemical Effluents Technology for purchasing or adapting a vessel for use in the 271-CR building. The vessel will be about 500 gallon capacity and operate at 50 psig steam pressure. A vendor information print was made for purchase, but a vessel was located on-site which may be modified for use. The vessel is code, but the records cannot be located. Facilities Engineering has contacted the manufacturer of the vessel to obtain records. If complete records can be obtained, the old vessel will be modified.

Assistance was provided for the fabrication of a hydrogen reaction system including a small vessel. The unit is designed for only 100 psig, but must be protected against an unrestrained reaction of hydrogen and oxygen.

The Travelers Insurance Company third party inspector inspected all the vessels within the PRTR containment vessel. The only recommendation was to periodically monitor the pitting attack (corrosion) in the deaerator vessel.

Facilities Operation

Landlord costs for the month of April were \$136,151, which is 81 percent of the forecast for the month. Fiscal costs for 10 months are \$1,637,089, which represents 100 percent of predicted. This realignment of the expenditures to the predicted costs was accomplished by reducing maintenance levels

and by obtaining credits for overliquidations from servicing components. Maintenance activity is returning to normal.

The following table summarizes the Waste Disposal Operation:

<u>Item</u>	<u>March</u>	<u>April</u>
Concrete waste barrels disposed to 300-Wye burial ground	7	2
Concrete waste barrels disposed to 200-W plutonium burial ground	8	5
Loadluggers of dry waste disposed to 300-Wye burial ground from 300 Area sites other than the 325 building	26	20
Loadluggers of dry waste disposed to 300-Wye burial ground from the 325 building	2	5
Loadluggers of dry waste disposed to 200-W plutonium burial ground from 300 Area sites	7	6
Cans of dry waste disposed to 300-Wye burial ground vertical pipes	115	86

Nonroutine work in the 327 and 309 buildings during the month generated an above normal flow of crib waste. Eighty-four hours of overtime were worked to dispose of this additional waste.

Building Operations

When PRTR shut down on May 8 for scheduled maintenance, both river pumps were pulled, inspected, and electrical circuits were modified. New oil seals were installed in #2 pump. Filter plant basins, clearwell, and filters are being cleaned.

Leakage through the CWS filter beds of all three units in 308 building were checked with zinc sulfide and black light. No. 1 bed showed excessive leakage. This bed was inspected, and three filters were found damaged. These were renewed, and all other filters were checked for tightness.

A small water still jacket required repair of several small pinhole leaks in 325 building. Emergency diesel generator switchgear in 325 was tested this month. A coil failure in the switchgear opened the normal breaker, but caused no outage, because the emergency feeder supplied the necessary power. The coil circuitry of the diesel generator switchgear is being reviewed. DC motor generator set is being installed between 1 and 2 supply units. This unit will be used exclusively by laboratory personnel.

On May 19, a switching fault at the substation caused all equipment and lights to be out of service for approximately five minutes. This fault also caused a false criticality alarm and area evacuation.

Drafting

The equivalent of 184 drawings were produced during the month for an average of 24 man-hours per drawing.

Major jobs in progress are: (1) ultrasonic tester for irradiated fuel elements, N Reactor; (2) high temperature furnace, 306; (3) powder processing line, 231-Z; (4) 309 building piping service drawings; (5) FRPP service piping to waste calcination equipment; (6) critical mass physics safety and control rods; and (7) thoria hood line, 325.

Construction

	<u>Unexpended Balance</u>
Orders outstanding beginning of month	\$413 645
Issued during the month (inc. supp. & adj.)	138 429
J. A. Jones expenditures during month (includes C.O. cost)	179 644
Balance at month end	372 420
Orders closed during month	99 865

Maintenance work orders active - 6, face value - \$18,014.

Major nonproject jobs in progress during the month were: (1) construct swine farrowing barn and pens, 141-F; (2) modify heating and ventilating system, 144-F; (3) install hoods and exhaust duct work, 1705-F; (4) construct new dog runs and modify existing dog runs, 144-F; (5) install canopy and services, 1705-F; (6) install fire detection, 100-F Area; (7) construct pasture and sprinkler system at meteorological tower; (8) modify and install hood 44, 308; (9) construct autoclave pit, storage area, and HTLTR mock-up, 314; (10) construct thoria laboratory room 417, and install emergency generator, 325; (11) install lighting, fire detectors, and construct roof, 3718-A/B; (12) construct manhole and retention waste by-pass line, install snubbers in high

pressure lines and install job crane and hoist, 309; (13) modify E-cell and install safety valves, 327; (14) install electrical services and air conditioning for computer, 321; (15) install hydrogen system, install air conditioning unit in metallography lab, and install rectifier for arc melt furnace, 306; and (16) construct offices and storage addition, 328.

Containment Systems Experiment - Eighteen scope design and vendor information drawings are scheduled for this program. Twelve have been issued to Vitro for design or to J. A. Jones for procurement. J. A. Jones Company has awarded a subcontract to Chicago Bridge and Iron Company in the amount of \$245,830 for the fabrication and installation of the containment vessel. Two bids were received for the simulator vessel. The apparent low bid was received from Struthers-Wells Corporation in the amount of \$111,350. The delivery period submitted by both bidders is considerably more than anticipated. This will affect the sequence of experiments in this program. Construction work is progressing as scheduled. Demolition work is now confined to the cell beam and column. The galleries are being prepared for occupancy. Electrical transformers and switchgear are being obtained from on-site locations which are not in use. The expenditure of funds authorized Facilities Engineering for FY 1964 for the criteria, design, procurement, and construction will amount to \$185,000. Of this amount, \$10,000 will be used in administration and field inspection; \$40,000 in criteria and design; and \$135,000 in construction and procurement.

Renovation of Wells - The subcontractor has completed six wells and is on schedule.

Waste Solidification Prototype - Fabrication work is on schedule.

300 Area Waste Lines Testing - Preliminary proposals for testing have been received from two potential contractors. The use of nitrous oxide as a test gas is being analyzed for possible reaction with waste fluids.

Crane Safety Inspection - The inspector was on site from May 13 through May 28. Inspections were conducted for other HAPO departments as requested. All Hanford Laboratories' cranes and hoists have been inspected, and repairs are being made as required.

Acting Manager
Finance and Administration

DS Parsley:RDT:whm

REACTOR DEVELOPMENT - O4 PROGRAMPLUTONIUM RECYCLE PROGRAMPlutonium Recycle Test ReactorOperation

Reactor output for May was 84 MWD. A summary of the fuel irradiation program as of May 31, 1964, follows:

	<u>Al-Pu</u>		<u>UO₂</u>		<u>PuO₂-UO₂</u>		<u>Other</u>		<u>Program Totals</u>	
	<u>No.</u>	<u>MWD</u>	<u>No.</u>	<u>MWD</u>	<u>No.</u>	<u>MWD</u>	<u>No.</u>	<u>MWD</u>	<u>No.</u>	<u>MWD</u>
In-Core	0		7	1474.4	78	12214.7			85	13689.1
Maximum				295.4		289.9				
Average				210.6		156.6				
In Basin	7	569.9	25	2720.1	33	2426.7			65	5716.7
Buried							1	7.3	1	7.3
Chem. Process.	68	5465.8	35	1965.8					103	7431.6
Program Totals	75	6035.7	67	6160.3	111	14641.4	1	7.3	254	26844.7

Note: (MWD/Element X 20 $\approx$ MWD/TU for UO₂ and PuO₂-UO₂.)

The major portion of the month was devoted to containment vessel leak rate tests and maintenance. The performance of the tests required that the reactor be totally discharged of fuel. The primary system was drained to permit repair and modification work.

Heavy water loss and indicated helium loss for May were 627 pounds and 39,056 scf., respectively.

A total of 173 reactor outage hours were charged to repair work. Main items were:

Containment vessel leak repairs	101 hours
HX-5 fitting repairs	53 hours

Several containment leaks were detected and repaired. Very few of the mechanical closures required correction. Many electrical cables and potted vessel penetrations leaked. These were the more difficult and time-consuming to locate and repair.

New type fittings were installed on the outlet of HX-5. The replacements were necessary when leaks developed on many of the fittings which had been used following the inspection and hydrotest of HX-5 tubes in November 1963.

Preventive maintenance required 400 hours or 9% of the total maintenance effort (assigned craftsmen).

Improvement Work Status (significant items)

Work Completed

Removal of Motor Operated Valve on HX-1
Modify Containment Vessel Vacuum Breakers
Aldrich Injection Pumps - Installation of Low Lift Valves
Instrument Power Transfer System
Indication of DC Solenoid Failure
Process Sewer Bypass Manhole #2A
Compressed Air Modifications
High Pressure Helium Filter Installation

Work Partially Completed

Corrosion Loop Installation
Installation of New Alarm Annunciator
Vibration Snubbers for Earthquake Protection
Supplemental Emergency Water Addition

Design Work Completed

Corrosion Loop Installation

Design Work Partially Completed

Flux Wire Scanning System
Pneumatic Irradiation Facility
PRTR Experimental and Building Facilities Addition
PRTR Increased Power Level
Creep Test Facility

Process Engineering and Reactor Physics

Some two-dimensional calculations of the proposed flux trap in PRTR for the NASA nuclear rocket program have been completed. It was determined that fluxes in excess of 1×10^{14} would probably be attainable in the sample fuel pieces.

Preliminary calculations to estimate the desired enrichment for a high density core - physics loading for a continuous six-month run indicated that $\text{UO}_2 - 2 \text{ w/o PuO}_2$ would be too reactive, with a predicted cold, clean K effective of $\sim (1.22)$ -- nearly twice the probable requirement, and that an enrichment $< 1.5 \text{ w/o PuO}_2$ would be adequate.

The possibility of installing a neutron diffraction spectrometer in PRTR was discussed.

Final reports were issued for the following PRTR Tests:

No. 5 (Proposal to Irradiate a Nested Tubular Fuel Element, Mark II-C, in the PRTR).

No. 42 (Full Design Operation of Steam Generator).

No. 47 (Irradiation of Unautoclaved Zr-2 Clad LX Pu-Al Fuel Element).

No. 66 (Calibration of New Effluent Activity Monitors).

A leakage rate of less than one percent at a test pressure of 14-1/2 psig was measured on the containment vessel. The vessel was pressurized five different times, reaching a test pressure of 15 psig on three occasions and stopping at 6 psig on the other two tests. Leakage rate tests were conducted at each test pressure and in addition, preliminary leakage rate tests were conducted at 3 and 6 psig prior to proceeding to the 15 psig test pressure on two of these tests.

Considerable time was gained in estimating a leakage rate by using the differential pressure measurement between the reference volume and the containment vessel provided by the servomanometer. It was possible to predict a good estimate of the leakage rate projected to a 24-hour interval within an hour of the beginning of the test. The testing technique was checked by superimposing a known leakage rate onto the existing leakage rate for approximately 10 hours. Detailed test experience and findings will be reported separately.

While pressure testing the HX-5 tube bundle, a single tube failure due to stress corrosion cracking from the outside of the tubing was detected. Visual examination of the tube bundle did not reveal any more evidences of stress corrosion cracking. Precautions were taken to prevent conditions which would promote further stress cracking.

Fuel Element #5168, a 0.48% enriched $\text{UO}_2\text{-PuO}_2$ Mark I cluster, was found to have a cladding defect. This element differed from most previous fuel failures in that the element failed after more than 200 MWD exposure. Because of the high rates of heat generation of the fuel following the long period of reactor operation, stagnant water tests were not conducted. The failed element was located by gamma scans of coolant samples taken from the tube nozzles just prior to the discharge of the fuel. A slightly higher Xe-135 activity was observed with the defective element and the failure was confirmed by small bubbles observed in the storage basin.

Experimental Reactor Services

The status of the various test elements at the end of May 1964, is shown below. Those elements which had reached their assigned goal exposure or had been permanently discharged for other reasons prior to May 1, 1964, have been deleted from the table.

Test No.	Location	Number	Description	Date Initial Charge	Discharged	Approximate Accumulated MWD
14	1956	5097	Moxtyl-Swaged	4/2/62	--	182.4 Repad
14	1352	5098	Moxtyl-Vipac	5/8/62	--	274.2 Repad
14	1758	5099	Moxtyl-Vipac	5/8/62	--	196.4 Repad
48	1156	5150	Moxtyl (1/2" x 1/2" Pads)	8/1/62	--	191.3
54	1542	5116	Moxtyl (Clip-on Pads)	5/8/62	--	199.0
54	1554	5118	Moxtyl (Clip-on Pads)	5/8/62	--	289.3
61	1249	5185	Moxtyl-Physics	5/28/63	--	183.0
61	1354	5186	Moxtyl-Physics	5/28/63	--	175.9
61	1445	5192	Moxtyl-Physics	6/13/63	--	184.6
67	1152	5119	Moxtyl (Repaired Wire)	10/20/63	--	108.6
67	1457	5117	Moxtyl (Repaired Wire)	10/20/63	--	149.5
80	1544	5214	Moxtyl (1% PuO ₂ , Swaged)	11/18/63	--	119.9
85	1847	5230	Moxtyl (1% PuO ₂ , Vipac)	1/30/64	--	69.3
37	1548	1098	UO ₂ -Physics	5/12/62	--	172.1
37	1550	1097	UO ₂ -Physics	5/12/62	--	183.9
37	1451	1100	UO ₂ -Physics	5/12/62	--	151.3
37	1552	1099	UO ₂ -Physics	5/12/62	--	153.7

Four fuel elements were stagnant water tested in the basin, confirming element 5168 as a leaker (5168 is a 0.48% Moxtyl having 250 MWD exposure). The failed rod was removed from element 5168 and shipped to Radiometallurgy for examination.

Plutonium Recycle Critical Facility

Experiments with EBWR fuel continued. Data was taken for void and substitution measurements and for flux distribution and spectrum studies. An outage was taken beginning May 8 for miscellaneous modifications and inspections including changes to the EBWR core lattice plates. This outage, concurrent with PRTR containment testing work, lasted through month-end.

The EBWR core for the PRCF has been modified through the provision of a removable nineteen hole center section. This additional experimental capability was required to permit insertion in the core of test assemblies with diameters greater than the present grid hole diameters. These assemblies will include such things as special test chambers for flux measurements, oversize tubes for traverse mechanisms and kinetics experiments and special wire flux monitors for flux measurements between fuel cells.

UNCLASSIFIED

Fuel Element Rupture Test Facility

The Rupture Loop was restored to operating status. A dummy decontamination run was completed without difficulty. Current plans are to charge the "UO₂ Water Tube Element" into the Rupture Loop.

Chemical Processing of Spent PRTR Fuels

Analyses of the ~7.4 Kg of PuO₂ recovered during the April Redox Campaign showed >5 ppm boron for ~4 Kg of the powder. One can (~700 grams) showed 50 ppm boron.

The Commission was given a list of twelve defective, low-exposure, 1.0% PuO₂-UO₂ fuel elements to determine their ultimate disposal.

TECHNICAL SHOPS OPERATION

Total productive time for the period was 22,849 hours. This includes 15,307 hours performed in Technical Shops, 4,333 hours assigned to J. A. Jones Company, 3,057 hours assigned to offsite vendors, and 152 hours to other project shops. Total shop backlog is 15,747 hours, of which 90% is required in the current month with the remaining hours distributed over a three-month period. Overtime worked during the month totaled 703 hours or 3.9% of the total available hours.

Distribution of time was as follows:	<u>Man Hours</u>	<u>% of Total</u>
N Reactor Department	2 128	9.3
Irradiation Processing Department	3 958	17.3
Chemical Processing Department	482	2.1
Hanford Laboratories	16 281	71.3
Hanford Utilities and Purchasing Operation	-	-

LABORATORY MAINTENANCE OPERATION

Total productive time was 17,100 hours of 19,000 hours potentially available. Of the total productive time, 89% was expended in support of Hanford Laboratories components, with the remaining 11% directed toward providing service for other HAPO organizations. Craft overtime worked during the month was 3.2% of total available hours.

Manpower utilization (in Hours for May was as follows:

A. Shop Work		1 800
B. Maintenance		6 800
1. Preventive Maintenance	2 900	
2. Emergency or Unscheduled Maintenance	1 400	
3. Normal Scheduled Maintenance	2 500	
C. R&D Assistance		8 500

UNCLASSIFIED

INVENTIONS OR DISCOVERIES

All persons engaged in work that might reasonably be expected to result in inventions or discoveries advise that, to the best of their knowledge and belief, no inventions or discoveries were made in the course of their work during the period covered by this report except as listed below. Such persons further advise that, for the period therein covered by this report, notebook records, if any, kept in the course of their work have been examined for possible inventions or discoveries.

<u>INVENTOR</u>	<u>TITLE OF INVENTION OF DISCOVERY</u>
G. S. Allison	The Field of High Surface Area to Fuel Volume Ratio Nuclear Fuel Elements of a Wide Range of Materials and Operating Temperatures (HWIR-1645)
R. E. Skavdahl	Preparation of Beta-Pu ₂ O ₃
D. R. Green	Ultra-Stable Eddy Current Method for Detecting Hydride in Zircaloy-2 (HWIR-1727)
C. L. Frederick	A Rapid Nondestructive Method for Determination of Material Elastic Properties Using Ultrasonic Wave Synthesis, Propagation and Analysis (HWIR-1730)
B. B. Brenden	A Novel Method for Imaging Ultrasonic Energy (HWIR-1731)
R. D. Dierks, N. P. Wilburn, and E. Shimoda	The Invention Report for March (HW-81472 C) contained an error. The correct listing should be: Continuous Analysis of Organic Solutions for Uranyl Nitrate

Manager, Hanford Laboratories

END

**DATE
FILMED**

4 / 13 / 93