D. -100-100154-T3

RECEIVED
U.S. DEPT. OF ENERGY
00 APR 11 PM 10:00
ADMINISTRATIVE SERVICES DIV.

DOE/PC/79654--T3
DE93 011512

DEVELOPMENT OF A RETROFIT COAL COMBUSTOR FOR INDUSTRIAL APPLICATIONS

TECHNICAL PROGRESS REPORT APRIL - JUNE 1987

PREPARED FOR:

U.S. DEPARTMENT OF ENERGY
PITTSBURGH ENERGY TECHNOLOGY CENTER

DOE CONTRACT DE-AC22-87PC79654

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

BY:

MANAGEMENT AND TECHNICAL CONSULTANTS, INC.

P.O. Box 21, Columbia, Maryland, 21045 (301) 982-1292 Telex 292354 / MTCI UR

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PREFACE

A detailed description of the background, technology and application for the development of a retrofit coal combustor for industrial applications was provided in the first quarterly report for the period January 1987 - March 1987. This material is omitted in this report.

During this quarter, testing continued on the advanced refractory chamber (ARC) to monitor the behavior of slag flow as a function of configuration and a new tailpipe configuration was tested on both pulverized and micronized coal (Pittsburgh #8). Slag buildup within the tailpipe was minimal.

The design and fabrication of the tandem unit was initiated. This unit will be completely lined with Pyrotab 3400 alumina. A flue gas scrubber was also designed, fabricated and installed, primarily to meet the California required restrictions during off-design or upset operations.

TABLE OF CONTENTS

	<u>Page</u>
1.0 <u>PROGRAM DESCRIPTION AND WORK STATUS.</u>	1
1.1 PROGRAM DESCRIPTION.	1
1.2 TASK DESCRIPTIONS.	1
1.2.1 <u>Task 1: Optimization of the Laboratory</u> <u>Scale Combustor.</u>	1
1.2.2 <u>Task 2: Scale-Up Pilot Unit Design</u>	3
1.3 STATUS	3
2.0 <u>TECHNICAL DISCUSSION OF WORK COMPLETED</u> <u>DURING THE REPORTING PERIOD.</u>	7
3.0 <u>PLANNED ACTIVITY FOR THE NEXT PERIOD</u>	9

LIST OF FIGURES

1 PROGRAM LOGIC FOR DEVELOPMENT OF A PULSE COAL COMBUSTOR FOR RETROFIT APPLICATIONS	2
2 TANDEM PULSE COMBUSTOR WITH COUPLED INLET AND CYCLONIC EXHAUST . .	5
3 PULSE COMBUSTION TEST FACILITY WITH SO ₂ SCRUBBER UNIT.	6

SECTION 1.0

PROGRAM DESCRIPTION AND WORK STATUS

1.1 PROGRAM DESCRIPTION

The objective of this phase of the program for the development of a retrofit pulse coal combustor for industrial applications is to design, fabricate, test and evaluate advanced chamber designs at the laboratory scale utilizing several fuels (Task 1). The activities are structured to provide design criteria for scaling up to the pilot-scale level for the demonstration of a pulse combustor fired with coal-water mixtures for industrial boiler and process heater retrofit applications. The program logic is depicted in Figure 1.

The design data and information acquired during Task 1 of the initial phase will be used to develop scale-up design criteria for scaling the laboratory-scale design to pilot-scale including interface requirements for the field demonstration. The scale-up pilot unit design will be sufficiently developed to allow fabrication of the unit for testing in the existing test facility upon DOE exercising its option for the follow-on activities of this program. These follow-on activities will include the fabrication, test and engineering evaluation of the pilot-scale combustor and include technical and laboratory test support activities for reducing the technical risks and costs of development at the pilot-scale. Based on the information, test, data and technical support activities, a retrofit combustor system will be designed for field demonstration as shown on the left in Figure 1.

At the end of this phase of the program, a design for a retrofit combustor system for field demonstration will be completed with the exception of site-specific design details which will be provided after approval for the field demonstration at the subcontractor test site.

1.2 TASK DESCRIPTIONS

1.2.1 Task 1: Optimization of the Laboratory-Scale Combustor

The specific objectives of this task are to optimize the chamber design of the feasibility units developed under Contract No. DE-AC22-83PC60419 for optimized performance with coal and coal-water slurry fuels and to reduce performance sensitivity to variations in fuel specifications.

To meet these objectives, two advanced combustion chamber configurations will be designed and fabricated at the laboratory-scale (1 - 2 MMBtu/hr) size. Design options will include both bare metal and refractory-lined units to permit both air-cooled and adiabatic operation. These advanced designs will be fabricated and then tested to evaluate the performance with respect to the following parameters:

FIGURE 1:
PROGRAM LOGIC FOR DEVELOPMENT OF A PULSE
COAL COMBUSTOR FOR RETROFIT APPLICATIONS

- o Combustion intensity and heat release rates,
- o Staging capability,
- o Dry sulfur capture and ash rejection performance,
- o Carbon burnout efficiency,
- o NO_x emissions performance, and
- o Sensitivity to changes in fuel specifications.

Refractory-lined combustor tests will be conducted employing both the feasibility unit chamber design and one of the advanced chamber designs selected on the basis of the evaluation tests.

1.2.2 Task 2: Scale-Up Pilot Unit Design

The specific objective of Task 2 is to design a pilot-scale test unit for evaluation in the existing MTCI facility. To meet this objective, the data acquired under Task 1 will be utilized to develop design scale-up criteria for scaling the laboratory-scale design to pilot-scale. These criteria include consideration of the effect of scale-up on combustor operating frequency, firing intensity (in MMBtu/hr cu.ft.), and the intensity of pressure fluctuation with increased firing rate. The scale-up design also considers all the interface requirements of the pilot-scale development activities at the subcontractor test site. The design developed will be sufficiently detailed to permit the fabrication of the unit when approved by DOE.

1.3 STATUS

Several combustor configurations were tested to evaluate the general performance of the Advanced Refractory Chamber (ARC) and to monitor the behavior of slag flow as a function of system configuration.

The ARC was oriented vertically in a down-fired mode. An air plenum was provided at the aerodynamic valve inlet. The fuel supply system consisted of a phase injector with a one-inch injector tube and deflector. The unit was tested with and without preheated air to the coal eductor.

In the first system configuration, a refractory tailpipe was employed consisting of a 36-inch long straight section (two-inch diameter) followed by a 30-inch section which smoothly flared to a seven-inch diameter at the tailpipe exit. The tailpipe was tangentially connected to a decoupling cyclone drum. Performance was tested on both pulverized and micronized coal. Pulverized Pittsburgh No. 8 was fed at a rate of 44 lbs/hr with a support natural gas flow rate of 4.3 SCFM (i.e., approximately 69 percent coal based on a total fired heating value of 818,000 Btu/hr). Combustion efficiency, calculated using the carbon in ash method, was 72.4 percent. Micronized coal was fed at a rate of 32 lbs/hr with a support natural gas flow rate of 3.5 SCFM (i.e., 66 percent coal based on a total fired heating value of 615,000 Btu/hr). Combustion efficiency for the micronized coal was 88 percent at the tailpipe exit, and 96 percent at the exit of the cyclone drum.

Although combustion performance appeared to be high, the general stability of operation was relatively poor, particularly in later stages of the test run. Further testing indicated that slag build-up in the 36-inch straight section of tailpipe was compromising performance by increasing resistance leading to a choking effect. Random disengagement of slag in this region was probably also responsible for instabilities within the system.

Based on this hypothesis, a new tailpipe configuration was devised and tested. Here, a single 30-inch section was used which was continuously flared from the combustor to the tailpipe exit (two-inch to seven-inch). This configuration was tested on both pulverized and micronized Pittsburgh No. 8. Combustion efficiencies of 88 percent were measured for micronized coal. More importantly, slag build-up within the tailpipe did not appear to occur to any great degree.

The design and fabrication of the tandem pulse combustors shown in Figure 2 progressed well. The entire unit is made up of castable refractory material (Pyro-tab 3400 Alumina). The chambers are made in two sections each for ease of inspection. The tailpipes are made in one section each and are conical. The exhaust plenum is a rectangular box type (two-foot wide by three-foot long by one-foot high) with two inlets on top and one exit in the bottom connecting to a cyclone. The cyclone is also refractory lined. The flue gases are sent to a scrubber before discharging.

MTCI's test facility operations meet the California required standards for environmental emissions control. However, since the possibility of excess SO_2 emissions exist during off-design operations, it was deemed prudent to replace the present quench tank and baghouse with a scrubber for these tests. This also eliminated the need for servicing the baghouse which has required frequent change-outs due to quench tank condensate formation on the fabric and subsequent pressure drop increase. A schematic of the scrubber is shown in Figure 3.

The scrubber designed consists of two parts, lower packing and upper packing. The body of the scrubber is a six-foot high stainless steel tank with a 2-foot diameter. The gases will enter the tank through a ten-inch port, two feet from the bottom and then pass through a two-foot bed of stainless steel raschig rings with a spray of water and Na_2CO_3 solution on top. The bottom two feet is used to hold the recycle solution. Above the tank is an eight-foot length of ten-inch stainless steel pipe filled with raschig rings. An identical spray is set up above these rings too. The Na_2CO_3 solution will be sprayed above either of these two beds or both at a rate of nine gallons per minute. This will quench the gases and remove any SO_2 and ash. A level control will be installed on the holding section of the scrubber, so that when the caustic solution gets low, a water spray will come on to maintain the liquid level.

The flue gas scrubber was also assembled and tested during this period and will serve both the industrial retrofit program (DE-AC22-87PC79654) and the residential program (DE-AC22-86PC90278).

FIGURE 2: TANDEM PULSE COMBUSTOR WITH COUPLED INLET AND CYCLONIC EXHAUST

FIGURE 3: PULSE COMBUSTION TEST FACILITY WITH SO₂ SCRUBBER UNIT

SECTION 2.0

TECHNICAL DISCUSSION OF WORK COMPLETED DURING THE REPORTING PERIOD

As previously reported for test runs conducted during the last period, slag deposition in the tailpipe and combustor for the ARC unit was somewhat problematic. Initial test runs with the ARC fired horizontally with coal resulted in slag collection on the chamber walls. Vertical firing of the ARC on coal resulted in slag deposition on the straight sections of the tailpipe walls. Therefore, the objective of investigations conducted during this period was to evaluate and identify the optimum combustor orientation and tailpipe configuration leading to control of slag build-up within the combustion system.

It is now believed that the continuously flared tailpipe controls slag build-up in the following manner. First, as slag forms in the combustion chamber, it slowly flows into the neck of the tailpipe entrance. Here, the slag is met with a high velocity combustion gas flow which shears the slag into small droplets. Since the wall of the tailpipe is continuously expanding, the momentum of the entrained slag prevents impingement on the tailpipe walls. As the slag traverses down the tailpipe, it is cooled forming hardened particles that do not adhere on surfaces and that are subsequently collected in the cyclone. Although exhaustive data collection and analysis was not performed for each run, several important results were achieved. First, straight tailpipe sections degraded combustion stability through a mechanism which is believed to involve slag choking. Second, this problem can be avoided using continuously flared tailpipes. Third, combustion efficiencies over 88 percent were measured for micronized coal fed at a rate accounting for 66 percent of the total fired fuel. The results of the series of tests indicated that future configurations should employ the continuously flared tailpipe.

Previous testing has been performed using only single pulse combustors. Improved phasing of fuel has been attempted using a phased injector as described in the prior reports. The purpose of the phase injector was to reduce the amount of fuel (coal particles, in particular) which is forcibly injected into the combustor during the exhaust phase. Injection during the exhaust phase is obviously undesirable since fuel particles are rapidly and prematurely conveyed out of the combustion chamber thereby resulting in a low combustion efficiency.

An alternate method of fuel biasing using tandem combustors may be more effective in accomplishing the task of fuel phasing and may also offer a more practical means of implementation. The tandem unit concept offers other benefits which are addressed below.

In the tandem configuration, the fuel supply system consists of a main fuel line feeding a tee connected to each of the tandem combustors. The fuel tee acts as a couple allowing automatic fuel biasing between the combustors.

Efficient phasing of fuel in the coupling line is dependent on the ability to operate the tandem chamber 180° out of phase. Under these conditions, one chamber achieves a low pressure phase just as the other chamber simultaneously

achieves a high pressure phase. Due to the pressure gradient existing in the fuel coupling line, combustion products are accelerated from the high pressure chamber to the low pressure chamber. The momentum of the accelerated gases biases a flow of fuel from the main fuel line into the tee and eventually into the low pressure combustion chamber. One half cycle later, a similar phenomena occurs in the opposing direction. By these means, fuel can be properly phased without the use of mechanical flapper valves or an independent phasing chamber.

Efficient fuel phasing through the use of a common fuel coupling line depends on operation of the tandem units with a 180° phase lag. It is possible that the natural instability of the tandem units employing a common fuel coupling line may be sufficient to automatically pull the two units 180° out of phase. This conclusion derives from the assumption that the units will inherently hunt for the most stable and robust operating state. And, of course, this state is most probably that condition which results in efficient fuel phasing, i.e., the condition of a 180° phase lag.

However, in order to accelerate achieving this state during start-up and to dampen excursions from this state during transients or natural system upsets, additional coupling means can be employed.

Several means for coupling the tandem units can be envisioned including: 1) tailpipe coupling, and 2) aerodynamic valve coupling. Tailpipe coupling is anticipated to be an effective approach due to the super-charging action of the high momentum exhaust fluids. Tailpipe coupling is also advantageous in that unburned particles will most probably be retained within the influence of the intense fluctuating flow field at the exhaust region.

Despite the benefits offered by tailpipe coupling, aerodynamic valve coupling appears to provide a more simplistic approach. If coupling is performed at the aerodynamic valve, the high velocity exhaust at the exit of the tailpipes may be directly connected to a cyclone decoupler. Furthermore, blow-back of unburned particles through the aerodynamic valve will result in particle capture at the opposing valve. This is significant since the collection of blow-back particles at the inlet plenum may present somewhat of a practical problem.

Most importantly, since the industrial unit is intended for operation in a slagging mode, erosion of opposing exhausts in the tailpipe coupled mode could be excessive. Furthermore, since practical coupling of the tailpipes requires the introduction of an elbow bend, it is possible that slag particles may plug the exhaust at this point. Therefore, coupling of the advanced refractory tandem combustors will be performed at the aerodynamic valves. In the inlet side of the combustor, the coal fuel feed lines and the auxiliary flue (gas) feed lines for the two combustors are connected by "tees", as shown in Figure 2.

SECTION 3.0

PLANNED ACTIVITY FOR THE NEXT PERIOD

The tandem configuration will be assembled and tested. The entire unit will be refractory lined, including the cyclone. Each of the units making up the tandem configuration will be tested for performance verification. Depending upon the degree of testing and data evaluation completed, and the availability of test fuels, the scale-up pilot unit design activity may be initiated.

END

DATE
FILMED
5/13/93