**DOE/PC/90157-1
(DE92014386)**

**CYCLONE REBURN USING COAL-WATER FUEL
Final Report**

**By
C. F. Eckhart
R. F. DeVault**

October 1991

Work Performed Under Contract No. AC22-90PC90157

**For
U.S. Department of Energy
Pittsburgh Energy Technology Center
Pittsburgh, Pennsylvania**

**By
The Babcock & Wilcox Company
Alliance, Ohio**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, **DTIC-65-018**.

Available to the public from the National Technical Information Service, U. S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

CYCLONE REBURN USING COAL-WATER FUEL

Pilot-Scale Development and Testing

FINAL REPORT

October 1991

Report DOE/PC/90157-1
(Babcock & Wilcox Report RDD:91:4119-01-01:01)

Principal Investigators

C. F. Eckhart and R. F. DeVault

Sponsored by

The U. S. Department of Energy
Pittsburgh Energy Technology Center

Work Performed Under Contract DE-AC22-90PC90157

DOE Program Manager

P. M. Goldberg

The Babcock & Wilcox Company

Research and Development Division
Alliance Research Center
Alliance, Ohio 44601-2196

CUSTOMER FEEDBACK QUESTIONNAIRE

Please help us do a better job for you.

Report Title: CYCLONE REBURN USING COAL-WATER FUEL

Pilot-Scale Development and Testing

Report No.: B&W Report RDD:91:4119-01-01:01
DOE Report DOE/PC/90157-1

Customer feedback on our work is important to us. We would like to have your comments concerning this report. Your cooperation in completing this form and returning it to the address shown will assist us in improving our service to you.

Do the contents of this report meet your needs? ☐ Yes ☐ Not Entirely, because _____

Did you receive this report when we promised it? ☐ Yes ☐ No

Comment: _____

How could we have made this report more useful to you? _____

Thank you.

Name: _____ Date: _____

Organization: _____

Please fold and return this form to address shown on the reverse side.

(1 LEAF OFF)

CONTENTS

Section	Page
1 INTRODUCTION	1-1
1.1 Problem and Objectives	1-1
1.2 Background	1-1
1.3 Technical Approach	1-4
1.4 Limitations and Report Organization	1-7
2 FUEL FORMULATION AND OPTIMIZATION	2-1
2.1 Introduction	2-1
2.2 Background	2-1
2.3 Objectives	2-2
2.4 Work Performed	2-2
2.5 Results and Discussion	2-6
2.6 Conclusions	2-9
3 EXPERIMENTAL APPARATUS AND PROCEDURE	3-1
3.1 Small-Boiler Simulator	3-1
3.2 Cyclone Furnace	3-4
3.3 Reburning Burner	3-6
3.4 CWF Handling, Delivery, and Measurement System	3-6
3.5 Air Delivery and Measurement System	3-9
3.6 Fuel Atomizer	3-10
3.7 Convective Pass Section	3-12
3.8 Temperature/Gas-Sampling Probe	3-12
3.9 Gas Analysis System	3-13
3.10 Data Acquisition System	3-13
3.11 Particulate Sampling and Dust Loading	3-15
3.12 Procedures	3-15
3.13 Test Plan	3-15
4 DISCUSSION OF PILOT-SCALE TEST RESULTS	4-1
4.1 Shakedown	4-2
4.2 CWF Baseline Tests	4-2
4.3 All-CWF Reburning Tests	4-7

CONTENTS (Continued)

Section	Page
5 CONCLUSIONS AND RECOMMENDATIONS	5-1
5.1 Conclusions	5-1
5.2 Recommendations	5-2
6 REFERENCES	6-1

Appendix

A HISTOGRAMS AND CUMULATIVE PSDs OF PRODUCT CWFs
B INSTRUMENTATION
C TABULATED TEST RESULTS, DATA TABLES, AND ISOKINETIC SAMPLING RESULTS
D MEASUREMENT ACCURACY AND UNCERTAINTY ANALYSIS
E SBS DATA ACQUISITION AND REDUCTION DISCUSSION

ILLUSTRATIONS

Figure	Page
2-1 Effects of dispersant concentration on viscosity of CWF	2-8
3-1 Schematic of small-boiler simulator (SBS)	3-2
3-2 Proposed full-scale furnace arrangement	3-3
3-3 Babcock & Wilcox cyclone furnace	3-5
3-4 Cyclone furnace	3-5
3-5 Overfire air port and single reburner location on small-boiler simulator with furnace dimensions and a typical temperature profile	3-7
3-6 Reburning burner for small-boiler simulator	3-7
3-7 Reburning coal-water fuel (CWF) supply system	3-8
3-8 Side view of CWF piping arrangement on small-boiler simulator	3-8
3-9 Front view of CWF piping arrangement on small-boiler simulator ...	3-9
3-10 Reburner ducting for combustion air and flue gas recirculation ..	3-11
3-11 Design of T-jet atomizer	3-11
3-12 Schematic of final I-jet atomizer for reburning	3-12

ILLUSTRATIONS (Continued)

Figure	Page
3-13 Water spray produced using I-jet atomizer	3-13
3-14 Arrangement of convective pass section of SBS	3-14
3-15 Schematic of gas-sampling and analysis system	3-14
3-16 Data acquisition system for small-boiler simulator	3-15
4-1 Change in stack NO _x emissions with excess oxygen for old and new CWF	4-4
4-2 Effect of air preheat on stack NO _x emissions for old and new CWF ..	4-4
4-3 Stack NO _x emissions as a function of cyclone load for old and new CWF	4-6
4-4 Furnace exit gas temperatures (FEGTs) for baseline tests of old and new CWF	4-6
4-5 Final CWF atomizer configuration for reburning (B&W I-Jet design)	4-8
4-6 Stack NO _x as a function of stoichiometry	4-8
4-7 Sensitivity of stack NO _x emissions to reburn-zone stoichiometry ..	4-10
4-8 Comparison of NO _x destruction in reburn zone for natural gas and CWF reburn fuels	4-10
4-9 Effect of flue gas recirculation on final NO _x emissions for old and new CWF	4-12

TABLES

Table	Page
2-1 Analyses and T-250 of Pittston Moss No. 3 Coals	2-4
2-2 Predicted T-250 of Pittston Moss No. 3 Coal	2-6
2-3 Properties of Pittston Moss No. 3 CWF	2-8
3-1 Comparison of Baseline Conditions Between SBS and Commercial Units	3-1
3-2 CWF Analysis	3-16

ACKNOWLEDGMENTS

This work was sponsored by the U.S. Department of Energy (DOE) under contract DE-AC22-90PC90157. The support, interest, and guidance of contract manager Phil Goldberg is appreciated. The authors also thank all those people at Babcock & Wilcox who contributed to the success of the program. They are E. Stoffer, V. Burgess, H. Farzan, M. Holmes, J. Lyden, L. Basar and L. Rodgers.

EXECUTIVE SUMMARY

PROBLEM AND OBJECTIVE

Application of coal combustion to oil- or gas-designed boilers in the industrial sector is being sought by the United States Department of Energy (DOE). The abundance, availability, and price of coal all contribute to its attractiveness as an alternative energy source to replace premium fuels presently in use in this market. However, characteristics such as ash content, ignition properties, high combustion emissions, and handling/waste disposal difficulties have remained major deterrents to its application by residential, institutional, commercial, or industrial users.

Parallel research and development programs have been initiated by DOE over the past several years to investigate and develop retrofit technologies that would overcome difficulties of firing coal in boilers not suited for standard types of coal combustion. One approach that has maintained popularity and gained momentum since its inception is the use of a slagging combustor that attaches to the front of the furnace and serves to remove a significant amount of the coal ash before the hot combustion gases reach the furnace. With this approach, the coal is crushed or pulverized, and blown into the combustor to promote intense combustion on the unit's sidewalls, melting the mineral matter in the coal, which is then tapped off and disposed of in landfills.

Temperatures necessary to melt the coal ash are also high enough to convert diatomic nitrogen in the combustion air to nitrogen oxides (NO_x) and coal-bound sulfur (as well as free sulfur) to sulfur oxides (SO_2). Tail-end cleanup processes may then become necessary, adding significantly to the cost of the retrofit. Prevention of NO_x and SO_2 formation within the combustor has been attempted with some success (NO_x has been reduced significantly, while control of SO_2 is marginal), but has typically resulted in combustors with physical dimensions that prohibit application. Additionally, when these systems involve the use of dry coal, storage, handling, and preparation are negative issues to most users.

BACKGROUND

In 1986, the DOE awarded a contract (No. DE-AC22-86C90276) to Babcock & Wilcox (B&W) to develop and demonstrate a coal retrofit system for industrial, institutional, or commercial boilers in the size range of 10 million to 100 million Btu's per hour. The work was to be performed at B&W's small-boiler simulator (SBS), a nominal 6-million-Btu-per-hour combustor, at its Alliance (Ohio) Research Center (ARC). B&W's approach was to use existing technology by combining cyclonic combustion, coal-water-slurry fuel, and re-burning expertise to develop a compact, reliable combustion unit that had operating characteristics similar to those of liquid-fueled furnaces.

The work at the pilot was successful in removing between 70% and 80% of the coal's mineral matter while reducing NO_x emissions 60% to 70% from baseline levels of about 1000 ppmV. For these tests, natural gas was used as a re-burning fuel, amounting to about 18% to 24% of the total furnace load.

An economic study performed as part of the program's workscope predicted nearly a four-year payback on a commercial retrofit assuming premium fuel prices of \$6/MBtu. The payback period could be reduced to about 2.8 years by using coal-water fuel (CWF) as a re-burning fuel to replace natural gas. This change would also provide the advantage of marketing a single, liquid-fuel technology that provides combustion and control characteristics similar to an oil-fired system. Based on these advantages, B&W submitted a proposal to DOE to perform a demonstration test of an all-CWF system, the results of which are the topic of this report.

TECHNICAL APPROACH

This program was comprised of four major tasks

- Fuel formulation and production
- Reburn injector design
- Pilot-scale tests
- Project management and reporting

The primary concern regarding the technical success of using CWF as a re-burning fuel was ignition and combustion characteristics under substoichiometric conditions with a 30% moisture fuel. Delayed or poor ignition could mean that resulting improper reburner zone stoichiometries would shift the chemistry away from NO destruction. Additionally, efficiency losses from high carbon content in the ash could occur. Other concerns included reburn-zone mixing, pumping and handling, and shifts in furnace exit gas temperature (FEGT).

B&W's approach to evaluation of the all-CWF concept was to:

- Utilize an existing pulverized coal reburner design and atomizer modified for CWF combustion.
- Make comparative tests based on the previous reburning work using CWF and natural gas.

The coal reburner was part of a previous project jointly funded by the Electric Power Research Institute (EPRI) and the Gas Research Institute (GRI) and performed in support of a clean-coal project for utility-scale reburning. It was designed for dry, pulverized coal but required only minimal modifications for CWF combustion. The atomizer selected was especially developed by B&W for droplet dispersion and drying in a dry-scrubber environment and was modified slightly to conform to requirements of CWF atomization.

RESULTS

Selection of the parent coal and production of about 30 tons of CWF was performed based on the need to match the prior program's fuel characteristics. An in-house computer program that uses coal ash properties to predict molten ash viscosities was used to maximize chances of successful slag-tapping performance during combustion. Additionally, other coal properties were matched as closely as possible by selecting a coal from a similar seam.

A comparison of the parent coal properties is shown in Table S-1. Once selected, laboratory-scale tests were performed with the parent coal to establish the proper formulation for the production run. B&W was on-site and responsible for supervision and quality assurance for the production of about 30 tons of CWF at the Kennedy Van Saun Co. (See details in Section 2.)

Table S-1
COMPARISON OF PRIOR AND PRESENT CWFs BY ULTIMATE
ANALYSIS, GRINDABILITY, AND BTU VALUE

	Pittston Moss No. 3 Coal August 1987 CWF Production		Lower Seaboard Seam, 5/3/91 @ KVS	
	As Rcvd.	Dry	As Rcvd.	Dry
Ultimate Analysis, %				
Moisture	7.08	---	4.57	---
Carbon	75.70	81.47	78.37	82.12
Hydrogen	4.65	5.00	4.77	5.00
Nitrogen	1.29	1.39	1.35	1.41
Sulfur	0.53	0.57	1.22	1.28
Ash	5.37	5.78	6.42	6.73
Oxygen (difference)	5.38	5.79	3.30	3.46
Grindability (ASTM D-409)		71		91
Btu/lb	13,650	14,690	13,877	14,542

This fuel contained 72.3% coal and had a viscosity of 830 centipoise (cP) at a shear rate of 100 sec⁻¹. This compares with the previous CWF as follows: solids = 72.3%, viscosity = 1360 cP at a shear rate of 100 sec⁻¹. The reason for the significantly lower viscosity is not known but seemed to be a function of coal-packing properties. While this difference did not impose any kind of limitation on the combustibility of the fuel, atomization performance would be affected. Except for a fuel pressure variation at the atomizer, however, the effect of this parameter on combustion performance would probably not be quantifiable.

Pilot-scale tests were divided into two primary areas of investigation:

- Shakedown and baseline tests
- Reburning and parametric tests

Baseline tests were further divided into slurry only at the cyclone, CWF at the cyclone with natural gas reburning, and natural gas at the cyclone with CWF at the reburner. Reburning and parametric tests were performed following baseline tests to investigate specific differences between the prior contract's reburning results and the present all-CWF system.

Shakedown and slurry-only baseline tests established that comparable combustion performance was occurring as compared to results from the prior program. The correlation between the two test programs is shown in Figure S-1,

which depicts NO_x emissions as a function of cyclone stoichiometry. Though some variation in emissions is evident at lower stoichiometries, B&W cyclones are not operated in this regime under normal conditions. A minimum stoichiometry of 1.1 is typical, and the data shown in the figure are quite similar in this area. The differences in NO_x emissions observed at the low stoichiometry are actually a function of how air was added downstream of the cyclone (to complete combustion) and not differences in cyclone combustion performance.

Development of a reburning atomizer was performed by firing natural gas 100% at the cyclone and CWF 100% at the reburning burner. For each change made to the CWF atomizer, isokinetic stack sampling afforded a quantifiable method of comparing the reburner/atomizer pair performance without interfering effects (such as coal ash) from the cyclone.

While initial testing indicated that stable combustion at the reburner was achieved (visual observation), carbon in the ash was higher than desirable (12.1%). The exit holes of the atomizer were consequently changed to direct most of the atomized CWF somewhat downward, counter to the combustion gases flowing up from the cyclone. This dramatically reduced the average carbon in ash values to 4.0%. A further improvement was made by changing the spray

Figure S-1. Comparison of baseline NO_x emissions (no reburning) measured for prior and present tests with SBS cyclone furnace firing CWF.

angle from 60° to 90°, with a final carbon-in-ash value of 3.01% for the reburner. These are shown in Figure S-2. However, the values for percent of carbon remaining in the ash have been subtracted from 100 so that results are presented as percent of carbon burnout. Both the cyclone and the reburner were then fired simultaneously on CWF to achieve an overall carbon-in-ash value of 1.33%. (This is lower than the reburner on its own, since ash from the cyclone is blended with ash from the reburner prior to sampling). The use of flue gas recirculation (FGR) to reduce NO_x emissions resulted in slight increases in carbon loss from the system. Compared to the 1.33% carbon-in-ash values, the use of FGR returned values from 3.1% to 5.6%, depending on operating system specifics. This is still a very acceptable range for typical boiler operation.

NO_x emissions were measured and used as a comparison with the prior CWF/natural gas system. As expected, NO_x values were slightly higher than the old system but remained well within DOE guidelines of conformance to NO_x emission limits for industrial boilers fired on bituminous coals.

This limit is 0.7 lbs NO/MBtu input, or about 510 ppmV with stack excess oxygen corrected to 3%. Figure S-3 compares NO_x results for several reburning fuels used in the SBS system over the last few years. In Figure S-3, the NO_x reduction percentages shown are a ratio of stack NO_x emissions ob-

Figure S-2. Effect of atomizer configuration on percent of carbon burnout at reburner.

served during reburning and stack NO_x emissions observed during baseline testing (i.e., 100% of the furnace load originating from combustion in the cyclone). For the gas, oil, and coal reburning curves shown in Figure S-3, dry, pulverized coal was fired in the cyclone during baseline tests. For these tests, NO_x emissions were nominally 1000 ppmV. During the baseline CWF tests, NO_x emissions were also approximately 1000 ppmV, thereby allowing a direct comparison of NO_x reduction using CWF as a reburning fuel. Therefore, the absolute NO_x level (ppm) on the left side of Figure S-3 translates directly to a single value of percent NO_x reduction. CWF basically follows the NO_x reduction curve of dry coal except that the percentage of CWF required to achieve the same results is less and the use of FGR is not necessary. This is a positive result in regard to the capital and operating expense of a commercial retrofit.

Furnace exit gas temperatures (FEGTs) were measured during several tests and compared to prior data, since large changes in FEGT for a commercial retrofit could cause significant operational problems.

Figure S-3. Comparison of NO_x emissions measured for several reburning fuels.

The following results were observed:

Test	Baseline Average FEGT, °F	Reburning Average FEGT, °F
Prior program	2157	2087
Present tests	2125	2071

Based on the data and known error bands of about 30° to 50° for single-shielded suction pyrometers, the data are in excellent agreement and show that no problems with large changes in FEGT are indicated for the all-CWF system.

CONCLUSIONS

Pilot-scale testing of an all-CWF reburning system was successfully demonstrated during this test program. It was shown that CWF can replace natural gas as a reburning fuel without causing significant degradation in combustion performance. Ignition stability, flame length, and carbon burnout were also well within acceptable limits for this system.

In addition, NO_x emissions can be controlled to levels within about 10% of natural gas reburning. While operational aspects of the system were observed on a qualitative basis, all issues associated with CWF handling, pumping, and atomization were positive and indicate that little, if any, development work in these areas is necessary prior to commercialization.

However, there are several operational concerns that need to be addressed prior to the marketing of such a system:

- Additional ash input at the reburner will mean an increased burden on an electrostatic precipitator (ESP) and also increased erosion potential in the convective pass of a boiler.
- There are also questions of mixing efficiency for the reburner and the overfire air ports when applied to the geometry of an industrial boiler.
- Integrating the cyclone's cooling circuit into the steam generating bank of the retrofit boiler should be addressed.

Prior to commercialization, a full-scale demonstration of the technology is recommended, along with an engineering study to address questions about

steam circuit and hardware configuration. A full-scale demonstration would be the integrating step of all the subsystem development performed to date toward the development of a coal conversion technology for oil- or gas-designed boilers. Certain limitations inherently existing for small-scale tests could be eliminated. Also, capital, operating, and maintenance cost issues could be resolved.

Section 1

INTRODUCTION

1.1 PROBLEMS AND OBJECTIVES

There is an ongoing effort in the United States by the Department of Energy (DOE) to develop retrofit technologies capable of converting oil- and/or gas-fired boilers to coal combustion. Reducing U.S. dependency on foreign oil in the industrial sector is the primary goal of this effort. To be successful, these technologies must be capable of maintaining acceptable levels of both particulate and gaseous emissions while minimizing any operational problems in the furnace that could be created when switching from oil or gas to coal. These include boiler derating, sootblowing, fuel handling, corrosion, erosion, and ash removal. Finally, economics of a successful retrofit technology must be competitive with the price of premium fuels. Payback periods on the order of four years have been specified by DOE in a previous program for research and development announcement^[1] based on a 70% boiler utilization rate and delivered premium fossil fuel price of \$6/MBtu.

The objective of this project is to demonstrate the technical feasibility of an improved portion of a previously developed retrofit system^[2]. This improvement would almost entirely eliminate the use of premium fuels, thereby significantly increasing the economical attractiveness of the system. Specifically, B&W's goals in this program were to replace natural gas as a reburning fuel with coal-water fuel (CWF). The advantages of such a system include:

- Increased return on investment (ROI) for conversions.
- Nearly complete elimination of premium oil or gas fuel.
- A more integrated approach to the conversion of oil- or gas-designed boilers to CWF.

1.2 BACKGROUND

Prior Development of a Reburning System by Babcock & Wilcox

In a prior contract with DOE (Contract Number DE-AC22-86C90276), Babcock & Wilcox (B&W) developed and demonstrated a CWF retrofit system that used a cyclone-fired furnace to minimize ash flow into the boiler and a natural gas

reburning system to reduce NO_x emissions to levels that are 60% lower than typical cyclones.

The approach used several existing technologies developed by B&W over the years. The cyclone combustor was a scaled-down version of the large commercial cyclones used in electric utility boilers. Its advantage is found in its ability to reject most of the coal ash before it enters the furnace.

During operation on the small-boiler simulator (SBS) furnace for the previous DOE contract, more than a 70% rejection rate was measured while firing CWF. Coal ash viscosity characteristics are critical in this type of system to maintain maximum ash rejection rates. The temperature that provides an ash viscosity of about 250 Poise is an industry standard for judging the suitability of the coal for cyclone application. This T-250 temperature must fall between 2200°F and about 2450°F to provide acceptable performance in B&W's SBS furnace. (Large utility cyclones operate with T-250 values up to 2600°F). Artificial modification of this temperature can be made through adding limestone or other fluxing agents. These agents shift the base-to-acid ratio of the coal ash constituents, thereby causing a corresponding shift in the ash melting point and viscosity characteristics.

As part of the previous program, B&W investigated the effect of adding fluxing agents to the CWF to demonstrate that out-of-specification coals (based on T-250 values) for cyclone use could be burned successfully. During testing, it was shown that increased turndown of furnace load could be achieved through fluxing. Demonstrating the flexibility of CWF as a cyclone fuel was a major result of the prior work.

A second existing technology that was applied to system development by B&W in the prior work was B&W's expertise in the production, handling, pumping, and combustion of CWFs. B&W specified and supervised production of the CWF used in the program (12 tons) and maintained quality assurance on a daily basis through monitoring of percent solids and rheologic properties. A stable, well-behaved fuel and a reliable delivery system was the result of this effort.

Optimizing the combustion process to achieve the project objectives was a final area in which B&W's prior expertise facilitated development of a working system. Reburning burner design and location provided mixing and residence times appropriate for achieving a balance of NO_x emission control and fuel (carbon) burnout performance. Reburning/cyclone fuel ratios were investigated, as were reburning burner stoichiometries, reburning zone stoichiometries, and effects of flue gas recirculation (FGR). As a result, an integrated retrofit system was developed using CWF as a cyclone fuel and natural gas as a reburning fuel.

Basis for Present Work

While this system was successful in capturing between 70% and 80% of the coal's mineral content prior to its entrance into the boiler and also maintaining NO_x emissions below 0.6 pound per million Btu input (lbs/MBtu), it was revealed that the economics of the technology could be improved if an all-CWF system were implemented. This would involve firing CWF into the furnace in the reburning zone as a replacement to natural gas. While this operation would result in increased particulates to the system, since a baghouse or electrostatic precipitator will be employed on nearly any commercial coal-fired retrofit, the burden of a slight increase in particulates from CWF reburning would not be significant.

The economic study done in the prior work showed that eliminating natural gas consumption would decrease the payback time for this technology from four years to approximately 2.8 years. B&W originally chose coal in the form of CWF to facilitate handling, storage, and fuel feeding operations for industrial, commercial, or institutional applications using furnaces sized between 10 MBtu/hr and 100 MBtu/hr. For this size range, most owners would not have the space or expertise to handle dry coal.

SO_x emissions were controlled using a low-sulfur-compliance coal to preclude the use of scrubbers. Natural gas quantities at the reburner (necessary to achieve up to 70% reduction of NO_x emissions) represented about 20% to 26% of the total fuel heating value input to the furnace. Using CWF as a replacement for this natural gas could result in increased NO_x emissions for the overall system, however. This was to be investigated as part of the present work.

1.3 TECHNICAL APPROACH

Hypothesis Definition

While CWF has been successfully burned in B&W's SBS cyclone furnace, the use of slurry as a reburning fuel had not been previously attempted. Okiura, et al.^[3], described the main chemical reactions of reburning as follows:

Step 1. The reaction process is begun when fuel introduced at the reburning burner zone pyrolyzes in an oxygen-deficient atmosphere. Since the partial pressure of oxygen in this zone is an inhibiting parameter to the process, it is controlled via reburner stoichiometry (near field of the reburner) and/or cyclone stoichiometry (overall reburning zone control). This step provides hydrocarbon radicals to the process and, though more complex than methane, would be released regardless of whether methane or coal is the reburn fuel of choice.

Step 2. The second event in the reburning process is the reaction of free hydrocarbon radicals, with NO in the combustion gases entering the reburning zone. In this step, there is a competitive reaction between available diatomic oxygen and oxygen that is part of the NO species of the zone. Eventually, CN radicals are formed through a series of reactions shown here using the basic methane hydrocarbon radical (chemical species from coal would be much more complex):

Therefore, increased amounts of excess air will result in the preferential combination with hydrocarbon radicals from the initial step and inhibit NO reduction. Application of CWF to this chemistry demands that atomization, drying, ignition, and radical generation occur within appropriate zone residence times. Otherwise, too much available oxygen may exist at a critical time in the process.

B&W's hypothesis regarding the required reactions was that drying time and mixing of the CWF injected in the reburning zone could be controlled to achieve a significant reduction of NO_x via the reburning chemistry within the physical bounds of the typical furnace existing in the marketplace for this technology. The basis for this hypothesis was past performance experience on oil and dry coal. It was proven by demonstration that proper logistics of coal injection combined with adequate mixing could reduce NO_x by between 60% and 70% with relatively little adverse effects on carbon conversion efficiency or temperature profiles at the furnace exit^[4]. Equivalent combustion performance in the reburn zone using CWF in place of the other fuels should yield nearly equivalent results.

Step 3. The final step in the reburning process is the combination of the CN radicals and other products with NO to form N_2 . If excess oxygen is not properly limited, direct reactions with diatomic oxygen will prevail as in the following two examples:

With the use of CWF as a reburning fuel, cooler temperatures due to the high moisture content of the fuel were a consideration. Favorable performance from the perspective of NO_x formation via thermal NO_x (Zeldovich mechanism) was expected, but delayed reactions were also possible. Additionally, proper combustion in the final zone of the process could be inhibited by improper temperature profiles. This final combustion zone consists of the injection of overfire air to complete the combustion process. In this zone, downstream of the reburn zone, the balance of air is introduced and the mixture enters the burnout zone. In this zone, it is possible to regenerate NO species through reactions of existing ammonia compounds with oxygen. The following are typical reactions:

The temperature and oxygen concentrations in the burnout zone are the controlling variables in this region. For example, lower temperatures and less oxygen in the zone can promote further reductions of NO species via the following typical reactions:

Methodology

Proof of the hypothesis described above was to be performed through a demonstration in B&W's SBS furnace. This unit has been used for many reburning experiments over the last several years. The result of this work is an extensive data base regarding the reburning process and practical experience.

A four-task test program was established:

- Fuel formulation and manufacturing.
- Injector design for development and design of an atomizer for CWF reburning.
- Testing and development to first verify existing baseline performance data and then investigate a 100% CWF system
- Management and reporting.

The fuel formulation task consisted of selecting a parent coal, laboratory-scale formulation tests to optimize particle size distribution and chemical loading quantities prior to full production, and specification and on-site supervision of production operations. Also, the responsibility and support of providing appropriate fuel quality throughout the pilot-scale tests at ARC fell under this task.

The task for injector design was to review existing atomizers being used in CWF combustion and select one or more injectors for the pilot-scale tests. Design modifications or scaling of the selected injector was also to be a milestone. Concerns like droplet size distribution, ratio of atomizing air to fuel, relative velocities of the burner air and atomized CWF spray, mix-

ing based on known furnace patterns and CWF spray angle, and droplet drying time were all part of the considerations.

The pilot-scale testing task consisted of system design considerations, site preparation, shakedown, baseline verification tests with CWF and CWF-gas reburn, development testing of the CWF reburner subsystem, and parametric tests of the entire system. In addition to operational data, emphasis was placed on documenting furnace exit gas temperatures (FEGT), combustible losses, stack emissions for several loads, cyclone and reburn zone stoichiometries, flue gas recirculation (FGR), and combustion air temperatures.

The management and reporting task maintained schedule and organization of personnel to assure timely performance of all contract activities. Some equipment from the previous contract was updated and used to make the project more cost effective. This included the reburn burner, the storage and pumping facility, and several system drawings that only required slight modification from previous tests.

1.4 LIMITATIONS AND REPORT ORGANIZATION

Limitations

As in the previous contract, the primary limitation to evaluating the technology at the pilot scale was the SBS furnace geometry. This limitation only applied to predicting full-scale field performance based on data obtained from the SBS. Comparative results based on previous tests in the SBS are completely valid as long as established baseline data is comparative to baseline performance under the present program.

For predictive considerations, however, the SBS is limited since it was built to simulate a utility boiler. FEGT is several hundred degrees higher than industrial counterparts. In addition, the high surface-to-volume ratio of the small SBS cyclone furnace prevents obtaining the full 2:1 turndown typical of a cyclone. Despite these limitations, significant performance data were obtained at a much more reasonable cost than full-scale through the use of baseline testing, comparisons with previous similar tests in the facility, and finally development and parametric testing. Furnace heat-re-

lease characteristics were considered part of an engineering effort associated with a full-scale demonstration and were therefore not in the scope of work for this project.

An accurate evaluation of the effectiveness of an all-CWF system was made by virtue of direct comparison with previous data from the prior DOE contract work. The parent coal selected for this program had properties nearly identical to those of the coal used previously, including slag-tapping performance. This allowed a smaller test matrix, since verification of baseline performance validated the prior-established data base.

One item of note related to the facility is a variation in the number of reburners used in the present work compared to previous. For this program, only one reburner was used; two were used in the prior work. Based on calculations of burner velocities, only one reburner was necessary. This is primarily because a significant amount of air (usually routed to the reburner) was used for atomization of the CWF. The mass flow of this air was not figured into the burner throat velocity and thereby reduced the required cross-sectional reburner throat area enough to eliminate one reburner. The limitation associated with this hardware change is considered minimal, since baseline reburning data (CWF at the cyclone, natural gas at the reburner) compared to data from the prior program are quite similar. Also, though mixing and temperature profiles in the furnace could be affected by this physical change, emissions and sampling at the outlet side of the furnace showed no significant differences.

Report Organization

Parent coal selection, CWF laboratory-scale formulation work, and commercial CWF production for the pilot-scale work are discussed first in Section 2, since the choice of coal and the properties of the final production run were of critical importance to the remainder of the program. Next, in Section 3, the experimental apparatus and procedures are discussed. Details of the installation of the reburner, the design of the CWF atomizer, and all other subsystems are discussed in this section. Combustion test results are discussed in Section 4, which covers the comparison of previous natural gas reburning data with that of the all-CWF system. Since the work performed in

this program was originally proposed as an add-on to the previous contract, direct comparison with the prior data is a sound basis for reporting the results. All emissions and operational data are discussed. Overall conclusions and recommendations (Section 5) end the main body of the report. A number of appendixes are provided to give detailed descriptions and explanations of results, calibrations, data logging and reduction, and tabulated results.

Section 2

FUEL FORMULATION AND OPTIMIZATION

2.1 INTRODUCTION

This section describes the results of the coal selection, bench-scale characterization, and large-batch production at Kennedy Van Saun (KVS) of the coal-water fuel (CWF) used in the test program.

2.2 BACKGROUND

Fuel Specifications

The specifications of the coal for use as a slurry in a cyclone boiler are as follows:

- Ash content equal to or greater than 6% (dry).
- Volatile content equal to or greater than 15% (dry).
- Sulfur emission of 1.2 lb/MBtu SO_x or less

In addition, the properties of the coal must be conducive to preparing a good quality slurry. The CWF prepared from the selected coal must have a coal content greater than 62%, a viscosity less than 2000 centipoise (cP), and an acceptable stability. B&W has evaluated more than 100 different coals -- mainly eastern coals and several western and foreign coals -- for their ability to form a slurry. This data base was used to select the coal for CWF preparation in this study.

Slag Viscosity

The coal ash viscosity must also be considered when selecting a fuel for cyclone combustion. Slags will tap from wet-bottom furnaces normally in the range of 10 to 100 Poise, with 250 Poise as the upper limit. The T-250, the temperature at which the slag has a viscosity of 250 Poise, is used as a design criterion to determine its suitability for cyclone application. For ease of slag tapping, the ash T-250 should not be greater than the temperature range of 2450° to 2600°F. A high T-250 will inhibit tapping of molten slag from the cyclone during operation. The tapping ability or viscosity of a coal slag at a particular temperature depends on the ash chemical composition.

For this program, it was advantageous to select a coal that had properties, excluding ash chemical composition, similar to Pittston Moss No. 3 used in Phase I, and would not require the addition of fluxing agents. Demonstrating how fluxing agents can lower the slag viscosity of a coal or CWF, making it suitable for cyclone boiler use, was not an objective in this program.

2.3 OBJECTIVES

The objectives of this task were to:

- Select a coal that meets the fuel specifications for cyclone burners.
- Prepare CWFs in bench scale for developing B&W specifications for large-batch production.
- Produce a large-batch production of CWF with properties similar to those in the large-batch production of CWF made in Phase I.

2.4 WORK PERFORMED

Approach

The following coal selection criteria were used:

- Sulfur content to meet new-source performance standards (NSPS).
- Good slurryability and fuel quality.
- Appropriate ash chemistry and slag viscosity temperature characteristics for use in cyclone burners.

Samples of CWFs were prepared in the laboratory and evaluated. Information obtained from the bench-scale evaluation was used as guidelines for setting the operating conditions of the large-batch CWF production. Unlike Phase I, it was decided to exclude pilot testing and go directly from bench scale to large-batch CWF production because:

- A similar coal was used in both programs.
- Similar CWF bench-scale test results were obtained for both coals.
- The cost associated with pilot testing was prohibitive for this program.

Based on the results of bench-scale testing, the specifications and operating conditions for the production of approximately 5,600 gallons of CWF were

developed. The large quantity of test CWF was produced in a 2-ton/hr CWF preparation facility located at KVS according to B&W specifications.

Fuel Selection

B&W has a great deal of experience in preparing and combusting CWF from Pittston Moss coals. The Moss CWF has a high-solids content (above 70%) with low viscosity (at about 1000 cP) and low dispersant demand. The annual production of this coal is approximately 3 million tons. Based on B&W's CWF experience and the considerations of the fuel properties, Pittston Moss No. 3 coal was selected as the test coal for this program.

From phone conversations with the plant manager of Pittston Coal Co., it was learned that Pittston Moss No. 3 is a generic coal term and that six different seams are blended to give various desired coal properties. What B&W desired for this program was a coal having a similar calculated T-250 as the coal used in Phase I. For this case, the Lower Seaboard seam met the calculated T-250 requirements and was chosen. Table 2-1 compares B&W's coal analyses performed in Phase 1 and this program; calculated T-250 levels are also shown.

Coal Purchase

Forty tons of the Lower Seaboard coal were ordered from Pittston Coal Co. The coal was requested to be freshly mined with a particle size of 3/4 inch x 0 and no chemicals applied on the surface. The coal was shipped to the KVS CWF preparation plant in Danville, Pa., for large-batch production of test CWF. A one-drum sample of the coal was obtained by B&W personnel at KVS and brought back to B&W's Alliance (Ohio) Research Center (ARC), where a representative sample of the coal was collected and a complete coal analysis was performed (see Table 2-1).

CWF Preparation

Coal Preparation and Measurement of Particle Size Distribution. The one-drum coal sample was crushed to 1/4 inch x 0 and air dried. Three fractions (that is, coarse pulverized coal, fine pulverized coal, and stirred-ball-mill material) were prepared. The particle size distributions (PSDs) of the three fractions were measured using Leeds & Northrup Microtrac analyzers. The

Table 2-1
ANALYSES AND T-250 OF PITTSTON MOSS NO. 3 COALS

	Pittston Moss No. 3 Coal August 1987 CWF Production		Lower Seaboard Seam, 5/3/91 @ KVS	
	As Rcvd.	Dry	As Rcvd.	Dry
Total Moisture, %	7.08	---	4.57	---
Proximate Analysis, %				
Moisture	7.08	---	4.57	---
Volatile Matter	29.15	31.37	25.05	26.25
Carbon	58.40	62.85	63.96	67.02
Ash	5.37	5.78	6.42	6.73
Btu/lb	13,650	14,690	13,877	14,542
Ultimate Analysis, %				
Moisture	7.08	---	4.57	---
Carbon	75.70	81.47	78.37	82.12
Hydrogen	4.65	5.00	4.77	5.00
Nitrogen	1.29	1.39	1.35	1.41
Sulfur	0.53	0.57	1.22	1.28
Ash	5.37	5.78	6.42	6.73
Oxygen (difference)	5.38	5.79	3.30	3.46
Grindability (ASTM D-409)	71		91	
Equilibrium Moisture, %	1.63		1.80	
Ash Analysis, Dry (ICP), %				
Silicon as SiO ₂	35.00		40.09	
Aluminum as Al ₂ O ₃	21.86		21.51	
Iron as Fe ₂ O ₃	12.54		16.55	
Titanium as TiO ₂	1.10		0.88	
Calcium as CaO	11.99		7.13	
Magnesium as MgO	2.17		2.08	
Sodium as Na ₂ O	1.25		0.51	
Potassium as K ₂ O	1.33		3.19	
Sulfur as SO ₃	10.02		6.58	
Phosphorus as P ₂ O ₅	0.17		0.56	
Ash Fusion Temp.	Red.	Oxid.	Red.	Oxid.
A (I.D.)	2230	2240	2160	2390
B (S.T., Sp)	2370	2440	2250	2430
C (S.T., HSp)	2390	2450	2290	2480
D (F.T., 1/16")	2480	2470	2440	2520
E (F.T., FLAT)	2500	2530	2520	2560
Calculated T-250 (In-house program), °F		2210		2320

PSDs were input to an in-house developed computer program that predicts the amount of each fraction required to optimize particle packing in the slurry.

Bench-Scale Preparation. Pint-size samples of CWFs were prepared by mixing the appropriate percentages of the three fractions as determined by the computer program. Appropriate amounts of dispersant were added to the CWF to improve its fluidity. A test matrix was designed and performed to determine the optimum conditions of solids content, dispersant concentration, and pH needed to prepare a high-solids, low-viscosity, and stable CWF.

The viscosities of the CWFs were measured using a Haake RV-100 rotational viscometer in a continuous increasing (then decreasing) mode of shear rate. The shear viscosity determined at 100 sec^{-1} on the descending curve of the rheogram was used as a benchmark for CWF viscosity comparison. The pH at which the CWF had low viscosity was selected as the optimum pH. Additional CWFs were prepared at the optimum pH and a constant coal solids content at several dispersant concentrations. The resulting shear viscosity was plotted against the dispersant concentration of the CWFs to obtain the optimum dispersant concentration. The optimum dispersant concentration was selected from the viscosity versus the dispersant concentration curve, where the viscosity reached a minimum.

CWF Production at KVS. Based on the results of the B&W bench-scale testing, the specifications and operating conditions for the production of 5,600 gallons of CWF were developed. The CWF was produced in a tumbling ball mill at KVS. The throughput was approximately 2 tons/hr, and the CWF was produced to B&W specifications. B&W personnel were on-site to supervise production. The CWF was ground in the tumbling ball mill, transferred to a holding tank for further mixing, pumped to two truck tankers for storage, and then shipped to ARC. The solids content, pH, and the viscosity were measured every hour during processing. The PSD was monitored by wet screening a few selected size fractions and determining the percentage of each fraction, giving a rough indication of PSD. After production, the CWF was shipped to B&W's Alliance, Ohio Research Center in the two tank trucks.

Combustion Tests

The fuel characteristics (slurry viscosity, solids content, and pH) of the CWF produced at KVS were determined in the laboratory prior to combustion in B&W's 6 MBtu/hr SBS cyclone furnace at ARC.

2.5 RESULTS AND DISCUSSION

Fuel Selection

It was desirable to obtain a coal with fuel characteristics similar to those of the Phase I coal to compare combustion test results. The coal analysis performed by B&W on the Lower Seaboard shipment is shown in Table 2-1. The Pittston Moss No. 3 coal had an ash content of 6.73%, a volatile content of 26.25%, and a sulfur content of 1.28% (all measurements are on a dry-coal basis). The coal met the fuel specifications for performing the DOE cyclone combustion test.

T-250 Temperature

Since the predicted T-250, utilizing B&W's in-house slagging computer program, compared very closely to the measured slag viscosity of the coal in Phase I testing (2210° versus 2260°F), the decision was made to use just the in-house program for predicting the T-250 of the coal and CWF in this program and to forego measuring slag viscosity because of cost. Table 2-2 compares the predicted T-250 between the Phase I coal and Lower Seaboard coal based on their respective dry coal ash analysis performed by B&W.

Bench-Scale CWF Evaluation

Since Pittston Moss No. 3 coal was used again in this program, and based on large-batch test results in Phase I (1987), a pH of 9 and 72% coal content were selected for bench-scale CWF preparations. For this study, more emphasis was placed on determining the optimum dispersant concentration for the CWF and its relationship with settling stability.

Table 2-2
PREDICTED T-250 OF PITTSTON MOSS NO. 3 COAL

Method of Prediction	T-250, °F	
	Based on B&W Coal Analysis, Phase I	Based on B&W Coal Analysis, Lower Seaboard Coal
In-House Program	2210	2320
Measured at ARC	2260	—

All reported viscosities are apparent viscosities. The shear viscosity versus dispersant concentration of seven CWFs prepared at a coal content of 72% at a pH of 9 is shown in Figure 2-1. The results indicate that at an approximate 0.6% dispersant concentration, viscosity reaches a minimum. The dispersant concentration is expressed on the basis of an active dry coal.

The prepared CWFs had a particle size of 0.1% of material greater than 50 mesh (300 microns), 83% of material less than 200 mesh (75 microns), and a mass mean diameter (MMD) of approximately 39 microns. This information is shown in Table 2-3. The histogram and the cumulative PSD of the product CWF are shown in Appendix A. The settling stability of the CWF with a coal content of 72%, a viscosity of about 700 cP, and a dispersant concentration of about 0.6% had no soft-pack settlement formation after 5 days of static storage. Based on the results of these tests, the following slurry specifications were chosen for large-batch CWF preparation:

- Coal content: 72% coal
- pH: 9
- Viscosity: approximately 1000 cP
- Dispersant Concentration: 0.6%

CWF Production at KVS

There were 5,600 gallons of CWF produced at KVS and shipped to B&W by two tank trucks. Samples were taken from each of the two tankers at B&W, and composite samples were prepared. The product quality of the as-received CWF composite sample is shown in Table 2-3. The histogram and the cumulative PSD of the product CWF for both 1991 and 1987 are shown in Appendix A. A comparison of the particle size and the MMD of the CWFs produced in bench-scale, KVS production in 1991, and KVS production in 1987 is shown in Table 2-3. At essentially the same coal content, an increase in viscosity in the large-batch CWF (1991) as compared to the B&W bench-scale CWF is attributed to poorer dispersion of coal particles due to less intense mixing. Allowing for the small differences between the large-batch runs (shown in Table 2-3), the coal used for 1991 production yielded a CWF with lower viscosity at the same coal content.

Figure 2-1. Effects of dispersant concentration on viscosity of CWF

Table 2-3
 PROPERTIES OF PITTSTON MOSS No. 3 CWF

	Bench-Scale (B&W, 1991)	2-TPH Production (KVS, 1991)	2-TPH Production (KVS, 1987)
Viscosity @ 100 sec ⁻¹	650	830	1360
% Coal	72.0	72.3	72.3
pH	9.2	9.2	8.8
% Greater than 300 microns	0.1	0.5	0.6
% Less than 75 microns	83	89.5	86
Mass Mean Diameter, microns	39	30	35

2.6 CONCLUSIONS

The major conclusions of this investigation of the preparation of CWFs for industrial cyclone applications were:

- The predicted T-250 of the dry coal ash, utilizing the B&W in-house slagging computer program, allowed a coal to be selected for CWF production suitable for cyclone boiler use.
- Since information on pilot-scale preparation had already been obtained for a similar coal, it was possible to provide specifications and produce a good quality CWF for cyclone application (large-batch production) after just bench-scale testing.
- The large-batch production in 1991 at KVS yielded a CWF with lower viscosity at the same coal content as compared to 1987 CWF production.

Section 3

EXPERIMENTAL APPARATUS AND PROCEDURE

This section describes the major components of the test facility and analytical instrumentation. Operating conditions and test results are discussed in Section 4.

3.1 SMALL-BOILER SIMULATOR

Pilot-scale tests were carried out in the 6 MBtu/hr small-boiler simulator (SBS). The water-cooled furnace is a scaled-down version of a B&W single-cyclone, front-wall-fired boiler. A schematic of the test facility is shown in Figure 3-1. Temperature profiles, residence times, NO_x levels, slagging potential, ash retention within the resulting slag, unburned hydrocarbon, fly ash particle size, and other combustion characteristics of this facility accurately represent full-scale behavior. A summary of these comparisons is listed in Table 3-1.

The interior surface of the furnace is insulated to yield a FEGT of 2250°F at full load. While this is higher than typical industrial FEGTs, comparative measurements of this variable made between baseline and parametric tests were the basis for acceptable performance at the pilot scale (for this test program). The furnace has five water jacket modules located at the primary furnace, lower furnace, middle furnace, furnace arch, and upper fur-

Table 3-1
COMPARISON OF BASELINE CONDITIONS BETWEEN SBS AND COMMERCIAL UNITS

	SBS	Utility Cyclone
Cyclone Temperature	> 3000°F (1900K)	> 3000°F (1900K)
Residence Time	1.4 sec	0.7 - 2 sec @ full load
Furnace Exit Gas Temp.	2250°F (1500K)	2250 - 2350°F (1500 - 1560K)
NO _x (Baseline)	900 - 1200 ppm	600 - 1400 ppmV
Ash Retention	80% - 85%	60% - 80%
Unburned Carbon*	< 1% in ash	1% - 20% in ash
Ash Size	6 - 8 microns	6 - 11 microns

* Percent of ash as carbon by weight

Figure 3-1. Schematic of small-boiler simulator (SBS).

nace. Visually examining the flame and the interior of the furnace is done from several observation windows at different heights. In addition, a number of access ports are available along the walls of the furnace and the convective pass section to conduct tube deposition experiments and flue gas temperature and composition measurements.

Although the SBS has a vertical geometry much like a utility boiler, it was used for this project to test the feasibility of application and to obtain data to be applied to industrial units. Actually, if the SBS were laid on its side, it would have a geometry configuration similar to that proposed to DOE for commercialization in the prior contract. This involves locating the axis of the cyclone furnace perpendicular to the gas flow path of the industrial furnace to which it would be attached (see Figure 3-2). This arrangement allows the use of a refractory "target-wall" chamber in place of the original windbox and burner in order to:

- Promote slag capture.
- Maintain smooth cyclone operation.
- Assure correct gas flow patterns in the main boiler.

Figure 3-2. Proposed full-scale furnace arrangement.

Molten slag flows through a notch in the front of the cyclone and into a water-filled tank, where it fractures and is removed via a screw conveyor.

The capture of 70% to 80% of the ash is a primary advantage of the cyclone retrofit approach, because it minimizes any furnace derating caused by concerns of tube erosion. Typical oil- or gas-designed industrial boilers have tight tube spacings and fire-side gas velocities of more than 100 feet per second. This is twice the design velocity for coal firing and essentially precludes the use of full-load, directly fired coal retrofit schemes due to tube erosion considerations. Consequently, ash must be removed either before combustion through cleaning techniques or during combustion but prior to contact with furnace walls or convective pass tubes.

3.2 CYCLONE FURNACE

A scroll-type cyclone burner (Figure 3-3) is used in the pilot-scale SBS facility. During typical operation, dry coal and primary air are premixed and injected tangentially into the burner. Secondary and tertiary air flows are also scrolled tangentially into the furnace, as shown in Figure 3-4. As the coal particles scroll out of the burner and enter the barrel, the larger particles are captured and burned in a molten slag layer formed on the barrel walls, while the finer particles burn in suspension. Part of the ash and the mineral matter leave the cyclone as molten slag through a hole at the bottom of the primary furnace and drop into a water-filled slag tank. The remaining ash leaves the cyclone with the flue gases and enters the furnace.

To maintain similar inherent cyclone firing characteristics, the pilot-scale cyclone furnace design is primarily a geometrically scaled down version of a full size unit. Furnace dimensions and a typical temperature profile are shown in Figure 3-5. However, due to surface-to-volume ratio differences between the full-scale and pilot-scale cyclones, certain operating changes are necessary to preserve the cyclone concept and to maintain a representative time/temperature history within the cyclone and furnace. For example, coarse pulverized coal (44% - 50% through 200 mesh) is used instead of crushed coal to duplicate the commercial unit's centrifugal force and, consequently, the cyclone collection efficiencies. The reduced particle size

Figure 3-3. Babcock & Wilcox cyclone furnace.

Figure 3-4. Cyclone furnace.

also increases the combustion intensity. Finally, to simulate the available heat per unit surface area, combustion air is supplied at a higher temperature than normal utility operation (about 700°F versus 500°F).

For firing CWF, the coal chute arrangement in Figure 3-4 was removed and a CWF injector/lighter package was installed in the rear of the scroll burner, as shown in Figure 3-5.

3.3 REBURNING BURNER

In the reburning arrangement as shown in Figure 3-5, one additional coal-fired burner is installed above the cyclone burner on the furnace rear wall. This burner consists of essentially two zones (see Figure 3-6). Air and/or recirculated flue gas are introduced from the outer zone through a set of spin vanes, while the reburning fuel (coal or coal-water slurry) is injected from the inner zone. Overfire air is supplied above the fuel-rich reburning zone to complete the combustion process. All gas flow rates are measured by orifice meters.

3.4 CWF HANDLING, DELIVERY, AND MEASUREMENT SYSTEM

CWF from a 3000-gallon storage tank was transported by a progressive-cavity-style pump to a 600-gallon daytank at the rear of the SBS. For reburn tests, CWF was pumped from the 600-gallon daytank to an independent, 50-gallon supply system that consisted of another progressive-cavity pump and a mass flowmeter and water flush system. This arrangement is shown in Figure 3-7.

An independent supply system was selected for pilot-scale testing to minimize problems associated with pressure interactions between main burner pumping rates and reburner pumping requirements. Since a demonstration of actual hardware arrangements of a commercial system was not part of the scope of this program, this simplification was justified.

Fuel flow rates to the cyclone furnace were measured using a separate, Micromotion^R mass flowmeter. Flow rates for both the main burner and the reburner were controlled by controlling the rotational speed of the pump. The primary CWF supply system is shown in Figures 3-8 and 3-9. Fuel flowmeters, airflow orifice pressure transducers, and other instrumentation are listed in Appendix B.

Figure 3-5. Overfire air port and single reburner location on small-boiler simulator with furnace dimensions and a typical temperature profile.

Figure 3-6. Reburning burner for small-boiler simulator.

Figure 3-7. Reurning coal-water fuel (CWF) supply system.

Figure 3-8. Side view of CWF piping arrangement on small-boiler simulator.

Figure 3-9. Front view of CWF piping arrangement on small-boiler simulator.

3.5 AIR DELIVERY AND MEASUREMENT SYSTEM

Combustion air was supplied by a forced-draft fan. An indirect-gas-fired air heater provided preheating of the secondary air. Intake ports for the primary, secondary main and reburner, tertiary, and overfire air are shown in Figure 3-1. Flows were controlled via remote/manual pneumatic controllers or blast gates. Flow measurement was obtained by using orifices constructed to ASME specifications. Flue gas recirculation (FGR) was provided by using an existing FGR fan and installing piping to connect with the reburner. Flow was controlled manually with slide gate valves and measured with an orifice. The reburner combustion air and FGR supply ducting are shown in Figure 3-10. For this program, one of the two reburners shown was removed and the remaining reburner centered on the rear wall of the SBS. Atomizing air for the CWF mixture at the cyclone and the reburner was measured with separate orifices attached to Barton gauges for differential pressure measurements and bellow-type gauges for static pressure measurements.

3.6 FUEL ATOMIZER

CWF Atomizer for the Cyclone

Based on previous testing of CWF in the cyclone furnace, a B&W T-jet atomizer was selected for this test program. This atomizer had six exit holes and sprayed CWF at a 70° angle inside the cyclone. It was selected based on the following criteria:

- Ability to produce a consistent, flowing, molten slag layer in the cyclone.
- Minimum sidewall impingement of wet slurry on the sidewalls of the cyclone.
- Confined flame within the cyclone. While some flame always escapes the throat of the cyclone, this arrangement minimized the occurrence and facilitated slag retention.
- Minimum sparklers leaving the cyclone. This is the result of poor atomization and spray placement via atomized spray angle and jet momentum from the atomizer spray.

As in the previous program, the carbon content of all baseline tests using this atomizer was below 1%, indicating excellent combustion.

Figure 3-11 shows the basic design of a T-jet atomizer. High-pressure (150 psig) atomizing air was used in all tests and its flow rate was measured by the orifice meter noted in Section 3.5. The air-to-fuel ratio used for this test program was nominally 0.3 lbs air/lb CWF.

CWF Atomizer for Reburner

B&W experience in atomizer development is significant in the area of droplet dispersion control and particle sizing. The bulk of this experience has come from slurry development and dry-scrubber work, where droplet drying time is critical to the success of the process. In-house experts were consulted for an appropriate design for reburning using CWF.

After reviewing several potential designs, a B&W I-jet atomizer was selected for initial testing with a backup design from an outside source. This atomizer was sized to provide a finely atomized spray jet with a low momentum. The philosophy was one of allowing the combustion air from the reburner and the combustion gases from the cyclone to control the mixing dynamics of the

Figure 3-10. Reburner ducting for combustion air and flue gas recirculation.

Figure 3-11. Design of T-jet atomizer.

reburn zone. A forceful jet that penetrated the airstream was not considered desirable.

The final design is shown in Figure 3-12, with a picture of the atomizer spraying water in Figure 3-13. The tip has four exit holes and a spray angle of 90°. Atomization pressure is relatively low at 95 psig, but air consumption of 1.0 pound of air per pound of CWF is three times that of the main cyclone T-jet atomizer. Initial tests using this atomizer returned carbon-in-ash values below 1.2%. Though some further changes were made to optimize the tip, it was not necessary to test any other atomizer design.

3.7 CONVECTIVE PASS SECTION

Figure 3-14 illustrates the construction of the convective pass section. It consists of four different sections simulating secondary superheater, reheater, primary superheater, and economizer - each containing 42, 40, 100, and 216 tubes, respectively. All four sections are connected to a common atmospheric steam drum that recirculates cooling water to the tube banks and walls. Deposits on the tubes and the walls are removed by sootblowers in front of each section.

3.8 TEMPERATURE/GAS-SAMPLING PROBE

Combustion gas temperatures within the furnace were measured by a high-velocity-thermocouple (HVT) probe. The thermocouple is shielded by a short refractory tube to minimize radiation losses and is housed inside a water-cooled gas sampling probe.

Figure 3-12. Schematic of final I-jet atomizer for reburning.

Figure 3-13. Water spray produced using L-jet atomizer.

3.9 GAS ANALYSIS SYSTEM

Figure 3-15 shows an overall schematic of the gas analysis system. CO, CO₂, and SO₂ concentrations were measured by Beckman nondispersive infrared analyzers. NO and NO_x were measured by a Thermoelectron chemiluminescent analyzer. Oxygen was measured by a Beckman paramagnetic analyzer. Prior to the measurements, flue gas samples were dehumidified by a refrigerated water trap and a Perma Pure dryer. Therefore, all reported concentration measurements are on a "dry" basis. A complete list of the gas analyzers and the calibration standards is given in Appendix B.

3.10 DATA ACQUISITION SYSTEM

Analog data from pressure transducers, thermocouples, and gas analyzers were sampled every second and averaged over a preset time span. Macro programs and commercially available software, including Labtech Notebook®, Real-Time Access®, and Lotus 1-2-3®, were used for data acquisition and postprocessing. The microcomputer-based data-logging system is shown schematically in Figure 3-16.

Figure 3-14. Arrangement of convective pass section of small-boiler simulator.

Figure 3-15. Schematic of gas-sampling and analysis system.

An analysis of the fuel is shown in Table 3-2. The parent coal, Lower Seaboard Seam, is from Preparation Plant No. 3 of the Pittston Coal Co. of Russell County, Virginia. The ash content of 6.42% was about the lowest suggested amount for normal B&W cyclone combustion, and the sulfur level of 1.22% was barely within EPA specifications for SO₂ emissions of 1.2 lb/MBtu (520 ng/J). Nitrogen content of the parent coal was 1.41% on a dry basis. Because the fuel contained an ammonium-based stabilizer, however, the nitrogen content of the slurry was 1.90% on a dry basis. Fuel viscosity was about 830 cP (0.9 kg/mg) at a shear rate of 100 sec⁻¹ for the majority of testing.

Scope

The workscope of the program consisted of demonstrating the feasibility of using CWF as a reburning fuel in place of natural gas. The approach to accomplishing this effort was to first establish the validity of the existing CWF data base on the facility so that it could be used for comparative analysis with data gathered. Next, a development and optimization of the reburner performance was to be made. Finally, parametric testing of the

**Table 3-2
CWF ANALYSIS**

	As Received	Dry
Total Moisture, %	4.57	---
Proximate Analysis, %		
Moisture	4.57	---
Volatile Matter	25.05	26.25
Carbon	63.96	67.02
Ash	6.42	6.73
Btu/lb	13,877	14,542
Ultimate Analysis, %		
Moisture	4.57	---
Carbon	78.37	82.12
Hydrogen	4.77	5.00
Nitrogen	1.35	1.41
Sulfur	1.22	1.28
Ash	6.42	6.73
Oxygen (difference)	3.30	3.46
Grindability (ASTM D-409)	91	
Equilibrium Moisture, %	1.80	

all-CWF system was to be performed to establish operating trends and characterize the system. Emphasis of testing was on: 1) combustion stability at the reburner, 2) overall carbon burnout, 3) reduction of NO_x compared to uncontrolled levels at the cyclone, and 4) minimizing particulate loading increases at the stack. Fuel selection and slurry formulation and manufacture were also considered major milestones and were conducted as an integral part of the project. The percentage of total fuel input at the reburner was varied to determine final NO_x levels as a function of reburn fuel loading. Control of SO_2 emissions was not a part of this test program, though as a matter of course, SO_2 was monitored at the boiler stack.

The design concept behind this test program originated, in part, from the economic study of the previous program. A portion of this study evaluated the cost benefit of changing the reburning fuel type from natural gas to CWF (the same fuel as used in the cyclone). By changing to an all-coal (CWF) system, the payback period for a retrofit of this technology was reduced from nearly 4 years to about 2.8 years. Though additional particulates would enter the stack, an ESP that would likely be necessary anyway, could handle the slight increase in solids. The slurry was injected at the same residence time as the gas reburning subsystem (between 0.1 and 0.2 second) and served to create a reducing zone in the main furnace. Unlike the gas reburn system, however, the CWF and its combustion air did not have a NO_x -dilution factor. That is, since the CWF is a nitrogen bearing fuel, a nitrogen balance on the system would show increased nitrogen input for every pound of reburning fuel injected. By comparison, such a balance for the natural gas (NG) reburning system would show decreasing amounts of nitrogen input as the level of reburning fuel was increased. Though this is a minor consideration for commercial application, fundamental information on actual destruction of NO species as compared with dilution would be valuable.

Test Program

The test plan for the combustion portion of the program concentrated on operational and emission-related evaluations. Operational aspects included atomizer design and observations of the functional aspects of CWF injection in the reburn zone. Required CWF and atomizing pressures as well as air to fuel ratios were monitored to assure that reasonable values for future commercial applica-

tion were possible. From an emission perspective, NSPS restrictions for NO_x were minimum target values, with the underlying goal of minimizing the emissions of this gas species while maintaining acceptable operating methods.

Addressing emission control included investigating various subsystem stoichiometries on stack NO_x and carbon burnout. Cyclone, reburning zone, and reburner stoichiometries were interactive variables that affected primarily NO_x but which were also very important from the perspective of stack particulate loadings. Several stoichiometries were selected from the previous test program to establish comparative data. For this reason, if the data collected for this program were to stand alone, it would not have the significance of an integral comparison with prior results. The collection of a smaller amount of data can be justified from a cost perspective and technically from the perspective that once the previous data base is validated, there is no need to duplicate every test result.

Section 4

DISCUSSION OF PILOT-SCALE TEST RESULTS

The pilot-scale tests were divided into two primary areas of investigation:

- Shakedown and baseline tests
- Reburning and parametric tests

Baseline tests were further divided into slurry-only at the cyclone, slurry-at-the-cyclone with natural gas reburning, and natural gas at the cyclone with slurry at the reburner. Once these baseline tests were completed, the parametric tests were performed to find optimum operating conditions by comparison with preselected tests from a prior program. Several tests from the previous program were selected and test conditions duplicated using the all-slurry system as compared to the previous slurry/gas system. This reduced the total amount of data collection that would otherwise have been necessary to make accurate performance predictions.

For descriptive purposes, the furnace can be schematically partitioned into three combustion zones: 1) the main combustion zone, located in the cyclone combustor, 2) the reburning zone, located in the main furnace, and 3) the burnout zone, located in the upper main furnace. In addition, the stoichiometry of the reburner, while not a combustion zone, does significantly affect the reburning zone performance and is therefore included in this discussion.

Calculating a set of desired test conditions requires consideration of the interactive nature of the various system parameters. For a given cyclone stoichiometry, fuel must be added (at the reburner) to obtain the desired reducing zone stoichiometry. This addition of fuel, however, increases the total load to the furnace so that one must make concessions in either holding overall furnace load constant or holding the cyclone load constant. If the cyclone load is held constant, then the reburner load must vary to achieve a desired reburn zone stoichiometry. This results in increases and decreases of fuel nitrogen to the reburn zone. If the overall furnace load

is to be maintained, then the cyclone load must be decreased by an amount equal to the increase in reburner load. Additionally, any changes to the reburn burner impact reburn zone stoichiometry. Finally, overfire air is added to promote complete combustion and establish desired levels of excess air at the stack. For this test program, a tabulation of test numbers and their corresponding operating parameters are included in Appendix C.

4.1 SHAKEDOWN

Since CWF had been fired in the cyclone previously, hardware requirements as far as atomizer design, injection techniques, and pumping and handling requirements were well established. In review, cyclone combustion relies on the capture of fuel particles in a molten slag layer on the wall of the cyclone. It was learned in previous development that rather large, wet, atomized droplets of CWF did not perform well in the cyclone environment, because there was not an adequate amount of drying before the droplet would contact the surface of the cyclone wall. Continued contact of wet droplets resulted in a build-up of dried, partially combusted slurry on the cyclone walls. This build-up either intermittently broke off, or continued to build to the point of disrupting flow currents in the cyclone. The result would be a severe reduction in the amount of slag captured in the cyclone and in the burning efficiency of the system. Operating flexibility of the unit would also be affected, since heat release rates are critical to maintaining adequate slag-tapping performance.

During this program, the plan followed in establishing proper combustion in the cyclone was to duplicate prior operating conditions. This meant atomization quality to a level equal to pulverized coal - 70% < 200 mesh (70% of coal particles passing through a 200-mesh sieve that has 74-micron openings). Note that this restriction will diminish rapidly as the scale of combustion is increased to a commercial level, because the relative proportion of cyclone diameter to droplet size and residence time to wall contact becomes much more forgiving.

4.2 CWF BASELINE TESTS

This series of tests was performed to validate the old data base, which existed from the prior work. All hardware was configured previously, and testing went smoothly for nearly all test series. Combustion of the slurry

was initially noted as less intense than prior combustion, and a brief period of burner adjustments and positioning of the atomizer was performed to improve the initially observed performance. The lower three holes of the six-hole atomizer were plugged to minimize jet impact on the floor of the cyclone and to boost fuel-side pressure drop to levels observed during the prior test program. The lower pressure was due to a lower fuel viscosity as compared with prior tests (see Section 2). This change improved operating conditions markedly as follows: 1) deposits of partially burned fuel which accumulated on the cyclone walls (due to relatively poor atomization) were eliminated, 2) the size and quantity of particulates exiting the cyclone throat were reduced to levels observed in the prior program, and 3) prior-observed stack O_2 swings and CO excursions were smoothed to nearly straight-line performance indicating excellent combustion.

Figure 4-1 shows the change in NO_x emissions as a function of excess oxygen at the boiler stack. Heat input to the furnace was 4 and 6 MBtu/hr. For this data, the 4 MBtu/hr NO_x levels are somewhat higher than full-load NO_x levels. Though this may appear inconsistent, a consideration of the magnitude of the differences shows that only a 4% variation in NO_x emissions exists (40 parts out of 1000). This was considered well within statistically acceptable limits of performance for this furnace system.

The effect of air preheat on NO_x emissions also showed variations from the original data base, as depicted in Figure 4-2. These variations were slightly higher, being about 10% for much of the data. Though the reason for this is unknown, the change in the atomizer previously described in the shakedown section of this report could have affected results by changing the slagging performance and, therefore, the heat release rates in the furnace. If mineral matter is deposited differently inside the cyclone, heat transfer is affected and thermal production can change quickly affecting stack NO_x for single-stage operation of the system. But for reburning, this slight variation in NO_x should not affect the chemistry of the reburning zone. This was proven later in the program.

Figure 4-3 plots NO_x emissions as a function of cyclone load for air preheat values of 650° and 800°F. Here, duplication of the 6-MBtu/hr data is very

Figure 4-1. Change in stack NO_x emissions with excess oxygen for old and new CWF.

Figure 4-2. Effect of air preheat on stack NO_x emissions for old and new CWF.

close to established trends, while the 4-MBtu/hr data are skewed somewhat. Slightly more than a 10% difference in NO_x was observed at full load for the 650°F air preheat. This could be due to daily variations in cyclone operation.

NO_x emissions were very sensitive to combustion performance and observations made by trained personnel during testing indicated that very slight variations in atomizer performance due, for instance, to wear at the atomizer outlet holes, could quickly drop NO_x 10%, and at the same time, produce a noticeable change in the smoothness of operation. Stack oxygen fluctuations of 0.2% to 0.4% would begin occur as compared to fluctuations of less than 0.1% under the best of combustion conditions. As previously noted, these observed variations were not felt to be statistically significant, and on an overall basis, duplication of the prior data base was excellent.

This statement is supported in looking at the FEGTs for the baseline testing, which are plotted in Figure 4-4. At a load of 6 MBtu/hr, and an air preheat temperature of 800°F, FEGT values from the two test programs agree within 10°F. This is well within the variability of test data taken using an HVT instrument (suction pyrometer).

A two-test series was performed to document NO_x reduction levels and general furnace performance when reburning using natural gas at the cyclone. The result of this test was NO_x values of 355 ppmV compared to prior program values of within 3% of this value. Also carbon level in the stack ash for this test was less than 1.2%, which also corresponds closely with prior test results.

The comparisons made with prior baseline data indicate that performance characteristics for the furnace and the fuels, while not identical, were well within acceptable limits. Accordingly, it was established that the old data base would be valid for comparative purposes with new data collected.

Testing proceeded by performing tests in which only natural gas was burned in the cyclone, while CWF was burned at the reburner to isolate carbon-in-ash performance to the reburner. Initial results showed a 12.1% level of

Figure 4-3. Stack NO_x emissions as a function of cyclone load for old and new CWF.

Figure 4-4. Furnace exit gas temperatures (FEGTs) for baseline tests of old and new CWF.

carbon in the stack ash. To reduce this and promote improved overall performance, the top hole of the four-hole reburning atomizer tip was plugged. The philosophy behind this change was to direct more of the CWF into the lower, hotter regions of the main furnace to expose the fuel to higher temperatures and to add some effective residence time of the coal particles in the furnace. This change was effective and resulted in a reduction of carbon-in ash values to 5.07%.

A final configuration was tested; it included the plugged top hole but widened the spray angle to 90° instead of the 60°. This again generated an improvement to carbon-in-ash values to 3.01%. No further development was pursued once values this low had been established. The 90°, three-hole atomizer was adopted for the remainder of the test program and is shown schematically in Figure 4-5.

The effect of flue gas recirculation was also established for the baseline configuration of the reburner operating with CWF and the cyclone with natural gas only. These tests were performed using both the 60° and the 90° spray angles and returned carbon-in-ash values of 26.65% and 16.91%, respectively. This significant increase in carbon values is considered to be caused by reduced gas residence times compared to no FGR and by the cooling effect of the FGR on the reburning zone flame.

4.3 ALL-CWF REBURNING TESTS

During this test series, the parameters of cyclone stoichiometry and reburn zone stoichiometry were of primary interest. When varying cyclone stoichiometry, it is important to hold the reburn zone stoichiometry in the furnace at a fixed value, since stack NO_x is sensitive to both parameters.

Figure 4-6 shows stack NO_x as a function of cyclone stoichiometry for fixed reburn zone stoichiometries of both 0.8 and 0.9. The new NO_x data are higher than when using natural gas as reburn fuel by nearly 20%. This is an expected increase, however, since more fuel nitrogen is being injected into the furnace. The increase in this nitrogen injection is 18% to 22% and a direct correlation with the CWF/natural gas exchange rate. That is, the increase in observed NO_x emissions is the same as the increased percentage of

Figure 4-5. Final CWF atomizer configuration for reburning (B&W I-Jet design).

Figure 4-6. Stack NO_x as a function of stoichiometry.

fuel nitrogen entering the furnace at the reburn zone. Therefore, there appears to be no synergism in going to an all-CWF system that affects NO_x reduction. By decreasing the value of the stoichiometry in the reburning zone from 0.9 to 0.8, stack NO_x levels can be reduced to levels as low as using natural gas reburning at 0.9. In this case, slightly lower loads at the cyclone are offset by slightly higher loads at the reburner.

These results show the benefit of a deeper staging of the combustion process; this is consistent with other documented results. The most important conclusion from Figure 4-6 is that while NO_x emissions equivalent to previous levels can be obtained, it will require greater amounts of CWF at the reburner. The result will be a penalty of a small increase in particulates in the main furnace.

From a commercial prospective, it would be necessary to more closely consider the corrosion aspects of such an operating arrangement before judging its value. But this was beyond the scope of the present test program.

Sensitivity of the operating system to reburn zone stoichiometry is depicted in Figure 4-7. In this figure, cyclone stoichiometry is held constant at 1.1, or about 2% excess oxygen, with a total load to the furnace of 5.6 MBtu/hr. Reburner zone stoichiometry is varied from 0.88 to 0.98, which corresponds to a reburner fuel input rate of 27% to 15%, respectively. Again, the stack results are predictable based on proportional increases in total pounds of nitrogen injected to the furnace compared to natural gas reburning. The present EPA limit for emissions for coal firing in industrial boilers is shown on this figure and indicates that at least 18% of the total furnace load would have to be input at the reburner location.

Figure 4-8 is a similar curve but adds the calculated increase in stack NO_x values that would be measured if the dilution effect of using natural gas as a reburning fuel were removed. This is calculated by removing the mass flow of the combustion air for the natural gas and the mass flow of the natural gas itself and then correcting the NO_x values for the smaller volume of gases at the boiler stack. The basis for this calculation is that since natural gas is a non-nitrogen-bearing fuel that does contribute to the heat

Figure 4-7. Sensitivity of stack NO_x emissions to reburn-zone stoichiometry.

Figure 4-8. Comparison of NO_x destruction in reburn zone for natural gas and CWF reburn fuels.

input of the furnace, it and its combustion air are a source of dilution of the stack gas stream. Therefore, a determination of the actual destruction of NO_x in the reburning zone would have to show a dilution correction (shown in Figure 4-8 as a broken-line curve).

As the reburn-zone stoichiometry increases, the distance between the dilution curve and the data curve widens. This is the result of the increased use of natural gas to decrease the reburn zone stoichiometry. Likewise, as less natural gas is used to increase the reburn-zone stoichiometry, the two curves will eventually converge.

Figure 4-8 shows that as the reburn zone stoichiometry is reduced, the actual destruction rate of NO_x species formed in the cyclone increases. At high reburn zone stoichiometries (0.92 and above), more NO_x on a volumetric basis is destroyed during natural gas reburning than for CWF reburning. But when reburn zone stoichiometries fall below 0.92, more are destroyed using CWF reburning than for natural gas reburning. It is speculated that the reason for this phenomenon is poorer mixing and hydrocarbon radical generation at low CWF reburn loads. Depending on the particular requirements of a given retrofit application, this observation could be used to determine the best reburning fuel.

The effect of flue gas recirculation on NO_x emissions is shown graphically in Figure 4-9. Again, a predictable trend is indicated, with NO_x increases proportional to increased levels of nitrogen entering the furnace. Carbon-in-ash values of 5.64% were measured for an FGR rate of 8.7%, which is quite acceptable for solid waste streams for industrial-scale boilers.

FEGT for tests conducted during this program were consistent with previous results. For baseline tests using single-stage combustion at the cyclone, FEGT averaged 2140°F compared to about 2132°F for data obtained four years ago under similar test conditions. During reburning, FEGT values dropped slightly to an average of 2062°F. These values are rather low for the SBS on dry coal combustion and could be the result of increased moisture in the fuel composition. The changes are small and would not have a significant impact on commercialization of the technology.

Figure 4-9. Effect of flue gas recirculation on final NO_x emissions for old and new CWF.

System Design Parameters

Design information for reburning has been published in literature for several years. This available reference data (along with internal B&W knowledge of staged combustion, mixing, and design of overfire air ports) was the basis for the pilot-scale furnace configuration. Total furnace residence time for the SBS parallels large-scale utility boilers that are cyclone-fired. Calculations of the residence time was based on bulk gas velocities and internal furnace dimensions from the burner level to the entrance of the screen tubes (this represents the end of the radiant section of the boiler). Average gas temperatures were derived using a log mean value of the calculated adiabatic flame temperature near the burner and design values (or actual data if available) for furnace exit gas temperature.

This same technique is used in designing the reburner location. Log mean temperatures of the furnace gases are used to place the throat of the reburner 0.1 to 0.2 second from the throat of the cyclone. The reburner was

placed on the rear wall, opposite the cyclone, to take advantage of the existing gas flow patterns in the SBS. These patterns were quantified using a plastic model and smoke injection as part of the initial reburn design several years ago. Because cyclone throat velocities are high (about 8000 ft/min), the exiting gases impact the rear wall and travel up the wall in a bias toward the rear of the furnace.

For other furnace systems, reburner placement may be optimum at other locations. Likewise, penetration of the furnace gases by the gas jet exiting the reburner throat was quantified through model-based experimentation. Bulk velocities at the throat without inclusion of atomizing air were calculated to be about 60 ft/sec, which is rather low by conventional burner standards for CWF combustion. These values for a wall-fired burner are typically in the 100 ft/sec range. Because stoichiometries of only 0.4 to 0.2 are used at the reburner, however, decreased velocities assist flame stability.

Effective mixing of the reburn flame with furnace combustion gases was achieved without changes to the original system design, except that only one reburner was used. The basis for this change was the calculation of the reburner throat velocity in light of the effective loss of some air to use for atomizing the CWF. At an air/fuel ratio of 1.0, the atomizing air mass flow represented nearly 40% of the typical reburner air flow. Therefore by eliminating one reburner, air velocities were in a proper range for stable combustion and reasonable mixing effectiveness.

Flue gas recirculation to the reburner is also an effective method to enhance mixing in the main furnace. In addition, it also serves to enhance NO_x destruction by virtue of its inert properties. There seems to be a reduction in the effectiveness of FGR beyond the 10% range. NO_x emissions are reduced initially by an additional 15% to 20% from the lowest values possible without FGR. This phenomenon decreases rapidly as increases in FGR from 10% to 20% or more are used. There is never an inflection point obtained where NO_x begin increasing, but the additional decrease is extremely small.

For this test, the reburn atomizer was designed to use a fuel-side pressure drop of 60 psig to 75 psig and an air-side pressure drop of 90 psig held constant over the load range. The size of the atomizer exit hole was based on experimental work indicating that an exit hole one order of magnitude greater than the largest coal particle is needed to minimize pluggage.

Overfire air port design was not changed from existing ports on the SBS. Two overfire ports are located about 0.5 second above the reburner based on bulk gas velocity calculations. Jet penetration was based on conventional approaches available in the literature and was optimized for the SBS through experimental plastic flow models and smoke injection tests. This was performed several years ago as part of a different test program. A typical velocity at the overfire ports is 22 ft/sec at full furnace load using 600°F preheated air.

Section 5

CONCLUSIONS AND RECOMMENDATIONS

5.1 CONCLUSIONS

A demonstration of the feasibility of replacing natural gas with CWF as a reburning fuel was successfully performed at the pilot scale. The results of the program have shown that combustion performance under these operating conditions are quite acceptable for use in the commercial market.

A parent coal was selected that had properties very similar to the coal used in the previous test program. Laboratory-scale formulation tests were conducted and served as the basis for product specifications to the slurry manufacturer. On-site supervision of the production process was performed and a slurry that met B&W specifications was delivered to the Alliance Research Center.

The injector design task provided a reburner atomizer that developed a stable, consistent flame at the reburner and promoted the mixing characteristics for low NO_x . This atomizer was a modified version of B&W's I-jet design and had three exit holes drilled at a 90° included angle. These holes were spaced to provide a slight downward component to the spray direction to enhance carbon burnout. Carbon-in-ash values of 3.01% were achieved using this atomizer installed in the reburning burner while firing natural gas at the cyclone.

Pilot-scale testing initially validated the previous data base then developed a reburn system capable of reducing baseline NO_x emissions more than 60% while maintaining carbon-in-ash values below 6%. NO_x emissions corresponding to the increased nitrogen flow entering the furnace were observed. However, stack NO_x emissions below EPA requirements could still be maintained as long as reburn fuel levels of about 20% of the total furnace load are used. Reductions of reburn zone stoichiometry also reduced NO_x emissions, as did FGR.

FEGT values were relatively unchanged from four years ago. During reburning tests, FEGT dropped slightly but was well within acceptable variances from the baseline values.

5.2 RECOMMENDATIONS

A full-scale industrial retrofit is needed to completely evaluate this technology. Engineering aspects of integrating water circuits from the cyclone into the boiler are needed. Other technical issues that should be addressed include:

- Air preheat requirements and how they would be met for commercial applications.
- Boiler turndown schemes and the effect of scale-up on this performance parameter.
- Overfire air port locations and effectiveness in mixing.
- Coal fluxing to address turndown or out-of-specification coals. Though this was investigated in the previous program, tests in a large cyclone (where correct surface-to-volume ratios exist) are needed.

Section 6

REFERENCES

1. *Program Research and Development Announcement for Advanced Combustion Systems and Technology Development*, PRDA No. RA22-86PC90259, PETC March 19, 1986 p. 1-6.
2. *Conversion of Industrial Boilers to Burn Coal Water Fuel, Phase I - Pilot-Scale Development and Testing*, DOE Contract DE-AC22086PC90276, December 1989. (Babcock & Wilcox Report RDD:90:4344-01-01:01.)
3. Okiura, et al., "Combustion Process of Reducing Nitrogen Oxides," U.S. Patent No. 4,403,941, September 3, 1983.
4. H. Farzan, et al., "Pilot Evaluation of Reburning for Cyclone Boiler NO_x Control," Babcock & Wilcox Report RDD:91:4576-01-02:01, August 1991.

Appendix A

HISTOGRAMS AND CUMULATIVE PSDs OF PRODUCT CWFs

TABLE A-1 PSDs OF BENCH-SCALE (ARC) PRODUCT CWF

CMF92-7: LOWER SEABOARD COAL.
BENCH-SCALE TESTS. 6/14/92

MICRONS	% LESS	DIFF
4800.00		
3394.11		
2400.00		
1697.06		
1200.00	100.00	0.01
848.59	99.99	0.00
600.00	99.99	0.05
424.26	99.94	0.03
300.00	99.91	1.22
212.13	98.89	3.14
150.00	96.56	4.00
106.07	91.58	8.71
76.00	82.86	11.40
53.03	71.45	20.09
37.50	63.35	4.01
26.52	59.35	6.43
18.75	52.91	5.74
13.26	47.17	5.74
9.38	41.42	8.38
6.63	33.06	7.62
4.69	25.44	5.91
3.31	19.52	4.51
2.34	16.02	3.63
1.66	11.39	2.87
1.17	8.52	2.61
0.83	6.01	2.20
0.59	3.82	2.28
0.41	1.54	1.42
0.29	0.12	0.12
0.21	0.00	0.00
0.15		

C9(CAL SURF AREA)=1.54 MM2/CM2
AMD(D43)=39.16 MICRONS
SMD(D32)=3.86 MICRONS

 CHEF92-2 LOWE'S RESEARCH COAL.
 BENCH-SCALE TESTS. 6/14/82

FIGURE A-1 HISTOGRAM OF BENCH-SCALE (ARC) PRODUCT CWF

FIGURE A-2 CUMULATIVE OF BENCH-SCALE (ARC) PRODUCT CHF

TABLE A-2 PSDs OF PRODUCT CNF FROM 2 TPH PRODUCTION (KVS), 1991

P-4748: CNF SAMPLE FROM DRY
TANK SLURRY PUMP OUTLET.
1150 HRS.: 8-28-91

MICRONS	Z LESS	DIFF
4800.00		
3994.11		
2400.00		
1697.08		
1200.00	100.00	0.06
848.53	99.94	0.06
600.00	99.89	0.23
424.26	99.66	0.16
300.00	99.50	0.64
212.13	98.66	1.00
150.00	97.66	2.10
106.07	96.66	6.03
75.00	89.63	9.38
53.03	80.13	5.03
37.50	75.11	4.02
26.52	71.09	7.79
18.75	63.30	6.37
13.26	56.93	6.96
9.38	49.98	10.48
6.63	39.50	8.63
4.69	30.67	5.89
3.31	24.90	4.63
2.34	20.36	4.18
1.66	16.10	3.38
1.17	12.80	3.29
0.63	9.50	3.20
0.58	6.30	3.49
0.41	2.81	2.48
0.29	0.39	0.33
0.21	0.00	0.00
0.15		

CS(CAL SURF AREA)=2.12 mm²/CM³
MMO(043)=29.90 MICRONS
SMO(092)=2.63 MICRONS

F-4745, CHE SAMPLE FROM DAY
 TANK SURVEY PUMP OUTLET.
 1160 HRS., 8-28-91

FIGURE A-3 HISTOGRAM OF PRODUCT C.I.F FROM 2 TPH PRODUCTION (KVS), 1991

FIGURE A-4 CUMULATIVE OF PRODUCT CMF FROM 2 TPA PRODUCTION (KVS), 1991

TABLE A-3 PSDs OF PRODUCT CHF FROM 2 TPH PRODUCTION (KVS), 1987

F-3685, CHF-CYCLONE
 DRY TANK. 0630 HRS.. 9/16/87

MICRONS	Z LESS	DIFF
4800.00	100.00	0.04
3994.11	99.96	0.03
2400.00	99.93	0.32
1697.06	99.61	0.23
1200.00	99.58	0.84
848.63	98.54	2.52
600.00	98.01	4.13
424.26	91.88	5.82
300.00	86.05	6.16
212.13	79.90	6.67
150.00	73.23	8.07
106.07	67.16	7.76
75.00	59.40	5.61
53.03	53.59	9.69
37.50	44.90	9.28
26.52	35.62	6.77
18.75	28.85	6.55
13.26	22.30	4.29
9.38	18.01	3.43
6.63	14.56	3.16
4.69	11.40	3.01
3.31	8.39	2.83
2.34	5.58	3.00
1.66	2.55	2.26
1.17	0.91	0.31
0.83	0.00	0.00
0.69		
0.41		
0.29		
0.21		
0.15		

CS(CAL SURF AREA)=1.93 Mm2/CHm3
 HMD(D43)=34.67 MICRONS
 SMD(D92)=3.12 MICRONS

E-3005, CHE-CYCLONE
 DAY TANK: 0830 HRS.: 9/18/87

FIGURE A-5 HISTOGRAM OF PRODUCT CHE FROM 2 TPH PRODUCTION (KVS), 1987

FIGURE A-6 CUMULATIVE OF PRODUCT CMF FROM 2 TPH PRODUCTION (KVS), 1987

Appendix B
INSTRUMENTATION

Instruments

SBS

B & W Serial	Manufacturer	Model	Description	MFG Serial	Function
0000147	Fisher Sci	Fortin Typ	Barometer, Mercury	2063	Atmospheric Pressure
0520008	Leeds & Northrup	Cat. No. 8621	Optical Pyrometer	1097177	Cyclone Temp
0660156	Barton	800-6	Gage, Pressure	800-6-83133	Atomiz. Air D-P
0770469	Bailey Cntrl.	OC1530A560	Analyz, Gas	829272	O2/Combustable Analyzer
0770470	Bailey Cntrl.	WM55A	Rec. Analyz Gas	829273	O2/Combustable Analyzer
0770594	Toledo	2181	Scale	15495	Calibration
0780094	Bailey Cntrl.	BQ75221	Transmitt, D-P	114118	FGR Static
0780448	Ashcroft	Duragauge	Gage, Pressure	780448-100	Reburn Air Press
079046	Weksler	CA1	Gage, Pressure	790460-160	Atomiz. Air Press After Office
0820259	Bailey Cntrl	BQ73221	Transmitt, D-P	490138	Nat. Gas D-P
0820310	L&N	EMAX-V	Cntrl, Cat	82-67639-1-1	Air Heater Control/ Pri Temp
0820373	Fluke	2160A	Ind, Temp, Digtl	2955008	Temp Indication
0820398	Chessell	320-D	Rec. Milliamp, DC	0682-7212	Analyzer Recorder
0820431	L&N	SPMX 250	Rec, Temp	82-30117-1-1	Multipoint TC Recorder
0820461	Micro Motion	C12-F	Meter Flow, .12	8793	Reburn Slurry Flow
0820462	Micro Motion	D10-RT	Ind, Flow Rate	3438	Reburn Slurry Flow
0820489	Weksler	BA14P	Gage, Press	820489-1000	3000 gal Pump Outlet
0830028	Micro Motion	C-25F	Meter Flow, .24	9793	Cyc. Slurry Mass Flow Meter
0830029	Micro Motion	D10-RT	Ind, Flow Rate	3879	Cyc. Slurry Flow Indicator
0830163	Ashcroft	1279SS	Gage, Pressure	830163-600	Cyc. Slurry Supply Press.
0830171	Chessell	320-D	Analyz, Rec	0783-8379	Analyzer Recorder
0830191	Ashcroft	1279SS	Gage, Press	830191-600	Cyc. Pump Outlet
0840079	Ashcroft	Duragauge	Gage, Pressure	840079-600	Cyc. Slurry Pressure @ gun
0840103	Brown & Sharpe	599-573	Caliper	127503	Measure Dust Loading Tip
0840292	L&N	7075-1-052	Monitor	84-70845-648-2	Conductivity
0860331	Fischer & Porter	10A3555	Rotameter	8911A9325R	Reburn Air Flow Rate
0860418	Mettler	PE 3600	Balance	PE3600	Measure Dust Loading Filters
0860421	Andersen	90-800	Analyz, Particulate	486-316	EPA Particulate Sampler
0870057	Keithley	570	Unit, Data, Acq	353833	Data Acquisition
0870134	Fluke	25	Multipoint, Analyz	4190046	SO2 Voltage
0870142	Beckman Instl.	755	Analyz, Paramag, 4-20ma, 0-50%	1001964	O2 Analyzer
0870197	Rosemount	1151DP4E12	Transmitt, D-P	716413	FGR D-P
0870198	Rosemount	1151DP4E12	Transmitt, D-P	777037	OFA dP
0870199	Rosemount	1151DP4E12	Transmitt, D-P	777040	Sec. Air to Cyclone D-P
0870202	API/LFE Instl.	50	Meter, Vlt, Digtl	870202	O2, NO/NOx, CO, CO2 Volts
0870253	Rosemount	1151GP4E12	Transmitt, Press	779385	Sec. Air to Cyclone Static
0880016	Rosemount	1151DP4E12	Transmitt, D-P	716417	Pri. Air Static
0880137	Fluke	2166A	Ind, Temp, Digtl	4540015	HVT, Reburn Air & Slurry
0890146	Ashcroft	Duragauge	Gage, Pressure	890146-300	Atomiz. Air Before Office

B&W Serial	Manufacturer	Model	Description	MFG Serial	Function
0890325	Anarad	AR-30	Analyzer, Gas	3280-3281	SO2 Analyzer
0890326	Rosemount	1151DP3E22	Transmitt, D-P	1115669	Pl. Air D-P
0890464	Rosemount	1151GP4E12	Transmitt, Press	768475	OFA Static
0890465	Rosemount	1151GP4E12	Transmitt, Press	768477	Sec. Air Static
0890513	Rosemount	1151DP3E22	Transmitt, D-P	1139619	Sec. Air D-P
0890585	API/LFE Inst.	2002	Cntrl, Ind, Curr	890585	ID Fan Damper Settings
0890520	API/LFE	2002	Cntrl, Ind, Temp	890620	Heat Exch Flue Gas Out Temp
0890521	API/LFE	2002	Cntrl, Ind, Temp	890621	Heat Exch H2O In Temp
0890530	Rosemount	2	Transmitt, D-P	1179770	Stack Venturi, D-P
0890533	Rosemount	1151DP4E12	Transmitt, Pres	116329	Stack Venturi Static
0890561	Beckman	864	Analyz, Infrared 4-20ma, 0-20%	106249	CO2 Analyzer
0900020	Beckman Inst.	51A	Analyz, Chemilum, 0-1v, 0-10,000ppm	010438	NO/NOx Analyzer
0900163	Rosemount	1151DP3E22	Transmitt, D-P	122954	Sec. Reburn D-P
0900164	Rosemount	1151DP3E22	Transmitt, D-P	1229446	Sec. Reburn Static
0900213	Cole-Parmer	08672-62	Stopwatch, Digil	0900213	Calibration
0900214	Cole-Parmer	08672-62	Stopwatch, Digil	0900214	Calibration
0910015	L&N	7931-25	Monitor	9051-246810-01	Dissolved Oxygen
0910311	US Gauge		Gage, Press	910311-600	Reburn Slurry Pump Out

MANOMETER LIST

SBS

<u>Manometer Number</u>	<u>Manometer Measurement</u>	<u>Static</u>	<u>dP</u>	<u>Units (Inches)</u>
1	Primary Air	x		_____ Hg
2	Primary Air		x	_____ Oil
3	Secondary Air	x		_____ Hg
4	Secondary Air		x	_____ H2O
5	Total Overfire Air	x		_____ Hg
6	Total Overfire Air		x	_____ H2O
7	Furnace	x		_____ H2O
8	Sec. Air to Cyclone	x		_____ Hg
9	Sec. Air to Cyclone		x	_____ H2O
10	Baghouse Vent	x		_____ H2O
11	Baghouse Vent		x	_____ H2O
12	Cyclone Burner	x		_____ Hg
13	Cyclone Burner		x	_____ Hg
14	Stack	x		_____ H2O
15	Stack		x	_____ H2O
16	FGR	x		_____ Hg
17	FGR		x	_____ H2O
18	Sec. Air to Reburner	x		_____ Hg
19	Sec. Air to Reburner		x	_____ H2O
20	Aspirator @ MSW Bin	x		_____ H2O

NOTE: o Specific Gravity #3 Oil = 2.96 M-39826
 o Specific Gravity Hg = 13.56 M-39825

Thermocouples

SBS

	TYPE	PO # T.C.	WIRE SIZE & COATING	PO # WIRE	SW #1 POS. SW (#2) POS.	T.C. WIRE #
Sec. Air Orifice °F	1/4" - 12" K	66397 UN	20 Ga. - ASB	66393 UN	2	12
Sec. Air to Cyc. Orifice °F	1/4" - 12" K	69785 UN	28 Ga. - PVC	94880 UM	5	67
				20 Ga. ASB to SW. 1		
Sec. Air to Reburner Orifice °F	1/4" - 12" K	69785 UN	20 Ga. - PVC		(14)	47
Nat. Gas Orifice °F	1/8" - 18" K	94880	28 Ga. - PVC	94880 UM	(12)	
Overfire Air Orifice °F	1/4" - 12" K	69785 UN	20 Ga. - PVC		(13)	46
Atomizing Air Orifice °F	1/8" - 18" K	94880	20 Ga. - PVC	82661 UM	(3)	110
Dry Bulb - Sec. Air °F	1/8" - 6" K	281465	20 Ga. - PVC	94880 UM	7	41
Wet Bulb - Sec. Air °F	1/8" - 6" K	281465	20 Ga. - PVC	94880 UM	8	43
Pri. Air Orifice °F	1/4" - 6" K	66397 UN	20 Ga. - ASB	66393 UN	1	11
Baghouse Vent Orifice °F	1/4" - 6" K	66397 UN	20 Ga. - ASB	66393 UN		35
F.G.R.C. Orifice °F	1/4" - 6" K		Short-spliced 28 Ga. - PVC	66393 UN	(11)	61
			28 Ga. - PVC	80803 US	6	19 TC 68 DA
Tertiary Air Orifice °F	1/8" - 6" K					
Furnace Exit Gas C Venturi °F	1/8" - 12" K		20 Ga. - ASB	66393 UN	4	17
Cyclone Slurry °F	1/8" - 18" K	94880	20 Ga. - PVC	90415 UM	(4)	111
Reburn Atomizing Air °F	1/8" - 6" K	281465			Fluke (B&W S/N 0880137)	
Reburn Slurry °F	1/8" - 6" K	281465			Fluke (B&W S/N 0880137)	

STANDARD GASES SBS

<u>P.O. No.</u>	<u>Manufacturer</u>	<u>Cylinder No.</u>	<u>Composition</u>
275048	Linde	T 647372	2.01% O2, 18% CO2, Bal. N2
275048	Linde	T 048352	8.0% O2, 12% CO2, Bal. N2
264134	Linde	T 157572	205 ppm CO, 16.1% CO2, Bal. N2
267488	Linde	T 536019	4500 ppm SO2, Bal. N2
264134	Air Products	SG-1443NB	950 ppm NO, Bal. N2
280639	Matheson	SX-15590	348 ppm NO, Bal. N2
83207	Liquid Carbonic	557083	100% N2
83207	Liquid Carbonic	R1176	100% N2

Appendix C

TABULATED TEST RESULTS, DATA TABLES, AND ISOKINETIC SAMPLING RESULTS

BASELINE DATA

RUN	CYCLONE STOICH	LOAD (MKB)	STACK O ₂ (PPM)	STACK NO _x (ppm)	NO _x @ 3% O ₂ (ppm)	SA TEMP (°F)
6-20-1b	1.16	5.64	2.90	996.90	991.39	746
6-21-1b	1.08	5.82	2.08	1162.6	1106.1	728
6-21-2b	1.05	3.86	1.97	1012.2	957.41	813
6-21-3b	1.11	3.84	2.90	1042.6	1036.8	776
6-24-1b	1.07	5.78	2.12	1015.8	968.45	653
6-24-2b	1.15	5.80	3.17	952.40	961.48	643
6-24-3b	1.07	3.97	2.25	1040.2	998.59	672
6-28-1b	1.03	4.61	2.16	987.20	943.18	759
7-22-1b	1.13	4.57	3.09	1005.9	1010.9	784
7-27-1b	1.08	4.25	2.14	818.40	781.08	674

GAS TO REBURN BURNER

RUN	CYCLONE STOICH	REBURN STOICH	REBURN ZONE STOICH	CYCLONE LOAD (MKB)	REBURN LOAD (MKB)	TOTAL LOAD (MKB)	STACK O2 (ppm)	STACK NOx (ppm)	NOx @ 3% O2 (ppm)	SA TEMP (°F)
6-23-1GR	1.02	.23	.86	4.62	1.22	5.83	2.90	355	353	683

GAS AT CYCLONE & CWS TO REBURN BURNER

RUN	CYCLONE STOICH	REBURN STOICH	REBURN ZONE STOICH	CYCLONE LOAD (MKB)	REBURN LOAD (MKB)	TOTAL LOAD (MKB)	STACK O2 (ppm)	STACK NOx (ppm)	NOx @ 3% O2 (ppm)	SA TEMP (°F)	FGR (%)
7-03-1SR	1.04	.31	.87	4.09	1.19	5.28	2.90	198	197	732	0.0
7-08-1SR	1.02	.38	.88	4.30	1.08	5.38	3.04	274	275	653	0.0
7-08-2SR	1.12	.38	.96	4.22	1.08	5.31	2.76	341	336	660	0.0
7-12-1SR	1.10	.35	.94	3.88	1.06	4.94	2.89	220	219	793	0.0
7-16-1SR	1.08	.34	.90	3.80	1.09	4.89	3.02	233	233	807	0.0
7-18-1SR	1.12	.39	.94	3.64	1.10	4.75	3.03	193	193	807	16.14
7-18-2SR	1.11	.39	.94	3.73	1.09	4.83	2.98	193	193	806	16.05
7-18-3SR	1.07	.39	.91	3.80	1.08	4.88	2.83	214	212	806	0.0
7-18-4SR	1.08	.35	.92	3.81	1.05	4.87	2.89	227	226	807	0.0

CWS AT CYCLONE & REBURN BURNER

RUN	CYCLONE STOICH	REBURN STOICH	REBURN ZONE STOICH	CYCLONE LOAD (MKB)	REBURN LOAD (MKB)	TOTAL LOAD (MKB)	STACK O2 (ppm)	STACK NOx (ppm)	NOx @ 3% O2 (ppm)	SA TEMP (°F)	FGR (%)
7-22-1SR	1.09	.24	.88	4.18	1.36	5.53	2.81	431	426	765	0.0
7-24-1SR	1.10	.26	.90	4.14	1.34	5.48	3.00	483	483	655	0.0
7-24-2-1SR	1.11	.25	.93	4.16	1.09	5.25	3.18	462	467	652	0.0
7-24-2SR	1.09	.26	.89	4.17	1.34	5.50	2.90	444	441	660	0.0
7-24-3SR	1.08	.33	.96	4.18	0.82	5.00	2.98	617	616	668	0.0
7-26-1SR	1.10	.29	.93	4.18	1.09	5.28	2.81	477	472	659	0.0
7-26-2SR	1.13	.21	.91	4.10	1.32	5.42	2.70	431	424	658	0.0
7-26-3SR	0.99	.24	.80	4.00	1.32	5.32	2.76	302	298	668	0.0
7-27-1EX	0.99	.25	.81	4.00	1.32	5.32	2.76	302	298	670	0.0
7-27-1SR	1.10	.29	.89	4.00	1.40	5.40	2.82	347	344	672	8.7
7-27-2-1-2SR	1.10	.28	.90	4.11	1.40	5.51	2.98	352	352	667	0.0
7-27-2SR	1.07	.28	.87	4.18	1.40	5.58	2.67	331	325	670	14.4
7-27-3SR	1.09	.27	.89	4.26	1.40	5.66	2.73	344	339	668	17.76
7-27-4SR	0.90	.31	.79	4.17	0.86	5.03	2.91	288	287	687	0.0
7-27-5SR	0.80	.27	.70	4.12	1.01	5.13	2.77	267	264	653	0.0

DUST LOADING AND FEGT RESULTS

<u>TEST NO.</u>	<u>TEST SERIES</u>	<u>ATOMIZER TIP</u>	<u>% CARBON</u>	<u>FEGT</u>
6-20-1B	BASELINE		0.67	2104
6-21-1B	BASELINE		0.46	2110
6-24-1B	BASELINE		0.70	2151
6-24-2B	BASELINE		NA	2137
6-28-1GR	CWF @ CYCLONE N.G @ REBURNER	60' TIP	1.18	2117
7-8-1SR	N.G. @ CYCLONE CWF @ REBURNER	60' TIP	12.10	NA
7-12-1SR	N.G. @ CYCLONE CWF @ REBURNER	60' TIP	5.07	NA
7-16-1SR	N.G. @ CYCLONE CWF @ REBURNER	90' TIP	3.01	NA
7-18-1SR	N.G. @ CYCLONE CWF @ REBURNER w/ FGR	90' TIP	16.91	NA
7-18-2SR	N.G. @ CYCLONE CWF @ REBURNER w/ FGR	60' TIP	26.65	NA
7-22-1SR	CWF @ CYCLONE CWF @ REBURNER	70' TIP 90' TIP	4.98	2133
7-24-1SR	CWF @ CYCLONE CWF @ REBURNER	70' TIP 90' TIP	3.54	2130
7-26-1SR	CWF @ CYCLONE CWF @ REBURNER	70' TIP 90' TIP	1.33	2049
7-26-3SR	CWF @ CYCLONE CWF @ REBURNER	70' TIP 90' TIP	3.13	2098
7-27-1SR	CWF @ CYCLONE CWF @ REBURNER w/ FGR	70' TIP 90' TIP	5.64	2057

MAIN DATA REDUCTION PROGRAM - BASELINE TEST

Test ID:	6-20-1b	Stack Oxygen, (%)	2.90
time 16:45hrs - 17:00hrs		Stack CO, (ppm)	26.1
All Flow Rates are in lb/hr		Stack NOx, (ppm)	996.9
Cyclone Stoichiometry	1.16	Pri. air to Reburner	N/A
Reburning Burner Stoch.	N/A	Primary Airflow	1181
Reburning Zone Stoch.	N/A	Baghouse Airflow	606
Overall Stoichiometry	1.16	Primary Air to Cyclone	575
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.2575	Total Secondary Air Flow	4420
Atomizing Air	138.10	Sec. Air to Cyclone	4288
Load at Cyclone MBTU/hr	5.64	Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	5.64	SA Mass Balance %	N/A
Calc. Cyclone Coal (lb/hr)	795	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	330	% FGR	N/A
Total Flue Gas (lb/hr)	5714	Reburning Coal Flow	0
		Nat. Gas Flow	N/A
		Channels	
		(not all display)	
Fuel Analysis Basis as received			
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.5
PC coal			
Ash	N/A	Baghouse dp *H2O	0.7
Moisture	N/A	Baghouse st *H2O	0.5
cyclone coal		Baghouse Temp (°F)	105.0
Ash	4.87	FGR st *Hg	1.5
Moisture	27.70	Tertiary Air st *H2O	N/A
Btu Value, Fuel at Cyclone	10514	Tertiary Air dP *H2O	N/A
Btu Value, Fuel at Reburner	22370	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel at Reburner	16.03	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9926		
Dry Bulb Temp. F	94.0379		
Wet Bulb Temp. F	65.1898		
Humidity Calculation(ALL CAL.)			
PBAR	14.0177		
TKELV	291.772		
BETA	355.498		
PDENOM	518.648		
PNUM	2081.66		
PSAT	0.3108		
HSAT	0.0141		
HNUM	7.9801		
HDENOM	1069.56		
HUM	0.0075		
HUMIDITY CORRECTION	0.9978		
Atom Air St PSIG	156.00	Atom Air dp *H2O	16.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	93.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM -- BASELINE TEST

Test ID:	6-21-1b	Stack Oxygen, (%)	2.08
time 13:55hrs - 14:04hrs		Stack CO, (ppm)	34.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	1162.6
Cyclone Stoichiometry	1.08	Atomizing air to Reburner	N/A
Reburning Burner Stoich.	N/A	Primary Airflow	846
Reburning Zone Stoich.	N/A	Baghouse Airflow	512
Overall Stoichiometry	1.11	Primary Air to Cyclone	335
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.2340	Total Secondary Air Flow	4499
Atomizing Air	129.66	Sec. Air to Cyclone	4387
Load at Cyclone MBTU/hr	5.82	Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	5.82	SA Mass Balance %	-2
Calc. Cyclone Coal (lb/hr)	822	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	820	% FGR	N/A
Total Flue Gas (lb/hr)	5701	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70	Atmospheric Pressure "Hg	28.8
sum	100.00		
PC coal		Baghouse dp "H2O	0.5
Ash	N/A	Baghouse st "H2O	0.3
Moisture	N/A	Baghouse Temp (°F)	105.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	22370	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	16.03		
Hum., Lbdair/Lbair (calc.)	0.9912		
Dry Bulb Temp. F	90.8525		
Wet Bulb Temp. F	66.3156		
Humidity Calculation (ALL CAL.)			
PBAR	14.1356		
TKELV	292.398		
BETA	354.872		
PDENOM	519.360		
PNUM	2075.71		
PSAT	0.3232		
HSAT	0.0146		
HNUM	9.4806		
HDENOM	1067.02		
HUM	0.0089		
HUMIDITY CORRECTION	0.9974		
Atom Air St PSIG	185.00	Atom Air dp "H2O	12.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	90.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM - BASELINE TEST

Test ID: 6-21-2b		Stack Oxygen, (%)	1.97
time 16:40hrs - 16:45hrs		Stack CO, (ppm)	35.6
All Flow Rates are in lb/hr		Stack NOx, (ppm)	1012.2
Cyclone Stoichiometry 1.05		Atomizing air to Reburner	N/A
Reburning Burner Stoich. N/A		Primary Airflow	846
Reburning Zone Stoich. N/A		Baghouse Airflow	478
Overall Stoichiometry 1.10		Primary Air to Cyclone	368
Reburning Fuel (%) N/A		Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer 0.3729		Total Secondary Air Flow	2761
Atomizing Air 136.76		Sec. Air to Cyclone	2596
Load at Cyclone MBTU/hr 3.86		Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr N/A		OFA Flow	N/A
Total Load (MBTU/hr) 3.86		SA Mass Balance %	-6
Calc. Cyclone Coal (lb/hr) 544		FGR Flow	N/A
Meas. Cyclone Coal (lb/hr) 445		% FGR	N/A
Total Flue Gas (lb/hr) 3754		Reburning Coal Flow	0
Air/Fuel @ RB Atomizer N/A		Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon 59.37		(not all display)	
Hydrogen 3.62		1,2,3,4,5,9,11,12,13,14,	
Sulfur 0.92		15,16,17,18,19,20,22,24,	
Oxygen 2.50		26,28,34,35,36,37,38,39,41	
Nitrogen 1.02			
Ash 4.87			
Moisture 27.70		Atmospheric Pressure "Hg	28.8
sum 100.00			
PC coal		Baghouse dp "H2O	0.5
Ash N/A		Baghouse st "H2O	0.3
Moisture N/A		Baghouse Temp (°F)	122.0
cyclone coal		FGR st "Hg	1.5
Ash 4.87		Tertiary Air st "H2O	N/A
Moisture 27.70		Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Cyclone 10514		PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner 22370		PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone 8.00		PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner 16.03			
Hum., Lbdair/Lbair(calc.) 0.9913			
Dry Bulb Temp. F 94.2918			
Wet Bulb Temp. F 67.2387			
Humidity Calculation(ALL CAL.)			
PBAR 14.1356			
TKELV 292.910			
BETA 354.360			
PDENOM 519.942			
PNUM 2070.84			
PSAT 0.3336			
HSAT 0.0150			
HNUM 9.3787			
HDENOM 1067.63			
HUM 0.0088			
HUMIDITY CORRECTION 0.9974			
Atom Air St PSIG 164.00		Atom Air dp "H2O	15.0
NG st PSIG N/A		NG dp	N/A
Atom Air temp 93.0000		NG temp	N/A

MAIN DATA REDUCTION PROGRAM -- BASELINE TEST

Test ID:	6-21-86	Stack Oxygen, (%)	2.90	
time 17:21hrs - 17:30hrs		Stack CO, (ppm)	35.0	
All Flow Rates are in lb/hr		Stack NOx, (ppm)	1042.6	
Cyclone Stoichiometry		1.11	Atomizing air to Reburner	N/A
Reburning Burner Stoch.		N/A	Primary Airflow	845
Reburning Zone Stoch.		N/A	Baghouse Airflow	477
Overall Stoichiometry		1.16	Primary Air to Cyclone	368
Reburning Fuel (%)		N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer		0.3735	Total Secondary Air Flow	2960
Atomizing Air		136.54	Sec. Air to Cyclone	2814
Load at Cyclone MBTU/hr		3.84	Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr		N/A	OFA Flow	N/A
Total Load (MBTU/hr)		3.84	SA Mass Balance %	-5
Calc. Cyclone Coal (lb/hr)		542	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)		386	% FGR	N/A
Total Flue Gas (lb/hr)		8	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer		N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received			Channels	
Carbon		59.37	(not all display)	
Hydrogen		3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur		0.92		
Oxygen		2.50	15,16,17,18,19,20,22,24,	
Nitrogen		1.02	26,28,34,35,36,37,38,39,41	
Ash		4.87		
Moisture		27.70		
sum		100.00	Atmospheric Pressure "Hg	28.8
PC coal	Ash	N/A	Baghouse dp "H2O	0.5
	Moisture	N/A	Baghouse st "H2O	0.3
cyclone coal			Baghouse Temp (°F)	122.0
	Ash	4.87	FGR st "Hg	1.5
	Moisture	27.70	Tertiary Air st "H2O	N/A
Btu Value, Fuel at Cyclone		10514	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Reburner		22370	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone		8.00	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel at Reburner		16.03	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair (calc.)		0.9796		
Dry Bulb Temp. F		94.4925		
Wet Bulb Temp. F		80.9092		
Humidity Calculation (ALL CAL.)				
PBAR		14.1356		
TKELV		300.505		
BETA		346.765		
PDENOM		528.432		
PNUM		1999.65		
PSAT		0.5272		
HSAT		0.0241		
HNUM		21.9941		
HDENOM		1054.05		
HUM		0.0209		
HUMIDITY CORRECTION		0.9939		
Atom Air St PSIG		165.00	Atom Air d "H2O	15.0
NG st PSIG		N/A	NG dp	N/A
Atom Air temp		94.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – BASELINE TEST

Test ID: 6-24-1b		Stack Oxygen, (%) 2.12	
time 12:45hrs – 12:52hrs		Stack CO, (ppm) 27.6	
All Flow Rates are in lb/hr		Stack NOx, (ppm) 1015.8	
Cyclone Stoichiometry 1.07		Atomizing air to Reburner N/A	
Reburning Burner Stoich. N/A		Primary Airflow 849	
Reburning Zone Stoich. N/A		Baghouse Airflow 477	
Overall Stoichiometry 1.11		Primary Air to Cyclone 371	
Reburning Fuel (%) N/A		Tertiary Airflow N/A	
Air/Fuel @ Cyc. Atomizer 0.2577		Total Secondary Air Flow 4513	
Atomizing Air 141.62		Sec. Air to Cyclone 4328	
Load at Cyclone MBTU/hr 5.78		Sec. Air to Reburning Burner N/A	
Load at Reburners MBTU/hr N/A		OFA Flow N/A	
Total Load (MBTU/hr) 5.78		SA Mass Balance % -4	
Calc. Cyclone Coal (lb/hr) 815		FGR Flow N/A	
Meas. Cyclone Coal (lb/hr) 579		% FGR N/A	
Total Flue Gas (lb/hr) 5527		Reburning Coal Flow 0	
Air/Fuel @ RB atomizer N/A		Nat. Gas Flow N/A	
Fuel Analysis Basis as received		Channels (not all display)	
Carbon 59.37		1,2,3,4,5,9,11,12,13,14,	
Hydrogen 3.62		15,16,17,18,19,20,22,24,	
Sulfur 0.92		26,28,34,35,36,37,38,39,41	
Oxygen 2.50			
Nitrogen 1.02			
Ash 4.87			
Moisture 27.70			
sum 100.00		Atmospheric Pressure "Hg 29.0	
PC coal			
Ash N/A		Baghouse dp "H2O 0.5	
Moisture N/A		Baghouse st "H2O 0.3	
cyclone coal		Baghouse Temp (°F) 118.0	
Ash 4.87		FGR st "Hg 1.5	
Moisture 27.70		Tertiary Air st "H2O N/A	
Btu Value, Fuel at Cyclone 10514		Tertiary Air dP "H2O N/A	
Btu Value, Fuel at Reburner 22370		PA @ reburner St PSIG 0.0	
Lb dry air/Lb fuel, Cyclone 8.00		PA @ Reburner dp "H2O 0.0	
Lb dry air/Lb fuel at Reburner 16.03		PA @ Reburner temp (°F) 0.0	
Hum., Lbdair/Lbair(calc.) 0.9729			
Dry Bulb Temp. F 91.1723			
Wet Bulb Temp. F 86.8828			
Humidity Calculation(ALL CAL.)			
PBAR 14.2534			
TKELV 303.713			
BETA 343.557			
PDENOM 531.941			
PNUM 1970.07			
PSAT 0.6347			
HSAT 0.0290			
HNUM 29.2073			
HDENOM 1046.80			
HUM 0.0279			
HUMIDITY CORRECTION 0.9919			
Atom Air St PSIG 163.00		Atom Air dp "H2O 16.0	
NG st PSIG N/A		NG dp N/A	
Atom Air temp 81.0000		NG temp N/A	

MAIN DATA REDUCTION PROGRAM – BASELINE TEST

Test ID:	6-24-2b	Stack Oxygen, (%)	3.17
time 15:15hrs – 12:25hrs		Stack CO, (ppm)	31.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	952.4
Cyclone Stoichiometry	1.15	Atomizing air to Reburner	N/A
Reburning Burner Stoich.	N/A	Primary Airflow	865
Reburning Zone Stoich.	N/A	Baghouse Airflow	480
Overall Stoichiometry	1.17	Primary Air to Cyclone	395
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.2561	Total Secondary Air Flow	4703
Atomizing Air	141.22	Sec. Air to Cyclone	4570
Load at Cyclone MBTU/hr	5.80	Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	5.80	SA Mass Balance %	-3
Calc. Cyclone Coal (lb/hr)	818	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	820	% FGR	N/A
Total Flue Gas (lb/hr)	5834	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure "Hg	29.0
sum	100.00		
PC coal		Baghouse dp "H2O	0.5
Ash	N/A	Baghouse st "H2O	0.3
Moisture	N/A	Baghouse Temp (°F)	118.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	22370	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	16.03		
Hum., Lbdair/Lbair(calc.)	0.9937		
Dry Bulb Temp. F	83.6880		
Wet Bulb Temp. F	60.3292		
Humidity Calculation(ALL CAL.)			
PBAR	14.2534		
TKELV	289.072		
BETA	358.198		
PDENOM	515.556		
PNUM	2107.47		
PSAT	0.2620		
HSAT	0.0116		
HNUM	6.7346		
HDENOM	1069.83		
HUM	0.0063		
HUMIDITY CORRECTION	0.9981		
Atom Air St PSIG	163.00	Atom Air dp "H2O	15.8
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	84.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – BASELINE TEST

Test ID:	6-24-3b	Stack Oxygen, (%)	2.25
time 17:05hrs – 17:15hrs		Stack CO, (ppm)	34.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	1040.2
Cyclone Stoichiometry	1.07	Atomizing air to Reburner	N/A
Reburning Burner Stoich.	N/A	Primary Airflow	869
Reburning Zone Stoich.	N/A	Baghouse Airflow	453
Overall Stoichiometry	1.12	Primary Air to Cyclone	416
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.3820	Total Secondary Air Flow	2858
Atomizing Air	144.30	Sec. Air to Cyclone	2691
Load at Cyclone MBTU/hr	3.97	Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	3.97	SA Mass Balance %	-6
Calc. Cyclone Coal (lb/hr)	560	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	393	% FGR	N/A
Total Flue Gas (lb/hr)	3774	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels (not all display)	
Carbon	59.37	1,2,3,4,5,9,11,12,13,14,	
Hydrogen	3.62		
Sulfur	0.92		
Oxygen	2.50		
Nitrogen	1.02	15,16,17,18,19,20,22,24,	26,28,34,35,36,37,38,39,41
Ash	4.87		
Moisture	27.70		
sum	100.00		
PC coal		Atmospheric Pressure "Hg	29.0
Ash	N/A	Baghouse dp "H2O	0.4
Moisture	N/A	Baghouse st "H2O	0.3
cyclone coal		Baghouse Temp (°F)	116.0
Ash	4.87	FGR st "Hg	1.5
Moisture	27.70	Tertiary Air st "H2O	N/A
Btu Value, Fuel at Cyclone	10514	Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Reburner	22370	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel at Reburner	16.03	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9900		
Dry Bulb Temp. F	84.3335		
Wet Bulb Temp. F	66.0820		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	292.268		
BETA	355.002		
PDENOM	519.213		
PNUM	2076.95		
PSAT	0.3206		
HSAT	0.0143		
HNUM	10.7300		
HDENOM	1064.36		
HUM	0.0101		
HUMIDITY CORRECTION	0.9970		
Atom Air St PSIG	164.00	Atom Air dp "H2O	16.5
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	86.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM - BASELINE TEST

Test ID:	6-28-1b	Stack Oxygen, (%)	2.16
time 1310-1315		Stack CO, (ppm)	26.9
All Flow Rates are in lb/hr		Stack NOx, (ppm)	987.2
Cyclone Stoichiometry	1.03	Atomizing air to Reburner	N/A
Reburning Burner Stoich.	N/A	Primary Airflow	881
Reburning Zone Stoich.	N/A	Baghouse Airflow	479
Overall Stoichiometry	1.11	Primary Air to Cyclone	402
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/ Fuel @ Cyc. Atomizer	0.3296	Total Secondary Air Flow	3405
Atomizing Air	144.38	Sec. Air to Cyclone	3100
Load at Cyclone MBTU/hr	4.61	Sec. Air to Reburning Burner	149
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	4.61	SA Mass Balance %	-5
Calc. Cyclone Coal (lb/hr)	438	FGR Flow	8
Meas. Cyclone Coal (lb/hr)	445	% FGR	N/A
Total Flue Gas (lb/hr)	4179	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure "Hg	29.0
sum	100.00		
PC coal		Baghouse dp "H2O	0.5
Ash	N/A	Baghouse st "H2O	0.3
Moisture	N/A	Baghouse Temp (°F)	120.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	22370	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	16.03		
Hum., Lbdair/Lbair(calc.)	0.9884		
Dry Bulb Temp. F	92.0415		
Wet Bulb Temp. F	70.5547		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	294.753		
BETA	352.517		
PDENOM	522.025		
PNUM	2053.42		
PSAT	0.3737		
HSAT	0.0167		
HNUM	12.4843		
HDENOM	1063.31		
HUM	0.0117		
HUMIDITY CORRECTION	0.9965		
Atom Air St PSIG	173.00	Atom Air dp "H2O	15.8
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	88.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – BASELINE TEST

Test ID:7-22-1B		Stack Oxygen,(%)	3.09
time 1225-1235hrs		Stack CO,(ppm)	29.1
All Flow Rates are in lb/hr		Stack NOx,(ppm)	1005.9
Cyclone Stoichiometry	1.13	Atomizing air to Reburner	0
Reburning Burner Stoich.	N/A	Primary Airflow	962
Reburning Zone Stoich.	1.17	Baghouse Airflow	528
Overall Stoichiometry	1.17	Primary Air to Cyclone	434
Reburning Fuel (%)	0.00	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.33	Total Secondary Air Flow	3552
Atomizing Air @ Cyc.	144.16	Sec. Air to Cyclone	3407
Load at Cyclone MBTU/hr	4.57	Sec. Air to Reburning Burner	122
Load at Reburners MBTU/hr	0.00	OFA Flow	255
Total Load (MBTU/hr)	4.57	SA Mass Balance %	7
Calc. Cyclone Fuel (lb/hr)	434	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	444	% FGR	N/A
Total Flue Gas (lb/hr)	4487	Reburning Fuel Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	29.0
PC coal			
Ash	4.87	Baghouse dp "H2O	0.6
Moisture	27.70	Baghouse st "H2O	0.3
cyclone coal		Baghouse Temp (°F)	121.0
Ash	4.87	FGR st "Hg	1.5
Moisture	27.70	Tertiary Air st "H2O	N/A
Btu Value,Fuel at Cyclone	10514	Tertiary Air dP "H2O	N/A
Btu Value,Fuel at Reburner	10514	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel,Cyclone	8.00	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9863		
Dry Bulb Temp. F	96.9674		
Wet Bulb Temp. F	74.4140		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	296.897		
BETA	350.373		
PDENOM	524.430		
PNUM	2033.27		
PSAT	0.4256		
HSAT	0.0191		
HNUM	14.7123		
HDENOM	1061.64		
HUM	0.0139		
HUMIDITY CORRECTION	0.9959		
Atom Air St PSIG	173.00	Atom Air dp "H2O	15.8
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – BASELINE TEST

Test ID:	7-27-1B	Stack Oxygen, (%)	2.14
time 1750-1800hrs		Stack CO, (ppm)	36.3
All Flow Rates are in lb/hr		Stack NOx, (ppm)	818.4
Cyclone Stoichiometry	1.08	Atomizing air to Reburner	0
Reburning Burner Stoich.	N/A	Primary Airflow	932
Reburning Zone Stoich.	N/A	Baghouse Airflow	504
Overall Stoichiometry	1.11	Primary Air to Cyclone	429
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.34	Total Secondary Air Flow	3047
Atomizing Air @ Cyc.	138.60	Sec. Air to Cyclone	2954
Load at Cyclone MBTU/hr	4.25	Sec. Air to Reburning Burner	44
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	4.25	SA Mass Balance %	-2
Calc. Cyclone Fuel (lb/hr)	404	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	422	% FGR	N/A
Total Flue Gas (lb/hr)	3984	Reburning Fuel Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels (not all display)	
Carbon	59.37	1,2,3,4,5,9,11,12,13,14,	
Hydrogen	3.62	15,16,17,18,19,20,22,24,	
Sulfur	0.92	26,28,34,35,36,37,38,39,41	
Oxygen	2.50		
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.8
PC coal		Baghouse dp *H2O	0.5
Ash	4.87	Baghouse st *H2O	0.3
Moisture	27.70	Baghouse Temp (*F)	125.0
cyclone coal		FGR st *Hg	1.5
Ash	4.87	Tertiary Air st *H2O	N/A
Moisture	27.70	Tertiary Air dP *H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	N/A	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (*F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9961		
Dry Bulb Temp. F	88.8259		
Wet Bulb Temp. F	58.2546		
Humidity Calculation(ALL CAL.)			
PBAR	14.1503		
TKELV	287.919		
BETA	359.351		
PDENOM	514.226		
PNUM	2118.55		
PSAT	0.2433		
HSAT	0.0109		
HNUM	4.2059		
HDENOM	1074.18		
HUM	0.0039		
HUMIDITY CORRECTION	0.9988		
Atom Air St PSIG	167.00	Atom Air dp *H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – NATURAL GAS REBURNING TEST

Test ID:	6-28-1GR	Stack Oxygen,(%)	2.90
time 1520-1530		Stack CO,(ppm)	26.0
All Flow Rates are in lb/hr		Stack NOx,(ppm)	355.0
Cyclone Stoichiometry	1.02	Atomizing air to Reburner	N/A
Reburning Burner Stoich.	0.23	Primary Airflow	878
Reburning Zone Stoich.	0.86	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	400
Reburning Fuel (%)	20.85	Tertiary Airflow	N/A
Air/ Fuel @ Cyc. Atomizer	0.3143	Total Secondary Air Flow	4614
Atomizing Air	137.99	Sec. Air to Cyclone	3077
Load at Cyclone MBTU/hr	4.62	Sec. Air to Reburning Burner	205
Load at Reburners MBTU/hr	1.22	OFA Flow	1262
Total Load (MBTU/hr)	5.83	SA Mass Balance %	-2
Calc. Cyclone Coal (lb/hr)	439	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	445	% FGR	N/A
Total Flue Gas (lb/hr)	5367	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	54.36
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	29.0
PC coal		Baghouse dp *H2O	0.5
Ash	N/A	Baghouse st *H2O	0.3
Moisture	N/A	Baghouse Temp (*F)	120.0
cyclone coal		FGR st *Hg	N/A
Ash	4.87	Tertiary Air st *H2O	N/A
Moisture	27.70	Tertiary Air dP *H2O	N/A
Btu Value,Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value,Fuel at Reburner	22370	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel,Cyclone	8.00	PA @ Reburner temp (*F)	0.0
Lb dry air/Lb fuel at Reburner	16.03		
Hum., Lbdair/Lbair(calc.)	0.9872		
Dry Bulb Temp. F	92.0000		
Wet Bulb Temp. F	72.0000		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	295.556		
BETA	351.714		
PDENOM	522.928		
PNUM	2045.86		
PSAT	0.3925		
HSAT	0.0176		
HNUM	13.7370		
HDENOM	1061.85		
HUM	0.0129		
HUMIDITY CORRECTION	0.9962		
Atom Air St PSIG	167.00	Atom Air dp *H2O	15.0
NG st PSIG	37.0000	NG dp	4.0500
Atom Air temp	91.0000	NG temp	95.00

MAIN DATA REDUCTION PROGRAM -- N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-03-1SR	Stack Oxygen, (%)	2.90
time 1400-1410		Stack CO, (ppm)	29.7
All Flow Rates are in lb/hr		Stack NOx, (ppm)	198.3
Cyclone Stoichiometry	1.03	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.32	Primary Airflow	959
Reburning Zone Stoich.	0.87	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	480
Reburning Fuel (%)	21.91	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3907
Atomizing Air	N/A	Sec. Air to Cyclone	2593
Load at Cyclone MBTU/hr	4.12	Sec. Air to Reburning Burner	183
Load at Reburners MBTU/hr	1.16	OFA Flow	1013
Total Load (MBTU/hr)	5.28	SA Mass Balance %	-3
Calc. Cyclone Fuel (lb/hr)	184	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	N/A
Total Flue Gas (lb/hr)	4631	Reburning Fuel Flow	110
Air/Fuel @ RB Atomizer	0.91	Nat. Gas Flow	158.35
Fuel Analysis Basis as received		Channels (not all display)	
Carbon	59.37	1,2,3,4,5,9,11,12,13,14, 15,16,17,18,19,20,22,24, 26,28,34,35,36,37,38,39,41	
Hydrogen	3.62		
Sulfur	0.92		
Oxygen	2.50		
Nitrogen	1.02	Atmospheric Pressure "Hg	
Ash	4.87		
Moisture	27.70	Baghouse dp "H2O	
sum	100.00		
PC coal		Baghouse st "H2O	0.5
Ash	4.87	Baghouse Temp (°F)	120.0
Moisture	27.70	FGR st "Hg	1.5
cyclone coal		Tertiary Air st "H2O	N/A
Ash	0.00	Tertiary Air dP "H2O	N/A
Moisture	0.00	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Cyclone	22370	PA @ Reburner dp "H2O	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel, Cyclone	16.03		
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair (calc.)	0.9910		
Dry Bulb Temp. F	95.2969		
Wet Bulb Temp. F	67.9669		
Humidity Calculation (ALL CAL.)			
PBAR	14.1257		
TKELV	293.315		
BETA	353.955		
PDENOM	520.401		
PNUM	2067.01		
PSAT	0.3421		
HSAT	0.0154		
HNUM	9.7301		
HDENOM	1067.34		
HUM	0.0091		
HUMIDITY CORRECTION	0.9973		
Atom Air St PSIG	95.50	Atom Air dp "H2O	15.8
NG st PSIG	30.0000	NG dp	39.37
Atom Air temp	86.0000	NG temp	88.57

MAIN DATA REDUCTION PROGRAM – N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-08-1SR	Stack Oxygen,(%)	3.04
time 1553-1610		Stack CO,(ppm)	29.2
All Flow Rates are in lb/hr		Stack NOx,(ppm)	273.9
Cyclone Stoichiometry	1.02	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.38	Primary Airflow	868
Reburning Zone Stoich.	0.88	Baghouse Airflow	479
Overall Stoichiometry	1.16	Primary Air to Cyclone	389
Reburning Fuel (%)	20.12	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	4122
Atomizing Air	N/A	Sec. Air to Cyclone	2772
Load at Cyclone MBTU/hr	4.30	Sec. Air to Reburning Burner	213
Load at Reburners MBTU/hr	1.08	OFA Flow	808
Total Load (MBTU/hr)	5.38	SA Mass Balance %	-8
Calc. Cyclone Fuel (lb/hr)	192	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	187	% FGR	N/A
Total Flue Gas (lb/hr)	4759	Reburning Fuel Flow	103
Air/Fuel @ RB Atomizer	0.97	Nat. Gas Flow	158.64
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	29.0
PC coal		Baghouse dp *H2O	0.5
Ash	4.87	Baghouse st *H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	120.0
cyclone coal		FGR st *Hg	1.5
Ash	0.00	Tertiary Air st *H2O	N/A
Moisture	0.00	Tertiary Air dP *H2O	N/A
Btu Value,Fuel at Cyclone	22370	PA @-reburner St PSIG	0.0
Btu Value,Fuel at Reburner	10514	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel,Cyclone	16.03	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9905		
Dry Bulb Temp. F	92.0140		
Wet Bulb Temp. F	67.8317		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	293.240		
BETA	354.030		
PDENOM	520.316		
PNUM	2067.72		
PSAT	0.3405		
HSAT	0.0152		
HNUM	10.2550		
HDENOM	1066.02		
HUM	0.0096		
HUMIDITY CORRECTION	0.9371		
Atom Air St PSIG	173.00	Atom Air dp *H2O	15.8
NG st PSIG	30.0000	NG dp	39.37
Atom Air temp	89.00C0	NG temp	88.20

MAIN DATA REDUCTION PROGRAM – N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID: 7-08-2SR		Stack Oxygen, (%)	2.76
time 1635 – 1650		Stack CO, (ppm)	31.3
All Flow Rates are in lb/hr		Stack NOx, (ppm)	340.9
-----		-----	
Cyclone Stoichiometry	1.12	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.38	Primary Airflow	870
Reburning Zone Stoich.	0.96	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	391
Reburning Fuel (%)	20.42	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	4088
Atomizing Air	N/A	Sec. Air to Cyclone	3032
Load at Cyclone MBTU/hr	4.22	Sec. Air to Reburning Burner	218
Load at Reburners MBTU/hr	1.08	OFA Flow	503
Total Load (MBTU/hr)	5.31	SA Mass Balance %	-8
Calc. Cyclone Fuel (lb/hr)	189	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	N/A
Total Flue Gas (lb/hr)	4721	Reburning Fuel Flow	103
Air/Fuel @ RB Atomizer	0.97	Nat. Gas Flow	158.21
-----		Channels	
Fuel Analysis Basis as received		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.8
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	120.0
cyclone coal		FGR st "Hg	1.5
Ash	0.00	Tertiary Air st "H2O	N/A
Moisture	0.00	Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Cyclone	22370	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9895		
Dry Bulb Temp. F	89.7717		
Wet Bulb Temp. F	68.2326		
Humidity Calculation(ALL CAL.)			
PBAR	14.1356		
TKELV	293.463		
BETA	353.807		
PDENOM	520.568		
PNUM	2065.61		
PSAT	0.3452		
HSAT	0.0156		
HNUM	11.2589		
HDENOM	1064.63		
HUM	0.0106		
HUMIDITY CORRECTION	0.9969		
-----		-----	
Atom Air St PSIG	95.00	Atom Air dp "H2O	15.8
NG st PSIG	30.0000	NG dp	39.37
Atom Air temp	88.0000	NG temp	89.69

MAIN DATA REDUCTION PROGRAM – N.G TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-12-1SR	Stack Oxygen, (%)	2.89
time 1345-1355		Stack CO, (ppm)	28.2
All Flow Rates are in lb/hr		Stack NOx, (ppm)	220.2
Cyclone Stoichiometry	1.10	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.35	Primary Airflow	934
Reburning Zone Stoich.	0.94	Baghouse Airflow	505
Overall Stoichiometry	1.15	Primary Air to Cyclone	430
Reburning Fuel (%)	21.43	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3675
Atomizing Air	N/A	Sec. Air to Cyclone	2674
Load at Cyclone MBTU/hr	3.88	Sec. Air to Reburning Burner	185
Load at Reburners MBTU/hr	1.06	OFA Flow	874
Total Load (MBTU/hr)	4.94	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	173	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	N/A	% FGF	N/A
Total Flue Gas (lb/hr)	4334	Reburning Fuel Flow	101
Air/Fuel @ RB Atomizer	0.99	Nat. Gas Flow	159.85
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure "Hg	29.0
sum	100.00		
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	120.0
cyclone coal		FGR st "Hg	1.5
Ash	0.00	Tertiary Air st "H2O	N/A
Moisture	0.00	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	22370	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair (calc.)	0.9895		
Dry Bulb Temp. F	82.2118		
Wet Bulb Temp. F	66.1963		
Humidity Calculation (ALL CAL.)			
PBAR	14.2583		
TKELV	292.331		
BETA	354.939		
PDENOM	519.285		
PNUM	2076.34		
PSAT	0.3218		
HSAT	0.0144		
HNUM	11.3271		
HDENOM	1063.31		
HUM	0.0107		
HUMIDITY CORRECTION	0.9968		
Atom Air St PSIG	95.00	Atom Air dp "H2O	15.8
NG st PSIG	30.0000	NG dp	39.37
Atom Air temp	79.0000	NG temp	79.90

MAIN DATA REDUCTION PROGRAM – N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-16-1SR	Stack Oxygen, (%)	3.02
time 1605-1615		Stack CO, (ppm)	31.8
All Flow Rates are in lb/hr		Stack NOx, (ppm)	232.6
Cyclone Stoichiometry	1.08	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.34	Primary Airflow	922
Reburning Zone Stoich.	0.90	Baghouse Airflow	479
Overall Stoichiometry	1.16	Primary Air to Cyclone	443
Reburning Fuel (%)	22.32	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3632
Atomizing Air	N/A	Sec. Air to Cyclone	2509
Load at Cyclone MBTU/hr	3.80	Sec. Air to Reburning Burner	183
Load at Reburners MBTU/hr	1.09	OFA Flow	959
Total Load (MBTU/hr)	4.89	SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	170	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	0.00
Total Flue Gas (lb/hr)	4317	Reburning Fuel Flow	104
Air/Fuel @ RB Atomizer	0.96	Nat. Gas Flow	13.35
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure *Hg	29.1
sum	100.00		
PC coal		Baghouse dp *H2O	0.5
Ash	4.87	Baghouse st *H2O	0.3
Moisture	27.70	Baghouse Temp (*F)	120.0
cyclone coal		FGR st *Hg	1.5
Ash	0.00	Tertiary Air st *H2O	N/A
Moisture	0.00	Tertiary Air dP *H2O	N/A
Btu Value, Fuel at Cyclone	22370	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner temp (*F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9935		
Dry Bulb Temp. F	96.1904		
Wet Bulb Temp. F	64.9877		
Humidity Calculation(ALL CAL.)			
PBAR	14.2731		
TKELV	291.660		
BETA	355.610		
PDENOM	518.520		
PNUM	2082.73		
PSAT	0.3086		
HSAT	0.0137		
HNUM	7.0393		
HDENOM	1070.72		
HUM	0.0066		
HUMIDITY CORRECTION	0.9980		
Atom Air St PSIG	95.00	Atom Air dp *H2O	15.8
NG st PSIG	30.0000	NG dp	0.28
Atom Air temp	87.0000	NG temp	90.87

MAIN DATA REDUCTOIN PROGRAM – N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-18-1SR	Stack Oxygen, (%)	3.03
time 1530-1540		Stack CO, (ppm)	27.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	192.8
Cyclone Stoichiometry	1.12	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.39	Primary Airflow	924
Reburning Zone Stoich.	0.94	Baghouse Airflow	477
Overall Stoichiometry	1.16	Primary Air to Cyclone	447
Reburning Fuel (%)	23.26	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3591
Atomizing Air	N/A	Sec. Air to Cyclone	2559
Load at Cyclone MBTU/hr	3.64	Sec. Air to Reburning Burner	129
Load at Reburners MBTU/hr	1.10	OFA Flow	972
Total Load (MBTU/hr)	4.75	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	163	FGR Flow	695
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	16.14
Total Flue Gas (lb/hr)	4194	Reburning Fuel Flow	105
Air/Fuel @ RB Atomizer	0.95	Nat. Gas Flow	158.36
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.8
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	120.0
cyclone coal		FGR st "Hg	1.4
Ash	0.00	Tertiary Air st "H2O	N/A
Moisture	0.00	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	22370	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair (calc.)	0.9742		
Dry Bulb Temp. F	98.3443		
Wet Bulb Temp. F	86.7759		
Humidity Calculation (ALL CAL.)			
PBAR	14.1552		
TKELV	303.764		
BETA	343.506		
PDENOM	531.998		
PNUM	1969.60		
PSAT	0.6366		
HSAT	0.0293		
HNUM	27.8214		
HDENOM	1049.89		
HUM	0.0265		
HUMIDITY CORRECTION	0.9923		
Atom Air St PSIG	95.00	Atom Air dp "H2O	15.8
NG st PSIG	30.4000	NG dp	39.37
Atom Air temp	91.0000	NG temp	93.85

MAIN DATA REDUCTION PROGRAM - N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-18-2SR	Stack Oxygen, (%)	2.98
time 1730-1740		Stack CO, (ppm)	31.9
All Flow Rates are in lb/hr		Stack NOx, (ppm)	192.7
Cyclone Stoichiometry	1.11	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.39	Primary Airflow	932
Reburning Zone Stoich.	0.94	Baghouse Airflow	479
Overall Stoichiometry	1.1C	Primary Air to Cyclone	453
Reburning Fuel (%)	22.67	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3577
Atomizing Air	N/A	Sec. Air to Cyclone	2550
Load at Cyclone MBTU/hr	3.73	Sec. Air to Reburning Burner	126
Load at Reburners MBTU/hr	1.09	OFA Flow	972
Total Load (MBTU/hr)	4.83	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	167	FGR Flow	690
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	16.05
Total Flue Gas (lb/hr)	4257	Reburning Fuel Flow	104
Air/Fuel @ RB Atomizer	0.96		
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure "Hg	28.8
sum	100.00		
P C coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	120.0
cyclone coal		FGR st "Hg	1.5
Ash	0.00	Tertiary Air st "H2O	N/A
Moisture	0.00	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	22370	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9901		
Dry Bulb Temp. F	100.3504		
Wet Bulb Temp. F	70.5640		
Humidity Calculation(ALL CAL.)			
PBAR	14.1257		
TKELV	294.758		
BETA	352.512		
PDENOM	522.031		
PNUM	2053.37		
PSAT	0.3738		
HSAT	0.0169		
HNUM	10.6683		
HDENOM	1066.99		
HUM	0.0100		
HUMIDITY CORRECTION	0.9970		
Atom Air St PSIG	95.50	Atom Air dp "H2O	15.8
NG st PSIG	30.0000	NG dp	0.22
Atom Air temp	91.0000	NG temp	96.23

MAIN DATA REDUCTION PROGRAM – N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-18-3SR	Stack Oxygen, (%)	2.83
time 1740--1743		Stack CO, (ppm)	29.2
All Flow Rates are in lb/hr		Stack NOx, (ppm)	214.2
Cyclone Stoichiometry	1.07	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.39	Primary Airflow	935
Reburning Zone Stoich.	0.91	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	456
Reburning Fuel (%)	22.19	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3589
Atomizing Air	N/A	Sec. Air to Cyclone	2483
Load at Cyclone MBTU/hr	3.80	Sec. Air to Reburning Burner	221
Load at Reburners MBTU/hr	1.08	OFA Flow	958
Total Load (MBTU/hr)	4.88	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	170	FGR Flow	12
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	0.27
Total Flue Gas (lb/hr)	4267	Reburning Fuel Flow	103
Air/Fuel @ RB Atomizer	0.97		
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure "Hg	28.8
sum	100.00		
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	120.0
cyclone coal		FGR st "Hg	1.5
Ash	0.00	Tertiary Air st "H2O	N/A
Moisture	0.00	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	22370	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9884		
Dry Bulb Temp. F	98.9900		
Wet Bulb Temp. F	72.2365		
Humidity Calculation(ALL CAL.)			
PBAR	14.1257		
TKELV	295.687		
BETA	351.583		
PDENOM	523.075		
PNUM	2044.62		
PSAT	0.3956		
HSAT	0.0179		
HNUM	12.4471		
HDENOM	1064.72		
HUM	0.0117		
HUMIDITY CORRECTION	0.9965		
Atom Air St PSIG	95.50	Atom Air dp "H2O	15.8
NG st PSIG	30.0000	NG dp	0.22
Atom Air temp	86.0000	NG temp	97.09

MAIN DATA REDUCTION PROGRAM – N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-18-4SR	Stack Oxygen, (%)	2.89
time 1750-1755	NO FGR	Stack CO, (ppm)	27.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	227.4
Cyclone Stoichiometry	1.08	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.35	Primary Airflow	933
Reburning Zone Stoich.	0.92	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	455
Reburning Fuel (%)	21.61	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3596
Atomizing Air	N/A	Sec. Air to Cyclone	2545
Load at Cyclone MBTU/hr	3.81	Sec. Air to Reburning Burner	182
Load at Reburners MBTU/hr	1.05	OFA Flow	928
Total Load (MBTU/hr)	4.87	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	171	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	0.00
Total Flue Gas (lb/hr)	4269	Reburning Fuel Flow	100
Air/Fuel @ RB Atomizer	1.00	Nat. Gas Flow	90.66
Fuel Analysis Basis as received		Channels	
		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.8
PC coal			
Ash	4.87	Baghouse dp *H2O	0.5
Moisture	27.70	Baghouse st *H2O	0.3
cyclone coal		Baghouse Temp (*F)	120.0
Ash	0.00	FGR st *Hg	1.5
Moisture	0.00	Tertiary Air st *H2O	N/A
Btu Value, Fuel at Cyclone	22370	Tertiary Air dP *H2O	N/A
Btu Value, Fuel at Reburner	10514	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	16.03	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner temp (*F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9873		
Dry Bulb Temp. F	97.9475		
Wet Bulb Temp. F	73.3547		
Humidity Calculation(ALL CAL.)			
PBAR	14.1257		
TKELV	296.308		
BETA	350.962		
PDENOM	523.772		
PNUM	2038.78		
PSAT	0.4108		
HSAT	0.0186		
HNUM	13.6991		
HDENOM	1063.13		
HUM	0.0129		
HUMIDITY CORRECTION	0.9962		
Atom Air St PSIG	95.50	Atom Air dp *H2O	15.8
NG st PSIG	30.0000	NG dp	0.22
Atom Air temp	86.0000	NG temp	97.09

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-22-1SR	Stack Oxygen, (%)	2.81
time 1445-1515hrs		Stack CO, (ppm)	30.4
All Flow Rates are in lb/hr		Stack NOx, (ppm)	413.1
Cyclone Stoichiometry	1.09	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.24	Primary Airflow	946
Reburning Zone Stoich.	0.88	Baghouse Airflow	504
Overall Stoichiometry	1.15	Primary Air to Cyclone	443
Reburning Fuel (%)	24.52	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.34	Total Secondary Air Flow	4353
Atomizing Air @ Cyc.	134.78	Sec. Air to Cyclone	2941
Load at Cyclone MBTU/hr	4.18	Sec. Air to Reburning Burner	151
Load at Reburners MBTU/hr	1.36	OFA Flow	1320
Total Load (MBTU/hr)	5.53	SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	397	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	430	% FGR	N/A
Total Flue Gas (lb/hr)	5337	Reburning Fuel Flow	129
Air/Fuel @ RB Atomizer	0.78	Nat. Gas Flow	N/A
		Channels	
Fuel Analysis Basis as received		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.9
PC coal			
Ash	4.87	Baghouse dp "H2O	0.5
Moisture	27.70	Baghouse st "H2O	0.4
cyclone coal		Baghouse Temp (°F)	121.0
Ash	4.87	FGR st "Hg	1.5
Moisture	27.70	Tertiary Air st "H2O	N/A
Btu Value, Fuel at Cyclone	10514	Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Reburner	10514	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9858		
Dry Bulb Temp. F	94.0712		
Wet Bulb Temp. F	74.1599		
Humidity Calculation(ALL CAL.)			
PBAR	14.1847		
TKELV	296.755		
BETA	350.515		
PDENOM	524.272		
PNUM	2034.59		
PSAT	0.4220		
HSAT	0.0191		
HNUM	15.2804		
HDENOM	1060.61		
HUM	0.0144		
HUMIDITY CORRECTION	0.9958		
Atom Air St PSIG	195.00	Atom Air dp "H2O	12.5
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	95.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-24-1SR	Stack Oxygen, (%)	3.00
time 1515-1545hrs		Stack CO, (ppm)	31.3
All Flow Rates are in lb/hr		Stack NOx, (ppm)	482.7
Cyclone Stoichiometry	1.10	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.26	Primary Airflow	939
Reburning Zone Stoich.	0.90	Baghouse Airflow	530
Overall Stoichiometry	1.16	Primary Air to Cyclone	409
Reburning Fuel (%)	24.37	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.34	Total Secondary Air Flow	4356
Atomizing Air @ Cyc.	132.34	Sec. Air to Cyclone	2948
Load at Cyclone MBTU/hr	4.14	Sec. Air to Reburning Burner	170
Load at Reburners MBTU/hr	1.34	OFA Flow	1295
Total Load (MBTU/hr)	5.48	SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	394	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426	% FGR	N/A
Total Flue Gas (lb/hr)	5337	Reburning Fuel Flow	127
Air/Fuel @ RB Atomizer	0.79	Nat. Gas Flow	N/A
		Channels	
Fuel Analysis Basis as received		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	29.0
PC coal			
Ash	4.87	Baghouse dp *H2O	0.6
Moisture	27.70	Baghouse st *H2O	0.3
cyclone coal		Baghouse Temp (*F)	121.0
Ash	4.87	FGR st *Hg	1.5
Moisture	27.70	Tertiary Air st *H2O	N/A
Btu Value, Fuel at Cyclone	10514	Tertiary Air dP *H2O	N/A
Btu Value, Fuel at Reburner	10514	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner temp (*F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9930		
Dry Bulb Temp. F	87.4984		
Wet Bulb Temp. F	62.8315		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	290.462		
BETA	356.808		
PDENOM	517.152		
PNUM	2094.16		
PSAT	0.2862		
HSAT	0.0127		
HNUM	7.5612		
HDENOM	1069.02		
HUM	0.0071		
HUMIDITY CORRECTION	0.9979		
Atom Air St PSIG	195.00	Atom Air dp *H2O	12.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	95.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-24-2-1sr	Stack Oxygen,(%)	3.18
time 1705-1720hrs		Stack CO,(ppm)	31.1
All Flow Rates are in lb/hr		Stack NOx,(ppm)	461.8
Cyclone Stoichiometry	1.11	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.25	Primary Airflow	936
Reburning Zone Stoich.	0.93	Baghouse Airflow	503
Overall Stoichiometry	1.17	Primary Air to Cyclone	432
Reburning Fuel (%)	20.83	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	4169
Atomizing Air @ Cyc.	138.47	Sec. Air to Cyclone	2963
Load at Cyclone MBTU/hr	4.16	Sec. Air to Reburning Burner	114
Load at Reburners MBTU/hr	1.09	OFA Flow	1157
Total Load (MBTU/hr)	5.25	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	395	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426	% FGR	N/A
Total Flue Gas (lb/hr)	5181	Reburning Fuel Flow	104
Air/Fuel @ RB Atomizer	0.96	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	Atmospheric Pressure *Hg	29.0
sum	100.00	Baghouse dp *H2O	0.5
PC coal		Baghouse st *H2O	0.3
Ash	4.87	Baghouse Temp (°F)	125.0
Moisture	27.70	FGR st *Hg	1.5
cyclone coal		Tertiary Air st *H2O	N/A
Ash	4.87	Tertiary Air dP *H2O	N/A
Moisture	27.70	PA @ reburner St PSIG	0.0
Btu Value,Fuel at Cyclone	10514	PA @ Reburner dp *H2O	0.0
Btu Value,Fuel at Reburner	10514	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel,Cyclone	8.00		
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9929		
Dry Bulb Temp. F	90.6233		
Wet Bulb Temp. F	64.0234		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	291.124		
BETA	356.146		
PDENOM	517.909		
PNUM	2087.83		
PSAT	0.2984		
HSAT	0.0133		
HNUM	7.6754		
HDENOM	1069.21		
HUM	0.0072		
HUMIDITY CORRECTION	0.9979		
Atom Air St PSIG	167.00	Atom Air dp *H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-24-2sr	Stack Oxygen, (%)	2.90
time 1515-1545hrs		Stack CO, (ppm)	30.9
All Flow Rates are in lb/hr		Stack NOx, (ppm)	444.0
Cyclone Stoichiometry	1.09	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.26	Primary Airflow	139
Reburning Zone Stoich.	0.89	Baghouse Airflow	529
Overall Stoichiometry	1.15	Primary Air to Cyclone	409
Reburning Fuel (%)	24.27	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.33	Total Secondary Air Flow	4350
Atomizing Air @ Cyc.	132.32	Sec. Air to Cyclone	2947
Load at Cyclone MBTU/hr	4.17	Sec. Air to Reburning Burner	169
Load at Reburners MBTU/hr	1.34	OFA Flow	1288
Total Load (MBTU/hr)	5.50	SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	396	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426	% FGR	N/A
Total Flue Gas (lb/hr)	5331	Reburning Fuel Flow	127
Air/Fuel @ RB Atomizer	0.79	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels (not all display)	
Carbon	59.37	1,2,3,4,5,9,11,12,13,14,	
Hydrogen	3.62		
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	26,28,34,35,36,37,38,39,41	
sum	100.00		
PC coal		Atmospheric Pressure "Hg	29.0
Ash	4.87	Baghouse dp "H2O	0.6
Moisture	27.70	Baghouse st "H2O	0.3
cyclone coal		Baghouse Temp (°F)	121.0
Ash	4.87	FGR st "Hg	1.5
Moisture	27.70	Tertiary Air st "H2O	N/A
Btu Value, Fuel at Cyclone	10514	Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Reburner	10514	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9925		
Dry Bulb Temp. F	88.2841		
Wet Bulb Temp. F	63.8022		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	291.001		
BETA	356.269		
PDENOM	517.769		
PNUM	2089.01		
PSAT	0.2961		
HSAT	0.0132		
HNUM	8.0747		
HDENOM	1068.40		
HUM	0.0076		
HUMIDITY CORRECTION	0.9978		
Atom Air St PSIG	195.00	Atom Air dp "H2O	12.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	95.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-24-3sr	Stack Oxygen, (%)	2.98
time 1800-1810hrs		Stack CO, (ppm)	32.0
All Flow Rates are in lb/hr		Stack NOx, (ppm)	617.4
Cyclone Stoichiometry	1.08	Atomizing air to Reburner	100
Reburning Burner Stoichiometry	0.33	Primary Airflow	931
Reburning Zone Stoichiometry	0.96	Baghouse Airflow	502
Overall Stoichiometry	1.16	Primary Air to Cyclone	429
Reburning Fuel (%)	16.40	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	3933
Atomizing Air @ Cyc.	138.17	Sec. Air to Cyclone	2919
Load at Cyclone MBTU/hr	4.18	Sec. Air to Reburning Burner	106
Load at Reburners MBTU/hr	0.82	OFA Flow	960
Total Load (MBTU/hr)	5.00	SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	398	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426	% FGR	N/A
Total Flue Gas (lb/hr)	4913	Reburning Fuel Flow	78
Air/Fuel @ RB Atomizer	1.28	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.8
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	125.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair (calc.)	0.9856		
Dry Bulb Temp. F	90.9453		
Wet Bulb Temp. F	73.5236		
Humidity Calculation (ALL CAL.)			
PBAR	14.1503		
TKELV	296.402		
BETA	350.868		
PDENOM	523.877		
PNUM	2037.90		
PSAT	0.4131		
HSAT	0.0187		
HNUM	15.4979		
HDENOM	1059.86		
HUM	0.0146		
HUMIDITY CORRECTION	0.9957		
Atom Air St PSIG	167.00	Atom Air dp "H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID: test 3		7-26-1sr	Stack Oxygen, (%)	2.81
time 1330-1340hrs			Stack CO, (ppm)	30.8
All Flow Rates are in lb/hr			Stack NOx, (ppm)	477.2
Cyclone Stoichiometry	1.10		Atomizing air to Reburner	100
Reburning Burner Stoich.	0.29		Primary Airflow	932
Reburning Zone Stoich.	0.93		Baghouse Airflow	503
Overall Stoichiometry	1.15		Primary Air to Cyclone	429
Reburning Fuel (%)	20.72		Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35		Total Secondary Air Flow	4103
Atomizing Air @ Cyc.	138.46		Sec. Air to Cyclone	2973
Load at Cyclone MBTU/hr	4.18		Sec Air to Reburning Burner	142
Load at Reburners MBTU/hr	1.09		OFA Flow	1037
Total Load (MBTU/hr)	5.28		SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	398		FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426		% FGR	N/A
Total Flue Gas (lb/hr)	5114		Reburning Fuel Flow	104
Air/Fuel @ RB Atomizer	0.96		Nat. Gas Flow	N/A
Fuel Analysis Basis as received			Channels	
Carbon	59.37		(not all display)	
Hydrogen	3.62		1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92			
Oxygen	2.50		15,16,17,18,19,20,22,24,	
Nitrogen	1.02		26,28,34,35,36,37,38,39,41	
Ash	4.87			
Moisture	27.70			
sum	100.00		Atmospheric Pressure "Hg	29.0
PC coal			Baghouse dp "H2O	0.5
Ash	4.87		Baghouse st "H2O	0.3
Moisture	27.70		Baghouse Temp (°F)	125.0
cyclone coal			FGR st "Hg	1.5
Ash	4.87		Tertiary Air st "H2O	N/A
Moisture	27.70		Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Cyclone	10514		PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514		PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00		PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00			
Hum., Lbdair/Lbair(calc.)	0.9927			
Dry Bulb Temp. F	88.7184			
Wet Bulb Temp. F	63.6382			
Humidity Calculation(ALL CAL.)				
PBAR	14.2583			
TKELV	290.910			
BETA	356.360			
PDENOM	517.665			
PNUM	2089.88			
PSAT	0.2944			
HSAT	0.0131			
HNUM	7.8508			
HDENOM	1068.75			
HUM	0.0073			
HUMIDITY CORRECTION	0.9978			
Atom Air St PSIG	167.00		Atom Air dp "H2O	15.0
NG st PSIG	N/A		NG dp	N/A
Atom Air temp	89.0000		NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID: test 5		7-26-2sr	Stack Oxygen, (%)	2.70
time 1610-1620hrs			Stack CO, (ppm)	31.9
All Flow Rates are in lb/hr			Stack NOx, (ppm)	431.1
Cyclone Stoichiometry	1.13		Atomizing air to Reburner	100
Reburning Burner Stoich.	0.21		Primary Airflow	928
Reburning Zone Stoich.	0.91		Baghouse Airflow	503
Overall Stoichiometry	1.14		Primary Air to Cyclone	425
Reburning Fuel (%)	24.42		Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.36		Total Secondary Air Flow	4210
Atomizing Air @ Cyc.	138.44		Sec. Air to Cyclone	3005
Load at Cyclone MBTU/hr	4.10		Sec. Air to Reburning Burner	116
Load at Reburners MBTU/hr	1.32		OFA Flow	1116
Total Load (MBTU/hr)	5.42		SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	390		FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426		% FGR	N/A
Total Flue Gas (lb/hr)	5205		Reburning Fuel Flow	126
Air/Fuel @ RB Atomizer	0.79		Nat. Gas Flow	N/A
Fuel Analysis Basis as received			Channels	
Carbon	59.37		(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,		
Sulfur	0.92			
Oxygen	2.50	15,16,17,18,19,20,22,24,		
Nitrogen	1.02	26,28,34,35,36,37,38,39,41		
Ash	4.87			
Moisture	27.70			
sum	100.00		Atmospheric Pressure "Hg	29.0
PC coal				
Ash	4.87		Baghouse dp "H2O	0.5
Moisture	27.70		Baghouse st "H2O	0.3
cyclone coal			Baghouse Temp (°F)	125.0
Ash	4.87		FGR st "Hg	1.5
Moisture	27.70		Tertiary Air st "H2O	N/A
Btu Value, Fuel at Cyclone	10514		Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Reburner	10514		PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00		PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00		PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9920			
Dry Bulb Temp. F	88.7982			
Wet Bulb Temp. F	64.6258			
Humidity Calculation(ALL CAL.)				
PRAT	14.2583			
TKELV	291.459			
BETA	355.811			
PDENOM	518.291			
PNUM	2084.64			
PSAT	0.3048			
HSAT	0.0136			
HNUM	8.5585			
HDENOM	1067.80			
HUM	0.0080			
HUMIDITY CORRECTION	0.9976			
Atom Air St PSIG	167.00		Atom Air dp "H2O	15.0
NG st PSIG	N/A		NG dp	N/A
Atom Air temp	89.0000		NG temp	N/A

MAIN DATA REDUCTION PROGRAM - CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-26-3SR	Stack Oxygen, (%)	2.76
time 1800-1810hrs		Stack CO, (ppm)	33.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	302.3
Cyclone Stoichiometry	0.99	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.24	Primary Airflow	929
Reburning Zone Stoich.	0.80	Baghouse Airflow	529
Overall Stoichiometry	1.14	Primary Air to Cyclone	400
Reburning Fuel (%)	24.90	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	4178
Atomizing Air @ Cyc.	132.20	Sec. Air to Cyclone	2512
Load at Cyclone MBTU/hr	4.00	Sec. Air to Reburning Burner	140
Load at Reburners MBTU/hr	1.32	OFA Flow	1601
Total Load (MBTU/hr)	5.32	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	380	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	426	% FGR	N/A
Total Flue Gas (lb/hr)	5121	Reburning Fuel Flow	126
Air/Fuel @ RB Atomizer	0.79	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	29.0
PC coal		Baghouse dp "H2O	0.6
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	121.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9895		
Dry Bulb Temp. F	87.8765		
Wet Bulb Temp. F	67.8836		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	293.269		
BETA	354.001		
PDENOM	520.349		
PNUM	2067.45		
PSAT	0.3411		
HSAT	0.0152		
HNUM	11.2893		
HDENOM	1064.13		
HUM	0.0106		
HUMIDITY CORRECTION	0.9969		
Atom Air St PSIG	195.00	Atom Air dp "H2O	12.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	95.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID: 7-27-1ex		Stack Oxygen, (%) 2.76	
time 1800-1810hrs		Stack CO, (ppm) 33.5	
All Flow Rates are in lb/hr		Stack NOx, (ppm) 302.3	
Cyclone Stoichiometry 0.99		Atomizing air to Reburner 100	
Reburning Burner Stoich. 0.25		Primary Airflow 929	
Reburning Zone Stoich. 0.81		Baghouse Airflow 529	
Overall Stoichiometry 1.14		Primary Air to Cyclone 400	
Reburning Fuel (%) 24.90		Tertiary Airflow N/A	
Air/Fuel @ Cyc. Atomizer 0.35		Total Secondary Air Flow 4178	
Atomizing Air @ Cyc. 132.20		Sec. Air to Cyclone 2512	
Load at Cyclone MBTU/hr 4.00		Sec. Air to Reburning Burner 140	
Load at Reburners MBTU/hr 1.32		OFA Flow 1601	
Total Load (MBTU/hr) 5.32		SA Mass Balance % 2	
Calc. Cyclone Fuel (lb/hr) 380		FGR Flow 101	
Meas. Cyclone Coal (lb/hr) 426		% FGR 1.99	
Total Flue Gas (lb/hr) 5121		Reburning Fuel Flow 126	
Air/Fuel @ RB Atomizer 0.79		Nat. Gas Flow N/A	
Fuel Analysis Basis as received		Channels (not all display)	
Carbon 59.37		1,2,3,4,5,9,11,12,13,14,	
Hydrogen 3.62		15,16,17,18,19,20,22,24,	
Sulfur 0.92		26,28,34,35,36,37,38,39,41	
Oxygen 2.50			
Nitrogen 1.02			
Ash 4.87			
Moisture 27.70			
sum 100.00		Atmospheric Pressure *Hg 29.0	
PC coal			
Ash 4.87		Baghouse dp *H2O 0.6	
Moisture 27.70		Baghouse st *H2O 0.3	
cyclone coal		Baghouse Temp (°F) 121.0	
Ash 4.87		FGR st *Hg 1.5	
Moisture 27.70		Tertiary Air st *H2O N/A	
Btu Value, Fuel at Cyclone 10514		Tertiary Air dp *H2O N/A	
Btu Value, Fuel at Reburner 10514		PA @ reburner St PSIG 0.0	
Lb dry air/Lb fuel, Cyclone 8.00		PA @ Reburner dp *H2O 0.0	
Lb dry air/Lb fuel at Reburner 8.00		PA @ Reburner temp (°F) 0.0	
Hum., Lbdair/Lbair(calc.) 0.9895			
Dry Bulb Temp. F 87.8765			
Wet Bulb Temp. F 67.8836			
Humidity Calculation(ALL CAL.)			
PBAR 14.2583			
TKELV 293.269			
BETA 354.001			
PDENOM 520.349			
PNUM 2067.45			
PSAT 0.3411			
HSAT 0.0152			
HNUM 11.2893			
HDENOM 1064.13			
HUM 0.0106			
HUMIDITY CORRECTION 0.9969			
Atom Air St PSIG 195.00		Atom Air dp *H2O 12.0	
NG st PSIG N/A		NG dp N/A	
Atom Air temp 95.0000		NG temp N/A	

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-27-1sr	Stack Oxygen, (%)	2.82
time 1800-1810hrs		Stack CO, (ppm)	29.5
All Flow Rates are in lb/hr		Stack NOx, (ppm)	347.2
Cyclone Stoichiometry	1.10	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.29	Primary Airflow	935
Reburning Zone Stoich.	0.89	Baghouse Airflow	503
Overall Stoichiometry	1.15	Primary Air to Cyclone	432
Reburning Fuel (%)	25.90	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.36	Total Secondary Air Flow	4210
Atomizing Air @ Cyc.	138.46	Sec. Air to Cyclone	2791
Load at Cyclone MBTU/hr	4.00	Sec. Air to Reburning Burner	155
Load at Reburners MBTU/hr	1.40	OFA Flow	1341
Total Load (MBTU/hr)	5.40	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	381	FGR Flow	449
Meas. Cyclone Coal (lb/hr)	426	% FGR	8.70
Total Flue Gas (lb/hr)	5206	Reburning Fuel Flow	133
Air/Fuel @ RB Atomizer	0.75	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.8
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	125.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9926		
Dry Bulb Temp. F	91.1829		
Wet Bulb Temp. F	64.4779		
Humidity Calculation(ALL CAL.)			
PBAR	14.1503		
TKELV	291.377		
BETA	355.893		
PDENOM	518.197		
PNUM	2085.43		
PSAT	0.3032		
HSAT	0.0136		
HNUM	7.9879		
HDENOM	1069.01		
HUM	0.0075		
HUMIDITY CORRECTION	0.9978		
Atom Air St PSIG	167.00	Atom Air dp "H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-27-21sr	Stack Oxygen, (%)	2.98
time 1346-1355hrs		Stack CO, (ppm)	32.6
All Flow Rates are in lb/hr		Stack NOx, (ppm)	352.0
Cyclone Stoichiometry	1.10	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.28	Primary Airflow	937
Reburning Zone Stoich.	0.90	Baghouse Airflow	503
Overall Stoichiometry	1.16	Primary Air to Cyclone	433
Reburning Fuel (%)	25.38	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	4244
Atomizing Air @ Cyc.	138.52	Sec. Air to Cyclone	2906
Load at Cyclone MBTU/hr	4.11	Sec. Air to Reburning Burner	85
Load at Reburners MBTU/hr	1.40	OFA Flow	1326
Total Load (MBTU/hr)	5.51	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	391	FGR Flow	737
Meas. Cyclone Coal (lb/hr)	426	% FGR	14.17
Total Flue Gas (lb/hr)	5259	Reburning Fuel Flow	133
Air/Fuel @ RB Atomizer	0.75	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels (not all display)	
Carbon	59.37	1,2,3,4,5,9,11,12,13,14,	
Hydrogen	3.62		
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70	26,28,34,35,36,37,38,39,41	
sum	100.00		
PC coal			
Ash	4.87	Atmospheric Pressure "Hg	29.1
Moisture	27.70	Baghouse dp "H2O	0.5
cyclone coal		Baghouse st "H2O	0.3
Ash	4.87	Baghouse Temp (°F)	125.0
Moisture	27.70	FGR st "Hg	1.5
Btu Value, Fuel at Cyclone	10514	Tertiary Air st "H2O	N/A
Btu Value, Fuel at Reburner	10514	Tertiary Air dP "H2O	N/A
Lb dry air/Lb fuel, Cyclone	8.00	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner cp "H2O	0.0
		PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair (calc.)	0.9940		
Dry Bulb Temp. F	90.4409		
Wet Bulb Temp. F	62.3610		
Humidity Calculation (ALL CAL.)			
PBAR	14.2976		
TKELV	290.201		
BETA	357.069		
PDENOM	516.852		
PNUM	2096.66		
PSAT	0.2815		
HSAT	0.0125		
HNUM	6.4826		
HDENOM	1070.79		
HUM	0.0061		
HUMIDITY CORRECTION	0.9982		
Atom Air St PSIG	167.00	Atom Air dp "H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-27-2sr	Stack Oxygen,(%)	2.67
time 13280-1340hrs		Stack CO,(ppm)	32.0
All Flow Rates are in lb/hr		Stack NOx,(ppm)	330.9
Cyclone Stoichiometry	1.07	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.28	Primary Airflow	934
Reburning Zone Stoich.	0.87	Baghouse Airflow	504
Overall Stoichiometry	1.14	Primary Air to Cyclone	430
Reburning Fuel (%)	25.07	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	4213
Atomizing Air @ Cyc.	138.51	Sec. Air to Cyclone	2832
Load at Cyclone MBTU/hr	4.18	Sec. Air to Reburning Burner	98
Load at Reburners MBTU/hr	1.40	OFA Flow	1366
Total Load (MBTU/hr)	5.58	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	398	FGR Flow	748
Meas. Cyclone Coal (lb/hr)	426	% FGR	14.45
Total Flue Gas (lb/hr)	5242	Reburning Fuel Flow	133
Air/Fuel @ RB Atomizer	0.75	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.8
PC coal		Baghouse dp *H2O	0.5
Ash	4.87	Baghouse st *H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	125.0
cyclone coal		FGR st *Hg	1.5
Ash	4.87	Tertiary Air st *H2O	N/A
Moisture	27.70	Tertiary Air dP *H2O	N/A
Btu Value,Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value,Fuel at Reburner	10514	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel,Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9963		
Dry Bulb Temp. F	92.0018		
Wet Bulb Temp. F	59.1152		
Humidity Calculation(ALL CAL.)			
PBAR	14.1503		
TKELV	288.397		
BETA	358.873		
PDENOM	514.778		
PNUM	2113.95		
PSAT	0.2509		
HSAT	0.0112		
HNUM	4.0119		
HDENOM	1074.73		
HUM	0.0037		
HUMIDITY CORRECTION	0.9989		
Atom Air St PSIG	167.00	Atom Air dp *H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM -- CWF TO CYCLONE AND REBURN BURNER

Test ID: 7-27-3sr		Stack Oxygen, (%) 2.73	
time 13280 - 1340hrs		Stack CO, (ppm) 34.0	
All Flow Rates are in lb/hr		Stack NOx, (ppm) 344.0	
Cyclone Stoichiometry 1.09		Atomizing air to Reburner 100	
Reburning Burner Stoich. 0.27		Primary Airflow 962	
Reburning Zone Stoich. 0.89		Baghouse Airflow 504	
Overall Stoichiometry 1.14		Primary Air to Cyclone 459	
Reburning Fuel (%) 24.71		Tertiary Airflow N/A	
Air/Fuel @ Cyc. Atomizer 0.34		Total Secondary Air Flow 4271	
Atomizing Air @ Cyc. 138.61		Sec. Air to Cyclone 2949	
Load at Cyclone MBTU/hr 4.26		Sec. Air to Reburning Burner 65	
Load at Reburners MBTU/hr 1.40		OFA Flow 1323	
Total Load (MBTU/hr) 5.66		SA Mass Balance % 2	
Calc. Cyclone Fuel (lb/hr) 405		FGR Flow 936	
Meas. Cyclone Coal (lb/hr) 426		% FGR 17.76	
Total Flue Gas (lb/hr) 5335		Reburning Fuel Flow 133	
Air/Fuel @ RB Atomizer 0.75		Nat. Gas Flow N/A	
Fuel Analysis Basis as received		Channels (not all display)	
Carbon 59.37		1,2,3,4,5,9,11,12,13,14,	
Hydrogen 3.62		15,16,17,18,19,20,22,24,	
Sulfur 0.92		26,28,34,35,36,37,38,39,41	
Oxygen 2.50			
Nitrogen 1.02			
Ash 4.87			
Moisture 27.70			
sum 100.00		Atmospheric Pressure "Hg 28.8	
PC coal			
Ash 4.87		Baghouse dp "H2O 0.5	
Moisture 27.70		Baghouse st "H2O 0.3	
cyclone coal		Baghouse Temp (°F) 125.0	
Ash 4.87		FGR st "Hg 2.4	
Moisture 27.70		Tertiary Air st "H2O N/A	
Btu Value, Fuel at Cyclone 10514		Tertiary Air dp "H2O N/A	
Btu Value, Fuel at Reburner 10514		PA @ reburner St PSIG 0.0	
Lb dry air/Lb fuel, Cyclone 8.00		PA @ Reburner dp "H2O 0.0	
Lb dry air/Lb fuel at Reburner 8.00		PA @ Reburner temp (°F) 0.0	
Hum., Lbdair/Lbair(calc.) 0.9963			
Dry Bulb Temp. F 92.0018			
Wet Bulb Temp. F 59.1152			
Humidity Calculation(ALL CAL.)			
PBAR 14.1503			
TKELV 288.397			
BETA 358.873			
PDENOM 514.778			
PNUM 2113.95			
PSAT 0.2509			
HSAT 0.0112			
HNUM 4.0119			
HDENOM 1074.73			
HUM 0.0037			
HUMIDITY CORRECTION 0.9989			
Atom Air St PSIG 167.00		Atom Air dp "H2O 15.0	
NG st PSIG N/A		NG dp N/A	
Atom Air temp 89.0000		NG temp N/A	

MAIN DATA REDUCTION PROGRAM -- CWF TO CYCLONE AND REBURN BURNER

Test ID:	7-27-4sr	Stack Oxygen, (%)	2.91
time 1615-1625hrs		Stack CO, (ppm)	34.1
All Flow Rates are in lb/hr		Stack NOx, (ppm)	288.6
Cyclone Stoichiometry	0.90	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.31	Primary Airflow	930
Reburning Zone Stoich.	0.79	Baghouse Airflow	503
Overall Stoichiometry	1.15	Primary Air to Cyclone	427
Reburning Fuel (%)	17.14	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	3803
Atomizing Air @ Cyc.	138.52	Sec. Air to Cyclone	2290
Load at Cyclone MBTU/hr	4.17	Sec. Air to Reburning Burner	103
Load at Reburners MBTU/hr	0.86	OFA Flow	1479
Total Load (MBTU/hr)	5.03	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	396	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	422	% FGR	N/A
Total Flue Gas (lb/hr)	4818	Reburning Fuel Flow	82
Air/Fuel @ RB Atomizer	1.22	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.8
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	125.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dp "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hurn., Lbdair/Lbair(calc.)	0.9940		
Dry Bulb Temp. F	91.8768		
Wet Bulb Temp. F	62.5678		
Humidity Calculation(ALL CAL.)			
PBAR	14.1503		
TKELV	290.315		
BETA	356.955		
PDENOM	516.984		
PNUM	2095.56		
PSAT	0.2836		
HSAT	0.0127		
HNUM	6.4261		
HDENOM	1071.23		
HUM	0.0060		
HUMIDITY CORRECTION	0.9982		
Atom Air St PSIG	167.00	Atom Air dp "H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

MAIN DATA REDUCTION PROGRAM – CWF TO CYCLONE AND REBURN BURNER

Test ID: 7-27-5sr		Stack Oxygen, (%)	2.77
time 1703-1712hrs		Stack CO, (ppm)	34.9
All Flow Rates are in lb/hr		Stack NOx, (ppm)	266.6
Cyclone Stoichiometry	0.80	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.27	Primary Airflow	928
Reburning Zone Stoich.	0.70	Baghouse Airflow	504
Overall Stoichiometry	1.15	Primary Air to Cyclone	425
Reburning Fuel (%)	19.68	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.35	Total Secondary Air Flow	3851
Atomizing Air @ Cyc.	138.59	Sec. Air to Cyclone	1969
Load at Cyclone MBTU/hr	4.12	Sec. Air to Reburning Burner	109
Load at Reburners MBTU/hr	1.01	OFA Flow	1846
Total Load (MBTU/hr)	5.13	SA Mass Balance %	2
Calc. Cyclone Fuel (lb/hr)	392	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	422	% FGR	N/A
Total Flue Gas (lb/hr)	4869	Reburning Fuel Flow	96
Air/Fuel @ RB Atomizer	1.04	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
		(not all display)	
Carbon	59.37	1,2,3,4,5,9,11,12,13,14,	
Hydrogen	3.62	15,16,17,18,19,20,22,24,	
Sulfur	0.92	26,28,34,35,36,37,38,39,41	
Oxygen	2.50		
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure "Hg	28.8
PC coal		Baghouse dp "H2O	0.5
Ash	4.87	Baghouse st "H2O	0.3
Moisture	27.70	Baghouse Temp (°F)	125.0
cyclone coal		FGR st "Hg	1.5
Ash	4.87	Tertiary Air st "H2O	N/A
Moisture	27.70	Tertiary Air dP "H2O	N/A
Btu Value, Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value, Fuel at Reburner	10514	PA @ Reburner dp "H2O	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner temp (°F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9959		
Dry Bulb Temp. F	93.2994		
Wet Bulb Temp. F	60.2621		
Humidity Calculation(ALL CAL.)			
PBAR	14.1503		
TKELV	289.034		
BETA	358.236		
PDENOM	515.513		
PNUM	2107.83		
PSAT	0.2614		
HSAT	0.0117		
HNUM	4.4736		
HDENOM	1074.16		
HUM	0.0042		
HUMIDITY CORRECTION	0.9988		
Atom Air St PSIG	167.00	Atom Air dp "H2O	15.0
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	89.0000	NG temp	N/A

EQUATION 1: - PERCENT ISOMINETIC
$$V_{IC} = 1.3 \text{ mV collected}$$

$$1.66 \times 10^6 \left[(0.00267 \times 10^6) + \frac{1.66 \times 10^6}{10^6} \right]$$

TO WHOM IT MAY CONCERN:

19

Number	10-2111	Date
--------	---------	------

Appendix D

MEASUREMENT ACCURACY AND UNCERTAINTY ANALYSIS

MEASUREMENT ACCURACY AND UNCERTAINTY ANALYSIS

The project was run according to the B&W Research Center Standard Practice Manual. This is a collection of administrative, safety, and quality assurance procedures. Although in this work a formal uncertainty analysis was neither requested nor performed, a brief discussion of measurement errors is included here. The main purpose of the pilot-scale tests was to show the feasibility of the technology. Thus, highly precise data was never an objective of the project. Still, normally accepted instrumentation and calibration procedures were used. Since an uncertainty analysis involves the consideration of uncertainties in all the measurements that go into a calculation, only a general discussion will be given here. The bulk of the plotted results involve NOx corrected to 3% oxygen as functions of load or various stoichiometries. Thus errors occur due to the NOx instrument, data acquisition system, combustion air static and differential pressures, air temperature, and fuel flow (to calculate load or stoichiometries). A set of calculations from a related investigation for the primary and secondary air flow rates (measured by orifice meters) for this test facility had been done previously. When an orifice meter is used as a flow measuring device, the actual flow rate is not measured directly. Instead, the mass flow rate is determined from an expression involving other measurable quantities, which in turn are influenced by inaccuracies. The relationship is :

$$m = C A [2g_c P \quad P/(R T)]^{1/2}$$

where, m = mass flow rate
C = discharge coefficient
A = flow area
P = pressure drop across the orifice
P = pressure upstream of orifice
R = gas constant
T = temperature upstream of orifice
g_c = gravitational constant

In the previously mentioned calculations, potential sources of inaccuracy associated with the individual parameters were identified and their overall contribution to the uncertainty of the primary and secondary air flow rates evaluated. The uncertainty in the primary and secondary air flow rates were calculated to be ± 3.27 and 4.08%, respectively. These are typical values for ASME designed orifices. All other instrumentation used in the measurements conformed to their manufacturer's specification for accuracy. Instrument calibrations are routinely conducted using NBS traceable standards and documented by our Instrument Section per the B&W Standard Practice Manual. All thermocouples are NBS traceable and expected to measure within ±5°F. An equipment list for this project, along with the corresponding B&W serial number is included in Appendix B.

The accuracy of the flue gas constituents depends in large part upon the calibration gases used. Linde Custom Grade calibration gases were used as noted in the equipment list. These gases are adequate for tests not involving EPA regulations compliance and are made to within ± 10% of each minor component

for the 50-9999 ppm component concentration range. Certification accuracy is within $\pm 2-5\%$ of each minor component.

The emissions instruments are state-of-the-art and have been used in a number of research programs. In general, they measure concentrations to within 1% of full scale. Particulate sampling, to determine unburned carbon, relies on isokinetic sampling, weighing a filter before and after sampling, and analyzing the collected particulate for carbon. This uses an ultimate analysis to derive the carbon after laboratory combustion. Calculation is necessary to convert the carbon in the ash to a heat loss out the combustor (by using the ash in the coal and the firing rate). Although a large number of measurements affect the unburned carbon accuracy, very high conversion levels were consistently measured with and without reburning.

Appendix E

SBS DATA ACQUISITION AND REDUCTION DISCUSSION

SBS Data acquisition and Reduction Discussion

An existing data acquisition system was set up to log, convert, and reduce the instrument signals. This feature provided near real time information regarding test conditions as well as performance data. Many features of a commercial data acquisition software program were utilized and a Lotus 123 spreadsheet was used to provide final results. The following discussion briefly describes the configuration and use of the system. It is also meant to show that the plotted results presented in this report are based upon a number of averaged data for each test condition.

A personal-computer-based data acquisition system was used for data logging and reduction. The system is shown schematically in Figure A-1. The heart of this system is a Keithley model 570 Scientific Work station with thermocouple and analog input boards. These boards receive analog input from system thermocouples and pressure transducers and output a digitized signal to the PC memory buffers. These transient data files can then be accessed by the software for flow calculations and storage of data. Additionally, signals from stack gas analyzers are monitored in the same manner and stored for later calculations. The system acquires enough process data to allow calculations and/or back-calculations of furnace load, cyclone stoichiometry, reburn zone stoichiometry, excess oxygen, all air flows as well as a mass balance check of these air flows, and natural gas fuel flowrates. Because the number of transducer signals required to monitor all process variables exceeded the number of available input channels on the Keithley system, some data was manually inputted. Process variables such as fan static pressures, barometric pressure, and atomizing air static pressure were placed in a reserved zone of the software and manually updated for each test prior to beginning formal test data acquisition. This compromise did not introduce a significant source of error since these process variables are relatively constant and have only a small effect on the accuracy of calculated flowrates.

Software consists of a version 4.1 (summer, 1987) of Labtech Notebook and Labtech Real Time Access (Laboratory Technologies Corp.) working under Microsoft DOS 3.3 and with Lotus 1,2,3. This software was chosen to provide a relatively user-friendly, easily changeable interface between the hardware and the extensively used data reduction software, Lotus 1,2,3. Changing hardware (adding or deleting pressure transducers, thermocouples, or gas analyzers) could be accommodated by changing Labtech Notebook parameters via menu-driven commands. Thus, after the initial "learning curve", configuring the system for other test programs does not require extensive reprogramming. This system was used in part on another similar reburning project and the experience helped identify both hardware and software problems.

The companion software program, Real-Time Access was used in conjunction with Labtech Notebook to provide near real time data processing with data logging in the background. This greatly speeded up the data reduction for setting test conditions. That is, fuel splits and stoichiometries could be checked and various flows and fuel rates adjusted to obtain the desired test condition. Without this feature, test conditions could only be approximated unless all data was taken manually and input manually to check conditions. This would have been a very time-consuming effort.

Matching all the temperature, emissions, and pressure input signals with the Labtech software is done by using a configuring program. This matches the signal inputs to the Keithley to the A/D board and PC. To check for possible drift in the transducers, daily zeroing was performed. This involved checking the zero signal and adjusting a constant in the signal/engineering unit calculation equation in the spreadsheet. This drift was within the manufacturers specification of $\pm 2\%$.

Some of the channels of the lab tech software can be used for signal processing such as calculating running averages. This feature was utilized for this project by averaging every 10 signals from each analog input. These running average signals are stored in transient memory buffers in the PC which are then converted to files. A Lotus macro was developed which is able to access these buffers while data acquisition is occurring and obtain the latest set of data each time the macro is run, or looped. This ASCII data is input to Lotus in a one-cell string and is then parsed by the macro to place the data for each process variable in a pre-selected cell location. This data is in the form of voltages and must be converted to engineering units prior to subsequent input to data reduction equations. Second order equations based on transducer calibration data are used to make these conversions. Zero checks of the transducers were normally made at least twice daily to assure that corrections for drift were made to minimize associated error. Thermocouple signals were reduced to engineering units in the Labtech software and imported to Lotus via the macro. Finally, these results are used in data reduction equations to calculate furnace load, combustion air flows, stoichiometries, and corrected emissions.

The use of the spreadsheet to log, reduce, and calculate results is illustrated in the screen printouts which follow. The first 4 pages list the 4 main data reduction programs that take converted, averaged data (in engineering units) and calculates air flows, stoichiometries, furnace load, etc. This real-time reduced data is used to determine if a desired test condition has been achieved. If so, a formal set of data is taken, otherwise fine tuning of air splits on full flows is made accordingly and the results checked again on the data acquisition system to verify that desired conditions are met. The test number is given at the upper left and may be checked against the tabulated results shown elsewhere in Appendix C. On the next two pages, the averaged temperatures and analog signals as they are entered and parsed by the Lotus macro are shown. The program to perform a second order polynomial calibration curve fit for the transducers is given next (spreadsheet location I62-U75). These equations convert the averaged voltages to engineering units. The next two pages list the equations used for calculating the air flows, stoichiometries, etc. The next two pages list the main macro, and finally, the last page lists a macro which was used to consolidate and tabulate selected information from several files into a single file for comparative purposes such as sorting and graphing.

MAIN DATA REDUCTION PROGRAM - N.G. TO CYCLONE, CWF TO REBURN BURNER

Test ID:	7-03-1SR	Stack Oxygen,(%)	2.90
time 1400-1410		Stack CO,(ppm)	29.7
All Flow Rates are in lb/hr		Stack NOx,(ppm)	198.3
Cyclone Stoichiometry	1.03	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.32	Primary Airflow	959
Reburning Zone Stoich.	0.87	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	480
Reburning Fuel (%)	21.91	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	N/A	Total Secondary Air Flow	3907
Atomizing Air	N/A	Sec. Air to Cyclone	2593
Load at Cyclone MBTU/hr	4.12	Sec. Air to Reburning Burner	183
Load at Reburners MBTU/hr	1.16	OFA Flow	1013
Total Load (MBTU/hr)	5.28	SA Mass Balance %	-3
Calc. Cyclone Fuel (lb/hr)	184	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	N/A	% FGR	N/A
Total Flue Gas (lb/hr)	4631	Reburning Fuel Flow	110
Air/Fuel @ RB Atomizer	0.91	Nat. Gas Flow	158.35
		Channels	
Fuel Analysis Basis as received		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.8
PC coal			
Ash	4.87	Baghouse dp *H2O	0.5
Moisture	27.70	Baghouse st *H2O	0.3
cyclone coal		Baghouse Temp (*F)	120.0
Ash	0.00	FGR st *Hg	1.5
Moisture	0.00	Tertiary Air st *H2O	4.5
Btu Value,Fuel at Cyclone	22370	Tertiary Air dP *H2O	0.3
Btu Value,Fuel at Reburner	10514	PA @ reburner St PSIG	0:0
Lb dry air/Lb fuel,Cyclone	16.03	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel at Reburner	8.00	PA @ Reburner temp (*F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9910		
Dry Bulb Temp. F	95.2969		
Wet Bulb Temp. F	67.9669		
Humidity Calculation(ALL CAL.)			
PBAR	14.1257		
TKELV	293.315		
BETA	353.955		
PDENOM	520.401		
PNUM	2067.01		
PSAT	0.3421		
HSAT	0.0154		
HNUM	9.7301		
HDENOM	1067.34		
HUM	0.0091		
HUMIDITY CORRECTION	0.9973		
Atom Air St PSIG	95.50	Atom Air dp *H2O	15.8
NG st PSIG	30.0000	NG dp	39.37
Atom Air temp	86.0000	NG temp	88.57

MAIN DATA REDUCTION PROGRAM - BASELINE TESTS

Test ID:	6-20-1b	Stack Oxygen, (%)	2.90
time 16:45hrs - 17:00hrs		Stack CO, (ppm)	26.1
All Flow Rates are in lb/hr		Stack NOx, (ppm)	996.9
Cyclone Stoichiometry	1.16	Pri. air to Reburner	N/A
Reburning Burner Stoich.	N/A	Primary Airflow	1181
Reburning Zone Stoich.	N/A	Baghouse Airflow	606
Overall Stoichiometry	1.16	Primary Air to Cyclone	575
Reburning Fuel (%)	N/A	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.2575	Total Secondary Air Flow	4420
Atomizing Air	138.10	Sec. Air to Cyclone	4288
Load at Cyclone MBTU/hr	5.64	Sec. Air to Reburning Burner	N/A
Load at Reburners MBTU/hr	N/A	OFA Flow	N/A
Total Load (MBTU/hr)	5.64	SA Mass Balance %	N/A
Calc. Cyclone Coal (lb/hr)	795	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	330	% FGR	N/A
Total Flue Gas (lb/hr)	5714	Reburning Coal Flow	0
		Nat. Gas Flow	N/A
		Channels	
Fuel Analysis Basis as received		(not all display)	
Carbon	59.37		
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.5
PC coal			
Ash	N/A	Baghouse dp *H2O	0.7
Moisture	N/A	Baghouse st *H2O	0.5
cyclone coal		Baghouse Temp (*F)	105.0
Ash	4.87	FGR st *Hg	1.5
Moisture	27.70	Tertiary Air st *H2O	4.5
Btu Value, Fuel at Cyclone	10514	Tertiary Air dp *H2O	0.3
Btu Value, Fuel at Reburner	22370	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel, Cyclone	8.00	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel at Reburner	16.03	PA @ Reburner temp (*F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9926		
Dry Bulb Temp. F	94.0379		
Wet Bulb Temp. F	65.1898		
Humidity Calculation(ALL CAL)			
PBAR	14.0177		
TKELV	291.772		
BETA	355.498		
PDENOM	518.648		
PNUM	2081.66		
PSAT	0.3108		
HSAT	0.0141		
HNUM	7.9801		
HDENOM	1069.56		
HUM	0.0075		
HUMIDITY CORRECTION	0.9978		
Atom Air St PSIG	156.00	Atom Air dp *H2O	16.0
NG st PSIG	30.0000	NG dp	0.0000
Atom Air temp	93.0000	NG temp	87.62

MAIN DATA REDUCTION PROGRAM – NATURAL GAS REBURNING TEST

Test ID:	6-28-1GR	Stack Oxygen,(%)	2.90
time 1520-1530		Stack CO,(ppm)	26.0
All Flow Rates are in lb/hr		Stack NOx,(ppm)	355.0
Cyclone Stoichiometry	1.02	Atomizing air to Reburner	N/A
Reburning Burner Stoich.	0.23	Primary Airflow	878
Reburning Zone Stoich.	0.86	Baghouse Airflow	479
Overall Stoichiometry	1.15	Primary Air to Cyclone	400
Reburning Fuel (%)	20.85	Tertiary Airflow	N/A
Air/ Fuel @ Cyc. Atomizer	0.3143	Total Secondary Air Flow	4614
Atomizing Air	137.99	Sec. Air to Cyclone	3077
Load at Cyclone MBTU/hr	4.62	Sec. Air to Reburning Burner	205
Load at Reburners MBTU/hr	1.22	OFA Flow	1262
Total Load (MBTU/hr)	5.83	SA Mass Balance %	-2
Calc. Cyclone Coal (lb/hr)	439	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	445	% FGR	N/A
Total Flue Gas (lb/hr)	5367	Reburning Coal Flow	0
Air/Fuel @ RB Atomizer	N/A	Nat. Gas Flow	54.36
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92		
Oxygen	2.50	15,16,17,18,19,20,22,24,	
Nitrogen	1.02	26,28,34,35,36,37,38,39,41	
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	29.0
PC coal			
Ash	N/A 8.14	Baghouse dp *H2O	0.5
Moisture	N/A 6.8	Baghouse st *H2O	0.3
cyclone coal		Baghouse Temp (°F)	120.0
Ash	4.87	FGR st *Hg	N/A
Moisture	27.70	Tertiary Air st *H2O	4.5
Btu Value,Fuel at Cyclone	10514	Tertiary Air dP *H2O	0.3
Btu Value,Fuel at Reburner	22370	PA @ reburner St PSIG	0.0
Lb dry air/Lb fuel,Cyclone	8.00	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel at Reburner	16.03	PA @ Reburner temp (°F)	0.0
Hum., Lbdair/Lbair(calc.)	0.9872		
Dry Bulb Temp. F	92.0000		
Wet Bulb Temp. F	72.0000		
Humidity Calculation(ALL CAL.)			
PBAR	14.2583		
TKELV	295.556		
BETA	351.714		
PDENOM	522.928		
PNUM	2045.86		
PSAT	0.3925		
HSAT	0.0176		
HNUM	13.7370		
HDENOM	1061.85		
HUM	0.0129		
HUMIDITY CORRECTION	0.9962		
Atom Air St PSIG	167.00	Atom Air dp *H2O	15.0
NG st PSIG	37.0000	NG dp	4.0500
Atom Air temp	91.0000	NG temp	95.00

MAIN DATA REDUCTION PROGRAM - CWF TO CYCLONE & REBURN BURNER

Test ID:	7-22-1SR	Stack Oxygen,(%)	2.81
time 1445-1515hrs		Stack CO,(ppm)	30.4
All Flow Rates are in lb/hr		Stack NOx,(ppm)	413.1
Cyclone Stoichiometry	1.09	Atomizing air to Reburner	100
Reburning Burner Stoich.	0.24	Primary Airflow	946
Reburning Zone Stoich.	0.88	Baghouse Airflow	504
Overall Stoichiometry	1.15	Primary Air to Cyclone	443
Reburning Fuel (%)	24.52	Tertiary Airflow	N/A
Air/Fuel @ Cyc. Atomizer	0.34	Total Secondary Air Flow	4353
Atomizing Air @ Cyc.	134.78	Sec. Air to Cyclone	2941
Load at Cyclone MBTU/hr	4.18	Sec. Air to Reburning Burner	151
Load at Reburners MBTU/hr	1.36	OFA Flow	1320
Total Load (MBTU/hr)	5.53	SA Mass Balance %	1
Calc. Cyclone Fuel (lb/hr)	397	FGR Flow	N/A
Meas. Cyclone Coal (lb/hr)	430	% FGR	N/A
Total Flue Gas (lb/hr)	5337	Reburning Fuel Flow	129
Air/Fuel @ RB Atomizer	0.78	Nat. Gas Flow	N/A
Fuel Analysis Basis as received		Channels	
Carbon	59.37	(not all display)	
Hydrogen	3.62	1,2,3,4,5,9,11,12,13,14,	
Sulfur	0.92	15,16,17,18,19,20,22,24,	
Oxygen	2.50	26,28,34,35,36,37,38,39,41	
Nitrogen	1.02		
Ash	4.87		
Moisture	27.70		
sum	100.00	Atmospheric Pressure *Hg	28.9
PC coal		Baghouse dp *H2O	0.5
Ash	4.87	Baghouse st *H2O	0.4
Moisture	27.70	Baghouse Temp (*F)	121.0
cyclone coal		FGR st *Hg	1.5
Ash	4.87	Tertiary Air st *H2O	4.5
Moisture	27.70	Tertiary Air dP *H2O	0.3
Btu Value,Fuel at Cyclone	10514	PA @ reburner St PSIG	0.0
Btu Value,Fuel at Reburner	10514	PA @ Reburner dp *H2O	0.0
Lb dry air/Lb fuel,Cyclone	8.00	PA @ Reburner temp (*F)	0.0
Lb dry air/Lb fuel at Reburner	8.00		
Hum., Lbdair/Lbair(calc.)	0.9858		
Dry Bulb Temp. F	94.0712		
Wet Bulb Temp. F	74.1599		
Humidity Calculation(ALL CAL.)			
PBAR	14.1847		
TKELV	296.755		
BETA	350.515		
PDENOM	524.272		
PNUM	2034.59		
PSAT	0.4220		
HSAT	0.0191		
HNUM	15.2804		
HDENOM	1060.61		
HUM	0.0144		
HUMIDITY CORRECTION	0.9958		
Atom Air St PSIG	195.00	Atom Air dp *H2O	12.5
NG st PSIG	N/A	NG dp	N/A
Atom Air temp	95.0000	NG temp	N/A

FORMATLINE																
INPUTCELL																
OUTPUTCELLS																
Channel																
Description																
PA TEMP	SA TEMP	RB TEMP	OFA TEMP	SAC TEMP	TAST volts	PAST volts	SAST volts	RBst volts	OFAst volts	SACst volts	PADp volts	SADp volts				
1	2	3	4	5	9	11	12	13	14	15	16	17				
145.6657	143.4255	120.8432	228.8169	744.6451	0.9917	2.6380	3.0044	3.9424	1.6170	1.5681	2.3928	2.4680				
145.6657	144.5888	119.8557	227.8198	743.6007	0.9917	2.6429	3.0142	3.8251	1.5877	1.5486	2.3937	2.4621				
145.6657	143.5121	119.8557	227.8198	744.6451	0.9917	2.6331	3.0044	3.8153	1.5877	1.5486	2.3937	2.4658				
145.6657	144.5888	119.8557	228.9041	744.6451	0.9917	2.6331	3.0044	3.8251	1.5877	1.5584	2.3864	2.4641				
145.6657	141.3589	119.8557	228.9041	744.6451	0.9917	2.6429	3.0044	3.7958	1.5877	1.5486	2.3874	2.4641				
146.7428	143.4255	120.9296	228.6484	744.6451	0.9917	2.6331	3.0044	3.8153	1.5877	1.5486	2.3908	2.4680				
146.7428	143.5121	120.8432	227.8198	744.6451	0.9917	2.6331	3.0142	3.8202	1.5877	1.5584	2.3918	2.4680				
146.7428	145.6657	120.9296	227.8198	744.6451	0.9917	2.6429	3.0044	3.7860	1.5877	1.5486	2.3937	2.4680				
145.6657	144.5022	120.8432	227.8198	744.6451	0.9917	2.6331	3.0044	3.7763	1.5779	1.5486	2.3977	2.4690				
146.6561	145.5791	121.9173	228.8169	745.6895	0.9917	2.6429	3.0044	3.7958	1.5779	1.5486	2.3977	2.4690				
145.6657	143.4255	120.8432	228.8169	744.6451	0.9917	2.6380	3.0044	3.9424	1.6170	1.5681	2.3928	2.4680				
145.6657	143.4255	120.8432	228.8169	744.6451	0.9917	2.6380	3.0044	3.9424	1.6170	1.5681	2.3928	2.4680				
AVERAGE																

1.0112	1.0015	2.5048	1.0015	2.8969	28.0748	998.8858	65.1898	94.0379	114.4883	88.6875	87.6179	111.2695	1.0503
18	19	20	22	24	26	28	34	35	36	37	38	39	41
RBdp_volts	OFAdp_volts	SACdp_volts	FGAdp_volts	O2(%lavg	CO(ppm)avg	NOx(ppm)avg	Wet Bulb	Dry Bulb F	SA@Reburn F	FOR F	N.Q. °F	TA Temp	N.Q. dp
1.0161	0.9966	2.4719	1.0015	3.1058	27.2350	999.3285	64.2092	89.8434	113.4152	87.7039	87.7039	109.1243	1.0454
1.0137	1.0015	2.4963	1.0015	3.0447	27.2350	1000.8551	64.2092	90.9133	113.4152	88.7736	87.7039	109.1243	1.0454
1.0112	1.0015	2.4949	1.0015	2.8894	28.7989	1004.8243	66.3421	94.1240	113.4152	88.7736	87.7039	109.1243	1.0484
1.0112	0.9966	2.5007	1.0015	2.8819	28.7465	1002.9923	65.2756	94.1240	113.4152	87.7039	87.7039	109.1243	1.0489
1.0122	0.9966	2.4919	1.0010	2.8762	28.6244	995.8645	65.2756	89.8434	113.4152	88.6875	87.7039	110.1968	1.0503
1.0122	0.9966	2.4929	1.0010	2.8945	28.7465	998.1071	64.2092	91.9834	114.4883	87.7039	87.7039	110.1968	1.0503
1.0112	0.9917	2.4885	1.0015	2.9195	28.8687	997.4965	65.2756	91.9834	114.4020	88.7736	87.7039	110.1968	1.0503
1.0112	1.0015	2.5183	1.0015	2.9146	28.1969	1005.4349	66.2563	92.9675	114.4883	88.6875	88.7736	110.1968	1.0503
1.0112	1.0015	2.5164	1.0015	2.8378	28.1359	1004.8243	65.1898	91.8973	114.4020	88.7573	88.7573	111.2695	1.0503
1.0112	1.0015	2.5046	1.0015	2.8969	28.0748	998.8858	65.1898	94.0379	114.4883	88.6875	87.6179	111.2695	1.0503
1.0112	1.0015	2.5048	1.0015	2.8969	28.0748	998.8858	65.1898	94.0379	114.4883	88.6875	87.6179	111.2695	1.0503

MAIN PROGRAM LISTING

```

B7: (F2) [W8] (E10+E13+B13)*$B$42/(B14*10^6/B37*B39)
B8: (F2) [W8] ((E14+E7)*$B$42+E17*E3/21)/(E19*$B$40)
B9: (F2) [W8] ((E10+E13+E14+E7)*$B$42+E17*E3/21)/(B14*10^6/B37*B39+E19*B40)
B10: (F2) [W8] ((1-$B$11/100)*(100-(5.34195)*E3/(1.14895-0.05469*E3)))+(88$11/100)*(100+89.1*$E$3/(20.8-0.99*$E$3)))/100
B11: (F2) [W8] 100*B15/B16
B12: (F2) [W8] ' N/A +B13/(B14*10^6/B37)
B13: (F2) [W8] ' N/A ASORT(((($B$59)+14.7)*((($E$59/($B$61+460)))))*62.28*$B$56
B14: (F2) [W8] ((E10+E12+E7)*$B$42/(1+E3/(21-E3))-E19*B40)/B39*B37/10^6
B15: (F2) [W8] +E19*B38/10^6
B16: (F2) [W8] +B14+B15
B17: (F0) [W8] +B14/B37*10^6*100/(100-$B$35-$B$36)
B18: (F0) [W8] " N/A 158.35
B19: (F0) [W8] (E7+E10+E11+E12)*$B$42+(B17*(100-$B$35))/100
B20: (F2) [W8] +E7/(B15*10^6/B38)
B23: (F2) [W8] 59.37
B24: (F2) [W8] 3.62
B25: (F2) [W8] 0.92
B26: (F2) [W8] 2.5
B27: (F2) [W8] 1.02
B28: (F2) [W8] 4.87
B29: (F2) [W8] 27.7
B30: (F2) [W8] SUM(B23..B29)
B32: (F2) [W8] 4.87
B33: (F2) [W8] 27.7
B35: (F2) [W8] 0
B36: (F2) [W8] 0
B37: (F0) [W8] 22370
B38: (F0) [W8] 10514
B39: (F2) [W8] 16.03
B40: (F2) [W8] 8
B42: (F4) [W8] 1/(1+B55)
B43: (F4) [W8] +AD3
B44: (F4) [W8] +AC3
B46: (F4) [W8] +E30/2.036
B47: (F3) [W8] (B44+460)/1.8
B48: (F3) [W8] 647.27-B47
B49: (F3) [W8] +B47*(1+2.1873/1000*B48)
B50: (F2) [W8] +B48*(3.2438+5.8683/1000*B48+0.000000117*B48^3)
B51: (F4) [W8] 14.7*218.167*10^(-B50/B49)
B52: (F4) [W8] 0.62198*B51/(B46-B51)
B53: (F4) [W8] (1093-0.556*B44)*B52-0.24*(B43-B44)
B54: (F2) [W8] 1093+0.444*B43-B44
B55: (F4) [W8] +B53/B54
B56: (F4) [W8] ASORT(1/(1/28.85+B55/18.02)*(1+B55)/28.85)
B59: (F2) [W8] 95.5
B60: [W8] 30
B61: [W8] 86

```

E3: (F2) (W7) +Z3
E4: (F1) (W7) +AA3
E5: (F1) (W7) +AB3
E6: (W7) !-----
E7: (F0) (W7) 100
E8: (F0) (W7) @SORT(((N65/2.036)+14.7)*((N70/(OUTPUTCELLS+460))))*6544.86*\$8\$56
E9: (F0) (W7) @SORT(((N65/2.036)+14.7)*((N70/(OUTPUTCELLS+460))))*4496.57*\$8\$56
E10: (F0) (W7) +E8-E9
E11: (F0) (W7) " N/A @SORT(((E36/2.036)+14.7)*((E37/(AK3+460))))*399.57*\$8\$56
E12: (F0) (W7) @SORT(((N66/2.036)+14.7)*((N71/(J3+460))))*10794.93*\$8\$56
E13: (F0) (W7) @SORT(((N69/2.036)+14.7)*((N75/(M3+460))))*13883.35*\$8\$56
E14: (F0) (W7) @SORT(((N67/2.036)+14.7)*((N72/(AE3+460))))*2291.05*\$8\$56
E15: (F0) (W7) @SORT(((N68/2.036)+14.7)*((N73/(L3+460))))*7786.75*\$8\$56
E16: (F0) (W7) ((E13+E14+E15)-E12)/E12*100
E17: (F0) (W7) " N/A @SORT(((E35/2.036)+14.7)*((N76/(AF3+460))))*3364.204
E18: (F2) (W7) " N/A +E17/(e10+e12+b14*10^-6/b37+b15*10^-6/b38)*100
E19: (F0) (W7) 110
E20: (F2) (W7) @SORT(((N8\$60)+E30/2.036)*((N74/(AG3+460))))*88.98
E23: (W7) "
E30: (F1) (W7) 28.76
E32: (F1) (W7) 0.45
E33: (F1) (W7) 0.3
E34: (F1) (W7) 120
E35: (F1) (W7) 1.5
E36: (F1) (W7) +W65
E37: (F1) (W7) 0.3
E38: (F1) (W7) 0
E39: (F1) (W7) 0
E40: (F1) (W7) 0
E43: (W7) 'LIMESTONE
E44: (F0) (W7) 4
E45: (F0) (W7) 70
E46: (F1) (W7) 10
E47: (F2) (W7) 5
E48: (F0) (W7) 0.687*@SORT(14.7*144*28.9/(1545*(E45+460))))*60
E49: (F0) (W7) +E48+E44*60*(14.7*144*28.9)/(1545*(460+70))*@SORT((70+460)*(E46+14.7)/((E45+460)*14.7))
E50: (F1) (W7) +E49/(E7+E10+E11+E12)*100
E59: (F1) (W7) 15.8
E60: (F2) (W7) +W74
E61: (F2) (W7) +AG3

```

GETDATA    {}
           {writeln "MODE LAR"}
           {calo}
           {writeln "SELECT 1,2,3,4,5,9,11,12,13,14,15,16,17,18,19,20,22,24,26,28,34,35,36,37,38,39,41"}
           {readln INPUTCELL}
           {goto}INPUTCELL~
           {edit}{bs}{bs}~
           /dpfc
           l.{down}~
           oOUTPUTCELLS~
           g
           /wdr~
           {return}

```

```

INITIALIZE {}
           {indicate SBS}
           {paneloff}
           {windowsoff}
           /wgrm
           {open RTA,W}
           {return}

```

```

\B         {}
           {INITIALIZE}
B10DONEXT  {}
           {GETDATA}
           {REFRESH}
           {INITIALIZE}
           {SAVEDATA}
           {panelon}
           {getlabel "E to Exit, <CR> to Continue - ",B00CONTINUE}
           {paneloff}
           {if B00CONTINUE=""}{branch B10DONEXT}
           {REFRESH}
           {close}
           {quit}

```

REFRESH {}
/wgra
{calo}
{goto}{home} ~
{panelon}
{windowson}
{indicate}
{return}

3
SAVEDATA {}
{goto}DATA ~
/cDATA ~ {down}{end}{down}{down} ~
{return}

ENTER SUBDIRECTORY OF FILES

\D

```
{GOTO}A71 ~ ENTER SUBDIRECTORY OF FILES ~ {UP}{?} ~
/CA70 ~ B76 ~ /CA70 ~ B79 ~ /CA70 ~ B82 ~ /CA70 ~ B85 ~ /CA70 ~ B88 ~
{GOTO}A111 ~ /FIN
tr1
\CALC ~
{GOTO}L111 ~ /FIN
tr1
\GAS ~
{GOTO}P111 ~ /FIN
tr1
\PSA ~
{GOTO}W111 ~ /FIN
tr1
\RBOFA ~
{GOTO}AD111 ~ /FIN
tr1
\SACFGR ~
{GOTO}A100 ~ @AVG(A116..A1116) ~
/C ~ B100..A100 ~ /RVA100..A100
~ A100 ~ /rea110..a1116 ~
/cj100 ~ ah3 ~ /cl100 ~ y3 ~ /cm100 ~ z3 ~ /cn100 ~ aa3 ~
/cp100 ~ l3 ~ /cq100 ~ s3 ~ /cr100 ~ n3 ~ /cs100 ~ j3 ~
/ct100 ~ t3 ~ /cu100 ~ o3 ~ /cx100 ~ u3 ~ /cy100 ~ p3 ~
/cz100 ~ l3 ~ /caa100 ~ v3 ~ /cab100 ~ q3 ~ /cad100 ~ m3 ~
/cae100 ~ w3 ~ /caf100 ~ r3 ~ /cag100 ~ ae3 ~ /cah100 ~ x3 ~
```

END

**DATE
FILMED**

7 / 29 / 92