Final Report

**DOE/PC/88851-T1
(DE92010988)**

**SCALEUP TESTS AND SUPPORTING RESEARCH FOR THE DEVELOPMENT OF
DUCT INJECTION TECHNOLOGY**

Topical Report No. 1 Literature Review

By

**John P. Gooch
Edward B. Dismukes
Robert S. Dahlin
M. Gregory Faulkner
Michael G. Klett
Thomas L. Buchanan
John E. Hunt**

May 1989

Work Performed Under Contract No. AC22-88PC88851

For

**U.S. Department of Energy
Pittsburgh Energy Technology Center
Pittsburgh, Pennsylvania**

By

**Southern Research Institute
Birmingham, Alabama**

and

**Gilbert/Commonwealth, Inc.
Reading, Pennsylvania**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U. S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

**SCALEUP TESTS AND SUPPORTING RESEARCH
FOR THE DEVELOPMENT OF DUCT INJECTION
TECHNOLOGY**

**TOPICAL REPORT NO.1
LITERATURE REVIEW**

Presented to

U. S. Department of Energy

Pittsburgh, PA

by

Southern Research Institute

**John P. Gooch, Edward N. Dismukes, Robert S. Dahlin, and
M. Gregory Faulkner**

and

Gilbert/Commonwealth, Inc.

Michael G. Klett, Thomas L. Buchanan, and John E. Hunt

May, 1989

MASTER

CONTENTS

	<u>Page</u>
Executive Summary.....	E-1
1.0 Introduction.....	1-1
1.1 Process Description.....	1-1
1.2 Description of Key Issues.....	1-4
1.2.1 Chemical and physical processes.....	1-4
1.2.2 Engineering issues.....	1-16
2.0 Review of Previous Work.....	2-1
2.1 Scope.....	2-1
2.2 DOE-Sponsored Proof-of-Concept Tests.....	2-2
2.2.1 Bechtel National, Inc.....	2-2
2.2.2 Dravo Engineering.....	2-3
2.2.3 General Electric Environmental Services.....	2-3
2.3 Thermodynamic Compilations and Analyses.....	2-4
2.3.1 Equilibria of calcium sulfite and calcium sulfate with their hydrates.....	2-6
2.3.2 Equilibria between SO ₂ and calcium-based sorbents.....	2-8
2.3.3 Adiabatic humidification of flue gas.....	2-11
2.3.4 Adsorption and condensation of water vapor on solid sorbents.....	2-14
2.3.5 Solubilities of SO ₂ and Ca(OH) ₂ in water.....	2-22
2.3.6 Ion dissociation and precipitation processes.....	2-24
2.4 Kinetic Studies.....	2-32
2.4.1 Chemical forms of sorbent	2-32
2.4.2 Physical properties of sorbent.....	2-40
2.4.3 Methods of humidification.....	2-43
2.4.4 Control of Ca/S mole ratio.....	2-53
2.5 Review of Mathematical Models.....	2-55
2.5.1 Removal of SO ₂ with sorbent.....	2-55
2.5.2 Removal of solids by electrostatic precipitation.....	2-82
2.6 Economic Evaluation.....	2-86
2.6.1 Process comparison.....	2-87
2.6.2 Cost comparisons.....	2-87
3.0 Research Needs and Project Objectives.....	3-1

CONTENTS (Continued)

	<u>Page</u>
3.1 Test Program.....	3-1
3.1.1 Enhanced data development (Task 3).....	3-2
3.1.2 Mathematical model validation (Task 4).....	3-3
3.2 Existing Test Facility and Planned Modificaitons.....	3-4
4.0 Annotated Bibliography of Selected References.....	4-1
5.0 References Cited.....	5-1

EXECUTIVE SUMMARY

INTRODUCTION

This literature review and analysis report has been prepared as a part of a Department of Energy Project entitled "Scaleup Tests and Supporting Research for the Development of Duct Injection Technology". This program is a part of a larger DOE program to fully characterize low cost, retrofittable SO₂ removal technologies.

Duct injection technology is an SO₂ removal process that is intended to provide a simple, cost effective method to satisfy possible future regulations designed to control acid rain precursors. The technology is expected to be installed primarily at older power stations that are not subject to regulation under New Source Performance Standards. Performance goals for the process are to achieve a minimum of 50% SO₂ removal at a cost not to exceed \$500/ton of SO₂ removed.

Gilbert Commonwealth (G/C), Southern Research Institute (SRI) and the American Electric Power Service Corporation have embarked on a program to convert DOE's Duct Injection Test Facility located at the Muskingum River Power Plant of Ohio Power Company to test alternate duct injection technologies. The technologies to be tested include slurry sorbent injection of hydrated lime using dual fluid nozzles, or a rotary atomizer and pneumatic injection of hydrated lime, with flue gas humidification before or after sorbent injection. The literature review and analysis contained in this report is a part of the preparatory effort for the test program.

BACKGROUND

In a duct injection process, the sorbent will be injected in a finely divided suspended state (either as a dry powder or as a slurry) downstream of the air preheater, and will be expected to undergo most of its reaction with SO₂ in the suspended state prior to collection in the electrostatic precipitator (ESP). An essential aspect of successfully using a calcium based sorbent

in this environment is that the sorbent must be activated with an elevated concentration of water vapor, or more likely, it must be activated by physical contact with liquid water. Only a dry solid, however, is intended to reach the ESP; evaporation from the slurry or the plain water spray must occur before the gas stream reaches the ESP.

The principal development of wet sorbent injection in ducts has come from two contractors working under DOE sponsorship. Bechtel has advanced the use of slurry injection through a two fluid nozzle; General Electric, in contrast, has promoted the use of a rotary atomizer. CONSOL (Consolidated Coal Company) is a proponent of dry injection of calcium hydroxide with downstream injection of a water spray. Consol is now working under partial DOE sponsorship on a demonstration of this process. Dravo Lime Company, also under DOE sponsorship, is the other principal advocate of dry injection and has evaluated both upstream and downstream water sprays for humidification. Dravo, however, primarily employed the downstream spray at the larger-scale demonstration of the dry process.

A survey of duct configurations in U.S. power stations has been performed to obtain a clear idea of the constraints under which duct injection technology must operate. The physical dimensions of the ducts and the gas velocity are critical to the success of a duct injection process. The extent of deposition of dry or wet sorbent on walls surrounding the injection points must be minimized. In addition, the time of transit of the gas stream from the point of water or slurry injection must be long enough to allow complete droplet evaporation to occur, and, during the same time interval, allow most of the required SO_2 removal to occur. A consideration of both duct lengths and gas velocities indicates that, in half of the ducts surveyed, the drying time available will be less than 1.0 second. This limitation indicates the rate at which SO_2 removal must proceed when the sorbent is injected in a slurry. It also imposes significant constraints on dry injection accompanied by spray humidification; it imposes a maximum on the spray droplet size of about 60 microns and requires that both collision of droplets and sorbent particles and chemical reaction be complete in less than one second.

DESCRIPTION OF KEY ISSUES

An appropriate starting point for the literature review is the identification of key issues to examine in the process development effort. These issues have been categorized as follows:

Chemical and Physical Processes

Removal of SO₂. Factors that control the extent of SO₂ removal may be discussed from a fundamental point of view within the following categories:

- chemical thermodynamics
- chemical kinetics
- mass transfer

A review of available information indicates that the limiting processes which pertain to duct injection technology are more in the realm of mass transfer than chemical kinetics or chemical thermodynamics. The experimental program to be performed under this project is designed to quantify SO₂ removal rates under a number of process modes, and to identify to the extent possible the operative reaction mechanisms and limiting processes under practical operating conditions.

Removal of Solids. An ESP is the dust control device of main concern with respect to duct injection of sorbent as a retrofit technology. Many of the ESPs at potential duct injection application sites are relatively small in size and marginal in performance. Some type of performance upgrading technology, therefore, is likely to be required. The test program is designed to quantify the impact of duct injection on ESP performance under a variety of circumstances. In the event that serious collection efficiency limitations are observed, provisions for evaluating ESP upgrading strategies are contained within the advanced configurations portion of the test program.

Engineering Issues.

Since the project under which this literature review was conducted is concerned primarily with scale-up of bench and pilot experimental results, it is important to establish a linkage between process fundamentals and engineering issues. The following listing indicates key process and mechanical engineering issues which must be addressed in the process development effort.

Process issues include selection of approach temperature, designing for allowable residence time, maximizing sorbent utilization, minimizing duct wetting and solids deposition, selecting a reliable process control system, selecting a reactive but economically feasible sorbent source, and providing for an acceptable disposal method for process wastes.

Mechanical engineering issues include design of a lime receiving/storage system, design of sorbent slurring and injection system, or a dry injection/humidification system, design of a duct cleaning system and ash collection/recycle system, providing an adequate compressed air source, and providing the engineering for possible ESP modifications or upgrading.

REVIEW OF PREVIOUS WORK

Scope

A review of previous work has been performed to develop a knowledge base for the scale-up project (See Section 2.0). In view of the extensive research efforts and available literature concerning sulfur oxide control processes, it has been necessary to develop a strategy for focusing and organizing the information into a useful format. The following approach has been used in organizing the review:

- A brief description of the DOE-sponsored proof-of concept test programs is presented. These descriptions indicate the type of processes studied to date and provide qualitative information on the results obtained.

- A comprehensive compilation and analysis of thermodynamic data relative to duct injection processes is presented. The purposes of this section are to provide a thorough understanding of any limitations which may be imposed on the candidate processes by the laws of thermodynamics, and to provide a convenient collection of thermodynamic data for use in planning and interpretation of test program results.
- A review of available kinetic data is presented. The objective of this section is to provide a basis for designing the scale-up test program so that a maximum utilization of prior experimental work is obtained.
- Since model validation comprises an important element of the scale-up test program (See Section 3.0), a review of available models is provided. The models deal with the two key chemical and physical process issues: 1) removal of SO_2 , and 2) removal of solids.
- A brief discussion and review is presented of costs estimates prepared by the three contractors who performed the proof-of-concept testing for DOE. This evaluation is based on information obtained from this earlier phase of the DOE process development effort.

Results

Thermodynamics. Compilations of thermodynamic data were examined with regard to the following topics:

- Equilibria of calcium sulfite and calcium sulfate with their hydrates

- Equilibria between SO_2 and calcium-based sorbents
- Equilibria between SO_2 and calcium silicate
- Adiabatic humidification of flue gas
- Adsorption and condensation of water vapor on solid sorbents
- Solubilities of SO_2 and calcium hydroxide in water
- Ion dissociation and precipitation processes

The analysis of thermodynamic data for the above processes confirmed a generally accepted viewpoint concerning the role of thermodynamics in duct injection technology. That is, with the exception of solubility relationships, the equilibria for the known reaction systems do not play a major role in limiting sorbent utilization under process conditions of interest. The analysis also indicated that $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ and $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ (gypsum) are the stable forms of the sulfite and sulfate throughout the relevant range of flue gas conditions.

Kinetic Studies. The review of kinetic studies was subdivided as follows:

Chemical forms of sorbent—Both sodium and calcium compounds were considered, but it is recognized calcium compounds are the sorbents of choice for duct injection. Calcium hydroxide with additives has been studied by numerous investigators. The additives have included deliquescent inorganic salts and related inorganic salts, sodium containing basic compounds, organic compounds, and oxidation catalysts.

Physical properties of sorbent—Surface area, particle size, and porosity have been considered in assessing sorbent reactivity. Surface area, as determined by the BET method, is the physical property that has been most widely investigated as a factor influencing the rate of reaction with SO_2 .

Methods of humidification—Humidification has been accomplished by injection of sorbent and water separately with dry sorbent injection, and by evaporation of water from injection of a slurry. In general, lower sorbent utilizations have been reported with dry sorbent injection when results are compared with slurry injection.

Results from DOE proof-of concept tests—A correlation developed by Bechtel based on data from the Campbell Station has been used to estimate sorbent utilization in the approach range 10-50°F. An initial SO₂ concentration of 1500 ppm was assumed. The results for Ca/S ratios of 1.0 and 2.0 are presented in Figure E-1. The curve is unrealistic outside of the data range at close approaches to saturation, in that a utilization above 100% at Ca/S of 1.0 is indicated. However, the graph is consistent with one of the main conclusions from the Bechtel report, to the effect that a utilization of 45% (50% SO₂ removal) is attainable at Ca/S of 1.1.

Figure E-2 illustrates the dependence of SO₂ removal on Ca/S ratio at a fixed approach to saturation. One curve is based on an equation from the Bechtel report for an approach of 35°F, where most of Bechtel's data were collected (the curve crosses the line for 100% utilization at Ca/S < 0.3 and is therefore unrealistic in that range). The other curve is based on an equation from the General Electric report for an approach of 40°F, the minimum investigated. The predictions are quite similar, notwithstanding the substantial difference in SO₂ concentrations encountered in the two investigations--around 2000 ppm by Bechtel and nearly 4000 ppm by General Electric.

It is of interest to compare the predictions for slurry injection with the results for dry sorbent injection accompanied by downstream humidification with a water spray, as found in the Dravo investigation at an approach of 30°F. A bar is shown in Figure E-2 to indicate the approximate range of results reported by Dravo at Ca/S = 1.8. This comparison indicates dry injection of calcium hydroxide will result in significantly lower calcium utilizations than slurry injection unless recycle or an effective additive can significantly change the results obtained thus far.

Figure E-1. Sorbent utilization versus approach to saturation based on the Bechtel correlation.

6718-16

Figure E-2. SO₂ removal as a function of Ca/S ratio.

Review of Mathematical Models. A review was conducted of existing mathematical models dealing with 1) removal of SO₂ with sorbent, and 2) collection of particles in ESPs. Mathematical models of SO₂ removal were divided into two categories: 1) models dealing with spray drying and other lime slurry desulfurization processes, and 2) models dealing with sorbent/droplet collision in the separate injection of hydrated lime and water.

Although a considerable amount of work has been done in the area of spray dryer modeling, major deficiencies remain in the treatments of the fluid mechanics, droplet dispersion, and the role of the liquid phase resistance to mass transfer. Much less work has been done on modeling sorbent/droplet collision in the dry injection process. The one model reviewed for this process, while useful for illustrating certain trends, is deficient in its treatment of the two fluid jet dynamics and droplet trajectories.

Most currently available ESP models are based on the Deutsch equation, which is an exponential equation that provides a relationship between collection efficiency, the particle electrical migration velocity, and the ratio of plate area to volume flow. One widely used ESP performance model has been developed by SRI under EPA sponsorship. This model requires a detailed description of the physical and electrical properties of the ESP, the flue gas, and the entrained particles. None of the models currently available in the literature have been adequately evaluated with duct injection of sorbent.

A modification to the SRI model is currently under review at EPA. This version differs from the standard version in that the particulate space charge is calculated explicitly rather than approximately. To date there has been insufficient data on ESPs with high dust loading to adequately validate the model. The revised model may be useful for duct injection applications, however, if the new space charge algorithm is successful.

Economic Evaluation. Each of the three contractors (Bechtel, GE, Dravo) who performed proof of concept tests for DOE also generated a conceptual design and cost estimate for retrofitting their respective processes to a full scale unit. A review was performed on these cost estimates, and some changes were made to the cost assumptions to achieve as much consistency as possible.

However, no attempt was made to modify the design criteria to make them consistent. The approach used for the review consisted of inputting capital and operating costs into a standard economic model to ensure that consistent evaluations were performed. Table E-1 presents the summary of the normalized economics evaluation. The first year values are expressed in end-of year 1988 dollars.

TABLE E-1

SUMMARY OF NORMALIZED ECONOMIC RESULTS

<u>Report/Process</u>	Levelized cost of electricity <u>(Mills/kWh)</u>	<u>Cost of SO₂ removed</u>	
		1st Year <u>(\$/ton)</u>	Levelized <u>(\$/ton)</u>
Bechtel CZD Process	11.5	385	615
Dravo HALT Process	8.4	411	642
GE IDS Process	8.2	278	416

The results of the comparison seem to indicate that, although there are some differences between the processes as reported by the three contractors, there is general agreement of costs for these conceptual designs on a 500-MW unit. In general, the results suggest that duct injection has potential economic advantages as a desulfurization process in a retrofit application.

RESEARCH NEEDS AND PROJECT OBJECTIVES

The literature review has illustrated that relatively large pilot scale experimentation is required to determine the SO₂ and particulate removal performance that is achievable with various process modes and retrofit application scenarios. The Gilbert/Commonwealth team for the DOE Scale-up Tests and Supporting Research Project has prepared a project plan that is designed to supplement previous research and provide the information required to bring duct injection technology to commercial application. Modifications to the DOE Duct Injection Facility at the Muskingum River Plant are currently

in progress which will facilitate evaluations of various modes of duct injection.

The overall purpose of the test program is to gain a thorough and detailed understanding of the scale-up and design requirements, operational behavior, and limitations of duct injection technology. To accomplish this goal, the following specific objectives must be met.

- Both dry and slurry injection systems must be fully characterized in terms of their projected performance in retrofits to the population of candidate plants.
- The optimum process configurations must be identified for both the dry and the slurry forms of duct injection.
- Adequate data must be obtained to provide a reliable design basis and a reliable set of scale-up criteria. This requires an emphasis on determining mechanisms and limiting processes for the SO₂ removal achieved with various process modes.
- A reliable process control system, capable of handling all anticipated process upsets and variations, must be demonstrated.
- Equipment failure modes and methods to cope with them must be identified and demonstrated.
- The test program must be interactive with other ongoing DOE duct injection projects so as to make maximum use of all available data.

After a period of startup and shakedown tests, the actual test program will begin in the Summer of 1989 and run for two years. The test program is divided into two major tasks with eight major subtasks. The major elements of each subtask are very briefly described below.

Enhanced Data Development (Task 3)

Characterize System Performance. Validate sampling procedures; optimize humidification nozzle parameters; perform parametric tests of the effects of Ca/S ratio, approach to saturation, gas temperature and velocity, and duct configuration; evaluate vapor-phase versus collision effects; and examine effects on ESP operation.

Obtain Scale-up Data and Design Criteria. Examine effects of nozzle design and arrangement, flow conditioning, deposit cleaning strategies, sorbent dispersion, humidification, and ESP SCA and rapping with both dry and slurry injection.

Test Advanced Configurations. Evaluate advanced nozzle designs, various types of additives, advanced duct cleaning systems, spent sorbent recycle methods, ESP rapping reentrainment suppression, and inertial collectors (such as louver collectors) ahead of ESP with both dry and slurry injection.

Process Controls. Evaluate response of process control systems to normal variations in process conditions as well as upset conditions with both dry and slurry injection.

Failure Modes. Evaluate responses and corrective actions for major equipment failures, including nozzle pluggage, excessive nozzle wear, loss of atomizing air, wet solids to ESP, perforated plate pluggage, loss of ESP fields, ash hopper and piping pluggage, and loss of control system power.

Characterize Wastes. Thoroughly characterize spent sorbent and fly ash waste to demonstrate that it is nonhazardous and can be safely handled and land-filled in existing facilities.

Mathematical Model Validation (Task 4)

Other contract teams are working to develop first and second generation mathematical models for duct injection. This project has been assigned the

role of model validation through comparisons of model predictions with experimental data. The model evaluations are planned to occur in two separate phases as described in the following paragraphs.

First-generation Model Testing. Validate predicted evaporation rates, droplet deceleration rates, sorbent/droplet collision rates, SO₂ absorption rates, and ESP collection efficiency. Evaluate model capability for prediction of suspended phase and fixed bed components (from deposits and ESP electrodes) of overall SO₂ removal.

Second-generation Model Testing. Validate modifications made to first-generation model to improve predictions and incorporate improved rapping reentrainment correlation for ash/sorbent particulates.

Existing Test Facility and Planned Modifications

The existing test facility provided hydrated lime slurry to a rotary atomizer which could be located in one of three duct locations, one vertical and two horizontal orientations. Existing facilities and equipment which will be reused as part of this program, and in some cases modified, include the flue gas breaching and isolation dampers, test stations, cyclone and electrostatic precipitator collectors, induced draft fan, drag chain ash conveying system, ash silo, ash recycle blower, control room and motor control centers, data acquisition system, and most of the existing structures and platforms.

The following new facilities and equipment are required to support the desired test programs:

- Flue Gas Dilution System
- Slurry Sorbent Injection System

- Dry Sorbent Injection System
- Gas Humidification System
- Ash Collection and Ash Recycle System
- Compressed Air System
- Duct Cleaning System
- Cooling Water System
- Utility Systems

Operation of the duct injection test facility is comprised of startup, commissioning (shakedown) and normal operation. The duct injection test facility will be operated continuously, five days per week in three shifts. Personnel have been provided for continuous coverage Monday through Friday. For duration testing, continuous seven day a week operations will be provided.

The extensive capabilities of the modified facility, when combined with the comprehensive data acquisition and analysis program, are expected to provide all of the information required for appropriate commercial applications of the various duct injection process modes.

1.0 INTRODUCTION

1.1 PROCESS DESCRIPTION

Duct injection technology is one of the applications of a dry sorbent for low-cost control of SO_2 emission in coal-burning electric power stations. The process is intended for installation in older plants that are not subject to regulation under New Source Performance Standards. The process is meant to provide a simple, cost-effective method to satisfy possible future regulations in the interest of controlling acid rain. It is expected to be capable of removing a minimum of 50% of the SO_2 emitted from the burner and to do this at a minimum sorbent utilization of 35% and at a cost not to exceed \$500/ton of SO_2 removed.¹ These performance figures are in contrast to a removal efficiency of 90% or more at a utilization approaching 100% and at a cost of approximately \$1000/ton of SO_2 removed in a wet scrubber. The lower efficiency of duct injection is an acceptable limitation, however, in order to achieve a significant degree of SO_2 removal at low cost in plants that might otherwise operate without restraint in regard to SO_2 emission.

Duct injection technology will employ a calcium-based sorbent — $\text{Ca}(\text{OH})_2$ or an equivalent in reactivity — at a point of introduction between the air heater and the dust control equipment, which will be an electrostatic precipitator (ESP) in most of the power plants of concern. The zone of reaction between SO_2 and the calcium-based sorbent will be effectively restricted to existing ductwork connecting the air heater to the ESP. Duct injection technology is thus distinguished from furnace injection technology, such as the LIMB technology of the Environmental Protection Agency (limestone injection with multi-stage burners), in that the sorbent is not calcined (not converted to CaO) prior to reaction with SO_2 and the reaction begins below 300 °F rather than above 2000 °F.

In a duct injection process, the sorbent will be injected in a finely-divided suspended state (either as a dry powder or a slurry) and will be expected to undergo most of its reaction with SO_2 in the suspended state, prior to the time that it is precipitated in the ESP. Some of the sorbent will unavoid-

ably be deposited on the walls of the duct and will react to some degree there, albeit with lower efficiency. Some will also react after precipitation on the ESP plates, again with lower efficiency.

An essential aspect of successfully using a calcium-based sorbent in a low-temperature, post-furnace reaction zone is that the sorbent must be activated with an elevated concentration of water vapor or, more likely, it must be activated specifically by physical contact with liquid water. The concept that physical wetting is required has led to the development of two modes of sorbent injection in a duct process: 1) wet injection, in which a spray of an aqueous sorbent slurry is introduced, and 2) dry injection, in which the sorbent is introduced as a dry powder but subjected to wetting by a water spray, which may be injected either upstream or downstream from the sorbent. Only a dry solid, however, is intended to reach the ESP; evaporation from the slurry or the plain water spray must occur before the gas stream reaches the ESP.

The process of wet sorbent injection bears a strong similarity to spray drying, which is a high-efficiency, high-cost technology for SO₂ control on a par with wet scrubbing. The fundamental difference between the duct application and the conventional process is the lifetime of wet sorbent particles; only 1 to 2 s is allowable in the duct application, whereas 10 s is a typical residence time of wet particles in the conventional process. The principal development of wet sorbent injection in ducts has come from two contractors working under support of the Department of Energy (DOE). Bechtel has advanced the use of slurry injection through a two-fluid nozzle;² General Electric, on the other hand, has promoted the use of a rotary atomizer.³ Two related developments have come from the Environmental Protection Agency (EPA) and the Electric Power Research Institute (EPRI). EPA is developing E-SOX, in which a slurry is sprayed within the shell of the former first field of an ESP and the residual solid from the spray as well as fly ash is collected in the remaining fields of the ESP.⁴ EPRI is developing HYPAS, a process that takes place between an existing ESP and the stack; a slurry is sprayed into the duct at the ESP outlet and the dry residue is collected in an added baghouse that precedes the stack.⁵

CONSOL (Consolidated Coal Company) is a proponent of dry injection of $\text{Ca}(\text{OH})_2$ with downstream injection of a water spray and is working under sponsorship of DOE on a demonstration of this process.⁶ Dravo Lime Company, under DOE sponsorship, is the other principal advocate of dry injection and has evaluated both upstream and downstream water sprays for humidification.⁷ Dravo, however, primarily employed the downstream spray at the larger-scale demonstration of the dry injection process.⁸

A survey of duct configurations in the U.S. power industry has been performed to obtain a clear idea of the constraints under which duct-injection technology must operate. Burns and Roe Service Organization solicited information on nearby 500 power boilers that may be subject to duct injection as a retrofit technology for controlling SO_2 .¹ The survey actually elicited information from 324 units that operate with cold-side ESPs or baghouses. A brief summary of the results is given below:

- The low-temperature ducts where sorbent injection may be put into effect are, in cross-section, predominantly rectangular (87%), rather than square, trapezoidal or circular. The number of ducts available is usually one or two.
- Two-thirds of the ducts are horizontal or inclined from the horizontal by less than 30 degrees.
- The average duct cross-sectional area is 218 ft^2 . The range from 100 to 300 ft^2 represents 45% of the total, but the much smaller range from 21 to 99 ft^2 represents 32% of the total.
- The total duct length is less than 200 ft for 63% of the boilers, but averages 128 ft. The longest straight run is less than 40 ft for 54% of the boilers and averages only 54 ft.
- At full boiler load, the average gas velocity is 47 ft/s.
- The gas temperature is less than 300 °F in 33% of the ducts and less than 350 °F in 84%.

The physical dimensions of the ducts and the gas velocity are critical to the success of a duct-injection process. The extent of deposition of dry or wet sorbent on walls surrounding the injections has to be minimized. In addition, the time of transit of the gas stream from the point of water or slurry injection must be long enough to allow complete droplet evaporation to occur and, at the time, allow most of the required removal of SO_2 to occur. A consideration of both duct lengths and gas velocities leads to the following estimates of drying times available in straight-run ducts at full load:

<u>Time, s</u>	<u>Percentage of ducts</u>
<0.5	20
0.5-1.0	37
1.0-1.5	14
1.5-2.0	10
>2.0	19

In other words, in half of the duct surveyed, the drying time available will be less than 1.0 s. This limitation says a great deal about the rate at which SO_2 removal must proceed when the sorbent is injected in a slurry. It says much more about constraints imposed on dry injection accompanied by spray humidification; it imposes a maximum on the spray droplet size of about $60\text{ }\mu\text{m}$ and requires that first collision of droplets and sorbent particles and then chemical reaction be complete in less than 1.0 s.⁹

1.2 DESCRIPTION OF KEY ISSUES

1.2.1 Chemical and Physical Processes

Removal of SO_2 . The factors that control the extent to which SO_2 is removed may be discussed from a fundamental point of view within the following categories:

- Chemical thermodynamics
- Chemical kinetics
- Mass transfer

The first question in the sphere of thermodynamics is whether the fundamental overall chemical transformation

imposes a significant limitation on the extent to which SO_2 may be removed. For the simple form of the sorbent Ca(OH)_2 , the specific transformation is as follows:

Thermodynamic data for Equation 1.2 indicate that SO_2 at typical reaction temperatures below 300 °F can react until its concentration falls to a value far below 1 ppm (Section 2.3.2). In this case, obviously, attainment of 50 or 75% removal is not hindered by the thermodynamics of the overall chemical transformation involved. For certain other forms of the sorbent — such as a silicate produced from the hydrothermal reaction between CaO and fly ash — the equilibrium constant for Equation 1.1 may not be quite so favorable but still is not likely to offer deterrence to a high degree of removal of SO_2 .

Other more subtle questions in the sphere of thermodynamics arise as the focus shifts from the overall chemical transformation to the sequence of steps that lead ultimately to SO_2 removal. A schematic diagram of a step-wise process in which SO_2 and Ca(OH)_2 react with the intervention of liquid water is given in Figure 1.1. Thermodynamic issues pertinent to this three-component system of SO_2 , Ca(OH)_2 and H_2O are as follows:

- 1) What is the affinity of Ca(OH)_2 for water vapor?
- 2) What is the solubility of SO_2 in water?
- 3) What is the solubility of Ca(OH)_2 in water?
- 4) What are the ionization constants of dissolved SO_2 and the complex ion CaOH^+ ?

5) What is the solubility product of CaSO_3 , the ultimate reaction product?

Obviously, each of the questions can, in principle, have an answer that is unfavorable to the removal process. The first three issues may, in actuality, impose significance deterrence to SO_2 removal; the latter two issues are less likely to do this.

The fundamental issue with respect to kinetics is why the rate of the simple, direct gas/solid reaction shown by Equation 1.1 is so slow that effective reaction must occur through a complex scheme involving condensed water vapor, as depicted in Figure 1.1. The available kinetic data, it appears, are not adequate for answering the question unambiguously. A probable explanation, however, is that the reaction is limited not by chemical kinetics but by diffusion within the solid, which can only slowly move the chemical reaction front from the exterior to the interior of a particle. This explanation, if correct, shifts the rate limitation from the realm of chemical kinetics to that of mass transfer.

An appreciation of the kinetic limitations of the simple, direct gas/solid reaction can be gained by reviewing the results of kinetic analyses of corresponding reactions at much higher temperatures. Borgwardt and Bruce of EPA investigated the reaction between the calcination product of CaCO_3 with SO_2 in the presence of oxygen under furnace conditions (temperatures above 1400°F):¹⁰

The product here is CaSO_4 , rather than CaSO_3 , which is only stable at lower temperatures. The rate of the process was investigated under conditions where the diffusion of SO_2 into pores was not limiting and the rate could be interpreted in terms of either chemical kinetics or product-layer diffusion as the rate-controlling process. The latter process was deemed to be rate-controlling on the basis of several criteria: 1) the nature of the relationship between

Figure 1.1. Physical and chemical processes in the water-assisted reaction of SO_2 with Ca(OH)_2 .

the degree of conversion and the time of reaction, 2) the second-order dependence of the reaction rate on the specific surface area of the sorbent, and 3) the high dependence of the reaction rate on the temperature (activation energy, 36.6 kcal/mol). The consequences of the rate dependence on surface area and temperature are such that with a sorbent surface area of 20 m²/g (approximately that of ordinarily commercial Ca(OH)₂ materials) and at a temperature of 1475 °F (near the lower limit of the furnace range but far above that associated with duct injection) not more than 20% conversion of the sorbent can be achieved in 10 s.

A closer parallel to the reaction of Ca(OH)₂ and SO₂ in the dry state at duct temperatures is found in the reaction between these substances at so-called "economizer" temperatures, around 1000 °F:

Investigations at KVB have found that substantial SO₂ removal can be achieved by injecting Ca(OH)₂ in the range 900 to 1200 °F.^{11,12} In this range, Ca(OH)₂ reacts as such, not after calcination to CaO, which occurs at furnace temperatures as it does with CaCO₃; also, CaSO₃ is the product instead of CaSO₄. Ironically, the rate of reaction between Ca(OH)₂ and SO₂ is greater at 1000 °F than that of CaO and SO₂ (with O₂) at 2000 °F. Nevertheless, the rate of reaction falls off sharply if the temperature decreases below 900 °F and becomes negligible at 500 °F. The question of whether the rate of reaction in the range 900 to 1200 °F is chemically controlled or diffusionally controlled has not been resolved; however, the rate of reaction at duct temperatures below 300 °F, without the intervention of moisture, will surely be negligible.

As will be discussed subsequently, the effect of moisture as the vapor alone through the phenomena of adsorption becomes significant if the vapor concentration is increased and the temperature is lowered simultaneously in the range below 300 °F. The effect only becomes useful, however, if moisture is present as the liquid phase and the sorbent is physically wetted, allowing the sequence of events shown in Figure 1.1 to occur. There is no chemical event in that sequence that is conceivably slow enough to produce a significant deterrence to the removal of SO₂. The limitation in rate must therefore arise from

some mass-transfer process, such as the dissolution of SO_2 , the dissolution of $\text{Ca}(\text{OH})_2$, or the diffusion of one or another of the dissolved species to the site of $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ precipitation.

Various mathematical models have been proposed to describe SO_2 removal by the slurry droplets of a spray dryer and have dealt with mass-transfer limitations; they are also useful for describing SO_2 removal in a duct-injection process in either the wet or dry mode, provided a water spray is used to activate the sorbent in the latter mode. One of these models was developed by Damle for EPA;¹³ it will be used as the basis for discussion to follow. A primary conclusion from this model, as well as others, is that SO_2 capture occurs predominantly during the initial phase of the spray-drying process, when water is evaporating at essentially a constant rate. Once the size of the residual particle becomes fixed, with $\text{Ca}(\text{OH})_2$ particles all in contact and water only filling interstices between particles, the rate of SO_2 removal decreases sharply even though the residual particle may still be in suspension in the gas stream. After removal of the particle on a fabric filter and ESP plates, the rate decreases even further.

The concentration profiles visualized by Damle between the two separate reactants — gaseous SO_2 and solid $\text{Ca}(\text{OH})_2$ — are depicted in Figure 1.2. The rate of transport of SO_2 across the gas film adjoining one unit area of the droplet is expressed as follows:

$$R_s = k_g(C - C_i), \text{ mol}/(\text{cm}^2 \cdot \text{s}) \quad (1.5)$$

where k_g = mass transfer coefficient, cm/s

C = concentration of SO_2 gas in the
bulk gas phase, mol/cm³

C_i = concentration of SO_2 gas at the
interface, mol/cm³

Similarly, the rate of transport of dissolved SO_2 within the boundary layer just inside the droplet is expressed this way:

Figure 1.2. Concentration profiles with SO_2 adsorption/reaction in a water droplet containing Ca(OH)_2 .

$$R_L = k_L (C_s^* - C_s), \text{ mol}/(\text{cm}^2 \cdot \text{s}) \quad (1.6)$$

where k_L = mass-transfer coefficient, cm/s

C_s^* = concentration of SO_2 in the liquid
at the interface, mol/cm³

C_s = concentration of SO_2 in the bulk
liquid, mol/cm³

An alternative expression for the transport of dissolved SO_2 is the following:

$$R_L = k_L^\circ \psi (C_s^* - C_s) \quad (1.7)$$

where k_L° = mass-transfer coefficient in the
absence of chemical reaction within
the droplet (as in plain water)

ψ = enhancement factor due to the
chemical reaction

Damle's approach toward assigning values to the above mass-transfer coefficients is summarized in Figure 1.3. Numerical values thus assigned to the mass-transfer coefficients for typical spray-dryer (or duct-injection) conditions, with spray droplets having a diameter of 50 μm , were as follows:

$$k_g = 80 \text{ cm/s}$$

$$k_L^\circ = 0.20 \text{ cm/s}$$

$$\psi = 194$$

$$k_L = k_L^\circ \psi = 39 \text{ cm/s}$$

Then, the relative values of resistances in the gas and liquid phases were assessed from their relation to the overall mass-transfer coefficient, which determines the total rate of transfer of SO_2 from the gas to the liquid phase:

$$N_S = K_G (\pi d_p^2) C, \text{ mol/s} \quad (1.8)$$

1) By approximation, $k_g = 2D_{SG}/d_p$

where D_{SG} = diffusivity of SO_2 in the gas phase, cm^2/s
 d_p = drop diameter, cm

2) By approximation, $k_L = D_{SL}/\delta$

where D_{SL} = diffusivity of SO_2 in the liquid phase, cm^2/s
 δ = thickness of the liquid-phase boundary layer
(about 0.0001 cm)

3) From theoretical development,

$$\psi = 1 + (D_{CL}C_C)/D_{SL}C_S^*$$

where D_{CL} = diffusivity of $Ca(OH)_2$ in the liquid phase, cm^2/s
 C_C = concentration of $Ca(OH)_2$ in the bulk liquid phase
(corresponding to equilibrium solubility), mol/cm^3
 D_{SL} = diffusivity of SO_2 in the liquid phase, cm^2/s
 C_S^* = concentration of SO_2 at the interface, mol/cm^3

Figure 1.3. Evaluation of mass-transfer coefficients involved in the transfer of SO_2 gas to a $Ca(OH)_2$ slurry droplet.

where K_G - overall mass-transfer coefficient, cm/s
 d_p - diameter of the droplet, cm
 C - concentration of SO_2 in the
 bulk gas phase, mol/cm³

The relationship required for comparing the magnitudes of the gas- and liquid-phase resistances is the following:

$$1/K_G = 1/k_G + H/k_L \quad (1.9)$$

Here, the term H is Henry's constant for SO_2 , taken as 0.054 when both gas- and liquid-phase concentrations are given in mol/cm³. The result is as follows:

$$\begin{aligned} 1/K_G &= 1/80 + 0.054/39 \\ &= 0.0125 + 0.0014 \end{aligned}$$

The result indicates that K_G is approximately equal to k_G or, in other words, the gas-phase resistance exceeds the liquid-phase resistance. The diameter of spray droplets will not be enough larger than 50 μ m to alter this conclusion; smaller diameters will simply confirm the conclusion. (Other investigators, however, have argued that liquid-phase resistance may be appreciable, as discussed subsequently in Section 2.5.1.)

The counterpart of Equation 1.8, which gives the overall rate of transfer of SO_2 from the gas to the liquid, is an equation that gives the rate of dissolution of $Ca(OH)_2$. Damle derived the following equation for the dissolution rate:

$$R_D = D_{CL} \frac{\pi d_p^2 C_L}{\delta} \frac{d_{p0}^3 (1 - W_o)}{d_{p0}^3}, \text{ mol/s} \quad (1.10)$$

where D_{CL} - diffusivity of $Ca(OH)_2$ in the
 liquid phase, cm²/s
 d_p - diameter of the $Ca(OH)_2$ particle, cm
 d_0 - diameter of the liquid droplet, cm

C_L = equilibrium solubility of $\text{Ca}(\text{OH})_2$, mol/cm³

δ = thickness of the liquid-phase boundary layer, cm

W = liquid volume fraction in the droplet

(Parameters given with and without the subscript zero are initial and instantaneous values, respectively.)

In conclusion, the controlling mechanism of SO_2 removal will be determined by the magnitudes of N_s and R_p calculated from Equations 1.8 and 1.10; the gas-phase resistance to SO_2 transfer will control if $N_s < R_1$, or sorbent dissolution rate will control if $N_s > R_p$.

Removal of solids. An ESP is the dust-control device of main concern with respect to duct injection of sorbent as a retrofit technology. Most of the older utility power stations where duct-injection technology might be adopted operate with ESPs. Moreover, many of these ESPs are small in size with specific collecting areas (SCAs) between 100 and 400 ft²/1000 acfm. Their performance is marginal, at best, in terms of conventional performance standards, with fly ash as the only particulate substance to be collected. Their performance is certain to be severely stressed with the changes in characteristics of particulate matter, both in concentration and physical properties, that will be brought about by the adoption of duct injection technology.

Changes in the characteristics of particulate matter that will have significant impacts on ESP performance are the following:¹⁴

- Increase in the total mass concentration in the suspended state
- Change in the particle-size distribution in the suspended state
- Change in the electrical resistivity of precipitated particles
- Change in the cohesiveness of the precipitated particles
- Formation of a space-charge cloud in the ESP gas passages and a resultant suppression of corona current

The impact on sorbent injection can be illustrated in terms of a hypothetical coal containing 3% sulfur and 10% mineral matter. At typical excess

air levels, the combustion process will produce a flue gas containing about 2200 ppm of SO_2 , which is a mass concentration at 300 °F of 4.1 mg/L. At the same time, if all the mineral matter is entrained in the flue gas as fly ash, the ash concentration will be 6.8 mg/L (2.9 gr/ft³). Suppose that Ca(OH)_2 is added to produce a Ca/S ratio of 2.0; further, assume that 25% of the Ca(OH)_2 is converted to $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ (removing 50% of the SO_2). The resulting concentration of sorbent at the ESP inlet will be 11.1 mg/L, corresponding to a 163% increase in solids concentration (even more, relatively speaking, if all the mineral matter is not entrained in the flue gas as fly ash).

The influence of sorbent injection on particle-size distribution cannot be predicted unambiguously; it may depend upon whether the sorbent is injected in the dry state or the wet state. The investigation of the furnace injection of sorbents has shown that the effect is a shift toward smaller particles whose collection efficiency is relatively low. The injection of a dry sorbent in a duct is likely to have a similar effect. This conclusion is based on the assumption that the efficiency of particle deagglomeration during duct injection will be no less than that of furnace injection; the median size of Ca(OH)_2 particles to be used for duct injection will certainly be less than that of CaCO_3 , which is often the sorbent of choice for furnace injection. The injection of a sorbent slurry in a low-temperature duct is less likely to cause a shift than smaller particles. Suppose that the slurry droplets have a diameter of 50 μm and a Ca(OH)_2 concentration of 20%. The aggregate of Ca(OH)_2 remaining after the water evaporates from a single droplet will have a diameter (as a sphere) of about 20 μm if there is no porosity or about 30 μm if there is 50% porosity. These sizes are to be compared to mass-median diameters of dry specimens of commercial Ca(OH) that range down to 1 or 2 μm .

The effect of sorbent injection on electrical resistivity is not easily predicted. There will be, in actuality, effects of two types: 1) the change in chemical composition of the particulate matter, due to admixture of roughly one part of Ca(OH)_2 and related compounds to one part of conventional fly ash and 2) the associated increase in the water vapor concentration of the gas phase, due to the humidification process, which has a major influence on resistivity. There are adequate ways now to calculate the resistivity of conventional fly ash as a function of chemical composition and water vapor

concentration; there is no satisfactory basis for predicting the resistivity of ash-sorbent mixtures. There is one reason, however, for believing that the resistivity of these mixtures will not create an intractable problem; that is, the humidification of flue gas with a water spray has proven to be a satisfactory way of coping with a resistivity problem that would otherwise exist when a sorbent is injected into the furnace.¹⁴ The success achieved in using water vapor to condition dry mixtures of sorbent and ash from furnace injection makes it likely that wet mixtures from duct injection, never reaching a bone-dry state, can be dealt with adequately.

The cohesiveness of an ash deposit on ESP plates is important to ESP performance, not through the ash collection process but in the plate-cleaning process based on rapping. Ideally, the ash is highly cohesive, so that the deposit slides down the plates without disintegration into small particles that can be reentrained; obviously, however, interparticle cohesion must not extend to adhesion between particles and plates. The factors that control the cohesiveness of ordinary fly ash are not well understood; the same is true even more for mixtures of sorbent and ash. A conservative view, however, still permits optimism that the cohesiveness of these mixtures will be acceptable, particularly in view of the high moisture contents predicted; a perspective giving rise to concern, however, is that pozzolanic reactions between calcium-rich sorbent particles and silica-rich ash particles may produce cementitious deposits that will be difficult to remove from ESP plates by rapping.

Formation of a space-charge cloud and suppression of corona current is likely to parallel the shift, if any, in particle size to smaller values. The difficulty in ESP operation arises when there is a high number concentration of particles, which causes an inordinate attachment of charged gas molecules to suspended particles. Thus, space-charge suppression of corona current is likely to be a problem when sorbent is injected in the dry state but not so when it is injected in a slurry.

1.2.2 Engineering Issues

Since the project under which this literature review was conducted is concerned primarily with scale-up of bench and pilot experimental results, it

is important to establish a linkage between process fundamentals and engineering issues. The following subsections describe key process and mechanical engineering issues which must be addressed in the process development effort.

As has been previously indicated, duct injection technologies are basically low temperature and short residence time processes. Although the sulfur removal goals of 50% are modest, the process conditions are difficult and must approach the boundary conditions in order to achieve the process goals.

1.2.2.1 Process issues

Approach temperature. All the tests have indicated that the ability to operate close to the adiabatic saturation temperature is the single most important factor in determining sulfur removal, the closer to the saturation temperature the better the sulfur removal. However, increasing duct deposits, the potential for condensation and corrosion in the duct, and the need to maintain a minimum stack gas exit temperature will, in practice, limit the operating temperature to a point considerably above the saturation temperature. In general, for all other parameters being the same, operation at a closer approach temperature is required for dry injection than slurry injection to achieve the same sulfur removal.

Residence time. About 1 to 2 s residence time in a straight run of ductwork is required to allow the humidification or slurry drops to dry. The closer the approach to saturation the longer it takes for the drops to dry. Thus for a typical duct flue gas velocity of 50 ft/s, a straight run duct of 50 to 100 ft would be required for complete drying to occur.

Sorbent utilization. Significant sorbent utilization improvement would greatly expand the applicability of the process and reduce SO₂ removal costs. Sorbent recycle, either from solids dropped out in the ductwork or from the electrostatic precipitator catch, can be used to increase sorbent utilization. However, recycle also greatly increases the downstream solids loading. In actual practice, the amount of sorbent recycle is limited by the solids removal efficiency of the ESP.

Stoichiometry. With set conditions for inlet flue gas temperature and humidity and for a specified approach to saturation temperature, the amount of water which can be evaporated into this flue gas is set. For slurry injection, the sorbent stoichiometry is varied by raising or lowering the weight percent solids of a slurry containing this amount of water. As sorbent stoichiometry is increased to increase the level of SO_2 removal, two limiting factors are approached:

- Sorbent utilization decreases.
- An upper limit is reached on the weight percent of sorbent solids in a slurry which can be pumped.

For dry injection, the sorbent stoichiometry can be varied independently and thus only the sorbent utilization is a limiting factor.

Duct wetting/solids deposition. A major concern for all duct injection technologies is the control of duct wetting and deposits. Continuous operation is not possible if the duct wall becomes wet. Dry deposits that form will be friable and their thickness limited. Factors which can affect wall deposits include nozzle spray particle size, nozzle spray angle, approach to adiabatic saturation temperature, inlet velocity profile, nozzle and nozzle array alignment, duct alignment, and duct obstructions especially prior to complete drying of the flue gas. Even during normal continuous operation with good maintenance and performance of the nozzles, slow deposition of fine solids on the duct bottoms can be expected.

Process control. Spray dryers use automatic process control to maintain the approach temperature required and the SO_2 removal. Similar controls should be satisfactory for duct injection technologies.

Sorbent selection. Tests have shown that certain lime sorbents are more reactive than others for reasons that are not yet clearly understood. Sorbent selection will depend not only on cost and convenience but also on the reactivity of the lime. As in fluidized bed combustion, sorbent reactivity tests must be performed before process guarantees are given.

to avoid or to minimize these deposits. The ability to readily remove the nozzle array for inspection and cleaning is necessary.

Major factors which can affect deposition in the duct include nozzle spray coarseness, angle and wall distance nozzle array alignment, and approach to the adiabatic saturation temperature. As long as areas are not covered by a continuous liquid film, deposits that form will be dry and friable. Since, even in a well operated duct injection system, these deposits will likely form, provisions should be made for their removal. For horizontal ducts, options include placing removal hoppers along the length of the duct or moving solids to a removal site through the use of conveyors or soot blowers.

Solids collection. As previously indicated in Section 1.2.1, duct injection of sorbent with humidification for SO₂ control has the potential to produce dramatic changes in the operating characteristics of the ESP installed for particulate emissions control. If the net effect of the process is a significant increase in particulate emissions, major modifications may be required to many candidate ESPs which are marginally sized. The cost of such modifications could change the economics of in-duct SO₂ removal.

the addition of sorbent to the flue gas stream ahead of an ESP will produce a number of changes in the operating conditions experienced by the ESP. Among these changes, which have been previously enumerated, is the effect on electrical resistivity of the ash. Historically, ash resistivity produces the large majority of ESP operating problems. The data concerning the resistivity of the ash/sorbent dust layers produced by in-duct sorbent addition with humidification are, at present, confusing.

The population of pre-NSPS ESPs varies considerably with respect to relative size or specific collection area (SCA) and the respect to the number of separately rapped electrical fields in the direction of gas flow. Both of these parameters affect not only the non-rapping efficiency of the ESPs, but even more the quantity of particulate reentrained and exhausted to the atmosphere during electrode rapping. (Rapping emissions can account for as much as 80% of total emissions). Specifically, the more fields in the direction of gas flow (or smaller the percentage of electrode area rapped at one time) the lower

must be designed to achieve complete spray evaporation in 1 to 2 s instead of 10 s for spray dryers, and must be designed to control wall wetting and solids deposition within the ducts.

The different approaches taken by developers include dry hydrate versus slurry injection; rotary disk versus two-fluid nozzle atomization; and, for dry sorbent injection, the location of the injection point either upstream or downstream of humidification.

The design of atomizers for slurries is still in an early stage of development, and there is considerable room for improvement in the design. To achieve the required rapid evaporation of sprayed slurry or water, very fine droplets must be produced by the atomizer. A top size less than 100 μm will be required for rapid drying and to accommodate some atomization deterioration and inefficiencies in mixing.

In addition to droplet size, several other factors also must be considered when selecting atomizers. These include nozzle design, air/liquid ratio, air/liquid pressure, spray characteristics and coverage of the duct area, nozzle resistance to erosion, corrosion and deposits, and the ability of vendors to maintain strict quality control.

To maintain droplet size and the preferred narrow droplet size distribution, multiple small nozzles are required as opposed to fewer larger nozzles. The optimum number of nozzles, the arrangement of the nozzles in the duct, the design of the array, and selection of materials of construction for the array are additional factors which must be addressed. The ability of the nozzles to maintain performance during long term, continuous operation is probably the most critical nozzle issue outstanding. Long-term, continuous testing will be required to address this issue.

Duct deposition and cleaning. The duct injection process must be designed not only to minimize the solids deposition and build-up but also to cope with solids removal should deposition occur. Solids deposits on two-fluid atomizing nozzles have been experienced in tests and special precautions need to be taken

Waste disposal. Duct injection waste are amenable to disposal using essentially conventional systems, hardware and procedures. The potential environmental risks posed by these wastes are minimal and these wastes with their unused lime values appear to have significant utilization potential.

1.2.2.2 Mechanical design issues

The major systems that would be required for a duct injection retrofit include:

- Lime receiving/storage system
- Slurrying and injection system, or dry injection/humidification system
- Duct cleaning system
- Ash collection/recycle system
- Compressed air system
- Possible ESP modification or upgrading

Most of these are similar to systems found in commercially available spray dryer and flue gas desulfurization processes. The experience gained in these units can be utilized in the design of duct injection processes.

Two systems are, however, unique to duct injection technology; these are the slurry injection/humidification system and the duct cleaning system. These systems are keys to the success of the technology and require additional development work before a full-sized demonstration plant can be confidently designed.

Slurry injection/humidification system. To be compatible with the retrofit concept of fitting new equipment within existing ducts, injection systems

rapping emissions are likely to be, even at constant SCA. All of the above mentioned changes in ash layer characteristics can dramatically affect both of these emission rates.

2.0 REVIEW OF PREVIOUS WORK

2.1 SCOPE

A review of previous work has been performed to develop a knowledge base for the scale-up project. In view of the extensive research efforts and available literature concerning sulfur oxide control processes, it has been necessary to develop a strategy for focusing and organizing the information into a useful format. The following approach has been used in organizing Section 2:

- A brief description of the DOE-sponsored proof-of-concept test programs is presented. These descriptions indicate the type of processes studied to date and provide qualitative information on the results obtained.
- A comprehensive compilation and analysis of thermodynamic data relative to duct injection processes is presented. The purpose of this section is to provide a thorough understanding of any limitations which may be imposed on the candidate processes by the laws of thermodynamics.
- A review of available kinetic data is presented. The objective of this section is to provide a basis for designing the scale-up test program so that a maximum utilization of prior experimental work is obtained.
- Since model validation comprises an important element of the scale-up test program (see Section 3.0), a review of available models is provided. The models deal with the two key chemical and physical process issues: 1) removal of SO_2 and 2) removal of solids.
- A brief discussion and review is presented of cost estimates prepared by the three contractors who performed the proof-of-concept testing for DOE. This evaluation is based on information obtained from this earlier phase of the DOE process development effort.

2.2 DOE-SPONSORED PROOF-OF-CONCEPT TESTS

The initial phase of DOE's Duct Injection Technology Development Program consisted of slipstream tests on a relatively small scale, in that only three to seven percent of the flue gas from the host power plants was used, except in one installation investigated by Bechtel National, Inc. These pilot-scale tests were performed by Bechtel National, Inc., Dravo Engineering, and General Electric Environmental Services.

2.2.1 Bechtel National, Inc.

Bechtel conducted nearly 1000 h of testing at the Consumer Power Company's J. H. Campbell Power Plant. The Bechtel process sprays a finely atomized slurry of lime and water into the ductwork through dual-fluid atomizing nozzles. About 1 to 2 s residence time in a straight run of ductwork is required to allow the drops to dry.

Bechtel tests were conducted in a 3-ft diameter, 130-ft long horizontal duct equivalent to about 7 MWe (21,000 acfm). The flue gas was then treated by a two-field pilot-scale ESP which has a SCA of 165 ft²/1000 acfm at 21,000 acfm. The slurry was atomized by a pair of two-fluid nozzles in series. The slurry flow rate was controlled to maintain the desired exit gas temperature.

For most runs, the outlet temperature was 160 °F, giving an approach to saturation of 35 °F. The most successful tests were run at velocities of 20 ft/s resulting in residence times of 5 to 6 s. Usually, the system was operated 3 to 4 h each day. Deposition of solids in the duct limited the length of test periods. The longest continuous operation was a series of 20-h duration ESP tests.

Bechtel followed-up these tests with additional testing on a 70MWe-scale (230,000 scfm) at Pennsylvania Electric's Seward Station. The flue gas was treated in approximately 35 ft on an 8-ft wide by 11-ft high section of straight duct between two sets of turning vanes located between two existing ESPs. At a nominal flue gas velocity of 64 ft/s, the duct section had only a 0.5-s residence time. The slurry was atomized using an array of nine dual-

fluid nozzles. The test program consisted of two months of parametric tests and one month of continuous operations. To avoid deposition on the turning vanes, fine atomization and restricted lime feed rates were necessary for the atomized droplets to dry before contacting the turning vanes. This limited SO₂ removal. Also, since lime injection was manually controlled, it was not possible to follow load closely resulting at times in low downstream temperatures with some deposition on the vanes and surrounding areas. Poor atomization resulting from eroded atomizers also caused some deposits.

2.2.2 Dravo Engineering

Dravo's process involves a two-step injection of humidification water and dry sorbent into the flue gas. Dravo's tests were conducted in a 31 in. x 31 in. by 65 ft horizontal duct equivalent to about 5 MWe (20,000 acfm). The flue gas was then treated in a baghouse or, during portions of the test period, an ESP. Two stages of humidification nozzles were used to cool the flue gas. The first stage was used to maintain a constant temperature at the entrance of the test section and the second stage to cool the flue gas to the desired exit gas temperature. Multiple dual-fluid air-atomized nozzles were used to spray the water. The humidification flow rate was controlled to maintain the desired exit gas temperature.

The test program included a series of parametric tests and a two-month duration test. During duration testing the unit was essentially run continuously. To achieve 50% sulfur removal, typical approach temperatures were 20-30 °F with Ca/S ratios near 2 and, normally, residence times of 1 to 2 s. Cooling water was injected downstream of the lime injection. However, some runs were made in which water was sprayed into the duct upstream of the lime injection point. During normal continuous operation with good maintenance and performance of the nozzles, Dravo still experienced a continuous slow deposition of solids on the duct bottom. These were removed manually.

2.2.3 General Electric Environmental Services

The GE process involves the atomization of slaked lime slurry using a rotary disk atomizer to produce the slurry mist. GE's tests were conducted in

either a 50-in.-diameter vertical duct or a 50 in. x 38 in. horizontal duct equivalent to about 12 MWe (50,000 acfm). Following the rotating atomizer, the flue gas was conveyed to a four-field pilot-scale ESP which has a SCA of $360 \text{ ft}^2/1,000 \text{ acfm}$ at 40,000 acfm. The slurry feed rate was set to maintain the desired Ca/S ratio while slurry dilution water feed rate was adjusted to maintain the desired exit flue gas temperature.

The GE test program included clear water tests to screen wall wetting conditions followed by parametric lime tests under straight-through and recycle conditions to establish operating and SO_2 removal ranges. GE was able to achieve 50% SO_2 removal at a Ca/S ratio of 1.5. However, the pilot plant had to operate at half the design slurry flow rate to prevent wall wetting. Prolonged operation was not possible due to solids built-up on the duct surface and only short 2- to 3-h runs were made. The small pilot-scale ducts contributed to the wall wetting problem. GE reported an enhancement in SO_2 removal during recycle tests (i.e. 50% SO_2 removal at lower fresh lime feed rates).

2.3 THERMODYNAMIC COMPILATIONS AND ANALYSES

Brewer¹⁵ and Parker et al.¹⁶ compiled thermodynamic data specifically for flue-gas desulfurization reactions in 1981 and 1982. Wagman et al.¹⁷ included the data sanctioned by the National Bureau of Standards in a more inclusive compilation published in 1982. This last mentioned publication includes values of the terms $\Delta_f H^0$, $\Delta_f G^0$, and C_p at 298.15 K for gaseous, solid, and aqueous species involved in desulfurization reactions. A partial listing of the data from Wagman et al., which covers the chemical and physical transformations involved in duct injection processes, is given in Table 2.1.

The data in Table 2.1 have been used in the sections to follow for computation of equilibrium constants and other related thermodynamic parameters in the range extending above 298.15 K into the range relevant to low-temperature flue-gas desulfurization. The minimum temperature for desulfurization is approximately 325 K (125 °F), which corresponds to attainment of adiabatic saturation with flue gas of a typical composition and a initial temperature of 422 K (300 °F). The corresponding partial pressure of water vapor at satura-

Table 2.1. Thermodynamic Properties at 298.15 K
of Substances Involved in Flue-Gas
Desulfurization^a

Substance	$\Delta_f H^0$, kJ/mol	$\Delta_f G^0$, kJ/mol	C_p , J/(mol·K)
O ₂ (g)	0	0	29.355
H ⁺ (aq)	0	0	0
OH ⁻ (aq)	-229.994	-157.244	-148.5
H ₂ O (g)	-241.818	-228.572	33.577
H ₂ O (l)	-285.830	-237.129	75.291
SO ₂ (g)	-296.830	-300.194	39.87
SO ₂ (aq)	-322.980	-300.676	--
HSO ₃ ⁻ (aq)	-626.22	-527.73	--
SO ₃ ⁻² (aq)	-635.5	-486.5	--
CO ₂ (g)	-393.509	-394.359	37.11
SiO ₂ (s)	-910.94	-856.64	44.43
Ca ²⁺ (aq)	-524.83	-553.58	--
CaOH ⁺ (aq)	-703.7 ^b	-718.4	--
Ca(OH) ₂ (s)	-986.09	-898.49	87.49
CaSO ₃ (s)	-1159.0 ^c	-1075.7 ^c	91.71
CaSO ₃ · 1/2 H ₂ O (s)	-1311.7	-1199.23	--
CaSO ₄ (s)	-1434.11	-1321.79	99.66
CaSO ₄ · 1/2 H ₂ O (s)	-1576.74	-1436.74	119.41
CaSO ₄ · 2H ₂ O (s)	-2022.63	-1797.28	186.02
CaCO ₃ (s)	-1206.92	-1128.79	81.88
CaSiO ₃ (s)	-1634.94	-1549.66	85.27

a. Data from Wagman et al.¹⁷ unless otherwise indicated.

b. Data from Bell and George.¹⁸

c. Data from Cubicciotti et al.¹⁹

tion is about 0.13 atm. The basis for these conditions is discussed later in Section 2.3.3.

2.3.1 Equilibria of Calcium Sulfite and Calcium Sulfate with Their Hydrates

CaSO_3 and CaSO_4 , the possible reaction products from flue-gas desulfurization, are compounds known to exist in both anhydrous and hydrated forms, as listed below:

A complete description of the reactions between SO_2 and a sorbent such as $\text{Ca}(\text{OH})_2$ thus requires specification of the state of hydration of the reaction products. An appropriate task in the realm of thermodynamics, therefore, is to define the conditions for equilibrium in the following processes:

This task can be completed with the data published by Wagman et al., provided that supplemental data from another source be obtained for the anhydrous form of the sulfite, CaSO_3 . The supplemental source used to obtain the results described below was the work of Cubicciotti et al.¹⁹

The results of calculations of equilibrium partial pressures of water vapor with the solids $\text{CaSO}_3/\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$, $\text{CaSO}_4/\text{CaSO}_4 \cdot \frac{1}{2}\text{H}_2\text{O}$, and $\text{CaSO}_4/\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ are plotted in Figure 2.1. Also, the approximate limits of the conditions reached as the result of adiabatic humidification of flue gas - $P_{\text{H}_2\text{O}} = 0.13$ atm and $t = 125^\circ\text{F}$ — are shown in the figure. It is apparent that $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ and $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ (gypsum) are the stable forms of the sulfite and the sulfate throughout the relevant range of flue-gas conditions.

6715-4

Figure 2.1. Partial pressure of water in equilibrium with calcium sulfite and calcium sulfate in the anhydrous and hydrated forms.

$\text{CaSO}_4 \cdot \frac{1}{2}\text{H}_2\text{O}$, on the other hand, is unstable throughout the range of conditions depicted in the figure; whatever partial pressure of water vapor converts CaSO_4 to $\text{CaSO}_4 \cdot \frac{1}{2}\text{H}_2\text{O}$ then converts the latter to $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$.

2.3.2 Equilibria between SO_2 and Calcium-Based Sorbents.

$\text{Ca}(\text{OH})_2$. The experimental evidence now available points to the predominance of $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ as the product of low-temperature reaction between SO_2 and $\text{Ca}(\text{OH})_2$. There is a distinction, of course, between the nature of the product at low temperature and that at high temperature, where CaSO_4 is the only product, owing to thermodynamic considerations. There is still interest in comparing the thermodynamic stabilities of the sulfite and the sulfate at low temperatures, where both are potential reaction products. The foregoing discussion of hydrate stabilities indicates that the correct formulations of reactions for low-temperature removal of SO_2 are as follows:

The data of Wagman et al. were used to calculate equilibrium partial pressures of SO_2 at O_2 and H_2O partial pressures of 0.05 and 0.13 atm, respectively. The results given in Figure 2.2 indicate that a far lower equilibrium value of SO_2 is obtained if $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ is the reaction product. At the limiting temperature of 125 °F, however, the equilibrium value is still quite low — about 3×10^{-10} atm — if $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ is the product.

A complete analysis of the ability of $\text{Ca}(\text{OH})_2$ to remove SO_2 from flue gas must address the issue of whether it can react with some component of the gas to form an even more stable reaction product than the sulfite or the sulfate. If this happens, the potential for removing SO_2 will be weakened. A specific threat to SO_2 removal, in principle, is the occurrence of any one of the following reactions:*

* The possibility that the calcium salts produced in these reactions will be more stable as hydrates is disregarded here.

Figure 2.2. Partial pressure of SO_2 in equilibrium with Ca(OH)_2 and sulfite/sulfate reaction products at $P_{\text{O}_2} = 0.05 \text{ atm}$ and $P_{\text{H}_2\text{O}} = 0.13 \text{ atm}$.

The effect of the halide (HX = HF or HCl), SO₃, or NO would be without practical consequence, since the concentration of any of these gases is less than that of SO₂ and could not consume a substantial fraction of the Ca(OH)₂. With CO₂, however, the effect could be of major consequence. CO₂ is far more concentrated on flue gas than SO₂ and obviously forms a stable reaction product with Ca(OH)₂.

The effect of CO₂ from the point of view of thermodynamics can be considered in terms of the equilibrium constant for the reaction:

$$K = \frac{P_{\text{CO}_2}}{P_{\text{SO}_2} (P_{\text{H}_2\text{O}})^{1/2}} \quad (2.11)$$

At $t = 125^\circ\text{F}$, $K = 4.550 \times 10^7$; if $P_{\text{CO}_2} = 0.13$ atm (a representative concentration in flue gas) and if $P_{\text{H}_2\text{O}} = 0.13$ atm (a value representative of adiabatic saturation), then $P_{\text{SO}_2} = 7.924 \times 10^{-9}$ atm. The principal interpretation of this result is that, even if CaCO₃ were formed, it in turn would react with SO₂. An important secondary interpretation, however, is that at equilibrium, with CaCO₃ in excess, the SO₂ concentration could not be lowered as much as Figure 2.2 indicates.

Other calcium compounds. The thermodynamic potential of CaCO₃ for reacting with SO₂ is addressed immediately above. Aside from this compound, the other main type of calcium-based sorbent of current interest is a silicate. As discussed later in this review, complex silicates produced by the reaction of

Ca(OH)_2 with fly ash and other sources of SiO_2 are of interest as sorbents because of their high surface areas. These silicates undoubtedly are more complex than the compound CaSiO_3 , for which thermodynamic data are given by Wagman et al.¹⁷ The simple silicate, however, may be used for illustrative purposes; its reaction with SO_2 is as follows:

$$K = 1/P_{\text{SO}_2}(P_{\text{H}_2\text{O}})^{1/2} \quad (2.13)$$

For the above reaction, the equilibrium constant at 125 °F is 4.180×10^{13} ; the equilibrium partial pressure of SO_2 at $P_{\text{H}_2\text{O}} = 0.13$ atm is 6.635×10^{-14} atm. CaSiO_3 , therefore, could remove SO_2 from flue gas more completely than CaCO_3 , but less completely than Ca(OH)_2 .

2.3.3 Adiabatic Humidification of Flue Gas.

The variables that determine the result of adiabatically humidifying flue gas consist of the initial gas temperature and composition, the initial liquid water temperature, and the relative quantities of gas and water. The resulting conditions of humidification that are of primary interest are the final temperature and water vapor concentration and the nearness of approach to saturation. The fundamental equations underlying calculations of the final conditions are as follows:

$$Q_1 \text{ (heat absorbed by added water)} = Q_2 \text{ (heat evolved by flue gas)} \quad (2.14)$$

$$Q_1 = n_1 \left\{ \Delta H_v + \int_{T_1}^{T_f} C_p \text{ (water vapor)} \cdot dT \right\} \quad (2.15)$$

$$Q_2 = n_2 \int_{T_f}^{T_2} \bar{C}_p \text{ (flue gas)} \cdot dT \quad (2.16)$$

where n_1 = moles of liquid water evaporated
 n_2 = moles of flue gas cooled

- ΔH_v - molar heat of evaporation of water
 (10,519 cal/mol at 298.15 K)
 T_1 - initial temperature of water, K
 T_2 - initial temperature of flue gas, K
 T_f - final temperature of flue gas, K
 C_p - molar heat capacity of water vapor (cal/mol·deg)
 $\bar{C}_p$ - weighted average molar heat capacity of the
 components of the flue gas (cal/mol·deg)

In the above equation, the heat loss of suspended fly ash in cooling from T_2 to T_f is ignored.

An example calculation was made by assuming that n_1 moles of liquid water is injected into 100 moles of flue gas of the composition 75% N_2 , 4% O_2 , 13% CO_2 , and 8% H_2O . The initial gas temperature was taken as 423 K (302 °F); the initial water temperature was assumed to be 298 K (77 °F). Heat capacity equations published by Spencer et al.^{20,21} were assumed to be valid; from these equations, the following were obtained:

$$\begin{aligned}
 C_p \text{ (water vapor)} &= 7.219 + (2.374 \times 10^{-3})T & (2.17) \\
 &+ (0.267 \times 10^{-6})T^2
 \end{aligned}$$

$$\begin{aligned}
 \bar{C}_p \text{ (flue gas)} &= 6.490 + (2.693 \times 10^{-3})T & (2.18) \\
 &- (0.522 \times 10^{-6})T^2
 \end{aligned}$$

Table 2.2 gives the results of calculations based on the assumption of a series of values of T_f and the computation of the corresponding values of n_1 . In the columns of the tables following T_f and n_1 are listed:

% H_2O , the adjusted value including the evaporated water;

Table 2.2. Calculation of the Effect of Adiabatic Humidification of Flue Gas at a Total Pressure of 1 Atm^a

Final temp, T_f , K	Moles of water, n_1	Concentration of H ₂ O, %	Partial pressures, mm Hg		Relative partial pressure, p/p^0
			p	p^0	
324	6.983	14.005	106.44	97.20	1.095 ^b
325	6.909	13.945	105.98	102.09	1.038 ^b
326	6.834	13.885	105.53	107.20	0.984 ^c
328	6.685	13.765	104.61	118.04	0.886
330	6.541	13.648	103.73	129.82	0.799
333	6.314	13.464	102.30	149.38	0.685
338	5.945	13.163	100.04	187.54	0.533
343	5.579	12.861	97.74	233.7	0.418
358	4.492	11.955	90.86	433.6	0.210
373	3.425	11.047	83.95	760.0	0.110
388	2.376	10.135	77.03	1268.	0.061
403	1.346	9.222	70.09	2026.	0.035
423	0	8.000	60.80	3570.	0.017

- a. Initial conditions: 100 moles of flue gas consisting of 75% N₂, 4% O₂, 13% CO₂, and 8% H₂O at 423 K.
- b. Values in excess of $p/p^0 = 1.000$, of course, cannot be reached.
- c. Interpolation gives $p/p^0 = 1.000$ at 325.7 K (126.5 °F), $n_1 = 6.857$ moles, and % H₂O = 13.903.

p , the total partial pressure of water including the evaporated water;

p^0 , the saturation partial pressure of water;

p/p^0 , the relative partial pressure of water
(the fraction of saturation).

The table indicates by interpolation that the addition of 6.857 moles of water gives adiabatic saturation ($p/p^0 = 1.000$) at 325.7 K (126.5 °F) and 13.903% water vapor. The table further indicates how lesser additions of water produce subsaturation as a result. The general relationship between p/p^0 and the final temperature, or the approach to saturation, is depicted in Figure 2.3.

Further calculations were made at other assumed water vapor concentrations and other initial gas temperatures. For these calculations, the properties of N_2 , O_2 , and CO_2 , were kept fixed; the total concentration of water vapor was adjusted to 6 or 10%. The results of these further calculations are listed in Table 2.3 and plotted in Figure 2.4. The figure reveals that increasing either the initial gas temperature or the initial water vapor concentration will raise the adiabatic saturation temperature, whereas decreasing either parameter will lower the saturation temperature. The figure also establishes the range where adiabatic saturation will be established for a majority of the instances in which coal is the fuel: temperature, 119-133 °F; water vapor concentration, 11-17%.

2.3.4 Adsorption and Condensation of Water Vapor on Solid Sorbents.

Adsorption. The adsorption of water vapor by $Ca(OH)_2$ and $CaCO_3$ has been investigated by Glasson²² and by Klingspor et al.²³ Glasson was concerned primarily with possibility that adsorbed water vapor would react with $Ca(OH)_2$ to produce the postulated hydrate $Ca(OH)_2 \cdot \frac{1}{2}H_2O$; he concluded that the effect did not occur. Klingspor et al. were concerned with the effect of adsorbed water vapor on the ability of $Ca(OH)_2$ or $CaCO_3$ to react with SO_2 . They deter-

Figure 2.3. Relative partial pressure of water vapor as a function of absolute temperature and approach to saturation (for details see Table 2.2).

Table 2.3. Summary of the Results of Adiabatic Saturation
of Flue Gas at Different Initial Conditions

<u>Initial Conditions</u>			<u>Final Conditions</u>		
<u>T₂,K</u>	<u>t, °F</u>	<u>%H₂O</u>	<u>T₂,K</u>	<u>t, °F</u>	<u>%H₂O</u>
408.0	275.0	6	321.7	119.3	11.38
		8	324.5	124.3	13.10
		10	328.2	131.0	15.64
423.0	302.0	6	323.0	121.6	12.18
		8	325.7	126.5	13.90
		10	328.2	131.0	15.64
438.0	329.0	6	324.3	124.0	12.98
		8	326.9	128.7	14.73
		10	329.2	132.8	16.42

67115-4

Figure 2.4. Final conditions of adiabatic saturation versus initial gas conditions.

mined the effect of sorbent type (hydroxide or carbonate) and sorbent surface area on water vapor uptake; they also interpreted the adsorption data in terms of the number of monolayers of water vapor adsorbed.

Klingspor et al. measured water vapor adsorption isotherms at 158 °F for five samples of Ca(OH)_2 and one sample of CaCO_3 . Surface areas ranged from 14 to 26 m^2/g for the Ca(OH)_2 ; the value was 3 m^2/g for the CaCO_3 . The quantities of water adsorbed depended upon both the relative partial pressure p/p^0 and the surface area; at $p/p^0 = 0.5$, for example, the quantity of water adsorbed ranged from 0.03 to 0.15% of the weight of the solid substrate. If adsorption was calculated relative to surface area instead of sorbent mass, however, a single isotherm was representative of all six materials.

Figure 2.5 depicts the adsorption isotherm showing the water uptake (units, mg/m^2) that was representative of all the materials investigated. This is a Type II isotherm in the Brunauer classification system. The investigators analyzed the isotherm in the low-pressure range by the BET method and concluded that coverage of the surface by one monolayer occurred at a water uptake of 0.4 mg/m^2 near $p/p^0 = 0.2$. Extrapolation to higher p/p^0 values yielded the number of monolayers listed along the right-hand vertical axis of the figure; at the limit of the data near $p/p^0 = 0.9$ the number of monolayers was between 2.5 and 3.0.

Condensation. Condensation of water vapor on sorbent particles may occur through either of two reversible processes. The first of these is capillary condensation due to the presence of small pores. The second process occurs if a deliquescent compound is present in the sorbent.

The equation governing the equilibrium of water vapor with liquid water under a concave surface, which exists when the walls of a pore are wetted, is as follows:

$$RT \ln p/p^0 = -2\sigma V/r \quad (2.19)$$

5914-43

Figure 2.5. Water vapor adsorption on $\text{Ca}(\text{OH})_2$ and CaCO_3 at 158°F .²³

where σ = surface tension of water
 V = molar volume of water
 r = radius of curvature of the surface.

For a pore that has a radius of $0.1 \mu\text{m}$, the value of p/p^0 is approximately 0.99; for a radius of $1.0 \mu\text{m}$, p/p^0 is approximately 0.999. It is thus apparent that a very close approach to saturation is required to produce significant capillary condensation.

Condensation due to the presence of a deliquescent compound may produce far more dramatic results. The effects of LiCl and NaCl as additives to Ca(OH)_2 at a mole fraction of 0.1 are depicted in Figure 2.6. The experimental data were obtained at Southern Research Institute;⁹ the curves predict the effects of condensation, based on equilibrium vapor pressure data of aqueous solutions of LiCl and NaCl. LiCl is more strongly deliquescent than NaCl; with LiCl condensation occurs if p/p^0 exceeds 0.10, whereas with NaCl it takes place only if p/p^0 exceeds 0.75. Even at a modest value of p/p^0 of 0.50, LiCl causes a 14% increment in sorbent weight due to the condensation of water vapor.

In addition to the reversible processes, transient condensation may occur if sorbent particles are injected into flue gas at a temperature that is below the dew point of the flue gas. Such an event may occur, for example, when dry sorbent is injected at a point downstream from a water spray, as in one of the two modes of dry injection investigated by Dravo.⁷ If, for example, the gas is cooled to 140°F and humidified to $p/p^0 = 0.70$ (an approach to saturation of about 15°F), a particle of Ca(OH)_2 injected at 75°F will be below the dew point until the particle temperature rises to about 125°F . The maximum quantity of water that can condense can be calculated by equating 1) the enthalpy gain when Ca(OH)_2 is heated from 75 to 125°F and 2) the enthalpy loss when water vapor is condensed isothermally at 125°F . The enthalpy gain for 1 g of Ca(OH)_2 is about 6.7 cal; the enthalpy loss for 1 g of water is about 540 cal. Thus, 1 g of Ca(OH)_2 can pick up $6.7/540 = 0.0124$ g of liquid water. The weight increment is not large — only 1.24% of the weight of the Ca(OH)_2 .

Figure 2.6. Comparison of predicted and observed adsorption relationships of $\text{LiCl}/\text{Ca}(\text{OH})_2$ and $\text{NaCl}/\text{Ca}(\text{OH})_2$ systems at 140°F .

2.3.5 Solubilities of SO₂ and Ca(OH)₂ in Water

SO₂. Two of the standard reference works, the International Critical Tables²⁴ and Perry's Chemical Engineers' Handbook,²⁵ give only limited information about the solubility of SO₂ in water under the conditions of interest in flue-gas desulfurization. Both works give data only for temperatures of 120 °F and less, and both have little information at gas-phase concentrations of SO₂ below 10,000 ppm. The available data reveal the nonlinear relationship between the concentration in solution and the vapor concentration, which is due to ionization of dissolved SO₂; they give little definition, however, of the solubility relationship below a vapor concentration of 10,000 ppm.

Rabe and Harris²⁶ have published solubility data that are far more useful for problems in flue-gas desulfurization. Their tabulation of data covers the temperature range from 32 to 266 °F and the liquid concentration range from 0.01 g/100g H₂O upward. Data depicting total liquid-phase concentrations of SO₂ at 122 and 140 °F are shown by the solid curves in Figure 2.7. Projections of the liquid-phase concentrations of the molecular species SO₂ alone, exclusive of ionization products, are shown by the dashed lines. These lines are based on a mathematical equation for Henry's constant H, defined as $a(\text{SO}_2, \text{l})/a(\text{SO}_2, \text{g})$, where activity in the liquid state is relative to concentration on the molal scale and activity in the vapor state is relative to partial pressure in atmospheres. The temperature dependence of H is given by the equation:

$$\ln H = 2851.1/T - 9.3795 \quad (2.20)$$

Dissolved SO₂ undergoes two ionization reactions in water:

The first of these processes is dominant when the vapor dissolves in pure water; it is responsible for most of the enhancement in solubility over that of the molecular species SO₂. In other words, SO₂ and HSO₃⁻ are the principal

6715-7

Figure 2.7. Solubility of SO_2 in water.²⁶

dissolved species when the vapor dissolves in pure water. The equilibrium constants for the two ionization processes are discussed subsequently in Section 2.3.6.

Ca(OH)₂. Determination of the solubility of Ca(OH)₂ is a difficult problem and has caused considerable disagreement and uncertainty. Linke's solubility treatise²⁷ recognizes the work published by Bassett²⁸ as the most definitive; the results of Bassett's work will be presented here.

Bassett pointed out that divergent results are obtained when solubility is measured for coarsely crystalline Ca(OH)₂ or for finely sized Ca(OH)₂ from freshly slaked CaO. The latter material gives a higher measured solubility but, of course, the result is attributable to a metastable state. The coarse material gives the true solubility; however, the persistence of small particles — the slow growth to larger crystals — makes the higher solubility experimentally and technically significant.

Data on the true solubility of Ca(OH)₂, measured with coarse crystals, are presented in Figure 2.8. Solubilities 10-15% higher than those plotted were readily measured with fine crystals. The difference in solubilities of coarse and fine crystals is, of course, of potential significance in duct injection technology, when Ca(OH)₂ is injected in an aqueous slurry. The fine particles from freshly slaked CaO may dissolve more rapidly and also may maintain a somewhat higher concentration in the dissolved state.

2.3.6 Ion Dissociation and Precipitation Processes

The ion dissociation and precipitation processes occurring within a Ca(OH)₂ slurry droplet that are related to the removal of SO₂ from the gas phase are the following:

- Ionization of water

6715-4

Figure 2.8. Solubility of Ca(OH)_2 in water.²¹

- Two-step ionization of dissolved SO_2

- Two-step dissolution and ionization of $\text{Ca}(\text{OH})_2$

- Precipitation of dissolved Ca^{+2} and SO_3^{-2} ions

Equilibrium constants for these processes are shown in Figures 2.9 and 2.10 as functions of temperature in the range of interest. None of the equilibrium constants changes sharply with temperature; only the dissociation constant of water ($K_{2.23}$) changes by as much as a factor of 100 on going from 80 to 240 °F.

The ultimate reaction in the above sequence, the precipitation of Ca^{+2} and SO_3^{-2} ions, is impeded in certain ranges of pH because of reactions that convert these ions to other species. At high pH values, Ca^{+2} is converted to CaOH^+ by reaction with OH^- . At low pH values, SO_3^{-2} does not exist but is converted to SO_2 or HSO_3^- by reaction with H^+ . The distributions of SO_2 , HSO_3^- , and SO_3^{-2} and of Ca^{+2} and CaOH^+ as functions of pH at a temperature of 125 °F are shown in Figure 2.11. The pH values covered range from a minimum of 2.5 to a maximum of 11.5. The lower limit is controlled by an assumed SO_2 concentration of 2000 ppm in the gas phase as well as by the acid strength of dissolved SO_2 ; the upper limit is determined by the solubility of $\text{Ca}(\text{OH})_2$. The figure shows that Ca^{+2} and SO_3^{-2} are simultaneously the dominant species in the two distributions in only the pH range above pH 7.5. Below pH 7.5, HSO_3^- is the dominant species derived from SO_2 gas; undissociated hydrated SO_2 is of

Figure 2.9. Dissociation constants of water and dissolved SO_2 .

67116-11

Figure 2.10. Equilibrium constants for the dissolution of $Ca(OH)_2$ and the precipitation of $CaSO_3 \cdot \frac{1}{2}H_2O$. (Note: for $K_{2.28}$ the value plotted is $-\log K_{2.28}$; see Fahrenheit scale at top).

6716-12

Figure 2.11. Distributions of dissolved SO_2 and Ca^{+2} in various forms (temperature, 125 °F).

negligible importance, reaching a maximum fraction of 0.25 at the lowest pH (2.5). At high pH values, the maximum fraction of Ca^{+2} converted to CaOH^- is 0.33.

In the $\text{Ca}(\text{OH})_2$ slurry droplet, the pH will range from an acidic value at the interface with the gas to an alkaline value at the interface with $\text{Ca}(\text{OH})_2$ particles. A question of some importance is whether $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$ will be formed by precipitation in the acidic range where HSO_3^- is dominant over SO_3^{-2} ; in other words, the question is whether the following reaction will occur:

For this reaction the equilibrium constant $K_{2.29} = K_{2.25}K_{2.28}$. Obviously, the precipitation process will be less likely to occur the lower the pH, due to the reversal of the process as the H^+ concentration increases.

A factor expressing the precipitability of dissolved calcium and sulfur species may be defined as a modified solubility product $[\text{Ca}_t][\text{S}_t]$, where the terms denote the total concentrations of the calcium and sulfur constituents that are required to bring about the precipitation of $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$. This factor is approximately equal to the conventional solubility product $[\text{Ca}^{+2}][\text{SO}_3^{-2}]$ when Ca^{+2} and SO_3^{-2} ions are dominant, as at pH 9. The relative value of the factor increases in the low pH range, as shown in Figure 2.12, where HSO_3^- rather than SO_3^{-2} is dominant, since only a fraction of the total sulfur constituent exists as SO_3^{-2} ion. The relative value of the modified solubility product at pH 4, for example, is 2300, signifying that the product must be 2300 times as great at pH 4 as at pH 9 to bring about the precipitation of $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$.

This discussion contains no reaction of the formation of any solid bisulfite of calcium, which would be the product of reaction of dissolved calcium and sulfur at a mole ratio of $\text{Ca/S} = 0.5$, as suggested by the following hypothetical process:

Figure 2.12. Precipitability of $CaSO_3 \cdot \frac{1}{2}H_2O$ as a function of pH.

Bisulfites and so-called pyrosulfites, equivalent compounds the $S_2O_5^{-2}$, are known as salts of other metals but not of calcium.

2.4 KINETIC STUDIES

2.4.1 Chemical Forms of Sorbent

Sodium compounds. A sodium-based sorbent such as the bicarbonate ($NaHCO_3$) might be the sorbent of choice for duct injection technology on the basis of reactivity alone. Low-temperature injection of $NaHCO_3$ provides effective removal of SO_2 in plants burning low-sulfur coals. Effective removal of SO_2 occurs even when the sorbent is injected in the dry state.²⁹ Removal would certainly be more effective with $NaHCO_3$ injected wet rather than dry; it would surely be more effective with wet injection of $NaHCO_3$ than with wet injection of $Ca(OH)_2$, since $NaHCO_3$ is far more soluble. Injection of $NaHCO_3$ does, however, cause some difficulty from "brown plumes" that result from an enhanced emission of NO_2 .³⁰ Moreover, the process is not economical in much of the country, owing to the limited availability of the sorbent as a raw material, and it produces a less acceptable, more soluble waste product.

Calcium compounds. Since sodium compounds have limited utility, calcium compounds are the sorbents of choice for duct injection. The preeminent compound in this category is $Ca(OH)_2$, which is an industrial product resulting from the calcination of limestone ($CaCO_3$) and the hydration of the resulting lime (CaO). Clearly, from the point of view of cost, $CaCO_3$ or CaO would either be preferable to $Ca(OH)_2$. The discussion of $CaCO_3$ in Section 2.3.2 makes it evident that this compound has adequate thermodynamic reactivity for removing SO_2 effectively; the compound has the distinct disadvantage, however, of being far less soluble in water than $Ca(OH)_2$ and thus substantially less active kinetically. Investigators in Sweden have made serious studies of limestone for spray drying and found ways of achieving satisfactory reactivity, including the addition of $CaCl_2$ as a deliquescent additive;²³ these measures, however, are not likely to be adequate under the more severe time constraints of duct injection, especially when duct injection is coupled with an ESP instead of a baghouse. The use of CaO in place of $Ca(OH)_2$ for the wet mode of duct injection

tion may be entirely satisfactory; General Electric, for example, slaked CaO , converting it to Ca(OH)_2 for slurry injection in the rotary atomizer.³ It is certain, however, that CaO cannot be used in the dry mode of duct injection, because of the unacceptable particle size available commercially and because of competition between the highly exothermic hydration reaction and the SO_2 removal reaction in the duct.

In addition to Ca(OH)_2 , which is often referred to as calcitic hydrated lime, the commercial product known as pressure-hydrated dolomite lime (PHDL) has received significant attention for duct injection. PHDL may be represented as $\text{Ca(OH)}_2\text{-Mg(OH)}_2$ when it is derived from true dolomite, $\text{CaCO}_3\text{-MgCO}_3$; in general, however, PHDL will consist of more Ca(OH)_2 than of Mg(OH)_2 on the mole basis. Pressure hydration is the key to commercial processing of dolomitic lime (CaO-MgO), since MgO will not be hydrated unless a pressure vessel is employed. Bechtel at one time touted PHDL very highly for its duct injection process but later found that the calcitic hydrate might react more efficiently and also cause less problem from duct deposits.² CONSOL also has found calcitic hydrates preferable to PHDL.⁶ One source of difficulty with PHDL may be the limited solubility of Mg(OH)_2 , which is far lower than the solubility of Ca(OH)_2 ; the thermodynamic driving force for the reaction of Mg(OH)_2 with SO_2 is thus less than for the reaction of Ca(OH)_2 with SO_2 .

Ca(OH)_2 with additives. Numerous investigators have explored the possibility of modifying Ca(OH)_2 with additives to achieve more favorable kinetics in the reaction with SO_2 .³¹⁻³⁵ The investigations reported to date have been largely in the laboratory or in small pilot-scale reactors. There have been few efforts to utilize additives on a larger scale; those that have been reported have not been notably successful.

The type of additives that have been investigated may be classified as follows:

- Deliquescent inorganic salts and related inorganic salts.
- Sodium-containing basic compounds.

- Organic compounds.
- Oxidation catalysts.

There is some cross-classification among the compounds tested to date. NaOH, for example, is a deliquescent compound but, of greater significance, it is capable of reacting directly with SO₂ and thus augmenting the effect of Ca(OH)₂. Na₂CO₃ is capable of reacting with Ca(OH)₂ to produce the deliquescent product NaOH by a double-decomposition reaction:

Na₂CO₃ also can react directly with SO₂, just as NaOH does.

The majority of the compounds that have been evaluated fall into the first category above. Most of these salts, whether properly regarded as deliquescent or not, have been termed deliquescent by one or more investigators. The crucial point in the terminology is whether or not the affinity of a salt for water vapor is so high under the conditions of usage that it will cause the vapor to condense, dissolve the salt, and then distill into the resulting solution. A number of alkali salts, including LiCl and NaCl, have been found promising as additives under laboratory conditions and have been loosely referred to as deliquescent compounds; they differ widely, however, in affinities for water vapor, as indicated previously by the data for LiCl and NaCl in Figure 2.6. LiCl dissolves in condensed atmospheric moisture if the relative partial pressure p/p^0 exceeds 0.10, which means that the approach to saturation has to be no closer than 100 °F (refer to Figure 2.3). NaCl, on the other hand, will not dissolve in atmospheric moisture unless p/p^0 exceeds 0.75, which requires that the approach to saturation be as close as 10 °F (again, refer to Figure 2.3).

Yoon et al.³⁵ reported that several sodium salts produced beneficial effects with respect to SO₂ capture: NaOH, NaCl, NaNO₃, Na₂CO₃, and Na₂SO₃. These compounds were incorporated in Ca(OH)₂ either by slurring Ca(OH)₂ in water containing each of the additives or by hydrating CaO in water containing each additive. Their effects were evaluated in a laboratory differential

reactor; they increased the utilization of $\text{Ca}(\text{OH})_2$ by factors ranging from 30 to 100%. The thresholds of deliquescence of the compounds are compared in Figure 2.13. There was no correlation between the degrees of deliquescence for NaOH and NaCl and their effects on sorbent utilization, since the less deliquescent compound produced the higher utilization (114% rather than only 55%).

Ruiz-Alsop and Rochelle³⁴ have recognized that deliquescence is not the controlling property of certain beneficial additives. They found the most promising additives among the compounds they studied to be LiCl, KCl, NaCl, NaBr, and NaNO_3 . Of these, only LiCl can be considered a classical deliquescent salt. The authors speculated about effects of these salts other than deliquescence but were not able to specify which effects are dominant.

CaCl_2 is one of the more frequently investigated additives. It is a classical example of a deliquescent salt, dissolving in atmospheric moisture if p/p^0 exceeds 0.20. Studies at Southern Research⁹ have indicated, however, that CaCl_2 has less affinity for water vapor in combination with $\text{Ca}(\text{OH})_2$ than it does as a pure compound, requiring p/p^0 to exceed 0.60 before significant uptake of atmospheric moisture occurs in the mixture. The explanation for this anomaly may be the reaction between CaCl_2 and $\text{Ca}(\text{OH})_2$ to produce a basic salt, $\text{Ca}(\text{OH})_2 \cdot \text{CaCl}_2 \cdot \text{H}_2\text{O}$, which does not have a strong affinity for water vapor.

With NaOH, one must be concerned with the question of whether the compound produces an effect on SO_2 removal that exceeds its capacity for direct reaction with SO_2 . In other words, does NaOH merely serve as a supplemental base, or does it enhance the reactivity of $\text{Ca}(\text{OH})_2$? In early work in a field installation at the 1-MW scale by Yoon et al.,³⁶ the residue from boiler-injected limestone was activated in a low-temperature duct with a water spray containing dissolved NaOH; the effect of the NaOH was no more than could be accounted for by the conversion of NaOH to Na_2SO_3 or Na_2SO_4 . In later work in a research facility at the 0.5-MW scale by the same investigators,³⁷ $\text{Ca}(\text{OH})_2$ was injected in the dry state and activated by a water spray containing NaOH; some of the data indicate that NaOH itself not only reacted but imparted incremental reactivity to the $\text{Ca}(\text{OH})_2$. The ability of NaOH to affect $\text{Ca}(\text{OH})_2$, however, probably must be considered marginal at best.

5914-83

Figure 2.13. *Ranges of deliquescence of various sodium compounds at 140 °F (deliquescence occurs in shaded range of p/p^0).^a*

Organic additives that have been investigated include sucrose, glycerin, and adipic acid.³⁵ Still another compound that has been used in preparing $\text{Ca}(\text{OH})_2$ is methanol;^{7, 31} incorporation of methanol in the water used for hydrating CaO has the capacity of yielding a product with a substantially elevated surface area. Methanol, however, unlike the other compounds listed, does not remain in the product, since it is volatilized as the $\text{Ca}(\text{OH})_2$ product is dried. Sucrose can have a minor effect on the surface area of $\text{Ca}(\text{OH})_2$; glycerin may attract water, but the role of adipic acid is unclear. One laboratory showed sucrose, glycerin, and adipic acid to have little favorable effect on SO_2 capture or even a negative effect.³⁵ Another small-scale pilot study indicated that the combination of methanol and sucrose was promising;⁷ however, when a larger scale study was undertaken by the same investigators, the organic additives were not used further.⁸

Oxidation catalysts that have been incorporated in calcium-based sorbents include $\text{Co}(\text{NO}_3)_2$ ³⁸ and V_2O_5 .³⁹ Either was intended to convert SO_2 to SO_3 ; the use of the cobalt salt seems to have been more fully developed. The original intent of using the cobalt salt was to obtain a commercially useful product, CaSO_4 , rather than CaSO_3 . Experiments showed that another advantage of using the cobalt salt was that SO_2 was taken up by the sorbent much more effectively. This effect was attributed to the release of acid, which increases the dissolution rate of CaCO_3 in slurry droplets. A mechanism for the effect may be the oxidation of bisulfite to bisulfate, with the attendant release of acid:

Two fundamentally different ways to introduce additives have been employed. One technique is to dissolve the additive (usually NaOH) in the water to be sprayed into a duct for humidification.³⁶ Obviously, a spray of NaOH solution is likely to remove SO_2 from the gas phase without influencing a separately injected calcium-based sorbent at all; any effect of the NaOH on the calcium-based sorbent per se must depend upon collisions between the spray droplets and the solid sorbent particles. The other technique involves combining the additive and the sorbent before the sorbent is injected; this has been the usual procedure with deliquescent salts.³⁵ If $\text{Ca}(\text{OH})_2$ is the sorbent,

it may be mixed with a soluble additive in a slurry and then dried before injection; alternatively, it may be formed by hydrating CaO in water containing a soluble additive. Published data suggest that whether the addition is made before or after hydration occurs makes a difference on the reactivity of the Ca(OH)_2 ; data for CaCl_2 suggest that it must be added prior to hydration, because otherwise it affects surface area adversely.

Investigators at CONSOL have been the most faithful to the use of additives. Apart from laboratory studies, however, their practical applications have been based mainly on NaOH and that compound only as a component of the water spray used for duct humidification. NaOH -containing sprays have been used in two types of applications — activation of spent sorbent from boiler injection and activation of Ca(OH)_2 from duct injection immediately upstream from the spray nozzles.³⁶ Investigators at Dravo found various additives promising in their small-scale pilot work, either NaOH in a water spray or additives incorporated in Ca(OH)_2 prior to injection.⁷ No additive was employed, however, in Dravo's 5-MW test of the HALT process.⁸

The EPRI program of pilot-scale studies of duct injection processes has included tests of additives. Blythe et al.,⁴⁰ however, have reported largely negative results with Ca(OH)_2 injection into ash-containing flue gas. They found surface area elevation with alcohols or sorbent modification with NaCl or CaCl_2 to provide not more than a 5% increase in the performance of Ca(OH)_2 . Giovanni et al.⁵ have reported similar negative results with Ca(OH)_2 injection into the clean gas environment of HYPAS.

Ca(OH)_2 with SiO_2 activation. SiO_2 is, in a sense, an additive that can make Ca(OH)_2 a more active sorbent. This compound, however, is more complex than the additives discussed above in that it is chemically combined with Ca(OH)_2 to produce a silicate, which becomes the active sorbent. The reaction between Ca(OH)_2 and SiO_2 is carried out in the presence of water, at an elevated temperature and, in some instances, an elevated pressure. Reactions between Ca(OH)_2 and SiO_2 in various chemical forms, especially including fly ash, and studies of the reactivities of the products with SO_2 have been the subject of numerous publications.^{41,42,43}

From a thermodynamic sense, it is surprising that converting Ca(OH)_2 to a silicate enhances rather than diminishes reactivity with SO_2 , as discussed previously in Section 2.3.2. SiO_2 , after all, is an acid, albeit a weaker acid than SO_2 ; thus, SiO_2 diminishes the thermodynamic potential for reaction with SO_2 . The key to enhanced reactivity, however, appears to be an increase in surface area. One investigation has shown that the reaction of Ca(OH)_2 with fly ash increases the surface area from 3 to 30 m^2/g ; the same study showed that SO_2 capture measured in moles of SO_2 per unit weight of the reaction product increased in proportion to the logarithm of the surface area.⁴²

Fly ash is a favored source of SiO_2 from the point of view that it is a naturally occurring waste product that can be put to effective use. Moreover, the use of fly ash with spent sorbent from furnace injection provides an attractive means of recycling the sorbent without the need for carrying out a physical separation. Other less complex sources of SiO_2 , however, have also been investigated; these include silicic acid and diatomaceous earth.

One factor that limits the practical utility of SiO_2 enhancement of Ca(OH)_2 is that the mass of sorbent required to achieve SO_2 removal is substantially increased. The weight ratio of fly ash to Ca(OH)_2 that is used to produce more effective sorbents may range up to 1:10. The quantity of sorbent that must be entrained in the gas stream and then removed in a dust collector is thus substantially increased. Reaching the higher ratios of ash to Ca(OH)_2 also means that an external source of ash is required for a recycle process. The weight ratio established at normal boiler injection rates will not suffice.

Enhancement of the reactivity of Ca(OH)_2 with SiO_2 has been more successfully substantiated in pilot tests than has enhancement with the other additives discussed above. EPRI-supported investigations have produced promising results with SiO_2 -modified Ca(OH)_2 .^{5,40} A pending pilot-scale test at Ohio Edison's Edgewater plant will evaluate a product known as ADVACATE, which has been developed under EPA auspices and most recently modified by production under pressure.⁴³

2.4.2 Physical Properties of Sorbent

Surface area. Specific surface area, as determined by the BET method, is the physical property of sorbents that has been most widely investigated as a factor influencing the rate of reaction with SO_2 . Most of the experimental work has been done with sorbents in the dry state, with the properties unaffected at any time by the presence of liquid water. In a few studies that have been conducted, however, the area has been measured for the dry solid and then reactivity has been measured after wetting has occurred.

Studies of dry solids with no exposure to liquid water have usually been conducted with the solids in a simulated filter cake, as on a fabric filter. In some experiments, the solids in a finely divided state have been allowed to react under differential conditions — that is, the solids are limited in mass and make no significant change in the composition of the gas flowing over them. In other experiments, the solids have been mixed with sand in a so-called sand-bed reactor, which minimizes channeling of the gas through the reactor bed, but makes no attempt to maintain differential conditions. Indeed, sometimes the measurement of reactivity may be the time required for SO_2 to break through the bed at a detectable concentration.

Examples of research procedures and experimental results that have been described in the literature are described in the following items:

- Yoon et al.³⁵ employed a differential reactor and measured the extent of utilization of commercial $\text{Ca}(\text{OH})_2$ materials as a function of reaction time at constant conditions of temperature, humidity, and SO_2 concentration. Utilization increased sharply initially but leveled off far from completion — in the range 20 to 30% in 10 to 60 min at 150 °F, 60% relative humidity, and 1000 ppm of SO_2 . A plot of limiting conversion level versus sorbent surface area yielded a straight line in the range 0-40 m^2/g .
- Borgwardt and Bruce⁴⁴ made measurements on commercial $\text{Ca}(\text{OH})_2$ materials by a similar procedure and reached similar conclusions.

- Klingspor et al.²³ placed limestone in a fixed bed and passed dilute SO_2 through at either of two values of water vapor partial pressure ($p/p^0 = 0.55$ or 0.78). The initial reaction rate was directly proportional to the surface area of the limestone in the range 0 to $20 \text{ m}^2/\text{g}$. The slope was approximately three times as great at $p/p^0 = 0.78$ as at $p/p^0 = 0.55$.
- Jozewicz et al.⁴³ used a sand bed reactor to investigate SiO_2 -enhanced $\text{Ca}(\text{OH})_2$ prepared from $\text{Ca}(\text{OH})_2$ and fly ash in water under pressure. The relationship between sorbent conversion and surface area showed two approximately linear segments with the slope higher in the range 0-15 m^2/g than in the range 15-30 m^2/g .

Blythe et al.³¹ reported a study of sorbents that were entrained in an SO_2 -containing gas stream and then deposited on a filter. The sorbents investigated included a commercial $\text{Ca}(\text{OH})_2$ material and several modified $\text{Ca}(\text{OH})_2$ materials that were produced in the laboratory by hydration techniques including alcohols and sucrose as additives; their surface areas ranged from 5 to $50 \text{ m}^2/\text{g}$. SO_2 removal was a linear function of surface area throughout the range investigated.

One of the few investigations of the influence of surface area with the sorbent in contact with liquid water was reported by Stouffer,⁶ as the result of sorbent screening for a demonstration of CONSOL's Coolside process. Samples of calcitic and dolomitic hydroxides were entrained in an SO_2 -containing gas stream, humidified with a downstream water spray, and then collected on a fabric filter. The water used in the spray was either plain water or a solution of NaOH . The results on SO_2 removal as a function of sorbent surface area with NaOH absent are depicted in Figure 2.14. The corresponding results obtained when NaOH was present showed no evident effect from surface area.

Porosity. The work of Stouffer et al.⁶ cited above included measurements of sorbent porosity by the use of the N_2 adsorption technique. This technique, it was said, provided a distribution of pore volume over the range of pore

6715-4

Figure 2.14. SO₂ removal as a function of sorbent surface area with spray humidification.⁶

diameters from 1.5 to 300 nm* and indicated that porosities ranged from 19 to 30% of total solid volume for the calcitic hydroxides investigated. SO₂ removal increased with sorbent porosity.

Particle size. There is no clear indication from the literature as to how important sorbent particle size may be to the low-temperature capture of SO₂. Seeker et al.³⁹ reported one of the few attempts to determine the effect of particle size on SO₂ capture; their work was done with the sorbent in a fixed bed and yielded results showing a significant superiority of particle sizes below 2 μm over those above 2 μm. The utilization of the smaller particles was approximately 25% higher than that of the larger particles.

One of the problems in correctly deducing the importance of particle size is that the state of subdivision of agglomerates in the suspended state will surely be more important as a determining factor than the distribution of particle sizes obtained in the laboratory. The range of mass-median particle size commonly found with commercial samples of Ca(OH)₂ is 1 to 10 μm; this range is not likely to bear much relation to the coarse sizes achieved with incompletely agglomerated particles from dry injection. The measurement really needed, therefore, for the dry injection of a sorbent is particle sizing in situ with an impactor. Data from measurements of this type are lacking.

Particle size may have an effect in wet injection that can be more easily hypothesized than documented. Smaller particles of Ca(OH)₂ have a higher solubility than coarse particles, as reported by Bassett;²⁸ they should also dissolve more rapidly since they will present a greater superficial surface area in contact with the liquid phase. Particle size may be a factor in the superiority reported by Bechtel for freshly slaked CaO over slurried Ca(OH)₂.²

2.4.3. Methods of Humidification

Investigators of low-temperature processes of SO₂ removal are agreed in their regard for humidification of flue gas as an essential means of achieving

*The paper cited may have a misprint. A more likely upper limit of pore diameters characterized by the N₂ adsorption technique is 30 nm, not 300 nm.

satisfactory results. They commonly use the parameter known as the approach to adiabatic saturation, measured as a temperature difference, as a measure of the degree of humidification. This parameter is an appropriate measure of humidification because usually humidification and cooling are brought about together by the evaporation of water — from either a spray of water droplets accompanying the dry injection of sorbent or a spray of aqueous slurry droplets giving the wet injection of sorbent.

Several illustrations will follow these introductory remarks showing the relationship of sorbent utilization or SO_2 removal versus the approach temperature. The functional relationships bear a striking resemblance to the relationship between the relative partial pressure of water (p/p^0) and the approach to saturation, which has already been illustrated in Figure 2.3.

Humidification with dry sorbent injection. A question of both theoretical and practical importance is how flue-gas humidification should be effected when sorbent is injected in the dry state. Can humidification be effective when water is present in only the vapor state, or must it be based on spray droplets that physically collide with the sorbent particles? Can a water spray be introduced with equal effectiveness either upstream or downstream of the sorbent?

One of the investigations that compared the effects of water in the vapor and liquid states was conducted by Yoon et al.⁴⁵ A pilot-scale combustor was operated with low-temperature $\text{Ca}(\text{OH})_2$ injection and with humidification from either steam or a water spray. When humidification was provided with steam, the burner was operated at a lower firing rate so that reaction temperature and humidity levels were comparable to those obtained with the water spray. The results comparing the effects of steam and water spray are shown schematically in Figure 2.15; they show that substantially higher SO_2 removal was accomplished with the water spray.

The data obtained with steam were interpreted in terms of the number of monolayers of water vapor adsorbed, based on the adsorption isotherms of Klingspor et al.²³ Plots of the concentrations of SO_2 removal versus the number of water monolayers was linear at each of two Ca/S ratios, in the range

6715-3

Figure 2.15. Removal of SO₂ with humidification by steam or water spray.⁴⁵

from 1.3 to 2.5 monolayers. The authors indicated that this relationship is empirical and is based on the assumption that adsorption equilibrium was maintained. Part of the water uptake by the sorbent could have been due, however, to transient condensation of water vapor on sorbent particles that were injected with a temperature below the flue-gas dew point. The maximum water uptake by this mechanism, although not large, can exceed that due to adsorption alone, as previously indicated in Section 2.3.4.

Another investigation that compared the effects of water in the vapor and liquid states was reported by Gooch et al.^{9,14} Two sorbents, fresh Ca(OH)_2 and partially sulfated calcine that resulted from earlier furnace injection of Ca(OH)_2 , were each injected at the inlet of a low-temperature reaction chamber. For conditioning by water vapor, the gas stream was enriched in water vapor and precooled before reaching the sorbent injector; for conditioning by liquid water, a spray was injected immediately downstream from the sorbent injector. For reference, in a third series of experiments, either sorbent was first slurried in water and injected in the wet form. In all experiments, the approach to saturation was about 30 °F. Increments in sorbent utilization were as follows:

	<u>Increment in utilization, %</u>	
	<u>Calcine</u>	<u>Ca(OH)_2</u>
Vapor	1	10
Spray	6	12
Slurry	33	28

The above data indicate that the two sorbents differed substantially in the ability to respond to vapor humidification. The partially sulfated calcine was essentially unresponsive to vapor, undoubtedly because of the shell of previously formed reaction product that existed on each particle. The increases in utilization observed when humidification occurred with the water spray are indicative of low efficiency in the collision process; the surprisingly low response of the Ca(OH)_2 to spray humidification is attributed to the inefficiency of the collision process. A comparison of spray and slurry results for the calcine led to the estimate that only 15% of the sorbent was wetted by the spray.

Several investigators have considered the question of whether a water spray should be introduced upstream or downstream from the sorbent injector. Babu et al.⁷ addressed the issue during the initial pilot testing of the HALT process; they reported that the removal of SO₂ was higher by 6 to 7% with the water spray at the downstream location. For example, at a Ca/S ratio of 2.0, the removal was 46% with an upstream spray or 53% with a downstream spray. Blythe et al.³¹ found that shifting the location of the spray from an upstream site to a downstream location increased SO₂ removal by as much as from 50 to 70%. The preference for the downstream spray location undoubtedly arises from the increased likelihood of collision between spray droplets and sorbent particles. If the spray location is upstream, a substantial degree of evaporation will occur before there is the possibility of collision with sorbent.

The most intensive large-scale investigation of spray humidification of dry sorbent was conducted by Babu et al.⁸ in testing Dravo's HALT process at a 5-MW pilot facility installed at Ohio Edison's Toronto steam plant. The final report from that work included a number of graphs that show sorbent utilization as a function of approach to saturation for test conditions approximately as follows: gas temperature, 275-350 °F; SO₂ concentration 2100-2900 ppm; and Ca/S ratio, 1.6-2.2. One graph is reproduced in Figure 2.16; it depicts the mathematical relationship based on a least-squares analysis that was used to represent the functional relationship between sorbent utilization and approach to saturation:

$$\eta = e^{(A-B\Delta t)} \quad (2.33)$$

where η - utilization

A, B - constants

Δt - approach to saturation

The limiting utilization of 24% shown here at an approach of 10 °F was typical of the results obtained at Ca/S ratios near 2.0; the corresponding removal of SO₂ is 48%, which is given by the relationship:

6716-14

Figure 2.16. Sorbent utilization versus approach to saturation as reported by Dravo.¹

$$\text{Utilization, \%} = \frac{\text{SO}_2 \text{ removal, \%}}{\text{Ca/S}} \quad (2.34)$$

The data from the Toronto test discussed above are based on the difference between SO₂ concentrations measured with gas analyzers upstream from the sorbent injector and downstream of an ESP. The contributions to the overall SO₂ removal by the suspended solids, deposited solids on the duct walls, and filter cake or ESP plate deposits are not indicated and, in general, were not determined. On a limited scale, however, representatives of Southern Research, working on a subcontract, found that only about half of the total removal occurred in the suspended phase. Specifically, a utilization of about 10% was found at an approach of 20 °F and Ca/S = 1.0 (about half of the value on the curve in Figure 2.16).

Humidification by wet sorbent injection. The two most thorough investigations of wet-sorbent injection have been conducted by Bechtel² and General Electric³ under DOE auspices. Bechtel investigated the Confined-Zone Dispersion (CZD) process, in which the slurry is meant to be dispersed by a spray nozzle within a duct but isolated from the duct walls with a sheath of hot gas; Bechtel's investigations were conducted at Consumer Power's Campbell Station at the 7-MW scale and at Pennsylvania Electric Company's Seward Station at the 70-MW scale. General Electric's process is termed the In-Duct Scrubbing (IDS) process; the heart of the IDS process is a rotary atomizer for dispersing the Ca(OH)₂ slurry. The IDS process was investigated in a 12-MW pilot facility installed at Ohio Edison's Muskingum River Station.

Bechtel correlated SO₂ removal, expressed as a fraction of the inlet concentration, with key variables in equations of the form below:

$$\text{Fractional SO}_2 \text{ removal} = K(\text{NWIR})^{0.85}(\text{Wt\%})^{0.45}(\text{Avg SO}_2)^{-0.4}(\text{AST})^{-0.4} \quad (2.35)$$

where K = coefficient for the selected sorbent type
(calcitic or dolomitic lime)

NWIR = "normalized water injection rate", expressed
as the ratio of water addition in gallons

per minute to gas flow in thousands of
standard cubic feet per minute.

Wt% - sorbent concentration in the slurry

Avg SO₂ - average of inlet and outlet SO₂ concentrations
in parts per million on the wet basis

AST - approach to adiabatic saturation in degrees
Fahrenheit.

The Bechtel equation fundamentally deals with the effects of two key parameters: the degree of humidification and the Ca/S ratio. The equation does not, however, contain either parameter as an explicit term. The effects of humidification appear in two terms, NWIR and AST; the effects of these two terms obviously cannot be independent, however, because the rate of water addition is a major factor in determining approach to saturation. The effects of the Ca/S ratio appear through three terms — NWIR and Wt%, which introduce the quantity of sorbent in the numerator, and Avg SO₂, which indirectly places the inlet concentration in the denominator but not in a simple form.

General Electric derived a theoretical equation relating the fractional removal of SO₂ within the evaporation zone to the degree of humidification and the Ca/S ratio, with the following form:

$$-\ln(1 - E) = a S \ln [(T_1 - T_{as})/(T_2 - T_{as})] \quad (2.36)$$

where E - fractional SO₂ removal

a - constant

S - Ca/S ratio

T₁ - initial gas temperature

T₂ - final gas temperature

T_{as} - adiabatic saturation temperature

(the difference T₂ - T_{as}, then,
is the approach to saturation).

Practical experience showed, however, that the theoretical equation could be usefully modified by the empirical addition of an exponent:

$$-\ln(1 - E) = a X^b \quad (2.37)$$

where b = constant

$$X = S \ln[(T_1 - T_{as})/(T_2 - T_{as})]$$

With the empirical modification, the equation was used satisfactorily for correlating SO_2 removal with Ca/S and approach to saturation both within the evaporation zone and the total system, including an ESP.

Neither the Bechtel investigation nor the General Electric investigation was as thorough as the Dravo study in varying the approach to saturation. The Bechtel report states that AST ranged from 25 to 55 °F; however, the report clearly shows that the majority of the data points were taken at $\text{AST} = 35$ °F. For calcitic hydroxide as the sorbent under investigation at Campbell, 71 experiments are summarized, but only 8 experiments involved AST values different from 35 °F (these were either 25 or 45 °F). Nevertheless, the equation presented above (with $K = 24.4$ for the calcitic sorbent, based on data from the Campbell station) has been used in this review to estimate sorbent utilizations in the approach range 10-50 °F. An initial SO_2 concentration of 1500 ppm (within the actual range at Campbell) was assumed. The results for Ca/S ratios of 1.0 and 2.0 are presented in Figure 2.17. The curves based on the Bechtel data rise much more sharply than those based on the Dravo data (Figure 2.16) as the approach nears 10 °F; they are obviously unrealistic in that by extrapolation they would yield impossible results at close approaches to saturation — a utilization above 100% at $\text{Ca/S} = 1.0$ or a utilization above 50% at $\text{Ca/S} = 2.0$. In the range where actual data were obtained, however, the curve at $\text{Ca/S} = 2.0$ still shows utilizations that are higher than those found by Dravo (see Figure 2.16). That graph is also consistent with one of the main conclusions in the Bechtel report, to the effect that a utilization of 45% (50% SO_2 removal) is attainable at $\text{Ca/S} = 1.1$.

The General Electric study, at SO_2 concentrations around 2000 ppm, was based on approaches to saturation not less than 40°F. Even so, the semiempirical equation given above from the General Electric report ($a = 0.50$, $b = 0.675$) was used in this review to calculate sorbent utilizations at approaches down to

Figure 2.17. Sorbent utilization versus approach to saturation based on the Bechtel correlation¹ (Equation 2.35).

10 °F; the results are plotted in Figure 2.18. The curves for Ca/S values of 1.0 and 2.0 do not rise sharply near a 10 °F approach and in this sense are similar to those of Dravo; however, the General Electric curve for Ca/S = 2.0 and an approach of 20 °F predicts a utilization of 37% (74% SO₂ removal), whereas the Dravo curve shows a utilization of only 21% (42% SO₂ removal).

The estimates of sorbent utilization given in Figures 2.17 and 2.18 from the Bechtel and General Electric studies of slurry injection include the effects that occur in an ESP. The Bechtel reports estimates that 5% of the observed SO₂ removal occurred in the ESP, and the General Electric report estimates that 10 to 20% occurred in the ESP. Neither report provides any basis for assessing the contributions of wall deposits; hence, any attempt to apply the results to larger-scale operations is risky, since contributions from wall deposits could differ markedly.

2.4.4 Control of Ca/S Mole Ratio

An obvious way to increase the removal of SO₂ is to increase the relative quantity of sorbent supplied to the desulfurization system. The effects of increasing the Ca/S ratio under the conditions investigated by Bechtel and General Electric were indicated previously, in an indirect way, by Figures 2.17 and 2.18. In Figure 2.18, for example, the sorbent utilizations at a 40 °F approach to saturation are 48% at Ca/S = 1.0 and 32% at Ca/S = 2.0. Through the relationship given by Equation 2.34, the corresponding SO₂ removals are 48% at Ca/S = 1.0 and 64% at Ca/S = 2.0.

The above examples are qualitatively typical of the results to be expected as the Ca/S ratio is increased; that is, the SO₂ removal increases as the Ca/S ratio increases, but it does not increase proportionally. The literature gives occasional exceptions to this generalization. For example, a paper by Yoon et al.⁴⁵ indicates that SO₂ removal increases proportionally as Ca/S increases when humidification occurs with steam rather than with a water spray. In addition, the final report on the testing of Dravo's HALT process⁶ indicates that differences in utilization at different Ca/S ratios tend to vanish if the approach to saturation is brought near 10 °F; utilizations in the narrow range

6716-16

Figure 2.18. Sorbent utilization versus approach to saturation based on the General Electric correlation¹ (Equation 2.37).

from 25 to 27% were found at an approach of 10 °F in one series of tests with Ca/S ratios ranging from 1.74 to 2.05. These data indicate near linearity between the SO₂ removal and the Ca/S ratio. By and large, however, the available data show that an excess of sorbent is used inefficiently and that the inefficiency increases as the excess increases.

The dependence of SO₂ removal on Ca/S ratio at a fixed approach to saturation, is illustrated in Figure 2.19. One curve is based on Equation 2.35 from the Bechtel report² for an approach of 35 °F, where most of Bechtel's data were collected (the curve crosses the line for 100% utilization at Ca/S < 0.3 and is therefore unrealistic in that range). The other curve is based on Equation 2.37 from the General Electric report³ for an approach of 40 °F, the minimum investigated. The predictions are quite similar, notwithstanding the substantial difference in the SO₂ concentrations encountered in the two investigations — around 2000 ppm by Bechtel and nearly 4000 ppm by General Electric.

It is of interest to compare the predictions discussed above, for wet sorbent injection, with the results for dry sorbent injection accompanied by downstream humidification with a water spray, as found in the Dravo investigation at an approach of 30 °F.⁸ A bar is shown in Figure 2.19 to indicate the approximate range of results reported by Dravo at Ca/S = 1.8. There is a strong implication that dry injection cannot give the extent of removal that wet injection can.

It may be noted that on one occasion General Electric has chosen to represent the relationship between SO₂ removal and Ca/S ratio as a straight line.¹ This was done, however, in the Ca/S range from 0.4 to 1.6 and with a line that did not extrapolate to the origin. The relationship in Figure 2.19 can be approximated by a straight line in the same Ca/S range.

2.5 REVIEW OF MATHEMATICAL MODELS

2.5.1 Removal of SO₂ with Sorbent

For the purposes of this discussion, the mathematical models on SO₂ removal have been divided into two categories: (1) models dealing with spray

6715-10

Figure 2.19. SO₂ removal as a function of Ca/S ratio.

drying and other lime slurry desulfurization processes, and (2) models dealing with sorbent/droplet collision in the separate injection of lime and water. The discussion of spray drying models will include both rigorous and empirical approaches, since either approach may be useful under certain circumstances. To allow the reader to understand the key features and differences in these models, the discussion will include the essential governing equations and limiting assumptions for each case. The discussion of spray drying and slurry models will conclude with a summary of the current state of the modeling and the needs for further improvement. Although a considerable amount of work has been done in the area of spray dryer modeling, it will be evident from this discussion that major deficiencies remain in the treatments of the fluid mechanics, droplet dispersion, and the role of the liquid-phase resistance to mass transfer.

Much less work has been done on modeling sorbent/droplet collision in the dry injection process. Only one model has been described in detail in the literature, and it will be the basis for the discussion given here. Again, this discussion will include the key governing equations, as well as the limiting assumptions used in their derivation. The model will be used to illustrate certain concepts, such as the notion of an optimum droplet size to maximize sorbent/droplet collision. While its usefulness will be apparent, it will also be evident that it is deficient in its treatment of the two-fluid jet dynamics and droplet trajectories. These are key issues that need to be addressed in both the collision and absorption models before they can be coupled to create an overall duct injection process model.

2.5.1.1 Models of lime slurry spray drying and desulfurization

Current models of lime slurry spray drying and desulfurization are based on the qualitative description originated by Getler, Shelton, and Furlong in 1979.⁴⁶ Based on x-ray analysis of spray dryer reaction products, they suggested that the reaction between SO_2 and lime slurry takes place in two steps. In the first step, the rate of reaction is controlled by either the rate of gas-phase diffusion or the rate of dissolution of the solid $\text{Ca}(\text{OH})_2$ particles. The rate of gas-phase diffusion is controlled by the SO_2 concentration and the relative velocity between the slurry droplet and the gas. The rate of lime

dissolution is limited by the build up of sulfite reaction product on the surface of the Ca(OH)_2 particles. Most of the water is evaporated during the first step, leaving behind a porous agglomerate of Ca(OH)_2 particles. In the second step, the reaction is controlled by pore diffusion and diffusion through the sulfite product layer. Pore diffusion becomes progressively more important as the particles expand and pores fill due to the larger molar volume of the reaction product (as compared to the lime).

The assertion that a sulfite surface layer controlled the rate of lime dissolution was later refuted by Downs, Sanders, and Miller.⁴⁷ In their scanning electron photomicrographs, they found many free-standing crystals of calcium sulfite (and sulfate) that were not attached to the lime particle surface. Based on this finding, they concluded that the aqueous ionic reactions were more important than the reaction at the solid/liquid interface. They also associated the two reaction steps discussed above with the two stages of drying, the constant rate period and the falling rate period. They also suggested a third stage of reaction after the particles had reached an equilibrium moisture content. It is this third stage that accounts for SO_2 removal across a baghouse, after the particles are nominally dry.

Downs et al.⁴⁷ derived a simple model based on the assumption that all the SO_2 absorption takes place during the first drying stage. The model assumed that the absorption rate was controlled only by gas-phase diffusion, and the evaporation rate was limited by convective heat transfer. Under these conditions, the removal efficiency, E , was given by the simple relation:

$$-\ln(1 - E) = \frac{D_v N_{Sh}}{\alpha N_{Nu}} \ln \frac{T_{in} - T_{sat}}{T_{out} - T_{sat}} \quad (2.38)$$

where D_v is the diffusivity of SO_2 ; α is the thermal diffusivity; N_{Sh} is the Sherwood number for SO_2 absorption; N_{Nu} is the Nusselt number for convective heat transfer; and T_{in} , T_{out} , and T_{sat} are the inlet, outlet, and saturation temperatures of the gas. When tested against 20 sets of pilot plant data obtained over a range of conditions, this simple model greatly underestimated

the SO₂ removal. This suggested that the constant-rate period is not the predominant stage for SO₂ absorption.

In a more empirical approach, Downs et al.⁴⁷ successfully correlated pilot plant data in terms of the lime specific surface area, S_p; the stoichiometric lime-to-sulfur ratio, S_r; and the residence time, t.

$$\ln (1 - E) = - K S_p S_r t \quad (2.39)$$

where K is a proportionality constant that depends on the approach to saturation. Using this empirical relation, it was possible to accurately correlate the pilot plant data in two groups: one with a 18 to 21 °F approach, and one with a 29 to 34 °F approach.

Using a modified version of Equation (2.38) above, Samuel et al.⁴⁸ were able to successfully correlate data from a prototype spray dryer installed on a 8500-acfm slipstream of flue gas from a 85-MW pc-fired utility boiler. Their modified equation (equivalent to Equation 2.36, which was given previously) may be written as follows:

$$-\ln (1 - E) = A X_c S_r \ln \frac{T_{in} - T_{sat}}{T_{out} - T_{sat}} \quad (2.40)$$

where A is given by the relation

$$A = k_r C_p / N_{Nu} k_t \quad (2.41)$$

in which k_r is the reaction rate constant, C_p is the flue gas heat capacity, N_{Nu} is the Nusselt number for heat transfer, and k_t is the thermal conductivity of the flue gas. The term X_c is related to the initial droplet diameter, D_i, and the final diameter of the dried reaction product, D_f, by the relation

$$X_c = 1 - D_f^3 / D_i^3 \quad (2.42)$$

The value of X_0 approaches unity for low slurry concentrations. It is treated as a constant in correlating data for a single lime slurry concentration. Equation (2.40) was used to correlate all the data at a given inlet SO_2 concentration, yielding a series of curves for concentrations of 500, 1000, 1500, 2000, and 2500 ppm. The regression coefficients for all curves exceeded 0.9. This approach, as applied by Samuel et al., requires estimation of the value of X_0 for each set of runs. The value can be estimated from the lime slurry concentration, the slurry density, and the reaction product density, or X_0 can be treated as an adjustable parameter.

While the approaches discussed above are useful for correlating field data and even extrapolating to certain conditions, they do not provide a mechanistic understanding of the spray drying and desulfurization processes. The first attempt to derive a truly mechanistic representation appears to be that of Josewicz and Rochelle in 1984.⁴⁹ They used the analogy between mass and heat transfer to relate the local change in SO_2 concentration to the local change in gas temperature in a concurrent mode of gas/liquid contacting. This resulted in a relation similar to Downs' Equation (2.38) above, except that it was applied to small differential elements within the spray dryer.

$$dY_{\text{SO}_2}/Y_{\text{SO}_2} = 1 - \exp(-0.6 N_Q) \quad (2.43)$$

where dY_{SO_2} is the differential change in the mole fraction of SO_2 , and N_Q is the number of heat transfer units, which is given by

$$N_Q = \ln \frac{T_{\text{in}} - T_{\text{sat}}}{T_{\text{out}} - T_{\text{sat}}} \quad (2.44)$$

where Y_{SO_2} , T_{in} , and T_{out} represent local values within a differential element. If the ratio of the Sherwood and Nusselt numbers is taken to be unity (in accordance with the mass/heat transfer analogy), and the ratio of mass and thermal diffusivities is taken to be 0.62 (typical for flue gas), it may be shown that Equations (2.43) and (2.44) are the differential equivalents of Equation (2.38). Since the SO_2 concentration and gas temperature are both

changing and are related by these equations, a differential treatment is clearly called for.

To obtain the overall SO₂ removal, Josewicz and Rochelle integrated Equation (2.43) with respect to the interfacial surface area, a , as follows:

$$E = \frac{1}{a} \int [1 - \exp(-0.6 N_Q)] da \quad (2.45)$$

A similar expression may be derived for the amount of water evaporated. Other forms of these relations may also be derived for cross-flow and back-mixed modes of contacting. However, Josewicz and Rochelle showed that the concurrent relations gave a better simulation of spray dryer SO₂ removal. The concurrent mode would also be expected to be more appropriate for duct injection.

There is one serious flaw in the above treatment of the concurrent contacting case; it assumes that the droplet motion is completely governed by the gas flow (i.e., there is no relative velocity between the droplet and gas). This is far removed from reality, at least near the atomizer where the droplets are still decelerating. In a dry duct injection process, all the sorbent/droplet contacting would take place in this region. If SO₂ absorption did not commence until after contacting and deceleration, the assumption of zero relative velocity may not seriously impact the absorption calculations. Therefore, it may still be possible to directly couple the spray dryer equations with a treatment of inertial impaction in a duct injection process.

In the Josewicz and Rochelle treatment, the rate of lime dissolution was also evaluated. If this rate exceeded some critical value, the SO₂ absorption was predicted by the equations for gas-phase diffusion control. No other liquid-phase resistances to mass transfer were considered by Josewicz and Rochelle.

Comparison of the Josewicz and Rochelle modeling with test data revealed that the model generally under-predicted actual performance. It was suggested

that this was due to additional reaction after all the "unbound" moisture was evaporated. This is analogous to Downs' third period of drying, which is said to account for reaction across the bag filters. Two of the cases used for model validation also used ash recycle, which is not taken into account in the model. A crude attempt to empirically correlate data with recycle was included in the work of Samuel et al.⁴⁸

Damle¹³ presented the first user-oriented, comprehensive mathematical model of spray dryer desulfurization in 1985. This model is based on fundamental treatments of the slurry droplet evaporation and the SO₂ absorption/reaction mechanisms. A flowchart of the Damle model is given in Figure 2.20. In deriving this model, Damle considered the mass transfer resistances imposed by gas-phase diffusion, lime dissolution, and liquid-phase mass transfer. Based on an estimate of the degree of chemical enhancement of the liquid-phase mass transfer, Damle concluded that the liquid-phase mass transfer resistance was negligible, so that either gas-phase diffusion or lime dissolution was the controlling step. However, his analysis is based on an assumed liquid film thickness of 1 μm . As the reaction proceeds, and sulfite penetrates further into the film, the effective distance for diffusion is increased, and the liquid-phase resistance may become appreciable. This effect will be discussed in more detail in conjunction with some of the more recent modeling efforts.

The Damle model addresses SO₂ removal in all three stages of drying (constant rate, falling rate, and equilibrium moisture). The early deceleration of the droplet is ignored in all calculations because this period is said to be quite short (less than 0.1 s). This enables Damle to use the approximation that the Sherwood and Nusselt numbers are both equal to 2. Thus, simple expressions can be derived to relate the mass and heat transfer coefficients to the diffusivities (of water vapor and SO₂) and the thermal conductivity of the gas. These expressions are used to calculate the rates of drying and SO₂ absorption during the first stage of the process. The rate of SO₂ absorption must also be corrected for the effect of water evaporation on SO₂ diffusion. The net rates are given by:

6716-17

Figure 2.20. Flowchart for Program SPRAYMOD.

$$N_w = 2 \pi D_{H_2O} c d_p \ln \frac{1 - x_{s,w}}{1 - x_{d,w}} \quad (2.46)$$

$$N_s = \frac{x_{s,s} N_w}{F - 1} - \frac{N_w x_{d,s} F}{F - 1} \quad (2.47)$$

$$F = \exp (N_w / 2 \pi D_{SO_2} c d_p) \quad (2.48)$$

where N_w , N_s = molar rates of water evaporation and SO_2 absorption, respectively;

D_{H_2O} , D_{SO_2} = diffusivities of water vapor and SO_2 ;

$x_{s,w}$, $x_{d,w}$ = water vapor mole fractions in bulk and at surface;

d_p = droplet diameter;

c = mean molar density of the gas phase;

$x_{s,s}$, $x_{d,s}$ = SO_2 mole fractions in bulk and at surface.

The above equations are applied during the constant rate period of drying for calculations of N_w and during the wet-particle stage for calculations of N_s . During the falling rate period, the drying rate, N_w , is adjusted by multiplying by the term

$$(X - X_c) / (X_e - X_c)$$

where X is the solids moisture content at time t , X_e is the equilibrium moisture content, and X_c is the critical moisture content at which the solid particles come into contact. For spherical particles arranged in a cubical pattern,

$X_0 = 0.476$. The equilibrium moisture content, X_0 , can vary over a wide range from 0.5% to 20% and is related to the relative humidity or approach to saturation in the flue gas.

The Damle model also includes calculation of the lime dissolution rate based on the diffusivity of lime in water and the lime concentration gradient across the liquid film. However, the film thickness is not adjusted to compensate for the penetration of sulfite into the liquid film. This reduces the distance that fresh lime diffuses away from the solid particle, and increases the distance that SO_2 must diffuse into the liquid to reach the lime. Thus, in the latter stages of reaction, the liquid-phase resistance could become more important than Damle's analysis would indicate.

During the dry-particle stage, Damle treats the SO_2 removal process by a simplified approach using a bulk-volume reactivity, K_r . This reactivity constant is, in effect, a proportionality constant between the rate of SO_2 removal and the product of the gas-phase SO_2 concentration and the concentration of remaining lime.

$$N_s = K_r \frac{\pi d_p^3}{6} C_{\text{SO}_2} C_{\text{Ca(OH)}_2} \quad (2.49)$$

The value of K_r must be determined experimentally. This is a very simplistic approach compared to the rigorous analyses of diffusion in porous solids used by others who have addressed this problem (cf, Ruiz-Alsop and Rochelle.⁵⁰

The SO_2 absorption during the semi-dry stage has been most rigorously simulated by a shrinking core model with treatment of gas-film diffusion, product layer diffusion, and chemical reaction. Ruiz-Alsop and Rochelle⁵⁰ solved the governing differential equations for the case of combined gas-film and product layer control (i.e., infinitely fast chemical reaction) and chemical reaction control. The resulting model contains two unknown parameters: the effective diffusivity of SO_2 through the product layer, D_p , and the kinetic

rate constant, k_s . Ruiz-Alsop and Rochelle determined the values of these parameters by comparison of the modeling results with experimental data from a fixed bed reactor in which SO_2 was absorbed on pure $\text{Ca}(\text{OH})_2$. Their studies showed that reaction kinetics were controlling at high relative humidities and high SO_2 concentrations, while product layer diffusion was controlling at low relative humidities and low SO_2 concentrations. The governing equations that were derived for two limiting cases are given below:

Chemical kinetics controlling —

$$-\frac{dN_{\text{SO}_2}}{dt} = 4 \pi R^2 \rho_{\text{lime}} k_s X_{\text{lime}}^{2/3} \quad (2.50)$$

Gas-film and product-layer diffusion controlling —

$$-\frac{dN_{\text{SO}_2}}{dt} = \frac{C_{\text{SO}_2}^s}{\frac{X_{\text{lime}}^{-1/3} - 1}{4 \pi D_o N R} + \frac{1}{4 \pi R^2 k_s N}} \quad (2.51)$$

where $-dN_{\text{SO}_2}/dt$ = molar rate of removal of SO_2 ;

R = radius of particle;

k_s = mass transfer coefficient;

N = number of lime particles;

ρ_{lime} = molar density of $\text{Ca}(\text{OH})_2$;

k_s = kinetic rate constant;

X_{lime} = fraction of $\text{Ca}(\text{OH})_2$ converted;

C_{SO_2} = concentration of SO_2 in the bulk gas; and

D_e = effective diffusivity of SO_2
through product layer.

Ruiz-Alsop and Rochelle also modified these equations by introducing an empirical correction factor to account for the non-spherical shape and surface roughness of the lime particles.

All of the modeling efforts discussed above have concentrated on the mass transfer aspects with little regard for the actual fluid mechanics and droplet behavior. In fact, all of the above treatments have dealt with a single droplet size, with the tacit assumption that the mean size will adequately represent the entire droplet size distribution. This is far removed from reality.

Yoon et al.³⁵ used a commercial fluid flow modeling package ("FLUENT" developed by Creare, Inc.) to simulate the fluid mechanics and droplet behavior produced by dual-fluid atomization of water into a duct configuration. Their results showed that good dispersion of the droplets is not a given and requires careful optimization of the injection velocity. At low injection velocities, dispersion was found to be poor. This resulted in a core of droplets surrounded by highly humidified gas, thus retarding evaporation and resulting in the carry over and wall deposition of droplets. Yoon et al. also showed that the behavior of a polydisperse spray was markedly different from that of a monodisperse spray of the mean droplet size. These two cases differed significantly in terms of predicted droplet dispersion and evaporation. Therefore, there is clearly a need to incorporate these fluid mechanic considerations into existing models of spray dryer desulfurization. The models also need to be expanded to account for the entire droplet size distribution, rather than operating on a single size droplet.

The modeling efforts discussed above have also been lacking in their treatment of the resistance to mass transfer in the liquid phase. Damle dismissed this resistance based on an estimate of the chemical enhancement factor for a constant film thickness. Other workers neglected the liquid-phase resistance entirely without good reason. In 1986, Harriott and Kinzey⁵¹ presented a

new model that took into account the variable resistance to mass transfer in the liquid phase. They pointed out that SO_2 must diffuse from the gas/liquid interface to a reaction front within the droplet, the location of which varies as OH^- ion is consumed by dissolved SO_2 . They presented the following expression for the rate of advancement of the reaction front into the droplet.

$$-\frac{d}{dt} \left[C_1 \frac{\pi d_r^3}{6} \right] = -N_s \pi d_p^2 \quad (2.52)$$

where C_1 is the lime concentration in the unreacted core;

d_r is the diameter of the reaction front;

N_s is the molar flux of SO_2 ; and

d_p is the drop diameter.

The left hand side of Equation (2.52) represents the molar lime consumption rate, and the right hand side represents the rate of SO_2 absorption. This equation applies in the shrinking droplet stage, corresponding roughly to the constant rate drying period. It is used to predict the diffusion (film) thickness that is used to calculate the liquid-phase SO_2 mass transfer coefficient. The film thickness, δ , is related to the droplet diameter, d_p , and the reaction front diameter, d_r , by the following:

$$\delta = \frac{d_p (d_p/d_r - 1)}{2} \quad (2.53)$$

This film thickness, together with the diffusivity of H_2SO_3 (dissolved SO_2), determine the liquid-phase mass transfer coefficient, k_1 , by the following:

$$k_1 = \frac{D_{H_2SO_3}}{\delta} (1 + \Phi) \quad (2.54)$$

where Φ represents an enhancement factor due to ionization.

$$\Phi = \frac{C_{H_2SO_3} - D_{H_2SO_3}}{C_{H_2SO_3} D_{H_2SO_3}} \quad (2.55)$$

where C denotes the molar concentration and D denotes the diffusivity.

The liquid-phase resistance is then treated as a series resistance with the gas-phase resistance, resulting in the following expression for the overall mass transfer coefficient, K_s :

$$\frac{1}{K_s} = \frac{1}{k_g} + \frac{H}{k_l RT} \quad (2.56)$$

where K_s , k_g , and k_l denote the overall, the gas-phase, and the liquid-phase mass transfer coefficients; H is the Henry's Law constant for absorption of SO_2 into water; R is the ideal gas constant; and T is the temperature.

During the constant drop size stage, which corresponds roughly to the falling rate drying period, an additional term is added in the series resistances to account for the effective mass transfer coefficient of SO_2 through the porous solid in the semi-dry state, k_s .

$$\frac{1}{K_s} = \frac{1}{k_g} + \frac{1}{k_s} + \frac{H}{k_l RT} \quad (2.57)$$

When the rapidly moving gas/liquid interface overtakes the reaction front, there is no longer a liquid-phase resistance, and the last term in Equation (2.57) may be dropped. Harriott and Kinzey used a void fraction of 0.4 for the

porous solid in the semi-dry state; this may be compared to a value of 0.476 for ideal cubic packing of spheres.

While previous models generally underpredicted spray dryer performance, the Harriott and Kinzey model tends to overpredict the SO₂ removal. Harriott and Kinzey suggested that this could be due to inadequate representation of the true flow regime. While their model assumes plug flow, there is probably some degree of back-mixing in a spray dryer. When a completely back-mixed case was run, Harriott and Kinzey reported that their model underpredicted. This seems to suggest that an accurate representation of the flow lies somewhere between purely plug flow and purely back-mixed.

In late 1986, Maibodi, Pearson, and Davis⁵² modified the Damle model described earlier to include an absorption flux equation with terms to account for gas-phase, enhanced liquid-phase, and dissolution resistances.

$$N_{SO_2} = \frac{P_{SO_2}/H + BC_{Ca(OH)_2,s}}{1/Hk_g + 1/k_1 + aB/k_s a_p} \quad (2.58)$$

where P_{SO_2} is the partial pressure of SO₂; B is the ratio of liquid-phase diffusivity of Ca(OH)₂ to that of SO₂; $C_{Ca(OH)_2,s}$ is the saturation concentration of Ca(OH)₂; k_s is the solid dissolution mass transfer coefficient; a is the interfacial area per unit volume of a droplet; and a_p is the particulate surface area per unit volume of droplet. All other variables are as defined previously. This approach allows all resistances to be treated simultaneously, rather than treating only a single controlling resistance at each condition.

A greatly simplified model may be derived if the product of the mass transfer coefficient and the total interfacial area of the droplets, $K_s a$, is considered a constant at its mean value. As suggested by Harriott,⁵³ this allows direct integration of the differential equation describing the incremental change in SO₂ concentration with time, yielding the following:

$$E = 1 - \exp(-X) \quad (2.59)$$

where X is the overall number of mass transfer units for SO_2 given by

$$X = K_g a P t / \rho_M \quad (2.60)$$

in which P is the total gas pressure, t is time, and ρ_M is the molar density of the gas.

By expressing the overall mass transfer coefficient, K_g , in terms of the individual gas-phase and liquid-phase coefficients, k_g and k_l , and assuming that the liquid-phase coefficient is proportional to the lime stoichiometry (i.e., $k_l = k_l' \times \text{SR}$), Harriott showed that

$$K_g = \frac{k_g \text{ SR}}{B + \text{SR}} \quad (2.61)$$

where SR is the molar lime to SO_2 stoichiometric ratio and B is given by

$$B = \frac{H k_g}{k_l' \Phi} \quad (2.62)$$

in which Φ is the chemical enhancement factor.

If the evaporation time and approximate time for mass transfer, t , is assumed to be inversely proportional to the log-mean driving force for evaporation, it may be shown that

$$X = \frac{A \text{ SR}}{B + \text{SR}} \ln \frac{T_{\text{in}} - T_{\text{sat}}}{T_{\text{out}} - T_{\text{sat}}} \quad (2.63)$$

where

$$A = \alpha \& k_g P / \rho_M \quad (2.64)$$

The constant, α , is an assumed proportionality constant relating the interfacial area and the temperature drop, and β is an assumed proportionality constant relating the evaporation time and the log-mean temperature driving force. These proportionalities should be approximately valid, so that Equation (2.63) should be a useful means of correlating experimental data, as suggested by Harriott. Harriott used this simple model to correlate data from tests of in-duct slurry injection conducted by GE and Bechtel under separate DOE contracts. The Bechtel data included results from both calcitic and dolomitic lime injection. Both of these data sets were fitted to Equation (2.63) along with the data from the GE tests, which were done with calcitic lime only. This analysis showed that all three data sets could be adequately represented by a single value of B equal to 2.0, partly because the value of A is largely insensitive to the value of B . However, the corresponding best value of A varied from 1.25 for the Bechtel calcitic case to 0.78 for the Bechtel dolomitic case. This is reasonable since calcitic and dolomitic limes exhibit different dissolution rates and possibly different evaporation times as a result of differing levels of dissolved salts in the droplets.

In surveying the slurry spray drying/desulfurization models developed to date, it appears that the treatment of the mass transfer aspects is fundamentally sound, although some controversy remains in regard to the role of the liquid-phase resistance. All of the models discussed here are seriously deficient in their treatment of the fluid mechanics and droplet dispersion and the role that these play in droplet drying and SO_2 removal. There is also a need to incorporate a more rigorous calculation of SO_2 removal in the semi-dry state, such as the diffusion treatment suggested by Ruiz-Alsop and Rochelle.⁵⁰ Other areas that require further work include the effect of fly ash and the role of the fluid flow regime (plug flow versus back-mixed).

2.5.1.2 Models of sorbent/droplet collision and dry injection

In the case of dry (i.e., separate lime and water) injection, the process of in-duct desulfurization may be viewed as a two-step process. First, the sorbent particles must become "activated" by coming into contact with water. This can be accomplished by collision of the sorbent particles with water

droplets, or by condensation of water vapor on the sorbent particle surface. After this "activation" step, the moist sorbent can begin to absorb SO_2 . This second step takes place by a combination of mechanisms involving gas-phase diffusion of the SO_2 to the moist sorbent, chemically-enhanced absorption into the liquid, and liquid-phase mass transfer of the reacting species (lime and SO_2), as discussed in the previous section.

In general, bulk condensation of water vapor will not be an important wetting mechanism in duct injection, since the flue gas temperature will never reach the adiabatic saturation temperature. However, it is possible that "transient" condensation can contribute to sorbent wetting. Transient condensation is possible because the sorbent particles and their entraining air (or jet) are initially much cooler than the flue gas at the injection point. If the sorbent jet is at ambient temperature, significant transient condensation can occur while the sorbent particles are being heated. Thus, this mechanism of sorbent wetting must be considered in parallel with the direct collision of sorbent particles and water droplets.

Beittel and Dahlin⁵⁴ described a preliminary computer model of sorbent wetting during spray humidification. To date, this model only includes the sorbent/droplet collision mechanism (i.e., transient condensation is not modeled). However, minimal effort would be required to modify the model to include transient condensation. This could be accomplished in a very straightforward manner by using simultaneous heat and mass balances to determine the changes in particle temperature and the amounts of water condensed on the particles. The appropriate heat and mass transfer coefficients could be predicted by the generally-accepted, Froessling-type correlations for heat and mass transfer to spheres. With the model in its present form, these equations could be easily implemented to take into account the transient condensation mechanism.

The Beittel and Dahlin model, called COLLIDE.BAS, predicts the fraction of sorbent particles that are wetted by collision with water droplets during spray humidification of sorbent-laden flue gas. The degree of desulfurization (SO_2 removal) can then be predicted by assuming that the wetted sorbent particles behave like spray dryer slurry droplets. In practice, this has been accom-

plished by coupling COLLIDE.BAS with a modified version of Damle's spray dryer model, SPRAYMOD.BAS. Damle's model was modified to include droplet and particle size distributions, rather than mean sizes only. The calculation of the mass transfer coefficients was also improved by inserting a rigorous Froessling correlation in lieu of the assumption of a constant Sherwood number of 2. Of course, the SO₂ absorption calculations are applied to only the wetted fraction of the sorbent particles (i.e., no absorption by "dry" sorbent particles). Like Damle's model, the Beittel and Dahlin model has been structured to simulate either a plug-flow case or a back-mixed case. These two cases set the limits on SO₂ capture obtainable under the specified conditions.

COLLIDE.BAS addresses the four major processes that occur simultaneously during spray humidification of sorbent-laden flue gas, namely:

1. Sorbent/droplet collision,
2. Droplet acceleration due to drag,
3. Droplet evaporation, and
4. Cooling and deceleration of the flue gas.

Sorbent/droplet collision is modeled in terms of a conventional inertial impaction treatment. The fraction of particles colliding with water droplets (dc/c) is given by

$$-\frac{dc}{c} = \frac{3 Q_L |U_G - U_D|}{2 Q_G d_p U_D} \eta dz , \quad (2.65)$$

where Q_L and Q_G are the flowrates of liquid and gas, U_G and U_D are the gas and droplet velocities, d_p is the droplet diameter, dz is the differential increment of length over which the collisions occur, and η is the inertial target efficiency predicted by the Ranz and Wong correlation for spheres.⁵⁵ This correlation is given by

$$\eta = \left(\frac{K_p}{K_p + 0.7} \right)^2 , \quad (2.66)$$

in which K_p is the Stokes impaction parameter given by

$$K_p = \frac{C_r \rho_p d_p^2 |U_G - U_D|}{9 \mu_G d_D}, \quad (2.67)$$

where ρ_p is the sorbent particle density, d_p is the sorbent particle diameter, μ_g is the gas viscosity, and C_r is the Cunningham slip correction factor, expressed in terms of the particle diameter and the mean free path of the flue gas:

$$C_r = 1 + \frac{2\lambda}{d_p} \left(1.257 + 0.40 \exp \left(\frac{-1.10 d_p}{2\lambda} \right) \right), \quad (2.68)$$

in which λ is the mean free path of the gas.

Droplet deceleration is calculated from the drag relationships for spheres moving through a gas.

$$\frac{dU_D}{dt} = \left(\frac{3 \rho_G (U_G - U_D) |U_G - U_D|}{4 \rho_L d_D} \right) C_D + g \left(\frac{\rho_L - \rho_G}{\rho_L} \right), \quad (2.69)$$

where ρ_L is the liquid droplet density, g is the acceleration of gravity, and the drag coefficient, C_D , is calculated from the well-known correlation

$$C_D = 0.22 + \frac{24}{N_{Re}} (1 + 0.15 N_{Re}^{0.6}) . \quad (2.70)$$

in which N_{Re} is the Reynold's number for the droplet, given by

$$N_{Re} = \frac{d_D |U_G - U_D| \rho_G}{\mu_G} \quad (2.71)$$

The change in droplet diameter due to evaporation is calculated from

$$\frac{dd_D}{dt} = \frac{2 M_L}{\rho_L} k_G (P_{L1} - P_G) , \quad (2.72)$$

in which M_L is the molecular weight of the liquid (18 for water), P_{L1} is the vapor pressure of water at the gas/liquid interface, P_G is the partial pressure of water vapor in the bulk gas, and k_G is the mass transfer coefficient, expressed in terms of the Sherwood number, N_{Sh} , by the relation

$$k_G = \frac{N_{Sh} D_G P}{R T_G d_D P_{LM}} \quad (2.73)$$

in which D_G is the diffusivity of water vapor, P is the total gas pressure, R is the ideal gas constant, T_G is the gas temperature, and P_{LM} is the log-mean difference between the partial and vapor pressures. Here the Sherwood number is computed from the correlation

$$N_{Sh} = 2 + 0.552 N_{Re}^{0.5} N_{Sc}^{0.33} \quad (2.74)$$

in which N_{Re} and N_{Sc} are the Reynolds and Schmidt numbers. The vapor pressure at the liquid interface, p_{L1} , is predicted from the empirical correlation

$$\begin{aligned} \log p_{L1} = & 16.373 - \frac{2818.6}{T_{L1}} - 1.6908 \log T_{L1} - 0.0057546 T_{L1} \\ & + 4.0076 \times 10^{-6} T_{L1}^2 \quad (2.75) \end{aligned}$$

where T_{Li} is the temperature at the interface. The gas velocity is simultaneously updated in terms of the change in gas density with gas temperature. The latter is predicted from a simple heat balance relating the gas cooling to the extent of droplet evaporation.

The overall fraction of particles wetted by a given droplet size is obtained by integrating over the particle size distribution, $f(d)$. The result can then be integrated over the range of droplet sizes as well.

There are five major assumptions that have been made in deriving COLLIDE.BAS.

1. The droplets and sorbent particles are evenly distributed across the duct at the plane where contact begins ($z = 0$). This may physically be the location of the sorbent injection nozzle or the water spray nozzle, whichever comes after the other.
2. The droplets leaving the water spray nozzle are immediately subject to the drag force exerted by the surrounding flue gas (i.e., they are subject to maximum deceleration).
3. The flue gas flow is one-dimensional and incompressible, and the particles and droplets travel along the axis of the spray nozzle. In the coupled model, this restriction is relaxed to allow a back-mixed case, but the collision (impaction) calculations are performed assuming co-directional sorbent/particle streamlines.
4. The specified sorbent and droplet size distributions are those that exist at the point of initial sorbent/droplet contact. In practice, this means droplet distributions measured as close as possible to the spray nozzle exit, and impactor measurements made just upstream of the spray nozzle.

5. The sorbent particles move at the gas velocity and follow the gas streamlines at all times prior to collision with droplets.

The first assumption implies an ideal case in which the sorbent and droplets are perfectly distributed by an array of spray nozzles. This represents the best possible dispersion of materials across the duct and is never achieved in actual practice. At first glance, the second assumption may seem to impose an unrealistic restriction on the collision process, especially for dual-fluid nozzles. The carrier fluid (air) used in dual-fluid systems insulates the droplets from some of the drag forces near the jet. Thus, the droplets decelerate more slowly than predicted in a dual-fluid system. This effect, however, is offset to some extent by the ability of the jet to entrain particles and thereby promote particle/droplet contact. The net effect of these two countermanding mechanisms is to reduce the overall collision rate.⁵⁶ Therefore, COLLIDE.BAS predicts an upper limit on the degree of sorbent wetting achieved with two-fluid nozzles.

The effects of swirl, jet entrainment, and back-mixing are not taken into account in the collision model. As implied in the third assumption, the collision model cannot simulate any departure of the particles or droplets from the gas streamlines, except that which occurs during the inertial impaction process. Note, however, that this is no longer true in the coupled model. A key aspect of the model is its ability to integrate over the entire distribution of sorbent and droplet sizes. This feature is essential for accurate prediction of the collision rates. The droplet distribution also has a significant impact on evaporation rates and, therefore, droplet lifetimes. Also, the lifetime of a 20- μm droplet in one distribution will not necessarily be the same in another distribution. Also, two different distributions with the same median diameters will not necessarily give the same lifetimes or collision rates. This is due to the complex interaction of the droplet size, evaporation rate, and water partial pressure. Higher amounts of very fine particles generally lead to higher partial pressures near the nozzle, since evaporation is faster. This tends to suppress evaporation of larger droplets at points further downstream in the jet.

As is expected in inertial processes, the key factor governing the degree of collision (wetting) is the relative velocity between the sorbent particle and the droplet. As the droplet is slowed by the drag of the surrounding flue gas, the relative velocity decreases, and the collision rate decreases accordingly. Eventually, the droplets are slowed to the gas velocity, so that the relative velocity becomes zero. At this point, there is no longer any driving force for impaction, and all collisions cease. For modeling purposes, the calculations of collision rates may be stopped when the droplet velocity drops to within 1%, or so, of the gas velocity. The droplets may continue to be tracked in terms of their evaporation in order to predict exit gas temperatures. In general, however, the droplets are fully decelerated long before they are evaporated.

As mentioned above, the collision process, and hence the wetting process, can only continue as long as there is a sufficient difference in sorbent and droplet velocities. For any given droplet size and initial velocity, there is a unique residence time available for collisions. This residence time is determined by the distance that the droplet can penetrate into the relatively stagnant gas before being stopped (i.e., before reaching the gas velocity). Figure 2.21 shows a plot of "stopping distances" predicted by COLLIDE.BAS as a function of droplet diameter. This droplet diameter is an initial value only, and changes during deceleration due to evaporation. Since the stopping distances are usually quite short for practical drop sizes, the diameter change during deceleration is normally very small. Thus, the predicted stopping distance follows the same trend as the terminal velocity of the droplet.

Based on the above considerations, it would seem that sorbent/droplet collisions can be maximized by using the largest possible droplets. This is not true, however, for a fixed rate of water injection (i.e., a fixed approach to saturation). For a fixed amount of water, the number of water droplets must decrease as the droplet size increases. This means that there will be less coverage of the duct cross-section, or the impaction cross-section, with larger droplets. Thus, there is a trade-off between the "ballistic" effect of longer stopping distances and the "coverage" effect of droplet concentration. This leads to the concept of an optimum droplet size, as illustrated in Figure 2.22. For the case simulated, a 29 °F approach in the spray chamber at Southern

Figure 2.21. "Ballistic" stopping distance as a function of initial droplet diameter.

Figure 2.22. Predicted sorbent wetting as a function of initial droplet diameter.

Research Institute, the "optimum" droplet size is predicted to be about 150 μm . This may seem quite large in comparison to typical duct injection processes. However, it is at the lower range of optimum sizes predicted for simple spray tower particulate collectors.⁵⁷

In actual practice, it is impossible to utilize the droplet sizes that are optimal from a collision viewpoint. Droplets that were large enough to maximize collisions would not be evaporated in the available residence time. To illustrate this, we used the model to estimate the maximum droplet size that could be fully evaporated in a 50-ft length of ductwork. At the assumed gas velocity, the residence time available was about 1.1 s. For this particular run, it was found that the largest acceptable droplet size was predicted to be 71.3 μm . This means that all smaller droplets could be fully evaporated within the available residence time. This assumes that the droplets follow the gas streamlines, and do not hit the duct wall prior to evaporation. With real nozzle trajectories, the acceptable droplet size may be even smaller due to wall-wetting considerations.

2.5.2 Removal of Solids by Electrostatic Precipitation

Most currently available ESP models are based on the Deutsch equation, which is an exponential equation of the form:

Efficiency = 1 - penetration

$$= 1 - \exp(-\omega A/V), \quad (2.76)$$

where A is the collection plate area, V is the gas volume flow rate, and ω is the electrical migration velocity, which is calculated from:

$$\omega = \frac{qEC}{6\pi\mu a} \quad (2.77)$$

In this equation, q is the charge on a particle of radius a , E is the electric field at the plate, C is the Cunningham correction factor, and μ is the gas viscosity. This equation was proposed by Deutsch in 1922⁵⁸ and assumes that the gas is sufficiently turbulent to cause complete and uniform particle mixing across each ESP lane and that all of the particles are of a single size. These assumptions do not accurately describe the conditions found in a typical ESP in that actual particle sizes are usually distributed across several orders of magnitude and, although the particle concentration is fairly uniform at the ESP inlet, stratification has been observed at the outlet. In spite of this, the Deutsch equation has been successfully used for many years to predict ESP performance. Although variations of the Deutsch equation have been devised to allow the description of the entire range of particle sizes by a single effective migration velocity (precipitation rate parameter), these are in general not as accurate as models which divide the range of particle sizes into narrow size bands. In recent years, attention has been paid to the assumption of uniform particle mixing, with the result that some developers⁵⁹⁻⁶¹ have proposed using models based on a turbulent diffusion equation derived from fluid mechanics rather than the Deutsch equation. This approach will be discussed later.

One widely used ESP performance model is revision 3 of the SRI/EPA ESP Model described by Faulkner et al.⁶² This model applies the Deutsch equation to narrow particle size bands over short ESP length increments to find the ESP efficiency. The model requires a detailed description of the physical and electrical properties of the ESP, the flue gas, and the entrained particles. The electric field, E , used in the equation for the Deutschian migration velocity is obtained from an algorithm which simultaneously solves Poisson's equation and the current continuity equation in the interelectrode space in each increment of ESP length. This is a self-consistent, iterative calculation which takes into account an approximation of both ionic and particulate space charge and solves the equations on a rectangular grid running from mid-lane to plate to obtain the field at the plate. The particle charge, q , is computed using a unipolar ionic charging theory.⁶³ The algorithm sums the time-rate-of-charging for 1) field charging, until the saturation limit is reached for a given particle size; 2) charging by thermal diffusion of ions; and 3) charging by field-enhanced thermal diffusion. The charge acquired by the particles

depends on the particle size, the density of unipolar ions, the treatment time, and the average electric field in each increment of length. The efficiency in each length increment is calculated before the model considers the subsequent length increments in the ESP.

In addition to the basic efficiency calculation, this model offers two ways to estimate the electrical operating conditions if they are unknown, including the SRI/EPRI power plant operating point correlation.⁶⁴ There are corrections for the effects of gas sneakeage and non-uniform gas velocity (based on theory) and for rapping reentrainment (an empirical correction based on field tests). There is also a calculation of the outlet plume opacity. This model has been shown to give good agreement with measured performance for a wide range of utility ESPs.⁶⁴

Lawless and Sparks⁶⁵ describe a model which uses a theoretical description of corona onset and the interaction of electric fields to predict V-I curves for positive or negative glow corona in an ESP. The calculation includes the effects of an adjustable space charge on the corona. The derived operating points are then used in a simplified version of the SRI model. This model does not calculate plume opacity.

Version 2 of this model is described by Lawless et al.⁶⁶ This model is similar to Version 1 except that it now includes a calculation for tuft corona current. This model contains a more realistic and accurate space charge collection mechanism. The model iterates between the V-I calculation and the ESP performance model, via the calculated space charge, to produce a self-consistent prediction. The effects of corona tuft spacing, wire spacing, and ash layer resistivity are included. The onset of back-corona is calculated. However, the model uses a dilute charging approximation which is most accurate with low dust loadings.

An ESP model which is in review by EPA is a revised version of the SRI/EPA model described by Faulkner et al.⁶⁷ The revised version differs from the standard version (Revision 3) in that the particulate space charge is calculated explicitly rather than approximately. This allows the interrelation of the particle charge and electric field calculations, which are iterated until

they become self-consistent. Their explicit dependence on the space charge directly relates them, and therefore the collection efficiency, to the dust load present in the gas stream. This model is rigorously Deutschian. Corrections for the effects of gas sneaking, non-uniform gas velocity, and rapping reentrainment, and a calculation of the outlet plume opacity are included in this model. Calculations are made as rigorously as possible. The only empirical calculations are the rapping reentrainment correction and a small particle migration velocity correction. This model has shown its accuracy on ESPs processing low dust loads. To date there has been insufficient data on ESPs with high dust loading to adequately validate the model.

Lawless et al.⁶⁶ also describe Version 3 of their predictive V-I model, which is under development. This version includes more realistic calculations of sneaking and rapping reentrainment than the previous models. A correction to the Deutsch equation for turbulent diffusive effects and an opacity calculation are included. The model has more adjustable parameters than the previous models.

The Deutsch equation's assumption of uniform particle concentration across each precipitator lane has been proven invalid, as an increase in concentration near the collection plates and a decrease in the center of the lane has been observed on many occasions. Leonard et al.⁶⁰ want to replace the Deutsch equation with a turbulent diffusion equation of the form:

$$u \frac{\partial n}{\partial x} + w \frac{\partial n}{\partial y} - D \left(\frac{\partial^2 n}{\partial x^2} + \frac{\partial^2 n}{\partial y^2} \right) = 0, \quad (2.78)$$

where n is the particle concentration, u is the gas velocity, x is the direction of gas flow, w is the electrical migration velocity, and D is the eddy diffusivity. This is a particle transport equation where the particles are moving downstream at rate u and are subjected to electrical force, resulting in a migration velocity toward the plates, and to gas turbulence. In the limit of infinite turbulence (perfect mixing), the solution to this equation becomes the Deutsch equation. In general, the solution to this equation is complicated, resulting in series-type solution in which the dominate mode is chosen as the

usable value. The diffusivity is an empirical coefficient which must be evaluated by comparison to measured results. The equations greatly over-predict the amount of stratification and collection which occurs in an ESP. Efforts to introduce a reentrainment coefficient into the equations have not been successful. Concentration measurements show that the degree of stratification is between the uniform concentration of the Deutsch equation and the amount predicted by turbulent diffusion theory.

Self et al.⁶¹ and Kihm⁶⁸ have proposed a turbulent diffusion theory in which the diffusivity coefficient is non-uniform across the ESP lane. In their model, the interelectrode space consists of a core region, where the diffusivity is constant, and a diffusion layer, where the diffusivity varies rapidly with the distance from the wall. The diffusion layer is composed of two regions: a thin viscous sublayer next to the wall, where the diffusivity increases as a cubic function of the distance from the wall, and a linear region in which the diffusivity increases linearly up to the core value. The thickness of the diffusion layer and the core diffusivity must be estimated by fitting the model analysis to experimental data. The predicted concentrations across the lane resemble the data measured for wire-plate ESPs much more closely than do uniform diffusivity concentrations. However, this scheme involves very complicated mathematics and was not fully developed in the reports. In their present state of development, models based on turbulent diffusion are still rudimentary and have not been widely used in the ESP industry.

2.6 ECONOMIC EVALUATION

Each of the three contractors who performed proof of concept tests for DOE (Bechtel, GE, Dravo) also generated a conceptual design and cost estimate for retrofitting their process to a full scale unit. This section provides a brief discussion and review of these cost estimates.

Each contractor used different design criteria and cost bases. No attempt was made to modify the design criteria to make them consistent. However, some changes were made to the cost assumptions to achieve as much consistency as possible.

It was not the intent of this review to make a direct cost comparison between processes. However, the cost estimates presented here should give a good indication of the potential of these technologies to become a cost competitive option for SO₂ removal.

2.6.1 Process Comparison

The three DOE contractors each took a different approach to injecting lime into the duct. Bechtel used slurry injection utilizing a two-fluid nozzle for atomization, GE used slurry injection with a rotary disk for atomization, and Dravo had dry lime injection but utilized two-fluid nozzles for humidification. Table 2.4 compares the pertinent design bases for each contractor.

The cost of lime is a major cost item for these processes and thus the assumptions concerning lime use (Ca/S ratio, lime utilization, SO₂ removal, approach to saturation) will have a significant cost impact. Bechtel used a highly reactive pressure-hydrated dolomitic lime slurry. They assumed that a 50% sulfur removal could be achieved at a 0.73 Ca/S ratio resulting in a 68.5% calcium utilization using a relatively modest approach temperature of 45 °F. Dravo assumed they could achieve a 65% sulfur removal at a 1.77 Ca/S ratio with dry hydrate injection and recycle resulting in a 36.7% calcium utilization using an aggressive approach temperature of 20 °F. GE assumed that a 50% sulfur removal could be achieved by using a lime slurry at a Ca/S ratio of 1.0 resulting in a 50% calcium utilization. These different assumptions resulted in part from the different processes being used but to greater degree from the uncertainty of the data that have been generated.

2.6.2 Cost Comparisons

Evaluation of the economics included review of the technical and cost sections of the duct injection reports pertaining to the 500-MW generic conceptual design. Following this review, some aspects of the capital and operating costs were modified or revised to attain a more consistent relationship between the three studies. This normalization was only partial in nature since only those changes that could clearly be incorporated without risk of misrepre-

TABLE 2.4

DESIGN BASES OF DUCT-INJECTION PROCESSES

	<u>Bechtel</u>	<u>GE</u>	<u>Dravo</u>
Plant rating, MW	500	500	500
Heat rate, Btu/kWh	10,000	10,100	10,367
Capacity factor, %	65	65	65
Coal sulfur content, %	4.0	4.0	2.5
SO ₂ removal, %	50	50	65
SO ₂ , lb/hr	37,540	39,600	20,226
SO ₂ concentration, ppm	2,780	2,640	1,807
Approach to saturation, °F	45	40	20
Flue gas exit temperature, °F	170	167	150
Fresh Ca/S ratio	0.73 ^a	1.0	1.8
Total Ca/S ratio	—	1.7	2.6
Lime utilization, %	68.5 ^b	50.0	36.7
Lime use, lb/hr	59,260 ^a	38,500 ^c	42,674 ^c
Recycle rate, lb/lb fresh lime	0	3.58	1.25
Atomizing air pressure, psig	90	—	115
Atomizing air flow, lb/lb	0.3	—	0.5
Water injection rate, gal./1000 scf	0.265	0.269	0.343

a. Pressure-hydrated dolomitic lime (PHDL) assumed. (Ca + Mg)/S = 1.46.

b. Ca + Mg utilization = 34.3%. c. Pebble lime hydrated on site assumed.

senting or altering the report data were incorporated. This approach necessitated not changing some of the data that was recognized as not being consistent from report to report. Capital and operating costs were then input into a standard economic model to ensure that consistent evaluations were performed. This process results in cost values that more closely reflect generic differences. Listed in Table 2.5 are summary results of the normalized economics evaluation. The first year values are expressed in end-of-year 1988 dollars.

2.6.2.1 Approach

The approach consisted of reviewing the capital costs, the operation costs, the basis of the estimate, and the physical scope of the systems. A review of the specific item costs was not attempted. Also reviewed was the approach to estimating the cost for the balance of plant scope and the various factors that were applied to capital costs. These include indirect labor factors, engineering percentage, and process and project contingency factors; only the contingency factors were adjusted for consistency. This use of the previously identified economic model ensures that the other cost elements that constitute the total capital requirement are consistently determined. These include the escalation during construction, interest used during construction (AFUDC), royalty allowances, preproduction costs, and inventory capital costs.

TABLE 2.5

SUMMARY OF NORMALIZED ECONOMIC RESULTS

<u>Report/Process</u>	Levelized cost of electricity <u>(Mills/kWh)</u>	<u>Cost of SO₂ removed</u>	
		1st Year <u>(\$/ton)</u>	Levelized <u>(\$/ton)</u>
Bechtel CZD Process	11.5	385	615
Dravo HALT Process	8.4	411	642
GE IDS Process	8.2	278	416

The review of the operation costs of the systems consisted of reviewing the basis of estimating each category of operating cost, the quantity of each consumable item, and the unit cost of the various consumables. The categories of operating costs are the following: operating labor, maintenance material and labor, and consumables that includes waste disposal. Again, through use of the economic model, the costs for these operating costs were consistently determined. The model also consistently determined the levelized busbar cost of power impact to retrofit the desulfurization system into a 500-MW power plant. This figure of merit is expressed in mills/kWh. The model also consistently determined the levelized and first year cost per ton of SO₂ removed which is expressed as \$/ton.

The basis of the estimate was also reviewed. The changes that were made as a result of this review are summarized in the succeeding subsections. Similarly, the operating costs and cost basis that were normalized are summarized in a subsequent subsection.

2.6.2.2 Capital cost normalization

A number of specific aspects of the capital cost were adjusted for each of the reported processes. In addition to the cost adjustments, use of the model ensured that calculation of the estimate factors was consistent (i.e., the same level of cost was used to calculate the contingency values). A specific change that was incorporated pertains to the cost year dollars. Since all reports did not report capital costs in the same year dollars, all capital, as well as operating, costs were escalated, as required, so that all values are in end-of-year 1988 dollars. Sales tax was excluded from the capital costs since this is an item not applied for each process.

The contingency calculations were normalized in the adjusted estimates. Since each of these processes is approximately at the same stage of development the process contingency rate was assessed equally. This rate was established on the basis of the composite rate resulting from the Bechtel study application of varying rates per system. The calculated rate was 8.7%. Project contingency was similarly applied to each estimate. The rate was subjectively established at 20% and applied to each estimate.

Other capital related items that were not consistently established in the subject reports were royalty allowance, preproduction or startup costs, inventory capital, and land costs. The royalty allowance was consistently determined in the model at the EPRI suggested rate of 0.5%. Preproduction costs were similarly evaluated by the model, again on the basis of the EPRI-recommended approach. Inventory capital was similarly calculated on the basis of a 30-day supply of chemicals, primarily lime. Since the installation of the process system is intended to occur at an existing station, land was not considered to be an acquisition requirement. In the case where land was originally included, this cost was eliminated from the normalized equivalent.

One other change that was incorporated was to exclude from consideration the penalty for not achieving the target NO_x removals. In some of the reports a cost penalty had been assigned. Since this review focused on the SO₂ removal, the penalty did not seem appropriate.

2.6.2.3 Operating cost normalization

Similar to the capital cost normalization, a number of specific aspects were revised to achieve more consistent results. Generally, use of the model ensured a consistent calculation of the annual values that includes consideration of the plant capacity factor. In addition, a number of specific values were reviewed and normalized. The plant operator costs were determined on the basis of the number of operating jobs required per shift. Although there are some process differences the number of operating jobs was considered to be equivalent for each process. The number of jobs was established at two and the same labor rate was used to yield equivalent operator costs.

Maintenance costs was another area that was subjected to normalization of values. The approach consisted of applying a fixed percentage to the capital cost. Since the estimate details from process to process are not compatible, varying the rate per system was not possible on a consistent basis. The rate that was applied, 4%, represents the material and labor cost for plant maintenance on an annual basis. This developed value was considered appropriate for

the type of process involved and, once determined, was split into material and labor fractions on a 60/40 basis.

Consumable costs were also evaluated on a consistent basis except that quantities established by the investigators were verified but not changed. Several exceptions are noted, in the following subsection. The use of standard unit costs of most of the consumables further contributed to the consistency of consumable costs. Standard units were used for the cost of: 1) water, \$0.75 per 1000 gal.; 2) plant power, \$0.06 per kWh; and 3) waste disposal, \$8.85 per ton. One other change to enhance consistency was adjustment of the waste disposal quantity to exclude the fly ash constituent since the fly ash quantity is not attributable to the desulfurization processes. In the original reports total waste quantity was used as the basis for cost and a separate item was incorporated to yield a credit for the fly ash component of total waste.

2.6.2.4 Capital and operating cost differences

There are a number of differences that still remain in the normalized cost evaluations. Each estimate was not recast into a common code of accounts in order to compare corresponding system unit costs for consistency since the various estimates were not in formats that are compatible for such recasting. Therefore this type of comparison was not possible. System components whose size was dependent on design parameters that impact capital cost, while recognized, were also not changed. The most apparent such inconsistency is the lime storage capacity. The Bechtel study provides for 30 days of material storage whereas the Dravo study provides 20 days storage and in the GE study, based on the available information, it is unclear what amount of storage was provided. The plant location is another recognized difference that may impact costs since one of the reports has a specific location and costs may reflect that location. With the other estimates the location is not specified. Therefore there is most likely some inconsistency between estimates due to the difference in location although the cost magnitude may be minimal.

A major factor that distinguishes one estimate from the others concerns recognition of the impact of retrofit construction. The Bechtel study clearly indicates a cost penalty for the retrofit installation of the process system.

With both the Dravo and GE estimates this factor does not appear to have been considered. However, since one or both of these studies may indeed have considered the retrofit impact, it was not considered prudent to either eliminate the penalty from the Bechtel study or to incorporate the penalty in the other estimates.

Similar to the treatment of the retrofit factor, the estimate factor for engineering costs was not adjusted. The factor used in each report was clear as was the calculation to arrive at the cost. There was not an accompanying explanation with each estimate to verify what scope was included in the estimate for engineering. Since not only the pure engineering and design may be involved—for example, some costs in the engineering category for one estimate may be included with the construction indirect category of another—use of a set rate may in one case duplicate costs and, in another, eliminate appropriate costs.

For operating and maintenance costs, the raw lime that is received is in a slightly different form. Since the unit costs did seem to reflect these differences they were left unchanged except for escalation adjustment to bring each to the end-of-year 1988 level. Since both Dravo and GE use pebble lime the unit prices in these two estimates were adjusted to be equal. The end result is a price for pressure-hydrated dolomitic lime of \$71.50 per ton and a pebble lime cost of \$65.00 per ton.

2.6.2.5 Normalized economic analysis results

The results of the normalization of the subject desulfurization processes are presented in separate Tables 2.6, 2.7 and 2.8. These tables indicate the capital, operating, and consumable costs that contribute to the total system impact figure-of-merit. In this particular case several figures-of-merit are reported. The traditional value of cost of electricity, COE, was supplemented with both a first year and levelized equivalent cost per ton of SO₂ removed. These alternate figures-of-merit are expressed in \$/ton. The mills/kWh value is a direct measure of the impact to the total power plant. The \$/ton values are a common measure of the cost of removal that is more appropriate to comparing competing removal system values.

Examination of the table results indicates that the cost of the systems with regard to impact on the power plant is higher for the Bechtel system but show rather close agreement. However, there are other factors that contribute to this apparent result. GE indicated the highest capital cost. This high cost level was not reconciled due to the level of information available. Their capital cost impact on total economic values is offset due to the lime utilization assumptions that were used by GE. These considerations result in a significantly lower lime quantity requirement. This impact is evident when comparing the GE \$/ton to the other corresponding values. Similarly, the Dravo results are somewhat misleading since several of their study parameters are different. Dravo selected a higher per cent removal level, 65% versus 50%, but they also selected a coal of lower sulfur content, 2.5% versus 4%. Again the \$/ton values tend to reveal the cost relationship relative to the other process results.

In any event, the results of the comparison seem to indicate that although there are some differences between the reported processes, there is general agreement of costs for these conceptual 500-MW sized processes. While the results do not seem to clearly focus on one of the three processes, the results do suggest the viability of this general concept for desulfurization especially in a retrofit application.

TABLE 2.6. CAPITAL INVESTMENT AND REVENUE REQUIREMENT SUMMARY
FOR BECHTEL CZD PROCESS

TITLE/DEFINITION			
Case:	Bechtel CZD Process		
Plant Size:	500.0 (MWe)	HeatRate:	10,000 (Btu/kWh)
Fuel(type):		Cost:	(\$/MMBtu)
Design/Construction:	2 (years)	BookLife:	30 (years)
TPC(Plant Cost) Year:	1988 (Dec.)	TPI Year:	1989 (Jan.)
Capacity Factor:	65 (%)		
CAPITAL INVESTMENT		\$x1000	\$/kW
Process Capital & Facilities		13,450	26.9
Engineering(incl.C.M.,H.O.& Fee)		1,210	2.4
Process Contingency		1,127	2.3
Project Contingency		<u>2,887</u>	<u>5.8</u>
TOTAL PLANT COST(TPC)		\$18,673	37.3
TOTAL PLANT INVESTMENT(TPI)		\$19,249	38.5
Royalty Allowance		67	0.1
Preproduction Costs		2,453	4.9
Inventory Capital		1,546	3.1
Initial Catalyst & Chemicals			
Land Cost			
TOTAL CAPITAL REQUIREMENT(TCR)		\$23,316	46.6
OPERATING & MAINTENANCE COSTS(First Year)		\$x1000	\$/kW
Operating Labor		438	0.9
Maintenance Labor		190	0.4
Maintenance Material		285	0.6
Administrative & Support Labor		<u>188</u>	<u>0.4</u>
TOTAL OPERATION & MAINTENANCE(1st yr.)		\$1,101	2.2
FIXED O & M (1st yr.)			1.43 \$/kW
VARIABLE O & M (1st yr.)			0.14 mills/kWh
CONSUMABLE OPERATING COSTS(less Fuel)		\$x1000	mills/kWh
Water		91	0.03
Chemicals		12,061	4.24
Other Consumables		1,367	0.48
Waste Disposal		<u>1,897</u>	<u>0.67</u>
TOTAL CONSUMABLES(1st yr.,-fuel)		\$15,416	5.41

TABLE 2.6 (Continued)

BY-PRODUCT CREDITS(First Year)

FUEL COST(First Year)

LEVELIZED OPERATION & MAINTENANCE COSTS

Fixed O & M	0.4 mills/kWh
Variable O & M	0.2 mills/kWh
Consumables	9.5 mills/kWh
By-product Credit	mills/kWh
Fuel	mills/kWh

LEVELIZED CARRYING CHARGES(Capital)

1.4 mills/kWh

LEVELIZED BUSBAR COST OF POWER

11.5 mills/kWh

Levelized Cost/SO₂ Removed

615 \$/ton

1st. Year Cost/SO₂ Removed

385 \$/ton

TABLE 2.7. CAPITAL INVESTMENT AND REVENUE REQUIREMENT SUMMARY
FOR DRAVO HALT PROCESS

TITLE/DEFINITION

Case:	Dravo HALT Process		
Plant Size:	500.0 (MWe)	HeatRate:	10,367 (Btu/kWh)
Fuel(type):		Cost:	(\$/MMBtu)
Design/Construction:	2 (years)	BookLife:	30 (years)
TPC(Plant Cost) Year:	1988 (Dec.)	TPI Year:	1989 (Jan.)
Capacity Factor:	65 (%)		

CAPITAL INVESTMENT	\$x1000	\$/kW
Process Capital & Facilities	12,523	25.0
Engineering(incl.C.M.,H.O.& Fee)	1,609	3.2
Process Contingency	1,090	2.2
Project Contingency	<u>3,044</u>	<u>6.1</u>

TOTAL PLANT COST(TPC) \$18,265 36.5

TOTAL PLANT INVESTMENT(TPI) \$18,829 37.7

Royalty Allowance	63	0.1
Preproduction Costs	1,812	3.6
Inventory Capital	774	1.5
Initial Catalyst & Chemicals		
Land Cost		

TOTAL CAPITAL REQUIREMENT(TCR) \$21,477 43.0

OPERATING & MAINTENANCE COSTS(First Year)	\$x1000	\$/kW
Operating Labor	438	0.9
Maintenance Labor	200	0.4
Maintenance Material	301	0.6
Administrative & Support Labor	<u>191</u>	<u>0.4</u>

TOTAL OPERATION & MAINTENANCE(1st yr.) \$1,130 2.3

FIXED O & M (1st yr.) 1.47 \$/kW

VARIABLE O & M (1st yr.) 0.14 mills/kWh

CONSUMABLE OPERATING COSTS(less Fuel)	\$x1000	mills/kWh
Water	596	0.21
Chemicals	6,034	2.12
Other Consumables	2,480	0.87
Waste Disposal	<u>1,349</u>	<u>0.47</u>

TOTAL CONSUMABLES(1st yr., -fuel) \$10,458 3.67

TABLE 2.7 (Continued)

BY-PRODUCT CREDITS(First Year)

FUEL COST(First Year)

LEVELIZED OPERATION & MAINTENANCE COSTS

Fixed O & M	0.5 mills/kWh
Variable O & M	0.2 mills/kWh
Consumables	6.4 mills/kWh
By-product Credit	mills/kWh
Fuel	mills/kWh

LEVELIZED CARRYING CHARGES(Capital) 1.3 mills/kWh

LEVELIZED BUSBAR COST OF POWER

Levelized Cost/SO ₂ Removed	8.4 mills/kWh
1st. Year Cost/SO ₂ Removed	642 \$/ton
	411 \$/ton

TABLE 2.8. CAPITAL INVESTMENT AND REVENUE REQUIREMENT SUMMARY
FOR GE IDS PROCESS

TITLE/DEFINITION			
Case:	GEESI IDS Process		
Plant Size:	500.0 (MWe)	HeatRate:	10,000 (Btu/kWh)
Fuel(type):		Cost:	(\$/MMBtu)
Design/Construction:	2 (years)	BookLife:	30 (years)
TPC(Plant Cost) Year:	1988 (Dec.)	TPI Year:	1989 (Jan.)
Capacity Factor:	65 (%)		
CAPITAL INVESTMENT		\$x1000	\$/kW
Process Capital & Facilities		18,425	36.9
Engineering(incl.C.M.,H.O.& Fee)		2,303	4.6
Process Contingency		1,397	2.8
Project Contingency		<u>4,425</u>	<u>8.9</u>
TOTAL PLANT COST(TPC)		\$26,550	53.1
TOTAL PLANT INVESTMENT(TPI)		\$27,370	54.7
Royalty Allowance		92	0.2
Preproduction Costs		1,824	3.6
Inventory Capital		982	2.0
Initial Catalyst & Chemicals			
Land Cost			
TOTAL CAPITAL REQUIREMENT(TCR)		\$30,268	60.5
OPERATING & MAINTENANCE COSTS(First Year)		\$x1000	\$/kW
Operating Labor		438	0.9
Maintenance Labor		276	0.6
Maintenance Material		414	0.8
Administrative & Support Labor		<u>214</u>	<u>0.4</u>
TOTAL OPERATION & MAINTENANCE(1st yr.)		\$1,341	2.7
FIXED O & M (1st yr.)			1.74 \$/kW
VARIABLE O & M (1st yr.)			0.16 mills/kWh
CONSUMABLE OPERATING COSTS(less Fuel)		\$x1000	mills/kWh
Water		58	0.02
Chemicals		7,662	2.69
Other Consumables		350	0.12
Waste Disposal		<u>1,015</u>	<u>0.36</u>
TOTAL CONSUMABLES(1st yr.,-fuel)		\$9,085	3.19

TABLE 2.8 (Continued)

BY-PRODUCT CREDITS(First Year)

FUEL COST(First Year)

LEVELIZED OPERATION & MAINTENANCE COSTS

Fixed O & M	0.5 mills/kWh
Variable O & M	0.3 mills/kWh
Consumables	5.6 mills/kWh
By-product Credit	mills/kWh
Fuel	mills/kWh

LEVELIZED CARRYING CHARGES(Capital)

1.8 mills/kWh

LEVELIZED BUSBAR COST OF POWER

8.2 mills/kWh

Levelized Cost/SO₂ Removed

416 \$/ton

1st. Year Cost/SO₂ Removed

278 \$/ton

3.0 RESEARCH NEEDS AND PROJECT OBJECTIVES

The preceding sections have provided a detailed review of previous work related to duct injection technology. It is apparent that relatively large pilot scale experimentation is required to determine the SO₂ and particulate removal performance that is achievable with various process modes and retrofit application scenarios. This section will describe the project plan prepared by the Gilbert/Commonwealth team for the DOE Scale-up Tests and Supporting Research Project. The plan is designed to supplement previous research and provide the information required to bring duct injection technology to commercial application.

Experimental work on the subject project will be performed at DOE's Duct Injection Test Facility located at the Muskingum River Power Plant of Ohio Power Company. Modifications to the facility are currently in progress which will facilitate evaluations of various modes of duct injection. The technologies to be tested include injection of hydrated lime slurry using dual fluid nozzles or a rotary atomizer, and pneumatic injection of hydrated lime with flue gas humidification before or after sorbent injection.

3.1 TEST PROGRAM

The overall purpose of the test program is to gain a thorough and detailed understanding of the scale-up and design requirements, operational behavior, and limitations of duct injection technology. To accomplish this goal, the following specific objectives must be met.

- Both dry and slurry injection systems must be fully characterized in terms of their projected performance in retrofits to the population of candidate plants.
- The optimum process configurations must be identified for both the dry and the slurry forms of duct injection.

- Adequate data must be obtained to provide a reliable design basis and a reliable set of scale-up criteria. This requires an emphasis on determining mechanisms and limiting processes for the SO₂ removal achieved with various process modes.
- A reliable process control system, capable of handling all anticipated process upsets and variations, must be demonstrated.
- Equipment failure modes and methods to cope with them must be identified and demonstrated.
- The test program must be interactive with other ongoing DOE duct injection projects so as to make maximum use of all available data.
- The test program has been structured to include a wide range of test parameters, system components, process configurations, and measurement techniques. A project schedule for the test program has been designed to fit within an overall schedule such that the project can supply the needed input to related duct injection projects.

After a period of startup and shakedown tests, the actual test program will begin in the Summer of 1989 and run for two years. The test program is divided into two major tasks with eight major subtasks. The major elements of each subtask are very briefly described below.

3.1.1 Enhanced Data Development (Task 3)

Characterize System Performance. Validate sampling procedures; optimize humidification nozzle parameters; perform parametric tests of the effects of Ca/S ratio, approach to saturation, gas temperature and velocity, and duct configuration; evaluate vapor-phase versus collision effects; and examine effects on ESP operation.

Obtain Scale-up Data and Design Criteria. Examine effects of nozzle design and arrangement, flow conditioning, deposit cleaning strategies,

sorbent dispersion, humidification, and ESP SCA and rapping with both dry and slurry injection.

Test Advanced Configurations. Evaluate advanced nozzle designs, various types of additives, advanced duct cleaning systems, spent sorbent recycle methods, ESP rapping reentrainment suppression, and inertial collectors (such as louvre collectors) ahead of ESP with both dry and slurry injection.

Process Controls. Evaluate response of process control systems to normal variations in process conditions as well as upset conditions with both dry and slurry injection.

Failure Modes. Evaluate responses and corrective actions for major equipment failures, including nozzle pluggage, excessive nozzle wear, loss of atomizing air, wet solids to ESP, perforated plate pluggage, loss of ESP fields, ash hopper and piping pluggage, and loss of control system power.

Characterize Wastes. Thoroughly characterize spent sorbent and fly ash waste to demonstrate that it is nonhazardous and can be safely handled and land-filled in existing facilities.

3.1.2 Mathematical Model Validation (Task 4)

Other contract teams are working to develop first and second generation mathematical models for duct injection. This project has been assigned the role of model validation through comparisons of model predictions with experimental data. The model evaluations are planned to occur in two separate phases as described in the following paragraphs.

First-generation Model Testing. Validate predicted evaporation rates, droplet deceleration rates, sorbent/droplet collision rates, SO₂ absorption rates, and ESP collection efficiency. Evaluate model capability for prediction of suspended phase and fixed bed components (from deposits and ESP electrodes) of overall SO₂ removal.

Second-generation Model Testing. Validate modifications made to first-generation model to improve predictions and incorporate improved rapping reentrainment correlation for ash/sorbent particulates.

3.2 EXISTING TEST FACILITY AND PLANNED MODIFICATIONS

The existing test facility provided hydrated lime slurry to a rotary atomizer which could be located in one of three duct locations, one vertical and two horizontal orientations. Existing facilities and equipment which will be reused as part of this program, and in some cases modified, include the flue gas breaching and isolation dampers, test stations, cyclone and ESP collectors, induced draft fan, drag chain ash conveying system, ash silo, ash recycle blower, control room and motor control centers, data acquisition system, and most of the existing structures and platforms.

The following new facilities and equipment are required to support the desired test programs:

- Flue Gas Dilution System
- Slurry Sorbent Injection System
- Dry Sorbent Injection System
- Gas Humidification System
- Ash Collection and Ash Recycle System
- Compressed Air System
- Duct Cleaning System

- Cooling Water System
- Utility Systems

Operation of the Duct Injection Test Facility is comprised of startup, commissioning (shakedown) and normal operation. The Duct Injection Test Facility will be operated continuously, five days per week in three shifts. Personnel have been provided for continuous coverage Monday through Friday. For duration testing, continuous seven day a week operations will be provided.

The extensive capabilities of the modified facility, when combined with the comprehensive data acquisition and analysis program, are expected to provide all of the information required for appropriate commercial applications of the various duct injection process modes.

4.0 ANNOTATED BIBLIOGRAPHY OF SELECTED REFERENCES

PART A. SO₂ CONTROL

1. J. Z. Abrams, S. Zaczek, J. H. Blake, M. J. Davidson, and H. W. Pennline. Development of the Confined Zone Dispersion Process for the Desulfurization of Flue Gas. Coal Technology '86. Pittsburgh, PA. November 18-21, 1986.

This paper gives a preliminary report on Bechtel's CZD process, as undertaken at Consumer Power's Campbell Station with support from DOE. The paper describes the test facility, preliminary test results, and plans for full-scale demonstrations.

2. J. Z. Abrams and R. M. Sherwin. Method for Reduction of SO₂ Emission from Fossil Fired Boiler. U.S. Patent 4,623,523. November 18, 1986.

The patent describes an apparatus and a method for removal of SO₂ from flue gas. The reactant for SO₂ is said to be either pressure-hydrated lime or pressure-hydrated dolomitic lime. The reactant may be used in a wet scrubber or a spray dryer, or it may be injected in gas passages upstream or downstream of the air heater. Use in the confined zone dispersion scheme allow injection into a flue gas duct.

3. M. Babu, R. C. Forsythe, C. V. Runyon, E. Evans, and J. L. Thompson. Results of 1.0 MM Btu/h Testing of HALT (Hydrate Addition at Low Temperature) for SO₂ Control. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 26, 1986.

This paper is a summary report on the testing of HALT on the 1 MM Btu/h scale at Dravo's research center. Removal of 60-70% of the SO₂ was achieved for a 3.2%-sulfur coal at Ca/S = 2. Promising results are favored by 1) close approach to adiabatic saturation, 2) downstream rather than upstream injection of a water spray, 3) injection of cold Ca(OH)₂ sorbent particles to enhance water condensation, 4) addition of NaOH to the water spray, and 5) modification of the sorbent prior to injection with methanol and sugar.

4. M. Babu, J. College, R. Forsythe, R. Herbert, D. Kanary, and K. Lee. 5-MW Toronto HALT Pilot Plant. Part I, Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81012. December 1988.

This part of the report describes the major and concluding portion of Dravo's work on the HALT process (see Forsythe and Kaiser (26) and Babu et al. (3)). The process employed at Toronto differed from earlier versions in that the water spray was injected only at a location downstream from the Ca(OH)₂ sorbent and NaOH was deleted as an additive from the spray. The process was coupled with either a baghouse or an ESP for solids collection. The primary test variables were 1) approach to adiabatic saturation, 2) Ca/S ratio, 3) gas flow rate, and 4) solids collection mode (baghouse or ESP). See also Babu et al. (5,6), Gooch et al. (33), and Stouffer (86).

5. M. Babu, J. College R. Forsythe, and D. Kanary. 1.0 Million Btu Combustor Testing. Part II, Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81012. December 1988.

This section of the report discusses the phase of HALT investigation previously reported by Babu et al. (3). Also see Babu et al. (4).

6. M. Babu, D. Kerivan, C. Hendrick, B. Kosek, D. Tackett, and M. Golightley. Conceptual HALT Scaleup Design. Part V, Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81012. December 1988.

This part of the report discusses HALT scale-up design and cost for 1) a 180-MW power station (specifically, Sammis Unit No. 1 of Ohio Edison and 2) a 500-MW unit, which is a hypothetical model. See Babu et al. (4).

7. D. F. Becker and J. L. DuBard. Conceptual Designs and Cost Estimates for E-SOX Retrofits to Coal-Fired Utility Power Plants. EPA-600/7-87-028. U.S. Environmental Protection Agency, Research Triangle Park, NC. February 1988.

Six operating modes of E-SOX (described by Sparks et al. (81) were addressed. Annualized costs ranged from \$301 to \$378 per ton of SO₂ removed. The generic cost basis was applied to a 500-MW utility plant burning a 2.5%-sulfur Eastern bituminous coal. Capital costs compare favorably with other retrofit technologies for SO₂ removal. Sorbent cost is the largest single component of costs.

8. Bechtel National, Inc. (no personal authors listed). Desulfurization of Flue Gas by the Confined Zone Dispersion Process. Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81009. April 1988 (Draft).

This report describes the two phases of Bechtel's investigation of duct injection technology for the control of SO₂ emissions. The first phase was a "proof-of-concept" investigation conducted at Consumer Power's Campbell Station; this was done at the 7-MW scale. The second phase was carried out at the Seward Station of the Pennsylvania Electric Company; this was performed at a much larger, 70-MW scale. The two investigations primarily addressed SO₂ control by the spray injection of a slurry of either calcitic or dolomitic hydroxide through a nozzle. There was also study of the incidental removal of NO_x by the wet hydroxide and study of the performance of ESPs under the altered conditions associated with duct injection.

9. R. Beittel and R. S. Dahlin. Mechanistic Studies of Sorbent Utilization Enhancement by Humidification. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper describes studies with a pilot-scale combustor with a rating of 1 MM Btu/h. Increments in sorbent utilization due to humidification were determined with reinjected, partially sulfated calcine and with fresh Ca(OH)₂. Humidification was with water vapor, water spray, or

slurry injection. The dominant mechanism of sorbent activation entails physical wetting of the sorbent particles, either with a water spray or a slurry. This paper also presents a sorbent/droplet collision model that can be used to simulate the separate injection of dry $\text{Ca}(\text{OH})_2$ and water. The collision model is coupled with a modified version of Damle's spray dryer in order to allow calculation of SO_2 removal in a dry $\text{Ca}(\text{OH})_2$ /water duct injection system. Damle's model is modified to take into account the entire array of droplet and particle sizes, and the region near the nozzle is more accurately simulated by a rigorous calculation of the Sherwood number using a Froessling correlation.

10. V. V. Bland, J. J. Hammond, and R. G. Rhudy. Full Scale Demonstration of Additive NO_2 Reduction with Dry Sodium Desulfurization. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

Dry sodium injection at a low temperature is a useful process for SO_2 removal in low-sulfur applications but, unfortunately, enhances NO_2 emission and leads to the appearance of a brown plume. This paper discusses SO_2 control with sodium sesquicarbonate and sodium bicarbonate and ancillary suppression of NO_2 emission with urea, ammonia, or ammonium bicarbonate.

11. G. Blythe, R. Smith, M. McElroy, R. Rhudy, V. Bland, and C. Martin. EPRI Pilot Testing of SO_2 Removal by Calcium Injection Upstream of a Particulate Control Device. 1986 Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

This paper describes process development tests that were conducted at a 2000-acfm pilot plant at EPRI's Arapahoe Test Facility; it also discusses supporting laboratory studies at Fossil Energy Research Corporation. The pilot-scale system consisted of units for flue gas humidification, dry sorbent injection, and particle collection on a fabric filter. Reaction parameters investigated on the pilot scale included approach to adiabatic saturation, sorbent factors, and recycle. Topics of laboratory study included sorbent surface area and sorbent modification with additives.

12. G. Blythe, V. Bland, C. Martin, M. McElroy, and R. Rhudy. Pilot-Scale Studies of SO_2 Removal by Addition of Calcium-Based Sorbents Upstream of a Particulate Control Device. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

This paper describes EPRI-supported studies at the Arapahoe Test Facility on both dry and wet processes of $\text{Ca}(\text{OH})_2$ injection in a low-temperature duct. The dry mode of injection was studied in combination with either a fabric filter or an ESP for particulate control; the extent of SO_2 removal was determined as a function of the approach to saturation, the relative locations of water and sorbent injection, the coinjection of steam and sorbent, the modification of sorbent properties, and the recycle of sorbent. The wet mode of injection was investigated in combination with an ESP.

13. R. H. Borgwardt and K. R. Bruce. EPA Study of Hydroxide Reactivity in a Differential Reactor. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

Most of the study was concerned with furnace injection of Ca(OH)₂ materials of various types. A brief investigation, however, was made of simulated low-temperature duct injection, with Ca(OH)₂ in a fixed-bed differential reactor. Reaction variables in the latter were sorbent surface area and reaction time.

14. J. C. S. Chang and C. B. Sedman. Scale-Up Testing of the ADVACATE Damp Solids Injection Process. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

ADVACATE is a term that describes a sorbent made by processing lime with fly ash or some other silicate source. This paper describes sorbent preparation by pressure hydration, development of the damp injection process, and activities toward commercialization of the process.

15. P. Chu and G. R. Rochelle. SO₂/NO_x Removal by Ca(OH)₂. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

This paper addresses the possibility of NO₂ removal as well as SO₂ removal when Ca(OH)₂ is modified with NaOH as an additive. The best sorbent for NO_x removal was prepared from a slurry of Ca(OH)₂, CaSO₃, NaOH, and fly ash; the best conditions were the highest temperature (125 °C) and the greatest concentrations of SO₂ (1500 ppm) and O₂ (20%), which removed 3-4 moles of NO_x per 100 moles of Ca(OH)₂, compared to 5-10 moles of SO₂ per 100 moles of Ca(OH)₂. The best SO₂ removal was obtained by slurrying fly ash with Ca(OH)₂ and NaOH; the best conditions were low temperature and high relative humidity, which removed 60-80 moles of SO₂ per 100 moles of Ca(OH)₂, compared to 0.5 to 1.0 mole of NO_x per 100 moles of Ca(OH)₂.

16. P. Chu and G. T. Rochelle. Removal of SO₂ and NO_x from Stack Gas by Reaction with Calcium Hydroxide Solids. Environ. Sci. Technol. 39, 175 (1989).

See notes on Chu and Rochelle (15).

17. P. Chu and G. T. Rochelle. SO₂/NO_x Removal by Ca(OH)₂. DOE/PC/81006-T1. U.S. Department of Energy (PETC), Pittsburgh, PA. 1988.

See notes on Chu and Rochelle (15).

18. A. S. Damle. Modeling of SO₂ Removal in Spray Dryer Flue-Gas Desulfurization System. EPA-600/7-85-038. December 1985.

This report presents the first user-oriented, comprehensive model of spray dryer desulfurization. The derivation of the model considers mass transfer resistances imposed by gas-phase diffusion, lime dissolution, and liquid-phase mass transfer. However, the liquid-phase resistance was said to be negligible due to the enhancement of liquid-phase mass transfer by the chemical reaction.

19. A. S. Damle, K. Ramanathan, and D. L. Harmon. Kinetics of Reaction between Hydrated Lime and Sulfur Dioxide. Sixth Symposium on the Transfer and Utilization of Particulate Control Technology. New Orleans, LA. February 25-28, 1986.

The reactivity of dry $\text{Ca}(\text{OH})_2$ and SO_2 , as applied in a spray dryer, was investigated. The sorbent was present in a shallow bed; the gas-phase SO_2 concentration, relative humidity, and sorbent particle size were the principal experimental variables. The relative humidity was found to have the dominant effect on the breakthrough of SO_2 from the bed. The reaction was first order in the SO_2 concentration. Fine $\text{Ca}(\text{OH})_2$ was found to have a greater utilization and somewhat higher reactivity than coarse $\text{Ca}(\text{OH})_2$.

20. W. T. Davis, G. D. Reed, and G. P. Partridge. Comparison of Pilot Plant Data with Predictions from the U.S. EPA SPRAYMOD Computer Program. Final Report to U.S. Environmental Protection Agency, Air and Energy Engineering Research Laboratory, Research Triangle Park, NC. Purchase Order 5D220NAEX. November 1985.

This report presents a comparison of 12 different data bases on $\text{Ca}(\text{OH})_2$ spray drying with the computer program developed by Damle (1985).

21. T. E. Dowdy, J. J. Lee, J. M. Henry, J. R. Smith, X. Q. Qian, and R. J. Schulz. Direct Sorbent Injection for Combined SO_2/NO_x Removal. Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81008. January 1989.

The tasks described in this report included 1) experiments on SO_2 removal in a pilot-scale facility, 2) measurements of spray-droplet velocity profiles with a laser velocimeter, 3) measurements of spray-droplet size distributions with a shadow spectrometer, and 4) mathematical modeling to support the experimental work. Use of hydrated lime removed 60% of the SO_2 at a Ca/S ratio of 1.5 to 1.6 and a 50 °F approach to saturation. Other sorbents were less effective. Only about 10% removal of NO_x was accomplished. The laser velocimeter demonstrated uniform velocity distribution across a duct at a velocity of 10 m/s; the instrument showed complete droplet evaporation in the test section of the duct. The shadow spectrometer showed the droplet size distribution to be uniform across the duct at a Sauter mean diameter of 45 μm . The modeling results were consistent with the experimental results, predicting a SO_2 removal only slightly higher than was observed.

22. W. Downs, W. J. Sanders, and C. E. Miller. Control of SO_2 Emissions by Dry Scrubbing. American Power Conference. Chicago, Illinois. April 21-23, 1980.

This paper refutes the assertion that a sulfite product layer limits the reaction rate. The authors show SEM photographs of free-standing sulfite crystals, suggesting a predominant aqueous-phase ionic reaction, rather than a reaction at the solid-liquid interface. The authors present a simplified equation relating removal efficiency to the ap-

proach to saturation, but show that it greatly underestimates the removal efficiency.

23. C. J. Drummond (editor). Duct Injection Technologies for SO₂ Control. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

An introduction to the subject is given by the editor. Results of proof-of-concept tests are given by DOE contractors: Dravo (HALT process), Bechtel (CZD process), GE (IDS process), and CONSOL (humidification by a nozzle array). An analysis of research goals and a description of DOE's program are given by the editor. Results of the survey of duct injection sites in relevant utility plants are given by one of the contractors, Burns and Roe Services.

24. G. C. England, B. A. Folsom, R. Payne, T. M. Sommer, M. W. McElroy, P. J. Chappel, and I. A. Huffman. Prototype Evaluation of Sorbent Injection with Humidification. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

A demonstration of furnace injection of a calcium-based sorbent is being conducted at Richmond Power and Light's Whitewater Valley Generating Station. Post-furnace humidification will be employed, as at the Edgewater demonstration (described by Nolan et al. (67)), to control the resistivity of the ash-sorbent mixture discharged from the furnace and to gain supplemental SO₂ control.

25. C. E. Fink, D. C. McCoy, and R. M. Statnick. Flue Gas Humidification with Boiler Limestone Injection for Improved ESP Performance and Increased SO₂ Removal. Coal Technology '85. Pittsburgh, PA. November 12-14, 1985.

This paper addresses some of the aspects of a 1-MW field demonstration of Coolside options, elsewhere described more comprehensively (Yoon, et al. (89)). It concerns boiler injection of the sorbent and deals in particular with ESP performance, as altered by both the additional solids entrained in the gas stream to be cleaned and the increased water vapor used to activate the sorbent.

26. R. C. Forsythe and R. A. Kaiser. Hydrate Addition at Low Temperature: SO₂ Removal in Conjunction with a Baghouse. Second Annual Pittsburgh Coal Conference. Pittsburgh, PA. September 16-20, 1985.

This paper describes the beginnings of research on the duct injection process known as HALT (Hydrate Addition at Low Temperature) as independent efforts by the Dravo Lime Company and Ohio Edison Company. As the program continued, it consisted of two main phases: 1) parametric testing on a 1 MM Btu/h combustor at the Dravo research facility and 2) long-term testing in a 5-MW pilot unit at Ohio Edison's Toronto Station. The program was financially supported by the Department of Energy. The essence of the program is discussed elsewhere by Babu et al. (4).

27. M. Garding and G. Svedberg. Modeling of Dry Injection Flue Gas Desulfurization. J. Air Pollut. Control Assoc. 38, 1275 (1988).

This paper is concerned with dry sodium-based sorbents, such as NaHCO_3 , with injection upstream from a baghouse. The paper presents a fundamental kinetic model and reports data from pilot-scale tests.

28. J. L. Getler, H. L. Shelton, and D. A. Furlong. Modeling the Spray Absorption Process for SO_2 Removal. J. Air Pollut. Control Assoc. 29, 1270 (1979).

This paper describes the first qualitative model of the spray drying desulfurization process. The authors suggest a two-step reaction mechanism based on x-ray analysis of spray dryer reaction products. In the first step, the reaction is controlled by either gas-phase diffusion or lime dissolution. In the second step, either pore diffusion or diffusion through the sulfite product layer is said to control.

29. D. V. Giovanni, R. G. Rhudy, J. McCarthy, and R. Giles. Technical and Economic Evaluation of HYPAS. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

The HYPAS process is comprised of four basic steps in sequence: 1) fly ash removal in a cold-side ESP, 2) evaporation cooling of the cleaned gas stream, 3) dry injection of $\text{Ca}(\text{OH})_2$ for removal of SO_2 , and 4) sorbent collection in a baghouse. This paper describes proof-of-concept testing that has been completed at EPRI's Arapahoe Test Facility in Denver and 4-MW pilot testing planned for EPRI's High Sulfur Test Center in New York State.

30. M. R. Gogineni, J. P. Clark, J. L. Marion, R. W. Koucky, D. K. Anderson, A. F. Kavasnik, E. Gootzait, D. G. Lachappelle, and S. L. Rakes. Development and Demonstration of Sorbent Injection for SO_2 Control in Tangentially Coal-Fired Boilers. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

A third demonstration of furnace injection of sorbent, with post-furnace humidification, will be performed at Virginia Power's Yorktown station. See Nolan et al. (67); England et al. (24).

31. J. P. Gooch, R. Beittel, E. B. Dismukes, and R. S. Dahlin. Humidification of Flue Gas to Augment SO_2 Capture by Dry Sorbents. Topical Report to Environmental Protection Agency, EPA Cooperative Agreements Nos. CR 811683 and CR 812811. August 1988 (Draft).

This report discusses research in four phases: 1) investigation of post-furnace humidification to achieve sorbent activation, 2) investigation of charge-augmented sorbent humidification, 3) studies of water-vapor adsorption by $\text{Ca}(\text{OH})_2$ with or without modification by additives, and 4) mathematical modeling of humidification and SO_2 removal processes. In the experimental area, the first two investigations were performed with a pilot-scale combustor, whereas the third was performed in the laboratory. The primary result of the humidification studies was

the finding that sorbent activation by water vapor alone is insufficient; activation requires the presence of the liquid phase. Charging of sorbent particles and water droplets with opposite polarities was found ineffective for increasing SO₂ removal. Adsorption isotherms of water vapor were interpreted with respect to the deliquesce of additives. Modeling took into account the effects of particle and droplet sizes, relative velocities, proximity to saturation, residence time, and Ca/S ratio.

32. J. P. Gooch, J. L. DuBard, M. G. Faulkner, Jr., R. S. Dahlin and R. Beittel. Effects of Sorbent Injection for Sulfur Dioxide Removal in Particulate Control Systems for Coal-Fired Boilers. EPA-600/7-88-023. U.S. Environmental Protection Agency, Research Triangle Park, NC. November 1988.

The research discussed in this report was concerned with the effects of sorbent injection on the performance of electrostatic precipitators. One task was to develop a predictor of the resistor of mixtures of sorbent with fly ash; the effort did not completely satisfy the research goal. A second task was to determine the effects of high mass loadings of suspended matter on the performance of an ESP; this task was addressed both experimentally and theoretically. Another task was to investigate the recycle, disposal, and utilization of ash-sorbent mixtures, based on laboratory and field experimentation. A final task included studies of the use of humidification to activate sorbents at low temperatures and to improve the performance of ESPs treating ash-sorbent mixtures.

33. J. Gooch, R. Beittel, J. DuBard, and G. Marchant, Jr. ESP Tests at Toronto. Part III, Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81012.

This part of the report discusses two phases of ESP study in connection with the HALT process, which were performed by Southern Research Institute. The first was at Dravo's installation in Ohio Edison's Toronto plant. The second was at the one-million-Btu/h pilot plant facility of Southern Research in Birmingham, Alabama. See Babu et al. (4).

34. R. Graf and J. D. Riley. Dry/Semi-Dry Flue Gas Desulfurization Using the Lurgi Circulating Fluid Bed Absorption Process. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

SO₂ removal occurs in a fluid-bed reactor. Ca(OH)₂ is supplied to the reactor either as a dry powder or an aqueous slurry. In addition to the Ca(OH)₂ in either dry or wet form, water is supplied to the reactor to increase the humidification of the gas stream. Effluent solids from the reactor are collected in an ESP and then recirculated through the reactor.

35. P. Harriott and M. Kinzey. Modeling the Gas and Liquid Phase Resistances in the Dry Scrubbing Process for SO₂ Removal. Third Annual Pittsburgh Coal Conference. Pittsburgh, PA. September 1986.

This paper includes the contribution of the liquid-phase resistance to mass transfer. The authors describe a moving reaction front within the spray dryer slurry droplet, the consequence of which is a variable film thickness for diffusion. As a result, the liquid-phase resistance can become appreciable during the latter stages of reaction. The authors conclude that this resistance can account for one-fourth to one-half of the total resistance.

36. P. Harriott. A Simple Model for the In-Duct Injection Process for SO₂ Removal. Unpublished Paper. U.S. Department of Energy, Pittsburgh Energy Technology Center, Pittsburgh, PA. 1989.

The author presents a greatly simplified model derived by assuming that the product of the overall mass transfer coefficient and the interfacial area, $K_g a$, is a constant. The model is used to correlate data from duct injection tests performed by Bechtel and GE.

37. R. G. Hooper, V. Bland, F. G. Pohl, M. McElroy, and R. Rhudy. Pilot Evaluation of Combined Particulate and SO₂ Removal Using a Fabric Filter System. Ninth Symposium on Flue Gas Desulfurization. Cincinnati, OH. June 4-7, 1985.

This paper discusses two EPRI research projects on low-temperature control of SO₂. In one project, dry sodium compounds were injected into the gas stream between the air heater and baghouse of a pilot plant. This project was performed at the Arapahoe Test Center in Denver. Process variables investigated were reagent type (bicarbonate, sesquicarbonate, or carbonate), reagent particle size, and stoichiometric ratio. In the second project, a dry calcium reagent augmented with steam or water was employed in a similar test site at Sneads, FL. The latter project was earlier reported by Pohl et al. (73).

38. L. S. Hovis, R. E. Valentine, B. J. Jankura, P. Chu, and J. C. S. Chang. E-SOX Pilot Evaluation. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

The E-SOX process was described earlier by Sparks et al. (81). This paper describes small-scale pilot experiments in preparation for a forthcoming 5-MW demonstration in a utility boiler. This demonstration is being supported jointly by EPA, the Dravo Coal Development Office, Babcock and Wilcox, and the Ohio Edison Company.

39. H. S. Huang, P. S. Farber, C. D. Livengood, J. T. Yeh, J. M. Markussen, and C. J. Drummond. Simultaneous NO_x and SO₂ Removal in a Spray Dryer System. AIChE 1987 Spring National Meeting. Houston, TX. March 29-April 2, 1987.

This paper describes joint research at the Argonne National Laboratory and the Pittsburgh Energy Technology Center, with NaOH as an additive to the lime slurry in a spray dryer. The data from both organizations indicate that the oxidation of NO to NO₂ can occur where NaOH is incorporated in the system and thereby the partial removal of NO_x can be effected.

40. C. Jorgensen, J. C. S. Chang, and T. G. Brna. Evaluation of Sorbents and Additives for Dry SO₂ Removal. EPA-600/D-86-025. U.S. Environmental Protection Agency, Research Triangle Park, NC. January 1986.

This report discusses bench-scale studies of enhanced SO₂ removal by calcium-based sorbents. The apparatus simulated the filter cake in a spray-dryer baghouse. Relative humidity plays a major role in SO₂ removal; additives such as CaCl₂, Ca(NO₃)₂, and NaNO₃ give enhanced removal.

41. C. Jorgensen, J. C. S. Chang, and T. G. Brna. Evaluation of Sorbents and Additives for Dry SO₂ Control. Environ. Progress 6 (2), 26 (1987).

See notes on Jorgensen et al. (40).

42. C. Jorgensen, J. C. S. Chang, T. G. Brna, and C. B. Sedman. Small-Scale Pilot Evaluation of Calcium- and Sodium-Based Sorbents for Dry SO₂ Removal. AIChE National Meeting. Houston, TX. March 29-April 2, 1987.

The pilot-scale apparatus was described earlier (Jozewicz et al. (48)). The primary sorbents were Ca(OH)₂ and NaHCO₃. The principal conclusions were as follows: 1) dry Ca(OH)₂ in the presence of enhanced water vapor but in the absence of liquid water droplets is limited in capability for SO₂ removal, 2) dry NaHCO₃ can, on the other hand, be quite effective under similar circumstances, and 3) Ca(OH)₂ can be improved by chemical combination with SiO₂. Conditions for optimizing SiO₂ enhancement are described.

43. C. Jorgensen, J. C. S. Chang, C. B. Sedman, and D. C. Drehmel. Pilot Plant Evaluation of Post-Combustion LIMB SO₂ Capture. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper describes post-furnace utilization of furnace-injected sorbents. Utilization was achieved by in-duct wetting. The best practical results, based on variation in spray droplet size and approach to saturation, was 10-20% SO₂ removal. For comparison, the solids were hydrated in a slurry, dried, and reinjected; in this form, the solids removed 25-55% of the SO₂. For further comparison, the solids were again hydrated but injected wet with excess recycled solids; the mixture achieved about 80% SO₂ removal.

44. W. Jozewicz and G. T. Rochelle. Modeling of SO₂ Removal by Spray Dryers. Pittsburgh Coal Technology Conference. Pittsburgh, PA. September 17-21, 1984.

This paper describes the first attempt at a truly mechanistic model of the spray drying desulfurization process. The model relates local changes in SO₂ concentration to local changes in gas temperature by using the analogy between heat and mass transfer. To obtain the overall SO₂ removal, the differential removal is integrated with respect to interfacial surface area.

45. W. Jozewicz and G. T. Rochelle. Fly Ash Recycle in Dry Scrubbing. EPA-600/D-85-257. U.S. Environmental Protection Agency, Research Triangle Park, NC. October 1985.

Laboratory experiments with a packed-bed reactor showed that utilization of $\text{Ca}(\text{OH})_2$ in the reaction with SO_2 was increased several fold when the sorbent was first slurried with fly ash. The enhancement increased as the ratio of ash to $\text{Ca}(\text{OH})_2$ increased. Even greater enhancement occurred when silicic acid was substituted for fly ash. SEM showed that reaction occurred to produce a more reactive calcium silicate.

46. W. Jozewicz and G. T. Rochelle. Fly Ash Recycle in Dry Scrubbing. Environ. Progress 5 (4), 218 (1986).

See notes on Jozewicz and Rochelle (45).

47. W. Jozewicz, J. C. S. Chang, T. G. Brna, and C. B. Sedman. Reactivation of Solids from Furnace Injection of Limestone for SO_2 Control. 1986 Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

Mixtures of spent sorbent and fly ash from the demonstration of furnace limestone injection at the Hoot Lake Station were characterized as received and after hydration. Virtually no SO_2 removal was measured with the as-received solids. Significant SO_2 removal, on the other hand, occurred after hydration; removal increased with the time and temperature of hydration. New chemical substances, including ettringite (a complex compound including CaO and SiO_2), were produced by the hydration process, and the BET surface area of the mixture substantially increased by the process.

48. W. Jozewicz, C. Jorgensen, J. C. S. Chang, C. B. Sedman, and T. G. Brna. Development and Pilot Plant Evaluation of Silica-Enhanced Lime Sorbents for Dry Flue Gas Desulfurization. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

The work described by Jozewicz et al. (47) was extended. $\text{Ca}(\text{OH})_2$ was tested as a sorbent for SO_2 in a sand-bed reactor as such or after chemical reaction with fly ash in water. Increasing amounts of fly ash increased reactivity. Diatomaceous earth produced an effect like that due to fly ash. The $\text{Ca}(\text{OH})_2$ sorbents modified by fly ash or diatomaceous earth were then tested in a pilot scale device including a humidifier, a sorbent injector, and a baghouse. Once-through sorbent removed 50 to 90% of the SO_2 at a Ca/S ratio of 1 to 2. Recycling raised the utilization from about 50% to 80-90%.

49. W. Jozewicz, J. C. S. Chang, C. B. Sedman, and T. G. Brna. Characterization of Advanced Sorbents for Dry SO_2 Removal. AIChE National Meeting. Houston, TX. March 29-April 2, 1987.

The work described earlier by Jozewicz et al. (47, 48) on SiO_2 -enhanced sorbents was further extended to include these variables: 1) fly ash to lime ratios from 1:1 to 1:10, 2) phosphate additives, and 3) alternative sources of SiO_2 including clays.

50. W. Jozewicz, J. C. S. Chang, C. B. Sedman, and T. G. Brna. Silica-Enhanced Sorbents from Dry Injection Removal of SO₂ from Flue Gas. Air Pollution Control Association Annual Meeting. New York, NY. June 21-26, 1987.

The principal innovation here in SiO₂ enhancement is the use of a pressure hydration vessel.

51. W. Jozewicz, J. C. S. Chang, T. G. Brna, and C. B. Sedman. Reactivation of Solids from Furnace Injection of Limestone for SO₂ Control. J. Air Pollut. Control Assoc. 21 (7), 664 (1987).

See notes on Jozewicz et al. (47).

52. W. Jozewicz, J. C. S. Chang, C. B. Sedman, and T. G. Brna. Silica-Enhanced Sorbents for Dry Injection Removal of SO₂ from Flue Gas. J. Air Pollut. Control Assoc. 38 (8), 1027 (1988).

See notes on Jozewicz et al. (50).

53. H. T. Karlsson, J. Klingspor, M. Linné, and I. Bjerle. Activated Wet-Dry Scrubbing of SO₂. J. Air Pollut. Control Assoc. 33, 23 (1983).

This paper discusses the concept of using a promoter, such as CaCl₂, to improve wet-dry scrubbing of SO₂ by limestone or lime in slurry. The concept was tested in the laboratory and on the pilot scale. The criteria by which a promoter was found acceptable are performance as a deliquescent material and suppression of the solubility of dissolved SO₂ by forming an insoluble hydroxide. Experimental results in a pilot unit indicate that promoted limestone is a feasible option to lime in wet-dry scrubbing.

54. H. T. Karlsson and J. Klingspor. Tentative Modelling of Spray Dry Scrubbing of SO₂. Excerpt from doctoral thesis of J. Klingspor. Lund Institute of Technology, Lund, Sweden. April 1986.

The development of the spray-dryer model was augmented by data from a 0.5-MW pilot plant. The primary conclusions are as follows: 1) with a high excess of lime, SO₂ absorption is limited by gas-phase diffusion; 2) with a shortage of lime, the dissolution of lime is rate-determining; 3) the flow patterns in a spray dryer can best be described as well mixed; and 4) the SO₂ concentration has no direct effect on removal efficiency.

55. T. Kenakkala, M. Suokas, J. Hautanen. The Tampella LIFAC SO₂ Removal Process. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

The LIFAC process consists of two steps: 1) injection of limestone in a boiler and 2) low-temperature activation of the spent sorbent with a water spray. This paper describes the full-scale operation of the process, following successful laboratory and pilot-scale developments.

56. T. Kenakkala. LIFAC: the Solution to Sulphur Emissions. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper reports the current status of the LIFAC process, previously discussed by Kenakkala et al. (55).

57. M. Kinzey and P. Harriott. Effects of Droplet Size and Residual Water on SO₄ Removal in a Spray Dryer. AIChE National Meeting. Houston, TX. March 29-April 2, 1987.

This paper is an extension to the original description of the model by Harriott and Kinzey (35).

58. M. K. Kinzey and P. Harriott. Effects of Droplet Size Distribution on the Dry Scrubbing Process for Flue Gas Desulfurization. AIChE National Meeting. Washington, DC. November 1988.

This paper is another extension of an earlier model (see Harriott and Kinzey (35), and Kinzey and Harriott (57)). The treatment here broadens the applicability of the model by dealing with a polydisperse spray rather than a monodisperse spray.

59. J. Klingspor, H. T. Karlsson, and I. Bjerle. A Kinetic Study of the Dry SO₂-Limestone Reaction at Low Temperature. Chem. Eng. Commun. 22, 81 (1983).

This study was focussed on wet-dry scrubbing. Variables were 1) temperature, 313-353 K; SO₂ concentration, 50-4000 ppm; O₂ concentration, 0-9%; CO₂ concentration, 0-10%; relative humidity, 0-92%; limestone particle size, 4-100 μ m; and limestone conversion, 0-95%. The rate is most dramatically affected by relative humidity, particle size, and degree of prior conversion.

60. J. Klingspor, A. Strömberg, H. T. Karlsson, and I. Bjerle. Similarities between Lime and Limestone in Wet-Dry Scrubbing. Chem. Eng. Process 18, 239 (1984).

Limestone is not considered competitive with lime for wet-dry scrubbing of SO₂ because of its lower reactivity. Limestone, however, is potentially less expensive; thus, ways to upgrade its reactivity were studied. Factors which have a major impact on the reactivity of lime and limestone in the dry reaction period include the sorptive capacity for water vapor, the BET surface area, the relative humidity, and the extent of conversion to the SO₂ deviation. Ways to enhance limestone reactivity include careful selection of the stone, extreme grinding, addition of deliquescent salts, and addition of an oxidizing catalyst, for converting SO₂ to SO₃.

61. J. S. Klingspor. Improved Spray Dry Scrubbing Using a Grinding of FGD Recycle Material. J. Air Pollut. Control Assoc. 37, 801 (1987).

The effect of grinding waste on SO₂ removal was studied in a laboratory-scale spray dryer and pulse jet baghouse. Grinding can enhance SO₂

removal to a level comparable to that achieved with a large excess of free lime.

62. J. C. Kramlich, D. K. Moyeda, G. H. Newton, and R. Payne. Rate Controlling Processes in Humidification for Duct SO_2 Capture. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

Two aspects of the reaction of $\text{Ca}(\text{OH})_2$ with SO_2 under duct injection conditions were investigated. First, the factors that influence the physical wetting of sorbent particles were characterized. Second, the reactivity of the sorbent in a slurry droplet was determined.

63. S. Kudo, M. Narita, T. Ueno, N. Arashi, T. Nishimura, and T. Mizoguchi. Dry Flue Gas Desulfurization Process Using Absorbent Made from Flyash. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

The raw materials of the absorbent are fly ash, lime, and gypsum. The reaction mechanisms with SO_2 are differentiated from those with conventional sorbents. A pilot demonstration of the sorbent has attained 90% SO_2 removal at a Ca/S ratio of 1.05 to 1.10.

64. M. Linné, J. Klingspor, H. T. Karlsson, and I. Bjerle. Limestone Based Wet-Dry Scrubbing to Form Gypsum. Chem. Eng. Sci. 37, 807 (1982).

This paper describes the addition of $\text{Co}(\text{NO}_3)_2$ to limestone for wet-dry scrubbing. The intent was to produce a more useful product — CaSO_4 , rather than CaSO_3 . Another advantage gained was more effective utilization of the sorbent.

65. M. M. Maibodi, T. L. Pearson, R. M. Counce, and W. T. Davis. Simulation of Spray Dryer Absorber for Removal of SO_2 from Flue Gases. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

The authors present a generalized equation for the SO_2 mass transfer that accounts for gas-phase, liquid-phase, and dissolution resistances. This equation is incorporated into the Damle model.

66. D. K. Moyeda, G. H. Newton, J. F. LaFond, R. Payne, and J. C. Kramlich. Rate Controlling Processes and Enhancement Strategies in Humidification for Duct SO_2 Capture. EPA-600/2-88-047. U.S. Environmental Protection Agency, Research Triangle Park, NC. August 1988.

This report summarizes an investigation of the fundamental rate processes that govern SO_2 capture at low temperatures with flue-gas humidification, specifically when furnace-injected sorbents are reactivated for post-furnace SO_2 capture. Physical contact between spray water and sorbent seems to be essential; ways to promote contact are described. With sorbent wetting, the dissolution rate of sorbent and droplet lifetime are the principal factors governing SO_2 capture.

67. P. S. Nolan, R. V. Henricks, and N. Kresovich. Operation of the LIMB/Humidifier Demonstration at Edgewater. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

The demonstration at Ohio Edison's Edgewater station was originally planned primarily to deal with furnace injection of $\text{Ca}(\text{OH})_2$ for SO_2 removal. Later, however, it became necessary to add flue gas humidification to the cold end of the system. Humidification became necessary because water-vapor conditioning was needed to lower the resistivity of the ash to achieve acceptable ESP performance. Supplemental SO_2 removal at low temperatures may thus be achieved.

68. G. P. Partridge, W. T. Davis, R. M. Counce, and G. D. Reed. A Mathematical Model for SO_2 Removal in a Spray Dryer Absorber. AIChE National Meeting, Houston, TX. March 29-April 2, 1987.

This paper extends the modeling work of Damle (18), Davis et al. (20), and Maibodi et al. (65). The primary change in earlier models improves the ability to deal adequately with a wide range of slurry concentrations.

69. H. W. Pennline, J. H. Tice, J. T. Newman, J. Z. Abrams, and A. D. Benz. The Bechtel Confined Zone Dispersion Process for FGD Retrofit Situations. J. Air Pollut. Control Assoc. 38, 1334 (1988).

This paper is a synopsis of work described fully by Bechtel National, Inc. (8).

70. J. R. Peterson and G. T. Rochelle. Production of Lime/Fly Ash Absorbents. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper reports a fundamental investigation of the $\text{Ca}(\text{OH})_2$ reaction with fly ash under hydrous conditions. The dissolution rate of ash, thought to be the limiting step, depends on ash type and pH. High calcium ashes dissolve faster than do low calcium ashes; the dissolution rate for either increases as pH is raised. A method was developed for determining the composition of the reactive layer of the $\text{Ca}(\text{OH})_2$ -ash reaction products. The method determines the conversion of silica, which correlates with the ability of the substance to remove SO_2 .

71. J. R. Peterson and G. T. Rochelle. Aqueous Reaction of Fly Ash and $\text{Ca}(\text{OH})_2$ to Produce Calcium Silicate Absorbent for Flue Gas Desulfurization. Environ. Sci. Technol. 22, 1299 (1988).

This paper describes determinations of dissolved calcium when fly ash and $\text{Ca}(\text{OH})_2$ are slurried at 85 °C. Higher concentrations of dissolved calcium are favorable to obtaining a reactive product. Dissolved calcium is affected by the ratio of ash to $\text{Ca}(\text{OH})_2$, the ash type, the presence of CaSO_3 , and the presence of NaOH .

72. T. Peterson, J. Peterson, H. T. Karlsson, and I. Bjerle. Physical and Chemical Activation of Fly Ash to Produce Reagents for Dry FGD Processes. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

Wet grinding of fly ash prior to reaction with lime dramatically increases the reactivity of the reaction product. Grinding of high calcium-ash produces a highly reactive product even in the absence of lime due to the reaction with silica calcium released from the ash. Reactivity of the ground ash in a slurry is comparable to the reactivity of a lime-based slurry.

73. F. G. Pohl, M. McElroy, and R. Rhudy. Pilot Evaluation of Combined SO_2 and Particulate Removal on a Fabric Filter. First Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. San Diego, CA. November 13-16, 1984.

Pilot tests were conducted with a 100-acfm slipstream from a pulverized coal boiler. Calcium compounds were injected and humidified with water or steam. The work here, at the EPRI test facility at Sneads, FL, was later continued on a larger scale at the Arapahoe Test Center in Denver, as reported by Blythe et al. (11, 12).

74. R. Rhudy, M. McElroy, and G. Offen. Status of Calcium-Based Dry Sorbent Injection SO_2 Control. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

Various processes using dry, calcium-based sorbents are reviewed. They include processes using the boiler, convection pass, and downstream ducts for injection sites. They also include the hybrid system dubbed HYPAS (see Giovanni et al. (29)).

75. L. A. Rohlack, G. M. Blythe, T. G. Brna, and R. G. Rhudy. Evaluation of a Bench-Scale Dry Flue Gas Desulfurization System for Screening Potential Reagents and Operating Conditions. EPA-600/D-86-042. U.S. Environmental Protection Agency, Research Triangle Park, NC. February 1986.

Two series of bench-scale experiments are described. The first used a spray dryer/fabric filter system for once-through and recycle tests with hydrated lime. The second series involved a modification in apparatus to permit dry injection of reagents (sodium- and calcium-based).

76. R. N. Ruiz-Alsop and G. T. Rochelle. Effect of Deliquescent Salt Additives on the Reaction of SO_2 with $\text{Ca}(\text{OH})_2$. ACS Symposium Series 319, 208 (1986).

The effects of relative humidity, temperature, amount of lime, and SO_2 concentration on the reaction of SO_2 with $\text{Ca}(\text{OH})_2$ solids in a sand bed reactor was studied. Small amounts of salts, some deliquescent and other not, were incorporated in the $\text{Ca}(\text{OH})_2$. Most of the salts tested increased reactivity; the most effective were LiCl , NaCl , KCl , NaBr , and NaNO_3 .

77. R. Ruiz-Alsop and G. T. Rochelle. Effect of Relative Humidity and Additives on the Reaction of Sulfur Dioxide with Calcium Hydroxide. EPA-600/2-88-037. U.S. Environmental Protection Agency, Research Triangle Park, NC. July 1988.

A synopsis of the experimental work discussed in this report is given in the notes on Ruiz-Alsop and Rochelle (76). Modelling of the data, which is also included in the report, addresses the SO_2 absorption in the semi-dry stage, after the lime solids have reached a pseudo-equilibrium moisture content. The process is treated by a shrinking core model with gas-film diffusion, product layer diffusion, and chemical reaction. At high relative humidities and high SO_2 concentrations, the reaction kinetics were found to be controlling. At low relative humidities and low SO_2 concentrations, product layer diffusion was said to control.

78. E. A. Samuel, T. W. Lugar, D. E. Lapp, and K. R. Murphy. Process Characterization of SO_2 Removal in Spray Absorber/Baghouse Systems. Eighth Symposium on Flue Gas Desulfurization. New Orleans, LA. November 1983.

This paper presents a modified version of the simplified equation of Downs et al. (22). The modified version makes allowance for the effects of stoichiometry and variable particle size of the dried reaction product. In applying the equation to correlate data at a given inlet SO_2 concentration, the authors reported correlation coefficients exceeding 0.9.

79. E. A. Samuel, K. R. Murphy, and A. Demian. A 12-MW Pilot Study of In-Duct Scrubbing (IDS) Using a Rotary Atomizer. Final Report to Department of Energy, Contract DE-AC22-85PC81010. January 1989 (Draft).

This report describes a field investigation of duct injection technology that was carried out by General Electric Environmental Services. The facilities for studies at the 12-MW scale were installed at the Muskingum River power plant of Ohio Edison Company. A key feature of GE's approach is injection of a $\text{Ca}(\text{OH})_2$ slurry through a rotary atomizer. The report discusses SO_2 removal, ancilliary NO_x removal, and ESP performance.

80. W. R. Seeker, S. L. Chen, J. C. Kramlich, S. B. Greene, and B. J. Overmoe. Fundamental Studies of Low-Temperature Sulfur Capture by Dry Calcitic Sorbent Injection. 1986 Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

Three experimental studies are described: laboratory determination of SO_2 removal in a fixed sorbent bed of $\text{Ca}(\text{OH})_2$, simulating the filter cake in a baghouse; laboratory determination of the relative degrees of SO_2 removal by sorbent in the dispersed phase and in filter bed; and pilot-scale evaluation of the performance of a baghouse collecting dispersed sorbent. The conclusions are that 1) low-temperature capture is most strongly influenced by relative humidity, 2) various hydrates differ little in reactivity, 3) sulfite is the main product of low-temperature reaction, 4) reaction rate is proportional to the SO_2 concentration, 5) $\text{Mg}(\text{OH})_2$ in dolomitic hydrates participates in low-temperature capture of SO_2 , and 6) useful catalysts fall in two categories — deliquescent additives (such as CaCl_2) and oxidation catalysts (such as V_2O_5).

81. L. E. Sparks, G. H. Ramsay, R. E. Valentine, and N. Plaks. Results of Pilot Tests of E-SOX. Sixth Symposium on the Transfer and Utilization of Particulate Control Technology. New Orleans, LA. February 25-28, 1986.

The E-SOX process for SO_2 removal consists of 1) the injection of an aqueous solution or slurry of an alkali in the chamber that formerly served as the first field of an ESP and 2) the removal of suspended particulate matter in the remaining fields of the ESP. This paper presents the results of mathematical modeling and pilot-plant study with NaHCO_3 sprayed in solution or Ca(OH)_2 in a slurry. NaHCO_3 removed more than 90% of the SO_2 and Ca(OH)_2 40-65%.

82. G. Staudinger, H. Schröfelbauer, and H. Meier. Laboratory Tests on Furnace Limestone Injection and Development of a Second Desulfurization Step with FLI Ash through Duct Injection. 1986 Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

The removal of SO_2 by furnace-injected limestone is augmented in a low-temperature process. The combination of spent sorbent from the furnace and fly ash (known as FLI ash) is separated from the flue gas, milled, treated with steam, and reinjected upstream from the dust collector.

83. G. Staudinger, P. Melcher, and E. Eckersdorfer. Austrian Experience with Furnace Limestone Injection. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper reports the current status of steam activation of the mixture of sorbent and fly ash resulting from boiler injection of calcium-based sorbent, previously described by Staudinger et al. (83).

84. M. R. Stouffer. Boiler Limestone Injection and Coolside Desulfurization Field Tests. Council of Industrial Boiler Owners Technical Committee Meeting. Washington, DC. February 4, 1986.

This paper deals with the 1-MW field demonstration of Coolside options, elsewhere described more comprehensively and in greater detail (Yoon et al. (89)).

85. M. R. Stouffer, M. M. Wu, H. Yoon, and R. A. Winschel. Support Activities for the Edgewater Coolside Process Demonstration. American Flame Research Committee 1988 Fall International Symposium. Pittsburgh, PA. October 4-6, 1988.

A demonstration of furnace injection of Ca(OH)_2 for SO_2 control is underway at Ohio Edison's Edgewater Station under the primary sponsorship of EPA. A subsequent demonstration, scheduled for 1989, will be a demonstration of the Coolside duct process based on injection of Ca(OH)_2 with spray humidification. This paper describes CONSOL's support activities for the latter demonstration. It includes a discussion of the evaluation of candidate sorbents of both calcitic and dolomitic types and the characterization of waste products from the Coolside process.

86. M. Stouffer. Multi-Nozzle Humidification Tests. Part IV, Final Report to Department of Energy (PETC), Pittsburgh, PA. Contract DE-AC22-85PC81012. December 1988.

This part of the report describes CONSOL's contribution to the investigation of HALT at Toronto Station. The work demonstrated humidifier scale-up from single-nozzle test data. See Babu et al. (4).

87. A. Strömberg and H. T. Karlsson. Spray Dry Absorption-Oxidation of SO_2/NO_x . First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper discusses additives to the conventional slurry in a spray dryer that would achieve NO_x removal as well as SO_2 removal. A promising additive, sodium chlorite, is workable with both lime and limestone.

88. H. Yoon, M. R. Stouffer, W. A. Rosenhoover, and R. M. Statnick. Laboratory and Field Development of Coolside SO_2 Abatement Technology. Second Annual Pittsburgh Coal Conference. Pittsburgh, PA. September 16-20, 1985.

Three options for flue-gas desulfurization with injections into low-temperature ducts with humidification are described. Straight Coolside involves dry injection of $\text{Ca}(\text{OH})_2$, followed by spray humidification. BLI/activation is based on boiler limestone injection; activation is by a water spray, which may contain an additive such as NaOH. BLI/recycle also is based on boiler limestone injection; it entails removal of spent sorbent on the cool side of the system (in an ESP, for example), followed by hydration in an external reactor, and reinjection in a low-temperature duct along with a water spray. The influences of sorbent surface area and salt additives are described on the basis of laboratory investigations.

89. H. Yoon, P. A. Ring, and F. P. Burke. Coolside Abatement Technology: 1-MW Field Tests. Coal Technology '85. Pittsburgh, PA. November 12-14, 1985.

Results are given for 1-MW field tests of CONSOL's three Coolside options (see Yoon et al. (88)). Injection of $\text{Ca}(\text{OH})_2$ with humidification in a low-temperature duct gave 80% removal of SO_2 at a sorbent utilization of 40%. Flue-gas humidification with a spray of NaOH additive during boiler limestone injection gave similar results. A study of process design and economics associated with the Coolside processes was performed and the results were compared with corresponding information for wet flue-gas desulfurization.

90. H. Yoon, J. A. Withum, W. A. Rosenhoover, and F. P. Burke. Sorbent Improvement and Computer Modeling Studies for Coolside Desulfurization. 1986 Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

Laboratory studies were made of two ways to improve the reactivity of $\text{Ca}(\text{OH})_2$ for Coolside desulfurization (see Yoon et al. (88)). One process is to control surface area by controlled hydration. The other process is to incorporate additives in the $\text{Ca}(\text{OH})_2$. Two ways to modify

Ca(OH)_2 with additives are described: 1) hydration of CaO in water containing dissolved additive; 2) slurring Ca(OH)_2 in a solution of an additive. Several compounds of sodium were found beneficial; several chloride compounds of various metals were also found beneficial, but organic compounds were without effect. The activation of spent sorbent from boiler limestone injection by rehydration is described. Finally, a computer model of flue-gas humidification with a water spray is developed. The paper points out the importance of the fluid mechanics and the atomizer performance on droplet trajectories and evaporation. A commercial fluid flow modeling package was used to simulate droplet dispersion and evaporation. The results suggested that careful optimization of the injection velocity was required to assure good dispersion. Poor dispersion was found to significantly retard evaporation by allowing zones of high humidity in the jet core.

91. H. Yoon, F. W. Theodore, F. P. Burke, and B. J. Koch. Low Capital Cost, Retrofit SO_2 Control Technologies for High Sulfur Coal Applications. Air Pollution Control Association 79th Annual Meeting. Minneapolis, MN. June 22-27, 1986.

Various boiler sorbent injection processes and coolside processes for flue-gas desulfurization are described and compared. The processes are CONSOL's Coolside, Dravo's HALT, EPRI's calcium-sorbent process, GE's in-duct scrubbing, Bechtel's CZD process, and EPA's E-SOX process.

92. H. Yoon, M. R. Stouffer, W. A. Rosenhoover, J. A. Withum, and F. P. Burke. Pilot Process Variable Study of Coolside Desulfurization: AIChE National Meeting. Houston, TX. March 29-April 2, 1987.

A discussion is given of the use of a 0.15-MW pilot test unit for studying CONSOL's Coolside option based on duct injection of Ca(OH)_2 , followed by humidification with a water spray. This pilot-scale study was a equal to laboratory and field studies reported earlier (Yoon et al. (88-91)). Parameters affecting SO_2 removal that were investigated consisted of the Ca/S molar ratio, the approach to adiabatic saturation, the additive NaOH as a component of the water spray, and the atomization pressure used with the water spray.

93. H. Yoon, M. R. Stouffer, and F. P. Burke. Coolside Desulfurization Reactions and Mechanisms. American Chemical Society National Meeting. New Orleans, LA. August 30-September 4, 1987.

The pilot unit previously described (Yoon et al., (92)) was used to address the issue of how humidification must be effected to activate Ca(OH)_2 in a low-temperature duct process. Humidification by steam, accompanied by cooling to approach water-vapor saturation, makes Ca(OH)_2 capable of removing significant amounts of SO_2 . Humidification by a water spray, on the other hand, which simultaneously cools the gas, is much more effective than humidification by steam. Physical wetting of the sorbent particles by collision with water droplets is therefore a key to successful Coolside desulfurization.

94. H. Yoon, M. R. Stouffer, W. A. Rosenhoover, J. A. Withum, and F. P. Burke. Pilot Process Variable Study of Coolside Desulfurization. Environ. Progress 7 (2), 104 (1988).

This published article is similar in content to the paper described under Yoon et al. (92).

PART B. ESP PERFORMANCE

1. J. H. Abbott, J. P. Gooch, and J. D. Kilgroe. Effects of Furnace Injection of Sorbent for SO_2 Control on Electrostatic Precipitator Technology and Requirements. Second International Conference on Electrostatic Precipitation. Kyoto, Japan. November 12-14, 1984.

This paper describes EPA sponsored research programs concerning ESP collection of ash/sorbent mixtures. Results of laboratory and in situ measurements of particle size distribution and resistivity are presented. The effects of SO_3 and water conditioning of the ash/sorbent mixture are discussed. The paper also presents computer simulations which show the effects of sorbent injection on ESP performance.

2. K. Bradburn and C. Mauritzson. Full Scale Precipitator Experience Following a Lime Slurry Flue Gas Desulphurization System. Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.

This paper describes the results of using a lime slurry for 18 months. No difficulties in ESP operation were encountered. Some evidence of beginning corrosion was observed.

3. C. A. Brown, G. M. Blythe, L. R. Humphries, R. F. Robards, R. A. Runyan, and R. G. Rhudy. Results from the TVA 10-MW Spray Dryer/ESP Evaluation. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper summarizes the results of the first 18 months of pilot scale tests. A ten-fold increase in ESP inlet loading was observed with the spray dryer on. No space charge induced corona suppression was detected. Cooler temperature and lower gas velocity resulted in increased SCA but not increased ESP efficiency. The authors infer increased reentrainment.

4. R. S. Dahlin, J. P. Gooch, and J. D. Kilgroe. Effects of Furnace Sorbent Injection on Fly Ash Characteristics and Electrostatic Precipitator Performance. First Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. San Diego, CA. November 13-16, 1984.

This paper discusses the same data as the paper by Abbott et al. (1) which was presented simultaneously in Kyoto.

5. C. J. Drummond (editor). Duct Injection Technologies for SO₂ Control. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper is a compilation of the reports of several authors. The HALT process (Hydrate Addition at Low Temperature - duct injection of hydrated lime followed by humidification) is discussed, with a brief comparison of ESP and baghouse performance. The CZD process (Confined Zone Dispersion - a narrow, non-wall-wetting hydrated lime slurry spray) is also discussed. Results on a pilot-scale ESP showed increased emissions. Results on a full-scale ESP showed a short term drop in opacity. However, after 5 to 10 hours, the opacity rose and could only be reduced by power-off rapping. For In-Duct Scrubbing (duct injection of a slaked-lime slurry), the ESP behaved normally except for a slight change in operating point in the first field. Humidification scale-up and the use of arrays of spray nozzles is discussed. DOE's research plan for SO₂ control was summarized.

6. J. L. DuBard, J. P. Gooch, R. Beittel, S. L. Rakes, and G. R. Offen. Particle Properties Related to ESP Performance with Sorbent Injection and Gas Conditioning. Proceedings: 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies, Vol. 2. EPRI CS4966. Electric Power Research Institute, Palo Alto, CA. December 1986.

This paper describes pilot- and laboratory-scale measurements of ash/sorbent particle properties related to ESP performance. The data include in situ resistivities, particle size distributions, and the effect of dust load on ESP V-I characteristics. Humidification and SO₃ were each evaluated as conditioning agents. A mathematical model was used to project ESP performance with flue gas conditioning, over a range of SCA values up to 300 ft²/kacfm.

7. M. D. Durham, C. Huang, J. DeGuzman, B. F. Kee, and R. G. Rhundy. Analysis of the Performance of an ESP Operating Downstream of a Spray Dryer on High-Sulfur-Coal Flue Gas. Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.

This paper discusses data from the 10-MW spray dryer/ESP pilot plant at Shawnee Station. Tests were run at different SCAs and gas velocities. No difficulties were encountered, although the ESP performance did not show the expected performance improvement. Increased reentrainment is the suspected cause.

8. T. E. Emmel and N. Kaplan. Lime/Limestone FGD and Sorbent Injection Technology Retrofit Difficulty at 60 Coal-Fired Utility Power Plants. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper discusses criteria for choosing to retrofit a plant with furnace or duct sorbent injection. Cost analyses are also discussed.

9. G. C. England, B. A. Folsom, R. Payne, T. M. Sommer, P. J. Chappell, M. W. McElroy, and I. A. Huffman. Field Evaluation of Humidification for Precipitator Performance Enhancement. Seventh Symposium on the Transfer and

Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.

This paper presents initial results of a full scale utility boiler evaluation of ash/sorbent conditioning by flue gas humidification. Only short-term (less than 4-6 hours) operation was studied. Data acquisition was limited to normal plant and system operating parameters. Humidification resulted in significantly improved ESP electrical performance and lower opacity.

10. G. C. England, B. A. Folsom, R. Payne, T. M. Sommer, M. W. McElroy, P. J. Chappell, and I. A. Huffman. Prototype Evaluation of Sorbent Injection with Humidification. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper is a later version of the paper presented at Nashville (9). Humidification is said to have been extremely effective in maintaining ESP performance. Inspection after 300 hours showed no permanent buildup of material in the ESP and only minor deposits in the duct immediately downstream of the nozzles.

11. M. G. Faulkner, J. P. Gooch, R. Beittel, and J. L. DuBard. Rapping Properties of Precipitated Ash/Sorbent Mixtures. Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.

This paper compares the rapping characteristics of fly ash and ash/sorbent mixtures on the basis of the rapping accelerations required to clean the ESP plates and of visual observations of the ash layer throughout the collection and rapping process. The measurements were made on a laboratory ESP on dust generated by a pilot coal combustor. The processes examined were SO₃ conditioned LIMB ash, humidified LIMB ash, and lime-slurry conditioned ash.

12. Faulkner, M. G., G. H. Marchant, Jr., E. C. Landham, Jr., and J. L. DuBard. Field and Laboratory Measurements of Fly Ash Properties and Precipitator Performance Parameters with Furnace Sorbent Injection. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper describes the failure of the Edgewater ESP to collect unconditioned LIMB ash. The paper then describes the humidified LIMB experiments at SRI. Observations of the pilot ESP include electrical operating points, rapping characteristics of the ash, ash resistivity, and opacity as the temperature was reduced to saturation. Results of modeling based on the pilot ESP data were presented.

13. N. W. Frisch and W. R. Hartshorn. A Design Methodology for Optimized Water Conditioning of High Resistivity Fly Ash. Proceedings: Sixth Symposium on the Transfer and Utilization of Particulate Control Technology, Volume 2. EPRI CS-4918. Electric Power Research Institute, Palo Alto, CA. November 1986.

This paper discussed the importance of controlling resistivity in an ESP. A literature review on the effects of moisture and temperature on

fly ash resistivity is presented. Use of Sonic Development Corp.'s design model for estimating the amount of water necessary and configuring the system is presented. Conclusions re. humidification are listed.

14. J. P. Gooch, J. L. DuBard, and R. Beittel. The Influence of Furnace Sorbent Injection on Precipitator Performance, and Methods for Improving Performance. Third International Conference on Electrostatic Precipitation. Abano-Padova, Italy. October, 1987.

This paper is a more detailed version of the paper given by DuBard et al. (6).

15. J. P. Gooch, G. H. Marchant, Jr., R. Beittel, and J. L. DuBard. The Effect of Hydrate Injection on ESP Performance. 81st Annual Meeting of the Air Pollution Control Association. Dallas, TX. June 20-24, 1988.

This paper compares the HALT and LIMB sorbent injection processes, in regard to their effect on ESP performance. Measurements of the changes in inlet particle mass loading and size distribution and the bulk electrical resistivity are presented. Computer simulations of these changes on ESP performance are discussed.

16. D. J. Helfritch, P. L. Feldman, B. Weinstein, and M. W. McElroy. Electrostatic Precipitator Upgrades for Furnace Sorbent Injection. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

This paper examines the benefits of increasing SCA, humidification, cooling by heat exchange, pulse energization, and SO₃ conditioning as applied to sorbent conditioned fly ash. Cost analysis is included.

17. R. G. Hooper. Full Scale Demonstration of Flue Gas Desulfurization by the Injection of Dry Sodium Bicarbonate Upstream of an Electrostatic Precipitator. Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.

This paper discusses duct injection of sodium bicarbonate. The data show that the ash resistivity was essentially unchanged by the sorbent addition and that ESP performance remained satisfactory throughout the test.

18. L. S. Hovis, R. E. Valentine, B. J. Jankura, P. Chu, and J. C. S. Chang. E-SOX Pilot Evaluation. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper describes results of E-SOX experiments with a laboratory-scale ESP. Data showed that there was no significant change in efficiency with dust loading as long as some moisture was present. Plans for a 5-MWe pilot-scale test were presented.

19. M. S. Mozes, R. Mangal, and R. Thampi. Sorbent Slurry Injection for SO₂ Control. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper reports on an in-furnace sorbent slurry injection study performed by Ontario Hydro. In spite of a resistivity rise from 10^8 to 10^9 - 10^{10} ohm-cm, no problems were encountered with the ESP.

20. P. S. Nolan, R. V. Hendriks, and N. Kresovich. Operation of the LIMB/Humidifier Demonstration at Edgewater. First Combined FGD and Dry SO_2 Control Symposium. St. Louis, MO. October 25-28, 1988.

This paper is the first report on the operation of the LIMB/humidifier system. Initial results show that humidifier outlet temperatures of about 250 °F are adequate to allow the ESP to operate continuously with no high resistivity problems.

21. H. Yoon, J. A. Withum, W. A. Rosenhoover, and F. P. Burke. Sorbent Improvement and Computer Modeling Studies for Coolside Desulfurization. 1986 Joint Symposium on Dry SO_2 and Simultaneous SO_2/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

This paper describes laboratory studies of methods to improve coolside and furnace-injected sorbent utilizations. Also discussed are modeling studies of nozzle and humidifier design and operating parameters.

5.0 REFERENCES CITED

1. C. J. Drummond (editor). Duct Injection Technologies for SO₂ Control. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.
2. Bechtel National, Inc. (no personal authors listed). Desulfurization of Flue Gas by the Confined Zone Dispersion Process. Final Report to Department of Energy, Contract DE-AC22-85PC81009. April 1988 (Draft).
3. E. A. Samuel, K. R. Murphy, and A. Demian. A 12-MW Pilot Study of In-Duct Scrubbing (IDS) Using a Rotary Atomizer. Final Report to Department of Energy, Contract DE-AC22-85PC81010. January 1989 (Draft).
4. L. E. Sparks, G. H. Ramsay, R. E. Valentine, and N. Plaks. Results of Pilot Tests of E-SOX. Sixth Symposium on the Transfer and Utilization of Particulate Control Technology. New Orleans, LA. February 25-28, 1986.
5. D. V. Giovanni, R. G. Rhudy, J. McCarthy, and R. Giles. Technical and Economic Evaluation of HYPAS. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.
6. M. R. Stouffer, M. M. Wu, H. Yoon, and R. A. Winschel. Support Activities for the Edgewater Coolside Process Demonstration. American Flame Research Committee 1988 Fall International Symposium. Pittsburgh, PA. October 4-6, 1988.
7. M. Babu, R. C. Forsythe, C. V. Runyon, E. Evans, and J. L. Thompson. Results of 1.0 MM Btu/h Testing of HALT (Hydrate Addition at Low Temperature) for SO₂ Control. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 26, 1986.
8. M. Babu, J. College, R. Forsythe, R. Herbert, D. Kanary, and K. Lee. 5-MW Toronto HALT Pilot Plant. Part I, Final Report to Department of Energy, Contract DE-AC22-85PC81012. June 1988 (Draft).
9. J. P. Gooch, R. Beittel, E. B. Dismukes, and R. S. Dahlin. Humidification of Flue Gas to Augment SO₂ Capture by Dry Sorbents. Topical Report to Environmental Protection Agency, EPA Cooperative Agreements No. CR 811683 and CR 812811. August 1988 (Draft).
10. R. H. Borgwardt and K. R. Bruce. Effect of Specific Surface Area on the Reactivity of CaO with SO₂. AIChE Journal 32, 239 (1986).
11. S. J. Bortz, V. P. Roman, and R. J. Yang. Dry Hydroxide Injection at Economizer Temperature for Improved SO₂ Control. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

12. S. J. Bortz, V. Roman, and G. Offen. Hydrate and Process Parameters Controlling SO₂ Removal During Hydroxide Injection near 1000 °F. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.
13. A. S. Damle. Modeling of SO₂ Removal in Spray Dryer Flue-Gas Desulfurization System. EPA-600/7-85-038. December 1985.
14. J. P. Gooch, J. L. DuBard, M. G. Faulkner, Jr., R. S. Dahlin, and R. Beittel. Effects of Sorbent Injection for Sulfur Dioxide Removal on Particulate Control Systems for Coal-Fired Boilers. EPA-600/7-88-023. U.S. Environmental Protection Agency, Research Triangle Park, NC. November 1988.
15. L. Brewer. Thermodynamic Values for Desulfurization Processes. In: Flue Gas Desulfurization (J. L. Hudson and G. T. Rochelle, editors). ACS Symp. Ser. 188, 1 (1982).
16. V. P. Parker, B. R. Staples, T. L. Jobe, Jr., and D. B. Neumann. A Report on Some Thermodynamic Data for Desulfurization Processes. DOE/METC-82-656. September 1981.
17. D. D. Wagman, W. H. Evans, V. B. Parker, R. H. Schumm, I. Halow, S. M. Bailey, K. L. Churney, and R. L. Nutall. The NBS Tables of Chemical Thermodynamic Properties. J. Phys. Chem. Ref. Data 11, Supplement No. 2 (1982).
18. R. P. Bell and J. H. B. George. The Incomplete Dissociation of Some Thallous and Calcium Salts at Different Temperatures. Trans. Faraday Soc. 49, 619 (1953).
19. D. Cubicciotti, A. Sanjurjo, and D. L. Hildenbrand. The Thermal Decomposition of CaSO₃ and Its Enthalpy of Formation. J. Electrochem. Soc. 124, 933 (1977).
20. H. M. Spencer and J. L. Justice. Empirical Heat Capacity Equations for Simple Gases. J. Am. Chem. Soc. 56, 2311 (1934).
21. H. M. Spencer and G. N. Flanagan. Empirical Heat Capacity Equations of Gases. J. Am. Chem. Soc. 64, 2511 (1942).
22. D. R. Glasson. Reactivity of Lime and Related Oxides. II. Sorption of Water Vapor on Calcium Oxide. J. Appl. Chem. 8, 798 (1958).
23. J. Klingspor, A. Strömberg, H. T. Karlsson, and I. Bjerle. Similarities between Lime and Limestone in Wet-Dry Scrubbing. Chem. Eng. Process 18, 239 (1984).
24. E. W. Washburn, Editor-in-Chief. International Critical Tables. McGraw-Hill Book Company, New York, NY. Volume III, p. 258 (1928).
25. D. W. Green, Editor. Perry's Chemical Engineers' Handbook. McGraw-Hill Book Company, New York, NY. Sixth Edition, p. 3-103 (1984).

26. A. E. Rabe and J. F. Harris. Vapor Liquid Equilibrium Data for the Binary System, Sulfur Dioxide and Water. J. Chem. Eng. Data 8, 333 (1963).
27. W. F. Linke. Solubilities, Inorganic and Metal-Organic Compounds. D. Van Nostrand Company, Inc. Princeton, NJ. 1958.
28. H. Bassett. Notes on the System Lime-Water, and on the Determination of Calcium. J. Chem. Soc. 1934, 1270.
29. R. G. Hooper, V. Bland, F. G. Pohl, M. McElroy, and R. Rhudy. Pilot Evaluation of Combined Particulate and SO₂ Removal Using a Fabric Filter System. Ninth Symposium on Flue Gas Desulfurization. Cincinnati, OH. June 4-7, 1985.
30. V. V. Bland, J. J. Hammond, and R. G. Rhudy. Full Scale Demonstration of Additive NO₂ Reduction with Dry Sodium Desulfurization. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.
31. G. Blythe, R. Smith, M. McElroy, R. Rhudy, V. Bland, and C. Martin. EPRI Pilot Testing of SO₂ Removal by Calcium Injection Upstream of a Particulate Control Device. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.
32. C. Jorgensen, J. C. S. Chang, and T. G. Brna. Evaluation of Sorbents and Additives for Dry SO₂ Control. Environ. Progress 6 (2), 26 (1987)
33. H. T. Karlsson, J. Klingspor, M. Linné, and I. Bjerle. Activated Wet-Dry Scrubbing of SO₂. J. Air Pollut. Control Assoc. 33 (1), 23 (1983).
34. R. N. Ruiz-Alsop and G. T. Rochelle. Effect of Deliquescent Salt Additives on the Reaction of SO₂ with Ca(OH)₂. ACS Symposium Series 319, 208 (1986).
35. H. Yoon, J. A. Withum, W. A. Rosenhoover, and F. P. Burke. Sorbent Improvement and Computer Modeling Studies for Coolside Desulfurization. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.
36. H. Yoon, P. A. Ring, and F. P. Burke. Coolside Abatement Technology: 1-MW Field Tests. Coal Technology '85. Pittsburgh, PA. November 12-14, 1985.
37. H. Yoon, M. R. Stouffer, W. A. Rosenhoover, J. A. Withum, and F. P. Burke. Pilot Process Variable Study of Coolside Desulfurization. AIChE National Meeting. Houston, TX. March 29-April 2, 1987.
38. M. Linné, J. Klingspor, H. T. Karlsson, and I. Bjerle. Limestone Based Wet-Dry Scrubbing to Form Gypsum. Chem. Eng. Sci. 37, 807 (1982).
39. W. R. Seeker, S. L. Chen, J. C. Kramlich, S. B. Greene, and B. J. Overmoe. Fundamental Studies of Low-Temperature Sulfur Capture by Dry Calcitic Sorbent Injection. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.

40. G. Blythe, V. Bland, C. Martin, M. McElroy, and R. Rhudy. Pilot-Scale Studies of SO₂ Removal by Addition of Calcium-Based Sorbents Upstream of a Particulate Control Device. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.
41. W. Jozewicz and G. T. Rochelle. Fly Ash Recycle in Dry Scrubbing. Environ. Progress 5 (4), 218 (1986).
42. W. Jozewicz, J. C. S. Chang, T. G. Brna, and C. B. Sedman. Reactivation of Solids from Furnace Injection of Limestone for SO₂ Control. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.
43. W. Jozewicz, J. C. S. Chang, C. B. Sedman, and T. G. Brna. Silica-Enhanced Sorbents for Dry Injection Removal of SO₂ from Flue Gas. J. Air Pollut. Control Assoc. 38, 1027 (1988).
44. R. H. Borgwardt and K. R. Bruce. EPA Study of Hydroxide Reactivity in a Differential Reactor. 1986 Joint Symposium on Dry SO₂ and Simultaneous SO₂/NO_x Control Technologies. Raleigh, NC. June 2-6, 1986.
45. H. Yoon, M. R. Stouffer, and F. P. Burke. Coolside Desulfurization Reactions and Mechanisms. American Chemical Society National Meeting. New Orleans, LA. August 30-September 4, 1987.
46. J. L. Getler, H. L. Shelton, and D. A. Furlong. Modeling the Spray Absorption Process for SO₂ Removal. J. Air Pollut. Control Assoc. 29, 1270 (1979).
47. W. Downs, W. J. Sanders, and C. E. Miller. Control of SO₂ Emissions by Dry Scrubbing. American Power Conference. Chicago, Illinois. April 21-23, 1980.
48. E. A. Samuel, T. W. Lugar, D. E. Lapp, and K. R. Murphy. Process Characterization of SO₂ Removal in Spray Absorber/Baghouse Systems. Eighth Symposium on Flue Gas Desulfurization. New Orleans, LA. November 1983.
49. W. Jozewicz and G. T. Rochelle. Modeling of SO₂ Removal by Spray Dryers. Pittsburgh Coal Technology Conference. Pittsburgh, PA. September 17-21, 1984.
50. R. Ruiz-Alsop and G. T. Rochelle. Effect of Relative Humidity and Additives on the Reaction of Sulfur Dioxide with Calcium Hydroxide. EPA-600/2-88-037. U.S. Environmental Protection Agency, Research Triangle Park, NC. July 1988.
51. P. Harriott and M. Kinzey. Modeling the Gas and Liquid Phase Resistances in the Dry Scrubbing Process for SO₂ Removal. Third Annual Pittsburgh Coal Conference. Pittsburgh, PA. September 1986.
52. M. M. Maibodi, T. L. Pearson, R. M. Counce, and W. T. Davis. Simulation of Spray Dryer Absorber for Removal of SO₂ from Flue Gases. Tenth Symposium on Flue Gas Desulfurization. Atlanta, GA. November 18-21, 1986.

53. P. Harriott. A Simple Model for the In-Duct Injection Process for SO₂ Removal. Unpublished Paper. U.S. Department of Energy, Pittsburgh Energy Technology Center, Pittsburgh, PA. 1989.
54. R. Beittel and R. S. Dahlin. Mechanistic Studies of Sorbent Utilization Enhancement by Humidification. First Combined FGD and Dry SO₂ Control Symposium. St. Louis, MO. October 25-28, 1988.
55. W. E. Ranz and J. B. Wong. Impaction of Dust and Smoke Particles on Surface and Body Collectors. Ind. Eng. Chem. 44, 1371 (1952).
56. L. J. Muzio. Fossil Energy Research Corp., Personal Communication to J. P. Gooch, Southern Research Institute. December 11, 1986.
57. W. Strauss. Industrial Gas Cleaning. Pergamon Press, New York, NY. 1966. p 302.
58. W. Deutsch. Ann. Phys. (Leipzig) 68, 335 (1922).
59. J. C. Williams and R. Jackson. The Motion of Solid Particles in an Electrostatic Precipitator. The Third Congress of The European Federation of Chemical Engineering, Symposium on the Interaction between Fluids and Particles. 1962.
60. G. Leonard, M. Mitchner, and S. A. Self. Particle Transport in Electrostatic Precipitators. Atmos. Environ. 14, 1289 (1980).
61. S. A. Self, M. Mitchner, and K. D. Kihm. Effects of Turbulence in Wire-Plate Precipitators. The Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.
62. M. G. Faulkner, and J. L. DuBard. A Mathematical Model of Electrostatic Precipitation (Revision 3). EPA-600/7-84-069a,b,c. (Volume I, Modeling and Programming; Volume II, User's Manual; FORTRAN Source Code Tape) U.S. Environmental Protection Agency, Research Triangle Park, North Carolina. 1984.
63. W. B. Smith, and J. R. McDonald. Development of a Theory for the Charging of Particles by Unipolar Ions. J. Aerosol Sci. 7, 151 (1976).
64. J. L. DuBard, and R. S. Dahlin. Precipitator Performance Estimation Procedure. EPRI CS-5040. Electric Power Research Institute, Palo Alto, CA. 1987.
65. P. A. Lawless, and L. E. Sparks. An Interactive Computer Model for Calculating V-I Curves in ESPs. Version 1.0. EPA-600/8-86-030. U.S. Environmental Protection Agency, Research Triangle Park, NC. 1986.
66. P. A. Lawless, N. Plaks, and L. E. Sparks. An Interactive Model for Analysis of Electrical Conditions in Electrostatic Precipitators. The Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.

67. M. G. Faulkner, J. L. DuBard, and L. S. Hovis. A Self-Consistent Deutschian ESP Model. The Seventh Symposium on the Transfer and Utilization of Particulate Control Technology. Nashville, TN. March 22-25, 1988.
68. K. D. Kihm. Effects of Nonuniformities on Particle Transport in Electrostatic Precipitators. Topical Report T-258. High Temperature Gasdynamics Laboratory, Stanford University. March, 1987.

END

**DATE
FILMED
6 / 1 / 92**