EGG-EAST-9853
February 1991

MAR 26 1992

INFORMAL REPORT

EVALUATION OF THE LOSS OF RESIDUAL HEAT REMOVAL
SYSTEMS IN PRESSURIZED WATER REACTORS

Leonard W. Ward
William C. Arcieri

*Managed
by the U.S.
Department
of Energy*

*Work performed under
DOE Contract
No. DE-AC07-76ID01570*

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

This document contains new concepts or the author(s) interpretation of new calculations and/or measurements; accordingly, E & G Idaho, Inc. is required by the United States Government to include the following disclaimer:

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

EGG-EAST--9853

DE92 010847

EVALUATION OF THE LOSS OF RESIDUAL HEAT REMOVAL SYSTEMS
IN PRESSURIZED WATER REACTORS

Leonard W. Ward
William C. Arcieri

February 1991

Idaho National Engineering Laboratory
EG&G Idaho, Inc.
Washington Technical Office
Rockville, MD 20852

Prepared for the
Division of Nuclear Reactor Regulation
Washington, D.C. 20555
Under DOE Contract No. DE-AC07-76ID01570

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ABSTRACT

Following the loss of vital AC power and the Residual Heat Removal Systems (RHRS) during shutdown of Vogtle Unit 1 on March 20, 1990, much attention has been focused on the need to evaluate system performance following a loss of the RHRS. Because there is a lack of understanding of the thermal-hydraulic behavior and nuclear steam supply system performance following a loss of the RHRS, system performance analyses were performed to identify the key phenomenological behaviors characterizing such an event. To evaluate system performance following such an event a simplified transient system performance code was developed to predict reactor coolant and secondary system performance following a loss of RHRS event. In the evaluation of system performance following a loss of the RHRS, the use of the steam generators as an alternate means of decay heat removal was assessed. Because the RCS is maintained at reduced inventories with air in the primary, pressurization of the RCS will occur with pressure eventually stabilizing as steam produced due to boiling in the core is condensed in the steam generator. This alternate means of decay heat removal is potentially attractive since the successful use of the steam generators to remove heat, should the RHRS fail and boiling occur, would not require the addition of coolant to the RCS.

Analyses of the loss of the RHRS under such conditions demonstrated that RCS pressures in the range of 30 to 50 psia can be achieved. Since RCS pressures in this range are within the design limits of many of the temporary boundaries placed in the RCS during shutdown, success of the use of the steam generators may not be assured. Furthermore, should a temporary boundary fail or because it is impractical to reseal the RCS and use the steam generators for decay heat removal, boiling in the RCS will require the addition of coolant makeup water to prevent uncover and damage to the fuel. The addition of borated water to the RCS will, however, result in the accumulation of boric acid in the vessel. Should boiling persist for several hours, the restoration of the RHRS could cause precipitation of the boric acid in the RHRS system precluding its further use for decay heat removal. The successful lineup of makeup coolant to the RCS to prevent core uncover therefore does not assure the core

can be cooled for an extended period of time and emphasizes the need to prevent or quickly terminate boiling should a loss of the RHRS occur.

SUMMARY

Following the loss of vital AC power and the Residual Heat Removal System (RHRS) during shutdown at Vogtle Unit 1 on March 20, 1990, much attention has been focused on the need to evaluate system performance following a loss of the RHRS. The NRC Incident Investigation Team (IIT) published their findings regarding the Vogtle Unit 1 event in NUREG-1410 and noted that alternate methods of residual heat removal, which would be required in the event the RHRS failed, need to be identified and made available for core cooling. The IIT also identified the need for emergency procedures to deal with an extended loss of the RHRS. Because there is some lack of understanding of thermal-hydraulic behavior and nuclear steam supply system performance following a loss of the RHRS, system performance analyses are required to develop a better understanding of the important phenomena characterizing such events. The analyses presented herein therefore addresses plant behavior which can also be used to support and assess the development of appropriate guidance to successfully deal with an extended loss of the RHRS.

To evaluate system performance following the loss of the RHRS, a simplified fast executing transient system performance analysis code was developed. This method was developed to provide an early insight to the consequences of a loss of RHRS event and to quickly identify key phenomenological and system behaviors for further more detailed assessments using the RELAP5/MOD3 code. The methods developed herein therefore serve to identify potential thermal and hydraulic behaviors pertinent to the loss of the RHRS event while also providing a supplemental method to check the RELAP5/MOD3 results.

During shutdown, with the RCS at reduced pressure, temperature, and inventory, the RCS contains air since entry into the RCS is necessitated to perform steam generator outage maintenance. If the RHRS fails under such conditions, use of the steam generators for decay heat removal may be attempted provided the RCS can be re-closed. This alternate means of heat removal is desirable since it precludes the need for coolant makeup to the RCS should boiling occur. This strategy is particularly attractive since during refueling outages, coolant

makeup systems are typically removed from service and may not be reactivated in a timely manner to permit its effective use. If there is insufficient time to re-close the RCS and boiling initiates, a source of coolant makeup will be needed to prevent core uncover and fuel damage.

To assess system performance following a loss of the RHRS, analyses were performed to:

- (1) Identify RCS and secondary pressure and temperature behavior using the steam generators as an alternate means of decay heat removal and,
- (2) Assess the potential for boric acid precipitation if boiling cannot be prevented and persists for an extended period of time.

In evaluating item (1), RCS peak pressures in the range 30 to 50 psia can be achieved which approach the design or failure pressures of the RCS temporary boundaries which include nozzle dams, temporary thimble seals, and temporary level sight glass tubing. As such, the success of the use of the steam generators as an alternate means of decay heat removal cannot be assured. Furthermore, should boiling persist for several hours, the buildup of boric acid identified in item (2) will result in an appreciable accumulation of boric acid in the reactor vessel. The subsequent restoration of the RHRS could cause the inadvertent precipitation of the boric acid in the RHRS lines as the primary coolant is cooled thereby blocking the RHRS with precipitate, preventing its further use for decay heat removal. The action of simply adding borated water to the RCS to prevent core uncover can therefore represent a potential precursor to a major core damage event.

While the results of these early insights have identified several areas of concern regarding the consequences of a loss of the RHRS and potential strategies to deal with such an event, the analyses of the consequences of a loss of the RHRS, particularly during reduced inventory operation should form the basis for future research and experimental studies aimed at identifying viable and successful strategies for preventing and mitigating the

consequences of a loss of RHRS events in PWRs with U-tube steam generator designs.

CONTENTS

ABSTRACT	ii
SUMMARY	iv
CONTENTS	vii
1. INTRODUCTION	1
2. OBJECTIVES	5
3. DISCUSSION	6
3.1 Use of the Steam Generators for Decay Heat Removal	7
3.2 Steam Compresses Air	9
3.3 Effect of Decay Heat Power on Peak RCS Pressure	13
3.4 Effect of Condensation Coefficient on Peak RCS Pressure	13
3.5 Loss of the RHRS with the Upper Support Plate in Position	14
3.6 Consequences of Borated Water Addition to the Reactor Vessel	19
3.7 Failure of the Temporary Thimble Seals During Decay Heat Removal Using the Steam Generators	21
4. CONCLUSIONS	23
4.1 Use of the Steam Generators to Remove Decay Heat	23
4.2 Loss of RHRS with the Upper Support Plate in Position	25
4.3 Consequences of Borated Water Addition to Cool the Core	25
5. REFERENCES	27
APPENDIX A	28
APPENDIX B	33
APPENDIX C	38
APPENDIX D	43

LIST OF TABLES

- Table 1 Steam Mixes With Air
- Table 2 Summary of Results For Models (1) and (2)
- Table 3 Primary and Secondary Side Heat Transfer Coefficients
- Table 4 Summary of Temporary Thimble Seal Data

LIST OF FIGURES

- Fig. 1 Primary System Representation for Determining the Liquid Distribution in the RCS
- Fig. 2 Calvert Cliffs: Case A - Steam Compresses Air
- Fig. 3 Calvert Cliffs: Case A - Steam Compresses Air
- Fig. 4 Calvert Cliffs: Case B - Steam Compresses Air
- Fig. 5 Calvert Cliffs: Case B - Steam Compresses Air
- Fig. 6 Calvert Cliffs: Case 1 - Steam Mixes With Air
- Fig. 7 Calvert Cliffs: Case 1 - Steam Mixes With Air
- Fig. 8 Calvert Cliffs: Case 2 - Steam Mixes With Air
- Fig. 9 Calvert Cliffs: Case 2 - Steam Mixes With Air
- Fig. 10 Calvert Cliffs: Case 3 - Steam Mixes With Air
- Fig. 11 Calvert Cliffs: Case 3 - Steam Mixes With Air
- Fig. 12 Calvert Cliffs: Case 4 - Steam Mixes With Air
- Fig. 13 Calvert Cliffs: Case 4 - Steam Mixes With Air
- Fig. 14 Calvert Cliffs: Case 4 - Steam Mixes With Air
- Fig. 15 H. B. Robinson: Case 3 - Steam Mixes With Air
- Fig. 16 H. B. Robinson: Case 3 - Steam Mixes With Air
- Fig. 17 H. B. Robinson: Case 4 - Steam Mixes With Air
- Fig. 18 H. B. Robinson: Case 4 - Steam Mixes With Air
- Fig. 19 H. B. Robinson: Case 4 - Steam Mixes With Air

LIST OF FIGURES (Continued)

- Fig. 20 Calvert Cliffs and H. B. Robinson Summary of RCS Pressures
- Fig. 20A Effect of Decay Heat on Peak Pressure - Decay Heat at 1 Day Versus 7 Days
- Fig. 20B Effect of Condensation H. Transfer Coeff. on RCS Pressure
- Fig. 21 Reactor Core and Reactor Vessel Internals Elevation
- Fig. 22 Refuel Pool Flooded with Upper Support Plate in Vessel
- Fig. 23 H. B. Robinson - Kutateladze Flood Limit versus Time After Shutdown
- Fig. 24 Minimum Core Two-Phase Level Versus Time After Shutdown (Cosine Power Shape)
- Fig. 25 Minimum Core Two-Phase Level Versus Time After Shutdown (Top Peaked Power Shape)
- Fig. 26 Boron Concentration vs Time (Calvert Cliffs Units 1 & 2)
- Fig. 27 Boron Concentration vs Time (H. B. Robinson)
- Fig. 28 Leak Flow Versus Pressure for Temporary Thimble Seal Ruptures
- Fig. 29 Failure of Ten Temporary Thimble Seals
- Fig. 30 Failure of Ten Temporary Thimble Seals
- Fig. 31 Failure of 58 Temporary Thimble Seals
- Fig. 32 Failure of 58 Temporary Thimble Seals
- Fig. 33 Representative Instrument Tube Routing

EVALUATION OF THE LOSS OF RESIDUAL HEAT REMOVAL SYSTEMS IN PRESSURIZED WATER REACTORS

1. INTRODUCTION

Following the loss of vital AC power and the Residual Heat Removal System (RHRS) during shutdown at Vogtle Unit 1 on March 20, 1990, much attention has been focused on the need to evaluate system performance following a loss of the RHRS. The NRC Incident Investigation Team (IIT) published their findings regarding the Vogtle Unit 1 event in NUREG-1410 and noted that alternate methods of residual heat removal, which would be required in the event the RHRS failed, need to be identified and made available for core cooling. The IIT also identified the need for emergency procedures to deal with an extended loss of the RHRS. Because there is some lack of understanding of thermal-hydraulic behavior and nuclear steam supply system performance following a loss of the RHRS, system performance analyses are required to develop a better understanding of the important phenomena characterizing such events. The analyses presented herein therefore addresses plant behavior which can also be used to support the development of appropriate guidance to successfully deal with an extended loss of the RHRS.

To evaluate system performance following the loss of the RHRS, transient calculations were performed to predict primary and secondary, thermal and hydraulic behavior using the steam generators as an alternate means of decay heat removal. Following a cooldown of reactor coolant system (RCS) and after the RCS pressure, temperature, and inventory have been reduced to very low levels, the pressurizer and steam generator manway entries can then be removed in preparation for the outage maintenance and refueling activities. Since the primary system will contain air after opening of the primary system manways, the loss of the RHRS at this time presents two important considerations to recovering from the event:

- 1) If the RCS boundary can be re-sealed, use of the steam generators as an alternative source of heat removal may be a desirable strategy since such actions would preclude the need to add water to the primary system once bulk boiling begins, and
- 2) If there is insufficient time to re-close the RCS, then a source of injection water will be needed to either prevent boiling or prevent core uncover following bulk boiling. If boiling persists for an extended period of time, then the potential for precipitation of the boric acid needs to be addressed.

For Item 1 conditions, air in the primary system at low pressures inhibits the condensation of steam in the steam generator primary tubes. Since RCS pressure is strongly influenced by this condensation process, an assessment of resulting peak primary pressure is of importance to the success of this strategy, particularly for those plants with temporary thimble seals in place. Temporary thimble seals are designed to accommodate a peak pressure of approximately 40 psia. With air in the RCS, peak pressures could potentially exceed the failure limit of these temporary boundaries.

For Item 2, should there be insufficient time to re-close the RCS, a source of injection water to the vessel would be required to prevent uncover of the core once bulk boiling in the core initiates. The use of a borated water source to maintain core cooling, when core boiling persists for an extended period of time, will result in the accumulation of boric acid in the vessel. If the RHRS is restored following an extended period of boiling, use of the RHRS could reduce RCS fluid temperature below the precipitation temperature of the boric acid, thereby precipitating the boric acid in the vessel and RHRS lines. Restoration of the RHRS under such conditions does not therefore assure long term cooling can be successfully reestablished by simply re-initiating operation of the RHRS.

As part of the Item 2 investigation, additional calculations were performed for a loss of the RHRS for the case with the reactor vessel head removed, but with the upper support plate assumed to remain in position. The

flow area through this plate, which represents the flow path for communication of the refueling pool water with the upper plenum and core, is less than 5.0 FT² for some Westinghouse plant designs. With this very small flow area, once bulk boiling in the reactor vessel initiates following a loss of the RHRS, the steam velocities through the plate are sufficient to preclude the downflow of water from the refueling pool, which would be needed to maintain the core covered with a two-phase mixture. In these circumstances, core uncover could occur which could result in the heatup and oxidation of the fuel. While temperatures are not expected to exceed 1500 °F, the low rate heat oxidation processes could pose a potential challenge to fuel rod integrity.

Lastly, calculations were performed to estimate the leak flow through ruptured thimble seals following pressurization of the RCS, when using the steam generators as an alternate means of decay heat removal. The system response and resulting time to core uncover following the assumed rupture of one and ten temporary thimble seals was also evaluated.

The analyses contained herein address the above Items 1 and 2 through an assessment of the primary and secondary, thermal and hydraulic behavior following a loss of the RHRS. A non-equilibrium transient system performance code was developed to simulate the RCS and secondary system, thermal and hydraulic behavior following a loss of the RHRS with air in the system. Condensation models were also developed which are capable of assessing the degradation of steam condensation due to the noncondensable gas as the steam-air mixture enters the primary steam generator tubes. Several correlations for condensation heat transfer coefficient were incorporated into the heat transfer model as options and include free and forced convection with and without interfacial shear between the liquid and steam-air mixture.

Models for the prediction of boric acid concentration during bulk boiling in the vessel are also included in the methodology. A drift-flux model was incorporated into the system code to compute the axial void distributions in the core following boiling. The Kutateladze flooding correlation was included

to assess core uncovering for the cases where the upper support plate was assumed to be in position at failure of the RHRS.

To simulate the failure of temporary thimble seals, a leak flow model of the thimble seal tubes was also developed and included in the system code to assess the timing and degree of core uncovering.

The objectives of the evaluation are given below in Section 2.0. The results of the study are presented Section 3.0 while the conclusions are given in Section 4.0.

2. OBJECTIVES

The objectives of the overall investigations into the consequences of a loss of the RHRS include the following:

1. To better understand the phenomena which can affect recovery following the loss of the RHRS;
2. To identify the phenomena which can affect RHR capability during a loss of the RHRS;
3. To obtain early (February 1991) insight into expected nuclear steam supply system (NSSS) behavior, particularly with respect to weaknesses in understanding system response identified in NUREG 1410; and
4. To assess RHR strategies and resulting NSSS behavior following the loss of the RHRS.

The purpose of the results presented herein is to address the above objectives, but specifically to provide the information enumerated in Objective 3 above which, at the request of NRR, is to provide early preliminary insights into the understanding of the consequences of a loss of the RHRS.

The results of the study are presented in the discussion below.

3. DISCUSSION

This evaluation presents the results of the thermal and hydraulic behavior in a Pressurized Water Reactor (PWR) for the following conditions:

1. Use of the steam generators as an alternate decay heat removal capability with the RCS liquid level at reduced inventory conditions and air in the remainder of the RCS;
2. The consequences of addition of borated water to the RCS for core cooling in the event the steam generators cannot be utilized for decay heat removal and boiling initiates;
3. The consequences of a loss of the RHRS with the vessel head removed, but with the upper support plate assumed to remain in position; and
4. The consequences of failure of the temporary thimble seals on system response following a loss of the RHRS in the event RCS pressure exceeds the assumed thimble failure pressure of 40 psia.

The above Items were evaluated for Calvert Cliffs Unit 1 & 2, a Combustion Engineering (CE) designed Nuclear Steam Supply System (NSSS) and H. B. Robinson, a Westinghouse (W) designed NSSS. The Calvert Cliffs plants are identical two hot leg/four cold leg, two loop PWRs, while H. B. Robinson is a three loop configuration.

Item 3 above was evaluated for the H. B. Robinson plant only since the upper support plate flow areas in CE designed plants are sufficiently large to allow the downflow of water from the refuel pool to cool the core should boiling occur.

The models used to perform the above analyses are described in the Appendices A, B, C, and D.

The results of Items 1, 2, 3, and 4 above are discussed in more detail below.

3.1 USE OF THE STEAM GENERATORS FOR DECAY HEAT REMOVAL

To assess RCS and secondary behavior following a loss of the RHRS, a non-equilibrium, transient thermal and hydraulic blowdown code described in Reference 1 was used to perform the analyses. The model is described briefly in Appendix A. In the model, the primary system is represented with two regions, a lower liquid region which can be either subcooled or saturated, with an air region above. The air is treated as an ideal gas. Figure 1 depicts the primary system with subcooled liquid below an upper air region in the RCS for mid-loop conditions. The model, described in Appendix A, computes the mass, energy, and pressure for the steam-air-liquid fluid composition in the RCS.

Once boiling begins, the RCS steam distribution in the two-phase region is computed using a drift-flux formulation where the steam release rate is computed based on the void fraction at the two-phase surface. The core void distribution is also power shape dependent. This void distribution model is described in Appendix B. Once the mass, energies and pressure are determined from the methods described in Appendix A, the liquid mass is distributed between the hot and cold sides of the RCS, depicted in Figure 1, by hydrostatically balancing the liquid level on the cold side with the steam mixture on the hot side of the system. A variable area versus height geometric model of the hot and cold sides of the RCS is used to determine the liquid and two-phase mixture heights in the RCS.

As the lower liquid region heats up following a loss of RHR, the expanding liquid region slowly compresses the upper air region. Once boiling begins, heat removal from the steam generator primary tubes was determined using two separate models. These models included:

Model 1: Steam Compresses Air - Upon boiling, the steam was assumed to artificially compress the air until the volume of the air was decreased to the volume necessary for steam to enter the primary tubes. A condensation height was then computed with the condensation coefficient on the primary side based on pure steam flowing in the primary tubes.

Model 2: Steam Mixes with Air - Upon boiling, the steam is assumed to mix uniformly with the air. The resulting mass fraction of air was then used to compute the effective condensation heat transfer coefficient in the steam generator primary tubes. This model also includes a methodology to compute the degradation in condensation heat transfer with a noncondensable present. This model is presented in Appendix C.

The secondary sides of the steam generators were modeled with a lower liquid region, containing either subcooled or saturated liquid, and an upper steam region which could be saturated or superheated. The fluid levels on shell and tube sides of the secondary are balanced hydrostatically for the purpose of determining the proper distribution of liquid and two-phase in this region. A variable area control volume description is also used for the secondary sides of the steam generators. Heat transfer from both the primary steam and primary air to the secondary was also included. The secondary safety relief and atmospheric dump valves are also modeled with provisions for also adding auxiliary feedwater to the secondary. An approach similar to that for the primary side and which is described in Appendix A but without air, was used to compute the change in mass, energy, and pressure on the steam generator secondary sides.

For the Calvert Cliffs plant two calculations were performed using model (1) above where the steam is assumed to compress the air. These cases include:

3.2 STEAM COMPRESSES AIR

- Case a. The primary steam is assumed to compress the air to a volume less than the total volume of two steam generators, two steam generator outlet plenums, and the reactor vessel upper head before pure steam condensation is allowed.
- Case b. Same as a. above except the upper head is omitted. That is, the steam also compresses the air in the upper head into the steam generators before condensation occurs.

The initial conditions for the Calvert Cliffs plant include:

- Plant Power = 2700 Mwt
- Decay Heat Fraction = 0.5% (24 hours after shutdown)
- No. of Available S. Gen = 1
- RCS Liquid Temperature = 100°F
- Secondary liquid Temperature = 100°F
- Secondary Liquid Level = Top of Active Tubes
- Secondary pressure = 14.7 psia
- Secondary Vent Area = 0.4 Ft²
- RCS Liquid Level = Center line of Hot/Cold Legs
- RCS Pressure = 1.7 psia
- RCS Air Temperature = 100.0°F
- RCS Air Humidity = 0%

It is noted that use of the decay heat at 24 hours is considered an upper limit. For the most part, midloop operation would not be expected to be initiated any earlier than 48 hours following shutdown. Furthermore, as discussed further below, the peak RCS pressure is insensitive to the decay heat power level. Decay power impacts the timing of the peak RCS pressure where lower decay heat power levels delay the initiation of boiling and hence delay the time the peak pressure is achieved.

A prerequisite for the success of heat removal through the steam generators is that a secondary vent path be opened to prevent the secondary pressure from increasing above 14.7 psia once secondary boiling occurs. An area of 0.4 Ft² was assumed which corresponds to the atmospheric dump valve area plus the first three banks of secondary safety relief valves. These vent paths were chosen arbitrarily and may not be appropriate for many plants. However, the importance of this assumption is that there is a need for a vent path to maintain a low secondary pressure and temperature should boiling initiate. The total vent area was calculated to be that area required to predict the steam flow rates through the valves at design conditions using the Moody critical flow model.

Also, after the initiation of boiling, auxiliary feedwater was also assumed to be added to the secondary side at the secondary boiling rate to prevent exposure of the steam generator tubes and loss of the heat sink.

Figures 2 and 3 present the results of Case a. described above for model (1), where the steam is assumed to compress the air. Case b. is presented in Figures 4 and 5. The results are presented for the Calvert Cliffs Plant, only.

Figure 2 presents the RCS liquid temperature and total pressure, and secondary liquid temperature and pressure. Inspection of Figure 2 shows that once the air volume, shown in Figure 3, has been sufficiently compressed to allow steam to enter the primary steam generator tubes, the secondary liquid begins heating up at about 2000 seconds following a loss of the RHRS. The secondary liquid temperature reaches saturation at about 3000 seconds shown in Figure 2, and remains at saturation with the secondary pressure remaining at a pressure of about 15 psia due to the open secondary vent paths. Without this secondary vent path, once the secondary liquid reached saturation, the secondary temperature would continue to increase as boiling would then begin to pressurize the secondary side. Figure 3 shows that when boiling of the RCS liquid begins at about 1700 seconds, the increasing steam volume compresses the air volume until sufficient condensing surface is available to allow

condensation to begin in the steam generator active tubes. Once approximately six feet of steam generator primary tube length is exposed for condensation, the primary pressure stabilizes at about 39 psia.

If the air in the upper head of the reactor vessel is included in the air volume which is to be compressed into the steam generators by the expanding steam, the peak pressure achieved for this case is about 45 psia. The results for this Case b. are presented in Figures 4 and 5.

For Model (2), where the steam mixes with the air, four cases were evaluated to study the effect of the condensation length in the steam generator primary active tubes and steam-air mixing volume. The mixing volume is used to compute the mass fraction of air in the steam-air mixture after boiling begins and is input to the condensation model described in Appendix C. The four cases are listed in Table 1:

Table 1. Steam Mixes with Air

	<u>Condensation Length</u>	<u>Mixing Volume</u>
Case 1 -	Hot Side of S.G. or 50% of S.G. Tube Length or 32.2 Ft.	Upper Plenum, Upper Head, Hot Legs, S.G. Inlet Plenums, and 50% of S.G. Primary Tube Vol.
Case 2 -	50% of S.G. Tube Length or 32.2 Ft.	Same As Above Except Upper Head Excluded
Case 3 -	25% of S.G. Tube Length or 16.1 Ft.	Same As Case 1
Case 4 -	12.5% of S.G. Tube Length or 8.05 Ft.	Same As Case 1

The above cases were evaluated for the Calvert Cliffs Plant and are presented in Figures 6 through 14.

Inspection of the above results demonstrates that as one would expect, the peak RCS pressure achieved during the event increases with decreasing condensation length. The peak pressure for Case 1 was calculated to be about 27.5 psia with progressively higher peak pressures for Cases 2 through 4. The peak pressure for Case 4 was calculated to be 33.0 psia.

Figure 14 presents the mass fraction of air in the RCS and the percent reduction in effective heat transfer coefficient in the steam generators for Case 4. The condensation model in the presence of noncondensable gas used in these calculations is briefly described in Appendix C. In determining the reduction in heat transfer during condensation, the steam entering the primary steam generator tubes was assumed to be in the forced convection mode. A comparison of the reduction in heat transfer during condensation for forced convection versus free convection is illustrated in Appendix C, Figure C-2. Forced convection steam condensation is considered appropriate for the decay heat and resultant steam flow rates in the generators which characterize the conditions for these events.

Comparison of Cases 1 and 2 reveal the peak pressures are approximately the same or 28.0 psia, demonstrating that the mixing volume is insensitive to a change equal to the upper head volume of 437 Ft³. This insensitivity is due to the fact that the upper head represents a small fraction of the total air volume so that resulting air mass fractions of 89% for Case 1 and 91% for Case 2 have about the same degradation impact on the condensation heat transfer coefficient thereby producing very similar peak pressures.

For the H. B Robinson Plant only Cases 3 and 4 were repeated with the results of these analyses presented in Figures 15 through 19. The peak pressure achieved for the H. B. Robinson Plant was 23 psia for Case 3 and 28 psia for Case 4. The lower peak pressures for the H. B. Robinson plant are due to the larger steam generator primary heat transfer area relative to the Calvert Cliffs Units 1 & 2 plants. The lower primary system volume for H. B. Robinson results in less air in the primary system which tends to reduce the peak pressure achieved during the event. The initial conditions for the H. B.

Robinson plant were the same as those described above for the Calvert Cliffs plants, except thermal power for H. B. Robinson is 2300 Mwt.

Figure 20 presents all of the above RCS pressures for both the Calvert Cliffs and H. B. Robinson Plants. The peak pressure varied between 25 and 45 psia which suggest the potential viability of the strategy to use the steam generators as an alternate means of decay heat removal. For the Calvert Cliffs Plants, the difference in peak pressures between model (1) where the steam compresses the air and model (2) where the steam was assumed to mix with the air was approximately 17 psi (i.e., 45 psia for model (1), Case b. versus 28 psia for model (2), Case 4). The "best guess" peak pressure is expected to be within this range of pressures. Comparisons of the model with experimental data are needed to support these results and conclusions. Comparisons of the analysis methods and models are being performed to identify the condensation length in the steam generator active tubes, degradation in heat transfer coefficient in the presence of air, and the degree of steam-air mixing in the RCS which influences the condensation heat transfer coefficient.

3.3 EFFECT OF DECAY HEAT POWER ON PEAK RCS PRESSURE

Figure 20A presents the RCS pressure response, for the Calvert Cliffs plant, for the case when the RHRS is lost seven days following shutdown compared to the response for the loss of the RHRS at 1 day. The peak RCS pressure for the loss of RHRS at one day is 44 psia versus 42.4 psia when decay heat is lost seven days following shutdown. This insensitivity is attributed to the fact that the steam must compress the air to a volume less than that of the primary active tube region of the steam generators in order to allow condensation of the primary steam. The lower decay heat powers simply delay the time the peak RCS pressure is achieved since the time to boiling is dependent on the decay heat power.

3.4 EFFECT OF CONDENSATION COEFFICIENT ON PEAK RCS PRESSURE

Figure 20B presents the results of the sensitivity of steam condensation coefficient to peak RCS pressure for the Calvert cliffs plant. The results of the loss of the RHRS at one day following shutdown for condensation coefficients of 150, 300, and 1000 BTU/HR-FT²-°F are illustrated in Figure 20B. Figure 20B shows that the peak RCS pressure is also insensitive to steam condensation coefficient and is due again to the fact that the steam must compress the air to a volume less than that for the steam generator active tube region to initiate condensation. The changes in air volume in the steam generator active tube region needed to accommodate changes in heat transfer coefficient in the above range have a small impact on peak pressure.

It is also important to note that References 5, 6, and 7 demonstrate that during steam condensation in an inverted steam generator tube in the presence of a noncondensable gas, the steam compresses the air into the steam generator active tube region prior to condensation. Reference 7 also demonstrated that the region at the entrance to the tube undergoing condensation was free of noncondensable gases and that the transition region, the region downstream containing steam and the noncondensable gas mixture had little impact on heat removal and hence system pressure. As such, model (1) described above, where the steam is assumed to compress the air, is the appropriate method for evaluating a loss of the RHRS behavior from midloop operation with air in the RCS.

Lastly, the effect of RCS pressurization and associated increase in primary temperature on thermal stress to the vessel walls and external piping was not evaluated. The increase in primary pressure was calculated to be approximately 30 psi while the temperature increases about 150°F to 175°F. Under these conditions the vessel walls and external piping exposed to steam may experience temperature gradients that could develop quickly during a loss of the RHRS event.

3.5 LOSS OF THE RHRS WITH THE UPPER SUPPORT PLATE IN POSITION

Investigations into the consequences of a loss of the RHRS has identified the potential for core uncover during Mode 6 operation. During Mode 6, the reactor vessel head will be removed, followed by removal of the vessel internals located above the reactor core. With the refuel pool filled with water in preparation to remove the reactor vessel internals and fuel, a loss of the RHR systems at this time could result in a potential core uncover if the injection of a source of cooling water into the RCS cannot be established prior to the onset of bulk boiling in the core. Core uncover following the initiation of bulk boiling in the reactor vessel core and upper plenum ensues because with the vessel internals in place, the upper support plate flow area for steam relief from the core and upper plenum to the refuel pool is approximately 2.3 FT^2 , exclusive of any additional flow area due to an increased gap at the periphery of the plate, for the H. B. Robinson plant. Should boiling begin following a loss of the RHR systems with this upper support plate in position, the large volume of water in the refuel pool region above the top of the vessel will not be available to cool the core, since the steam velocities passing through the upper head plate will be well in excess of the flooding limit. Furthermore, as the liquid heats up in the upper plenum and hot legs, little or no downflow of the cold refuel pool water would also be expected.

An investigation into Combustion Engineering plant designs demonstrated that the flow area from the upper plenum to the upper head region is sufficiently large (i.e., 199 FT^2) to permit downflow of liquid from the refuel pool and thereby keep the core cooled for an extended period of time. The flow area through the upper support plate for the Oconee B&W plant is 43.23 FT^2 and is also of sufficient size to permit water downflow to cool the core should boiling be initiated.

The flooding calculations used to determine the degree of core uncover are presented below for the H. B. Robinson (W) plant, only. Since the upper support plate flow areas are sufficiently large for the Oconee (B&W), and Calvert Cliffs (CE) Plants to permit the downflow of liquid, no calculations are needed for these plants.

The H. B. Robinson reactor vessel is illustrated in Figure 21. The flow path between the upper plenum into the upper head through the upper support plate consists of two separate flow paths. These flow paths include flow through the support plate flow holes with an area of 1.3 FT² and flow through the guide tubes with the flow area of 1.0 FT² for a total of 2.3 FT².

Figure 22 shows the refuel pool and the reactor vessel after the head has been removed in preparation for refueling. Because the flow area through the H. B. Robinson upper support plate is very small, water in the refuel pool cannot readily communicate with the reactor vessel upper plenum and core with the support plate in position.

To assess the potential for core uncover during shutdown, the Kutateladze correlation is used to compute flooding conditions at the upper support plate where:

$$K_g^{0.5} + K_l^{0.5} = 3.2^{0.5}$$

Flooding occurs at a value of $K_g = 3.2$, or when $K_l = 0.0$.

K_g and K_l are defined by;

$$K_{f,g} = \frac{j_{f,g} [(\rho_f - \rho_g) \sigma g g_c]^{-0.25}}{[\rho_g^2]}$$

where;

$j_{f,g}$ = superficial steam or liquid velocity

g = acceleration due to gravity

g_c = conversion factor

σ = surface tension

$\rho_{f,g}$ = liquid or steam density

The steam velocity exiting the top of the core is given by:

$$v_g = Q/[\rho_s h_g A]$$

where:

Q = decay heat energy

ρ_s = steam density

h_{fg} = latent heat
A = flow area through upper support plate

Calculations of K_g , were performed at 25 psia for several decay heat levels and are shown in Figure 23. Since the value of K_g must be less than 3.2 to permit the downflow of liquid from the refuel pool through the support plate into the reactor vessel, the value of the steam velocity and hence, maximum core two-phase level can readily be determined. Figure 24 presents the maximum core two-phase level that corresponds to a value of K_g that would allow a downflow rate of liquid that matches the core steaming rate. At this condition, the core two-phase level would no longer experience a decrease since the downflow of liquid into the core equals the rate at which liquid is boiled. Figure 24 shows that the potential for core uncover exists for the first 10 days following shutdown if the RHRS is lost during this time with the reactor vessel internals assumed in place and the head removed. It is also important to note that the degree of core uncover is very sensitive to the pressure in the RCS since small changes in pressure have a significant effect on steam density and the resulting flooding behavior. The analyses were performed at a pressure of psia which corresponds to a level in the refuel pool which is about 25 feet above the upper support plate. For lower refuel pool levels, the degree of core uncover presented in Figure 24 would increase while the potential for uncover would also extend for a longer period of time following shutdown. For illustration purposes, calculations performed at 14.7 psia would extend the time period following shutdown for which core uncover could occur, if the RHRS was lost, to about 16 days.

Figure 24 presents the core level response for a cosine power distribution while Figure 25 considered a top peaked power distribution. The cosine shape produces more core uncover than the top peak since the top peak requires a higher level to produce the same steaming rate at the same elevation for the cosine shape. Calculations for the cosine shape indicate that the peak clad temperature for the average power rods near the top of the core will experience a peak temperature of approximately 1500°F at the decay heat power at one day following shutdown, while the peak average rod temperature for the top peaked distribution is about 1300°F. The hot rod peak clad temperatures

are in excess of 2200°F for these conditions. While a gross core melt is unlikely for this event, the heatup, low-rate oxidation processes, and deformation of the hot bundle rods could result in the loss of the clad structural integrity and potential release of radioactive fission gas to the containment and environment.

Also, during the period of liquid downflow, the cooling of the exposed core is expected to be minimal as the entire core would not be expected to be uniformly cooled by the low flowrates of liquid experienced during this condition.

The above calculations assumed that there is no additional leakage on the periphery of the plate with the upper head removed. Since it may be reasonable to assume that a leakage path will result after removal of the head, the effect of increasing the flow area on the periphery of the plate by an additional 1.5 FT (producing a total flow area of 3.8 FT) was investigated. For the cosine shape at a pressure of 25 psia, core uncover is limited to only the first 2 days following shutdown. For the case where RCS pressure is near 14.7 (during filling of the refuel pool), core uncover is limited to approximately the first 5 days following shutdown.

The above calculated minimum two-phase levels are considered a bounding condition. The transient behavior of the core two-phase level under these conditions could also be oscillatory, as the steam relief through upper support plate changes with the initial variations in core two-phase levels. As the two-phase level approaches the values given in Figures 24 and 25, the steam velocity through the upper plate decreases allowing an increase in the water downflow entering the vessel and core regions. The subsequent increase in core level could then cause increases in steam flow followed by a reduction in liquid downflow. The core then experiences uncover until a steam velocity through the plate is again reduced to permit downflow again. Regardless of whether the core two-phase level behavior is oscillatory or stabilizes at some level that allows a downflow which matches the core steaming rate, the maximum level is not expected to exceed that defined by Figures 24 and 25. Additional analyses will be performed to assess the effects of steam condensation on the

countercurrent flow behavior through the support plate and resulting transient pressure behavior.

Furthermore, if the behavior becomes oscillatory, the rate of introduction of subcooled water into the reactor vessel could also represent a waterhammer concern. In addition, as the steam pressure increases below the plate, the developing pressure differential across the upper support plate could move the plate sufficiently to cause a sudden larger downflow of cold refuel pool water into the upper plenum and core region. The rapid introduction of subcooled water into the upper plenum and core could produce waterhammer effects which may damage the core and vessel internals. The potential failure of the nozzle dams could also result in the loss of the refuel pool water through the open steam generator manways. In view of the above considerations, operation with the upper support plate in position for extended periods of time is not desirable.

Since the upper support plate flow areas for the Oconee and Calvert Cliff plants are sufficiently high to permit downflow, core uncover is not expected for these plants. A survey of the other Westinghouse, CE and B&W plant types will be performed to investigate the potential for holdup for a wider range of plant designs.

3.6 CONSEQUENCES OF BORATED WATER ADDITION TO THE REACTOR VESSEL

If the steam generators cannot be used for decay heat removal, the eventual bulk boiling of the liquid in the core, and subsequent injection of borated water for core cooling, will cause boric acid to accumulate in the reactor vessel. Figures 26 and 27 present the boric acid concentration versus time following loss of the RHRS. The RHRS was assumed to be lost one day following shutdown.

The following conditions and assumptions which are pertinent to these calculations are given below:

- Time RHRS is Lost = 24 hours following shutdown
- Mixing Volume for Boric Acid Concentration = Volume of Core and Lower Plenum
- Boric Acid Concentration of Injected Water (RWST) = 2200 ppm

If boiling is allowed to persist for 12 hours or more, boric acid concentrations in excess of 10% could result. In the event higher concentrate water is used for core cooling, such as the much higher boric acid content of the water in the Boric Acid Storage Tanks (BAST), the rate of accumulation of boric acid would be much more rapid than that illustrated in Figures 26 and 27. The BASTs have concentrations as much as 10 times that of the Refueling Water Storage Tank (RWST), and would therefore more rapidly increase the boric acid content in the vessel if these tanks are used as a source of cooling water. Even with the concentrations illustrated in Figures 26 and 27, should the RHRS be restored and decay heat removal be re-established using the shutdown cooling system, the reduction in RCS liquid temperature to values below the precipitation temperature would precipitate the boric acid in the vessel and piping to the shutdown cooling system. Figures 26 and 27 present the precipitation temperature versus the boric acid concentration during the event.

The results of these calculations indicate that following a loss of the RHRS, should boiling in the reactor vessel occur over an extended period of time, the re-establishment of the shutdown cooling system for decay heat removal should not be attempted until the boric acid concentration in the vessel is reduced to levels below the precipitation temperature corresponding to the desired operating temperature of the shutdown cooling system.

Caution in using very high concentrate boric acid for core cooling should also be exercised, particularly since the addition of a high concentrate source could initiate precipitation if boiling cannot be terminated. Also, should the injection of water be switched to a colder temperature source, the addition of cold water to the vessel after an extended boiling period (i.e.,

greater than 10 hours) could reduce the vessel fluid temperature and also cause an inadvertent precipitation.

The buildup of boric acid following a loss of the RHRS is not expected to be a concern when the reactor vessel internals have been removed and the refuel pool flooded to normal refueling levels. While such concerns would be appropriate to those conditions where the refuel pool level has been reduced to very low levels, the potential for boric acid buildup and its consequences suggest that operation at reduced refuel pool levels should not be performed for long periods of time without contingency or emergency procedures to address a loss of the RHRS. More importantly, in view of the potential consequences, steps should be put in place to prevent boiling or to quickly terminate it after boiling is initiated.

3.7 FAILURE OF THE TEMPORARY THIMBLE SEALS DURING DECAY HEAT REMOVAL USING THE STEAM GENERATORS

Calculations were performed to evaluate the potential for core uncover as a result of a failure of the temporary thimble seals should the RCS pressure exceed the assumed failure pressure of 40 psia for these temporary seal boundaries.

The Calvert Cliffs Plant was used to illustrate the system response under these conditions, although the Calvert Cliffs plants do not have bottom mounted instrument tubes penetrating the reactor vessel lower head.

A RELAP5/MOD3 model of the instrument tube was used to compute the leak flow through ten tubes for the range of saturated liquid pressures, 20 to 120 psia. The tubes were assumed to failure at the seal table elevation. The resulting leak flows at the seal table were then used to identify the time to core uncover following failure of the seals. Figure 28 presents the liquid flow through 10, 20, and 100 tubes. From a knowledge of the liquid mass above the top elevation of the core, the Figure 28 leak flows can be used to

estimate the time to uncover for a range of assumed tube failures. The results presented in Figure 28 were based on the following conditions.

- The RHRS was lost 24 hours after shutdown
- The plant was in mid-loop operation
- The RCS liquid is at saturation

The RELAP5/MOD3 leak flow model results were incorporated into the transient system code described above and analyses performed assuming ten and all 58 tube seals failed. Figures 29 and 30 present the results for ten failed tubes. The tubes were assumed to fail for the Calvert Cliffs model (1), Case b. described above, where the steam is assumed to compress the air. The tubes were assumed to fail when the pressure exceeded 40 psia. Figure 30 shows that for the ten ruptured tubes, core uncover does not occur until about seven hours into the event.

Figures 31 and 32 present the results of all 58 failed tubes. Figure 32 demonstrates that core uncover occurs at about three hours into the event. It is important to note that the time to uncover is only dependent on the liquid mass expulsion rate through the tube. While the RCS is saturated, boil-off due to decay heat generation in the core does not contribute significantly to liquid depletion since condensation in the steam generators returns a significant amount of liquid to the vessel. The use of the Figure 28 leak flows should provide an approximate estimate of time to core uncover for the full range of assumed failed tubes. Clearly, if all of the tubes fail, there should be sufficient time to act to prevent core uncover. From these results, the failure pressure of the temporary seals and dams in the system should be well understood and all precautions taken to ensure all such temporary RCS boundaries can be preserved before any strategies which could result in repressurization of the RCS are implemented.

4. CONCLUSIONS

An evaluation was performed to investigate PWR thermal and hydraulic behavior following the loss of the RHRS. The conditions investigated include:

1. Use of the steam generators as an alternate decay heat removal capability with the RCS liquid level at reduced inventory conditions and air in the remainder of the RCS;
2. The consequences of addition of borated water to the RCS for core cooling in the event the steam generators cannot be utilized for decay heat removal;
3. The consequences of a loss of the RHRS with the vessel head removed, but with the upper support plate in position; and
4. The consequences of failure of the temporary thimble seal on system response following a loss of the RHRS in the event RCS pressure exceeds an assumed thimble failure pressure of 40 psia.

The above conditions were evaluated for the Calvert Cliffs Units 1 & 2, a Combustion Engineering (CE) designed NSSS and H. B. Robinson, a Westinghouse (W) designed plant.

Based on the analyses of the above, the following conclusions are summarized:

4.1 USE OF THE STEAM GENERATORS TO REMOVE DECAY HEAT

1. Peak pressures following a loss of the RHRS were computed to be in the range 25 to 45 psia, where the results are sensitive to the condensation length in the steam generator active tubes for the model where the steam is assumed to mix with the air. Peak pressures for

the minimum condensation length of 8.0 feet were calculated to be 45 psia for the Calvert Cliffs Plants.

2. For the model where the steam compresses the air, peak RCS pressure is insensitive to the condensation coefficient and decay heat power level. Decay heat level simply affects the time the peak pressure is achieved. Since the repressurization is attributable to the need to compress the air to a volume less than that for the steam generator active tube region to allow condensation, peak pressure is not sensitive to decay heat level. For this reason, peak RCS pressure is also not sensitive to the condensation coefficient in the range 150 to 1000 BTU/HR-FT²-°F. Test data also demonstrates the model where the steam is assumed to compress the air more appropriately represents RCS behavior for loss of the RHRS with air in the RCS.
3. If the steam generators are used for RCS heat removal and RCS pressures exceed the thimble seal failure pressure, the failure of ten seals could result in core uncover within about seven hours following failure. The failure of all 58 tubes could result in uncover in about three hours following the loss of the RHRS. With the potential to fail all of the temporary seals or other temporary boundaries, strategies which result in repressurization of the RCS in addition to the failure conditions for such boundaries should be well understood before implementation.
4. The peak RCS pressure following a loss of the RHRS is not sensitive to initial levels within the top and bottom elevation of the hot leg. RCS initial levels above the top elevation of the hot leg, although the amount of air in the system will be less than that for mid-loop conditions, may result in higher RCS peak pressures. These higher RCS pressures may occur as result of liquid expansion into the steam generator active tube region which could preclude the development of an adequate condensing surface and cause RCS pressures to increase

well above those for the mid-loop reflux boiling cases considered herein.

5. When using the steam generators for decay heat removal, it is necessary to (1) open a vent path to relieve steam and maintain secondary pressure at values near 14.7 psia should boiling initiate, and (2) provide a means of adding auxiliary feedwater to the secondary side to prevent loss of the heat sink should boiling occur. If a vent path is not available on the secondary side, secondary boiling will result in an uncontrolled pressurization of the RCS.

4.2 LOSS OF RHRS WITH THE UPPER SUPPORT PLATE IN POSITION

1. Loss of the RHR within the first 10 days following shutdown could cause core uncover.
2. The degree of core uncover is sensitive to the level in the refuel pool at the time of loss of the RHRS. Lower refuel pool levels at the time of the loss of the RHRS will result in an increase in core uncover. A refuel pool level of about 25 feet above the support plate produces uncover for the first 10 days following loss of the RHRS. This duration of uncover time extends to 16 days as the pool level approaches the elevation of the reactor vessel flange.

4.3 CONSEQUENCES OF BORATED WATER ADDITION TO COOL THE CORE

1. If boiling persists for an extended period of time (i.e. greater than 10 hours), boric acid concentrations will approach 10 wt% with a precipitation temperature of about 122°F. Upon restoration of decay heat removal capability, the re-activation of the shutdown cooling system could precipitate the boric acid in the vessel and RHR lines.

2. The switch to an injection source of higher boric acid concentration will cause a rapid increase in concentration and could cause early precipitation if boiling is not terminated.
3. The switch to a colder source of injection water after an extended boiling period could cause the inadvertent precipitation of the boric acid in the vessel.
4. The potential consequences of boric acid buildup suggests that procedures should be devised to stress the prevention of boiling.

5. REFERENCES

1. Ward, L. W. "A Simplified Methodology for the Prediction of the Small Break Loss-of-Coolant Accident," Ph.D. Thesis, Columbia University, N.Y., N.Y., November 1987.
2. "Loss of Vital AC Power and the Residual Heat Removal System During Mid-Loop Operations at Vogtle Unit 1 on March 20, 1990, US Nuclear Regulatory Commission, NUREG-1410, June 1990.
3. "Liquid Carry-Over and Entrainment in Air-Water Countercurrent Flooding," EPRI NP-2344, April 1982.
4. "Stability of Steam-Water Countercurrent Stratified Flow," NUREG/CR-4416, Northwestern University, October 1986.
5. Tien, C. L., Chen, S. L., and Peterson, P. F., "Condensation Inside Tubes," EPRI NP-5700, University of California at Berkeley, January 1988.
6. Nguyen, Q. and Banerjee, S., "Experimental Data Report on Condensation in a Single Inverted U-Tube," EPRI NP-3471, University of California at Santa Barbara, May 1984.
7. Hein, D., R. Rippel and P. Weiss, "The Distribution of Gas in a U-Tube Heat Exchanger and Its Influence on the Condensation Process," Proceedings of the International Heat Transfer Conference, Munich, Vol. 5 pp. 467 (1982).

APPENDIX A

To derive the time rate of change of pressure for the RCS with a steam-air-liquid composition, a two-region model of the RCS is utilized as shown in Figure A-1.

For the lower region containing liquid or a steam-liquid mixture, from continuity:

$$\frac{d}{dt} M_1 = \sum_{j=1}^J w_j \quad (\text{A-1})$$

The energy of the lower region is:

$$\frac{d}{dt} U_1 = \sum_{j=1}^J w_j h_j + Q_1 - \frac{144}{778} P \frac{dV_1}{dt} \quad (\text{A-2})$$

Using the definition of specific volume where:

$$M_1 v_1 = V_1 \quad (\text{A-3})$$

and

$$v_1 = v(h_1, P) \quad (\text{A-4})$$

Taking the derivative of Eq. 3, the time rate of change in volume of region 1 is:

$$\frac{d}{dt} V_1 = v_1 \frac{dM_1}{dt} + M_1 \left(\frac{\partial v}{\partial h} \frac{dh_1}{dt} + \frac{\partial v}{\partial P} \frac{dP}{dt} \right) \quad (\text{A-5})$$

From the equation of state:

$$U_1 = M_1 h_1 - \frac{144}{778} P V_1 \quad (\text{A-6})$$

From the derivative of the equation of state above and from Eq. 2, the time rate of change of the region 1 enthalpy can be expressed as:

$$\frac{d}{dt} h_1 = \frac{1}{M_1} \left(\sum_{j=1}^J w_j h_j + Q_1 - h_1 \frac{dM_1}{dt} + \frac{144}{778} \frac{dV_1}{dt} P \right) \quad (\text{A-7})$$

Equations 5 and 7 define the time rate of change of volume and enthalpy for the lower region 1.

For region 2 containing the air, the continuity equation is:

$$\frac{d}{dt} M_2 = \sum_{j=1}^J w_n \quad (\text{A-8})$$

The energy equation for the air is:

$$\frac{d}{dt} U_2 = \sum_{j=1}^J w_n c_p T_n + Q_2 - \frac{144}{778} P \frac{dV_2}{dt} \quad (\text{A-9})$$

From the equation of state for an ideal gas:

$$U_2 = M_2 C_p T_2 - \frac{144}{778} M_2 R T_2 \quad (\text{A-10})$$

where

$$PV_2 = M_2 RT_2 \quad (\text{A-11})$$

Taking the derivative of the Eq. 10 and using Eq. 9, the time rate of change in air temperature is:

$$\frac{d}{dt} T_2 = \left(\frac{1}{M_2 C_p} \right) \left[\left(\sum_{n=1}^J w_n c_p T_n + Q_2 \right) - C_p T_2 \frac{dM_2}{dt} + \frac{144}{778} V_2 \frac{dP}{dt} \right] \quad (\text{A-12})$$

From the derivative of the equation for an ideal gas, the time rate of change in volume becomes:

$$\frac{d}{dt} V_2 = \frac{V_2}{M_2} \frac{dM_2}{dt} + \frac{V_2}{T_2} \frac{dT_2}{dt} - 144 \frac{V_2^2}{M_2 R T_2} \frac{dP}{dt} \quad (\text{A-13})$$

From the definition of total volume or:

$$V = V_1 + V_2 \quad (\text{A-14})$$

and taking the derivative of the total volume which is constant:

$$\frac{d}{dt} V_1 = - \frac{d}{dt} V_2 \quad (\text{A-15})$$

To derive the expression for the time rate of change in pressure for the RCS which includes regions 1 and 2, Eqs. 5, 7, 11, and 12 are used along with Eq. 14 to obtain the following:

$$\frac{d}{dt} P = \frac{\left[h_1 \sum_{j=1}^J w_j - \left(\sum_{j=1}^J w_j h_j + Q_1 \right) \right] \frac{\partial v}{\partial h} - v_1 \sum_{j=1}^J w_j + \frac{V_2}{M_2 C_p T_2} \left[C_p T_2 \frac{dM_2}{dt} - \left(\sum_{j=1}^J w_n c_p T_n + Q_2 \right) \right] - \frac{V_2}{M_2} \frac{dM_2}{dt}}{M_1 \frac{\partial v}{\partial P} + \frac{144}{778} \frac{\partial v}{\partial h} V_1 + \frac{V_2^2}{M_2 T_2} \left(\frac{144}{778} \frac{1}{C_p} - \frac{144}{R} \right)} \quad (\text{A-16})$$

NOMENCLATURE

M_i	= region, i, total mass; where i = 1 or 2
U_i	= region, i, internal energy
V_i	= region, i, volume
h_i	= region, i, enthalpy
γ_i	= region, i specific volume
$\bar{P}$	= total pressure
Q_i	= heat load for region, i
w_i	= mass flow rate of into or out of region 1
w_n	= mass flow rate of air into or out of region 2
C_p	= air specific heat
T_i	= region, i temperature
R	= gas constant

Fig.A-1 Primary System Two-Region Model for Determining the State of the Air-Steam-Water Mixture in the RCS

APPENDIX B

The distribution of steam in the liquid region following the initiation of boiling in the RCS is described in this Appendix.

In the core region, during periods of boiling, the void distribution is determined from a simple balance where:

Accumulation of steam = steam production - loss by bubble rise
which is expressed as:

$$\frac{d}{dt} M_{gb} = w - \frac{M_{gb}}{\tau} \quad (\text{B-1})$$

where:

- w = mass flow rate of steam into the bottom of the core
- M_{gb} = two-phase region steam mass
- τ = bubble rise time constant

For steady-state conditions

$$\frac{d}{dt} M_{gb} = 0 \quad (\text{B-2})$$

The steam void fraction is

$$\alpha = \frac{\text{volume of steam}}{\text{total volume}} \quad (\text{B-3})$$

or

$$\alpha = \frac{M_{gb} v_g}{M_{gb} v_g + M_f v_f} \quad (\text{B-4})$$

which can be written as

$$\alpha = \frac{\frac{w v_g}{A}}{\frac{w v_g}{A} + \frac{M_f v_f}{\tau_b A}} \quad (\text{B-5})$$

This form suggests setting

$$\tau_b = \frac{M_f v_f}{V_b A} \quad (\text{B-6})$$

Thus, the void fraction can be expressed by

$$\alpha = \frac{j_g}{j_g + V_b} \quad (\text{B-7})$$

where

$$\frac{w v_g}{A} = \frac{Q_g}{A} = j_g \quad (\text{B-8})$$

and

$$\frac{j_g}{\alpha} = j_g + V_b \quad (B-9)$$

which is the Zuber-Findlay drift-flux formulation with C_0 equal to 1.0, the drift velocity equal to V_b , and the liquid volumetric flux density set to zero.

The steam release rate from the two-phase surface is therefore:

$$releaserate = \frac{\alpha V_b A \rho_g}{1 - \alpha} \quad (B-10)$$

Applying a quasi-steady condition to the core region where production equals release, thus the rate of steam production is set equal to the rate of steam release from the two-phase surface or:

$$\dot{P}_Z + w_n = \frac{\alpha}{1 - \alpha} V_d \rho_g A \quad (B-11)$$

which simply means that for quasi-steady state conditions, the amount of steam released is no greater than the amount of steam produced plus the amount of steam that is convected into the two-phase region.

Applying the above equation to a core divided into N regions;

$$\frac{V_d}{1 - \alpha(z)} \rho_g A \alpha(z) = \dot{P}_i (z - z_{i-1}) + w_{i-1} \quad (B-12)$$

where

$$w_{i-1} = V_d \rho_g A \frac{\alpha_s}{1 - \alpha_s} \quad (\text{B-13})$$

and α_s is the void fraction at the two-phase surface.

The void fraction as a function of axial position is

$$\alpha(z) = \frac{\dot{P}_i(z - z_i) + w_{i-1}}{\dot{P}_i(z_{2\phi}) + w_{i-1} + V_d \rho_g A} \quad (\text{B-14})$$

The void fraction at the two-phase surface is

$$\alpha_s = \frac{\dot{P}_{ii}(z_{2\phi} - z_{ii}) + w_{ii-1}}{\dot{P}_{ii}(z_{2\phi} - z_{ii}) + w_{ii-1} + V_d \rho_g A} \quad (\text{B-15})$$

The steam mass in each core region, i , is computed by integrating the expression for the void fraction in each core region or

$$M_{gb} = \rho_g A \int_{z_i}^{z_i^f} \alpha(z) dz \quad (\text{B-16})$$

The steam mass in each core region becomes:

$$M_{gb,i} = \rho_g A \left[z_{ii}^t - \frac{V_d \rho_g A}{\dot{P}_i} \ln \left(\frac{\dot{P}_i z_i^t + w_{i-1} + V_d \rho_g A}{w_{i-1} + V_d \rho_g A} \right) \right] \quad (B-17)$$

where

$$z_i^t = z_{ii}^t - z_i \quad (B-18)$$

z_i^t is the minimum of the height of region, i , and the two-phase surface in region, i .

The density in the core region is

$$\rho_c = \sum_{i=1}^N \frac{M_{gb,i} + M_{f,i}}{V_{tot}} \quad (B-19)$$

NOMENCLATURE

M_{gb}	=	steam mass in the two-phase region
w	=	steam flow rate
A	=	flow area
α	=	steam void fraction
j_g	=	volumetric flux density of steam
V_d	=	steam bubble drift velocity
$\dot{P}$	=	linear steam production rate in region, i
w_{i-1}	=	steam flow rate entering bottom of region i
V_i	=	total region volume
v_g	=	steam specific volume

APPENDIX C

This Appendix describes the method used to assess the effect of noncondensable gases on primary steam condensation in the primary active tubes of the steam generators during condensation. The methods and analysis techniques presented herein is based on the methods described in References C-1 and C-2.

The presence of a noncondensable gas in condensing water vapor increases the resistance to heat transfer at the liquid vapor interface. During use of the steam generators following a loss of the RHRS, a water vapor-air mixture will flow into the active tubes of the steam generators. If the primary system temperature is greater than that of the secondary, condensation of the water vapor will occur. The water vapor will condense on the wall forming the liquid film illustrated in Figure C-1. The noncondensable air, being carried toward the liquid film with the bulk mixture, may accumulate forming a gas layer. The partial pressure of the gas at the liquid interface, P_{gi} , increases above that in the bulk mixture, P_{go} , which produces a diffusive outward flow of gas away from the surface. The outward flow is balanced by the convective inflow of the water vapor and the noncondensable gas mixture. The driving force for convective inflow of the mixture is a result of the lower partial pressure of the vapor at the liquid interface, P_{vi} , relative to that in the bulk mixture, P_{vo} . The latent heat liberated during the condensation process is conducted through the liquid film with a heat transfer rate dependent on the temperature difference between the interface vapor temperature, T_{vi} , and the wall temperature, T_w .

To evaluate the heat transfer rate, the conditions at the liquid film interface must be determined. The heat transfer from the mixture to the interface is composed of two components: the sensible heat transferred through the diffusion layer, and the latent heat liberated as a result of condensation at the liquid film surface. The heat from both of these components is transported through the liquid film by conduction. The heat

transfer rate from the mixture when equated to the latent heat conducted through the film results in the following expression:

$$U_o \Delta T_{overall} = h_o (T_{vi} - T_w) = h_g (T_{vo} - T_{vi}) + K M_g h_{fg} (P_{vo} - P_{vi}) \quad (C-1)$$

- h_o = heat transfer coefficient in liquid film, BTU/hr-ft²-°F
 - h_g = sensible heat transfer coefficient, BTU/hr-ft²-°F
 - T_{vo} = vapor temperature in bulk mixture, °F
 - T_{vi} = vapor temperature at liquid interface, °F
 - T_{go} = gas temperature in bulk mixture, °F
 - T_{gi} = gas temperature at liquid interface, °F
 - P_{vo} = partial pressure of vapor in bulk mixture, psia
 - P_{vi} = partial pressure of vapor at liquid interface, psia
 - K = mass transfer coefficient, lb mole/hr-sq. ft-psia
 - M_g = molecular weight of gas, lb/lb-mole
 - h_{lv} = latent heat, BTU/lb
 - T_w = wall temperature, °F
- and K_g is determined from

$$\left(\frac{K_g L R T}{D} \frac{P_{am}}{P} \right) = C_1 \left[\frac{g L^3 \rho}{\mu D} \left(\frac{P_o}{\rho} - 1 \right) \right]^{0.373} \quad (C-2)$$

with C_1 equal to 1.02 for vertical surfaces and where:

- C_g = specific heat of gas, BTU/lbm-°F
- P_{am} = log mean of partial pressures of gas, psia
- Pr = Prandtl number
- Sc = Schmidt number

and:

- μ = viscosity, lb/ft-hr
- k = conductivity, BTU/hr-ft°F
- ρ = density, lb/ft³
- D = volumetric diffusivity, ft²/hr

The vapor pressure, P_w , the wall temperature, T_w , and the noncondensable gas mass fraction, W , are known quantities. The heat transfer rate can then be determined by choosing the value of the liquid interface temperature, T_w , which satisfies Equation 1.

The total pressure is computed from the relation:

$$\frac{P_{vo}}{P} = \frac{1-W}{1-w(1-\frac{M_v}{M_g})} \quad (C-3)$$

where:

- M_v = molecular weight of vapor, lb/lb-mole
- M_g = molecular weight of gas, lb/lb-mole
- P = total pressure, psia
- w = mass fraction of air

Figure C-2 presents the results of the model described above with air-water vapor condensation test data for (1) laminar or free convection and (2) forced convection condensation. The results are presented as the ratio of the degraded condensation rate to the pure steam condensation rate as a function of the mass fraction of air in the steam-air mixture. Note the dramatic reduction in heat transfer rate for the free convection condition with air mass fractions as low as 5%.

The forced convection model was used for computing the reduction in condensation rate with air present for the loss of RHR events evaluated in this report.

REFERENCES

- C-1 Collier, J. G., Convective Boiling and Condensation, McGraw-Hill, New York, N.Y., 1972, pp. 314-340.
- C-2 Akers, W. W. et. al., Condensation of a Vapor in the Presence of a Non Condensing Gas, Chemical Engineering Progress Symposium, Series No. 30, 56, pp. 139-144 (1960).

TABLE 2

Summary of Results For Models (1) and (2)

<u>CASE</u>	<u>Assumptions</u>	<u>Peak RCS Pressure (psia)</u>
<u>Calvert Cliffs</u>		
Model (1), Steam Compresses Air		
Case a.	Air in upper plenum, hot legs, and S. G. inlet plenums is compressed into S. G. primary tube volume plus S. G. outlet plenum volumes.	38.7
Case b.	Air volume to be compressed by steam includes above plus upper head air volume	44.0
Model (2), Steam Mixes with Air		
Case 1	Condensation Length=50% of tube length or 32.2 ft. Steam air mixing volume includes upper plenum, hot legs, S. G. inlet plenums and 50% of S. G. primary volume.	26.9
Case 2	Condensation Length=50% of tube length or 32.2 ft. Mixing volume same as above except upper head included.	27.5
Case 3	Condensation Length=25% of tube length or 16.1 ft. Mixing volume same as Case 2.	33.3
Case 4	Condensation Length=12.5% of tube length or 8.05 ft. Mixing volume same as Case 2.	45.3
<u>H. B Robinson</u>		
Model (2), Steam Mixes with Air		
Case 3	Same as Case 3 above. Upper head not in mixing volume.	24.0
Case 4	Same as Case 4 above. Upper head not in mixing volume.	28.3

TABLE 3

Primary and Secondary Side Heat Transfer Coefficients

	Primary Steam Condensation Coefficient BTU/HR-FT ² -°F	Secondary Heat Transfer Coefficient BTU/HR-FT ² -°F
Model (1), Steam Compresses Air (1)	150 ²	Free Convection = 450-550 Nucleate Boiling = 900-1000
Model (2), Steam Mixes with Air (1)	350 ⁽³⁾	Same as Above

(1) The heat transfer coefficient for air in the primary tubes was assumed to be 2.0 BTU/HR-FT²-°F

(2) Lower bound for condensation heat transfer coefficient

(3) This is the approximate condensation coefficient on the primary side of the steam generators for pure steam conditions. To obtain the effective heat transfer coefficient with air present for Model (2), multiply the percent reduction in heat transfer coefficient (i.e. Q/Q_0 from Figures 14 and 19) times the approximate pure steam condensation coefficient of 350 from above.

TABLE 4

Summary of Temporary Thimble Seal Data

o Instrument Tube Design Based on Zion Plant (See Figure 33)	
o No. of Instrument Tubes	= 58
o Instrument Tube I.D. (1)	= 0.4 in.
o Tube Length from bottom of Vessel to Seal Table Elevation	= 40 - 60 ft.

(1) 50 tubes have an I.D. of 0.4 in. while eight have an I.D. of 0.6 in.
These diameters represent an empty instrument tube

Also note that the RELAP5/MOD3 model of Zion Instrument tube is based on the models developed for NUREG/CR-4672, entitled "Analysis of Instrument Tube Ruptures in Westinghouse 4-Loop Pressurized Water Reactors", EGG-2461, December 1986.

FIGURE 1

Primary System Representation
for Determining the
Liquid Distribution in the RCS

Figure 2

Calvert Cliffs: Case A - Steam Compresses Air

RHRC1P1

Figure 3

Calvert Cliffs: Case A - Steam Compresses Air

RHRC1P2

Figure 4

Calvert Cliffs: Case B - Steam Compresses Air

RHRC2P1

Figure 5

Calvert Cliffs: Case B - Steam Compresses Air

RHRC2P2

Figure 6

Calvert Cliffs - Case 1 - Steam Mixes With Air

RHR1D1P1

Figure 7

Calvert Cliffs: Case 1 - Steam Mixes With Air

RHR1D1P2

Figure 8

Calvert Cliffs: Case 2 - Steam Mixes With Air

RHR1DAP1

Figure 9

Calvert Cliffs: Case 2 - Steam Mixes With Air

RHR1DAP2

Figure 10

Calvert Cliffs: Case 3 - Steam Mixes With Air

RHR1D2P1

Figure 11

Calvert Cliffs: Case 3 - Steam Mixes With Air

RHR1D2P2

Figure 12

Calvert Cliffs: Case 4 - Steam Mixes With Air

RHR1D3P1

Figure 13

Calvert Cliffs: Case 4 - Steam Mixes With Air

RHR1D3P2

Figure 14

—•— Air Mass Fraction -+ - Q/Q_o

Calvert Cliffs: Case 4 - Steam Mixes With Air

RHR1D3P4

Figure 15

H. B. Robinson: Case 3 - Steam Mixes With Air

RHRHD2P1

Figure 16

H. B. Robinson: Case 3 - Steam Mixes With Air

RHRHD2P2

Figure 17

H. B. Robinson: Case 4 - Steam Mixes With Air

RHRHD3P1

Figure 18

H. B. Robinson: Case 4 - Steam Mixes With Air

RHRHD3P2

Figure 19

H. B. Robinson: Case 4 - Steam Mixes With Air

RHRHD3P4

Figure 20

Calvert Cliffs and H. B. Robinson

FIGURE 20 A
EFFECT OF DECAY HEAT ON PEAK PRESSURE
DECAY HEAT AT 1 DAY VERSUS 7 DAYS

CALVERT CLIFFS
STEAM COMPRESSES AIR
RHRS LOST AT 1 DAY AND 7 DAYS

FIGURE 20 B
EFFECT OF CONDENSATION H. TRANSFER COEFF. ON RCS PRESSURE

CALVERT CLIFFS
STEAM COMPRESSES AIR, RHRS LOST AT 1 DAY
H. TRANS. COEFF. UNITS = BTU/HR-FT²-F

Upper Support Plate

H. B. ROBINSON
UNIT 2

Carolina Power & Light Company
UPDATED FINAL
SAFETY ANALYSIS REPORT

REACTOR CORE AND
REACTOR VESSEL INTERNALS
ELEVATION

FIGURE

21

FIGURE 22: Refuel Pool Flooded with Upper Support Plate in Vessel

Figure 23

H.B. Robinson

Figure 24

Figure 25

Figure 26

Boron Concentration vs Time (Calvert Cliffs Units 1 & 2)

Figure 27

Boron Concentration Vs Time (H.B. Robinson)

Figure 28

Figure 29

Failure of Ten Temporary Thimble Seals

R1LC1P1

Figure 30

Failure of Ten Temporary Thimble Seals

R1LC1P2

Figure 31

Failure of 68 Temporary Thimble Seals

R1LC2P1

Figure 32

Failure of 58 Temporary Thimble Seals

R1LC2P2

FIGURE 33 Representative instrument tube routing.

JEN00067

END

**DATE
FILMED
5/05/92**