Lighting

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

This booklet is one in a series of three prepared for the Bonneville Power Administration (BPA) under contract #DE-AC79-82BP31302 by the Board of Regents of University of Wisconsin System, University Extension Department of Engineering. The series focuses on the concept of energy management and how it can be put into practice by the owners and operators of small businesses. Each booklet deals with a specific aspect of a building's energy use and presents, in order of cost-effectiveness, a list of energy conservation opportunities. For further information, a reference list can be found at the conclusion of each booklet.

The cost figures included in this series are computed for a 4000 heating degree day area with electric rates of 5¢/kWh and natural gas at 60¢/therm. Bonneville Power Administration covers a wide territory so these figures can be adjusted if they differ in your area.

DISCLAIMER

This booklet was originally printed in 1983. The information it contains is as valid today as it was nine years ago. With minor changes, the booklet is presented as written.

LEGAL NOTICE

Neither BPA nor any of its officers or employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement by BPA.

Lighting

Lighting accounts for about one-third of the energy used in commercial buildings. This amount is substantial and so are the opportunities to conserve. The amount of energy you use for your lighting system is generally measured in kilowatt-hours (kWh); it is a product of the amount of electricity used at a given time (kW) multiplied by the length of time in hours (h) that the lights are on. There are two ways to reduce lighting energy use: modify lighting systems so they use less electricity and/or reduce the number of hours the lights are used. This booklet presents a number of ways to do both. Topics covered include:

- Reassessing Lighting Levels
- Reducing Lighting Levels
- Increasing Bulb & Fixture Efficiency
- Using Controls to Regulate Lighting
- Taking Advantage of Daylight

A program to improve lighting efficiency and control lighting use can produce significant savings. No-cost/low-cost techniques can save 20 percent of your base usage without compromising security, safety or task performance. Modifying your lighting system with more efficient fixtures can save an additional 20-40 percent. To realize these savings, however, requires a systematic approach. It is possible that changing a few bulbs and disconnecting a few fixtures will result in some savings, but you won't begin to approach the savings possible until you look at your lighting as a whole.

Reassessing Lighting Levels

It has been the practice in most commercial buildings to maintain uniformly high levels of light throughout the building. Over the last few years recommended lighting levels have been changed; it is now generally acceptable to reduce overall lighting levels and provide task or selective lighting where necessary. By reducing unnecessarily high lighting levels you can produce substantial savings on your lighting bill.

Before you make any changes in your present system, you should examine your current lighting practices. You can do this yourself or have an energy auditor or consultant perform a lighting audit for you as part of a walk-thru energy audit. To conduct a lighting audit, go through your building room-by-room or area-by-area with a Building Operation Schedule in hand. (For more information and a sample form, see the *Energy Management* booklet in this series.) As you go through the building, take note of the activities or tasks being performed, the current lighting levels and the recommended levels. Also take note of the number and types of fixtures used and the number of switches available to control them. This information will be useful in reassessing your lighting needs and for discussing and planning changes in bulbs, fixtures or controls.

Lighting is often excessive in halls, corridors, lobbies and waiting rooms. Take note of tasks that occur in the

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

same area and require different lighting levels. For example, a typist needs less than 10 footcandles to work effectively at a computer. It makes no sense to locate this work station next to a drafting table which is often illuminated to 100 footcandles. Figure 1 illustrates some commonly used lighting terms which you should be familiar with.

Figure 1: Familiarity with common lighting terms is helpful when setting up a lighting conservation program.

Measuring Lighting Levels

You cannot determine where to lower lighting levels by observation alone; you need to use a light meter. Light meters sell for about \$50, but it may be possible to rent or borrow one from a local lighting contractor or your utility company. If a consultant performs a walk-thru energy audit ask the consultant to measure lighting levels. If you take your own measurements, read the meter instructions

carefully and take several readings at each location. When you are measuring daylight, take several readings at different times during the day, on both cloudy and sunny days to ensure accuracy.

Table 1 presents a general guide to appropriate lighting levels for selected commercial applications based on the 1981 *Illuminating Engineering Society (IES) Handbook* recommendations. An energy auditor or consultant will be able to give you more detailed information for your situation.

SUGGESTED LIGHTING LEVELS FOR SELECTED COMMERCIAL APPLICATIONS	
Area	Light Level (Footcandles)
Circulation area between work stations	20
Background beyond task at circulation areas	10
Waiting rooms and lounges	10-20
Conference rooms	20-50
Secretarial desks	50-60
Filing areas	50
Auditoriums	30
Kitchens	50 (average)
Cafeterias and snack bars	10-20
Drafting rooms	80-100
Accounting offices	80
Computer rooms, general	30
Computer rooms with self-illuminating screens (CRTs) installed	5-10
These are suggested lighting levels and are general in nature. Other considerations, such as building codes, tasks at hand, age of workers, importance of speed and accuracy in the task, and reflectance and glare should be considered. A more specific recommendation can be gained from your lighting consultant.	

Table 1: Use these lighting levels as a starting point for assessing your current lighting levels.

Lighting Power Standards

The previous section mentions how new lighting level recommendations encourage more energy-efficient lighting systems. Many states have gone a step further and adopted *lighting power standards*. These standards establish a power limit for buildings and are given in watts/ft²; that is, they set a maximum amount of power that may be used to provide light in a building. This upper limit on power use is called the lighting power budget.

The assumption behind lighting power standards is that lighting practices and systems must be set up more efficiently in order to have adequate light within the total allowable wattage limit. These standards do not translate directly into energy use (kWh) since hours of operation vary, but they do give a good indication of energy use.

In many states the lighting power standards are being applied just to new buildings, but in some states they apply to both new and existing structures. These requirements appear in your state code. The Oregon standard, for instance, limits overall lighting levels in offices to 2.5 W/ft² and in hotels and restaurants to 1.1-1.2 W/ft². Remember, these are maximum standards. You should be able to do much better in your building. The lighting in many office retrofits falls well below 2 W/ft² and new buildings are being designed with less than 1 W/ft² average.

In most rooms with fluorescent lighting, the new standards can be approached by substituting high-efficiency tubes and ballasts. Table 2 gives you an idea of the power budget required to provide various levels of light with standard fluorescents and an eight-foot ceiling. Energy-efficient tubes and ballasts can reduce the power budget by 20 percent.

LIGHTING LEVEL Footcandles	POWER BUDGET Watts per ft ²
7	0.6
15	1.0
20	1.4
50	2.0
70	2.7
100	3.5

Table 2: This table gives the power budget required for certain lighting levels with standard fluorescents. More efficient lights can reduce this budget.

Reducing Lighting Levels

After you have determined your building's lighting requirements and the levels currently being used, you can begin to plan lighting system modifications. There are many ways to reduce excessively high lighting levels while still providing adequate illumination. Some of these methods are presented in the following sections.

Delamping & Downwattling

In some areas, it is possible to cut back excessive lighting by removing bulbs. Some areas have more fixtures than are really needed, so it is simple to remove some bulbs from each fixture or to disconnect entire fixtures. Fluorescent bulbs are wired in pairs to one ballast, so if you wish to disconnect only one bulb, you will need to install a "phantom tube" to keep the fixture working. When removing pairs of fluorescent bulbs remember to disconnect the ballast so it won't continue to use energy.

Sometimes it is possible to reduce lighting levels by using lower wattage bulbs in place of higher wattage bulbs. For instance, in some cases a 40-watt bulb may be substituted for a 100-watt bulb and still provide adequate light.

Don't forget repainting as a part of your lighting conservation scheme. Walls painted a light color provide more useful light with lower wattage bulbs. White paint on walls and ceilings can reflect light and can increase light levels by as much as 100 percent.

Uniform lighting is rarely necessary. It is possible to delamp in such a way that it reduces overall lighting while providing higher levels of illumination at specific places such as work areas or display areas. Selective lighting works well in retail outlets where more intense lighting on shelves and display racks attracts customer interest. Task lighting places more light directly on a work area. It is often used in offices since background levels can be reduced to one-third the level required on desks or tables.

Installing Dimmers

When rooms serve several purposes each having different lighting needs, it is a good idea to install dimmer switches. Dimmers allow the users to adjust the lighting to the task at hand; when lights are turned down energy consumption is reduced. Dimmers also permit adjustment of lights according to the daylight available.

Dimmers for incandescent lights are relatively inexpensive and generally have a one-year payback. In a restaurant, for instance, a set of twelve 150-watt fixtures might be dimmed 50 percent or more during the day. The graph in Figure 2 shows that a savings of 75 watts per fixture would save about \$15/year per fixture or \$180/year for the room if electricity costs 5 cents/kWh. Thus a dimmer which costs \$100 installed would pay back in about seven months.

Dimmers are also available for fluorescent fixtures, but multilevel ballasts are needed. This raises the cost and extends payback by several years. Still, they can be an excellent investment and should not be overlooked.

Cutting Down on Decorative Lighting

Decorative outdoor lighting is often overused. You should decide whether it is essential to bathe your building, trees and lawn in light. It is not necessary to remove these lights; instead wire them to a manual switch and only use them on special occasions. In some cases outdoor lights are overgrown with shrubbery which limits their usefulness. At one apartment building, sixteen 150-watt floodlights burned all night, despite the fact they were completely overgrown by juniper bushes. At an electricity cost of five cents per kWh, turning these lights off saved the building owner \$500 per year.

For example, if one 200-watt incandescent fixture is replaced with a two-tube fluorescent fixture (two 32-watt tubes and a 10-watt ballast):

Watts saved = 200 - 74 = 126 watts	Cost/fixture = \$60
Dollars saved/yr @ .05/kWh = \$26	Payback = \$60/\$26 = 2.3 years

Figure 2: This graph allows you to estimate the annual savings and payback from replacing fixtures or using lower wattage bulbs.

Increasing Bulb & Fixture Efficiency

Lighting efficiency is a measure of the light output (lumens) vs the power used (watts). It is easy to measure the efficiency of a bulb and to compare bulb efficiencies such as is done in Figure 3. Actual lighting effectiveness, however, is a function of bulb, fixture type and placement, and room characteristics. We have already discussed the importance of light colored walls and ceilings. In this section suggestions are made for improving bulb and fixture effectiveness, as well as fixture placement. This is a complex subject and we suggest you get professional help from a lighting designer if you want to go beyond the basic recommendations in this booklet.

Relamping with High Efficiency Bulbs

It is possible to maintain the same light output but reduce energy use by replacing existing bulbs with new high-efficiency types. An inexpensive way to do this is to switch to higher efficiency bulbs as burned-out bulbs are replaced. Replacing incandescent flood lights with elliptical reflector (ER) bulbs in recessed fixtures saves as much as 50 percent (Figure 4). Clear bulbs are preferable to frosted ones as they give off more light. Substituting a 100-watt bulb for two 60-watt bulbs saves 17 percent per fixture. When relamping fluorescents, use energy-saving

Figure 4: ER lamps deliver more light and use less energy than incandescent bulbs.

Figure 3: A comparison of bulb life and light output for various types of lighting.

tubes: 32-watt tubes provide the same light output as the older 40-watt tubes. When replacing tubes, also replace existing ballasts with the new high-efficiency type. They save 25 percent over existing ballasts and will last longer.

Replacing Incandescent Bulbs with Fluorescent Adapter Units

Fluorescent adapter units are now available for use in incandescent fixtures. Fluorescent adapters require no rewiring (Figure 5). The adapter normally comes with a ballast, starter and bulb and is available in both screw-in and side-plug models. The fluorescent bulbs have a life of 12,000 to 20,000 hours compared to the 750 hours of an incandescent bulb, and they provide three to four times more lumens per watt than incandescent bulbs. The adapter units work well in recessed and semi-recessed fixtures. Remember to check the fixture size before purchasing the unit to make sure it will fit.

Your savings depend on the number of hours per year the fixture is used. For example, a 22-watt fluorescent adapter costs about \$25. Using it to replace a 75-watt incandescent bulb operating 2000 hours per year at five cents per kWh would result in the following savings:

$$\frac{\$0.05}{\text{kWh}} \times \frac{(75\text{W} - 22\text{W}) \times 2000 \text{ hr/yr}}{1000 \text{ watts/kW}} = \$5.30/\text{yr.}$$

Circular Fluorescent	Incandescent	P-I Fluorescent
(6 1/2" Dia) 15 Watt	= 60 Watt	= 13 Watt (9")
(8 1/2" Dia) 22 Watt	= 75 Watt	= 18 Watt (11")
(12 1/2" Dia) 32 Watt	= 100 Watt	= 27 Watt (11")

Figure 5: A guide for replacing incandescent bulbs with comparable fluorescents.

Table 3 gives the energy use and cost savings for replacing incandescent fixtures with comparable fluorescents.

USE & COST SAVINGS FOR COMPARABLE INCANDESCENT & FLUORESCENT FIXTURES		
INCANDESCENT		FLUORESCENT with Watt-Miser Bulbs
Eleven - 100 Watt Fixtures	REQUIRED	Three-2 lamp (32 W) Fixtures (76 Watts with Ballast)
1100 Watts (9.2 Watts/ft ²)	LOAD	228 Watts (1.9 Watts/ft ²)
\$110	ANNUAL COST	\$23
	SAVINGS	\$86
	INSTALLED COST	\$100 each x 3 = \$300
	PAYBACK	\$300 initial cost \$86 annual savings = 3.5 years

Table 3: Energy and cost savings for comparable incandescent and fluorescent fixtures.

Improving Maintenance Procedures

Regular maintenance of lighting fixtures is important for optimal efficiency. In many cases a thorough maintenance program can improve the quality and amount of illumination created by your lighting system. In fact, when compared to poorly maintained equipment, regularly cleaned fixtures, bulbs and room surfaces provide up to 20 percent more light. Be sure to include the following maintenance items in your overall TOM program.

- Set up a regular schedule to check all fixtures and replace burned-out bulbs.
- Keep fixtures, bulbs and reflectors clean.
- Replace any yellowed plastic lenses or covers over fixtures.
- Keep ceilings and walls clean. When repainting, consider using light colors to increase reflectance.

Replacing Fixtures

Factors such as visual discomfort or difficulty with maintaining lighting fixtures may make replacement necessary in some cases. When replacing fixtures install new energy-saving overhead units. Wherever

EXAMPLES OF ENERGY SAVINGS FROM REPLACING FIXTURES AND LAMPS	
EXISTING	REPLACEMENT
RETAIL STORE	
Sixty-six 500-W Incandescent Down Lights	Twenty 400-W Metal Halide Down Lights
Total kWh/yr = 122,100	Total kWh/yr = 34,040
Total Savings = 88,060 kWh/yr = 72% Savings (@ 3,700 operating hr/yr.	
Seventeen 1000-W Incandescent Pendant Fixtures	
Fourteen 400-W Metal Halide Pendant Fixtures	
Total kWh/yr = 62,900	Total kWh/yr = 24,050
Total Savings = 38,850 kWh/yr = 62% Savings	
PARKING AREA	
Twelve 1500-W Tungsten Halogen Lamp floodlights	Four 1000-W Metal Halide Cluster
Total kWh/yr = 27,000	Total kWh/yr = 6,480
Total Savings = 20,520 kWh/yr = 76% Savings (@ 1,500 operating hr/yr.	
SIGN	
Two 1500-W Tungsten Halogen Floodlights	Two 400-W Metal Halide Floodlights
Total kWh/yr = 12,000	Total kWh/yr = 3,680
Total Savings = 8,320 kWh/yr = 60% Savings (@ 4,000 operating hr/yr.	
SECURITY	
Six 500-W Tungsten Halogen Floodlights	Six 150-W High Pressure Sodium Lights
Total kWh/yr = 12,000	Total kWh/yr = 3,920
Total Savings = 8,080 kWh/yr = 67% Savings (@ 4,000 operating hr/yr.	
SUPERMARKET	
Two Hundred Fifty 4-lamp 40-W Strip Fluorescent Fixtures	Seventy 400-W High Pressure Sodium Down Lights (where change in color rendition is acceptable)
Total kWh/yr = 146,250	Total kWh/yr = 84,000
Total Savings = 62,250 kWh/yr = 43% Savings (@ 3,000 operating hr/yr.	

Table 4: Examples of the energy savings possible from various fixture replacements. From *Energy Conservation Standards* by Dubin and Long, 1978. Used with the permission of McGraw-Hill Book Company.

possible, use fluorescent fixtures which are approximately four times as efficient as the incandescent type. High intensity discharge (HID) fixtures are the most efficient and in some cases may be used inside. Table 4 gives some examples of fixture replacements with the resultant savings.

To calculate the payback on fixture replacements, find the annual savings from Figure 2 based on the watts saved per fixture and the cost of electricity. Then divide the fixture cost by the annual savings to get the payback. The number of hours the lamps are on also influences payback: generally, lamps should operate at least 40 hours per week to justify the replacement expense. The savings in Figure 2 are based on 80 hours/week which is typical for many commercial operations.

Improving Fixture Placement

It is sometimes effective to substitute table lamps or floor lamps for overhead lights. This allows a reduction in the number and wattage of overhead lamps. This lighting

Figure 6: Efficiency is increased by lowering fixtures.

Figure 7: Using extenders on spotlights increases lighting efficiency.

approach works well in foyers, waiting rooms and lounge areas. In offices and work areas, a fluorescent desk lamp is more efficient, and provides better task light than overhead fixtures.

Sometimes it's necessary to move existing fixtures if they aren't providing light where it's needed. One case like this occurred after a remodeling project in a grocery store. The shelves were moved without concern for the location of the lights. As a result, when remodeling was completed the existing ceiling fixtures illuminated the tops of the shelves rather than the merchandise. The lighting efficiency was reduced by 30 percent making it necessary to relocate the fixtures.

In areas with high ceilings, lowering fixtures increases lighting effectiveness. For example, in a room with a 12 foot ceiling, lowering a fixture two feet will allow you to use lower wattage bulbs and reduce energy consumption up to 30 percent while maintaining the same lighting level (See Figure 6.). Lowering a few fixtures is also a good way to provide selective or task lighting.

Extenders, which lower the bulb so light is not trapped in the fixture, work well in incandescent fixtures. This increases light on the task or display up to 50 percent (See Figure 7).

Other Considerations

There are many details to consider when choosing appropriate lighting methods and the correct lighting levels for your building. Table 5 compares the lighting characteristics of different lamps. In some cases, such as a retail store, it is necessary to consider the color rendering capability of the light source. Some lamps produce a color which is very similar to natural light while others may render most colors as shades of gray. In a situation where correct color rendition is essential, contact a lighting consultant for advice.

Another factor to take into consideration when modifying your lighting system is the average life of various lamps. For instance, fluorescents and HIDs have a much longer life than incandescents. If you choose to use fluorescent or HID lighting the savings in maintenance costs adds to the cost-effectiveness of the replacement unit.

As previously mentioned, the quality of light can affect a person's ability to perform a task. For this reason, it is important to avoid creating glare on the working surface (See Figure 8). This must be taken into consideration when moving or replacing fixtures. If necessary, contact a lighting consultant for assistance.

There are many new and efficient combinations of lamps waiting to be tried. The case study in the last section of this booklet is a good example of a successful combination of lighting types.

Figure 8: Avoid reflected glare on working surfaces.

As you can see, instituting changes in the lighting system affects many things besides energy use. While it is important to conserve energy you must also keep in mind such things as occupant comfort, worker productivity and various codes. It is a good idea to run a test to ensure that a lighting change produces the anticipated decrease in energy costs while still providing adequate light. Try changes in a small area before making a complete conversion. Ask your employees or tenants if these changes provide adequate illumination for their use. In any event, do not make drastic lighting changes without a trial.

TYPE	Incandescent (includes tungsten halogen)	Fluorescent	Low-Pressure Sodium	High-Intensity Discharge (HID)		
				Mercury Vapor (clear and phosphorous)	Metal Halide (clear and phosphorous)	High-Pressure Sodium
ADVANTAGES	Inexpensive No auxiliary equipment Easy to install Instant start-up Easy to dim, flash and control Good color rendition	Moderate efficiency Longer life than incandescent Burns "cool" Good color rendition	High efficiency Long life Minimal lumen depreciation	Good color rendition in phosphorous type		
				Higher efficiency at higher wattages Longer lamp life		
DISADVANTAGES	Low efficiency Short life Sensitive to voltage input High surface brightness Burns "hot"	Requires auxiliary equipment No instantaneous start-up Temperature sensitive	Requires auxiliary equipment No instantaneous start-up Poor color rendition	Not instantaneous on start-up or restrike Requires auxiliary equipment		

Table 5: Compare the characteristics of various lighting types to get the right combination of efficiency and other features for your situation.

Using Controls to Regulate Lighting

A great deal of energy can be saved by turning off unneeded lights. This requires employee and/or tenant cooperation. Meet with the building occupants to explain the potential savings involved in this practice. Discuss your energy management program with them so they are aware of the steps being taken to conserve lighting energy and so they can participate in making it a success.

Timed Switches

Lights are often left burning needlessly in storerooms, basements, seldom-used work areas and hallways. Connecting a small pilot light to light switches that are located away from the area they service can help keep lights turned off. The pilot light alerts occupants to turn off the lights when no longer needed. Timed switches are effective in walk-in coolers, corridors, storerooms or any place where people may forget to turn out the lights. These switches shut off lights after a predetermined amount of time (See Figure 9). Payback for these measures is usually less than two years.

TIMER TURNS LIGHTS
OFF AUTOMATICALLY
AFTER SELECTED
PERIOD OF TIME
(TIMERS RANGE FROM
5 MIN TO 12 HRS)

Figure 9: A timed switch assures that lights won't be left on for long periods in little-used areas.

Consult your building profile to determine times when the building is empty and lights can be turned off. If possible, schedule building use times to combine several activities. For example, consider scheduling janitorial work in your building during the normal business day, or scheduling events consecutively on one night and shutting the lighting down on the other nights.

Zone Control

Large lighting systems are often controlled by only one switch. This means entire floors or work areas have to be lit at the same time whether it is necessary or not. This practice is costly and inefficient. Zoning the lighting system corrects this situation by providing more switches so lights can be turned on only in the zone or work area where they are needed. When using zone control, label or color code the switches to indicate what area the switch controls. Offices, warehouses and storage areas all benefit from added switching. Three- and four-way switches, which can control the same lights from more than one location, make zone control easier.

In retail store, where lighting needs vary, use separate switches for display lighting and overhead lighting. This gives you more control, allowing you to turn display lights off and on independently of overhead lights. Group several display areas together to maximize the light from a display lighting fixture.

Proximity sensors and controls are now readily available at a reasonable cost. These controls turn lights on when a person enters a room and leave them on for a specified length of time. The lighting period can be extended by the occupants. These sensors are especially useful for off-hours and for areas with irregular users. They can also be incorporated into a security system.

Time Clock Switches & Photoelectric Cells

Time clock switches and photoelectric cells remove lighting systems from the realm of human forgetfulness. Automatic on-off controls are especially useful on display lighting, building and sign lights, and parking lot lights. These switches must be calibrated for day length and checked for proper operation. Remember to list this in your maintenance program.

Use time clock switches on exterior building lights at night. Studies show that vehicle traffic drops sharply after midnight, even on heavily traveled roads. Signs and building lights left on for advertising can be turned off by the time switch after midnight.

Photoelectric cells shut off both interior and exterior lights when there is adequate natural light. Conversely, they can also turn lights on when there is not enough light.

Install security lighting only where it is needed, for example on high-risk areas such as windows and doors. Install lamps with long lifetimes and use timers on the switches.

Taking Advantage of Daylight

Daylighting is often the most cost-effective means of lighting. Unfortunately, in many buildings where window areas have been reduced to cut heat loss, increased lighting bills have more than offset the heating savings. This is true even in cold climates. The graph in Figure 10 shows that total energy use for heating, cooling and lighting is substantially lower when daylighting is used. Since windows improve offices and classrooms in many ways, consult an architect before eliminating any. Keep windows and skylights clean and, where practical, schedule occupancy periods to use maximum daylight. Locate tasks requiring high illumination close to the windows with the viewing angle of the work parallel to the windows. Alter work stations as necessary to reduce glare.

Refinish room surfaces with light colors to reflect light. Clean and repaint as needed. Exterior surfaces can also enhance interior lighting. For instance, white stone or concrete at the base of a building will bounce light through windows onto the ceiling.

Figure 10: Graph demonstrates the cost-effectiveness of daylighting.

The amount of daylight varies, so when it is necessary, supplement it with efficient artificial light. Install switch and lamp combinations that permit turning on additional lights as incoming daylight diminishes. In the mornings, reverse the process, turning off lights as daylight increases. There are reliable and reasonably-priced controls available to automate this process. Consider wiring these switches to a photoelectric control which will make your system automatic. Payback is generally less than 4 years.

Heat Gain & Daylighting

In summer, heat from sunlight can be a problem. In an air-conditioned building, the heat gain from sunlight often produces an extra load on the cooling system, cancelling some of the electrical savings achieved by switching off the lights. Well-placed shading, however, can keep out direct summer sun while still allowing diffuse light to enter.

Exact control is difficult, since the most effective means of blocking heat also blocks some of the light. One solution is to use adjustable controls on exterior louvers or shutters. With an adjustment both heat and light can penetrate in winter, while in summer the system can be set to keep out direct sun but permit entry of indirect light. Interior blinds can also be effective for this purpose.

Another solution is to use windows with a metallic film coating the glass. The film reflects ultraviolet rays while allowing some light to enter. Before purchasing such windows, however, consult your utility company, a lighting designer or your glass supplier.

Inside the building, it is possible to use sunscreens or shades; many different types are available at a reasonable cost. Experiment with one or two before making a major investment. Be sure to consider durability and ease of maintenance when evaluating screens for sun control.

Skylights

Skylights are an excellent source of natural light, equaling up to 40 watts of fluorescent lighting per square foot of skylight. They can also double as a smoke hatch in stairwells. However, as with windows, skylights can cause heat and glare problems.

To use existing skylights effectively:

- Unblock and clean
- Clean and paint any light wells
- Paint the skylight with translucent white paint if glare is a problem
- Install a prismatic lens to diffuse light if desired
(See Figure 11)

Figure 11: There are a number of ways to enhance and control sunlight from skylights.

A Case Study

This case study encompasses a number of the measures discussed in this booklet. Use it as an example of the many ways you can improve your lighting system.

The Illuminating Engineering Society reports that a new department store located on the west coast uses energy-efficient lighting and sunlight to hold lighting energy to about half the industry average for retail stores. The anticipated savings, based on bills from a similar store, are \$7500 annually.

The 150,000 square foot building is lit with a total electricity input of 1.6 watts per square foot, about half the wattage used in existing buildings and 30 percent less than new lighting power standards.

A white fiberglass canopy, installed as part of the roof, allows about 500 footcandles of light to pass through. Its coated underside gives it high reflectance. It also attracts shoppers into the store with its unique design.

At night and on overcast days, ceiling fixtures shine on the canopy, providing indirect illumination. The fixtures are a combination of 1000-watt metal halide and low-pressure sodium lamps. Metal halide and low-pressure sodium are typically used outdoors. However, the designers of this project chose to use them because they have five times the efficiency and ten times the bulb life of traditional department store lighting (quartz halogen lamps). This saves on both operating and maintenance costs. The owners report that overall color rendition equals or surpasses that of stores with traditional lighting.

Metal halide fixtures alone would give merchandise a harsh appearance because of their brightness. In combination, however, the warm amber of the low-pressure sodium fixtures softens and balances the light to achieve a good overall color for merchandise.

In other areas of the store where product visibility is not important, two-foot-square parabolic fluorescent fixtures provide lighting. Energy-efficient lighting design is continued in special merchandising areas, where merchandise is highlighted by low-voltage track lighting with fluorescent lamps for background illumination.

Conclusion

Many of the ways to improve the efficiency of your lighting system involve little or no cost. These include turning off or eliminating unnecessary lights; reducing wattage; keeping lights, fixtures and reflective surfaces clean; and taking advantage of daylighting. Others, such as replacing fixtures and installing switches and timers, are expensive, but their paybacks are attractive. These items and others covered in this booklet are summarized in Table 6.

Lighting ideas are changing rapidly. New products are being introduced monthly. Lighting applications considered impossible a couple of years ago, such as using low-pressure sodium indoors, are now used effectively with careful design. You should be alert to changes in lighting design and to new products, and ask for advice before proceeding with any major remodeling or new construction.

LIGHTING CONSERVATION MEASURES	PAYBACK
Tuning, Operation & Maintenance Items <ul style="list-style-type: none"> • Remove unnecessary lamps • Use lower wattage bulbs • Reset timers • Clean fixtures and paint rooms 	Under 1 year
Low-Cost Measures <ul style="list-style-type: none"> • Replace incandescents with screw-in fluorescents • Install dimmers • Install timeclocks • Lower ceiling fixtures • Install photocells 	1-3 years
Moderate to High-Cost Measures <ul style="list-style-type: none"> • Replace incandescent fixtures with fluorescents • Replace selected fluorescents with H.I.D.'s • Rewire switches for zone control • Install daylight controls 	3-4 years

Table 6: A summary of the energy conservation measures in this booklet arranged from low cost to high cost.

References

- Dubin, Fred S. and Long, Chalmers G., Jr., **Energy Conservation Standards**. New York: McGraw-Hill, 1978.
- Massachusetts State Building Code Commission. **Energy Conservation Opportunities in Lighting**. 1981.
- National Lighting Bureau. **Getting the Most From Your Lighting Dollar**. Washington, D.C.
- National Lighting Bureau. **Lighting Energy Audit Workbook**. Washington, D.C.
- New York State Energy Office. **A Guide to Saving Lighting Energy Dollars**. Albany, New York, 1979.

YOUR ENERGY MANAGEMENT PROGRAM

Schedule	Conservation Program Areas*					
	Energy Management	Tuning, Operation & Maintenance (TOM)	Heating, Ventilating & Air Conditioning	Lighting	Water Heating & Water Conservation	Weatherization
YEARS 1 AND 2 GOAL: To save 10-15% of base year energy index PLAN OF ACTION:						
• Determine how, when and where energy is consumed. Use building profiles, energy records and energy audits as tools.	•					
• Tune systems to peak efficiency.		•	•			
• Operate systems only when needed.		•	•	•	•	
• Set and follow a maintenance schedule.		•	•	•	•	•
• Make no-cost/low-cost modifications.			•	•	•	
YEARS 3-5 GOAL: To save 15-40% of base year energy index PLAN OF ACTION:						
• Plan and perform energy conservation projects with paybacks of under four years.			•	•	•	•
• Purchase energy-efficient equipment.			•	•	•	
• Revise operations to optimize energy use.	•	•				
• Determine how energy availability and price changes might affect your business.	•					
YEARS 6 AND BEYOND GOAL: To save 35-50% of base year energy index PLAN OF ACTION:						
• Perform energy conservation projects with paybacks of 5 years or longer.			•			•
• Examine indirect energy use of your business product or service.	•					
• Include renewable resources in your building or remodeling plans.	•		•		•	

* There are three booklets in this series. The first booklet tells how to establish an Energy Management Program that can save up to 50% of your energy bills. The other booklets tell you how to implement this program. The booklets are available from your local utility company or from Bonneville Power Administration.

END

DATE
FILMED

3 / 28 / 94