**High-Pressure Coal Fuel Processor Development
Task 1. Proof of Principle Testing**

Topical Report

M.L. Greenhalgh

Work Performed Under Contract No.: DE-AC21-88MC25141

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880**

**By
Caterpillar Inc.
100 NE Adams Street
Peoria, Illinois 61629**

November 1992

Table of Contents

LIST OF FIGURES & TABLES	ii
INTRODUCTION	1
TASK 1.0 PROOF-OF-PRINCIPLE TESTING	1
SUBTASK 1.1 - ENGINE FEASIBILITY	2
Combustion Rig Description	2
<i>Test Cell Layout</i>	2
<i>Component Design</i>	3
Combustion Rig Tests	4
<i>Bench Rigs</i>	4
<i>SCTE Shakedown</i>	5
<i>Combustion Development at Rated Power</i>	6
Conclusions - Engine Feasibility	11
SUBTASK 1.2 - FUEL PROCESSOR FEASIBILITY	12
Fuel Processor Rig Description	12
<i>Test Cell Layout</i>	12
<i>Component Design</i>	15
Fuel Processor Rig Tests	17
<i>Reactor Pressure Vessel Shakedown Tests - (Runs #1 - #17)</i>	17
<i>Preliminary Results Corrected For High-Bypass Air Flow (Runs #18 - #26)</i>	20
<i>Water Injection, Hot Gas Sampling & Ash Collection Eff. (Runs #27 - #44)</i>	22
<i>Reaction Transfer & Minimum Air Flow (Runs #45 - #49)</i>	24
<i>Sulfur Capture, Particulate Analysis & Final Test Results (Runs #50 - #69)</i>	25
<i>Post Test Analysis</i>	27
Conclusions - Fuel Processor Feasibility	33

List of Figures & Tables

Figures

1. Combustion Rig Test Cell Layout	2
2. Combustion Rig Single Cylinder Test Engine Instrumentation	4
3. Combustion Rig Test Data Summary	6
4. Combustion Rig Cylinder Pressure-Volume Characteristic	7
5. Fuel Processor Rig Test Cell Layout	13
6. Reactor Vessel Unit #1 Cross Section	14
7. Reactor Vessel Unit #2 Stress Analysis	15
8. Reactor Vessel Unit #2 Cross Section	16
9. Typical Canister Temperature Profile vs Coal Bed Depth & Processing Time	18
10. Coal Bed Plug Depth vs Water Injection Time	19
11. Gasification Reaction Rates vs Coal Bed Depth	20
12. Fuel Processor Rig Test Data - Run #26	21
13. Fuel Processor Rig Test Data - Run #29	23
14. Gasification Reaction Rate vs Inlet Air Flow Rate	26
15. Methane Concentration vs Exit Gas Sampling Time	28
16. Hydrogen Concentration vs Exit Gas Sampling Time	28
17. CO & CO ₂ Concentrations vs Exit Gas Sampling Time	29
18. Predicted vs Measured CO	31
19. Predicted vs Measured CH ₄	31
20. Predicted vs Measured CO ₂	32
21. Predicted vs Measured H ₂	32

Tables

1. Synthetic Coal Gas Sample Analysis	7
2. Combustion Rig Test Results at 67 hp, 1800 rpm	8
3. Combustion Rig vs Fuel Processor Rig Compositions, vol%	11
4. Unprocessed Coal & Coal Bed Plug Analysis	19
5. Unprocessed Subbituminous Coal Analysis	22
6. Ash Collection Efficiency - Run #32	24
7. Gas Compositions & Heating Values - Run #45 (Two Units in Series)	24
8. Particulate Trap Mass Balance	25

HIGH-PRESSURE COAL FUEL PROCESSOR DEVELOPMENT - Test Program Topical Report -

INTRODUCTION

Caterpillar shares DOE/METC interest in demonstrating the technology required to displace petroleum-based engine fuels with various forms of low cost coal. Current DOE/METC programs on mild gasification and coal-water-slurries are addressing two approaches to this end. Engine and fuel processor system concept studies by Caterpillar have identified a third, potentially promising, option. This option includes high-pressure fuel processing of run-of-the-mine coal and direct injection of the resulting low-Btu gas stream into an ignition assisted, high compression ratio diesel engine. The compactness and predicted efficiency of the system make it suitable for application to line-haul railroad locomotives.

The objective of this program is to assess the feasibility of a high-pressure, coal-gas-fueled diesel engine, the concept of which is to be developed during the contract. The program consists of Task 1 - Proof-of-Principle Testing (fuel processor and engine feasibility) and Task 2 - Concept Design and Analysis (of the integrated engine/fuel processor system).

A successful conclusion of the program will enable further component development work and full-scale system demonstrations of this potentially important technology.

This report covers the work completed under Task 1. The Design Briefing and Final Report will cover the work completed under Task 2.

TASK 1.0 PROOF-OF-PRINCIPLE TESTING

The objective of Subtask 1.1 Engine Feasibility was to conduct research needed to establish the technical feasibility of ignition and stable combustion of directly injected, 3,000 psi, low-Btu gas with glow plug ignition assist at diesel engine compression ratios. This objective was accomplished by designing, fabricating, testing and analyzing the combustion performance of synthesized low-Btu coal gas in a single-cylinder test engine combustion rig located at the Caterpillar Technical Center engine lab in Mossville, Illinois.

The objective of Subtask 1.2 Fuel Processor Feasibility was to conduct research needed to establish the technical feasibility of air-blown, fixed-bed, high-pressure coal fuel processing at up to 3,000 psi operating pressure, incorporating in-bed sulfur and particulate capture. This objective was accomplished by designing, fabricating, testing and analyzing the performance of bench-scale processors located at Coal Technology Corporation (subcontractor) facilities in Bristol, Virginia.

These two subtasks were carried out at widely separated locations and will be discussed in separate sections of this report. They were, however, interdependent in that the composition of the synthetic coal gas used to fuel the combustion rig was adjusted to reflect the range of exit gas compositions being produced on the fuel processor rig.

Two major conclusions resulted from this task. First, direct injected, ignition assisted Diesel cycle engine combustion systems can be suitably modified to efficiently utilize these low-Btu gas fuels. Second, high pressure gasification of selected run-of-the-mine coals in batch-loaded fuel processors is feasible. These two findings, taken together, significantly reduce the perceived technical risks associated with the further development of the proposed coal gas fueled Diesel cycle power plant concept.

SUBTASK 1.1 - ENGINE FEASIBILITY

The objective of this subtask was to demonstrate the technical feasibility of a low-Btu gas combustion system (direct injected, ignition assisted, Diesel cycle compression ratio) on a laboratory combustion rig fueled with synthetic coal gas. The combustion rig consists of a modified Caterpillar 3401 Single Cylinder Test Engine (SCTE), dynamometer and fuel supply system. The fuel supply system includes a supply tank, gas compressor, fuel heater, piping and controls.

Although the support equipment components required a considerable investment in technical manpower and materials expenditures, the primary focus of this subtask was on the combustion system components. The combustion system components included the fuel injector (gas admission valve), glow plug ignition assist device and the components defining the boundary of the combustion chamber space (cylinder head, inlet & exhaust valves, cylinder liner and piston crater).

Combustion Rig Description

Test Cell Layout

The overall test cell layout is shown schematically in Figure 1.

Figure 1. Combustion Rig Test Cell Layout

The fuel supply system provides synthesized coal gas containing H₂, CO, CO₂, CH₄, N₂ and higher carbon-number volatile hydrocarbons to the SCTE at 3000 psi and up to 800°F. Synthesized coal gas at 1320 psi, premixed by commercial vendors to the desired composition, is provided from a 70,000 SCF tube trailer located at an outdoor site adjacent to the test cell.

The gas mixture is piped to a compressor in the test cell at 100 psi. A three-stage electrically driven reciprocating compressor (RIX Industries, Oakland, CA) supplies up to 80 SCFM gas flow rate at 4000 psi. A remotely actuated pressure reduction regulator reduces gas pressure to engine delivery pressure (2000 to 3000 psi).

The gas heater, designed for this project by Wellman Thermal Systems, Shelbyville, IN, consists of a coiled high pressure pipe surrounded by electric radiant heating elements. Gas and water can be heated simultaneously in separate parallel circuits to 725°F, water vapor and gas combined in a common circuit and the resultant mixture heated up to 880°F for delivery to the engine.

The SCTE (5.4 inch bore, 6.5 inch stroke) and supporting equipment are shown schematically in Figure 2. Controls and instrumentation of inlet air, exhaust, lubrication, cooling and cylinder pressure are those used routinely for engine testing at Caterpillar. Engine load is supplied by a 150 hp DC electric dynamometer. A state-of-the-art data acquisition system collects test data for further analysis including prediction of multi-cylinder engine performance.

Component Design

Alternative SCTE combustion chamber component designs were subjected to detailed thermal and mechanical stress analysis prior to procurement using finite element analysis models, available at Caterpillar, modified for this purpose. The combustion system was designed for 67 hp at 1800 rpm and 1800 psi peak cylinder pressure at fuel gas temperatures up to 800°F.

The grey iron cylinder head was designed for a low cycle thermal fatigue life of 4000 cycles at fuel gas temperatures up to 1350°F based on 110°F cooling water temperature. Calculated high-cycle fatigue life exceeded 1.9 times required, i.e., it would pass an internal Caterpillar production engine qualification test. Thermal boundary conditions for coal gas fuel combustion were obtained from an existing Caterpillar cycle simulation program.

The injector was designed for 3.5 grams/injection at 300°F and 2.5 g/inj at 800°F using steady flow analysis methods. A transient flow analysis (Dr. R.F.Hurt, Bradley U.) identified potential flow losses due to dynamic pressure and velocity flow fields within the injector of less than 7%, confirming the adequacy of the injector internal passage sizes. Pyromet 31 steel (56% Ni, 23% Cr) was selected for the critical injector parts - a castable steel used in production exhaust valves and valve inserts with adequate calculated stress rupture life ($B1 > 10,000$ hrs) for this application.

The 13:1 compression ratio, high top ring, two-piece steel-crown articulated piston with aluminum skirt has a predicted liner top ring turnaround temperature of 68°F hotter than on a Caterpillar production 3406 engine with one-piece aluminum pistons at 67 hp. This was deemed acceptable for the feasibility demonstration although readily available modifications to the cooling jacket and liner would be required for longer term durability.

The ignition assist glow plug and power supply designs were modifications of existing Caterpillar configurations developed for use on experimental direct injected natural gas engines. The ceramic-tipped glow plug, configured to Caterpillar specifications, was procured from a supplier.

Figure 2. Combustion Rig Single Cylinder Test Engine Instrumentation

Combustion Rig Tests*Bench Rigs*

The check stem of the gas injector is raised by porting high pressure hydraulic fluid to an actuator piston on top of the check stem located in the upper portion of the injector body. The performance of this hydraulic actuator circuit was evaluated on a bench rig prior to engine testing. Problems with the original design (fatigue, seizure, leakage) were identified and addressed with changes to materials, heat treatment, surface finish and/or geometry of the internal parts.

All of the observed failure modes resulted in failure of the injector check to open. The injector check opens (unseats) to allow fuel flow to the combustion chamber. It is held open by oil pressure in the hydraulic actuator circuit supplied by a modified diesel engine fuel pump. The check is held closed (seated) by static hydraulic oil pressure from an accumulator pressurized with nitrogen at 6000 psi. There were no observed failure modes where the check failed to close.

To guard against unforeseen failure modes resulting in an open check, a trade-off analysis of compression ratio, gas injection pressure and engine load (fuel gas delivery rate) was conducted. Two options were identified: lower the compression ratio from 13:1 to 11:1 or limit gas injection pressure to 2400 psi. For initial short-term testing, gas injection pressures were limited to 2400 psi rather than delay testing in order to machine lower compression ratio piston crowns. Several concepts, including fuel-line shuttle-valves and combustion chamber pressure relief valves, were identified for further investigation as a potential long-term solutions to injector malfunctions that would result in failure of the check to close during engine operation.

Initial engine testing did not produce detectable in-cylinder combustion pressure despite variations in fuel injection timing, delivery and pressure; air/fuel ratios; engine speed; and glow plug tip and inlet air temperatures. Samples of the fuel gas were analyzed for composition and found to be within the specifications warranted by the supplier.

Additional fuel gas samples were ignited in bench tests, at low velocity and atmospheric pressure, with a natural gas fired burner, a welder's spark and a glow plug energized to in-cylinder surface temperatures. The fuel gas appeared to burn in a part of the gas plume that was very fuel rich and with a flame similar in color to a natural gas flame at stoichiometric conditions.

SCTE Shakedown

Based on the bench test results, the engine inlet air was throttled and the gas flow rate substantially increased to obtain a near stoichiometric mixture in the combustion chamber. Combustion was erratic but the engine ran for a short period with a 5.1 hp load at 842 rpm. Fuel injection timing and air/fuel ratios were varied but no further improvements in combustion were observed.

Geometry of the fuel jet, at the above described in-cylinder conditions, was calculated. This analysis indicated that the fuel spray envelope was not in close enough proximity to the glow plug tip to achieve consistent start of ignition and stable combustion. As a result, an injector nozzle tip with an increased number of holes was procured for further testing.

Engine tests with the new nozzle tip produced some improvement in combustion characteristics. Start of combustion occurred as early as 12 CA° BTDC (crankangle degrees before top dead center) but the engine remained sensitive to air/fuel ratio and operation was limited to a narrow speed range around 1000 rpm.

Further refinements to nozzle tip geometry and engine control settings were explored, supported by fuel spray modeling, to identify design changes for follow-on tests. Fuel sprays were simulated using a computational fluid dynamics computer program (KIVA II) developed at Los Alamos National Laboratory and run by Caterpillar on the Cray XMP4 at the National Center for Supercomputer Applications at the University of Illinois, Urbana, IL.

In subsequent combustion rig tests engine power was increased to 26% of rated output at 1100 rpm primarily due to increasing the number and size of the injector nozzle orifices and advancing fuel injection timing. Excessive fuel pressure regulator droop occurred at these higher gas flow rates thereby reducing gas pressure to the engine during load and speed changes.

A dome-loaded pressure regulator was installed in the fuel gas supply line to replace the original regulator which had been selected based on incorrect supplier information. Engine power was increased to 70% of rated at 1380 rpm due to improved control of gas supply pressure. There was also a benefit from increased inlet gas temperature. At the higher flow rates the fuel transit time from the compressor to the engine was less, thereby reducing heat loss.

Combustion rig operation at 95% of rated power (64 hp) at rated speed (1800 rpm) resulted from increases in glow plug voltage and the accompanying slightly higher fuel gas temperatures due to higher fuel flow rates. Variations in the orientation of the glow plug about its longitudinal axis showed no improvement (decrease) in ignition delay.

Combustion Development at Rated Power

Full rated power (67 hp at 1800 rpm) and peak torque operating conditions (55 hp at 1260 rpm) were achieved by further advancing fuel injection timing to 69 CA° BTDC and increasing fuel injection pressure to 2600 psi.

Figure 3. Combustion Rig Test Data Summary

The operating range of the SCTE on diesel fuel is defined by the lug curve shown in Figure 3 where break mean effective pressure (BMEP) is plotted vs engine speed (RPM). The shaded area indicates the operating conditions investigated while running on 100 Btu/SCF synthetic coal gas with 2400 - 2600 psi gas injection pressure. Individual operating points at which data were recorded are marked by an "X".

Detailed cylinder pressure data were obtained at 50 and 70% load at rated speed (1800 rpm). A sample is shown by the solid line in Figure 4 where cylinder pressure, normalized to inlet pressure, is plotted vs cylinder volume, normalized to maximum cylinder volume, for 50% rated load. The shaded region represents the effect of fuel injection on in-cylinder pressure during the compression stroke. Further combustion system performance development was directed at recovering this loss in indicated work by reducing ignition delay to 20 CA° which, in turn, permitted later fuel injection timing.

Figure 4. Combustion Test Rig Cylinder Pressure-Volume Characteristic
50% Load, Rated Speed

The synthetic coal-gas fuel heater and support equipment were installed and checked-out in the combustion rig test cell. Synthetic coal-gas supplies were analyzed and stocks were replenished. A typical comparison between specified and actual composition is shown in Table 1.

Table 1. Synthetic Coal-Gas Sample Analysis

	<u>Specified</u> (vol %)	<u>Actual</u> (vol %)
H ₂	9.0	8.8
CO	9.0	9.0
CO ₂	16.0	16.9
CH ₄	6.0	5.
N ₂	60.0	59.6

The test at rated load and speed was repeated with the fuel heater installed but not activated. The remaining combustion rig tests were also all conducted at rated load and speed. Engine data and fuel gas compositions for these tests are shown in Table 2.

Table 2. Combustion Rig Test Results at 67 hp, 1800 rpm

	w/o heater	heater off (baseline)	<div style="text-align: center;">←———— heater —————→ on</div>						
Fuel Temp., °F	230	235	302	408	493	603	698	822	379
Airflow Rate, lbm/hr	369	354	365	365	370	340	343	352	362
A/F ratio, lbm/lbm	1.26	1.28	1.35	1.41	1.41	1.42	1.43	1.47	1.72
Fuel Press., psi	2600	2610	2470	2430	2480	2210	2300	2370	2110
Avg. PCP, psi	1421	1450	1670	1600	1480	1490	1440	1190	1330
Start of Inj., °BTDC	69	69	69	53	58	49	48	43	22
End of Inj., °BTDC	27	30	30	19	22	13	11	5	-28
Start of Comb., °BTDC	8	8	10	6	6	3	1	-6	3
Ignition Delay, °CA	61	61	59	47	52	46	47	49	19
Inj. Orif. Area, in ²	0.042	0.042	0.042	0.053	0.053	0.053	0.053	0.053	0.029
Fuel Composition, % vol.									
Methane	5.4	5.7	5.7	5.7	5.7	6.2	6.2	6.2	2.1
Carbon Monoxide	8.4	8.8	8.8	8.8	8.8	9.6	9.6	9.6	27.5
Hydrogen	9.2	9.0	9.0	9.0	9.0	9.2	9.2	9.2	4.1
Carbon Dioxide	14.6	16.9	16.9	16.9	16.9	15.6	15.6	15.6	4.1
Nitrogen	62.4	59.6	59.6	59.6	59.6	59.4	59.4	59.4	61.1
Propane	0	0	0	0	0	0	0	0	1.1
Higher Heating Value, Btu/lbm	1412	1431	1431	1431	1431	1552	1552	1552	1981
Methane Number	122	122	122	122	122	123	123	123	106

The first column of Table 2 is from the test on synthetic coal gas before the fuel gas heater was installed. The second column is from the test with the heater installed but turned off. This test will be referred to as the baseline test in the remainder of this narrative. The data in the last seven columns are from tests conducted with the fuel gas heater turned on.

The synthetic coal gas supply was replenished before the baseline test was conducted. Comparing the first two columns of Table 2 shows that the slight differences in composition had little impact on test results.

In the test at 302°F fuel gas temperature it was possible to operate at reduced fuel pressure (2470 psi) but peak cylinder pressures increased up to the structural design limit of 1800 psi. Peak cylinder pressures fluctuated from cycle-to-cycle in all the tests and only the average peak cylinder pressure for each test (Avg. PCP) is listed in Table 2. Fuel injection duration was too long to allow further retarding the start of injection from 69 CA°BTDC (to reduce peak cylinder pressure) and still maintain stable combustion. An even shorter fuel injection duration would be required for operation at higher fuel gas temperatures.

An existing Caterpillar fluid dynamics model was used to identify design changes to the fuel injector that would result in shorter injection duration. The diameter of the orifices in the nozzle tip were increased to accommodate fuel gas temperatures up to 800°F. The diameter of the check plunger was reduced by 20% to increase check lift rate 41% and, thereby, shorten injection duration.

These design changes permitted operation from 408°F to 822°F fuel gas temperatures without exceeding peak cylinder pressure limits. However, at these higher fuel temperatures, the rates of rise in cylinder pressure increased substantially. The start of injection was retarded (10 to 20 CA° depending on fuel gas temperature) to avoid the risk of piston seizure. As a result, the start of combustion on the 822°F fuel was delayed to the point (6 CA° After TDC) where combustion stability was again marginal. Stable combustion on fuel at temperatures above 800°F would require further reductions in ignition delay.

Ignition delay varied from 46 CA° to 52 CA° in these five tests (columns 4 - 8, Table 2) compared to a target of 20 CA°. The difference between 50 CA° and 20 CA° ignition delay causes a calculated four percentage point loss in the overall system thermal efficiency of the coal-fueled diesel concept.

Based on previous test experience with gaseous fuels, there are three potential approaches to reducing ignition delay.

- 1) Optimize the air-fuel ratio at the glow plug tip earlier in the injection period.
- 2) Raise the temperature of the air-fuel mixture in the vicinity of the glow plug.
- 3) Alter the fuel composition to improve its ignition quality.

The first two options were explored analytically using a computer-based fluid dynamics code (KIVA II) to simulate in-cylinder conditions during the period from inlet valve closing up to the start of combustion.

Analysis of the test data and simulations of in-cylinder conditions indicated that further reductions in ignition delay at these fuel gas temperatures are not likely through changes to air-fuel ratios, mixture velocity profiles or temperature levels in the vicinity of the glow plug tip.

It was concluded that air-fuel ratios in the vicinity of the glow plug tip during the last half of the ignition delay period were relatively constant and approximately equal to overall measured air-fuel ratios. This suggested that the observed ignition delay was not due to the lack of a proper air-fuel mixture at the glow plug tip.

Predicted air-fuel mixture temperatures at the glow plug tip during the period from the end of injection to the start of combustion were about 300°F higher for the high-temperature fuels than for the low-temperature fuels. This temperature differential was not enough to produce a significant reduction in ignition delay in the engine test. It was concluded that further increases in the temperature of the air-fuel mixture at the glow plug tip would require higher fuel temperatures. Although the original concept assumed fuel gas temperatures up to 1500°F, the current fuel heater was being operated at the limit of its capability.

Analysis of the fuel gas composition in terms of ignition quality (methane number) suggested that the observed ignition delay was chemistry limited. The ignition qualities of various gaseous fuels were investigated to estimate the extent to which the ignition delay of the mixture being tested might be chemistry dependent.

The mechanisms that govern ignition delay in compression ignition engines are similar to those that cause knocking in spark ignited engines, i.e., autoignition. Therefore, it was expected that factors that enhance knocking in spark ignited engines might reduce ignition delay in the combustion rig.

The knocking tendencies of gaseous fuels in spark ignited engines are determined in standardized engine tests and rated according to the fuel's methane number (Leiker et al., 1971)¹. Natural gas has a calculated methane number of 82 and has demonstrated an ignition delay of about 19 CA° in Caterpillar tests of engines with combustion systems similar to the combustion rig. The computed methane number of the synthetic coal gas used in the combustion rig was 122 and its ignition delay was about 50 CA° over the entire fuel-temperature range tested.

These results suggested that coal gas would need to have a computed methane number in the range of 85 to 90 to produce an ignition delay of 20 CA°. Methane numbers for exit gas samples taken from fuel processor rig tests (discussed in the next section of this report) were computed and compared to this criterion. The methane numbers of the gas samples were significantly lower (more favorable) than those for the synthetic coal gas used in the combustion rig up to this point.

Hydrocarbons higher than methane can favorably affect methane number even at low concentrations (0.5 to 2.0 vol%). Higher hydrocarbons had not been detected in cold exit gas samples taken from the fuel processor rig tests. Test procedures were modified to permit the collection of hot gas samples. Higher hydrocarbons were then detected in quantities sufficient to make a significant reduction in estimated exit gas methane number.

Hot gas samples from fuel processor rig test Run #29 indicated that the exit gas contained about 1.0 vol% light hydrocarbons (carbon numbers C₂-C₁₀). Analysis of light hydrocarbon characteristics indicated that these components would remain volatilized above 450°F. Transport to the combustion chamber could be accomplished by insulating the system between the fuel processor and the engine. It was therefore assumed that a fuel processor coupled to an engine would provide fuel gas containing about 1% light hydrocarbons and that the synthetic coal gas composition should be altered accordingly.

Propane (C₃H₈) was added to simulate the light hydrocarbons found in the hot gas samples. The % volumes of H₂, CH₄, and CO₂ were reduced by 55%, 65%, and 75%, respectively, and the CO concentration was tripled (Table 3).

The addition of 1% Propane and adjustment of the other gas component concentrations, to better correlate with the fuel processor rig test exit gas samples, reduced the calculated methane number to 106 (from 122) and increased the calculated heating value to 145 Btu/SCF.

Combustion rig ignition delay was reduced to 19 CA° using the reformulated fuel gas at 379°F as shown in the last column of Table 2.

¹ Leiker, M., Christopher, K., Rankl, M., Cartellieri, W., and Pfeifer, U., "The Evaluation Of The Antiknocking Property Of Gaseous Fuels By Means Of The Methane Number And Its Practical Application To Gas Engines," *9th International Congress on Combustion Engines*, Stockholm, Sweden, 1971.

Table 3. Combustion Rig vs Fuel Processor Rig Gas Compositions, vol%

	Fuel Gas #1	Exit Gas	Fuel Gas #2
O ₂	---	2.0	---
N ₂	59.6	63.8	61.1
H ₂	8.8	3.1	4.1
CH ₄	5.7	1.6	2.1
CO	9.0	24.5	27.5
CO ₂	16.9	3.7	4.1
C ₂ - C ₄	---	0.4	1.1
Light Oils, (>450°F)	---	0.9	---
Heating Value, 105 Btu/SCF		145	145

Conclusions - Engine Feasibility

1. Proof-of-Principle rig tests of the proposed combustion system have demonstrated the feasibility of ignition and stable combustion of directly injected low-Btu gas with glow plug ignition assist at diesel engine compression ratios over a range of fuel gas temperatures from 225°F to 822°F with potential for efficiently utilizing coal gas at substantially higher temperatures.
2. Injection duration and ignition delay can be controlled over a range sufficient to contain peak cylinder pressures and cylinder pressure rise rates to within commercial engine structural design limits.
3. Further research is required to address technical uncertainties (R&D gaps) inhibiting commercial exploitation of the proposed coal gas fueled diesel engine combustion system, including:
 - devices to limit fuel gas injection during the intake stroke in cases where injector malfunctions leave the check stuck open risking over-pressurization of the cylinder,
 - scaling the combustion system up to larger bore sizes appropriate for locomotive engine applications,
 - achieving acceptable engine performance with a fuel supply that varies in temperature, composition and energy content as would be expected from a cycling, batch loaded coal fuel processor,
 - operation on a non-steady state duty cycle characteristic of locomotive engine applications.

SUBTASK 1.2 - FUEL PROCESSOR FEASIBILITY

The objective of this subtask was to demonstrate the feasibility of an air-blown, fixed-bed, high pressure (3000 psi) gasifier concept incorporating in-bed particulate and sulfur capture on a laboratory-scale fuel processor rig. The fuel processor rig was designed by Caterpillar and assembled for testing by the subcontractor Coal Technology Corporation (CTC), Bristol, Virginia.

A containment structure was designed and constructed at CTC facilities to house the fuel processor rig and operator's control station. The experimental support equipment components, controls, instrumentation and data acquisition system required considerable technical manpower effort and materials expenditures but the primary focus of this subtask was on the gasification processes within the high pressure reactor vessels.

Fuel Processor Rig Description

Test Cell Layout

The overall test cell layout is shown schematically in Figure 5. The major components of the fuel processor rig included air compressors; air, water and nitrogen supply tanks; a high pressure reactor vessel and, in later tests, two vessels in series; hot and cold exit gas sampling ports; and an operator's station with computer-based test control, data acquisition and data reduction systems.

An Ingersoll-Rand H15T4 air compressor supplies 5000 psi air to Bauer SAS-2 air receiver tanks. The air receiver tanks provide pressurized air storage to supplement compressor flow capacity during the operating cycle. Pressurized, bottled nitrogen provides system air-purge for start up and for quick shutdown in the event of overtemperature in the test section. Water injection to the test section inlet controls water-to-coal ratio.

Electronically controlled, pneumatically actuated, in-line pressure and flow control valves (Fisher) regulate air and water to the test section. Pressures and temperatures are monitored upstream and downstream of the test section and temperatures are monitored within the test section.

The reactor pressure vessel houses the test section where injected air and water react with the coal charge to produce coal gas. A glow plug at the top of the coal charge provides an ignition source. High- and low-temperature exit gas sampling ports are located downstream of the reactor pressure vessel.

The high-temperature sampling port provides a cycle-averaged gas sample that includes condensibles. Seven low-temperature ports, downstream of the cooler, provide non-condensable gas composition samples at selected time increments during the operating cycle.

A cross section of the reactor pressure vessel Unit #1 is shown in Figure 6. A 2" diameter, 51" long removable canister is inserted into a pressure chamber lined with commercially available (Combustion Engineering Inc., Valley Forge, PA) cast in-place refractory. A pneumatically controlled, hydraulically actuated flange and supporting mechanism (bottom of Figure 6) provide sealing and opening of the pressure chamber as well as insertion and removal of the canister. Contact thermocouples (Type J), inserted through the pressure vessel wall and the refractory liner, come in contact with the external surface of the canister. The thermocouple readings are used to track the rate at which the reaction propagates down through the coal charge.

Coal gas passes through a granular-bed (double-screened sand) filter and a ceramic filter in the canister below the coal charge where solids are extracted from the gas stream. A portion of the gas stream is diverted to the sampling system and the remainder flared to the atmosphere.

A trap, not shown in Figure 5, is provided for assessing the feasibility of capturing coal gas stream particulates with granular bed and ceramic filters. The trap is installed in the reactor pressure vessel exit gas line. Exit gas bubbles up through dichloro-methane (CH_2Cl_2) to extract particulate matter from the gas stream, prior to passing on to the cold sampling port. A backup battery provides uninterrupted power for controlled shutdowns in the event of local utility power outages.

Figure 5. Fuel Processor Rig Test Cell Layout

Figure 6. Reactor Vessel Unit #1 Cross Section

The test controller, signal conditioning, data reduction and data logger electronic equipment (Action Instruments) were purchased "off the shelf" and were assembled, programmed, debugged and calibrated by CTC personnel with support from the supplier. This control and data acquisition system was expanded when a second reactor pressure vessel (Unit #2) was added later in the test program. The second unit (in series) was to demonstrate the feasibility of transferring gasification reactions between batch processors without the need for supplemental ignition sources.

Component Design

The stainless steel reactor pressure vessel, fabricated by Kanawha Manufacturing Co., Charleston, WV, was designed to withstand² creep rupture, high- and low-cycle fatigue, creep-fatigue interaction and environmentally-associated cracking.³ The vessel was inspected for casting voids (Conam Testing Services, Chicago, IL) using cobalt radiography and ultrasonic techniques. Prior to final assembly it was hydrostatically pressure checked to 6000 psi at room temperature for two hours with an ASME certified observer present. To pass this test, the original flange seals had to be replaced with die-formed (Graphoil) seals procured from SEPSCO, Birmingham, AL.

The design of Unit #2 drew from experience with Unit #1. The main pressure vessel was constructed of 17-4 PH stainless steel based on strength at temperature (Figure 7), material availability, weldability, machinability and the desire to keep the vessel as small as possible.

Figure 7. Reactor Vessel Unit #2 Stress Analysis

Unit #2 (Figure 8) has a pressure compensation circuit that maintains a pressure differential of less than 100 psi between the canister internal and external volumes, i.e., less than the pressure limit of

² ASME Boiler and Pressure Vessel Code Section VIII, Division 1, 1986 Edition, 1988 Addenda.

³ Nickell, Robert E., Ph.D., Analysis Report, Applied Science & Technology, Poway, CA, 1/13/89.

the O-ring seal on the canister inlet. This feature plus improved canister sealing eliminated inlet air bypass around the test section and air flow from the canister jacket volume into the test section due to thermal expansion. This ensured that test section air flow rate equaled the air flow rate measured upstream of the pressure vessel inlet.

Figure 8. Reactor Vessel Unit #2 Cross Section

The thermocouples on Unit #2 are spot welded to the external surface of the canister. This permits a more accurate determination of canister wall temperatures and more accurate tracking of gasification reaction propagation rates down through the coal charge than was possible with Unit #1. The contact-type thermocouples used on Unit #1 were not always in contact with the canister due to differential thermal expansion between the canister and the reactor pressure vessel wall in which they were mounted.

Fuel Processor Rig Tests

The fuel processor rig test operating procedure is started by bringing the reactor pressure vessel up to operating pressure with air from the compressor and air receiver tanks. The glow plug, located at the top of the coal charge, is turned on until reaction start is detected by a rise in canister wall temperature. The glow plug is then turned off and inlet air and water (when used) flow rates are controlled for the duration of the test. Canister wall thermocouple readings and pressure drop across the canister are monitored and fed back to the controller logic circuit which initiates a test shutdown if either exceeds preset limits. All pressure, temperature and flow rate data are displayed on a computer screen at the operator's control panel.

Gasification reaction rates are determined from the measured rate of propagation of the high temperature zone down through the canister. Reaction rates are estimated by plotting canister temperature profiles vs bed depth and processing time as shown in Figure 9. Canister temperatures are measured with thermocouples located in a helical pattern around and along the length of the canister in contact with the canister external surface. Successive thermocouples are spaced two inches apart axially and 90° circumferentially.

Reactor Pressure Vessel Shakedown Tests - (Runs #1 - #17)

Initial rig shakedown tests identified several challenges to getting the reactor pressure vessel operational. The first seventeen tests dealt with debugging the instrumentation and control program computer codes; correcting minor pipe joint leaks; diagnosing and replacing control valve needles and seats that were not within specification (replaced at supplier expense); and ramping up in operating pressure and quantity of coal processed.

During the test program, the need for design changes to the pressure vessel were identified. Problems with air bypass around the test section and intermittent thermocouple contact with the canister wall were discussed above in the Fuel Processor Rig Description section.

Unacceptably high coal bed temperatures (>2500°F) occurred at air flow rates above .025 lbm/sec. Small pellets of selected metals with different melting temperatures were placed in the coal bed and examined during post test inspection. Temperatures determined with this method were consistent with pin holes burned through the canister walls in tests at the higher air flow rates. Water injection was then employed in tests at higher air flow rates to reduce maximum coal combustion temperatures (to the point where measured canister wall temperatures were below 1900°F) in order to preserve canister structural integrity.

Initial tests with water injection were prematurely terminated due to a rapid rise in pressure across the canister. Post test inspection of the canister contents revealed that a plug had formed within the coal bed downstream of the reaction zone. Proximate and ultimate analyses of the as-received coal and the plug char material (Table 4) indicated the presence of heavy tar-like deposits.

The high moisture content in the plug char (21.65%), relative to the original coal (17.66%), indicated condensation of intermediate and heavy hydrocarbons in the cooler regions of the bed. High carbon and low oxygen contents from the ultimate analysis were further evidence of heavy tar-like deposits. Nearly equal nitrogen, sulfur, and heating values in the coal and plug char ruled out high temperature coking or slagging.

Figure 9. Typical Canister Temperature Profile: Function of Coal Bed Depth and Processing Time.

Table 4. Unprocessed Coal And Coal-Bed Plug Analysis

	Coal		Plug Char	
	As Rec'd	Dry	As Rec'd	Dry
PROXIMATE ANALYSIS, %				
Moisture (< 110°F)	17.66	0.00	21.65	0.00
Ash	4.61	5.60	4.80	6.12
Volatile (< 950°F)	33.08	40.18	21.84	27.87
Fixed Carbon	44.65	54.22	51.71	66.01
ULTIMATE ANALYSIS, %				
Moisture (< 110°F)	17.66	0.00	21.65	0.00
Carbon	57.51	69.84	60.44	77.14
Hydrogen	4.07	4.95	3.32	4.24
Nitrogen	.086	1.04	0.87	1.10
Sulfur	.036	0.44	.035	0.45
Oxygen*	14.93	18.13	8.57	10.95
Ash	4.61	5.60	4.80	6.12
HEATING VALUE				
Btu/lb	10117	12286	10183	12996
SWELLING INDEX				
	0.0	----	N/A	----

* Oxygen by difference.

The zero value of the swelling index confirmed that the subbituminous coal was non-caking, at least under atmospheric pressure conditions. Specialized bench tests would be required to determine whether or not this coal type swells under high-pressure conditions.

Figure 10. Coal Bed Plug Depth vs Water Injection Time

Plug location was dependent on the time at which water injection was initiated. Water injection at less than 10 seconds after the initiation of ignition prevented coal bed plugging (Figure 10). Early water injection apparently reduced gasification rates and lowered reaction zone peak combustion temperatures to the point where the quantity of condensibles in the coal gas

downstream of the reaction zone were low enough to preclude plugging. A lower gasification rate would slow down the reaction zone propagation rate. This would allow more time for gas phase condensibles to react and breakdown into non-condensable species before being swept out of the reaction zone, thus reducing the quantity of condensibles in the cooler downstream regions of the coal bed. Lower peak temperatures in the reaction zone would produce a cooler gas stream resulting in less condensibles driven off the coal charge downstream of the reaction zone.

Earlier water injection necessitated that water flow rates be reduced to prevent combustion extinction. Water flow control valve internal hardware modifications to permit doing so were procured and faster response thermocouples were installed to reduce the time-lag in detecting the rise in bed temperature.

Injecting water into the inlet air upstream of the test section did not provide a uniform distribution of water laterally across the test section. Resulting temperature gradients in the coal bed caused severe canister distortion (longitudinal "bowing"). An atomizing water injector was designed and procured for installation in the reactor pressure vessel top flange immediately above the top of the coal charge. A shroud was later added to inhibit attachment of the incoming water mist to the canister wall. These design changes reduced canister distortion to less than 0.5%.

Rig test results through Run #17 had proven to be very sensitive to initial conditions, e.g., air flow rates, timing of water injection and water flow rates. There was ample evidence that the coal combustion zone was propagating through the coal charge although uniform burning had not yet been repeatably demonstrated. Exit gas yields of about 100 Btu/SCF and 6 - 8 vol% hydrogen content were recorded although exit gas temperatures (<600°F) were well below original target values of 1500°F.

Preliminary Results Corrected For High-Bypass Air Flow (Runs #18 - #26)

The next nine tests (Runs #18 - #26) were all conducted using high-reactivity western lignite coals or bituminous chars at 2000 and 3000 psi operating pressure. Inlet air flow rates were varied from 0.025 to 0.055 lbm/sec and water flow rates from zero to 0.04 lbm/sec. Figure 11 compares the reaction rates at different bed depths for these tests.

Figure 11. Gasification Reaction Rates vs Coal Bed Depth

While reaction rates were quite variable during and among tests, they were within the target range of 1000 to 6350 lbm/ft²-hr (lbm of coal per gasifier square foot cross sectional area per hour).

Figure 12. Fuel Processor Rig Test Data - Run #26

An example of test data, at 3000 psi operating pressure and no water injection, is shown in Figure 12. The maximum canister wall temperature rose to 2281°F at 230 seconds when nitrogen was injected to quench the gasification reactions and limit canister wall temperatures. The maximum canister wall temperature had propagated down the coal bed to a depth of 22 inches.

This reaction propagation rate is within the target range (1000 to 6350 lbm/ft²-hr). Exit gas heating values varied from 28 to 64 Btu/SCF. The exit gas stream from which these samples were taken was diluted with nitrogen that bypassed the test section, e.g., rig modifications to seal off bypass flow had not yet been incorporated. Some of the nitrogen precharge gas from the pressure vessel jacket flowed into the exit gas downstream of the filters due to thermal expansion. Corrected heating values ("HV_{corr}" in Figure 12) were estimated based on calculated dilution flow due to thermal expansion and were found to be near the target of 100 Btu/SCF.

Water Injection, Hot Gas Sampling & Ash Collection Efficiency (Runs #27 - #44)

The next 18 tests consisted of experimenting with alternative water injector and canister bottom seal configurations, collecting hot gas samples with which to specify reformulation of the synthetic coal gas for the combustion rig, assessing particulate capture efficiency and shakedown testing of the second reactor pressure vessel (Unit #2). Proximate and ultimate analyses of the subbituminous coals used in these tests are documented in Table 5.

Table 5. Unprocessed Subbituminous Coal Analysis

	<u>Decker</u>		<u>Usibelli</u>	
	As Rec'd	Dry	As Rec'd	Dry
PROXIMATE ANALYSIS, %				
Moisture	17.66	0.00	25.95	0.00
Ash	4.61	5.60	8.60	11.61
Volatiles	33.08	40.18	35.39	47.79
Fixed Carbon	44.65	54.22	30.06	40.60
ULTIMATE ANALYSIS, %				
Moisture	17.66	0.00	25.95	0.00
Carbon	57.51	69.84	45.52	61.47
Hydrogen	4.07	4.95	3.44	4.64
Nitrogen	0.09	1.04	0.61	0.82
Sulfur	0.04	0.44	0.24	0.32
Oxygen (diff)	14.93	18.13	15.64	21.14
Ash	4.61	5.60	8.60	11.61
HEATING VALUE	10117	12286	7874	10633
Btu/lb				

Incorporation of the canister bottom seal reduced the total flow volume by 90%. This magnitude of reduction in flow volume destabilized control of the air flow rate due to amplification of the feedback (pressure spikes) from the outlet pressure-control valves to the inlet air-flow control valves. Several tests were required to check out the pressure-control valves, sized to produce lower pressure fluctuations, at the significantly lowered flow rate levels.

Hot gas samples were taken from Run #29 (Figure 13) to get an indication of the percentage light hydrocarbons to be expected in the exit gas stream. The samples (gas + liquid) were taken in a high-pressure metal container at 125 seconds after reaction start and allowed to cool to room temperature prior to analysis.

The sample bottle contained about 250 cc of liquids in addition to coal gas. The liquids consisted of 93.50 wt% water and 6.48 wt% liquid oils as determined by centrifuging. The liquid oil consisted of 42 vol% light hydrocarbons with carbon numbers from C5 to C10. The remaining 58 vol% consisted of heavier hydrocarbons with carbon numbers greater than C10.

Further analysis of the room temperature volatiles (C2 - C4) and liquids (C5 - C10) indicated that at up to 450°F the exit gas stream would contain 1.3 vol% volatile light hydrocarbons. Based on this finding, the composition of the combustion rig synthetic coal gas fuel was reformulated.

Figure 13. Fuel Processor Rig Test Data - Run #29

A preliminary estimate of particulate capture efficiency by the granular bed and ceramic filters was attempted by analyzing the residue (ash & sand) remaining in the canister above the ceramic filter in a test (Run #32) where all the coal was consumed. As shown in Table 6, the net ash collected (143.7 g) exceeded the calculated ash content (132.0 g) of the unprocessed Usibelli coal by 9%. The calculated ash content was based on the proximate analysis of the Usibelli coal (Table 5).

It was encouraging to note that a high collection efficiency was indicated. The result, being greater than 100%, was likely due to an increase in moisture content of the test coal vs the coal sample used for the proximate analysis since the moisture content of the test coal was not a controlled parameter.

Table 6. Ash Collection Efficiency - Run #32

• Coal Charge:	1535.3 g	----->	Ash: 132.0 g
			Moisture: 398.4 g
			Organics: <u>1004.9 g</u>
			1535.3 g
• Ash/Slag Collected	79.2 g		
+ Fused Sand & Ash	+204.5 g		
+ Non-Fused Sand	+320.4 g		
- Sand Bed Charge	<u>-460.4 g</u>		
Net Ash Collected:	143.7 g		
• Ash Collection Efficiency:	143.7 + 132.0	>	100 %

Reaction Transfer & Minimum Air Flow (Runs #45 - #49)

A second fuel processor pressure vessel (Unit #2) was installed in series with (and downstream of) Unit #1. This arrangement was tested to demonstrate the feasibility of transferring the gasification reactions between units without the need for a supplemental ignition source. Usibelli subbituminous coal was used in both units.

Gasification reactions were indeed transferred between units without incident and the rate of propagation of the reaction front through Unit #2 was stable and varied uniformly from 657 to 946 lbm/ft²-hr during the test. Exit gas compositions and heating values are shown in Table 7.

The first two samples were taken while the reaction front was within Unit #1. The last four were taken while the front was within Unit #2. Comparing sample #1 with samples #4 and #5 indicates that the gasification processes occurring within both units produce very nearly the same results. Based on this conclusion, the remaining fuel processor rig tests were conducted using a single reactor pressure vessel unit.

Table 7. Gas Compositions & Heating Values - Run #45 (Two Units in Series)

Sample #	1	2	3	4	5	6
Gas Comp., vol%						
O ₂	4.12	13.04	2.55	3.42	4.61	2.40
N ₂	62.29	79.69	68.30	60.73	67.97	74.32
H ₂	2.46	---	0.84	3.88	0.68	---
CH ₄	4.87	0.84	2.14	4.78	4.08	3.82
CO	13.50	4.24	19.27	14.99	11.13	10.06
CO ₂	12.76	2.19	6.90	12.20	11.53	9.40
Heating Value	101	22	86	109	79	71
HHV, Btu/SCF						

Four tests were conducted to identify the lowest inlet air flow rate that would sustain continuous gasification. A minimum inlet air flow rate of 0.0075 lbm/sec was achieved (Run #49) with a resulting gasification rate of 195 lbm/ft²-hr. Gasification rates at these conditions, together with the highest practical gasification rates demonstrated to date, indicate that fuel processor turndown ratios in the target range (1:10) are feasible.

Sulfur Capture, Particulate Analysis & Final Test Results (Runs #50 - #69)

The remaining tests dealt with demonstrating in-bed sulfur capture, analysis of exit gas stream particulates and documenting the effects of coal type, coal particle size, air flow rate and operating pressure on gasification reaction rates.

Two tests (Runs #54 & #56) were conducted using a bituminous coal from the Peach Orchard seam in the Licking River district of Eastern Kentucky. This coal has twice the sulfur content and higher caking and swelling characteristics than the previously tested subbituminous coals. Run #54 was the baseline high-sulfur test for comparison with Run #56 which contained in-bed sulfur sorbents.

Run #54, without sulfur sorbent, suffered an increase in pressure across the bed ("plugged up") with about two-thirds of the coal charge remaining. Run #56, with 10% by weight of sulfur sorbent (CaCO₃), ran to completion with no evidence of plugging. Analysis of the exit gas sample gas chromatograph data indicated that the in-bed sulfur sorbent reduced the bituminous coal exit gas sulfur content (H₂S + COS + SO₂) by 77% from 1651 ppm to 386 ppm.

Adding 10% CaCO₃ to the bituminous coal charge raised its calcium carbonate content to about the same level as the calcium carbonate content of the subbituminous coals. The CaCO₃ apparently served as a combustion catalyst and a tar-formation deterrent, inhibiting caking and swelling in both coal types under high-pressure gasification conditions, thereby allowing Run #56 to run to completion.

A tar/particulate trap was added at the exit of the reactor vessel to 1.) collect coal oils and tars from the exit gas that did not show up in the cooled exit-gas sampling system and 2.) collect particulates (ash) not captured by the in-bed granular filter. This hot-sample trap percolates the exit gas up through an eight-inch column (=1000 grams) of methylene chloride (CH₂Cl₂) and is located just downstream of the reactor vessel.

Black Butte subbituminous coal was gasified at 368 lbm/ft²-hr with an air flow rate of 0.015 lbm/sec and water injection rate of 0.008 lbm/sec. All the exit gas was directed through the trap from which coal oils, tars and particulates were separated. The mass balance in Table 8 indicates that some of the water and/or methylene chloride were not accounted for.

Table 8. Particulate Trap Mass Balance

	Liquid In		Liquid Out
Water Injected	472 g	Tar & Heavy Oil Products	40 g
CH ₂ Cl ₂	1058 g	CH ₂ Cl ₂ + H ₂ O + Water-soluble	1534 g
Coal Moisture	<u>215 g</u>	Products	<u>1574 g</u>
	1745 g		

The tars and heavy oils collected were about 3.4 wt% of the original coal organics. If the exit gas stream can be maintained above 450°F all the way to the engine, this component would contribute significantly to the overall quality of the coal gas fuel.

The water-soluble products were mainly phenolic compounds with trace amounts of soluble minerals. A total of 0.0531 g of particulates were collected which corresponds to 10.7 ppm mass loading in the gas stream which is low and encouraging.

Maximum particle size was expected to be about 50 microns. Particle analysis indicates that about 50% were larger than expected with 1.72% being larger than 400 microns. Particles larger than 100 microns may be bypassing the ceramic filter and/or particulate agglomeration may have occurred during separation.

Three tests were conducted using different particle size (6x16, 16x40 & 30x60 mesh) Black Butte subbituminous coal all at the same 0.007 lbm/sec inlet air flow rate and 3000 psi operating pressure. Gasification reaction rates varied less than 4% (227 to 235 lbm/ft²-hr) among the tests. Reaction rates from two tests on Belle Ayr subbituminous coal (6x16 & 16x40 mesh) at the same operating conditions varied less than 6% (332 to 351 lbm/ft²-hr). These results indicate that high pressure gasification rates are not sensitive to coal particle size in the size range and at the operating conditions tested.

Gasification reaction rates were, however, sensitive to coal type, inlet air flow rate and operating pressure (Figure 14).

Figure 14. Gasification Reaction Rate vs Inlet Air Flow Rate

Only the higher reactivity Belle Ayr subbituminous coal at 0.020 lbm/sec inlet air flow rate yielded a gasification reaction rate greater than the target rate of 1000 lbm/ft²-hr without water injection. The lowest gasification reaction rate for this coal (332 lbm/ft²-hr) at the minimum inlet air flow rate (0.0075 lbm/sec) was 25% of the maximum rate (1314 lbm/ft²-hr). This indicates that a turndown ratio of at least 1:4 is feasible without water injection. A greater turndown ratio will be required for transient load applications such as locomotives. This should be achievable with further refinement of the atomizing water injector concept that produced promising results in prior tests.

One test conducted at reduced operating pressure (2000 psi) on the Black Butte subbituminous coal at 0.015 lbm/sec inlet air flow rate had a gasification reaction rate 62% greater (986 vs 610 lbm/ft²-hr) than at 3000 psi operating pressure.

Post Test Analysis

Early in the test program an attempt was made to correlate available test data with a computer model that characterized reacting flows through packed beds.⁴ A simulation was needed to help guide the test program, aid in developing a fundamental understanding of the processes occurring within the high pressure gasifier, possibly providing guidance in configuring the second reactor vessel and for improving the representation of the fuel processor in the overall system simulation model.

Initial results from the model predicted the observed correlation between air flow rate and gasification rate and that water injection reduced peak coal bed temperatures. The model, however, had no provision for moisture and volatiles content of the raw coal, hence, the effect of drying and devolatilization on gasification rate was not simulated. As a consequence, the model predicted zero hydrogen and methane in the exit gas (1-3 vol% were measured), overpredicted CO and CO₂ (by 60 to 300%) and proved to be relatively insensitive to operating pressure.

As an alternative, Dr. Stephen Niksa of Stanford Univ. was contracted⁵ to examine the measured exit gas compositions and thermal histories from the test rig for insights into the rate-controlling mechanisms of the coal gasification processes occurring within the reactor pressure vessel. The impact of reaction time, coal type and air flow rate on the product distributions were analyzed.⁶ Databases and findings from the coal pyrolysis and combustion literature were surveyed.⁷ The relative importance of devolatilization and secondary volatiles pyrolysis, char oxidation, partial thermochemical equilibrium and finite-rate oxidation in the gas phase were established.⁸ The basis for a comprehensive process model to guide the design and scale-up of the gasifier, and selection of its optimal operating conditions, was identified.⁹

⁴ Thorsness, C.B., & Kang, S., A General Purpose, Packed-Bed Model for Analysis of Underground Coal Gasification Processes, April 25, 1986, DOE Contract W-7405-Eng-48.

⁵ Niksa, S., An Executive Summary Of Consulting Studies, October 8, 1992.

⁶ Niksa, S., Interim Report No. 1, Process Trends In The Available Reactor Test Rig Data, May 30, 1991.

⁷ Niksa, S., Interim Report No. 2, Initial Product Compositions From Coal Devolatilization In The Test Rig, August, 31, 1991.

⁸ Niksa, S., Interim Report No. 3, Product Compositions Based On Thermochemical Equilibrium In The Test Rig, March 27, 1992.

⁹ Niksa, S., Interim Report No. 4, A Rationale For Air Flowrate Effects, September 30, 1992.

Product compositions from the test rig varied with time. Their trends are best seen by converting the measured product distributions to an oxygen-nitrogen-free basis. For all three fuel types (Decker & Usibelli subbituminous coal and bituminous coal char) and at all air flow rates, CH₄ (Figure 15) and H₂ (Figure 16) levels decayed continuously throughout the process. Whole coals expel nearly twice the CH₄ as char early in the run, while the initial H₂ level in the char products is 20% higher than in the whole coal products.

Figure 15. Methane Concentration vs Exit Gas Sampling Time

Figure 16. Hydrogen Concentration vs Exit Gas Sampling Time

Carbon Monoxide and CO₂ levels (Figure 17) always changed inversely, with CO becoming more abundant as the run proceeded. Initially, CO₂ levels from whole coals were double those from char and the CO levels from whole coals were lower by a corresponding amount. During the last half of a burn the product compositions from subbituminous and bituminous coals as well as char become indistinguishable.

Figure 17. CO & CO₂ Concentrations vs Exit Gas Sampling Time

Increasing air flow rate did not change the initial level of CH₄ but did increase the levels of H₂ and CO, and lowered CO₂ levels. During the first 50-100 seconds the time scales for the decay of CH₄ and H₂ levels and the predomination of CO also decreased in rough proportion to increases in air flow rates.

Oxygen levels in the products always remained significant and rarely represented less than 5% of the O₂ in the inlet air stream.

These trends indicated that the products are generated in a large distribution reaction zone that has segments of four chemical processes: char combustion, char graphitization and secondary pyrolysis, coal devolatilization, and coal drying. Observed product distributions show that the elemental composition of the gas phase changes with time, implying that fuel consumed late in a run is substantially different than what is consumed initially.

During the first half of a run, all four chemical processes occur simultaneously. As the vitiated air stream moves through the bed it picks up CO and CO₂ in the char oxidation zone; H₂ and CO in the char graphitization section and CH₄, H₂ and CO in the secondary pyrolysis section; CH₄, H₂, H₂O, CO and CO₂ in the devolatilization section; and more H₂O in the drying section.

Product distributions for both primary devolatilization and secondary pyrolysis are available in the literature for many coal samples, including those which closely match all samples used in these experiments. Although no data has been reported for pressures close to 3000 psi, the products of atmospheric pyrolysis are reliably adjusted for the higher pressure by (1) assuming the CH₄ yield equals the sum of the observed amounts of CH₄, C₂- and C₃-hydrocarbons, plus oils; (2) basing the yields of secondary pyrolysis products on complete conversion of the oxygen in tar to CO and by equally apportioning the hydrogen in tar into CH₄ and H₂; and (3) basing the yields of char graphitization products on complete conversion of the hydrogen and oxygen in char into H₂ and CO, respectively.

Carbon monoxide is the only product of char oxidation at temperatures higher than 2000°F, while substantial amounts of CO₂ are expelled from cooler burn fronts. Maximum measured temperatures often exceed 2200°F for air flow rates of 0.015 lbm/sec and higher but stay much cooler than 1900°F at 0.007 lbm/sec. Conditions in burn fronts for the test rig database therefore span the entire temperature range for the transition from exclusive production of CO₂ to exclusive production of CO. Moreover, these considerations explain why the ultimate proportions of CO and CO₂ vary with air flow rate, and also why CO levels increase throughout any run.

At high air flow rates the heat release rate at the burn front is very high and the temperature in the hot zone quickly becomes hot enough for exclusive CO production. Stronger gas streams also transport more energy downstream allowing products from the burn front to mix with pyrolysis products at temperatures high enough to sustain chemical reactions. The modeling scenario developed for product compositions for 0.03 lbm/sec air flow rates and higher, successfully applied thermochemical equilibrium to mixtures of the oxidation and pyrolysis products.

The mixtures for the equilibrium calculations consisted of the products of primary devolatilization, with no additional H₂ from secondary pyrolysis, and an additional amount of CO based on complete conversion of the O₂ in air via char combustion. The predicted and observed level of all products agreed at about 1700°F for whole coals. Consequently, the abundance of CO in the products from higher air flow rates is attributed to the exclusive production of CO in hot combustion zones.

At low air flow rates, energy release rates at the burn fronts are relatively low and the burn fronts are cool enough that CO₂ is the primary char oxidation product. Slower gas streams also quickly cool to the local bed temperatures as they move downstream so that chemistry among oxidation and pyrolysis products is not as likely as in the hotter beds associated with higher air flow rates.

The situation for lower air flow rates is actually more complicated than for higher air flow rates because the pyrolytic processes and char oxidation make similar contributions. Strictly speaking, governing differential equations for all of the finite-rate chemical and transport processes should be solved to determine these contributions. Instead, the total molar evolution rate of all products was inferred from the measured O₂ and N₂ levels under the assumption that the product evolution rate from char oxidation is determined by the difference between the inlet air flow rate and the rate of efflux of residual O₂. The relative contributions from char oxidation and all pyrolytic processes were inferred from the sum of the measured CO and CO₂ levels.

The analysis accurately predicts the trends for air flow rate variations from 0.007 to 0.020 lbm/sec and the correlations were good for CO and CH₄ (Figures 18 & 19).

Figure 18. Predicted vs Measured CO

Figure 19. Predicted vs Measured CH₄

The predicted vs measured correlations were not as good for CO₂ levels (Figure 20) or H₂ levels (Figure 21) over the same air flow rate range. These discrepancies probably indicate that the inlet air utilized is consumed by char oxidation as well as combustion of some of the pyrolytic products and not solely by char oxidation as assumed in the analysis.

Figure 20. Predicted vs Measured CO₂

Figure 21. Predicted vs Measured H₂

The analytical model clarified the influences of several operating conditions including air flow rates, operating pressures and water injection. They also demonstrated that real-gas effects associated with high pressures are not responsible for any of the features in the measured product distributions.

At high air flow rates CO is the major char oxidation product and the gaseous products are in thermochemical equilibrium. High pressure operation yields substantial amounts of CH₄ and additional H₂ and CO from secondary pyrolysis. At least for high air flow rates where thermochemical equilibrium is applicable, the calculations indicate that adding water diminishes CH₄ and H₂ levels at all temperatures and counteracts the benefits of elevated pressures.

However, the products of virtually any hydrocarbon mixture are in water-gas shift equilibrium above 2300°F and shift equilibrium is independent of pressure. Consequently, to reap the additional components produced at high pressures, the products must be kept at a temperature much cooler than 2300°F. Lowering air flow rate will keep the product stream cool but will also lower burn front temperatures, eventually to the point of exclusive CO₂ production. Raising air flow rates enhances heating values as more CO is produced but eventually the stream becomes hot enough to counteract the benefits of high pressure operation.

Clearly there is a rather narrow temperature window for maximum heating value of the products, constrained by an abundance of CO₂ from the cool burn fronts for low air flow rates, and by water gas shift equilibrium at the hot burn fronts for high air flow rates.

The choice of coal type is most important at low air flow rates where pyrolysis products largely determine the heating value of the products because char oxidation produces so much CO₂. At high air flow rates the equilibrium of the products of oxidation and pyrolysis mitigates the impact of the variable elemental compositions of the pyrolysis products from different coal types. Swelling and agglomeration tendencies are likely to be more important concerns to guide the choice of fuel.

Conclusions - Fuel Processor Feasibility

1. Proof-of-Principle rig tests of the proposed concept have demonstrated that 3000 psi gasification of selected run-of-the-mine coals in batch-loaded fuel processors is feasible.
2. Gasification reactions can be transferred between processors without the need for supplemental ignition sources.
3. In-bed sulfur and particulate capture, though far from being fully developed, show promise as means to circumvent the need for costly and bulky external hot gas cleanup devices.
4. The atomizing water injector, used in these tests to control burn front temperatures at air flow rates >0.02 lbm/sec, needs further refinement to minimize non-uniform burning across the coal combustion zone which promotes canister distortion.
5. Heating values of exit gas from three subbituminous and one bituminous coal type are primarily controlled by inlet air flow rates.
6. Target reaction rates (>1000 lbm/ft²-hr) were achieved at 0.02 lbm/sec air flow rate on Belle Ayr subbituminous coal without water injection.

END

DATE
FILMED

6 / 30 / 93