MATERIALS COMPATIBILITY AND LUBRICANTS RESEARCH ON CFC-REFRIGERANT SUBSTITUTES

THERMOPHYSICAL PROPERTIES

Quarterly Report

1 January 1992 - 31 March 1992

Richard F. Kayser

Thermophysics Division
Building 221, Room A105
National Institute of Standards and Technology
Gaithersburg, Maryland 20899

April 1992

Prepared for
The Air-Conditioning and Refrigeration Technology Institute

This research project is supported, in whole or in part, by U.S. Department of Energy grant number DE-FO02-91CE23810: Materials Compatibility and Lubricants Research (MCLR) on CFC-Refrigerant Substitutes. Federal funding supporting this project constitutes 93.94% of allowable costs. Funding from non-government sources supporting this project consists of direct cost sharing of 6.06% of allowable costs; and in-kind contributions from the air-conditioning and refrigeration industry.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

The U.S. Department of Energy and the air-conditioning industry support for the Materials Compatibility and Lubricants Research (MCLR) program does not constitute an endorsement by the U.S. Department of Energy, nor by the air-conditioning and refrigeration industry, of the views expressed herein.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Department of Energy, nor the Air Conditioning and Refrigeration Technology Institute, nor any of their employees, nor of any of their contractors, subcontractors, or their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed or represents that its use would not infringe privately-owned rights.

THERMOPHYSICAL PROPERTIES

ABSTRACT

Numerous fluids have been identified as promising alternative refrigerants, but much of the information needed to predict their behavior as pure fluids and as components in mixtures does not exist. In particular, reliable thermophysical properties data and models are needed to predict the performance of the new refrigerants in heating and cooling equipment, and to design and optimize equipment to be reliable and energy efficient. The objective of this project is to provide highly accurate, selected thermophysical properties data for Refrigerants 32, 123, 124, and 125, and to use these data to fit simple and complex equations of state and detailed transport property models. The new data will fill in the gaps in the existing data sets and resolve the problems and uncertainties that exist in and between the data sets. This report describes the progress made during the first quarter of this fifteen-month project, which was initiated in late January, 1992.

SCOPE

This project will involve selected measurements of the thermodynamic properties of R-32, R-124, and R-125, and the development of high-accuracy modified Benedict-Webb-Rubin (MBWR) equations of state and improved Carnahan-Starling-DeSantis (CSD) equations of state for each fluid. It will also include selected measurements of the transport properties of R-32 (viscosity and thermal conductivity) and R-123 (thermal conductivity), and the development of detailed correlations for same. The experimental thermodynamic measurements will include, as appropriate, accurate determinations of the critical temperature, pressure, and density; vapor pressures and saturated liquid densities; ideal-gas heat capacity from measurements of the vapor-phase speed of sound; the PVT behavior in the superheated vapor region; the PVT behavior of the compressed liquid; and selected measurements of the liquid-phase heat capacity. The experimental transport measurements will cover the one-phase and saturated liquid and vapor states over the temperature range of interest. The measurements during this quarter have focused mostly on the PVT behavior and vapor pressure of R-32, the speed of sound of R-124, and the thermal conductivity of R-123.

SIGNIFICANT RESULTS

R-32

The Burnett apparatus is being used in the isochoric mode to determine the PVT relation for the vapor phase. Four isochores have been completed spanning the ranges 0-100°C and 0.5 to 5.5 MPa. A Burnett expansion was completed at 100°C and the virial coefficients of R-32 were estimated at 100°C from these data. Based on previous experience for other fluids, it should be possible to determine the vapor densities to within $\pm 0.05\%$.

The Burnett apparatus was used to redetermine the vapor pressure of R-32 in the range 280 to 350 K with a precision of 0.01%. (See Figure 1.) A comparative ebulliometer was used to

measure the vapor pressures at low temperatures (208 K to 236 K corresponding to pressures in the range 49 to 214 kPa). The standard deviation of the data is 0.03%. (See Figure 1.) At the lowest temperatures, the vapor pressures are 0.2% below those measured by Malbrunot, et al. The discrepancy is consistent with a small amount of air in Malbrunot's sample.

The vibrating tube densimeter was used to determine the PVT relation for the liquid phase. The data span the ranges -29 to 98°C and 1600 to 7000 kPa. The data were fitted to polynomial functions of temperature and density and extrapolated to the vapor pressure to obtain the density of the saturated liquid. Previous experience with this procedure indicates that the accuracy of the density data is $\pm 0.05\%$, or better. (Funded by non-ARTI sources.)

An optical cell containing four capillary tubes and a prism was used to measure the capillary rise and refractive index of both the liquid and vapor phases as functions of temperature at the vapor pressure. From these data, the critical temperature was found to be $(351.37 \pm 0.02)\text{K}$, in excellent agreement with Malbrunot, et al.'s value of $(351.55 \pm 0.20)\text{K}$. The critical density was found to be $(419 \pm 7)\text{kg/m}^3$, which is slightly lower than Malbrunot's value of $(429.6 \pm 1.2)\text{kg/m}^3$. (Funded by non-ARTI sources.)

A capacitance cell was used to determine the dielectric constant of the vapor phase as a function of temperature and density. The data were combined with the refractive index data to determine the dipole moment and the molecular polarizability of R-32. (Funded by non-ARTI sources.)

In connection with another contract, a Carnahan-Starling-DeSantis-Morrison (CSDM) equation of state was developed to simultaneously fit data for the vapor pressure and the liquid density, and to take into account explicitly the effects of the dipole moment. This equation will be the basis for a future version of REFPROP that will be suitable for blends of very polar fluids such as R-32 + R-134a.

R-124

The optical cell was used to measure the critical temperature; however, the critical density has not yet been determined.

The vibrating tube densimeter was used to determine the PVT relation for the liquid phase. The data span the ranges 2 to 95°C and 400 to 6500 kPa. The data were fitted to polynomial functions of temperature and density and extrapolated to the vapor pressure to obtain the density of the saturated liquid. (Funded by non-ARTI sources.)

A resonance technique was used to measure the vapor-phase speed of sound. It was necessary to modify the apparatus substantially to prevent condensation of the sample at cold spots in the gas manifold used to control the sample's pressure in the resonator. The speed-of-sound measurements span the temperature range 250 to 400 K and the pressure range from 20 to 900 kPa or 85% of the vapor pressure, whichever is less. The data have a precision of 0.005%. A detailed analysis is in progress. The ideal gas heat capacity has already been determined and expressed as a polynomial function of the temperature.

As in the case of R-32, the dielectric constant, permanent dipole moment, and molecular polarizability were determined from measurements of the refractive index and dielectric constant as a function of pressure and temperature in the vapor phase. (Funded by non-ARTI sources.)

R-125

The vibrating tube densimeter was used to determine the PVT relation for the liquid phase. The data span the ranges 2 to 96°C and 1600 to 6500 kPa. The data were fitted to polynomial functions of temperature and density and extrapolated to the vapor pressure to obtain the density of the saturated liquid. The accuracy of the density data is $\pm 0.05\%$, except in the immediate vicinity of the critical point. A preliminary modified Benedict-Webb-Rubin (MBWR) equation of state was fit to the limited data available. A manuscript describing these results has been submitted to an archival journal. (Funded by non-ARTI sources.)

As in the case of R-32 and R-124, the dielectric constant, permanent dipole moment, and molecular polarizability were determined from measurements of the refractive index and dielectric constant as a function of pressure and temperature in the vapor phase. (Funded by non-ARTI sources.)

Although it is less accurate than the MBWR equation of state mentioned above, the CSDM equation of state was fit to data for the vapor pressure, the saturated liquid density, and the dipole moment. This equation will provide the basis for a future version of REFPROP that will be suitable for blends of polar fluids such as R-125 + R-32.

R-123

The low- and high-temperature transient hot wire thermal conductivity apparatus were used to measure the thermal conductivity of R-123 in the liquid phase at temperatures from 180 to 400 K at pressures from the saturated vapor pressure to 70 MPa. The region of the PVT surface which has been studied thus far is shown in Figure 2. Liquid phase data have been reported for R-123 by Tanaka, et al. [International Journal of Thermophysics (1988)], Yata, et al. [Proceedings of the 2nd Asian Thermophysical Properties Conference (1989)], Fellows, et al. [in Thermal Conductivity 21 (1990)], and Gross, et al. [I.I.F.-I.I.R. Commission B1 (1990)]. For reference, the liquid data available in the literature cover only the region from 260 to 350 K. Two more liquid isotherms at 420 K and 440 K will be attempted for completeness since the critical temperature is near 457 K. Fellows, et al. report vapor data at 0.1 MPa from 305 to 330 K and Gross, et al. report saturated vapor data from 305 to 365 K. The two data sets do not agree well with each other; the Gross, et al. data are lower than the Fellows, et al. data even though the Gross, et al. data are at higher pressure. Figure 3 shows our data for the saturated vapor from 290 to 325 K relative to these other two data sets. It is apparent that our data are in better agreement with the data of Gross et al. (1990). Additional vapor measurements are in progress from 330 K to 440 K in increments of 10 K.

COMPLIANCE WITH AGREEMENT

NIST has complied with all terms of the grant agreement during the first quarter of calendar year

1992 modulo small shifts in the estimated level of effort from one property and/or fluid to another.

PRINCIPAL INVESTIGATOR EFFORT

Dr. Richard F. Kayser is the NIST Principal Investigator for the MCLR program. During the first quarter of calendar year 1992, Dr. Kayser devoted several weeks to planning the project, monitoring the research, and preparing the quarterly report. The project involves multiple researchers and capabilities in Gaithersburg, MD and Boulder, CO.

DISCLAIMER

The U.S. Department of Energy and the air-conditioning industry support for the Materials Compatibility and Lubricants Research (MCLR) program does not constitute an endorsement by the U.S. Department of Energy, nor by the air-conditioning and refrigeration industry, of the views expressed herein.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Department of Energy, nor the Air Conditioning and Refrigeration Technology Institute, nor any of their employees, nor of any of their contractors, subcontractors, or their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed or represents that its use would not infringe privately-owned rights.

1- Kanungo et.al.

□ - Malbrunot + Allied Signal

● - NIST (Ebulliometer)

Figure 1

R123 Thermal Conductivity

Figure 2

R123 Vapor Thermal Conductivity

Figure 3

**DATE
FILMED**

7/17/92