Scoping Heat Transfer Analysis of a Completely-Blocked Type-Q Septifoil (U)

G. P. Flach

December 1991

DISCLAIMER

This document contains information that is proprietary to Westinghouse Savannah River Company, Inc. (WSRC). It is the property of WSRC and is not to be distributed outside of WSRC without the written consent of the Director. This document is not to be used for any purpose other than that for which it was prepared. It is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of WSRC. The information contained herein is not to be used for any purpose other than that for which it was prepared. It is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of WSRC.

Westinghouse Savannah River Company
Savannah River Laboratory
Aiken, SC 29808

Prepared for the U.S. Department of Energy under Contract
DE-AC09-89SR18035

DISCLAIMER

This report was prepared by Westinghouse Savannah River Company (WSRC) for the United States Department of Energy under Contract No. DE-AC09-80SR18035 and is an account of work performed under that contract. Neither the United States Department of Energy, nor WSRC, nor any of their employees makes any warranty, expressed or implied, or assumes any legal liability or responsibility for accuracy, completeness, or usefulness, of any information, apparatus, or product or process disclosed herein or represents that its use will not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trademark, name, manufacturer or otherwise does not necessarily constitute or imply endorsement, recommendation, or favoring of same by WSRC or by the United States Government or any agency thereof. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

WSRC-TR--31-617

DE92 010678

NRTSC
NUCLEAR REACTOR TECHNOLOGY
AND SCIENTIFIC COMPUTATIONS

KEYWORDS: SEPTIFOILS
SAFETY
ANALYSIS
BLOCKAGE

RETENTION: PERMANENT

Scoping Heat Transfer Analysis of a Completely-Blocked
Type-Q Septifoil (U)

by

G. P. Flach

ISSUED: December 1991

J. P. Faraci

1-2-92

Authorized Derivative Classifier

Date

Westinghouse Savannah River Company
Savannah River Laboratory
Aiken, SC 29808

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PROJECT: 91-061-1
DOCUMENT: WSRC-TR-91-617
TITLE: Scoping Heat Transfer Analysis of a Completely-Blocked Type-Q Septifoil (U)
REVISION NUMBER: 0

APPROVALS

T.K. Larson / INEL 12/9/91
T. K. LARSON, TECHNICAL REVIEWER DATE

David A. Crowley 1/2/92
D. A. CROWLEY, NES CODE DEVELOPMENT GROUP MANAGER DATE

A. J. Garrett 1/3/92
A. J. GARRETT, NES MANAGER DATE

Table of Contents

Abstract	1
1 Introduction.....	1
2 Overall heat transfer analysis.....	3
3 Convective heat transfer coefficients.....	7
4 Power/heat flux limiting criteria.....	14
5 Results.....	16
6 Summary.....	47
7 References.....	47
8 Appendix.....	49

Abstract

Heat removal mechanisms for a completely-blocked Type-Q (new design) septifoil situated in an otherwise normally operating K-reactor are investigated in this report. The best-estimate maximum septifoil heat generation rate for a 26.2 °C cooling water inlet temperature is 119 to 141 kW depending on the counter-current flow limitation correlation chosen. The corresponding reactor powers are 648 and 768 MW or 27 and 32% of 2400 MW (historical annual averaged full power). These estimates are based on a steady-state scoping analysis and have a large uncertainty.

1 Introduction

The newly designed Type-Q septifoil is scheduled to be in K-Reactor when restarted. The Type-Q septifoil housing has 12 slots and holes at the poison plate level in contrast to the preceding Type-J housing which has perforations over the entire length (Drwg. ST-MDX5-10072). The new design is intended to enhance septifoil cooling under drained tank conditions. The Type-J septifoil subjected to a complete inlet flow (bottom) blockage in a full reactor tank can dissipate control rod heat generation relatively effectively through natural circulation cooling by the moderator. The Type-Q septifoil precludes natural circulation since the housing is perforated only at the top. This report examines the heat removal mechanisms which are available for cooling a Type-Q septifoil in the event of a complete inlet flow blockage and provides estimates of maximum septifoil heat generation rate.

Figure 1 is an approximate full-scale drawing of a septifoil cross-section. Five rods are shown in place since this is the maximum number which can be present under normal reactor operation. Some rods are full length; the remainder are partial length rods. The web separating the seven subchannels is slotted over its entire length such that roughly half the surface area separating subchannels is open. Figure 2 is a schematic longitudinal view of a Type-Q septifoil in the vicinity of a peripheral control rod and adjacent housing. The control rod actuator system above the reactor plenum contains an approximately 16' long guide tube for each septifoil which guides the actuator gripping mechanism onto the control rod tips. Some of the control rods are drawn up into the guide tube during reactor operation. Hydraulically, the guide tube serves as a standpipe vented to the atmosphere at the top extending several feet above the septifoil housing slots/holes.

Since the slots/holes at the top of the housing are below the liquid level in the tank, liquid boiled off within the housing can be replaced with liquid entering through the slots/holes. Therefore some control rod power can be dissipated through boiling within the housing. The power is directly proportional to the liquid flowrate incoming through the housing slots/holes and draining down the interior of the septifoil. The liquid flowrate is limited by the interfacial shear exerted on the liquid by the rising vapor counter-current flow. This phenomenon is known as a counter-current flow limitation (CCFL). Vapor may escape out the top of the septifoil through the standpipe and/or through the housing slots/holes. Most of vapor will probably escape out the standpipe. Nevertheless, it is prudent to consider the case of all vapor leaving through the slots/holes. In this case, the CCFL may occur below the slots/holes within the septifoil cross-section or at the slots/holes depending on which geometry is more limiting. The septifoil cross-sectional area with 5 rods in place is 0.00278 m² and the slot/hole area is 0.00396 m².

Additional energy can be dissipated from the hot internal fluid (single-phase liquid or steam and liquid) directly through the housing to the colder moderator (full tank). The difference between rod generation and losses to the moderator gives the energy available to vaporize liquid.

Provided the critical heat flux (CHF) is not exceeded anywhere locally, the maximum heat removal capability is the sum of the energies dissipated through boiling at the CCFL condition and convective heat transfer through the housing. Otherwise, the maximum heat removal is limited by critical heat flux. Whether the heat generation rate is limited by CCFL or CHF, the rod temperatures are expected to be sufficiently low (pre-CHF temperatures) that radiation is not an important heat removal mechanism.

Figure 1 Full-scale cross-sectional view of septifoil (approximately to scale).

Figure 2 Schematic illustration of longitudinal geometry and heat removal mechanisms for a completely-blocked, type-Q septifoil.

2 Overall heat transfer analysis

Strong axial power shapes are possible in a septifoil due to the presence of partial length rods (Brown, 1991). A detailed axial heat transfer analysis is necessary to capture the correct heat transfer behavior of a blocked septifoil. Figure 3 illustrates the one-dimensional computational mesh chosen for a steady-state analysis. The septifoil is divided into n_z cells which are generally nonuniform although uniform length cells are shown in Figure 3. All state variables (temperature, void fraction, ...) are defined at the cell centers while superficial velocities are defined at the cell faces or junctions (staggered mesh approach).

Also shown in Figure 3 are the energy inputs to an individual cell. Because the septifoil bottom (face number 0) is completely blocked, the steady-state total mass flowrate across all cell faces is zero. That is, there can be no net mass transfer into a cell and the mass balance for face j is

$$(\rho_g j_g)_j = (\rho_f j_f)_j \quad (1)$$

where

$\rho_k \equiv$ phasic density, $k = g$ or f

$j_g \equiv$ magnitude of upward vapor superficial velocity

$j_f \equiv$ magnitude of downward liquid superficial velocity

The steady-state energy analysis for the j th cell is

$$P_{rod,j} + (A_c \rho_g j_g \hat{h}_{gs})_{j-1} - (A_c \rho_f j_f \hat{h}_f)_{j-1} = P_{mod,j} + (A_c \rho_g j_g \hat{h}_{gs})_j - (A_c \rho_f j_f \hat{h}_f)_j \quad (2)$$

where

$P_{rod,j} \equiv$ cumulative control rod power

$P_{mod,j} \equiv$ power loss to the moderator through the housing

$\hat{h}_{gs} \equiv$ enthalpy of saturated steam at cell face

$\hat{h}_f \equiv$ enthalpy of liquid at cell face

A cell face enthalpy is defined to be the upstream cell center enthalpy (donored property). Constant saturation properties are assumed. Taking into account flow directions, the cell face properties become

$$\hat{h}_{gs,j} = h_{gs,j} = h_{gs} \quad (3)$$

$$\hat{h}_{f,j} = h_{f,j+1} = [h_{fs} - c_{pfs}(T_{sat} - T_f)]_{j+1} = h_{fs} - c_{pfs}(T_{sat} - T_{f,j+1}) \quad (4)$$

where

$h_{gs} \equiv$ saturated gas enthalpy (assumed constant)

$h_{fs} \equiv$ saturated liquid enthalpy (assumed constant)

$c_{pfs} \equiv$ specific heat capacity at saturation (assumed constant)

The moderator power loss is given in terms of the overall heat transfer coefficient, U , by

$$P_{mod,j} = U_j A_{w,j} (T_{f,j} - T_{mod}) \quad (5)$$

where A_w is the septifoil housing surface area and T_{mod} is the moderator temperature. Models for U_j in terms of cell temperatures and flowrates are given below. The energy balance given by equation (2) becomes

$$P_{rod,j} - U_j A_{w,j} (T_{f,j} - T_{mod}) = (A_c \rho_g j_g)_j [h_{fg} + c_{pfs} (T_{sat} - T_{f,j+1})] - (A_c \rho_g j_g)_{j-1} [h_{fg} + c_{pfs} (T_{sat} - T_{f,j})] \quad (6)$$

The unknowns associated with equation (6), which is for the j th cell, are $j_{g,j}$ and $T_{f,j}$. Two solutions are possible corresponding to subcooled liquid and saturated gas-liquid within the j th cell, respectively:

- 1) set $j_{g,j} = 0$ and solve for $T_{f,j}$
- 2) set $T_{f,j} = T_{sat}$ and solve for $j_{g,j}$

Solution 1) is the valid one if $T_{f,j} \leq T_{sat}$; otherwise, solution 2) is valid and $j_{g,j} > 0$. Solution 1) is given by

$$T_{f,j} = \frac{P_{rod,j} + U_j A_{w,j} T_{mod} + (A_c \rho_g j_g)_{j-1} (h_{fg} + c_{pfs} T_{sat})}{U_j A_{w,j} + (A_c \rho_g j_g)_{j-1} c_{pfs}} \quad (7)$$

and solution 2) by

$$j_{g,j} = \frac{P_{rod,j} - U_j A_{w,j} (T_{sat} - T_{mod}) + (A_c \rho_g j_g)_{j-1} h_{fg}}{(A_c \rho_g)_j [h_{fg} + c_{pfs} (T_{sat} - T_{f,j+1})]} \quad (8)$$

Equations (7-8) are solved iteratively using the Gauss-Seidel technique.

Cell rod power, $P_{rod,j}$, is defined through specification of total septifoil power and the relative axial power shape. The overall heat transfer coefficient, U , is defined in terms of an internal heat transfer coefficient, h_{cond} , and an external coefficient, h_{mod} , by

$$U = \frac{1}{\frac{1}{h_{cond}} + \frac{1}{h_{mod}}} \quad (9)$$

where resistance through the thin aluminum housing has been neglected. Models and correlations for h_{cond} and h_{mod} are given in the next section. The septifoil housing temperature T_w is defined by

$$h_{cond} (T_f - T_w) = h_{mod} (T_w - T_{mod}) \quad (10)$$

The moderator temperature T_{mod} is related to the septifoil power through total reactor power. Reactor power is related to septifoil power through the simple proportionality

$$P_{reactor} = R_{power} P_{septifoil} \quad (11)$$

where R_{power} is a constant. Knowing total reactor power and the cold side heat exchanger temperature, T_c , the moderator can be estimated from a heat exchanger analysis (Shadday, 1989). The result is

$$T_{\text{mod}} = T_c + \frac{P_{\text{reactor}}}{\epsilon(mc_p)_c} \quad (12)$$

where

$\epsilon \equiv$ effectiveness

$(mc_p)_c \equiv$ cold side heat capacity rate

The appropriate values for K-reactor are $\epsilon = 0.705 \pm 0.024$ and $(mc_p)_c = 44.11 \pm 0.24$ MW/°C (1.96 standard deviations or 95% confidence). Given the total septifoil power, moderator temperature may be estimated from equations (11) and (12).

Figure 3 Computational mesh for steady-state heat transfer analysis.

3 Convective heat transfer coefficients

As shown in Figure 2 the resistance to heat transfer through the septifoil housing is assumed to be negligible leaving internal and external convection coefficients to be estimated. The Mark-22 hydraulics manual DPSTM-22(H) states that the expected heat transfer coefficient between an USH and the moderator is 1050 BTU/hr-ft²-°F based on reactor operating experience (Boswell, 1974). A rigorous basis for this value is not given or referenced. Therefore, the external heat transfer coefficient will be estimated from handbook correlations/models. The external heat transfer process is assumed to be best modeled as single-phase forced convection through tube banks. Both longitudinal and cross flows are present in the tank moderator space and two corresponding correlations are presented in the following subsection for estimating the average external heat transfer coefficient.

The internal heat transfer process between the saturated gas-liquid mixture and the housing is assumed to occur typically at a zero net mixture mass flowrate comprised of a relatively small downward liquid mass flowrate balanced with an equal upward vapor mass flowrate. The appropriate heat transfer correlation for this flow situation is not clear. Since vigorous bulk boiling is occurring, engineering judgement suggests the internal heat transfer may be large relative to the external convection coefficient. In this case, the resistance is dominated by the external surface and the internal heat transfer coefficient could be assumed to be infinite without appreciable error. This assumption is clearly non-conservative so it is prudent to compute a finite internal heat transfer coefficient instead.

For lack of a better alternative, the internal heat transfer is assumed to be best modeled as a condensation process. The logic for this choice is as follows. When a pure vapor condenses onto a cold vertical surface, a liquid film forms and drains down the surface. Although thin, the condensate film provides a significant heat transfer resistance. Larger heat transfer coefficients are obtained if a significant vapor flow is present such that interfacial shear between the vapor and film is large. In the present blocked septifoil application, the vapor-liquid mixture at saturation temperature is presumably also separated from the relatively cold housing by a thin subcooled liquid layer. Assuming this layer is similar to those encountered in conventional condensing flows motivates estimating the heat transfer coefficient from conventional condensation correlations. Two such correlations are presented in the second subsection.

External heat transfer coefficient (forced flow through tube bank): Figure 4 illustrates the basic flow field in the tank under normal operating conditions. While these data are not for the exact K-Reactor restart charge and are not qualified, they are sufficient for providing qualitative understanding and rough velocity estimates. Observe that individual septifoils may experience a variety of flow patterns from longitudinal flow to crossflow. Of the flow fields for which heat transfer correlations are readily available, flow through tube banks most closely resembles the actual tank flow patterns. Correlations for longitudinal and cross flow through a triangular array of equal-sized tubes are presented below. For the purpose of evaluating these correlations, the USH diameter is chosen as shown in Figure 5 since the majority of the tubes in the reactor tank are USH's.

A series of correlations for crossflow in staggered tube bundles is given in the *Handbook of Single-Phase Convective Heat Transfer* (Kakac et al., 1987, Chap. 6) as

$$Nu = 1.04 Re^{0.4} Pr^{0.36} (Pr/Pr_w)^{0.25} \quad 1 < Re < 5 \times 10^2 \quad (13a)$$

$$Nu = 0.71 Re^{0.5} Pr^{0.36} (Pr/Pr_w)^{0.25} \quad 5 \times 10^2 < Re < 10^3 \quad (13b)$$

$$Nu = 0.35 (X_t^*/X_l^*)^{0.2} Re^{0.6} Pr^{0.36} (Pr/Pr_w)^{0.25} \quad 10^3 < Re < 2 \times 10^5 \quad (13c)$$

$$Nu = 0.031 (X_t^*/X_l^*)^{0.2} Re^{0.8} Pr^{0.36} (Pr/Pr_w)^{0.25} \quad 2 \times 10^5 < Re < 2 \times 10^6 \quad (13d)$$

where

$Nu \equiv$ Nusselt number based on tube diameter, hD/k

$Re \equiv$ Reynolds number based on tube diameter, $\rho u D/\mu$

$Pr \equiv$ Prandtl number

$Pr_w \equiv$ Prandtl number based on properties evaluated at wall temperature

$X_t^* \equiv$ nondimensional transverse distance, X_t/D

$X_l^* \equiv$ nondimensional longitudinal distance, X_l/D

All properties are evaluated at the bulk fluid temperature except Pr_w .

For longitudinal flow through a triangular-array tube bundle the *Handbook of Single-Phase Convective Heat Transfer* (Kakac et al., 1987, Chap. 7) indicates the data can be mainly fit with the following circular tube correlation

$$Nu_t = \frac{f/2 Re Pr}{h_1 + 12.7(f/2)^{1/2} (Pr^{2/3} - 1)} \quad (14)$$

where

$$h_1 = 1.07 + \frac{900}{Re} - \frac{0.63}{1 + 10Pr} \quad (15)$$

$$f = (3.64 \log_{10} Re - 3.28)^{-2} \quad (16)$$

and the Nusselt and Reynolds numbers are based on the infinite triangular-array hydraulic diameter defined by

$$\frac{D_{h,\infty}}{D} = \frac{2\sqrt{3}}{\pi} \left(\frac{P}{D} \right)^2 - 1 \quad (17)$$

In the above expressions

$Nu_t \equiv$ circular tube Nusselt number, $h_t D_{h,\infty}/k$

$Re \equiv$ circular tube Reynolds number, $\rho u D_{h,\infty}/\mu$

$Pr \equiv$ Prandtl number

$f \equiv$ friction factor of a circular pipe

$D \equiv$ tube diameter

$P \equiv$ pitch

All properties are evaluated at the film temperature. The circular tube correlation is valid for $4 \times 10^3 \leq Re \leq 6 \times 10^5$ and $0.7 \leq Pr \leq 5 \times 10^5$. The pitch to diameter ratio from Figure 5 is 1.70. Figure 7.19 of the *Handbook of Single-Phase Convective Heat Transfer* indicates the Nusselt number data is 10 to 20% higher than the circular tube correlation for $P/D = 1.70$. The Handbook presents an equivalent-annulus correction formula which largely captures the increase in Nu over the above circular tube correlation, but, a simple 1.15 multiplier is sufficient considering the scatter in the data:

$$Nu = 1.15 Nu_t \quad (18)$$

In equation (18) both Nusselt numbers are defined in terms of the infinite triangular-array hydraulic diameter $D_{h,\infty}$.

Equations (13) or (18) or a combination actually applies to individual septifoils depending on the core location. For simplicity, the average septifoil heat transfer coefficient is assumed to be the average of the longitudinal and cross flow values

$$h_{mod} = \frac{1}{2}(h_{long} + h_{cross}) \quad (19)$$

where

$h_{mod} \equiv$ external heat transfer coefficient between septifoil housing and moderator

$h_{long} \equiv$ heat transfer coefficient based on longitudinal flow through a tube bundle defined by equation (18)

$h_{cross} \equiv$ heat transfer coefficient based on cross flow through a tube bundle defined by equations (13)

Table I lists values of h_{long} and h_{cross} for the approximate fluid and wall temperatures expected for the present application and various fluid velocities. For the same velocity the cross flow correlation yields a significantly larger value than the longitudinal correlation. However, Figure 4 indicates the average cross flow velocities are lower than the longitudinal velocities so roughly the same heat transfer coefficient is expected throughout the reactor core. The model given by equation (19) and accompanying relations yields a moderator heat transfer coefficient of about 4100 W/m²·°C or 725 BTU/hr-ft²·°F for the case subsequently considered in the Results section. This is significantly lower than the 1050 BTU/hr-ft²·°F value given in the Mark 22 hydraulics manual (DPSTM-22(H)). The reason for the discrepancy is unknown.

This observation at least suggests that the calculated moderator heat transfer coefficient is conservative. Incidentally, while the moderator heat transfer coefficient is critical to this analysis, it typically need not be precisely known. Under normal reactor operating conditions for example, heat transfer to/from the moderator space is only about 1% the size of the assembly heat generation. Forced convection cooling within the assembly is a two orders of magnitude larger effect. This probably explains the lack of emphasis on moderator heat transfer coefficient in the Mark-22 hydraulics manual (Boswell, 1974).

Figure 4 Basic flow pattern in reactor tank moderator space (Carleton, 1959, Figure 7).

Figure 5 Assumed tube bundle geometry for moderator heat transfer coefficient correlations.

Table I Comparison of longitudinal and cross flow heat transfer correlations - D2O, $T_{\text{mod}} = 50^\circ\text{C}$, $T_{\text{wall}} = T_{\text{sat}} @ 1 \text{ atm} + 5 \text{ psig} = 110^\circ\text{C}$.

u_{long} (m/s)	h_{long} (W/m ² -C)	u_{cross} (m/s)	h_{cross} (W/m ² -C)
0.25	1588	0.25	3401
0.50	2846	0.50	5155
0.75	4014	0.75	6575
1.00	5128	1.00	7813

Internal heat transfer coefficient (condensation): The Nusselt equation for the average heat transfer coefficient of a laminar condensate film draining down a vertical plate is (Collier, 1972, pp. 314-317)

$$h_{\text{cond},1} = 0.943 \left[\frac{\rho_f \Delta \rho g h_{fg} k_f^3}{\mu_f L (T_{\text{sat}} - T_w)} \right]^{1/4} \quad (20)$$

where

$h_{\text{cond},1} \equiv$ average heat transfer coefficient

$\rho_f \equiv$ liquid density

$\Delta \rho \equiv$ density difference, $\rho_f - \rho_g$

$h_{fg} \equiv$ latent heat of vaporization

$k_f \equiv$ liquid thermal conductivity

$\mu_f \equiv$ liquid viscosity

$T_{\text{sat}} \equiv$ saturation temperature

$T_w \equiv$ wall temperature

$L \equiv$ vertical length of condensing surface

Properties are evaluated at saturation conditions. The choice of L is not clear for the present application but since it appears to the $1/4$ power in equation (20) the heat transfer coefficient is not very sensitive to L . The septifoil length is chosen for L for lack of a better choice. Equation (20) was developed assuming wall shear balances with the gravitational force.

If the vapor flowrate is high enough, interfacial shear (neglected above) dominates over gravitational and momentum terms. Carpenter and Colburn developed the following model for condensation in a tube with large interfacial shear (Collier, 1972, pp. 323-325):

$$h_{\text{cond},2} = 0.065 \frac{k_f}{\mu_f} (\rho_f \text{Pr}_f \tau_i)^{1/2} \quad (21)$$

Here

$h_{\text{cond},2} \equiv$ average heat transfer coefficient

$k_f \equiv$ liquid thermal conductivity

$\mu_f \equiv$ liquid viscosity

$\rho_f \equiv$ liquid density

$\text{Pr}_f \equiv$ liquid Prandtl number

$\tau_i \equiv$ interfacial shear stress

The interfacial shear stress is modeled as

$$\tau_i = f_i \left[\frac{\rho_g j_g^2}{2} \right] \quad (22)$$

where

$f_i \equiv$ interfacial friction factor

$\rho_g \equiv$ gas density

$j_g \equiv$ gas superficial velocity

For annular flow the interfacial friction factor can be estimated from (Collier, 1972, p. 78)

$$f_i = f_g [1 + 75(1 - \alpha)] \quad (23)$$

where f_g is the single-phase wall friction factor which can be estimated from the Blasius expression

$$f_g = 0.079 \text{Re}_g^{-1/4} \quad (24)$$

The various symbols in equations (23) and (24) are defined as

$\alpha \equiv$ void fraction (gas volume fraction)

$\text{Re}_g \equiv$ gas-phase Reynolds number based on superficial velocity, $\rho_g j_g D_t / \mu_g$

Equation (23) is valid within the approximate range of $0.75 < \alpha < 1$ (annular flow regime). For void fractions less than about 0.75 a dispersed regime is expected. The interfacial shear in a dispersed regime (bubbly, slug, churn-turbulent, ...) is typically much larger than that of separated (annular) flow. A conservative and convenient modification of equation (23) is

$$f_i = f_g \{ 1 + 75 [1 - \max(0.75, \alpha)] \} \quad (25)$$

and will be used in place of equation (23).

Equations (20) and (21) are valid for low and high vapor flowrates, respectively. As is done in RELAP5, equation (20) is treated as a lower bound (Ransom et al., 1985, p. 114) and the final condensation heat transfer coefficient is chosen as the maximum of these correlations:

$$h_{\text{cond}} = \max(h_{\text{cond},1}, h_{\text{cond},2}) \quad (26)$$

4 Power/heat flux limiting criteria

Two phenomena are candidates for limiting the septifoil power. The control rods are assumed to receive insufficient cooling if the local critical heat flux is exceeded on any surface. Secondly, septifoil power is restricted by the counter-current flow limit which must not be exceeded locally in the coolant channel between the rods and housing. Specific criteria for these phenomena are discussed below.

Critical heat flux: Based on an analysis of Taylor and Kelvin-Helmholtz instabilities associated with vapor escaping from a heated surface, Zuber (1959) (Lienhard, 1988) derived the following critical heat flux expression for an upward-facing, horizontal surface freely communicating with a pool of saturated liquid:

$$q_{\text{Zuber}}'' = 0.13 \rho_g h_{fg} \left(\frac{\sigma g \Delta \rho}{\rho_g^2} \right)^{1/4} \quad (27)$$

Various other values for the leading coefficient have been proposed by others to better reflect the data, including 0.16 and 0.18 (Rohsenow et al., 1985). For vertical surfaces, Lienhard and Dhir observed about a 15% reduction in the maximum heat flux given by equation (27) which was geometry insensitive (Lahey et al., 1977; Lienhard et al., 1972):

$$\frac{q_{\text{CHF}}''}{q_{\text{Zuber}}''} = 0.85 \quad (28)$$

The critical heat flux is significantly reduced when a heated surface is in contact with a pool having a significant bulk void fraction. Griffith proposed the following simple approximation to the data (Griffith et al., 1977; Lahey et al., 1977; Walkush et al., 1975)

$$\frac{q_{\text{CHF}}''}{q_{\text{Zuber}}''} = (1 - \alpha) \quad (29)$$

where void fraction is defined to be the fraction of channel volume occupied by gas:

$$\alpha = \frac{V_g}{V_g + V_f} \quad (30)$$

Note that for solid liquid ($\alpha = 0$), correlation (29) does not reduce to equation (28). The data can be correlated more precisely, incorporating equation (28) as a limit, but the exercise is unwarranted since CHF is not expected to be the limiting phenomenon. A CHF limit is not anticipated because the system is under low pressure (large volumetric vapor generation) and the channel dimensions are small; these conditions suggest CCFL will be reached before CHF. Consequently, equation (29) is taken as an upper limit on the local heat flux allowed on any heated surface.

In order to make use of equation (29) the local void fraction $\alpha(z)$ is needed. Since both the gas and liquid superficial velocities are available from the preceding mass and energy balances, a drift-flux model can be used to estimate α . The model is (Zuber and Findlay, 1965)

$$u_g = C_0 j + u_{gj} \quad (31)$$

where

$u_g \equiv$ gas phasic velocity

$j \equiv$ mixture superficial velocity, $j_g + j_f$

$C_0 \equiv$ distribution coefficient

$u_{gj} \equiv$ drift velocity

and j_k , $k = g$ or f , represents the magnitude of the superficial velocity as in the previous section. Solving equation (31) for void fraction yields

$$\alpha(z) = \frac{j_g(z)}{C_0 j_g(z) \left(1 - \frac{\rho_g}{\rho_f} \right) + u_{gj}} \quad (32)$$

For bubbly/churn-turbulent flow in vertical tubes, Ishii (1977) proposed the following expressions for the drift-flux parameters C_0 and u_{gj} :

$$C_0 = 1.2 - 0.2 \left(\frac{\rho_g}{\rho_f} \right)^{1/2} \quad (33)$$

$$u_{gj} = \sqrt{2} \left(\frac{\sigma g \Delta \rho}{\rho_f^2} \right)^{1/4} \quad (34)$$

Equivalent expressions for annular flow will yield higher drift velocities than those from equation (34). Holding superficial gas velocity constant, inspection of equation (32) indicates a lower void fraction is obtained with a higher drift velocity. Equation (34) can therefore be used regardless of flow regime to obtain a conservative critical heat flux

estimate from equation (32). This conservative approach is taken again in anticipation that critical heat flux will not be the limiting phenomenon.

Counter-current flow limitation: The counter-current flow limit (CCFL) is usually estimated from an empirical data correlation. For small pipes, the following Wallis form has proved successful (Whalley, 1987, Chap. 11)

$$|j_g^*|^{1/2} + m |j_f^*|^{1/2} = C \quad (35)$$

where

$$j_k^* \equiv j_k \left(\frac{\rho_k}{\Delta \rho g D_c} \right)^{1/2} \quad (36)$$

and

$j_k \equiv$ superficial velocity of k-phase

$m, C \equiv$ empirical constants

$\rho_k \equiv$ density of k-phase

$\Delta \rho \equiv$ density difference, $\rho_f - \rho_g$

$D_c \equiv$ characteristic dimension

The values of the CCFL parameters depend strongly on geometry. For a circular tube of diameter D , $D_c = D$, $m = 1$ and C is about 0.8 (Whalley, 1987, p. 110). These values are also frequently used as generic values for an arbitrary geometry. For an annular channel, Osakabe and Kawasaki (1989) suggest $D_c = \pi D_{avg}$, $m = 0.8$ and $C = 0.38$. This latter correlation may be more appropriate for channels between the rods and web.

5 Results

The above steady-state heat transfer model has been implemented in the FORTRAN code listed in the Appendix. The worst rod configuration is assumed to be the one with the most rods in place, the highest septifoil to reactor power ratio, and the peak power generation near the top of the septifoil. From the available rod configurations given in Calc-Note SRL-SAG-91-9051, case #8 appears to be the worst. Case #8 is 3 full rods and 2 partial rods at 700 vu. Two sets of computed results are given corresponding to using the Wallis and Osakabe & Kawasaki CCFL correlations, respectively, as the limiting CCFL criterion. The input information is the same for both cases except for septifoil total power. A detailed discussion of the input and computed results is given for the Wallis CCFL correlation case followed by a more brief discussion of the results using the Osakabe and Kawasaki correlation. Finally, two sensitivity runs with respect to the overall heat transfer coefficient are presented.

Results based on Wallis CCFL correlation: The first set of results is based on using the Wallis CCFL correlation with $C = 0.8$ as the limiting criterion. Table II is the code output for the limiting septifoil power of 141 kW. The number of cells, cell lengths,

and total length were chosen for convenience to be compatible with the power shape information given in Calc-Note SRL-SAG-91-9051 (Brown, 1991). The control rod diameter specified is 0.94" while the septifoil housing diameter is set to 3.30" (Drwg. ST-MDX5-10072). The power generation values in SRL-SAG-91-9051 are for 1324 MW reactor power. The total septifoil power for Case #8 is 243 kW. The reactor total power to septifoil power ratio is therefore $1324 \text{ MW} / 243 \text{ kW} = 5449.0$. The power shape and related information given in Table II are based on Figure 2 and the table given on Sheet 24 of SRL-SAG-91-9051. Note the strong 1.85 peak to average axial power shape present. The hydraulic parameters are based on Calc-Note SRL-SAG-910120 (Bornt, 1991). The cooling water temperature was chosen as 26.2 °C which is the maximum temperature recorded from 1985 to 1988 (Mertz, 1990). The system pressure is defined to be +5 psig = 34475 Pa which corresponds to the blanket gas pressure. The septifoil average pressure is expected to be higher so this input is conservative. The longitudinal and cross moderator velocities outside the septifoil housing are assumed to be 3.0 and 1.0 ft/s, respectively (see Figure 4 of this report or Figure 7 of DPST-59-13-6).

The computed results are given in the remainder of Table II and in Figures 6 through 10. The limiting power of 141 kW corresponds to a reactor power of 768 MW or 32% of historical annual-averaged full power (2400 MW). The power is CCFL limited in the septifoil cross-section where the gas superficial velocity is at the threshold of exceeding the limit imposed by equation (35) as shown in Figure 10. Note that the limiting condition does not occur at the exit as one might guess initially. In fact, relatively little net vapor escapes the septifoil housing. Only 4.1 kW out of a total of 141 kW is dissipated through net boiling. Figure 7 indicates the lower portion of septifoil contains subcooled bulk liquid. In the middle portion, the rod power exceeds that which can be dissipated through the housing and boiling occurs. In the top portion where the relative axial power drops sharply, the moderator heat loss exceeds the rod heat generation and nearly all of the vapor rising from the middle section condenses. Figure 8 confirms that critical heat flux is not limiting. Fluid and housing temperatures are shown in Figure 9.

Table II Computed results for septifoil power limited by the Wallis CCFL correlation.

--- INPUT INFORMATION ---

```

      number of cells      nz: 13
      septifoil length    z1(m): 4.328
      control rod diameter drod(m): 0.02388
      housing diameter    dw(m): 0.08382
      septifoil power     sp(kW): 141.0
      reactor/septifoil power ratio rpovsp: 5449.0

```

Cell CENTER input information:

i	dz/z1	zc/z1	pshape	nrodh	pkfac	arod (m ²)	prod (kW)	qrod (kW/m ²)
1	0.1831	0.0916	0.2950	3	1.410	0.17838	7.62	42.69
2	0.0704	0.2183	0.9348	3	1.400	0.06859	9.28	135.32
3	0.0704	0.2887	1.2118	3	1.400	0.06859	12.03	175.41
4	0.0704	0.3592	1.7387	5	1.340	0.11431	17.26	151.01
5	0.0704	0.4296	1.8377	5	1.340	0.11431	18.24	159.61
6	0.0282	0.4789	1.8117	5	1.340	0.04579	7.20	157.35
7	0.0070	0.4965	1.7897	5	1.340	0.01143	1.78	155.44

8	0.0352	0.5176	1.7527	5	1.340	0.05715	8.70	152.23
9	0.0704	0.5704	1.6237	5	1.340	0.11431	16.12	141.02
10	0.0704	0.6408	1.4058	5	1.340	0.11431	13.96	122.09
11	0.0704	0.7113	1.1698	5	1.340	0.11431	11.61	101.60
12	0.0704	0.7817	0.9048	5	1.340	0.11431	8.98	78.59
13	0.1811	0.9084	0.3179	5	2.160	0.29730	8.21	27.61

Cell FACE (JUNCTION) Input Information:

	ac (m ²)	dh (m)	dc (m)	ccflm	ccflc	nrod
1	0.003675	0.0156	0.0156	1.00	0.80	3
2	0.003675	0.0156	0.0156	1.00	0.80	3
3	0.003675	0.0156	0.0156	1.00	0.80	3
4	0.002780	0.0127	0.0127	1.00	0.80	5
5	0.002780	0.0127	0.0127	1.00	0.80	5
6	0.002780	0.0127	0.0127	1.00	0.80	5
7	0.002780	0.0127	0.0127	1.00	0.80	5
8	0.002780	0.0127	0.0127	1.00	0.80	5
9	0.002780	0.0127	0.0127	1.00	0.80	5
10	0.002780	0.0127	0.0127	1.00	0.80	5
11	0.002780	0.0127	0.0127	1.00	0.80	5
12	0.002780	0.0127	0.0127	1.00	0.80	5
13	0.002780	0.0127	0.0127	1.00	0.80	5
slot	0.003960		0.0167	1.00	0.80	

H/X cold-side temp	tcold(C):	26.2
gage pressure at slots	dpres(Pa):	34475.
moderator temp. flag	itmod:	1
temp. if itmod,not.1	tmod3(C):	70.0
moderator h flag	imod:	1
mod. h if imod,not.1	hmod3 (W/m ² -C):	0.0
longitudinal velocity	ulong (m/s):	0.900
cross velocity	ucross (m/s):	0.300
internal h flag	icond:	1
int. h if icond,not.1	hcond3 (W/m ² -C):	0.0
U multiplier	xu:	1.00
reactor power	rp (MW):	768.3
fraction of 2400 MW	(%):	32.0
moderator temperature	tmod (C):	50.9

under-relaxation weight	w:	0.50
maximum number of iterations	icrmax:	300

--- COMPUTED RESULTS ---

HEAVY WATER Properties

pressure	pres(Pa):	135800.
moderator temperature	tmod(K):	324.1
liquid properties @ tmod:		
density	rofm(kg/m ³):	1094.2
enthalpy	hfm(J/kg):	0.199E+06
viscosity	visfm(Pa-s):	0.639E-03
specific heat capacity	cpfm(J/kg-K):	0.421E+04
thermal conductivity	condfm(W/m-K):	0.618E+00
surface tension	sigmam(Pa/m):	0.677E-01
Prandtl number	prfm:	0.435E+01

```

saturation temperature      ts(K): 382.9
                             ts(C): 109.7
heat of vaporization        hfg(J/kg): 0.205E+07
density difference          drhos(kg/m^3): 1055.2
liquid properties @ ts:
  density                   rofs(kg/m^3): 1056.1
  enthalpy                  hfs(J/kg): 0.446E+06
  viscosity                 visfs(Pa-s): 0.296E-03
  specific heat capacity    cpfs(J/kg-K): 0.418E+04
  thermal conductivity      condfs(W/m-K): 0.636E+00
  surface tension           sigmas(Pa/m): 0.569E-01
  Prandtl number            prfs: 0.194E+01
gas properties @ ts:
  density                   rogs(kg/m^3): 0.855E+00
  enthalpy                  hgs(J/kg): 0.249E+07
  viscosity                 visgs(Pa-s): 0.129E-04
  specific heat capacity    cpgs(J/kg-K): 0.177E+04
  thermal conductivity      condgs(W/m-K): 0.248E-01

```

```

distribution parameter      c0: 1.194
drift velocity              ugj(m/s): 0.214

```

```

      septifoil power (kW): 141.0
total losses to moderator (kW): 137.3
m-slot[hgs-hfs+cpfs(Tsat-Tmod)] (kW): 3.7

```

Cell CENTER computed results:

1	prod/dz (kW/m)	pmod/dz (kW/m)	pvap/dz (kW/m)	qrod (kW/m^2)	qpeak (kW/m^2)	qcrit (kW/m^2)	ratio
1	9.61	9.61	0.00	42.69	60.20	1211.92	0.050
2	30.46	27.69	2.76	135.32	189.45	940.57	0.201
3	39.48	27.69	11.79	175.41	245.58	456.59	0.538
4	36.64	29.36	27.29	151.01	202.35	290.08	0.698
5	59.87	37.12	22.75	159.61	213.87	248.27	0.861
6	59.02	40.22	18.80	157.35	210.85	237.23	0.889
7	58.31	41.02	17.28	155.44	208.29	234.74	0.887
8	57.10	41.78	15.32	152.23	203.98	232.50	0.877
9	52.90	43.06	9.84	141.02	188.97	228.96	0.825
10	45.80	43.84	1.96	122.09	163.60	226.97	0.721
11	38.11	43.61	-5.50	101.60	136.14	227.57	0.598
12	29.48	42.34	-12.86	78.59	105.31	230.92	0.456
13	10.36	34.45	-24.09	27.61	59.65	259.90	0.229

1	zc (m)	dz (m)	alp	tf (C)	tw (C)	arod (m^2)
1	0.3963	0.7926	0.0000	72.98	60.46	0.1784
2	0.9450	0.3047	0.2239	109.70	77.19	0.0686
3	1.2497	0.3047	0.6232	109.70	77.19	0.0686
4	1.5544	0.3047	0.7606	109.70	78.67	0.1143
5	1.8592	0.3047	0.7951	109.70	85.49	0.1143
6	2.0726	0.1221	0.8043	109.70	88.17	0.0458
7	2.1488	0.0305	0.8063	109.70	88.86	0.0114
8	2.2403	0.1524	0.8082	109.70	89.51	0.0572
9	2.4688	0.3047	0.8111	109.70	90.61	0.1143
10	2.7736	0.3047	0.8127	109.70	91.28	0.1143
11	3.0783	0.3047	0.8123	109.70	91.09	0.1143
12	3.3830	0.3047	0.8095	109.70	90.00	0.1143
13	3.9317	0.7926	0.7855	109.70	83.16	0.2973
moderator space				50.91		

i	hcond (W/m^2-C)	hmod (W/m^2-C)	u (W/m^2-C)	aw (m^2)	hcond1 (W/m^2-C)	hcond2 (W/m^2-C)	hmod1 (W/m^2-C)	hmod2 (W/m^2-C)
1	2015.6	3818.6	1653.3	0.2087	2915.6	0.0	4400.5	3236.8
2	3234.5	4000.8	1788.5	0.0802	3234.5	200.1	4550.7	3450.9
3	3234.5	4000.8	1788.5	0.0802	3234.5	1243.9	4550.7	3450.9
4	3593.2	4014.9	1896.1	0.0802	3272.5	3593.0	4561.3	3468.6
5	5820.5	4076.1	2137.3	0.0802	3481.7	5820.5	4605.1	3547.1
6	7093.5	4098.6	2597.7	0.0321	3585.5	7093.5	4620.3	3576.9
7	7475.1	4104.2	2649.5	0.0080	3614.9	7475.1	4624.0	3584.4
8	7858.9	4109.5	2698.4	0.0401	3643.7	7858.9	4627.5	3591.5
9	8566.4	4118.3	2781.2	0.0802	3695.0	8566.4	4633.1	3603.4
10	9038.2	4123.6	2831.7	0.0802	3728.1	9038.2	4636.5	3610.6
11	8896.6	4122.0	2816.9	0.0802	3718.3	8896.6	4635.5	3608.5
12	8158.2	4113.4	2734.6	0.0802	3665.7	8158.2	4630.0	3596.7
13	4929.9	4055.9	2225.2	0.2087	3402.9	4929.9	4591.0	3520.8

Cell FACE (JUNCTION) computed results:

i	zf (m)	jg (m/s)	jgcef1 (m/s)	ratio
0	0.0000	0.000	6.440	0.000
1	0.7926	0.000	6.440	0.000
2	1.0973	0.131	6.440	0.020
3	1.4021	0.912	5.811	0.157
4	1.7068	2.622	5.811	0.451
5	2.0115	4.048	5.811	0.697
6	2.1336	4.520	5.811	0.778
7	2.1641	4.628	5.811	0.796
8	2.3165	5.108	5.811	0.879
9	2.6212	5.725	5.811	0.985
10	2.9259	5.847	5.811	1.006
11	3.2307	5.502	5.811	0.947
12	3.5354	4.696	5.811	0.808
13	4.3280	0.687	5.811	0.118
slot	4.3280	0.482	6.663	0.072

Figure 6 Relative linear power density axial profile as a function of relative position.

Figure 7 Linear power generation and dissipation as a function of axial position.

Figure 8 Heat fluxes as a function of axial position.

Figure 9 Internal fluid and housing temperature as a function of axial position.

Figure 10 Gas superficial velocities as a function of axial position.

Results based on Osakabe & Kawasaki CCFL correlation: A lower septifoil power limit is obtained if the Osakabe and Kawasaki correlation for annular flow channels is assumed. Table III indicates the septifoil power limit is 119 kW which corresponds to a reactor power of 648 MW or 27% of historical full power. Similar behavior is observed as for the preceding example as illustrated by Figures 11 through 14. A notable difference is that Figure 14 indicates no vapor exits the septifoil housing at the power limit. Therefore there is no net boiling and no power is dissipated through this mechanism.

Table III Computed results for septifoil power limited by the Osakabe and Kawasaki CCFL correlation.

--- INPUT INFORMATION ---

number of cells	nz: 13
septifoil length	zl(m): 4.328
control rod diameter	drod(m): 0.02388
housing diameter	dw(m): 0.08382
septifoil power	sp(kW): 119.0

reactor/septifoll power ratio rpovsp: 5449.0

Cell CENTER input information:

i	dz/zl	zc/zl	pshape	nrodh	pkfac	arod (m^2)	prod (kW)	qrod (kW/m^2)
1	0.1831	0.0916	0.2950	3	1.410	0.17838	6.43	36.03
2	0.0704	0.2183	0.9348	3	1.400	0.06859	7.83	114.21
3	0.0704	0.2887	1.2118	3	1.400	0.06859	10.15	148.04
4	0.0704	0.3592	1.7387	5	1.340	0.11431	14.57	127.45
5	0.0704	0.4296	1.8377	5	1.340	0.11431	15.40	134.70
6	0.0282	0.4789	1.8117	5	1.340	0.04579	6.08	132.80
7	0.0070	0.4965	1.7897	5	1.340	0.01143	1.50	131.19
8	0.0352	0.5176	1.7527	5	1.340	0.05715	7.34	128.47
9	0.0704	0.5704	1.6237	5	1.340	0.11431	13.61	119.02
10	0.0704	0.6408	1.4058	5	1.340	0.11431	11.78	103.04
11	0.0704	0.7113	1.1698	5	1.340	0.11431	9.80	85.75
12	0.0704	0.7817	0.9048	5	1.340	0.11431	7.58	66.33
13	0.1831	0.9084	0.3179	5	2.160	0.29730	6.93	23.31

Cell FACE (JUNCTION) input information:

i	ac (m^2)	dh (m)	dc (m)	ccflm	ccflc	nrod
0	0.003675	0.0156	0.0850	0.80	0.38	3
1	0.003675	0.0156	0.0850	0.80	0.38	3
2	0.003675	0.0156	0.0850	0.80	0.38	3
3	0.002780	0.0127	0.0850	0.80	0.38	5
4	0.002780	0.0127	0.0850	0.80	0.38	5
5	0.002780	0.0127	0.0850	0.80	0.38	5
6	0.002780	0.0127	0.0850	0.80	0.38	5
7	0.002780	0.0127	0.0850	0.80	0.38	5
8	0.002780	0.0127	0.0850	0.80	0.38	5
9	0.002780	0.0127	0.0850	0.80	0.38	5
10	0.002780	0.0127	0.0850	0.80	0.38	5
11	0.002780	0.0127	0.0850	0.80	0.38	5
12	0.002780	0.0127	0.0850	0.80	0.38	5
13	0.002780	0.0127	0.0850	0.80	0.38	5
slot	0.003960		0.0167	1.00	0.80	

H/X cold-side temp tcold(C): 26.2
gage pressure at slots dpres(Pa): 34475.
moderator temp. flag itmod: 1
temp. if itmod.not.1 tmod3(C): 70.0
moderator h flag imod: 1
mod. h if imod.not.1 hmod3 (W/m^2-C): 0.0
longitudinal velocity ulong (m/s): 0.900
cross velocity ucross (m/s): 0.300
internal h flag lcond: 1
int. h if lcond.not.1 hcond3 (W/m^2-C): 0.0
U multiplier xu: 1.00
reactor power rp (MW): 648.4
fraction of 2400 MW (%): 27.0
moderator temperature tmod (C): 47.1

under-relaxation weight w: 0.50
maximum number of iterations itrmax: 300

--- COMPUTED RESULTS ---

HEAVY WATER Properties

```

pressure                                pres(Pa): 135800.
moderator temperature                   tmod(K): 320.2
liquid properties @ tmod:
  density                               rofm(kg/m^3): 1096.0
  enthalpy                              hfm(J/kg): 0.183E+06
  viscosity                             visfm(Pa-s): 0.685E-03
  specific heat capacity                 cpfm(J/kg-K): 0.421E+04
  thermal conductivity                  condm(W/m-K): 0.615E+00
  surface tension                       sigmam(Pa/m): 0.684E-01
  Prandtl number                        prfm: 0.469E+01

saturation temperature                  ts(K): 382.9
                                          ts(C): 109.7
heat of vaporization                    hfg(J/kg): 0.205E+07
density difference                      drhos(kg/m^3): 1055.2
liquid properties @ ts:
  density                               rofs(kg/m^3): 1056.1
  enthalpy                              hfs(J/kg): 0.446E+06
  viscosity                             visfs(Pa-s): 0.296E-03
  specific heat capacity                 cpfs(J/kg-K): 0.418E+04
  thermal conductivity                  condfs(W/m-K): 0.636E+00
  surface tension                       sigmas(Pa/m): 0.569E-01
  Prandtl number                        prfs: 0.194E+01
gas properties @ ts:
  density                               rogs(kg/m^3): 0.855E+00
  enthalpy                              hgs(J/kg): 0.249E+07
  viscosity                             visgs(Pa-s): 0.129E-04
  specific heat capacity                 cpgs(J/kg-K): 0.177E+04
  thermal conductivity                  condgs(W/m-K): 0.248E-01

distribution parameter                  c0: 1.194
drift velocity                          ugj(m/s): 0.214

      septifoil power (kW): 119.0
      total losses to moderator (kW): 119.0
m-slot[hgs-hfs+cpfs(Tsat-Tmod)] (kW): 0.0

```

Cell CENTER computed results:

i	prod/dz (kW/m)	pmod/dz (kW/m)	pvap/dz (kW/m)	qrod (kW/m^2)	qpeak (kW/m^2)	qcrit (kW/m^2)	ratio
1	8.11	8.11	0.00	36.03	50.81	1211.92	0.042
2	25.70	25.70	0.00	114.21	159.89	1211.92	0.132
3	33.32	29.07	4.25	148.04	207.26	779.66	0.266
4	47.81	29.07	18.74	127.45	170.78	372.98	0.458
5	50.53	32.65	17.87	134.70	180.50	280.04	0.645
6	49.81	36.64	13.17	132.80	177.95	259.15	0.687
7	49.21	37.58	11.63	131.19	175.79	255.07	0.689
8	48.19	38.40	9.79	128.47	172.15	251.69	0.684
9	44.65	39.65	5.00	119.02	159.49	246.94	0.646
10	38.65	40.07	-1.42	103.04	138.08	245.41	0.563
11	32.16	39.07	-6.90	85.75	114.90	249.11	0.461
12	24.88	36.40	-11.52	66.33	88.88	260.28	0.341
13	8.74	23.10	-14.36	23.31	50.34	334.26	0.151

i	zc (m)	dz (m)	alp	tf (C)	tw (C)	arod (m^2)
1	0.3963	0.7926	0.0000	66.15	55.32	0.1784

2	0.9450	0.3047	0.0000	103.29	71.97	0.0686
3	1.0497	0.3047	0.3567	109.70	75.02	0.0686
4	1.5544	0.3047	0.6922	109.70	75.02	0.1143
5	1.9592	0.3047	0.7689	109.70	78.22	0.1143
6	2.0926	0.1271	0.7862	109.70	81.75	0.0458
7	2.1449	0.3335	0.7895	109.70	82.57	0.0114
8	2.1443	0.1524	0.7923	109.70	83.29	0.0572
9	2.1438	0.1547	0.7962	109.70	84.38	0.1143
10	2.1436	0.3047	0.7975	109.70	84.75	0.1143
11	3.1293	0.3147	0.7944	109.70	83.87	0.1143
12	3.3330	0.3047	0.7852	109.70	81.53	0.1143
13	3.9317	0.7926	0.7242	98.17	69.59	0.2973
moderator space				47.05		

	hcond (W/m^2-C)	hmod (W/m^2-C)	u (W/m^2-C)	aw (m^2)	hcond1 (W/m^2-C)	hcond2 (W/m^2-C)	hmod1 (W/m^2-C)	hmod2 (W/m^2-C)
1	2844.1	3724.8	1612.7	0.2087	2844.1	0.0	4284.1	3165.5
2	3116.3	3917.3	1735.6	0.0802	3116.3	0.0	4447.0	3387.5
3	3182.5	3947.7	1762.0	0.0802	3182.5	376.7	4470.3	3425.1
4	3182.5	3947.7	1762.0	0.0802	3182.5	1940.2	4470.3	3425.1
5	3939.2	3978.3	1979.3	0.0802	3260.7	3939.2	4493.0	3463.7
6	4978.4	4010.4	2221.1	0.0321	3359.0	4978.4	4515.9	3505.0
7	5259.9	4017.7	2277.8	0.0080	3384.1	5259.9	4520.9	3514.5
8	5522.3	4024.0	2327.8	0.0401	3407.0	5522.3	4525.2	3522.7
9	5946.3	4033.4	2403.2	0.0802	3443.1	5946.3	4531.6	3535.1
10	6098.4	4036.5	2428.8	0.0802	3455.7	6098.4	4533.7	3539.2
11	5743.6	4029.0	2367.9	0.0802	3426.0	5743.6	4528.7	3529.3
12	4906.2	4008.5	2206.1	0.0802	3352.5	4906.2	4514.5	3502.5
13	3069.0	3892.5	1716.0	0.2087	3069.0	2506.1	4427.5	3357.5

Cell FACE (JUNCTION) computed results:

i	zf (m)	zg (m/s)	zgccfl (m/s)	ratio
0	0.0000	0.000	3.596	0.000
1	0.7926	0.000	3.596	0.000
2	1.0973	0.000	3.596	0.000
3	1.4021	0.266	3.596	0.074
4	1.7068	1.440	3.596	0.401
5	2.0115	2.561	3.596	0.712
6	2.1336	2.891	3.596	0.804
7	2.1641	2.964	3.596	0.824
8	2.3165	3.271	3.596	0.909
9	2.6212	3.584	3.596	0.997
10	2.9259	3.495	3.596	0.972
11	3.2307	3.062	3.596	0.852
12	3.5354	2.287	3.596	0.636
13	4.3280	0.000	3.596	0.000
slot	4.3280	0.000	6.663	0.000

Figure 11 Linear power generation and dissipation as a function of axial position.

Figure 12 Heat fluxes as a function of axial position.

Figure 13 Internal fluid and housing temperature as a function of axial position.

Figure 14 Gas superficial velocities as a function of axial position.

Sensitivity to overall heat transfer coefficient between fluid and moderator: The preceding results indicate the dominant heat removal mechanism is heat transfer through the septifoil housing rather than net boiling. The overall heat transfer coefficient between the internal fluid and the moderator, U , controls heat loss to the moderator. The best-estimate model for U has a significant uncertainty because both h_{mod} and h_{cond} are not well known. To investigate the sensitivity of maximum septifoil heat generation rate to the overall heat transfer coefficient, simulations with U varied $\pm 50\%$ were performed. The Wallis correlation was used to test for a CCFL condition. Tables IV and V present the results for -50% and $+50\%$ variations in U , respectively. These results are plotted in Figures 15 through 22. With the overall heat transfer coefficient reduced by 50% , the predicted maximum septifoil power is 96 kW or 32% lower than the nominal case. For a 50% increase in U , the power increases 16% from nominal to 163 kW .

The physical behavior of both sensitivity simulations is somewhat different from that exhibited by the nominal case. For U reduced by 50% , Table IV indicates that the fraction of energy dissipated through net boiling is significant (15%). Like the nominal case using the Wallis correlation, the maximum heat generation rate is limited by CCFL rather than CHF. For U increased by 50% , Table V shows that all of the septifoil power is dissipated through the housing wall because there is no net boiling. More importantly, the limiting phenomenon has changed from CCFL to CHF. The CHF model discussed in the previous

section uses a conservative value of estimated void fraction so the maximum septifoil power predicted for a 50% increase in U is slightly conservative.

Table IV Computed results for septifoil power limited by the Wallis CCFL correlation and the overall heat transfer coefficient reduced by 50% from nominal.

--- INPUT INFORMATION ---

```

      number of cells      nzi 13
      septifoil length    z1(m): 4.328
      control rod diameter drod(m): 0.02388
      housing diameter    dw(m): 0.08382
      septifoil power     sp(kW): 96.0
      reactor/septifoil power ratio rpvsp: 5449.0

```

Cell CENTER Input Information:

i	dz/z1	zc/z1	pshape	nrodh	pkfac	arod (m^2)	prod (kW)	qrod (kW/m^2)
1	0.1831	0.0916	0.2950	3	1.410	0.17838	5.19	29.07
2	0.0704	0.2183	0.9348	3	1.400	0.06859	6.32	92.13
3	0.0704	0.2887	1.2118	3	1.400	0.06859	8.19	119.43
4	0.0704	0.3592	1.7387	5	1.340	0.11431	11.75	102.82
5	0.0704	0.4296	1.8377	5	1.340	0.11431	12.42	108.67
6	0.0282	0.4789	1.8117	5	1.340	0.04579	4.91	107.13
7	0.0070	0.4965	1.7897	5	1.340	0.01143	1.21	105.83
8	0.0352	0.5176	1.7527	5	1.340	0.05715	5.92	103.64
9	0.0704	0.5704	1.6237	5	1.340	0.11431	10.98	96.02
10	0.0704	0.6408	1.4058	5	1.340	0.11431	9.50	83.13
11	0.0704	0.7113	1.1698	5	1.340	0.11431	7.91	69.17
12	0.0704	0.7817	0.9048	5	1.340	0.11431	6.12	53.51
13	0.1831	0.9084	0.3179	5	2.160	0.29730	5.59	18.80

Cell FACE (JUNCTION) Input Information:

i	ac (m^2)	dh (m)	dc (m)	ccflm	ccflc	nrod
0	0.003675	0.0156	0.0156	1.00	0.80	3
1	0.003675	0.0156	0.0156	1.00	0.80	3
2	0.003675	0.0156	0.0156	1.00	0.80	3
3	0.002780	0.0127	0.0127	1.00	0.80	5
4	0.002780	0.0127	0.0127	1.00	0.80	5
5	0.002780	0.0127	0.0127	1.00	0.80	5
6	0.002780	0.0127	0.0127	1.00	0.80	5
7	0.002780	0.0127	0.0127	1.00	0.80	5
8	0.002780	0.0127	0.0127	1.00	0.80	5
9	0.002780	0.0127	0.0127	1.00	0.80	5
10	0.002780	0.0127	0.0127	1.00	0.80	5
11	0.002780	0.0127	0.0127	1.00	0.80	5
12	0.002780	0.0127	0.0127	1.00	0.80	5
13	0.002780	0.0127	0.0127	1.00	0.80	5
slot	0.003960		0.0167	1.00	0.80	

```

      H/X cold-side temp      tcold(C): 26.2
      gage pressure at slots   dpres(Pa): 34475.
      moderator temp. flag     itmod: 1
      temp. if itmod,not,1     tmod3(C): 70.0
      moderator h flag         lmod: 1

```

```

mod, h if lmod,not,1 hmod3 (W/m^2-C): 0.0
longitudinal velocity along (m/s): 0.900
cross velocity across (m/s): 0.300
internal h flag icond: 1
mod, h if icond,not,1 hcond3 (W/m^2-C): 0.0
U multiplier xul: 0.50
reactor power rp (MW): 523.1
fraction of 2400 MW (%): 21.8
moderator temperature tmod (C): 43.0

```

```

under-relaxation weight w: 0.50
maximum number of iterations itrmax: 200

```

--- COMPUTED RESULTS ---

HEAVY WATER Properties

```

pressure pres(Pa): 135800.
moderator temperature tmod(K): 316.2
liquid properties @ tmod:
density rofm(kg/m^3): 1097.7
enthalpy hfm(J/kg): 0.166E+06
viscosity visfm(Pa-s): 0.740E-03
specific heat capacity cpfm(J/kg-K): 0.421E+04
thermal conductivity condfm(W/m-K): 0.612E+00
surface tension sigmam(Pa/m): 0.691E-01
Prandtl number prfm: 0.509E+01

```

```

saturation temperature ts(K): 382.9
ts(C): 109.7
heat of vaporization hfg(J/kg): 0.205E+07
density difference drhos(kg/m^3): 1055.2
liquid properties @ ts:
density rofs(kg/m^3): 1056.1
enthalpy hfs(J/kg): 0.446E+06
viscosity visfs(Pa-s): 0.296E-03
specific heat capacity cpfs(J/kg-K): 0.418E+04
thermal conductivity condfs(W/m-K): 0.636E+00
surface tension sigmas(Pa/m): 0.569E-01
Prandtl number prfs: 0.194E+01
gas properties @ ts:
density rogs(kg/m^3): 0.855E+00
enthalpy hgs(J/kg): 0.249E+07
viscosity visgs(Pa-s): 0.129E-04
specific heat capacity cpgs(J/kg-K): 0.177E+04
thermal conductivity condgs(W/m-K): 0.248E-01

```

```

distribution parameter c0: 1.194
drift velocity ugj(m/s): 0.214

```

```

septifoil power (kW): 96.0
total losses to moderator (kW): 81.4
m-slot(hgs-hfs+cpfs(Tsat-Tmod)) (kW): 14.6

```

Cell CENTER computed results:

i	prod/dz (kW/m)	pmod/dz (kW/m)	pvap/dz (kW/m)	qrod (kW/m^2)	qpeak (kW/m^2)	qcrit (kW/m^2)	ratio
1	6.54	6.54	0.00	29.07	40.99	1211.92	0.034

2	20.74	17.21	3.53	92.13	128.99	889.47	0.142
3	26.88	17.21	9.67	119.43	167.20	465.95	0.350
4	38.57	17.21	21.36	102.82	137.77	355.22	0.451
5	40.76	19.91	20.85	108.67	145.62	257.20	0.566
6	40.19	21.80	18.39	107.13	143.56	243.34	0.593
7	39.70	22.31	17.39	105.83	141.81	240.13	0.591
8	38.88	22.81	16.06	103.64	138.88	237.13	0.586
9	36.02	23.74	12.27	96.02	128.66	232.06	0.554
10	31.18	24.50	6.69	83.13	111.39	228.34	0.442
11	25.95	24.78	1.17	69.17	92.69	227.01	0.408
12	20.07	24.66	-4.59	53.51	71.70	227.58	0.315
13	7.05	22.47	-15.42	18.80	40.61	239.15	0.170

i	zc (m)	dz (m)	alp	tf (C)	tw (C)	arod (m^2)
1	0.3963	0.7926	0.0000	72.78	64.44	0.1784
2	0.9450	0.3047	0.2661	109.70	92.46	0.0686
3	1.2497	0.3047	0.6155	109.70	92.46	0.0686
4	1.5544	0.3047	0.7481	109.70	92.46	0.1143
5	1.8592	0.3047	0.7878	109.70	94.90	0.1143
6	2.0726	0.1221	0.7992	109.70	96.60	0.0458
7	2.1488	0.0305	0.8019	109.70	97.06	0.0114
8	2.2403	0.1524	0.8043	109.70	97.51	0.0572
9	2.4688	0.3047	0.8085	109.70	98.35	0.1143
10	2.7736	0.3047	0.8116	109.70	99.02	0.1143
11	3.0783	0.3047	0.8127	109.70	99.27	0.1143
12	3.3830	0.3047	0.8122	109.70	99.16	0.1143
13	3.9317	0.7926	0.8027	109.70	97.21	0.2973
moderator space				43.02		

i	hcond (W/m^2-C)	hmod (W/m^2-C)	u (W/m^2-C)	aw (m^2)	hcond1 (W/m^2-C)	hcond2 (W/m^2-C)	hmod1 (W/m^2-C)	hmod2 (W/m^2-C)
1	2977.6	3801.4	834.9	0.2087	2977.6	0.0	4312.3	3290.5
2	3790.3	4059.4	980.1	0.0802	3790.3	247.6	4495.2	3623.5
3	3790.3	4059.4	980.1	0.0802	3790.3	1192.9	4495.2	3623.5
4	3790.3	4059.4	980.1	0.0802	3790.3	3171.3	4495.2	3623.5
5	5108.6	4077.3	1133.8	0.0802	3937.9	5108.6	4505.5	3649.2
6	6319.6	4089.4	1241.4	0.0321	4059.8	6319.6	4512.2	3666.7
7	6701.6	4092.7	1270.5	0.0080	4096.1	6701.6	4513.9	3671.4
8	7107.7	4095.8	1299.2	0.0401	4133.6	7107.7	4515.6	3676.0
9	7940.2	4101.6	1352.3	0.0802	4207.3	7940.2	4518.6	3684.5
10	8705.2	4106.2	1395.0	0.0802	4271.8	8705.2	4521.0	3691.3
11	9019.0	4107.9	1411.2	0.0802	4297.4	9019.0	4521.9	3693.8
12	8882.5	4107.1	1404.3	0.0802	4286.3	8882.5	4521.6	3692.7
13	6827.7	4093.7	1279.6	0.2087	4107.8	6827.7	4514.4	3672.9

Cell FACE (JUNCTION) computed results:

i	zf (m)	jg (m/s)	jgccfl (m/s)	ratio
0	0.0000	0.000	6.440	0.000
1	0.7926	0.000	6.440	0.000
2	1.0973	0.167	6.440	0.026
3	1.4021	0.827	5.811	0.142
4	1.7068	2.165	5.811	0.373
5	2.0115	3.472	5.811	0.598
6	2.1336	3.934	5.811	0.677
7	2.1641	4.043	5.811	0.696
8	2.3165	4.546	5.811	0.782
9	2.6212	5.315	5.811	0.915
10	2.9259	5.734	5.811	0.987

11	3.2307	5.807	5.811	0.999
12	3.5354	5.520	5.811	0.950
13	4.3280	2.646	5.811	0.455
slat	4.3280	1.858	6.663	0.279

Figure 15 Linear power generation and dissipation as a function of axial position.

Figure 16 Heat fluxes as a function of axial position.

Figure 17 Internal fluid and housing temperature as a function of axial position.

Figure 18 Gas superficial velocities as a function of axial position.

Table V Computed results for septifoil power limited by the Wallis CCFL correlation and the overall heat transfer coefficient increased by 50% from nominal.

--- INPUT INFORMATION ---

```

number of cells      nz: 13
septifoil length    z1(m): 4.328
control rod diameter drod(m): 0.02388
housing diameter     dw(m): 0.08382
septifoil power      sp(kW): 163.0
reactor/septifoil power ratio rpvsp: 5449.0

```

Cell CENTER input information:

i	dz/z1	zc/z1	pshape	nrodh	pkfac	arod (m ²)	prod (kW)	qrod (kW/m ²)
1	0.1831	0.0916	0.2950	3	1.410	0.17838	8.80	49.36
2	0.0704	0.2183	0.9348	3	1.400	0.06859	10.73	156.43
3	0.0704	0.2887	1.2118	3	1.400	0.06859	13.91	202.78
4	0.0704	0.3592	1.7387	5	1.340	0.11431	19.96	174.57

5	0.0704	0.4296	1.8377	5	1.340	0.11431	21.09	184.51
6	0.0282	0.4789	1.8117	5	1.340	0.04579	8.33	181.90
7	0.0070	0.4965	1.7897	5	1.340	0.01143	2.05	179.69
8	0.0352	0.5176	1.7527	5	1.340	0.05715	10.06	175.98
9	0.0704	0.5704	1.6237	5	1.340	0.11431	18.64	163.03
10	0.0704	0.6408	1.4058	5	1.340	0.11431	16.13	141.14
11	0.0704	0.7113	1.1698	5	1.340	0.11431	13.43	117.45
12	0.0704	0.7817	0.9048	5	1.340	0.11431	10.38	90.85
13	0.1831	0.9084	0.3179	5	2.160	0.29730	9.49	31.92

Cell FACE (JUNCTION) input information:

i	ac (m ²)	dh (m)	dc (m)	ccflm	ccflc	nrod
0	0.003675	0.0156	0.0156	1.00	0.80	3
1	0.003675	0.0156	0.0156	1.00	0.80	3
2	0.003675	0.0156	0.0156	1.00	0.80	3
3	0.002780	0.0127	0.0127	1.00	0.80	5
4	0.002780	0.0127	0.0127	1.00	0.80	5
5	0.002780	0.0127	0.0127	1.00	0.80	5
6	0.002780	0.0127	0.0127	1.00	0.80	5
7	0.002780	0.0127	0.0127	1.00	0.80	5
8	0.002780	0.0127	0.0127	1.00	0.80	5
9	0.002780	0.0127	0.0127	1.00	0.80	5
10	0.002780	0.0127	0.0127	1.00	0.80	5
11	0.002780	0.0127	0.0127	1.00	0.80	5
12	0.002780	0.0127	0.0127	1.00	0.80	5
13	0.002780	0.0127	0.0127	1.00	0.80	5
slot	0.003960		0.0167	1.00	0.80	

H/X cold-side temp	tcold(C):	26.2
gage pressure at slots	dpres(Pa):	34475.
moderator temp. flag	itmod:	1
temp. if itmod.not.1	tmod3(C):	70.0
moderator h flag	imod:	1
mod. h if imod.not.1	hmod3 (W/m ² -C):	0.0
longitudinal velocity	ulong (m/s):	0.900
cross velocity	ucross (m/s):	0.300
internal h flag	icond:	1
int. h if icond.not.1	hcond3 (W/m ² -C):	0.0
U multiplier	xu:	1.50
reactor power	rp (MW):	888.2
fraction of 2400 MW	(%):	37.0
moderator temperature	tmod (C):	54.8

under-relaxation weight	w:	0.50
maximum number of iterations	itrmax:	300

--- COMPUTED RESULTS ---

HEAVY WATER Properties

pressure	pres(Pa):	135800.
moderator temperature	tmod(K):	327.9
liquid properties @ tmod:		
density	rofm(kg/m ³):	1092.4
enthalpy	hfm(J/kg):	0.215E+06
viscosity	visfm(Pa-s):	0.598E-03
specific heat capacity	cpfm(J/kg-K):	0.420E+04
thermal conductivity	condfm(W/m-K):	0.620E+00
surface tension	sigmam(Pa/m):	0.671E-01

Prandtl number

prfm: 0.405E+01

saturation temperature ts(K): 382.9
 ts(C): 109.7
 heat of vaporization hfg(J/kg): 0.205E+07
 density difference drhos(kg/m^3): 1055.2
 liquid properties @ ts:
 density rofs(kg/m^3): 1056.1
 enthalpy hfs(J/kg): 0.446E+06
 viscosity visfs(Pa-s): 0.296E-03
 specific heat capacity cpfs(J/kg-K): 0.418E+04
 thermal conductivity condfs(W/m-K): 0.636E+00
 surface tension sigmas(Pa/m): 0.569E-01
 Prandtl number prfs: 0.194E+01
 gas properties @ ts:
 density rogs(kg/m^3): 0.855E+00
 enthalpy hgs(J/kg): 0.249E+07
 viscosity visgs(Pa-s): 0.129E-04
 specific heat capacity cpgs(J/kg-K): 0.177E+04
 thermal conductivity condgs(W/m-K): 0.248E-01

distribution parameter c0: 1.194
 drift velocity ugj(m/s): 0.214

 septifoil power (kW): 163.0
 total losses to moderator (kW): 163.0
 m-slot[hgs-hfs+cpfs(Tsat-Tmod)] (kW): 0.0

Cell CENTER computed results:

i	prod/dz (kW/m)	pmod/dz (kW/m)	pvap/dz (kW/m)	qrod (kW/m^2)	qpeak (kW/m^2)	qcrit (kW/m^2)	ratio
1	11.11	11.11	0.00	49.36	69.59	1211.92	0.057
2	35.21	35.21	0.00	156.43	219.01	1211.92	0.181
3	45.64	36.37	9.26	202.78	283.89	584.59	0.486
4	65.48	37.44	28.04	174.57	233.93	307.68	0.760
5	69.21	49.48	19.74	184.51	247.24	254.53	0.971
6	68.23	53.69	14.54	181.90	243.75	242.70	1.004
7	67.40	54.70	12.70	179.69	240.79	240.22	1.002
8	66.01	55.57	10.44	175.98	235.81	238.18	0.990
9	61.15	56.78	4.37	163.03	218.46	235.48	0.928
10	52.94	56.84	-3.90	141.14	189.13	235.36	0.804
11	44.06	54.94	-10.89	117.45	157.39	239.64	0.657
12	34.08	50.57	-16.49	90.85	121.74	251.22	0.485
13	11.97	28.30	-16.32	31.92	68.95	319.76	0.216

i	zc (m)	dz (m)	alp	tf (C)	tw (C)	arod (m^2)
1	0.3963	0.7926	0.0000	71.95	57.25	0.1784
2	0.9450	0.3047	0.0000	108.00	62.67	0.0686
3	1.2497	0.3047	0.5176	109.70	62.93	0.0686
4	1.5544	0.3047	0.7461	109.70	63.87	0.1143
5	1.8592	0.3047	0.7900	109.70	74.25	0.1143
6	2.0726	0.1221	0.7997	109.70	77.81	0.0458
7	2.1488	0.0305	0.8018	109.70	78.65	0.0114
8	2.2403	0.1524	0.8035	109.70	79.38	0.0572
9	2.4688	0.3047	0.8057	109.70	80.39	0.1143
10	2.7736	0.3047	0.8058	109.70	80.44	0.1143
11	3.0783	0.3047	0.8023	109.70	78.86	0.1143
12	3.3830	0.3047	0.7927	109.70	75.18	0.1143

13 3.9317 0.7926 0.7362 97.84 61.11 0.2973
 moderator space 54.76

i	hcond (W/m^2-C)	hmod (W/m^2-C)	u (W/m^2-C)	aw (m^2)	hcond1 (W/m^2-C)	hcond2 (W/m^2-C)	hmod1 (W/m^2-C)	hmod2 (W/m^2-C)
1	2870.0	3804.2	2453.8	0.2087	2870.0	0.0	4417.0	3191.5
2	2949.3	3872.2	2511.2	0.0802	2949.3	0.0	4478.8	3255.7
3	2953.4	3875.4	2514.1	0.0802	2953.4	745.1	4481.6	3269.2
4	3102.5	3886.6	2587.9	0.0802	2968.5	3102.5	4491.5	3281.8
5	5299.7	4000.8	3419.7	0.0802	3165.2	5299.7	4587.3	3414.3
6	6392.2	4036.1	3711.0	0.0321	3250.0	6392.2	4615.0	3457.3
7	6689.7	4044.3	3780.7	0.0080	3271.9	6689.7	4621.2	3467.1
8	6960.0	4051.2	3841.0	0.0401	3291.4	6960.0	4626.5	3475.9
9	7356.3	4060.7	3924.6	0.0802	3319.4	7356.3	4633.6	3487.8
10	7375.9	4061.1	3928.6	0.0802	3320.7	7375.9	4634.0	3488.3
11	6763.8	4046.2	3797.6	0.0802	3277.3	6763.8	4622.7	3469.7
12	5561.6	4010.2	3495.1	0.0802	3186.2	5561.6	4594.8	3425.6
13	2925.3	3853.2	2494.3	0.2087	2925.3	2802.1	4461.8	3244.6

Cell FACE (JUNCTION) computed results:

i	zf (m)	yg (m/s)	ygccfl (m/s)	ratio
0	0.0000	0.000	6.440	0.000
1	0.7926	0.000	6.440	0.000
2	1.0973	0.000	6.440	0.000
3	1.4021	0.581	5.811	0.100
4	1.7068	2.338	5.811	0.402
5	2.0115	3.575	5.811	0.615
6	2.1336	3.940	5.811	0.678
7	2.1641	4.019	5.811	0.692
8	2.3165	4.346	5.811	0.748
9	2.6212	4.620	5.811	0.795
10	2.9259	4.376	5.811	0.753
11	3.2307	3.694	5.811	0.636
12	3.5354	2.598	5.811	0.447
13	4.3280	0.000	5.811	0.000
slot	4.3280	0.000	6.663	0.000

Figure 19 Linear power generation and dissipation as a function of axial position.

Figure 20 Heat fluxes as a function of axial position.

Figure 21 Internal fluid and housing temperature as a function of axial position.

Figure 22 Gas superficial velocities as a function of axial position.

Limitations of the results: The scoping analysis and results just presented have a significant uncertainty because

- dynamic effects have not been considered (steady-state analysis)
- a detailed subchannel analysis was not performed
- the basis for the internal heat transfer coefficient is weak
- the computed external heat transfer coefficient is significantly lower than the value given in Mark 22 hydraulics manual
- a CCFL correlation verified to be applicable to the exact septifoll geometry was not used (not available to my knowledge)

Therefore the results presented in this report should be used with appropriate caution.

6 Summary

The best-estimate maximum septifoil power for a 26.2 °C cooling water inlet temperature is 119 to 141 kW. The corresponding reactor powers are 648 and 768 MW or 27 and 32% of 2400 MW. These estimates are based on a simple scoping analysis and have a large uncertainty.

7 References

- Boswell, J. M., 1974, "Hydraulics and Heat Transfer of Mark 22 Fuel Assemblies", DPSTM-22(H), p. IV-13.
- ✓ Bornt, F. W., 1991, "Septifoil Cross-sectional Areas and Hydraulic Diameters", Calc-Note SRL-SAG-910120.
- ✓ Brown, R., 1991, "Septifoil Assembly Heat Generation Rates", Calc-Note SRL-SAG-91-9051.
- Carleton, J. T., 1959, "Complete Pile Engineering Division Monthly Report - June 1959", DPST-59-13-6, Figure 7.
- Collier, J. G., 1972, *Convective Boiling and Condensation*, McGraw-Hill, London.
- Drawing ST-MDX5-10072, "Outer Housing Tube Machining".
- Griffith, P., Pearson, J. F., and Lepkowski, R. J., 1977, "Critical Heat Flux During a Loss-of-Coolant Accident", *Nuclear Safety* **18**, pp. 298-305.
- Ishii, M., 1977, "One-Dimensional Drift-Flux Model and Constitutive Equations for Relative Motion Between Phases in Various Two-Phase Flow Regimes", Argonne National Laboratory Report ANL-77-47.
- Kakac, S., Shah, R. K., and Aung, W., 1987, *Handbook of Single-Phase Convective Heat Transfer*, Wiley, New York.
- Lahey, R. T., Jr., and Moody, F. J., 1977, *The Thermal Hydraulics of a Boiling Water Reactor*, American Nuclear Society.
- Lienhard, J. H., 1988, "Burnout on Cylinders", *J. Heat Transfer* **110**, pp. 1271-1285.
- Lienhard, J. H., and Dhir, V. K., 1972, "Hydrodynamic Prediction of Peak Pool-Boiling Heat Fluxes from Finite Bodies", ASME paper 72-WA/HT-10, American Society of Mechanical Engineers.
- Mertz, S. M., 1990, "Cooling Water Inlet Temperature (U)", WSRC-TR-90-42-147.
- Osakabe, M., and Kawasaki, Y., 1989, "Top Flooding in Thin Rectangular and Annular Passages", *Int. J. Multiphase Flow* **15**, pp. 747-754.

- Ransom, V. H., Wagner, R. J., Trapp, J. A., Feinauer, L. R., Johnsen, G. W., Kiser, D. M., and Riemke, R. A., 1985, "RELAP5/MOD2 Code Manual - Volume 1: Code Structure, Systems Models, and Solution Methods", NUREG/CR-4312 & EGG-2396.
- Rohsenow, W. M., Harnett, J. P., and Garic, E. N., 1985, *Handbook of Heat Transfer Fundamentals*, 2nd edition, McGraw-Hill, New York, ch. 12, p. 38.
- Shadday, M. A., Jr., 1989, "The Impact of Cavitation During a DEGB LOCA, With Uncertainties (U)", WSRC-TR-89-1313, Appendix A.
- Walkush, J. P., and Griffith, P., 1975, "Counterflow Critical Heat Flux Related to Reactor Transient Analysis", EPRI-292-2, Interim Report, Electrical Power Research Institute.
- Whalley, P. B., 1987, *Boiling, Condensation, and Gas-Liquid Flow*, Clarendon Press, Oxford.
- Zuber, N., 1959, "Hydrodynamic Aspects of Boiling Heat Transfer", Ph.D. thesis, UCLA, Los Angeles, CA (also available as AECU-4439 Physics and Mathematics).
- Zuber, N., and Findlay, J. A., 1965, "Average Volumetric Concentration in Two-Phase Flow Systems", *J. Heat Transfer* **87**, pp. 453-468.

8 Appendix

7FOIL.FOR

```

c .....
c * 11/12/91 G.P. FLACH *
c * 7FOIL.FOR
c .....
c real jg, jgold, jgccfl, jgslof, jgfld2, jgavg
c parameter (zero=0.0, g=9.80665, ctok=273.15, patm=101325.0)
c parameter (na=100)
c
c dimension pshape(na), nroth(na), prod(na), qrod(na), alp(na),
c & tw(na), pvap(na), pmod(na), hcond(na), qcrit(na),
c & arod(na), aw(na), pkfac(na), hmod(na), u(na),
c & hcond1(na), hcond2(na), hmod1(na), hmod2(na),
c & dz(0:na), zc(0:na), tf(na+1)
c
c dimension zf(0:na), nrod(0:na), ac(0:na), jg(0:na),
c & dh(0:na), dc(0:na), ccflm(0:na), ccflc(0:na),
c & jgccfl(0:na)
c
c data zc(0)/0.0/, dz(0)/0.0/, zf(0)/0.0/, jgccfl(0)/0.0/,
c & eps/0.0001/, epsalp/0.00001/, epsjg/0.0001/, epstw/0.001/,
c & epstf/0.001/
c
c pi = acos(-1.0)
c
c do 5 i=1, na
c     hmod1(i) = 0.0
c     hmod2(i) = 0.0
c     hcond1(i) = 0.0
c     hcond2(i) = 0.0
c
c 5 continue
c
c READ ITERATION CONTROL PARAMETERS
c
c read(5,*) w, itrmax
c
c READ CELL CENTER INFORMATION
c
c sum1 = 0.0
c sum2 = 0.0
c read(5,*) nz, z1, drod, dw, sp, rpovsp
c do 10 i=1, nz
c     read(5,*) junk, dz(i), pshape(i), nroth(i), pkfac(i)
c     sum1 = sum1 + dz(i)
c     sum2 = sum2 + dz(i)*pshape(i)
c 10 continue
c
c RENORMALIZE POWER SHAPE
c
c pnorm = sum1/sum2
c do 20 i=1, nz
c     dz(i) = dz(i)/sum1
c     pshape(i) = pshape(i) * pnorm
c     zf(i) = zf(i-1) + dz(i)
c     zc(i) = 0.5*(zf(i-1) + zf(i))
c 20 continue
c
c READ CELL FACE INFORMATION
c

```

```

      read(5,*) anrod
      do 30 i=0, nz
        read(5,*) junk, arod(i), dh(i), dc(i), ccflm(i), ccflc(i)
        ac(i) = anrod - arod(i)*(pi/4.0)*drod**2
30      continue
      read(5,*) acslot, dcslot, slotm, slotc
c
c      READ REMAINING INFO.
c
      read(5,*) tcold, dpres, itmod, tmod3
      read(5,*) imod, hmod3, ulong, ucross
      read(5,*) icond, hcond3
      read(5,*) xu
c
c      ESTIMATE REACTOR POWER & MODERATOR TEMPERATURE
c
      tcold = tcold + ctok
      if (itmod .eq. 1) then
        rp = rpovsp*sp
        tmod = tcold + rp/(0.705*44.11*1.0e+6)
      else
        rp = 0.0
        tmod = tmod3 + ctok
      end if
c
c      COMPUTE ROD POWER & AVERAGE HEAT FLUX
c
      do 40 i=1, nz
        arod(i) = pi*drod*zl*dz(i) * nrodh(i)
        prod(i) = dz(i)*pshape(i)*sp
        qrod(i) = prod(i)/arod(i)
40      continue
c
c      WRITE CELL CENTER INFORMATION
c
      write(6,900) nz, zl, drod, dw, sp/1000.0, rpovsp
      do 50 i=1, nz
        write(6,901) i, dz(i), zc(i), pshape(i), nrodh(i), pkfac(i),
&          arod(i), prod(i)/1000.0, qrod(i)/1000.0
        write(10,901) i, dz(i), zf(i-1), pshape(i), nrodh(i), pkfac(i),
&          arod(i), prod(i)/1000.0, qrod(i)/1000.0
        write(10,901) i, dz(i), zf(i), pshape(i), nrodh(i), pkfac(i),
&          arod(i), prod(i)/1000.0, qrod(i)/1000.0
50      continue
c
c      WRITE CELL FACE INFORMATION
c
      write(6,910)
      do 60 i=0, nz
        write(6,911) i, ac(i), dh(i), dc(i), ccflm(i), ccflc(i),
&          nrod(i)
60      continue
      write(6,912) acslot, dcslot, slotm, slotc
c
c      WRITE REMAINING INFO.
c
      write(6,920) tcold-ctok, dpres, itmod, tmod3,
&          imod, hmod3, ulong, ucross,
&          icond, hcond3,
&          xu,
&          rp/1.0e+6, rp/2400.0e+6*100.0, tmod-ctok,
&          w, itermax
c
c      SET MODERATOR CELL TEMPERATURE

```

```

c
c      tf(nz+1) = tmod
c
c      COMPUTE LIQUID D2O PROPERTIES AT MODERATOR & SAT. TEMPERATURE;
c      GAS D2O PROPERTIES AT SATURATION TEMPERATURE ONLY
c
c      pres = patm + dpres
c
c      call liquid(pres,tmod,      2,rofm,hfm,visfm,cpfm,condfm,sigmam)
c      prfm = cpfm*visfm/condfm
c
c      call tsat(pres,2,ts)
c      call liquid(pres, ts,      2,rofs,hfs,visfs,cpfs,condfs,sigmas)
c      call gas(pres, ts,zero,2,rogs,hgs,visgs,cpgs,condgs)
c      prfs = cpfs*visfs/condfs
c      hfg = hgs - hfs
c      drhos = rofs - rogs
c
c      write(6,930) pres, tmod,
c      &      rofm, hfm, visfm, cpfm, condfm, sigmam, prfm
c      write(6,931) ts, ts-ctok, hfg, drhos,
c      &      rofs, hfs, visfs, cpfs, condfs, sigmas, prfs,
c      &      rogs, hgs, visgs, cpgs, condgs
c
c      COMPUTE DRIFT-FLUX PARAMETERS
c
c      c0 = 1.2 - 0.2*sqrt(rogs/rofs)
c      ugj = sqrt(2.0*sqrt(sigmas*g*drhos/rofs**2))
c      write(6,935) c0, ugj
c
c      COMPUTE MODERATOR HEAT TRANSFER COEFFICIENT PARAMETERS
c
c      if (imod .eq. 1) then
c          dush = 4.11*0.0254
c          pitch = 7.00*0.0254
c          xt = pitch*sqrt(3.0)
c          xl = 0.5*pitch
c          dhinf = 2.0*sqrt(3.0)/pi * pitch**2/dush - dush
c          xtstar = xt/dush
c          xlstar = xl/dush
c      end if
c
c      INITIALIZE ITERATES
c
c      do 90 i=1, nz
c          alp(i) = 0.0
c          jg (i) = 0.0
c          tw (i) = tmod
c          tf (i) = ts
c90  continue
c
c      START ITERATIVE LOOP
c
c      iter = 0
c1  continue
c      iter = iter + 1
c
c      difalp = 0.0
c      difjg = 0.0
c      diftw = 0.0
c      diftf = 0.0
c
c      LOOP OVER AXIAL CELLS
c
c

```



```

do 100 i=1, nz
c
c     SAVE PREVIOUS VALUES OF ITERATES
c
    alold = alp(i)
    jgold = jg(i)
    twold = tw(i)
    tfold = tf(i)
c
c     COMPUTE MODERATOR HEAT TRANSFER COEFFICIENTS
c
    if (imod .eq. 1) then
        call liquid(pres,tw(i),2,rofw,hfw,visfw,cpfw,condfw,sgmaw)
        prfw = cpfw*visfw/condfw
        roff = 0.5*( rofm + rofw)
        visff = 0.5*( visfm + visfw)
        condff = 0.5*(condfm + condfw)
        cpff = 0.5*( cpfm + cpfw)
        prff = cpff*visff/condff
        call hcross(rofm,visfm,condfm,prfm,prfw,ucross,dush,
c             xtstar,xlstar,hmod2(i))
        call hlong(roff,visff,condff,prff,ulong,dhinf,hmod1(i))
        hmod(i) = 0.5*(hmod1(i) + hmod2(i))
    else
        hmod(i) = hmod3
    end if
c
c     COMPUTE INTERNAL HEAT TRANSFER COEFFICIENT
c
    if (icond .eq. 1) then
        dhavg = 0.5*(dh(i-1) + dh(i))
        jgavg = 0.5*(jg(i-1) + jg(i))
        call hnuss(rofs,rogs,hfg,condfs,visfs,
c             ts,tw(i),zl,hcond1(i))
        call hshear(rogs,visgs,rofs,visfs,condfs,prfs,
c             alp(i),jgavg,dhavg,hcond2(i))
        hcond(i) = max(hcond1(i), hcond2(i))
    else
        hcond(i) = hcond3
    end if
c
c     COMPUTE OVERALL HEAT TRANSFER COEFFICIENT
c
    if (hmod(i) .gt. 0.0 .and. hcond(i) .gt. 0.0) then
        u(i) = 1.0/(1.0/hmod(i) + 1.0/hcond(i))
    else
        u(i) = 0.0
    end if
    u(i) = xu*u(i)
    aw(i) = pi*dw*zl*dz(i)
    uaw = u(i)*aw(i)
c
c     COMPUTE FLUID TEMPERATURE tf &
c     TOP FACE SUPERFICIAL VELOCITY jg
c
    if (u(i) .ne. 0.0) then
        trytf = (prod(i) + uaw*tmod
c             + ac(i-1)*rogs*jg(i-1)*(hfg + cpfs*ts))
c             /(uaw + ac(i-1)*rogs*jg(i-1)*cpfs)
    else
        trytf = 1.0e+6
    end if
    tryjg = (prod(i) - uaw*(ts - tmod)
c             + ac(i-1)*rogs*jg(i-1)*hfg)

```

```

c      &      / (ac(i)*rogs*(hfg + cpfs*(ts - tf(i-1))))
c
c      if (trytf .le. (ts+eps)) then
c          tf(i) = w*trytf + (1.0 - w)*tfold
c          jq(i) = 0.0
c
c      else if (tryjg .ge. 0.0) then
c          jq(i) = w*tryjg + (1.0 - w)*jqold
c          tf(i) = ts
c
c      else
c          write (*,*) 'no solution'
c          stop
c
c      end if
c
c      COMPUTE POWERS, WALL TEMPERATURE AND VOID FRACTION
c
c      pmod(i) = uaw*(tf(i) - tmod)
c      pvap(i) = prod(i) - pmod(i)
c
c      if (hcond(i) .ne. 0.0) then
c          tw(i) = tf(i) - pmod(i)/(hcond(i)*aw(i))
c      else
c          tw(i) = tmod
c      end if
c      avgjg = 0.5*(jq(i-1) + jq(i))
c      alp(i) = avgjg/(c0*avgjg*(1.0 - rogs/rofs) + ugj)
c
c      COMPUTE MAX CHANGE IN ITERATES
c
c      difalp = max(difalp, abs(alp(i) - alpold))
c      difjg = max(difjg, abs(jq(i) - jqold))
c      diftw = max(diftw, abs(tw(i) - twold))
c      diftf = max(diftf, abs(tf(i) - tfold))
c
c 100 continue
c
c      CHECK FOR CONVERGENCE
c
c      write(*,*) iter,difalp,difjg,diftw,diftf
c
c      if (((difalp .ge. epsalp) .or.
c          &      (difjg .ge. epsjg) .or.
c          &      (diftw .ge. epstw) .or.
c          &      (diftf .ge. epstf) ) .and. iter .lt. itrmax) go to 1
c
c      COMPUTE REMAINING RESULTS
c
c      qzuber = 0.13*rogs*hfg*(sigmas*g*drhos/rogs**2)**0.25
c
c      jgccfl(0) = ccflc(0)**2 * sqrt(drhos*g*dc(0)/rogs)
c          &      / (1.0 + ccflm(0)*(rogs/rofs)**0.25)**2
c
c      do 200 i=1, nz
c          qcrit(i) = (1.0 - alp(i))*qzuber
c          jgccfl(i) = ccflc(i)**2 * sqrt(drhos*g*dc(i)/rogs)
c          &      / (1.0 + ccflm(i)*(rogs/rofs)**0.25)**2
c 200 continue
c
c      jgslo2 = jq(nz)*ac(nz)/acslot
c      jgfld2 = slotc**2 * sqrt(drhos*g*dcslot/rogs)
c          &      / (1.0 + slotm*(rogs/rofs)**0.25)**2
c

```

```

c    GLOBAL ENERGY BALANCE
c
c    pmodc = 0.0
c    do 210 i=1, nz
c        pmodc = pmodc + pmod(i)
210    continue
c
c    pvapc = roqs*jg(nz)*ac(nz)*(hgs - hfs + cpfs*(ts - tmod))
c
c    WRITE CELL CENTER RESULTS
c
c    write(6,940) sp/1000.0, pmodc/1000.0, pvapc/1000.0
c
c    write(6,950)
c    do 300 i=1, nz
c        fac = 1000.0*zl*dz(i)
c        write(6,951) i, prod(i)/fac, pmod(i)/fac, pvap(i)/fac,
c        & qrod(i)/1000.0, pkfac(i)*qrod(i)/1000.0,
c        & qcrit(i)/1000.0, pkfac(i)*qrod(i)/qcrit(i)
c        write(10,951) i, prod(i)/fac, pmod(i)/fac, pvap(i)/fac,
c        & qrod(i)/1000.0, pkfac(i)*qrod(i)/1000.0,
c        & qcrit(i)/1000.0, pkfac(i)*qrod(i)/qcrit(i)
c        write(10,951) i, prod(i)/fac, pmod(i)/fac, pvap(i)/fac,
c        & qrod(i)/1000.0, pkfac(i)*qrod(i)/1000.0,
c        & qcrit(i)/1000.0, pkfac(i)*qrod(i)/qcrit(i)
300    continue
c
c    write(6,960)
c    do 310 i=1, nz
c        write(6,961) i, zc(i)*zl, dz(i)*zl, alp(i), tf(i)-ctok,
c        & tw(i)-ctok, arod(i)
c        write(10,961) i, zf(i-1)*zl, dz(i)*zl, alp(i), tf(i)-ctok,
c        & tw(i)-ctok, arod(i)
c        write(10,961) i, zf(i)*zl, dz(i)*zl, alp(i), tf(i)-ctok,
c        & tw(i)-ctok, arod(i)
310    continue
c    write(6,962) tf(nz+1)-ctok
c
c    write(6,970)
c    do 320 i=1, nz
c        write(6,971) i, hcond(i), hmod(i), u(i), aw(i),
c        & hcond1(i), hcond2(i), hmod1(i), hmod2(i)
c        write(10,971) i, hcond(i), hmod(i), u(i), aw(i),
c        & hcond1(i), hcond2(i), hmod1(i), hmod2(i)
c        write(10,971) i, hcond(i), hmod(i), u(i), aw(i),
c        & hcond1(i), hcond2(i), hmod1(i), hmod2(i)
320    continue
c
c    WRITE CELL FACE RESULTS
c
c    write(6,980)
c    do 330 i=0, nz
c        write(6,981) i, zf(i)*zl, jg(i), jgccfl(i), jg(i)/jgccfl(i)
330    continue
c    write(6,982) zf(nz)*zl, jgslot, jgfld2, jgslot/jgfld2
c
c    FORMATS
c
c    900    format(1x,'--- INPUT INFORMATION ---',//,
c    & 1x,'          number of cells      nz: ', i2,/,
c    & 1x,'          septifoil length    zl(m): ',f6.3,/,
c    & 1x,'          control rod diameter drod(m): ',f7.5,/,
c    & 1x,'          housing diameter    dw(m): ',f7.5,/,
c    & 1x,'          septifoil power    sp(kW): ',f9.1,/,

```

```

&      1x,'reactor/septifoil power ratio  rpvosp: ',f9.1,/,/,
&      1x,'Cell CENTER input information: ',/,/,
&      1x,' i dz/z1  zc/z1  pshape nrodh pkfac',
&      ' arod      prod      qrod ',/,/,
&      1x,'
&      ' (m^2)      (kW)      (kW/m^2)',/,/,
&      1x,80(' '))

c
901  format(2x,i2,2x,f6.4,2x,f6.4,2x,f6.4,2x,i2,2x,f5.3,
&      2x,f7.5,2x,f7.2,2x,f8.2)

c
910  format(/,1x,'Cell FACE (JUNCTION) input information:',/,/,
&      1x,' i ac dh dc ccfilm ccfic nrod',/,/,
&      1x,' (m^2) (m) (m) ',/,/,
&      1x,80(' '))

c
911  format(3x, i2 ,2x,f8.6,2x,f6.4,2x,f6.4,2x,f4.2,2x,f4.2,2x,i2)

c
912  format(1x,'slot',2x,f8.6,2x, 6x,2x,f6.4,2x,f4.2,2x,f4.2)

c
920  format(/,1x,' H/X cold-side temp tcold(C): ',f5.1,/,
&      1x,'gage pressure at slots dpres(Pa): ',f7.0,/,
&      1x,' moderator temp. flag itmod: ', i2,/,
&      1x,' temp. if itmod.not.1 tmod3(C): ',f5.1,/,
&      1x,' moderator h flag imod: ', i2,/,
&      1x,' mod. h if imod.not.1 hmod3 (W/m^2-C): ',f7.1,/,
&      1x,' longitudinal velocity ulong (m/s): ',f6.3,/,
&      1x,' cross velocity ucross (m/s): ',f6.3,/,
&      1x,' internal h flag icond: ', i2,/,
&      1x,' int. h if icond.not.1 hcond3 (W/m^2-C): ',f7.1,/,
&      1x,' U multiplier xu: ',f6.2,/,
&      1x,' reactor power rp (MW): ',f6.1,/,
&      1x,' fraction of 2400 MW (%): ',f5.1,/,
&      1x,' moderator temperature tmod (C): ',f5.1,/,/,
&      1x,' under-relaxation weight w: ',f4.2,/,
&      1x,'maximum number of iterations itrmax: ', i4,/)

c
930  format(/,1x,'--- COMPUTED RESULTS ---',/,/,
&      1x,'HEAVY WATER Properties',/,/,
&      1x,'pressure pres(Pa): ',f7.0,/,/,
&      1x,'moderator temperature tmod(K): ',f5.1,/,
&      1x,'liquid properties @ tmod:',/,/,
&      1x,' density rofm(kg/m^3): ',f6.1,/,
&      1x,' enthalpy hfm(J/kg): ',e10.3,/,
&      1x,' viscosity visfm(Pa-s): ',e10.3,/,
&      1x,' specific heat capacity cpfm(J/kg-K): ',e10.3,/,
&      1x,' thermal conductivity condfm(W/m-K): ',e10.3,/,
&      1x,' surface tension sigmam(Pa/m): ',e10.3,/,
&      1x,' Prandtl number prfm: ',e10.3,/)

931  format(/,
&      1x,'saturation temperature ts(K): ',f5.1,/,
&      1x,' ts(C): ',f5.1,/,
&      1x,'heat of vaporization hfg(J/kg): ',e10.3,/,
&      1x,'density difference drhos(kg/m^3): ',f6.1,/,
&      1x,'liquid properties @ ts:',/,/,
&      1x,' density rofs(kg/m^3): ',f6.1,/,
&      1x,' enthalpy hfs(J/kg): ',e10.3,/,
&      1x,' viscosity visfs(Pa-s): ',e10.3,/,
&      1x,' specific heat capacity cpfs(J/kg-K): ',e10.3,/,
&      1x,' thermal conductivity condfs(W/m-K): ',e10.3,/,
&      1x,' surface tension sigmas(Pa/m): ',e10.3,/,
&      1x,' Prandtl number prfs: ',e10.3,/,
&      1x,'gas properties @ ts:',/,/,
&      1x,' density rogs(kg/m^3): ',e10.3,/,

```

```

& 1x, ' enthalpy                hgs(J/kg): ',e10.3,/,
& 1x, ' viscosity                visgs(Pa-s): ',e10.3,/,
& 1x, ' specific heat capacity    cpgs(J/kg-K): ',e10.3,/,
& 1x, ' thermal conductivity     condgs(W/m-K): ',e10.3,/)
c
935 format(/,1x,'distribution parameter      c0: ',f5.3,/,
& 1x,'drift velocity      uqj(m/s): ',f5.3,/)
c
940 format(1x,'                septifoil power (kW): ',f9.1,/,
& 1x,'                total losses to moderator (kW): ',f9.1,/,
& 1x,'m-slot[hgs-hfs+cpfs(Tsat-Tmod)] (kW): ',f9.1,/)
c
950 format(1x,'Cell CENTER computed results:',/,/,
& 1x,' i      prod/dz      pmod/dz      pvap/dz',
&      '      qrod      qpeak      qcrit      ratio ',/,
& 1x,'                (kW/m)      (kW/m)      (kW/m) ',
&      '      (kW/m^2)      (kW/m^2)      (kW/m^2)      ',/,
& 1x,80('-'))
c
961 format(2x,i2,2x,f9.2,2x,f9.2,2x,f9.2,2x,f9.2,2x,f9.2,
& 2x,f6.3)
c
960 format(/,1x,' i      zc      dz      alp      tf      tw ',
&      '      arod ',/,
& 1x,'                (m)      (m)                (C)      (C) ',
&      '      (m^2) ',/,
& 1x,80('-'))
c
961 format(2x,i2,2x,f6.4,2x,f6.4,2x,f6.4,2x,f6.2,2x,f6.2,2x,f6.4)
c
962 format(1x,'moderator space      ',8x,f6.2)
c
970 format(/,1x,' i      hcond      hmod      u      aw ',
&      '      hcond1      hcond2      hmod1      hmod2 ',/,
& 1x,'                (W/m^2-C) (W/m^2-C) (W/m^2-C) (m^2) ',
&      '      (W/m^2-C) (W/m^2-C) (W/m^2-C) (W/m^2-C) ',/,
& 1x,80('-'))
c
971 format(2x,i2,2x,f7.1,2x,f7.1,2x,f7.1,2x,f6.4,
& 2x,f7.1,2x,f7.1,2x,f7.1,2x,f7.1)
c
980 format(/,1x,'Cell FACE (JUNCTION) computed results:',/,/,
& 1x,' i      zf      jg      jgccfl      ratio',/,
& 1x,'                (m)      (m/s)      (m/s)      ',/,
& 1x,80('-'))
c
981 format(2x,i2,2x,f6.4,2x,f8.3,2x,f6.3,2x,f6.3)
c
982 format(1x,'slot',1x,f6.4,2x,f8.3,2x,f6.3,2x,f6.3)
c
stop
end

```

HCROSS.FOR

```

subroutine hcross(rho,vis,cond,pr,prw,u,d,xtstar,xlstar,
& h)
c
real nu
c
re = rho*u*d/vis
if (re .lt. 1.0 .or. re .gt. 2.0e+6) then
write(*,900) re
stop

```

```

      end if
c
      if (re .le. 5.0e+2) then
        nu = 1.04 * re**0.4 * pr**0.36 * (pr/prw)**0.25
c
      else if (re .le. 1.0e+3) then
        nu = 0.71 * re**0.5 * pr**0.36 * (pr/prw)**0.25
c
      else if (re .le. 2.0e+5) then
        nu = 0.35 * (xtstar/xlstar)**0.2 * re**0.6 * pr**0.36
        * (pr/prw)**0.25
c
      else
        nu = 0.031 * (xtstar/xlstar)**0.2 * re**0.8 * pr**0.36
        * (pr/prw)**0.25
c
      end if
c
      h = cond/d*nu
c
900  format(/,1x,'Reynolds number is outside range of',
        &      /,1x,'cross tube bundle flow correlation',
        &      /,1x,'Re: ',1pe10.3)
c
      return
      end

```

HLONG.FOR

```

      subroutine hlong(rho,vis,cond,pr,u,dh,
        &      h)
c
      real nut
c
      re = rho*u*dh/vis
      if (re .lt. 4.0e+3 .or. re .gt. 6.0e+5) then
        write(*,900) re
        stop
      end if
c
      fover2 = 0.5/(3.64*log10(re) - 3.28)**2
c
      h1 = 1.07 + 900.0/re - 0.63/(1.0 + 10.0*pr)
c
      nut = fover2*re*pr/(h1 + 12.7*sqrt(fover2)*(pr**(2.0/3.0) - 1.0))
c
      ht = cond/dh*nut
c
      h = 1.15*ht
c
900  format(/,1x,'Reynolds number is outside range of',
        &      /,1x,'longitudinal tube bundle flow correlation',
        &      /,1x,'Re: ',1pe10.3)
c
      return
      end

```

HNUSS.FOR

```

      subroutine hnuss(rof,rog,hfg,condf,visf,tsat,tw,xl,
        &      h)
c
      parameter (q=9.80665)

```

```

rho = rho * (rho + rho) * q * afg * cond**3
rho = visf * x1 * (tsat - tw)
rho = rho * (rho + rho) ** 0.25
rho = rho
rho = rho
rho = rho

```

HSHEAR.FOR

```

subroutine hshear(roq,visq,rof,visf,condt,prf,alp,jg,dn,
               n)
data eps/1.0/
real jg

re = roq*jg*dh/visq
re = max(eps, re)

fg = 0.079/re**0.25
fi = fg*(1.0 + 75.0*(1.0 - max(0.75, alp)))

taui = fi * (0.5*roq*jg**2)

n = 0.065*(condt/visf)*sqrt(rof*prf*taui)

return
end

```

GAS.FOR

```

subroutine gas(p,tg,xa,m,roq,hq,visq,cpq,condq)
*
* INPUT:
*   p = PRESSURE IN Pa
*   tg = GAS TEMPERATURE IN K
*   xa = MASS FRACTION OF AIR
*   m = IDENTIFIER (m=1 FOR H2O, m=2 FOR D2O)
*
* INTERMEDIATE:
*   xs = MASS FRACTION OF STEAM
*   pa = PARTIAL PRESSURE OF AIR
*   ps = PARTIAL PRESSURE OF STEAM
*
* OUTPUT:
*   roq = DENSITY OF GAS IN kg/m^3
*   hq = ENTHALPY OF GAS IN J/kg
*   visq = DYNAMIC VISCOSITY OF AIR-STEAM GAS MIXTURE IN Pa-s
*   cpq = SPECIFIC HEAT OF AIR-STEAM GAS MIXTURE IN J/kg-K
*   condq = THERMAL CONDUCTIVITY OF AIR-STEAM GAS MIXTURE IN W/m-K
*
* RANGES:
*   Up to 1 MPa
*   275K to 700K
*
parameter (one=1.0, two=2.0, three=3.0, four=4.0,
           tconv=273.15)
dimension ws(2), rs(2), c04(2), c05(2), c06(2), c07(2), c08(2),

```

```

&      c09(2), c10(2), c11(2), c12(2), c13(2), cs1(2), cs2(2),
&      cs3(2), cs4(2), cs5(2), cs6(2), cs7(2), cs8(2), ds1(2),
&      ds2(2), ds3(2), ds4(2)
C
      data eps/2.96113/
C
C----- AIR PROPERTIES:
C
      data wa/28.01/, ra/287.0/, tref/375.0/, haref/215.0e-3/
      data c01/1005.9/, c02/-8.6140e-2/, c03/2.6295e-4/
C
C      AIR VISCOSITY, HEAT CAPACITY, & CONDUCTIVITY DATA (RESPECTIVELY)
      data ca1/145.8e-8/, ca2/110.4/
      data ca4/1005.9/, ca5/-8.6140e-2/, ca6/2.6295e-4/
      data da1/3.3350e-3/, da2/8.0021e-5/, da3/-1.8975e-8/
C
C----- H2O PROPERTIES:
C
      data ws(1)/19.016/, rs(1)/461.0/
      data c04(1)/57.931/, c05(1)/-4.6101/, c06(1)/0.16643/
      data c07(1)/2.4057e+6/, c08(1)/3949.5/, c09(1)/1684.5/
      data c10(1)/1901.4/, c11(1)/-0.62129/,
&      c12(1)/1.9538e-3/, c13(1)/-1.0083e-6/
C
C      STEAM VISCOSITY, HEAT CAPACITY & CONDUCTIVITY DATA (RESPECTIVELY)
      data cs1(1)/8.04e-6/, cs2(1)/4.07e-8/,
&      cs3(1)/1.858e-7/, cs4(1)/5.9e-10/
      data cs5(1)/1901.4/, cs6(1)/-0.62129/,
&      cs7(1)/1.9538e-3/, cs8(1)/-1.0083e-6/
      data ds1(1)/1.76e-2/, ds2(1)/5.87e-5/,
&      ds3(1)/1.04e-7/, ds4(1)/-4.51e-11/
C
C----- D2O PROPERTIES:
C
      data ws(2)/20.034/, rs(2)/415.0/
      data c04(2)/58.140/, c05(2)/-4.5875/, c06(2)/0.16435/
      data c07(2)/2.2314e+6/, c08(2)/4054.7/, c09(2)/1526.0/
      data c10(2)/1611.4/, c11(2)/3.6681e-3/,
&      c12(2)/1.3023e-3/, c13(2)/-6.6266e-7/
C
C      STEAM VISCOSITY, HEAT CAPACITY & CONDUCTIVITY DATA (RESPECTIVELY)
      data cs1(2)/8.3224e-6/, cs2(2)/4.1550e-8/,
&      cs3(2)/0.0/, cs4(2)/0.0/
      data cs5(2)/1611.4/, cs6(2)/3.6681e-3/,
&      cs7(2)/1.3023e-3/, cs8(2)/-6.6266e-7/
      data ds1(2)/1.7880e-2/, ds2(2)/5.1209e-5/,
&      ds3(2)/1.1218e-7/, ds4(2)/0.0/
C
C----- COMPUTE MASS FRACTION, PARTIAL PRESSURES
C
      xs = one - xa
      pa = p*(xa*ws(m))/(xa*ws(m) + xs*wa)
      ps = p - pa
C
C      COMPUTE AIR PROPERTIES
C
      roa = pa/(ra*tg)
      ha = haref + (c01 + ((c02/two) + (c03/three)*tg)*tg)*tg
&      + (-c01 + ((-c02/two) + (-c03/three)*tref)*tref)*tref
C
      visa = ca1*(sqrt(tg))**3/(tg + ca2)
      conda = da1 + (da2 + da3*tg)*tg
      cpa = ca4 + (ca5 + ca6*tg)*tg
C

```


COMPUTE STEAM PROPERTIES

```

roa = ps/(rs(m)*tg)
gamma = (p + ops)/ops
gamma = log(gamma)
a' = (c04(m) + (c05(m) + (c06(m) + 2)*z)*z)*z
z = log(p)
aaa = c07(m) + (c08(m) + c09(m)*z)*z
aa = aaa + (c10(m) + ((c11(m)/two) + ((c12(m)/three)
+ (c13(m)/four)*tg)*tg)*tg
s = (-c10(m) + ((-c11(m)/two)
+ ((-c12(m)/three) + (-c13(m)/four)*st)*st)*st

tinc = tg + tconv
vis = cs1(m) + cs2(m)*tinc - ros*(cs3(m) - cs4(m)*tinc)
conds = (ds1(m) + (ds2(m) + (ds3(m) + ds4(m)*tinc)*tinc)*tinc)
cps = cs5(m) + (cs6(m) + (cs7(m) + cs8(m)*tg)*tg)*tg

COMPUTE GAS PROPERTIES

rog = roa + ros
hg = xa*ha + xs*hs

visg = xa*visa + xs*vis
condg = xa*conda + xs*conds
cpg = xa*cpa + xs*cps

return
end

```

LIQUID.FOR

```

subroutine liquid(p,tf,m,rof,hf,visf,cpf,condf,sigma)
*****
* INPUT:
*   p = PRESSURE IN Pa
*   tf = LIQUID TEMPERATURE IN K
*   m = IDENTIFIER (m=1 FOR H2O, m=2 FOR D2O)
* OUTPUT:
*   rof = DENSITY OF LIQUID IN kg/m^3
*   hf = ENTHALPY OF LIQUID IN J/kg
*   visf = DYNAMIC VISCOSITY OF SATURATED LIQUID H2O IN Pa-s
*   cpf = SPECIFIC HEAT OF SATURATED LIQUID H2O IN J/kg-K
*   condf = THERMAL CONDUCTIVITY OF SATURATED LIQUID H2O IN W/m-K
*   sigma = SURFACE TENSION OF LIQUID H2O IN N/m
* RANGES:
*   Up to 1 MPa
*   275K to 450K
*****
parameter (two=2.0, tconv=273.15)

dimension      drhodp(2), c01(2), c02(2), c03(2), c04(2), c05(2),
4              c06(2), c07(2), c08(2), c09(2), c10(2), c11(2), c12(2),
6              c13(2), c14(2), c15(2), c16(2), c17(2), c18(2), c19(2)

----- H2O PROPERTIES

data drhodp(1)/4.58e-7/

```

```

      data c01(1)=-48.874/, c02(1)/0.29129/,
      c03(1)=-5.7314e-4/, c04(1)/4.0696e-7/
      data c05(1)/950.87/, c06(1)/1.2788/, c07(1)/-2.0526e-3/
      data c08(1)=-1.1694e+6/, c09(1)/3960.2/, c10(1)/-0.20668/

      LIQUID VISCOSITY, HEAT CAPACITY & CONDUCTIVITY DATA (RESPECTIVELY)
      data c11(1)/2.4127e-5/, c12(1)/5.74268e+2/, c13(1)/-1.491e+2/
      data c14(1)/3960.2/, c15(1)/0.36868/
      data c16(1)/0.5733243e+0/, c17(1)/0.179661e+2/,
      c18(1)/-3.72881959e-5/, c19(1)/0.32412245e-9/

c---- D2O PROPERTIES
      data drhodp(2)/5.29e-7/
      data c01(2)/-49.686/, c02(2)/0.29393/,
      c03(2)=-5.7036e-4/, c04(2)/4.0230e-7/
      data c05(2)/919.86/, c06(2)/1.5412/, c07(2)/-3.0963e-3/
      data c08(2)=-1.1856e+6/, c09(2)/4340.2/, c10(2)/-0.20733/

      LIQUID VISCOSITY, HEAT CAPACITY & CONDUCTIVITY DATA (RESPECTIVELY)
      data c11(2)/3.34625e-5/, c12(2)/490.126/, c13(2)/157.884/
      data c14(2)/4340.2/, c15(2)/-0.20733/
      data c16(2)/0.56340135e+0/, c17(2)/0.14504443e+2/,
      c18(2)/-0.79650470e-5/, c19(2)/0.71584948e-9/

c---- COMMON PROPERTIES TO H2O & D2O
      SURFACE TENSION (SAME FOR H2O & D2O)
      data c20/+0.75743910e-1/, c21/-0.14302481e-3/,
      c22/-0.29108772e-6/, c23/+0.28387790e-9/

c---- COMPUTE LIQUID PROPERTIES
      sp = exp(c01(m) + (c02(m) + (c03(m) + c04(m)*tf)*tf)*tf)
      rofs = c05(m) + (c06(m) + c07(m)*tf)*tf
      rof = rofs + drhodp(m)*(p - sp)
      hf = c08(m) + (c09(m) + c10(m)*tf)*tf

      tinc = tf - tconv
      viasf = c11(m)*exp(c12(m)/(tf - c13(m)))
      cpf = c14(m) + two*c15(m)*tf
      cond = c16(m) + (c17(m) + (c18(m) + c19(m)*tinc)*tinc)*tinc
      sigma = c20 + (c21 + (c22 + c23*tinc)*tinc)*tinc

      return
      end

```

TSAT.FOR

```

      subroutine tsat(p,m,ts)
      *****
      *
      *   INPUT:
      *       p = PRESSURE IN Pa
      *       m = IDENTIFIER (m=1 FOR H2O, m=2 FOR D2O)
      *
      *   OUTPUT:
      *       ts = SATURATION TEMPERATURE IN K
      *
      *   RANGE:
      *       611.3Pa < p < 1.0e+6Pa
      *
      *****

```

```

dimension c1(2), c2(2), c3(2)
data c1(1)/8,143/, c2(1)/-4,6131/, c3(1)/0,16643/

H2 PROPERTIES

data c1(2)/-8,143/, c2(2)/-4,6131/, c3(2)/0,16643/

H2 PROPERTIES

data c1(2)/8,143/, c2(2)/-4,6131/, c3(2)/0,16643/

gamma = (p + ops)/ops
z = log(gamma)
La = (c1(m) + (c2(m) + (c3(m))*z)*z)*z

return
end

```

END

**DATE
FILMED**

5 / 6 / 92