WSRC-TR-92-031

**LIMITS FOR THE NEW DWPF MELTER OFF-GAS JUMPER I.
D. (U)**

WSRC-TR--92-031

DE93 009112

by A. S. Choi

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

Other Authors:

This paper was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED *cb*

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P. O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401.

Available to the public from the National Technical Information Service, U. S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

WESTINGHOUSE SAVANNAH RIVER COMPANY
SAVANNAH RIVER LABORATORY

WSRC-TR-92-31

Keywords: DWPF, Melter Off-
Gas Jumper, I.D.

January 22, 1992

MEMORANDUM

To: C. T. Randall, 704-T

From: A. S. Choi, 704-1T *ASL*

LIMITS FOR
THE NEW DWPF MELTER OFF-GAS JUMPER I.D. (U)

Introduction and Summary

In order to minimize solids deposition in the off-gas line between the primary film cooler and the quencher, SRL recommended earlier that a new DWPF melter off-gas jumper be built which would increase the off-gas velocity from less than 40 ft/s under the original design to at least 55 ft/s, excluding the melter air inleakage. Two design changes proposed for the new jumper were: (1) relocation of the entry point for the melter pressure control air from the current position near the quencher to near the film cooler exit, and (2) reduction of the inside diameter of the jumper from 8.33 to 7.156 inches.

The objective of this study was to confirm the optimum I.D. proposed earlier and determine the upper and lower limits for the optimum I.D. to initiate the actual design process. Based on more conservative bases for optimization used in this study, it was determined that the design limits for the new jumper I.D. is $7.15 \leq \text{I.D.} \leq 7.25$ inches.

C. T. Randall, 704-T
Authorized Derivative Classifier

Bases for Optimization

Determination of the optimum diameter for the new jumper resulted in a new set of operating conditions for the melter off-gas system.¹ These revised operating conditions were the product of an extensive cross-checking to determine if all the key design conditions that are shown in Table 1 were met under those conditions. Conditions #5 and #8 included additional conservatism over those considered in an earlier study,¹ while Condition #6 was added for the first time in this study.

TABLE 1. Conditions for Design and Optimization

No.	Condition	Value	To avoid possibility of
1.	Actual/stoichiometric O ₂ ratio at 3X nominal combustible feed	≥ 1.5	O ₂ depletion in plenum
2.	Plenum gas residence time at nominal (1X) off-gas flow	≥ 8 sec	poor gas mixing
3.	Film cooler air/steam (mass)	≥ 3	steam condensation
4.	Film cooling effectiveness	≥ 0.68	entrance plugging
5.	Off-gas temperature at the film cooler exit	< 400 °C	glass softening
6.	Off-gas velocity at the film cooler exit	> 50 ft/s	downstream plugging
7.	Off-gas velocity including pressure control air flow	≥ 55 ft/s	downstream plugging
8.	Off-gas LEL at OGCT at 3X nominal off-gas flow	< 60%	off-gas explosion
9.	Inlet vapor flow to SAS #1	< 1,807 lbs/hr	exceeding 80% design
10.	Vapor exiting SAS #2	< 2,000 lbs/hr	entrainment (90%)
11.	Cooling duty @ OGCT	< 740 mPcu/hr	exceeding 90% design
12.	Vapor to exhauster	< 2,062 lbs/hr	exceeding 90% design
13.	Melter pressure @ 7X surge relative to cell	< -0.5" H ₂ O	glass spill (nonpour) & blowing the seal pot

Process of Optimization

Optimization of the new jumper I.D. and its design limits proceeded as follows:

- (1) Find the largest jumper I.D. and the optimum operating conditions that satisfy all the design conditions shown in Table 1, and produce the lowest liquid waste recycle rate.
- (2) Under the operating conditions determined in (1), find the smallest jumper I.D. that still results in dynamic stability at 7X off-gas surge (Condition #13).
- (3) The optimum diameter is then set at the midpoint between the largest and the smallest diameters found above.

The actual steps followed in this optimization study are given next. The majority of the efforts were essentially devoted to examining each of the design conditions given in Table 1 in order to determine the operating windows for several key operating parameters.

Step 1. Determination of Operating Windows

**Condition #1: Actual/stoichiometric O_2 ratio ≥ 1.5
at 3X nominal combustibles feed rate**

This condition ensures that oxygen will not be depleted in the melter plenum even for the worst case of 70% aromatic carbon removal and 3 times the nominal formic acid addition during the feed preparation steps. This condition also sets the minimum air purge requirement into the plenum at 430 lb/hr, including the backup film cooler purge at 350 lb/hr and the TV camera and seal pot purges at 80 lb/hr total. The air inleakage into the melter was not included in this calculation.

**Condition #2: Plenum gas residence time ≥ 8 sec
at nominal (1X) off-gas flow**

At a nominal slurry feed rate and the minimum air purge rate into the plenum, the highest plenum temperature that satisfies this gas residence time requirement is 900 °C, measured in the thermowell. Note that the thermowell temperatures are higher than the actual gas temperatures due to radiation effects on the thermowell wall.

According to the calculations based on the Scale Glass Melter (SGM) data, the correlation between the two temperatures is as follows:

$$T_{\text{gas}} = 0.91685 T_{\text{tw}} - 128, \quad \text{in } ^\circ\text{C} \quad (1)$$

The air inleakage into the melter at the design rate of 100 lb/hr was included in the residence time calculations.

Condition #3: Film cooler air/steam mass ratio ≥ 3

At air-to-steam ratios of 2 or lower, the air, essentially at ambient temperature, can at times partially condense the steam exiting the cooling slots.³ This can possibly lead to increased buildup of solids deposits in the film cooler. Condition #3 eliminates any possibility of steam condensation. During the initial stages of the optimization process, the air-to-steam mass ratio was set at 3.

Condition #4: Film cooling effectiveness ≥ 0.68

The definition of film cooling effectiveness was given earlier.¹ This condition sets the minimum coolant flow to the film cooler required to maintain the adiabatic film cooler wall temperature well below the glass softening point at the highest off-gas temperature of $\sim 700^\circ\text{C}$. This minimum coolant flow was calculated earlier to be 125 lb/hr at the air-to-steam mass ratio of 3.

**Condition #5: Off-gas temperature $\leq 400^\circ\text{C}$
at the film cooler exit**

In the new jumper, the entry point for the melter pressure control air will be located as closely to the film cooler exit as practical. This condition ensures that the off-gas is cooled to below 400°C , before the pressure control air is introduced. Obviously, the intention is to protect the off-gas equipment from pluggages and further meet the quencher design limit in the event of the pressure control air loss. This condition was made more conservative than the previous one which included the pressure control air in the calculation of cooled off-gas temperatures.

Furthermore, this condition lowers the highest plenum temperature allowable, set earlier by Condition #2, to 848°C . Above 848°C , the off-gas temperature at the film cooler exit is still higher than 400°C , even using the maximum design film cooler air and steam flows of

583 and 245 lb/hr, respectively. This condition further ensures that the region between the film cooler and the control air entry point is kept relatively deposit-free, no matter how narrow this region may be. The air inleakage into the melter was included at the design rate of 100 lb/hr.

**Condition #6: Off-gas velocity ≥ 50 ft/sec
at the film cooler exit**

At a given plenum temperature below 848 °C, the maximum off-gas jumper I.D. was calculated by adding appropriate amounts of the film cooler air and steam to the nominal melter off-gas flow so the off-gas temperature at the film cooler exit was at the design maximum of 400 °C. With the melter off-gas flow and plenum temperature both fixed, the allowable jumper I.D. is largest when the least amounts of film cooler air and steam are added. The melter air inleakage is not included in any velocity calculations. The off-gas velocity is then at least 50 ft/sec even in the absence of the pressure control air.

**Condition #7: Off-gas velocity ≥ 55 ft/sec
including melter pressure control air**

The off-gas velocity of 55 ft/sec is the minimum velocity required to minimize the formation of solid deposits in the off-gas jumper. The minimum pressure control air was then set by this condition. As in an earlier study,¹ however, the melter pressure control air was set at 550 lb/hr or 72% of the design capacity of the control air valve for a greater control capability of surges. It turns out that this value was more than enough to boost the off-gas velocity from 50 to 55 ft/sec.

**Condition #8: Noncondensable off-gas $< 60\%$ of the LEL
at 3X nominal off-gas flow**

Both the gas temperature and the gas residence time in the plenum decrease significantly during the off-gas surges. The lowest plenum gas temperature during the 3X off-gas surge was calculated using the melter off-gas dynamics model. Conservatism was then included in the kinetic calculations of CO and H₂ oxidation by assuming that the plenum gas temperature remained at that minimum throughout the surge period. The reduction in pressure control air flow during the 3X surge was also calculated using the dynamics model and included in the lower explosive limit (LEL) calculations. It was also checked

whether or not the plenum gas residence time was longer than 5-6 seconds during the 3X surge.

If the calculated percent LEL of noncondensable off-gas at a given plenum temperature below 848 °C was greater than 60%, the film cooler air flow was increased until the percent LEL dropped below 60%. In doing so, Condition #3 remained satisfied. The maximum jumper I.D. was then recalculated based on the adjusted film cooler air flow rate. It turned out that the minimum plenum thermowell temperature allowable is 765 °C. That is, the calculated percent LEL is 60% at 765 °C using the maximum design film cooler air flow. Condition #8 guarantees that the off-gas remains below 60% of the composite LEL anywhere in the off-gas system even during the 3X off-gas surges.

Conditions #9-12: Melter off-gas equipment design limits

So far, based on Conditions #1 through 8, several sets of melter off-gas system operating conditions were developed at different plenum temperatures chosen between 765 and 848 °C. It was then checked whether Conditions #9 through 12 were satisfied by each set of operating conditions. These conditions represent some of the key design limits which must be satisfied to eliminate an adverse impact on continuous, safe operation of the melter off-gas system.

Step 2. Determination of Optimum Operating Conditions

The DWPF liquid waste recycle rate was next calculated for each set of operating conditions which satisfies Conditions #1 through 12. As shown in Figure 1, the minimum liquid waste recycle rate is found at a plenum temperature of 775 °C or a gas temperature of 583 °C. At this temperature, the maximum allowable jumper I.D. is 7.28 inches. The primary film cooler air purge rate was increased to 520 lb/hr to satisfy Condition #8 so the resulting air-to-steam mass ratio was 3.5 (Condition #3). Under these conditions, the off-gas temperature at the film cooler exit was 390 °C, and immediately dropped to 317 °C at the control air entry point.

The primary reasons for choosing the minimum liquid waste recycle rate as the optimization criterion are to increase the attainment rate in DWPF and to lower the operating costs in the tank farms. Besides, costly upgrade of process equipment such as chiller and condensers is avoided.

Figure 1. Optimum Plenum Temperature vs Maximum Jumper I.D.

Step 3. Determination of Minimum Jumper I.D.

The minimum allowable jumper I.D. is determined by Condition #13 in Table 1. That is, at 7 times the nominal melter off-gas flow rate, the pressure drop in the new jumper should not be excessively high so that the melter pressure would not rise above -0.5" wc. As shown in Figure 2, the results of the dynamic simulation indicated that the melter pressure would peak at just below -0.5" wc during the 7X off-gas surge in a 7.156" I.D. jumper. Therefore, the minimum I.D. that is dynamically allowable was set at 7.15 inches.

7X OFF-GAS EXCURSION @ 775 C IN 7.156" JUMPER

JANUARY 9, 1992

RUN NUMBER: 001

FIGURE 2. Dynamic Simulation Results during 7X Off-Gas Surge in a 7.156 inch I.D. Jumper.

Conclusions and Recommendations

In Steps 2 and 3, the upper and lower limits for the new jumper I.D. was determined to be 7.28 and 7.15 inches, respectively. For DWPF design purposes, it is recommended that the new off-gas jumper be built within 7.2 ± 0.05 inches.

Note that the optimum I.D. found in this study is less than 1% larger than the one determined earlier.¹ However, additional conservatism included in this study requires that the melter be operated at 775 °C, which is 50 °C higher than the latest flowsheet.² The primary film cooler air purge rate should also be increased from 425 to 520 lb/hr. In return, the proposed DWPF jumper design along with the revised operating conditions will ensure that both off-gas line plugging and liquid waste recycle are minimized, while off-gas flammability and dynamic instability during severe off-gas surges are both eliminated.

References

1. Choi, A. S., "Revised Design and Operating Conditions for the DWPF Melter Off-Gas System (U)," WSRC-TR-91-88, April 22, 1991.
2. Choi, A. S., "Prediction of Melter Off-Gas Explosiveness (U)," WSRC-TR-90-346, to be published.

END

DATE
FILMED

5 / 10 / 93