DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

EGG-NRE--10586

DE93 007640

Calvert Cliffs RELAP5/MOD3/SCDAP Plant Deck

**C. E. Hendrix
J. C. Determan**

Published December 1992

**Idaho National Engineering Laboratory
EG&G Idaho, Inc.
Idaho Falls, Idaho 83415**

**Prepared for the
Division of Reactor Systems Safety
Office of Nuclear Regulatory Research
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555
Under DOE Idaho Field Office
Contract DE-AC07-76ID01570
FIN A6328**

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ABSTRACT

This report documents the development of a RELAP5/MOD3/SCDAP input deck for the Calvert Cliffs nuclear power plant. Through the addition of SCDAP inputs, NPA interactive capabilities, and significant nodalization enhancements the range of applicability of this input deck has been greatly increased.

SUMMARY

A RELAP5/MOD3/SCDAP input deck of the Calvert Cliffs nuclear reactor has been developed and is described in this report. The primary purpose of this task is to enhance the plant analysis capability of the NRC by modifying and upgrading existing RELAP5 plant decks of LWR systems.

This report provides a detailed description of the input deck, with sections covering the RELAP5/MOD3 nodalization, the SCDAP core description, and the nuclear plant analyzer (NPA) input and graphic display features. The results of three transient analyses performed with the deck are also discussed. To facilitate the use of this input deck the process of analysis with RELAP5 and the NPA is outlined.

CONTENTS

ABSTRACT	iii
SUMMARY	v
1. INTRODUCTION	1-1
2. PLANT DECK DESCRIPTION	2-1
2.1 RELAP5/MOD3 Input Description	2-2
2.1.1 Plant Deck Nodalization	2-2
2.1.2 Main Feedwater Train, Main Steam Line, Reactor Trip Logic, and Control Systems	2-14
2.2 SCDAP Input Deck for Severe Accident Analysis	2-15
2.2.1 Core Nodalization	2-16
2.2.2 Fuel Pin Component Inputs	2-16
2.2.3 Control Rod Components	2-19
2.2.4 SCDAP Component Connection to RELAP5/MOD3	2-19
2.3 NPA Description	2-22
2.3.1 NPA System Mask	2-22
2.3.2 NPA Core Region Mask	2-25
2.3.3 Interactive Options for the Calvert Cliffs NPA	2-25
3. PLANT DECK APPLICATIONS	3-1
3.1 Loss of Feedwater Transients	3-1
3.2 Large Break LOCA Accident	3-8
3.3 Small Break LOCA Calculation	3-14
3.4 User Instructions and Recommendations	3-25
3.4.1 Plant Transient Applications	3-32
3.4.2 Loss of Coolant Accident Applications	3-33
3.4.3 Severe Accident Applications	3-37
3.5 Problem Resolution	3-37

4. CONCLUSIONS	4-1
5. REFERENCES	5-1

FIGURES

2-1. SCDAP/RELAP5 reactor coolant system interactions	2-1
2-2. Calvert Cliffs RELAP5/MOD3/SCDAP core nodalization	2-3
2-3. Calvert Cliffs core nodalization for SCDAP heat structure modeling	2-4
2-4. Reactor vessel nodalization	2-5
2-5. Calvert Cliffs downcomer nodalization	2-6
2-6. Calvert Cliffs plant deck RCS Loop 1	2-7
2-7. Calvert Cliffs plant deck RCS Loop 2	2-8
2-8. Calvert Cliffs plant deck Loop 1 steam generator	2-9
2-9. Calvert Cliffs plant deck Loop 2 steam generator	2-10
2-10. Calvert Cliffs plant deck main feedwater system	2-11
2-11. Calvert Cliffs plant deck main steamline nodalization	2-12
2-12. Axial power distribution (taken from the Calvert Cliffs FSAR)	2-17
2-13. Calvert Cliffs fuel pin and control rod geometry	2-18
2-14. Calvert Cliffs NPA system mask	2-23
2-15. Calvert Cliffs NPA thermal-color parameters	2-26
2-16. Calvert Cliffs rod/chan and magnitude parameters	2-29
2-17. Calvert Cliffs NPA levels and on/off parameters	2-31
2-18. Calvert Cliffs NPA digital display parameters	2-33
2-19. Calvert Cliffs NPA core mask	2-35
3-1. Pressurizer pressure	3-4

3-2.	Steam generator mass	3-5
3-3.	Steam generator pressures	3-6
3-4.	Hot and cold leg liquid temperatures	3-7
3-5.	Loop 1 coolant flow	3-9
3-6.	Pressurizer level	3-10
3-7.	Break nodalization for a large break LOCA	3-11
3-8.	Upper head pressure	3-12
3-9.	Break flow	3-13
3-10.	Core inlet flow—center core	3-15
3-11.	Maximum clad temperature	3-16
3-12.	Break nodalization for a small break LOCA	3-17
3-13.	Primary and secondary pressures	3-18
3-14.	Hot leg temperatures	3-20
3-15.	Pressurizer level	3-21
3-16.	Break flow	3-22
3-17.	Hot leg void fraction	3-23
3-18.	Void fraction upstream of the break	3-24
3-19.	Core inlet flow	3-26
3-20.	Total HPE flow	3-27
3-21.	Integrated break and ECCS flows	3-28
3-22.	Collapsed liquid level	3-29
3-23.	Peak clad temperature	3-30
3-24.	Problem execution using the Calvert Cliffs plant deck	3-31

TABLES

2-1.	Reactor protection system	2-15
2-2.	System parameters available as RELAP5 control variables	2-15
2-3.	Axial power distribution	2-18
2-4.	SCDAP quantities available in RELAP5/MOD3/SCDAP minor edits	2-20
2-5.	Thermo-color displays	2-24
2-6.	Calvert Cliffs NPA display—THERMO-COLOR parameters	2-27
2-7.	Calvert Cliffs NPA display—ROD/CHAN and MAGNITUDE parameters	2-30
2-8.	Calvert Cliffs NPA display—LEVEL and ON/OFF parameters	2-32
2-9.	Calvert Cliffs NPA display—DIGITAL parameters	2-34
2-10.	Calvert Cliffs mask interactive commands	2-36
3-1.	Steady state parameter comparison	3-2
3-2.	Calvert Cliffs plant deck interactive variable input summary	3-34
3-3.	Restart deck input listing	3-37
3-4.	Suggested SCDAP minor edits	3-38
3-5.	Inputs to remove the main feedwater line	3-41

Calvert Cliffs RELAP5/MOD3/SCDAP Plant Deck

1. INTRODUCTION

A Plant Deck of the Calvert Cliffs 2700 MWt CE nuclear reactor system has been developed and is described in this report. The primary purpose of this task is to enhance the plant analysis capability of the NRC by modifying and upgrading existing RELAP5 plant decks of LWR systems. The deck described here is for applications with the RELAP5/MOD3/SCDAP code (1) and has nuclear plant analyzer (NPA) (2, 3) interactive capabilities. The starting point for this study was the Calvert Cliffs RELAP5/MOD2 input deck used in the operational safety study described in Reference 4. A QA review of this deck was completed and then the improvements to the deck were identified and added. These improvements include:

1. Multiple channel modeling of the core fluid region with cross flow between radial regions
2. Split downcomer nodalization
3. Modeling of the ECC inlet locations with the RELAP5/MOD3 ECCMIX component
4. Conversion of the RELAP5 input from RELAP5/MOD2 format to RELAP5/MOD3 format
5. Use of SCDAP heat structures to describe the fuel rods and control rods in the core region
6. Addition of NPA option in the deck to allow the user interactive analysis capability.

The Calvert Cliffs plant deck was balanced so the initial pressures, fluid temperatures, system mass flow, and other thermodynamic conditions simulated 100% power/flow conditions. Approximations were used for the fuel rod temperatures and conductivity at 100% power. The completed and balanced input deck was then exercised and tested by applying it for the analysis of several postulated accident and transient scenarios. These test scenarios included a loss of feedwater (LOFW) transient, a small break loss of coolant accident (SBLOCA), and a large break loss of coolant accident (LBLOCA). Also, the NPA capabilities of the deck were tested by executing interactive commands while running problems with the NPA display selected.

The Calvert Cliffs plant deck described here was developed to be applicable to a wide range of accidents and transients. The results of the test problems were satisfactory and show that the development goals were achieved. The RELAP5 input deck modifications summarized above are discussed in Section 2.1, the SCDAP input in Section 2.2, and the NPA capabilities in Section 2.3. The analyses are discussed in Section 3.1 through Section 3.3. User instructions are provided in Section 3.4 to aid engineers who apply the deck for accident and transient analysis. Section 3.5 explains methods for resolving problems that may be encountered during applications of the deck.

2. PLANT DECK DESCRIPTION

This section contains the Calvert Cliffs RELAP5/MOD3/SCDAP plant deck description. There are three primary parts of the deck. Section 2.1 explains the inputs related to the RELAP5/MOD3 code. System fluid volume nodalization, vessel and piping heat conductors, ECC systems, trips, and control systems are modeled with RELAP5 inputs. The core heat structures are modeled with SCDAP and are explained in Section 2.2. The SCDAP inputs are separated from the RELAP5 inputs in the deck but the two codes are connected as shown in Figure 2-1 (1). Models and numerical solutions in the RELAP5 code predict system thermal-hydraulics, control system interaction, ECC injection rates, etc. The SCDAP code is primarily directed to the prediction of damage progression phenomena in the core region during severe accident conditions. However, the methods presented in this report allowed development of a general deck applicable for many studies including transients that progress into severe accident situations.

The plant deck has interactive applications capability in conjunction with the NPA. Section 2.3 describes the NPA capabilities. To use the NPA, a mask, which is the name given to the computer terminal schematic of the reactor system modeled with RELAP5/MOD3/SCDAP, is created. The Calvert Cliffs system mask has reactor vessel, core, reactor coolant loop, steam generator, pressurizer, ECCS, and other components. The latest versions of the NPA have special core region displays that show fuel and control rod behavior during normal, transient, and severe accident conditions. To provide detailed displays of core data a second mask was developed. The core mask is also explained in Section 2.3.

Figure 2-1. SCDAP/RELAP5 reactor coolant system interactions.

2.1 RELAP5/MOD3 Input Description

The principal enhancements to the Calvert Cliffs deck that relate to RELAP5 input include: (a) core region modifications; (b) downcomer region modifications; (c) addition of ECCMIX components; (d) conversion from RELAP5/MOD2 format to RELAP5/MOD3 format. The significant features in the RELAP5 portion of the input are discussed in this section.

Reference 1 contains the RELAP5/MOD3 input description. The Calvert Cliffs plant deck user should review the User Manual (7) and become familiar with the basic input requirements before applying the deck. This will make it easier to interpret the results. For purposes of this discussion the RELAP5 component designation should be understood to avoid any confusion. RELAP5 hydrodynamic components and their alphanumeric designation include: (a) single volumes (snglvol); (b) branches (branch); (c) pipes (pipe); (d) annulus (annulus); (e) time dependent volumes (tmdpvol); (f) single junctions (sngljun); (g) time dependent junctions (tmdpjun); (h) separators (separatr); (i) turbines (turbine); (j) valves (valve); (k) pumps (pump); (l) multiple junctions (mtpljun); (m) accumulators (accum). There is only one type of heat structure component and there is no alphanumeric designator for heat conductors. In the text and the figures showing components, the components will normally be referred to by a three digit identifier. However, in the code output or in the NPA a nine digit identifier is used. For example the hot leg in Loop 1 is component 105. This will be identified as 105010000 in the output. A pipe or annulus component contains several volumes and junctions. The third volume node of pipe component 125, the primary side of the steam generator U-tubes, would be referred to as 12503.

2.1.1 Plant Deck Nodalization

The nodalization used to describe fluid volumes in the reactor vessel and steam generators is given in Figures 2-2 through 2-11. 137 RELAP5 fluid nodes are used to model the Calvert Cliffs primary and secondary systems. The nodalization selection contains enough detail to make the deck applicable to most analyses. In some calculations the nodalization detail may be reduced to improve computer running time. This is not difficult for the experienced user.

2.1.1.1 Core Region. The core is modeled with three radial channels and ten axial volumes per radial channel. Figure 2-2 shows the core region. RELAP5 component 513 is the outer core containing 60 14×14 fuel rod bundles. Component 515 is the middle core containing 92 bundles and component 517 describes the center core containing 65 bundles. Figure 2-3 shows the radial division in detail. The ten axial nodes in each channel are of equal length and are connected by cross flow junctions. The RELAP5/MOD3 code allows the user to specify a junction as a cross flow junction rather than a normal junction, thereby eliminating momentum flux terms in the momentum equation. The values of the loss coefficients for the cross flow junctions were determined using Reference 5. Reasonable values for the mass flow rates through the cross flow junctions were predicted by the code when these loss coefficients were used.

This modeling method for the core region was selected to allow the prediction of core damage progression during severe accident situations. In some scenarios, debris formation, debris melting, and slumping of core material may occur in the central region of the core while the outer region

Figure 2-2. Calvert Cliffs RELAP5/MOD3/SCDAP core nodalization.

Figure 2-3. Calvert Cliffs core nodalization for SCDAP heat structure modeling.

Figure 2-4. Reactor vessel nodalization.

CCMJD02

Figure 2-6. Calvert Cliffs plant deck RCS Loop 1.

CCM1003

Figure 2-7. Calvert Cliffs plant deck RCS Loop 2.

CCMJ004

Figure 2-8. Calvert Cliffs plant deck Loop 1 steam generator.

Figure 2-9. Calvert Cliffs plant deck Loop 2 steam generator..

41 N.102

Figure 2-10. Calvert Cliffs plant deck main feedwater system.

JENJ03

Figure 2-11. Calvert Cliffs plant deck main steamline nodalization.

remains essentially intact. Therefore, the core nodalization must allow the radial power distribution to be modeled as is done here. The Plant Deck testing described in Section 3.0 confirmed that the core input performs well in calculations where severe accident behavior does not occur. Thus, a general core model, suitable for a wide range of applications is provided in the deck.

2.1.1.2 Reactor Vessel and Downcomer. Figure 2-4 shows the reactor vessel nodalization outside the core. Components 575 and 505 are the lower plenum and core inlet region respectively. The upper plenum region is described by components 520, 525, and 530. The upper head is modeled with components 550 and 555. Components 540 and 545 describe a leakage path between the core and the upper head through the control elements.

Asymmetric thermal-hydraulic conditions can occur in the downcomer region during ECC injection. This asymmetric behavior can be predicted by RELAP5 if a split downcomer is modeled. Since Calvert Cliffs is a 2×4 design the downcomer is modeled with four azimuthal channels connected by cross flow junctions. The loss coefficients of the cross flow junctions were determined by considering the curvature of the downcomer and fanning friction losses. Fanning friction is not included in the equations for cross flow junctions; so a loss coefficient that will approximate the fanning losses was included. Figure 2-5 shows the details of the split downcomer model.

2.1.1.3 Reactor Coolant Loops and Steam Generators. Figures 2-6 and 2-7 show the Loop 1 and Loop 2 reactor coolant piping systems respectively. The pressurizer is connected to Loop 1 and includes the spray line, proportional heaters, backup heaters, PORV, and SRV. Eight nodes are used in the pressurizer and three in the surge line. The PORV opens on high pressurizer pressure of 2400 psia (16.55 MPa) and closes at 2280 psia (15.72 MPa). The SRV opens at 2532.2 psia (17.46 MPa) and closes at 2430.9 psia (16.76 MPa). The spray line valve positions and heater powers are controlled by the reactor coolant pressure regulating system and the pressurizer level control system.

Homologous curves are used in the RCP input to determine pump head and hydraulic torque. The pumps are controlled interactively by the analyst, as described later in the discussion of the NPA mask, or may be told to follow a predefined course of action using the RELAP5 trip logic.

The safety injection (HPI, LPI, and makeup) systems are connected to the cold legs between the pump and the vessel. The ECC pumps are not explicitly described, but are modeled with flow versus pressure tables, and the safety injection actuation signal occurs on low pressurizer pressure at 1754.7 psia (12.1 MPa). The temperature of the injected fluid is defined by time dependent volumes (components 640, 642, 810, 815, 820, 825, 830, 835, 840, and 845). The accumulators are modeled using the RELAP5 accumulator component option, which gives a lumped parameter treatment of accumulator behavior. Heat transfer to the nitrogen gas in the accumulators is considered and the surge line fanning friction losses are modeled.

The HPI, LPI, and accumulators inject into ECCMIX components (7). The ECC mixer models the ECC injection location where a jet of cold water is injected into a two-phase mixture. The primary phenomenon modeled by this component is the resulting condensation of the steam in the volume. When no steam is present this component behaves as an ordinary BRANCH component. Reference 1 gives a detailed discussion of this new feature of RELAP5/MOD3.

Figures 2-8 and 2-9 show the Loop 1 and 2 steam generator respectively. The steam generator U-tube fluid volumes are described with nine nodes on the primary side. The secondary side tube bundle region has four fluid volumes. There are six nodes in the downcomer and four nodes in the separator and steam dome region.

2.1.2 Main Feedwater Train, Main Steam Line, Reactor Trip Logic, and Control Systems

Other systems and parameters described using RELAP5/MOD3 input include the main feedwater train, the main steam line, the reactor trip logic, and other control variables. These portions of the plant deck are discussed in this section. The main feedwater train and the main steam line are described with the valves and pumps in these lines appropriately modeled. The principal control systems and reactor protection system trips are described in the input deck using the RELAP5/MOD3 controller, trip, and table function inputs.

2.1.2.1 Main Feedwater Train. Figure 2-10 shows the main feedwater system and the components modeled in the main feedwater train. Homologous curves are used to calculate the head, torque and pump speed relationships for the condensate pump, the condensate booster pump, and the main feed pumps. The main feed pumps will trip automatically on high discharge pressure (1464.7 psia, 10.1 MPa) or low suction pressure (225.7 psia, 1.56 MPa) and also trip if the steam generator isolation signal (SGIS) occurs on low steam generator pressure (667.7 psia, 4.6 MPa) or asymmetric steam generator pressure (115 psid, 0.79 MPa).

2.1.2.2 Main Steam Line. The RELAP5/MOD3 nodalization and component modeling of the main steam line is shown in Figure 2-11. The main steam isolation valves (MSIV) and the turbine stop valve (TSV) close on the SGIS. The atmospheric dump valve and the turbine bypass valve positions are regulated by the steam dump and turbine bypass controller. The safety relief valve component describes four safety valves in each line. The valves progressively open with increasing steam line pressure. The set points are 950, 960, 980, and 1000 psia. The closing set points are 1000, 1010, 1030, and 1050 psia. The condenser is modeled as a time dependent volume component.

2.1.2.3 Reactor Trip Logic. The Calvert Cliffs reactor protection system is described in the plant deck using trips that cause scram on: (a) low RCS flow; (b) low steam generator level; (c) low steam generator pressure; (d) high RCS pressure; (e) low RCS pressure; (f) asymmetric steam generator pressure. Table 2-1 lists the trips and set points modeled.

2.1.2.4 Other Control Variables. Some thermal-hydraulic parameters that are important to the analyst are not directly calculated by the code. For example, the density in each volume component in the steam generators will be given in the output, but the total mass in the steam generator, which is often of greater interest than node densities, will not appear in the major edit data. Therefore, control systems are used to calculate and display these quantities. Table 2-2 gives the system parameters that are calculated at each time step by RELAP5 control system variables.

Table 2-1. Reactor protection system.

Trip parameter	Set point
Low RCS flow	39952.4 lbm/s
Low steam generator level	-50.0 in.
Low steam generator pressure	667.7 psia
High RCS pressure	2400.0 psia
Low RCS pressure	2100.0 psia
Asymmetric steam generator pressure	115.0 psid

Table 2-2. System parameters available as RELAP5 control variables.

Parameter	Control variable number	Units
SG1 mass	310	lb _m
SG1 heat input	320	MW
SG1 near range level	336	in.
SG1 wide range level	344	in.
SG2 mass	410	lb _m
SG2 heat input	420	MW
SG2 near range level	436	in.
SG2 wide range level	444	in.
Pressurizer level	604	in.
Core heat output	1875	W

2.2 SCDAP Input Deck for Severe Accident Analysis

The SCDAP code predicts core behavior during a severe accident. Phenomena analyzed with SCDAP include fuel rod heat up, ballooning and rupture, fission product release, rapid oxidation, zircaloy melting, UO₂ dissolution, ZrO₂ breach, flow and freezing of molten fuel and cladding, and debris formation. The RELAP5/MOD3/SCDAP code fully couples the SCDAP and RELAP5/MOD3 codes at each time step. Figure 2-1 shows the functional interaction of the SCDAP and RELAP5/MOD3 codes. Therefore, a general plant deck for LOCA, plant transient, and severe accident analysis can be created by modeling the core fuel and other heat structures with SCDAP components, and modeling the remainder of the system with RELAP5/MOD3 components. This section describes the SCDAP core model.

2.2.1 Core Nodalization

The Calvert Cliffs reactor core is described with three radial regions and ten axial nodes per region to enhance the severe accident prediction capability of the input deck as explained in Section 2.1.1.1. Figure 2-3 shows this radial division. There are 217 total 14×14 fuel bundles in the core. In this plant deck the center core region contains 65 bundles with a radial peaking factor (RPF) of 1.1149, the middle core has 92 bundles with an RPF of 1.0209, and the outer core region contains 60 bundles with an RPF of 0.8453. The RPFs were determined by using typical beginning of life (BOL) power distribution data from the Calvert Cliffs FSAR (6).

The axial power distribution is given in Figure 2-12. SCDAP requires that an axial power fraction (APF) be input for each axial node in a radial region. So:

$\Sigma \text{ APF} = \text{Number of axial nodes} = 10$, for each radial region.

The APFs were determined by integrating the curve in Figure 2-12 and calculating the power fraction in each of the ten equal length axial nodes. Table 2-3 gives the resulting axial distribution.

The axial nodalization of the core was shown previously in Figure 2-2. Each of the 30 nodes contains a SCDAP fuel rod heat structure and a SCDAP control rod heat structure. Sections 2.2.2 and 2.2.3 explain the modeling of these components.

2.2.2 Fuel Pin Component Inputs

The fuel pin inputs include parameters describing the basic bundle and fuel geometry plus other key parameters. The sides of each bundle are 7.980 inches giving an area of 63.680 in^2 per bundle. The fuel rods are 136.7 inches in length with a pin diameter of 0.440 inches. There are eight zircaloy spacer grids in each bundle. Figure 2-13 shows the cross-sectional geometry of the fuel pins and the control rods.

Generally the SCDAP inputs were either calculated from fuel rod data or entered using recommended values where appropriate. The recommended values are given in the SCDAP input manual (7). The inputs that may be of special interest to the analyst are discussed here.

The SCDAP code requires power history data for the fuel rods. It was decided that selection of the generic power history data option would be best for a general model. The generic power history data extends to exposures of 33800 MWD/MT.

The SCDAP fuel behavior calculation uses a fixed gap conductance input by the user. The initial gap conductance value will vary if rod ballooning occurs during an analysis. In the plant deck a fixed gap conductance of $1000 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$ ($6.6111\text{E}+04 \text{ W/m}^2\text{-K}$) was used at all axial locations for all rods. This approximate value gave a reasonable prediction of fuel rod stored energy at 100% power. If an analysis is performed requiring highly accurate calculations of initial stored energy, some gap coefficient adjustments would be required. The code also requires input of a radial temperature distribution at each axial node. However, these temperatures will adjust when a steady-state calculation is performed with the deck. The rod gap pressure is modeled at 2620 psia ($1.806\text{E}+07 \text{ N/m}^2$) to equal the maximum design pressure.

Figure 2-12. Axial power distribution (taken from the Calvert Cliffs FSAR).

Table 2-3. Axial power distribution.

Axial node	Axial power fraction
1	0.5647
2	1.0790
3	1.3733
4	1.4925
5	1.4742
6	1.3593
7	1.1453
8	0.8240
9	0.4764
10	0.2102
Σ	10.0

SCDAP Heat Structure Geometries

Fuel Pin

r1 = fuel pellet radius
= 0.0156875 ft

r2 = clad inner radius
= 0.016000 ft

r3 = pin outer radius
= 0.018333 ft

Control Rod

r1 = B₄C radius
= 0.03583 ft

r2 = clad inner radius
= 0.03617 ft

r3 = rod outer radius
= 0.03950 ft

Radial Nodalization

Fuel pellet - 4 nodes
gap - 1 node
clad - 1 node

Control rod - 2 nodes

Figure 2-13. Calvert Cliffs fuel pin and control rod geometry.

2.2.3 Control Rod Components

Difficulties were encountered in modeling the control rods. SCDAP input was developed for Westinghouse type fuel bundles, where the control rods and fuel rods are about the same size, but the fuel bundles described in Reference 6 contain control rods that occupy the space of four fuel rods. Inputs were developed which satisfied SCDAP requirements and conserved the mass of the control rod cladding at any given axial level. The number of control rods modeled was increased four-fold, and the inner and outer radii were adjusted to conserve cladding mass. This allows accurate calculation of the time to cladding failure, the significant event in a severe accident scenario for this fuel configuration.

2.2.4 SCDAP Component Connection to RELAP5/MOD3

Figure 2-2 shows the Calvert Cliffs core with the SCDAP heat structures and the RELAP5/MOD3 fluid volumes. The SCDAP input requires that the user specify which RELAP5/MOD3 component volumes connect to each heat structure. The SCDAP heat structures are identified by the code iikkjj.

where

- ii = heat structure radial node number
- kk = heat structure axial node number
- jj = heat structure component number.

In the deck the SCDAP heat structure components are defined as follows:

Region/component	SCDAP number
Outer core/fuel rods	01
Outer core/control rods	02
Middle core/fuel rods	03
Middle core/ control rods	04
Center core/fuel rods	05
Center core/control rods	06

The fuel rod radial mesh definition includes four equally spaced nodes for the fuel pellet, one node for the fuel to clad gap, and one node for the clad, for a total of six nodes. The control rods are modeled with only two nodes because of a SCDAP limitation. Therefore, the surface temperature of the seventh axial node of the middle fuel rod sets would be cadct 050703, where cadct refers to the component temperatures. Table 2-4 lists the SCDAP quantities that can be edited using the RELAP5 minor edit or strip inputs. Note the SCDAP variables are always in SI units even if British units are selected on the RELAP5 102 card.

Table 2-4. SCDAP quantities available in RELAP5/MOD3/SCDAP minor edits.

Code	Index ^a	Quantity
CADCT	iikkjj	Component temperatures (K)
BGTH	0	Core total hydrogen generation rate (kg/s)
BGNHG	0	Core nuclear heat generation (W)
BGMCT	0	Core maximum surface temperature (K).
BGTFPRS	0	Core cumulative soluble fission product release (kg)
BGTFPRN	0	Core cumulative noncondensable fission product release (kg)
SHQIN	0	Total heat flowing through the inside surface of the flow shroud (W). (Available only if the shroud component is input.)
SHQOUT	0	Shroud total heat out (W). (Available only if the shroud component is input.)
BGTHQ	0	Core total oxidation heat generation (W)
CAOXDEO	kkjj	Component axial oxide thickness (m)
WDTQLP	jj	Thermal energy in the material from component jj that slumped below the bottom of component jj (J)
THKHPN	jj	Thickness of cohesive debris layer in component jj (m)
PGAS	jj	Gas pressure inside component jj (MPa)
HOOP	kkjj	Cladding hoop strain of component jj at axial node kk
ROCRST	kkjj	Outside radius of cladding (including the crust of the solidified material) of component jj at axial node kk (m)
RPEL	kkjj	Radius of fuel pellet of component jj at axial node kk (m)
WREMZR	kkjj	Mass of removed cladding of component jj at axial node kk (kg)
WREMUO	kkjj	Mass of removed fuel of component jj at axial node kk (kg)
DZFRQC	kkjj	Height of cohesive debris at axial node kk of component jj (m)
ACHDPN	jj	Temperature of the bottom surface of the cohesive debris layer for component jj (K)

Table 2-4. (continued).

Code	Index ^a	Quantity
REPOOL	—	Equivalent radius of the molten pool of core material (m)
ZBTRUB	jj	Elevation of the bottom of the rubble debris bed for component jj (m)
ZTPRUB	jj	Elevation of the top of the rubble debris bed for component jj (m)
ZBTCOH	jj	Elevation of the bottom surface of the cohesive debris bed for component jj (m)
ZTPCOH	jj	Elevation of the top surface of the cohesive debris bed for component jj (m)
DAMLEV	kkjj	Level of damage at axial node kk of component jj (unitless) 0.0 = intact geometry 0.1 = ruptured due to ballooning 0.2 = rubble (fragmented) 0.4 = cohesive debris 1.0 = molten pool
OXDEO	kkjj	Oxide thickness of the cladding at axial node kk of component jj (m)
RCI	kkjj	Inside radius of the cladding at axial node kk of component jj (m)
RULIQ	kkjj	Outside radius of the solid part of the fuel pellet at axial node kk of component jj (m)
RCO	kkjj	Outside radius of the cladding (not including the crust of solidified material) at axial node kk of component jj (m)
H20XD2	kkjj	Hydrogen production rate at axial node kk of component jj (kg/s)

a. *ii* is the radial number, *kk* is the axial number, and *jj* is the component number. For example, if the temperature is to be plotted at the sixth radial node of the fourth axial node of the third component, then the code CADCT with index 060403 would be specified.

2.3 NPA Description

The NPA allows the user to observe a RELAP5/MOD3/SCDAP analysis with the thermal-hydraulic, heat transfer, control system, and trip data animated on a computer terminal screen. Also, interactive inputs can be selected by the user to trip pumps, begin ECCS flow, etc. while observing the calculation. Reference 2 and 3 explain the NPA display system. This section will explain the necessary information to use the Calvert Cliffs plant deck with the NPA.

There are two files required to use the NPA. These are the pax file (<file name>.pax) and the dls file (<file name>.dls). These files drive the NPA mask, which is an animated display of the reactor system for NPA use. The techniques for creating these files are given in References 2 and 3. For the Calvert Cliffs deck two masks were created. The system mask displays all the significant system parameters plus some SCDAP core parameters. The core mask shows the reactor core and the core inlet plenum, but is driven by detailed SCDAP data that will show severe accident phenomena. Pax and dls files have been developed for both masks.

2.3.1 NPA System Mask

Figure 2-14 shows the NPA system mask with the display at steady state conditions. There are several NPA display components used in this mask. These are: (a) thermo-colors; (b) rod/chan; (c) levels; (d) digital displays; (e) on/off; and (f) magnitude indicators. The thermo-color option is used to display fluid conditions in the primary coolant loops, reactor vessel, and the steam generator secondary. A RELAP5/MOD3 component is associated with a defined region on the mask via the pax file and the RELAP5 code then inputs the void fraction (voidg), fluid temperature (tempf), gas temperature (tempg), saturation temperature (sattemp), and noncondensable state data to the NPA. The color shown on the mask is a function of these parameters. Table 2-5 shows the color selection. The NPA user has the option of changing the color selection scheme when developing the pax file. Default values were generally used in the Calvert Cliffs masks and it is recommended these not be changed.

The Rod/Chan display option is used in the core. With this option selected the thermal-hydraulic parameters in the core are shown with the thermo-color scheme on the outside of the mask component. The fuel rod behavior is displayed on the inside of the component. Rod surface temperature is indicated by color changes, and a temperature (°F) versus color chart is included on the mask. Other core behavior phenomena are also shown when the Rod/Chan option is used. Core damage is indicated when the rod and the fluid region colors change to gray. Rod ballooning and oxidation are shown as changes in the rod radius on the mask. Control rod parameters are not shown on the system mask to keep the display from becoming too crowded.

The level display is used in the pressurizer, the accumulators, and in the downcomers of both steam generator secondaries. This NPA component displays a calculated level from RELAP5 as a colored box whose height represents the level.

Digital indicators of the following parameters, in British units, are included:

1. Reactor power

Table 2-5. Thermo-color displays.^a

Liquid/vapor	Subcooled	Saturated	Superheated
Subcooled	Green	Cyan	Orange
Saturated	—	Blue	Magenta
Superheated	—	—	Red

a. A vapor void fraction exceeding 0.01 will cause the displayed color to lighten.

2. Mass flow in each hot leg
3. Upper plenum pressure, Steam generator pressures.

It should be noted that the NPA defaults to SI values for all parameters. For example, conversion factors were input to convert the digital indicator outputs to British units. If a user adds a new digital indicator it would also be necessary to include a conversion factor to maintain consistency.

On/off indicators are used to show if valves are open, pumps are running, etc. White is used to indicate an open valve or an operating pump, black indicates a tripped pump or a closed valve. The On/off option is applied to the following parameters:

1. Reactor coolant pumps, make up and letdown pumps
2. HPI and LPI pumps, accumulator isolation valves
3. Pressurizer PORV, SRV, and heater.

The magnitude display option is used to animate the remaining valves. This option represents a specified data range with a predefined color scale. In this case, fully closed valves are black, fully open valves are white, and partially open valves are a shade of gray.

Finally, any parameter calculated by the RELAP5/MOD3 or the SCDAP portions of the code may be displayed graphically by selecting the plot option and then identifying the desired variable or variables. These plots will be displayed on the terminal screen in SI units.

The following figures and tables summarize the parameters that are displayed on the Calvert Cliffs system mask.

Display	Figure	Table
Thermo-colors	2-15	2-6
Rod/chan and magnitude	2-16	2-7
Level and on/off	2-17	2-8
Digital	2-18	2-9

2.3.2 NPA Core Region Mask

A separate mask was developed for the core region because the system mask display would become too crowded if detailed core behavior phenomena and system thermal-hydraulics were displayed on one animation. The core mask uses the Rod/Clad/Chan option, which is similar to the Rod/Chan option explained above but gives more detail.

Figure 2-19 shows the NPA core mask. Parameters displayed included: (a) The thirty core region volume components; (b) The thirty SCDAP core fuel rod heat structures; (c) The SCDAP control rod heat structures; (d) The core inlet plenum volume; (e) Fixed graphic displays of core oxidation, core hydrogen generation, and maximum clad temperature. To save computer space only the five even numbered control rod components were modeled for each radial region. That is the second control rod structure from the bottom, the fourth, etc. are described.

The core behavior is displayed with the Rod/Clad/Chan option. This option displays rod temperature across the rod radius at each axial node. The fuel pellet radius, clad radius, clad deformation and oxidation, and core damage are all displayed. The thermal-hydraulic conditions in the core channels are shown using the thermo-color scheme, and the rod temperatures vary according to the temperature versus color chart on the mask. Thus, the core mask will give a larger and more detailed display of core phenomena than the system mask.

The core inlet plenum conditions are given using the thermo-color display. The fixed graphs differ from the graphs produced by using the plot option in that they are in British rather than SI units. It is not possible to change the scales on these graphs.

2.3.3 Interactive Options for the Calvert Cliffs NPA

The NPA provides a visual and graphic display of the predictions of the RELAP5/MOD3/SCDAP model. It also allows the analyst to interactively simulate operator actions during problem execution. Table 2-10 lists the interactive options that are available to the user. The interactive parameters are selected by clicking the mouse control with the cursor on the appropriate mask component to get the interactive options list displayed. For example, clicking on the reactor coolant pump component will display the pump trip option. Output and restart files are created during interactive runs so the time that the interactive operations are performed will be recorded.

Table 2-6. Calvert Cliffs NPA display—THERMO-COLOR parameters.

Region	Number ^a	Component number
Loop 1		
Hot leg	1	10501
Steam generator inlet plenum	2	12001
U-tubes (primary side)	3–11	12501-12509
Steam generator outlet plenum	12	13001
Loop 1a cold leg (suction)	13–15	13201,13401,13601
Loop 1a cold leg (discharge)	16	14501
Loop 1b cold leg (suction)	17–19	16201,16401,16601
Loop 1b cold leg (discharge)	20	17501
Loop 2		
Hot leg	21	20501
Steam generator inlet plenum	22	22001
U-tubes (primary side)	21–31	22501-22509
Steam generator outlet plenum	32	23001
Loop 2a cold leg (suction)	33–35	23201,23401,23601
Loop 2a cold leg (discharge)	36	24501
Loop 2b cold leg (suction)	37–39	26201,26401,26601
Loop 2b cold leg (discharge)	40	27501
Reactor Vessel		
Lower plenum	41	57501
Upper plenum	42	52001
Upper head	43	55001
Downcomer (Loop 1a side)	44–49	56601,57102-57106
Downcomer (Loop 1b side)	50–55	56701,57202-57206
Downcomer (Loop 2a side)	56–61	56801,57302-57306
Downcomer (Loop 2b side)	62–67	56901,57402-57406
Steam Generator Loop 1		
Tube bundle region	68–71	31001-31004
Separator inlet region	72, 73	31501,32001
Separator	74	32501
Steam dome	75	34001

Table 2-6. (continued).

Steam Generator Loop 2

Tube bundle region	76-79	41001-41004
Separator inlet region	80, 81	41501,42001
Separator	82	42501
Steam dome	83	44001

a. This number refers to the labeled components in Figure 2-15.

Table 2-7. Calvert Cliffs NPA display—ROD/CHAN and MAGNITUDE parameters.

Region	Number ^a	Heat conductor number ^b	Thermal-hydraulic component number
ROD/CHAN Parameters			
Outer core	1-5	0201, 0401, 0601, 0801, 1001	51302, 51304, 51306, 51308, 51310
Middle core	6-10	0203, 0403, 0603, 0803, 1003	51502, 51504, 51506, 51508, 51510
Center core	11-15	0205, 0405, 0605, 0805, 1005	51702, 51704, 51706, 51708, 51710
MAGNITUDE Parameters			
Loop 1 MFIV	16		vlvarea 734
Loop 1 MSIV	17		vlvarea 390
Loop 1 SRV	18		cntrlvar 385
Loop 1 ADV	19		cntrlvar 956
Loop 1 AFW	20		cntrlvar 785
Loop 2 MFIV	21		vlvarea 744
Loop 2 MSIV	22		vlvarea 490
Loop 2 SRV	23		cntrlvar 435
Loop 2 ADV	24		cntrlvar 957
Loop 2 AFW	25		cntrlvar 786
Pressurizer spray	26		cntrlvar 1867

a. This number refers to the labeled components in Figure 2-16.

b. The ROD/CHAN display option shows both fuel rod behavior data and thermal-hydraulic data. The fuel rod parameter is the SCDAP heat structure associated with the NPA location. The format used to number this heat structure is kkjj,

where

kk = axial location

jj = component number.

Table 2-8. Calvert Cliffs NPA display—LEVEL and ON/OFF parameters.

Region	Number ^a	Variable number
Level Displays		
Pressurizer	1	cntrlvar 1845
Loop 1 steam generator downcomer	2	cntrlvar 325
Loop 2 steam generator downcomer	3	cntrlvar 425
Accumulator 1a	4	cntrlvar 1842
Accumulator 1b	5	cntrlvar 1841
Accumulator 2b	6	cntrlvar 1843
Accumulator 2a	7	cntrlvar 1844
On/Off Displays		
Loop 1a HPI	8	cntrlvar 830
Loop 1b HPI	9	cntrlvar 831
Loop 2a HPI	10	cntrlvar 832
Loop 2b HPI	11	cntrlvar 833
Loop 1a LPI	12	cntrlvar 845
Loop 1b LPI	13	cntrlvar 846
Loop 2a LPI	14	cntrlvar 847
Loop 2b LPI	15	cntrlvar 848
SRV	16	vlvarea 652
PORV	17	vlvarea 651
Loop 1a pump	18	cntrlvar 1834
Loop 1b pump	19	cntrlvar 1835
Loop 2a pump	20	cntrlvar 1836
Loop 2b pump	21	cntrlvar 1837
Makeup pump 1	22	cntrlvar 1850
Makeup pump 2	23	cntrlvar 1850
Makeup pump 3	24	cntrlvar 1850
Let down pump	25	cntrlvar 648
Accumulator isolation valve 1a	26	cntrlvar 1861
Accumulator isolation valve 1b	27	cntrlvar 1862
Accumulator isolation valve 2b	28	cntrlvar 1863
Accumulator isolation valve 2a	29	cntrlvar 1864
Pressurizer heater	30	cntrlvar 615

a. This number refers to the labeled components in Figure 2-17.

Figure 2-18. Calvert Cliffs NPA digital display parameters.

Table 2-9. Calvert Cliffs NPA display—DIGITAL parameters.

Quantity	Number ^a	Variable number	
Upper plenum pressure	1	p	52001
Loop 1a pump rpm	2	pmpvel	140
Loop 1b pump rpm	3	pmpvel	170
Loop 2a pump rpm	4	pmvel	240
Loop 2b pump rpm	5	pmpvel	270
Loop 1 steam generator MSIV flow	6	mflowj	39000
Loop 1 SRV flow	7	mflowj	38500
Loop 1 ADV flow	8	mflowj	36500
Loop 1 steam generator dome pressure	9	p	32501
Loop 1 AFW flow	10	mflowj	7710
Loop 1a cold leg temperature	11	temp	13201
Loop 1a cold leg pressure	12	p	13201
Loop 1b cold leg temperature	13	tempf	16201
Loop 1b cold leg pressure	14	p	16201
Loop 2 steam generator MSIV flow	15	mflowj	49000
Loop 2 SRV flow	16	mflowj	48500
Loop 2 ADV flow	17	mflowj	46500
Loop 2 steam generator dome pressure	18	p	42501
Loop 2 MFW flow	19	mflowj	74600
Loop 2 AFW flow	20	mflowj	77300
Loop 1 MFW flow	21	mflowj	73600
Loop 1 hot leg flow	22	mflowj	10000
Loop 1 hot leg temperature	23	tempf	10501
Loop 2 hot leg flow	24	mflowj	20000
Loop 2 hot leg temperature	25	tempf	20501
Time	26	time	0
Loop 2a cold leg temperature	27	tempf	23201
Loop 2a cold leg pressure	28	p	23201
Loop 2b cold leg temperature	29	tempf	26201
Loop 2b cold leg pressure	30	p	26201
SRV flow	31	mflowj	65200
PORV flow	32	mflowj	65100
Core power	33	cntrlvar	1868

a. This number refers to the labeled components in Figure 2-18.

Figure 2-19. Calvert Cliffs NPA core mask

Table 2-10. Calvert Cliffs mask interactive commands.

Component	Command	Function
Reactor coolant pumps	Start Stop Auto	Manually on at rated speed Manually trip pump Automatic control
Control panel	Start RCPs Stop RCPs Auto RCPs Initiate SI Inhibit SI Auto SI Scram No scram Auto scram Turbine trip No turbine trip Auto turbine trip SGIS No SGIS Auto SGIS	Start all RCPs Manually trip all RCPs Automatic control all RCPs Manual SI signal SI signal manually inhibited Automatic operation Manual reactor trip Reactor trip inhibited Automatic operation Manual turbine trip signal Turbine trip signal inhibited Automatic operation Manual SG isolation signal SG isolation signal inhibited Automatic operation
ECC header	HPI1 HPI2 LPI	One pump delivery multiplier (0–1) Two pump delivery multiplier (0–1) LPI pump delivery multiplier (0–1)
Spray valve	Open Close Auto Offset	Valve manually wide open Valve manually closed Automatic operation User enters $-1 < x < 1$ to vary normal area
Accumulators	Isolate Auto	Isolate accumulator Automatic operation

Table 2-10. (continued).

Component	Command	Function
Pressurizer heater	On	Manually full on
	Off	Manually off
	Auto	Automatic operation
	Offset	User enters $-1 < x < 1$ to vary power by $-2 \text{ MW} < p(x) < 2 \text{ MW}$
PORV	Open	Manually open PORV
	Close	Manually close PORV
	Auto	Automatic operation
Makeup pump	No pumps	No MU pumps operating
	Two pumps	Two MU pumps operating
	Three pumps	Three MU pumps operating
	Auto	Automatic operation
Letdown pump	Max	Maximum letdown flow
	Isolate	Letdown isolated
	Auto	Automatic operation
	Offset	User enters $-0.03 < x < 0.03$ to vary velocity by $-0.3 < v(x) < 0.3$
Main feed valves	Open IV	Manually open isolation valve
	Close IV	Manually close isolation valve
	Auto IV	Automatic operation
	Open RV	Manually open regulating valve
	Close RV	Manually close regulating valve
	Auto RV	Automatic operation
	Offset RV	User enters $-1 < x < 1$ to vary normal area
	Open BV	Manually open bypass valves
	Close BV	Manually close bypass valves
	Auto BV	Automatic operation
	Offset BV	User enters $-1 < x < 1$ to vary normal area
Main steam isolation valves	Open	Manually open MSIV
	Close	Manually close MSIV
	Auto	Automatic operation

Table 2-10. (continued).

Component	Command	Function
Main feed pumps	On Off Auto	Pump manually on Pump manually tripped Automatic operation
Atmospheric dump valves	Open Close Auto Offset	Manually open ADV Manually close ADV Automatic operation User enters $-1 < x < 1$ to vary normal area
Turbine bypass valves	Open Close Auto Offset	Manually open TBV Manually close TBV Automatic operation User enters $-1 < x < 1$ to vary normal area
Auxiliary feedwater valves	Feed No feed Flow	Manual full feed Manually block feedwater User enters $0 \leq x \leq 2$ to set flow from none to 200%

3. PLANT DECK APPLICATIONS

Three calculations were performed to test the Calvert Cliffs plant deck to assure that it produces reasonable results when applied for the prediction of plant transients and accidents, and also to check the proper function of the basic features of the model. The calculations were also displayed on the NPA to check out the mask. The calculations selected were a loss of feedwater transient (LOFW), a small break loss of coolant accident (SBLOCA), and a large break loss of coolant accident (LBLOCA). This selection was judged to provide a representative set of problems for evaluating the model. These problems are intended as a test of the plant deck rather than as an independent validation of the RELAP5/MOD3/SCDAP code.

A calculation was run without the activation of any trips to obtain a steady state at 100% power, 100% flow conditions. The results of the steady state calculation are summarized in Table 3-1. If the analyst desires to obtain a steady state at nonrated conditions, then the analyst will need to perform another analysis of this type adjusting the power (RELAP5 Table 900 word 4) and changing the initial reactor coolant pump speed as required. No major problems would be anticipated in doing this. The time is reset to zero by restarting the steady state run with stdy-st input on word 2 of RELAP5/MOD3 card 100. This will also write a very short restart-plot file that can be used to begin transient calculations. Therefore, it is not necessary to perform input processing for every calculation.

3.1 Loss of Feedwater Transients

The results of the LOFW analyses are presented in this section. A LOFW transient will cause a loss of steam generator heat transfer and RCS over-pressurization. If feedwater flow for the steam generators cannot be reestablished it would require several hours to recover from this type of transient. The plant operators would use feed and bleed techniques to maintain the mass inventory of the primary system and to control the primary pressure. Safety injection could be required to assure recovery. Since this calculation was performed only to test the input deck the analysis was stopped at 2500 s after the transient initiation. Feed and bleed recovery procedure would be used after this time if the MFW pumps have not been restarted.

The boundary conditions for the LOFW analyses are:

1. Rated power and flow at the time of transient initiation
2. Trip MFW pumps to begin transient
3. Assume failure of the auxiliary feedwater system
4. Operator trip of the RCPs at 420 s after the start of the transient to simulate operating procedures
5. SCRAM was set to occur at 30 s, bypassing the automatic trip logic.

Table 3-1. Steady state parameter comparison.

Parameter	RELAP5/MOD3	Desired value	Source
Primary:			
Mass flow (lb _m /s)	42 361.0	42 282.0	BG&E 4 ^a
Hot leg temp. (°F)	598.8	594.6	BG&E 2 ^a
Cold leg temp. (°F)	552.8	547.1	BG&E 2 ^a
Pressure (psia)	2250.1	2250.0	Ref. 6
PZR level (in.)	215.9	215.0	LANL ^b
Core power (MW)	2700.0	2700.0	BG&E 2 ^a
ΔP _{SG} (psi)	35.0	28.15	BG&E 5 ^a
ΔP _{PUMP} (psi)	77.0	78.73	BG&E 5 ^a
Bypass flows (%)			
Guide tube	1.94	1.89	CE 2 ^c
HL nozzle (leak)	0.60	0.62	CE 2 ^c
UH to DC	0.092	0.097	CE 2 ^c
Secondary			
Pressure (psia)	872–883	870–880	BG&E 2 ^a
Mass (lb _m)	150000.0	138000.0	CE 1 ^c
NR level (in.)	0.15	0.0	BG&E 6 ^a
WR level (in.)	-62.1	-70.0	BG&E 10 ^a
Recirculation ratio	3.6	4.0	CE 1 ^c
Steam flow (lb _m /s)	3268.5	3268.0	BG&E 2 ^a
MFRV area (%)	90.0	90.0	Ref. 8

a. Information received from Baltimore Gas and Electric (BG&E) as part of the pressurized thermal shock study.

b. Information received from Los Alamos National Laboratory (LANL) as part of the pressurized thermal shock study.

c. Information received from Combustion Engineering (CE) as part of the pressurized thermal shock study.

Boundary condition five was imposed because the system behavior in a LOFW transient is very sensitive to the time of SCRAM. In a previously performed LOFW analysis of the Calvert Cliffs system (4) the reactor tripped at approximately 30 s. Therefore, assumption five was used to aid in evaluating the input deck by making the boundary conditions similar to those in the previous analysis.

Figure 3-1 shows the calculated pressurizer pressure during the 2500 second transient. The pressure initially rises because the turbine stop valve (TSV) closes on the feedwater pump trip. A combination of the opening of the PORV at 2400 psia (16.55 MPa), reactor scram, and opening of the turbine bypass valves causes the pressure to drop rapidly after 20 s. The PORV closes at 2280 psia (15.72 MPa). After 80 s the pressure generally begins to increase because of reduced steam generator heat transfer. The pressure drop between 530 and 610 s is a result of the opening and closing of the turbine bypass valve (TBV). The TBV area varies as a function of average primary temperature and ΔT (hot leg—cold leg temperature), and these two variables change when the pumps trip at 420 s. At 1840 s the PORV begins to cycle resulting in pressure oscillations between the PORV set points.

Figure 3-2 shows the calculated steam generator mass for both the Loop 1 and Loop 2 steam generators. The mass immediately begins to fall below the initial mass of 150 000 lbm (68 MT) after feedwater pump trip. The mass loss stops when the TBV closes between 580 and 800 s. The U-tubes begin to uncover after 400 s and become essentially uncovered by 1750 s.

Figure 3-3 shows the steam generator pressures. The pressure initially rises after feedwater is lost, but then drops back to its initial value of 875 psia after scram. The steam dump and turbine bypass control system acts to maintain constant pressure during this part of the transient. The pressure drops when the TBV opens after the RCPs trip as was explained above. When the TBV closes, the pressure increases until the TBV again opens at 800 s. The pressure then remains constant until the U-tubes effectively uncover and the heat transfer into the steam generators becomes very low. The pressure then decreases. The figure indicates that there is some asymmetric behavior between the two loops with the Loop 2 steam generator U-tubes uncovering before the U-tubes in Loop 1. This asymmetry can be attributed to the pressurizer influence on heat transfer during the period before reactor scram. Less mass was lost in the pressurizer loop (Loop 1) during the initial part of the transient because some heat is transferred from Loop 1 to the pressurizer and therefore, U-tube uncover occurs later in Loop 1 than in Loop 2.

Figure 3-4 shows the hot and cold leg temperatures. The temperature behavior is identical for both loops during the period before 1800 s. The temperature increases until reactor trip, then decreases to 535°F (553 K) in the hot legs and 533°F (552 K) in the cold legs. It remains constant until RCP trip at 420 s. After the RCPs trip the primary system ΔT increases because of the drop in core flow. When the TBVs close at 580 s the cold leg temperature increases because of lower heat transfer. The hot leg thermo-hydraulic parameters lag the cold leg parameters because the system fluid transit time is long during natural circulation. The temperatures are constant between 800 and 1750 s. When the U-tubes effectively uncover the cold and hot leg temperatures begin increasing again with the Loop 2 cold leg temperature rising before the Loop 1 temperature because the tubes uncover sooner in Loop 2 as explained above.

Calvert Cliffs Unit 1
Loss of Feedwater Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-1. Pressurizer pressure.

Calvert Cliffs Unit 1
 Loss of Feedwater Transient
 RELAP5/MOD3/SCDAP (7o)

Figure 3-2. Steam generator mass.

Calvert Cliffs Unit 1

Loss of Feedwater Transient

RELAP5/MOD3/SCDAP (7o)

Figure 3-3. Steam generator pressures.

Calvert Cliffs Unit 1

Loss of Feedwater Transient

RELAP5/MOD3/SCDAP (7o)

Figure 3-4. Hot and cold leg liquid temperatures.

The Loop 1 coolant flows are given in Figure 3-5. There are some flow changes early in the transient because of pressurizer surges, but the flow is then constant until RCP trip at 420 s. Recirculation flow continues to cool the core after pump trip.

Pressurizer level is given in Figure 3-6. The normal level is 215 inches. The pressurizer would be full at 345 inches. The level follows the same behavior as the reactor pressure, swelling initially until reactor trip, then dropping but beginning to rise again when the pressure begins to increase. When the PORV starts to cycle at 1840 s the pressurizer level continues increasing because the PORV flow is steam but the surge line flow is liquid. The level would be expected to increase until the pressurizer is full.

3.2 Large Break LOCA Accident

A large break LOCA event was initiated by a 200% double-ended guillotine break in the Loop 1B cold leg. This analysis was performed to test the plant decks applicability for the prediction of LOCAs that could begin severe accident scenarios. To model a large break it is necessary to add some additional volumes to the deck as shown in Figure 3-7. These additions are necessary because the basic deck does not include components that simulate breaks. Since there are many locations where a break could occur and also many possible sizes for each break, it would be difficult to include generalized components for break modeling. However, as seen in the figure it is simple to add the necessary components. Junction 191 represents the normal flow path. This flow path is modeled with a valve so that it can be closed when the guillotine break occurs. Junctions 193 and 195, representing the break flow paths, are then opened.

The following assumptions are used as boundary conditions:

1. 200% double-ended guillotine break
2. Accumulator flow inhibited (this was done to increase clad temperature increase for input deck evaluation purposes).

Figure 3-8 shows the calculated upper head pressure (Component 555010000). There is a very rapid pressure drop from 2250 to 1400 psia (15.5 to 9.6 MPa) during the subcooled blowdown period. The pressure drop becomes more gradual with the vessel pressure dropping to containment pressure by 25 s. This is the anticipated trend in a large break LOCA.

Figure 3-9 shows the break flow. Vessel side break flow (Component 195) is higher than the cold leg side (Component 193) as is normally the case. The maximum break flow rate is approximately 120 000 lbm/s (54 MT/s). The blowdown ends at approximately 25 s. ECCS bypass is indicated by flow surges through the break junctions after the end of blowdown. It should be noted here that RELAP5/MOD3 uses the Ransom-Trapp critical flow model for the prediction of break flow. This calculation is implicit in the code numerical solution so a table look-up method using a published break flow model such as the Moody model, is not used. The Ransom-Trapp model was derived using a thermal-equilibrium assumption in the two-phase flow regime, and therefore tends to approach the homogeneous equilibrium break flow rate.

Calvert Cliffs Unit 1
Loss of Feedwater Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3.5 Loop 1 coolant flow.

Calvert Cliffs Unit 1
Loss of Feedwater Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3.6 Pressurizer level.

Figure 3.7 Break nodalization for a large break LOCA.

Calvert Cliffs Unit 1
Large Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3.8 Upper head pressure.

Calvert Cliffs Unit 1
Large Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3.9 Break flow.

Figure 3-10 shows the inlet flow to the center core region. The flow reverses immediately after the time of break, then reverses again as condensation begins in the primary-side of the U-tubes. Upward flow in the core is short-lived because the primary pressure drops below the secondary pressures at 6 s, changing the condensation to vaporization. Steam is no longer drawn toward the U-tubes and again flows down through the core toward the vessel-side break. The core inlet flow becomes oscillatory after the ECC flow begins to reach the core inlet. Some of the calculated oscillations may be a result of numerical instabilities in the condensation rate calculation.

The highest clad temperature is shown in Figure 3-11. The location of the highest temperatures is at the fourth axial node from the bottom of the center core. This is also the highest power location. CHF occurs immediately after time of break causing a rapid temperature increase to 1772°F (1240 K). The upward flow described above slowed the temperature rise at 3 s, but temperatures remained high until downward flow of steam resumed at 7 s, carrying with it liquid ejected from the Loop 2 hot leg when vaporization occurred. At 12 s the heatup began because of core dry out. The second heatup was slower than the initial temperature rise because some of the stored energy in the core was removed. The PCT rose to 1952°F (1340 K), higher than expected in an actual LBLOCA because the accumulators were inhibited, before ECCS flow increased the core heat transfer and the temperature began to decrease.

3.3 Small Break LOCA Calculation

A small break with an area of 0.01 ft² (1.35 inch diameter) was simulated in the Loop 2B cold leg. The break, shown in Figure 3-12, is modeled with a single junction so that the crossflow option may be used. Primary pressure will drop low enough for high pressure injection (HPI) to initiate for breaks of this size, and the break flow rate will exceed the maximum HPI flow rate.

The boundary conditions for this calculation are taken from Reference 4 and are as follows:

1. One hundred percent core power.
2. One available HPI pump.
3. Reactor coolant pumps trip according to the emergency operating procedures (EOPs). The first two RCPs trip 30 s after the Pressurizer pressure equals 1725 psia (11.9 MPa), and the remaining RCPs trip 30 s after the RCS pressure equals 1300 psia (9 MPa) and the RCS subcooling drops below 30°F (17 K).

Figure 3-13 shows the predicted pressurizer (primary) and secondary pressures for the analysis that was run for 3300 s of transient time. After the break at $t=0.0$ s, the primary pressure drops rapidly to 1350 psia (9.3 MPa) during the initial 84 s. The depressurization rate then becomes more gradual. The secondary pressure initially rises. The low pressure scram signal occurs at 24 s and the steam generator pressures approach the initial value of 875 psia (6 MPa) shortly thereafter. The first two RCPs trip at 78.5 s followed by the trip of the second two RCPs at 255 s. The second trip induces the turbine bypass valve (TBV) to open at 340 s and close at 420 s. This causes a rapid drop in secondary pressure followed by a pressure increase at 420 s. The primary depressurization rate

Calvert Cliffs Unit 1
Large Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-10. Core inlet flow—center core.

Calvert Cliffs Unit 1
Large Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-11. Maximum clad temperature.

Figure 3-12. Break nodalization for a small break LOCA.

Calvert Cliffs Unit 1 Small Break LOCA Transient RELAP5/MOD3/SCDAP (70)

Figure 3-13. Primary and secondary pressures.

also increases when the valve opens due to increased heat transfer from the primary to the secondary. The primary and secondary pressure curves converge after 500 s. Between 500 and 1800 s there is little change in the pressure indicating that the heat transfer to the secondary plus the energy loss through the 0.01 ft² break approximately equals the heat generated in the core. During this period the heat transfer to the secondary decreases due to voiding in the primary side of the U-tubes but the energy loss through the break remains constant. The core energy generation is of course decreasing continuously. After 1800 s the primary and secondary pressures decouple with the primary pressure decreasing while the secondary pressure remains constant. There is little heat transfer between the two systems at this time because of U-tube voiding and recirculation flow stagnation but the break flow is removing more energy than is generated by the core causing the primary to depressurize. The break flow becomes two-phase after 2800 s increasing the energy flow out the break and increasing the depressurization rate.

Figure 3-14 shows the hot leg temperature for both loops. The temperatures are identical and therefore the two curves overlay. The temperature initially drops after reactor scram and then becomes constant at 533°F (552 K) after the first two RCPs trip at 78.5 s. When the remaining RCPs trip at 255 s the temperature begins to increase but drops when the TBVs open at 340 s. When the primary and secondary pressures converge after 500 s the hot leg temperature remains constant following the pressure trends. When the break flow becomes two-phase and the energy loss through the break increases at 2800 s, the temperature begins to drop.

The pressurizer level is given in Figure 3-15. The initial level is 215 inches, the nominal steady state value. The level drops rapidly and the pressurizer empties by 73 s. Because a small amount of dispersed liquid remains in the pressurizer the level does not indicate zero.

The break flow is shown in Figure 3-16. The break flow is single phase liquid until about 2800 s as was explained above. The peak break flow of 240 lbm/s (109 Kg/s) occurs immediately after the time of break. Between 0 and 900 s the break flow follows the trends in the primary pressure explained above. After 900 s some oscillations are seen in the break flow curve. Voiding and condensation on the primary side of the U-tubes induces pressure and enthalpy fluctuations that affect the break flow calculation. Abrupt changes in the break flow occur after the flow becomes two-phase at 2800 s. The void fraction upstream of the break fluctuates resulting in rapid changes in the flow. The energy loss through the break increases during two-phase flow because of the high internal energy of the vapor phase.

Figure 3-17 shows the predicted hot leg void fraction. Voiding begins in the hot leg shortly after the second RCP trip at 255 s. The void fraction generally increases until 900 s when voiding and condensation in the primary side of the U-tubes induces flow and pressure oscillations, which in turn result in void fraction fluctuations. After the U-tubes have voided and flashing occurs in the pump inlet piping downstream of the steam generator, the hot leg void increases rapidly from a value of approximately 0.24 to 0.50. After this rapid rise, the void fraction further increases until the hot legs are nearly 90% voided. When two-phase break flow begins at 2800 s, the void fraction drops due to a temperature drop in the primary system.

The void fraction immediately upstream of the break in the Loop 2B cold leg is given in Figure 3-18. The onset of two-phase break flow at 2800 s can be seen clearly in this figure.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-14. Hot leg temperatures.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-15. Pressurizer level.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-16. Break flow.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-17. Hot leg void fraction.

Calvert Cliffs Unit 1
 Small Break LOCA Transient
 RELAP5/MOD3/SCDAP (7o)

Figure 3-18. Void fraction upstream of the break.

The inlet flows to the three core channels modeled in the Calvert Cliffs plant deck are shown in Figure 3-19. The flows drop initially when the first two RCPs trip at 78.5 s and drop again after the second trip at 255 s. Ample natural circulation flow is available to the core from the time of the last RCP trip until approximately 900 s. U-tube voiding then begins to inhibit natural circulation and flow surges followed by flow stagnation are seen between 900 and 1450 s. After 1450 s reflux boiling begins.

Figure 3-20 shows the total HPI flow. A comparison of integrated break and ECC (HPI) flow is given in Figure 3-21. High pressure injection is initiated on low system pressure at 150 s. Between 500 and 2800 s the HPI flow rate is approximately 65 to 100 lbm/s (29 to 45 Kg/s) less than the predicted break flow during this period. Figure 3-21 indicates that the total mass loss through the break is 490 000 lbm (222 MT) at 3000 s with only 180 000 lbm (82 MT) of ECC liquid resupplied to the system during this time.

Figure 3-22 shows that the vessel collapsed liquid level dropped rapidly until the hot leg centerline was reached, at which time flow out of the vessel was reduced and the U-tubes began to void. The collapsed liquid level remained constant in the upper plenum while coolant drained from the legs, but fluctuated when two phase flow out the break began, and dropped momentarily below the top of the fuel. However, the frothy mixture in the voided core volumes was sufficient to cool the cladding, as seen in Figure 3-23, for the PCT did not rise at the time of core uncover, but instead dropped because of increased core flow. The PCT never rose above its initial value.

3.4 User Instructions and Recommendations

This discussion is primarily directed to the user who wishes to perform studies of thermal-hydraulic transients and severe accidents using the Calvert Cliffs plant deck, but does not have time to become highly familiar with the RELAP5/MOD3/SCDAP code and the code applications procedures. The NPA capability is very helpful for allowing a user to conduct analyses with a minimum amount of input data manipulation. Users who desire to obtain a greater knowledge of the RELAP5/MOD3/SCDAP code should attend one of the Code Users seminars conducted by EG&G Idaho.

The preferred method for executing an analysis with the deck is illustrated in Figure 3-24. Five steps are diagramed in the figure and the first three steps have already been completed as part of the deck development process. The user must do steps four and five to complete a calculation. An explanation of the steps is as follows:

Step 1

Perform a calculation without trips to achieve the desired steady state conditions based on plant data at 100% power conditions. The restart-plot file created by the steady state calculation is large in terms of computer space and has an end time of 1000 s.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-19. Core inlet flow.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-20. Total HPI flow.

Calvert Cliffs Unit 1
 Small Break LOCA Transient
 RELAP5/MOD3/SCDAP (7o)

Figure 3-21. Integrated break and ECCS flows.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-22. Collapsed liquid level.

Calvert Cliffs Unit 1
Small Break LOCA Transient
RELAP5/MOD3/SCDAP (7o)

Figure 3-23. Peak clad temperature.

Figure 3-24. Problem execution using the Calvert Cliffs plant deck.

Step 2

It is convenient for the user to reduce the size of the restart-plot file created in Step 1 and to reset the time from 1000 to zero. When a user begins a transient analysis the transient will begin at zero s. This is accomplished by restarting with `stdy-st` selected on word two of RELAP5 Card 100. On Card 105 use 100. for word one, 101. for word two, and 10. for word three. Word three is the CPU time limit and words one and two are CPU time remaining limits. The code will not execute but will reset the time to zero and write a restart-plot file containing only data from the last edit of the steady-state. This provides a file from which any transient analyses can begin.

Step 3

Run the PYGI program to create a deck with steady-state conditions. The PYGI program is an applications code that will rewrite a RELAP5/SCDAP deck with updated pressure, internal energy, and flow data. The remainder of the input is unaltered from the base deck, so the new deck contains steady-state thermal-hydraulic conditions.

Step 4

The analyst will create a restart deck with appropriate input to simulate the desired transient or accident and then execute the problem by restarting from the file created in Step 2. The deck created in Step 3 can provide useful input for the restart deck because the thermal-hydraulic data will match the data on the restart-plot file. Assume that the user desires to trip two of the RCPs at 10 s. This change can be accomplished by adding the inputs for these two pumps with new trip numbers. The inputs in the steady-state deck will have the correct pump pressure, internal energy, pump speed and pump fluid velocity. The analyst will only change the trip number to trip the pumps.

Step 5

Printed output and restart-plot files will be automatically generated. The analyst may also desire to review the results using the NPA. This is done by using the replay option on the NPA.

The alternative for performing a calculation is to use the NPA and execute interactively. This is often a very useful method of executing a problem because the required manipulation of input data can be reduced. For example, an analysis of a stuck open PORV transient can be initiated by using the NPA to select the full open position of the PORV and begin execution. However, the recommendation is to use the method explained above for problem execution. The NPA is best applied to display results and enhance the users ability to analyze and understand the code calculation after reviewing the printed output. This recommendation is made because some of the important diagnostic information is only given in the printed output.

3.4.1 Plant Transient Applications

The analysis of a thermal-hydraulic transient that is not caused by a break in the primary or secondary can normally be performed with few or no component additions to the base model. The interactive input data cards (801 through 999) and the trip input data (cards 20600000 through 206020000) are used to initiate transient events.

Table 3-2 lists the interactive variable inputs and the method of utilizing these inputs. Assume that the user wants to analyze a pump coastdown test where the RCP's trip when the test starts. If the variable rcps on card 805 is set to a value less than zero, then all of the pumps will trip. Table 3-3 shows a restart deck that will execute this problem with the following inputs:

- Title card
- Card 100—problem type and option card
- Card 102—input units card
- Card 103—restart number = 0 for the first restart from the steady state restart-plot file
- Card 105—CPU time remaining card
- Card 201—time step card
- Card 805—set rcps to -1.0
- End of problem card.

This deck will then initiate a transient where the rcps's trip and coastdown. Other inputs might be added such as additional time step control cards to vary the time step size and edit frequency as a function of problem time. The analyst might also desire to edit a different set of variables than were used in the base deck (cards 301 through 399). If new edit cards are added, the edit variables in the steady state deck will be deleted. More complex transient scenarios will require trip cards to initiate events that occur after the beginning of the problem. The analyst should refer to Reference 7 for information on restart decks requirements.

3.4.2 Loss of Coolant Accident Applications

The Calvert Cliffs plant deck does not explicitly include components that model break locations since it is difficult to develop generalized break inputs because of the many possible locations and sizes of breaks that can occur. Therefore, the user will normally be required to add certain components to model LOCA's. The nodalization used to describe a 200% double ended guillotine cold leg break was given in Figure 3-7. Figure 3-12 shows the components used to describe a 0.01 ft² small break located in the cold leg. These components can be added in the restart deck. The minor edit cards should be also input with edits of break flow parameters added.

The horizontal stratification entrainment/pullthrough option at the break junction (the v digit on the junction flag) will affect results for small break analyses. If 0 is selected then the break flow calculation will use the calculated fluid conditions in the volume immediately upstream of the break. If 1, 2, or 3 is selected then the fluid conditions will be modified by the horizontal stratification model. A selection of 1 indicates that the break is at the top of the pipe, 2 means a break at the bottom of the pipe, and 3 means a centrally located break.

Table 3.2. Calvert Cliffs plant deck interactive variable input summary.

* List of interactive variable initial values

* npa interactive variables

*

*-----

0000801 rcp1a	0.0	0000822 mupumps	1.0
0000802 rcp1b	0.0	0000823 letdown	0.0
0000803 rcp2a	0.0	0000824 sg1mfiv	0.0
0000804 rcp2b	0.0	0000825 sg2mfiv	0.0
0000805 rcps	0.0	0000826 sg1mfrv	0.0
0000806 si	0.0	0000827 sg2mfrv	0.0
0000807 hpi1	0.0	0000828 tstopv	0.0
0000808 hpi2	1.0	0000829 sg1mfbv	0.0
0000810 lpi	1.0	0000830 sg2mfbv	0.0
0000812 spray	0.0	0000831 sg1msiv	0.0
0000813 scram	0.0	0000832 sg2msiv	0.0
0000814 acc1a	0.0	0000833 mfp1	0.0
0000815 acc1b	0.0	0000834 mfp2	0.0
0000816 acc2a	0.0	0000835 sg1adv	0.0
0000817 acc2b	0.0	0000836 sg2adv	0.0
0000818 ttrip	0.0	0000837 tbv	0.0
0000819 sgis	0.0	0000838 sg1afw	1.0
0000820 heaters	0.0	0000839 sg2afw	1.0
0000821 porv	0.0		

* List of interactive options

*

*No.	Name	Parameter	Description
*801	rcp1a	Reactor coolant pumpd	manually on at rated speed if rcpxx > 0.0
*802	rcp1b		manually tripped if rcpxx < 0.0
*803	rcp2a		automatic control (includes normal manual trips if rcpxx = 0.0
*804	rcp2b		
*805	rcps	All rcps	same as 801-804 except applies to all rcps
*806	si	Safety injection signal	si > 0.0, manual si signal si < 0.0, si signal manually inhibited si = 0.0, normal automatic operation

Table 3-2. (continued).

*No.	Name	Parameter	Description
*807 *	hpi1	Multiplier for 1 hpi pump delivery curve	hpi1 = 1.0, 100% delivery = 0.0, 0 % delivery
*808 *	hpi2	Multiplier for 2 hpi pump delivery curve	hpi2 = 1.0, 100% delivery = 0.0, 0 % delivery
*810 *	lpi	Multiplier for 2 lpi pump delivery curve	lpi = 1.0, 100% delivery = 0.0, 0 % delivery
*812 * * * *	spray	Pressurizer spray valve normalized area	spray = 0.0, automatic operation = -1.0, manually closed = 1.0, manually wide open >-1. and <1., automatic operation plus constant manual offset
*813 * *	scram	Manual reactor trip	scram = 0.0, automatic operation > 0.0, manual reactor trip < 0.0, reactor trip inhibited
*814 *815 *816 *817	acc1a acc1b acc2a acc2b	Accumulator isolation valves	accxx ge 0.0, normal automatic operation lt 0.0, accumulator xx is isolated
*818 * *	ttrip	Manual turbine trip	ttrip = 0.0, automatic operation > 0.0, manual turbine trip < 0.0, turbine trip inhibited
*819 * *	sgis	Steam generator isolation signal	sgis = 0.0, automatic operation > 0.0, manual isolation signal < 0.0, isolation signal inhibited
*820 * * * *	heaters	Pressurizer heaters	heaters = 0.0, automatic operation = -1.0, manually off = 1.0, manually full on >-1. and <1., automatic operation plus constant manual offset
*821 * *	porv	Pressurizer porv normalized area	porv = 0.0, automatic operation > 0.0, porv manually full open < 0.0, porv manually closed
*822 * * *	mupumps	Number of makeup pumps running	mupumps = 0.0, no pumps running = 1.0, normal automatic operation = 2.0, two pumps running = 3.0, three pumps running
*823 * * * *	letdown	Letdown flow normalized area	letdown = 0.0, automatic operation = 1.0, maximum letdown = -1.0, letdown isolated ge -0.03 and le 0.03, automatic operation plus constant offset
*824 *825	sg1mfiv sg2mfiv	Main feed isolation valves	mfiv = 0.0, automatic operation > 0.0, manually full open

Table 3-2. (continued).

*No.	Name	Parameter	Description
*			< 0.0, manually closed
*826	sg1mfrv	Main feed regulating	= 0.0, automatic operation
*827	sg2mfrv	valves	= 1.0, manually full open
*			= -1.0, manually closed
*			> -1. and < 1., automatic operation
*			plus constant offset
*829	sg1mfbv	Main feed bypass	= 0.0, automatic operation
*830	sg2mfbv	valves	= 1.0, manually full open
*			= -1.0, manually closed
*			> -1. and < 1., automatic operation
*			plus constant offset
*831	sg1msiv	Main steam isolation	= 0.0, automatic operation
*832	sg2msiv	valves	> 0.0, manually full open
*			< 0.0, manually closed
*833	mfp1	Main feed pump status	= 0.0, automatic operation
*834	mfp2		> 0.0, manually on
*			< 0.0, manually tripped
*835	sg1adv	Atmospheric dump	= 0.0, automatic operation
*836	sg2adv	valves	= -1.0, manually closed
*			= 1.0, manually full open
*			> -1. and < 1., automatic operation
*			plus constant offset
*837	tbv	Turbine bypass valves	= 0.0, automatic operation
*			= -1.0, manually closed
*			= 1.0, manually full open
*			> -1. and < 1., automatic operation
*			plus constant offset

Table 3-3. Restart deck input listing.

```
=Calvert Cliffs Unit 1 pump coastdown transient
*
-----
* problem card
0000100          restart          transnt
*
-----
* problem options card
0000101          run
*
-----
* units card
0000102          british          british
* restart card
0000103 1
* CPU time remaining card
0000105 10.0 20.0 2000.0
*
-----
*
-----
* time step control card
00000201 200.0 1.0e-6 0.05      03      100 600      600
* interactive options card
805 rcps -1.0
*****
. end
```

3.4.3 Severe Accident Applications

The plant deck should be directly applicable for severe accident studies as was explained in Section 2.2. Analyses which extend into the region of severe accident behavior will require detailed interpretation of the SCDAP output. It is recommended that minor edits related to the SCDAP calculation be added. Table 3-4 gives a suggested list. Also the NPA core mask is very helpful for interpreting severe accident phenomena.

3.5 Problem Resolution

This section discusses the options available to solve problems encountered while applying the Calvert Cliffs plant deck. The most common problem encountered when executing RELAP5/MOD3/SCDAP is water property failure. When this occurs the message "Water property error with minimum time step, transient being terminated" will be written after the last major edit before the error occurred. The message is followed by an extensive diagnostic printout that contains data on each component in the model. The data is always in SI units in the diagnostic printout. This is then followed by a major edit at the time the error occurred. The final major edit contains all the normal major edit data.

Table 3-4. Suggested SCDAP minor edits.

cadct	050101	Outer core surface temperatures at the first, fourth, seventh, and tenth axial nodes
cadct	050401	
cadct	050701	
cadct	051001	
cadct	050103	Middle core surface temperatures at the first, fourth, seventh, and tenth axial nodes
cadct	050403	
cadct	050703	
cadct	051003	
cadct	050105	Center core surface temperatures at the first, fourth, seventh, and tenth axial nodes
cadct	050405	
cadct	050705	
cadct	051005	
caoxdeo	0101	Outer core oxide thickness at the first, fourth, seventh, and tenth axial nodes
caoxdeo	0401	
caoxdeo	0701	
caoxdeo	1001	
caoxdeo	0103	Middle core oxide thickness at the first, fourth, seventh, and tenth axial nodes
caoxdeo	0403	
caoxdeo	0703	
caoxdeo	1003	
caoxdeo	0105	Center core oxide thickness at the first, fourth, seventh, and tenth axial nodes
caoxdeo	0405	
caoxdeo	0705	
caoxdeo	1005	
rocrst	0101	Outer core radius of cladding at the first, fourth, seventh, and tenth axial nodes
rocrst	0401	
rocrst	0701	
rocrst	1001	
rocrst	0103	Middle core radius of cladding at the first, fourth, seventh, and tenth axial nodes
rocrst	0403	
rocrst	0703	
rocrst	1003	
rocrst	0105	Center core radius of cladding at the first, fourth, seventh, and tenth axial nodes
rocrst	0405	
rocrst	0705	
rocrst	1005	

Table 3-4. (continued).

damlev	0101	Outer core level of damage at the first, fourth, seventh, and tenth axial nodes
damlev	0401	
damlev	0701	
damlev	1001	
damlev	0103	Middle core level of damage at the first, fourth, seventh, and tenth axial nodes
damlev	0403	
damlev	0703	
damlev	1003	
damlev	0105	Center core level of damage at the first, fourth, seventh, and tenth axial nodes
damlev	0405	
damlev	0705	
damlev	1005	
bgth	0	Core total hydrogen generation rate (kg/s).
bgnhg	0	Core nuclear heat generation (W).
bgmct	0	Core maximum surface temperature (K).
bgthq	0	Core total oxidation heat generation (W).

The water property error indicates that the transient has been stopped because an unrealistic state condition has been calculated in one or more components. The diagnostic printout will contain the message "Water property error in component" followed by the component number. The data on the component in the final major edit can then be checked. Generally a negative pressure or an extremely high or low liquid or vapor internal energy will be seen in the major edit. After identifying the component where the water property error occurred several actions can be taken that may solve the problem. The calculational results prior to the error should be studied, particularly near the component where the water property error occurred. Phenomena that should be checked for when reviewing the results are:

- Unrealistic flow surges or spikes in junction components
- Rapid pressure changes in a component that do not follow the pressure transient in adjacent components
- Flow or pressure oscillations that cannot be explained.

The internal time step control logic that selects the time step for the next advancement does not always function perfectly. If the results appear reasonable prior to the error, then the cause may

be in the time step selection. In this case, the problem can be solved by restarting the problem at the last restart edit before the error occurred and using a smaller maximum time step. The minimum time step is automatically set to 1.0e-06 s unless the user selects a smaller minimum time step. Attempting to avoid the water property error by using a lower minimum time step is not recommended because this technique usually does not solve the problem and can cause excessive calculation time.

An example of avoiding a water property error follows. Assume that a transient analysis with the Calvert Cliffs deck fails at 96.27 s into the calculation. At the time of failure the time step control specifies a 0.1 second maximum time step, a 1.0e-06 minimum time step, and a major and restart edit every 10.0 s. So the time step control card would be:

**	end	min	max	control	minor edit	major edit	restart
**	time	dt	dt	flag	frequency	frequency	frequency
0000201	500.0	1.0e-6	0.10	03	10	100	100

If the last restart edit is at 90.0 s the following cards would be used on restart to avoid the water property error:

**	end	min	max	control	minor edit	major edit	restart
**	time	dt	dt	flag	frequency	frequency	frequency
0000201	94.0	1.0e-6	0.10	03	10	40	40
0000202	97.0	1.0e-6	0.005	03	100	600	600
0000203	100.0	1.0e-6	0.05	03	10	40	40
0000204	500.0	1.0e-6	0.10	03	10	100	100

The problem has been restarted at 90 s and the maximum time step size reduced from 0.10 s to 0.005 s at 94 s. After 97 s the water property problem will have been bypassed and the time step size is gradually increased back to 0.10 s.

Some water property failure problems cannot be solved this easily. The maximum time step size may have been too large during the time period before the error occurred. Flow spikes or pressure oscillations are indicators of this problem. The problem would have to be restarted with a smaller maximum time step at a restart edit where the results were still acceptable.

The trip signal edits should also be reviewed to see if a trip occurred shortly prior to the time of the water property error. Sometimes the actions caused by the trip will result in calculational problems. Applications using the Calvert Cliffs plant deck have failed when the condensate pumps or the condensate booster pumps trip. If this occurs the user should check if the feedwater system is still active in terms of influencing the results of the calculation. If it is not active, then the steam generator feedwater system is isolated. Then the feedwater line components can be deleted and the analysis continued. Table 3-5 lists the cards that will eliminate the feedwater line.

Table 3-5. Inputs to remove the main feedwater line.

*-----						
* trips referencing deleted quantities re-entered as dummy trips						
*-----						
20605910 time	0	gt	null	0	100000.0	1 * dummy
20605920 time	0	lt	null	0	100000.0	1 * dummy
*-----						
* control volume delete cards						
*-----						
7570000	"rcsink4"		delete			
7560000	"cnsprc"		delete			
7550000	"rcsink3"		delete			
7540000	"bstrc"		delete			
7530000	"rcsink2"		delete			
7520000	"mfp2rc"		delete			
7510000	"rcsink1"		delete			
7500000	"mfp1rc"		delete			
7460000	"sgbinlet"		delete			
7450000	"sgbinhdr"		delete			
7440000	"mfwivb"		delete			
7430000	"bfwdhr"		delete			
7420000	"mfbva"		delete			
7410000	"mfwrvb"		delete			
7400000	"bfwhdr"		delete			
7360000	"sgainlet"		delete			
7350000	"sgainhdr"		delete			
7340000	"mfwiva"		delete			
7330000	"afwdhr"		delete			
7320000	"mfbva"		delete			
7310000	"mfwrva"		delete			
7300000	"afwhdr"		delete			
7290000	"mfphdr"		delete			
7280000	"hphtrout"		delete			
7270000	"mphtrs"		delete			
7260000	"mfp2chk"		delete			
7250000	"mfp1chk"		delete			
7240000	"mfp2dis"		delete			
7230000	"mfp1dis"		delete			
7220000	"mfp2"		delete			
7210000	"mfp1"		delete			
7200000	"mfpsuct"		delete			
7160000	"htrdrns"		delete			
7150000	"htrsump"		delete			
7110000	"lp34out"		delete			
7100000	"lphtr3&4"		delete			
7090000	"lp3init"		delete			

Table 3-5. (continued).

7080000	"cbpout"	delete
7070000	"bstrpmp"	delete
7060000	"lphts"	delete
7050000	"filtout"	delete
7040000	"filter"	delete
7030000	"speout"	delete
7020000	"hwpout"	delete
7010000	"hwpump"	delete
7000000	"hotwell"	delete
* -----		
* heat structure delete cards		
* -----		
17041000	delete	
17042000	delete	
17044000	delete	
17061000	delete	
17062000	delete	
17081000	delete	
17101000	delete	
17102000	delete	
17201000	delete	
17202000	delete	
17271000	delete	
17291000	delete	
* -----		
* changed control variables		
* -----		
20503450	"afloerr "	sum 3600.0000 -1620.471 0
20503451	0.0	2.2045 mflowj 350010000
20504450	"afloerr "	sum 3600.0000 -1273.652 0
20504451	0.0	2.2045 mflowj 450010000
* -----		
* deleted control variables		
* -----		
20506900	"fqfilter"	delete
20506910	"fqfilter"	delete
20506920	"fqlpht1"	delete
20506930	"fqlpht2"	delete
20506940	"fqlpht3"	delete
20506950	"fqlpht4"	delete
20506960	"fqlpht5"	delete

Table 3-5. (continued).

20506970	"fqhphtr7"	delete
20507020	"p720"	delete
20507030	"maxhd"	delete
20507050	"mhtrdrm"	delete
20507060	"tafttt"	delete
20507070	"htrdrain"	delete
20507200	"delpa"	delete
20507210	"delpb"	delete
20507220	"dpmax"	delete
20507230	"dperr"	delete
20507240	"delrpm"	delete
20507250	"mfpspd"	delete
20507300	"mfbvarea"	delete
20507320	"sg1mfbva"	delete
20507420	"sg2mfbva"	delete
20507500	"velf725s"	delete
20507520	"velf726s"	delete
20507540	"velf710s"	delete
20507560	"velf703s"	delete

The calculation will also fail due to a thermo-properties error if the temperature in a heat conductor becomes either greater than or less than the temperature range input on the thermal conductivity cards (201mmm01 through 201mmm49) or the volumetric heat capacity cards (201mmm51 through 201mmm99). This is an unusual error. To correct this type of problem the user should identify the reason that the table range was exceeded and extend the table range if appropriate. If the range of other tables is exceeded then the end value will be used. The code will not extrapolate beyond the end of the table so the user should be aware of this.

Another potential problem is excessive mass error. High mass error is an indicator of unrealistic analytical results. The mass error and mass error ratio is given in the time advancement summary at the beginning of each major edit. If this error becomes excessive, the user should then refer to the time step control matrix that is printed after the volume data at each major edit for information on the location of the volume component or components where the largest mass error occurs. Reduction of the maximum time step size should reduce the mass error.

RELAP5/MOD3/SCDAP has been applied for many different types of studies, and therefore most code applications problems can be solved in some manner. Efforts are currently in progress to fix various problems in the code that can cause failures of the types described and it is anticipated that the code will be much more robust in the future.

4. CONCLUSIONS

A RELAP5/MOD3/SCDAP plant deck of the Calvert Cliffs 2700 MWt CE reactor system has been developed and is described in the body of this report. The deck can be used for plant transient, LOCA, and severe accident applications and has NPA display capability. The following features are contained in the deck:

1. The thermal-hydraulic input is in RELAP5/MOD3 format
2. The core is modeled with three radial channels and ten axial nodes per channel
3. SCDAP heat structures model the fuel rods and the control rods
4. The downcomer is divided into four radial divisions
5. Files allowing interactive execution with the NPA are included with the deck
6. A detailed NPA display of the core region only is also provided
7. Steady state at 100% power, 100% flow conditions.

The deck has been tested by applying it for the analysis of a loss of feedwater transient, a large break LOCA, and a small break LOCA. The results of these studies were satisfactory and it is concluded that the input deck is suitable for general applications and for accident management applications. The NPA display capability was also thoroughly tested. Applying the input deck with the NPA display allows a significant enhancement for result interpretation and analysis.

A set of user instructions and recommendations are also provided to aid users who wish to perform studies with the Calvert Cliffs plant deck but who do not have time to become RELAP5/MOD3/SCDAP experts. Methods for avoiding or resolving calculational problems are included in these instructions.

5. REFERENCES

1. C. M. Allison et al., *SCDAP/RELAP5/MOD3 Code Manual Volume II: SCDAP Code Structure, System Models, And Solution Methods* (Draft), EG&G Idaho, NUREG/CR-5535, EGG-2596, Draft, September 1990.
2. D. M. Snider and K. L. Wagner, *Nuclear Plant Analyzer Computer Visual System (CVS) Reference Manual*, EG&G Idaho, EGG-EAST-9095, April 1990.
3. D. M. Snider, K. L. Wagner, W. H. Grush, *Nuclear Plant Analyzer (NPA) Reference Manual*, EG&G Idaho, EGG-EAST-9096, April 1990.
4. P. D. Wheatley et al., *Evaluation of Operational Safety at Babcock & Wilcox Plants Volume 2—Thermal-Hydraulic Results* (Draft), EG&G Idaho, NUREG/CR-4966, EGG-2515, DRAFT, July 1987.
5. I. E. Idel'Chik, *Handbook of Hydraulic Resistance, Coefficients of Local Resistance and of Friction*, U.S. Department of Commerce, AEC-TR-6630, 1960.
6. Calvert Cliffs Final Safety Analysis Report (FSAR).
7. C. M. Allison et al., *SCDAP/RELAP5/MOD3 Code Manual Volume III: Users Guide and Input Requirements* (Draft), EG&G Idaho, NUREG/CR-5535, EGG-2596, Draft, June 1990.
8. D. L. Selby et al., *Pressurized Thermal Shock Evaluation of the Calvert Cliffs Unit 1 Nuclear Power Plant*, Martin Marietta Energy Systems, Inc., NUREG/CR-4022, ORNL/TM-9408, September 1985.

END

**DATE
FILMED**

5 / 13 / 93