An Analysis of Predicted vs. Monitored Space Heating Energy Use in 120 Homes

RCDP Cycle 2

NOV 1981 OSTI
MAY 1982

Residential
Construction
Program
Report

Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

An Analysis of Predicted vs. Monitored Space Heat Energy Use in 120 Homes

Residential Construction

Demonstration Project Cycle II

October 1991

John G. Douglass
Marvin Young

Prepared by Washington State Energy Office for
Bonneville Power Administration under
Contract # DE-AC7985BP23821

MASTER

Executive Summary

The Model Conservation Standards are based on simulated performance of homes using the SUNDAY thermal simulation program. Several prior studies have assessed the ability of SUNDAY to predict space heat energy consumption. The Washington State Energy Office found good agreement between SUNDAY predictions and monitored performance for 282 homes located in Washington State that were constructed in the Residential Standards Demonstration Program, and for 83 homes in the northwest region that were constructed in the Residential Construction Demonstration Project (RCDP) Cycle I. A University of Washington team also validated SUNDAY in a detailed comparison of predicted and monitored performance in four test homes.

Controversy has diminished concerning SUNDAY's ability to accurately predict space heat energy consumption without bias. However, the model has not hitherto been validated sufficiently for predicting the performance of houses with non-heat-recovery ventilators. In this second cycle of RCDP, the SUNDAY thermal simulation program was used to predict space heat energy consumption for 120 energy efficient homes. Most had non-heat-recovery ventilators. There was hope of validating SUNDAY's ability to predict energy performance in these homes. SUNDAY's performance with the RCDP Cycle II homes was indeed validated, with results consistent with prior comparative studies.

Several other variables that were not directly included as inputs to the simulation were examined with an analysis of covariance model. The objective was to see if an empirical adjustment could improve the simulation's prediction of space heat. The variables having the greatest effect were conditioned floor area, heating system type, and foundation type. By including them, the model was able to create a better match of predicted to monitored. Unmodified, SUNDAY algorithms explained 44 percent of the variation between predicted and monitored results. Modified by the covariance model, SUNDAY explained 67 percent of the variation. Including ventilation system type (i.e. heat recovery or not) in the model did not significantly improve the match of predicted to monitored. Likewise, including an index of conservation robustness (overall UA per square foot of floor area) did not improve the match. This implies that SUNDAY needs no adjustment to accommodate variation in these parameters.

As prior studies have shown, SUNDAY is able to accurately predict mean space heat consumption of houses in aggregate. As with any building model that does not schedule individual occupant-related loads, there is considerable variation among individual houses. This is akin to the caveat usually placed in automobile gas mileage reports, "Your own mileage may vary..."

Introduction

In 1980 Congress passed the Northwest Electric Power Planning and Conservation Act. The Act established the Northwest Power Planning Council (NWPPC) and directed it to create a set of model conservation standards (MCS) based on regional cost-effective conservation measures for residential and commercial construction.

In 1983 the NWPPC directed the Bonneville Power Administration to create the Residential Standards Demonstration Program. The program's purpose was to demonstrate construction of the MCS and collect cost and thermal data in residential structures. Much information was gained from that program, and as a consequence the MCS were reevaluated and updated. A second program, the Residential Construction Demonstration Project, was created to further investigate residential energy efficiency measures for both cost and thermal performance. This analysis was based upon information collected during the second cycle of the Residential Construction Demonstration Project.

The MCS is a set of performance requirements that vary depending on climate. Three climate zones defined by heating degree days (65 °F base) were established. Table 1 lists climate zones and corresponding degree days.

Table 1 Pacific Northwest Climate Zones

Climate Zone	Heating Degree Days
Zone 1	<6000
Zone 2	6000-8000
Zone 3	>8000

The Model Conservation Standards are based on simulated performance of homes determined by using the SUNDAY thermal simulation program. Several studies have been undertaken to assess the ability of SUNDAY to predict space heat energy consumption. The Washington State Energy Office found good agreement between SUNDAY predictions and monitored performance for 282 homes located in Washington state and constructed in the Residential Standards Demonstration Program (Byers, 1988), and for 83 homes in the northwest region constructed in the Residential Construction Demonstration Project Cycle I, (Downey, 1989). A University of Washington team tested metered energy performance in four residences against predictions of SUNDAY and other simulation models. The team concluded that the comparisons validated the different simulation programs and conferred a sense of accuracy upon them (Emory, et.al, 1989). Older studies have shown SUNDAY predictions to be as much as 30 percent high (Yoder, 1986). Controversy surrounding SUNDAY's ability to accurately predict space heat energy consumption without bias has diminished. However, it has been noted that the model has not been validated sufficiently for predicting performance of houses with non-heat-recovery ventilators.

The purpose of this study is to examine the relationship between SUNDAY predicted and monitored space heat consumption in RCDP houses. Specifically, this analysis will determine the degree to which SUNDAY predictions agree with monitored use; examine the correlations (if any) between the degree of agreement with such factors as house size, architecture, heating system type, and location; and determine which estimated SUNDAY inputs lead to the most consistent comparison between predicted and actual performance.

This analysis is separated into two primary sections. The first section contains descriptions of calculated and estimated SUNDAY input variables. This section also contains descriptions of methodologies used to collect and calculate physical inputs. The second section contains analysis of predicted and monitored performance including variables that are not included in the simulation model, but may impact energy consumption.

SUNDAY Input Variables

Conduction Heat Loss Coefficients

Many complex inputs are required to perform a prediction of space heat energy consumption. This section describes methodologies used to calculate or estimate these inputs. Model variables include overall building heat loss coefficient, internal heat gains from people and appliances, structural heat storage capacity, internal temperature set points and schedule, glazing orientation and transmissivity, and local weather. Overall building heat loss is broken into three components: conduction heat loss, mechanical convection heat loss, and natural convective heat loss.

Inputs that are either inaccurate or imprecise may negate any analysis of simulated performance. Effort has been made to ensure that the data do not contain systematic errors. However, due to fiscal and organizational constraints, compromises in the collection of data were necessary.

Standardized heat loss coefficients for wall, ceiling, and floor components were taken from a set of standardized U-values created for the Super Good Cents program and were calculated with standard ASHRAE procedures (Baylon and Heller, 1988). Basements were modeled with heat loss through the below grade walls and heat loss through the below grade slab. Heat loss coefficients for doors were assumed to be $0.33 \text{ Btu/hr ft}^2 \text{ }^\circ\text{F}$ and $0.19 \text{ Btu/hr ft}^2 \text{ }^\circ\text{F}$ for solid core wood and insulated metal doors, respectively.

Glazing heat loss coefficients were extracted from tested data available in the April 1987 Glazing Test Report List (Hogan, 1987). Windows were categorized by frame type, number of glazings, air space width, coating type, and filled gas type. Mean heat loss coefficients were then calculated for each category.

Component areas were examined for extreme values. Any extreme values were checked against construction blueprints and corrected if needed. A total of seven corrections were made. Three basement perimeter lengths and four glazing areas were incorrectly recorded and consequently corrected. Component areas and descriptions were extracted from house plans and were verified through a series of construction inspections. The methodology for collecting component data (plans check and inspection process) was similar to that used in the Residential Standards Demonstration Program and Cycle I of the Residential Construction Demonstration Project. This methodology was examined by the Washington State Energy Office (WSEO) and found to provide data that was accurate and relatively free from errors (Downey, 1988).

Overall conduction heat loss coefficient was calculated with Equation 1.

Equation 1

$$UA_c = U_1A_1 + U_2A_2 + \dots + U_nA_n + F_sP_s$$

where:

UA_c = the overall conduction UA in $\text{Btu/hr } ^\circ\text{F}$

U_n = the conduction heat loss coefficient for component n in $\text{Btu/hr SF } ^\circ\text{F}$

A_n = the area of component n in ft^2

F_s = the conduction heat loss coefficient for slab in $\text{Btu/hr ft } ^\circ\text{F}$

P_s = the perimeter of slab in lineal feet

Table 2 contains summary statistics of the conductive heat loss coefficient calculated for the 120 homes examined in this analysis. Because different thermal standards were required depending on the climate zone where the structure was located, Table 2 is cross tabulated by the three climate zones. Figure 1 contains histograms of these data.

Table 2

Conduction Heat Loss Coefficients by Climate Zone

Zone	n	Mean	Std. Dev.	Min.	Max.
1	57	318	76.2	181	518
2	39	286	86.7	209	638
3	24	275	61.4	153	408
All	120	299	78.8	153	638

Figure 1

Convection Heat Losses

Convective losses are problematic for the simulation software used in this analysis since they can not be scheduled. Consequently convective heat loss must be condensed into an annual figure. Since all of the test homes were equipped with mechanical ventilation, convective heat loss is broken into two components: mechanical and natural convective losses.

Mechanical Convection Losses. Each home in the program was equipped with ventilation systems. These included air-to-air heat exchangers, exhaust air heat pumps, and several alternative configurations of non-heat-recovery ventilation systems. Two configurations of air-to-air heat exchangers were used: conventionally ducted and integrated into the ducting of a forced air heating system. All exhaust air heat pumps were the same model, the DEC Thermastor Products HPVAC. The non-heat-recovery systems are described in Table 3.

Table 3 Mechanical Ventilation Systems

System	Intake	Exhaust	No. of Homes	% of Total
AAHXc	Air-to-air heat exchanger integrated with heating system		5	3.9
AAHX	Air-to-air heat exchanger		26	15.5
EAHP	Through-wall vents or make-up air to forced air heating system	Exhaust air heat pump	13	6.2
nHRV1	Through-wall vents or central ducted intake	Designated bathroom, kitchen, or laundry fan	51	30.2
nHRV2	Through-wall vents or central ducted in-take	Central ducted exhaust	15	10.1
nHRV3	Through-wall vents or central ducted intake	Separate whole house exhaust fan	6	4.7
nHRV4	Make-up air to forced-air heating system	Designated fan, whole house fan, or central exhaust	44	29.5

Heat exchanger air flow rates were measured at all fixed operating speeds during a single site survey conducted by Ecotope Inc. The field technician attempted to balance supply and exhaust flows during the site survey. In some instances the technician found it impossible to either measure flows or balance the HRV unit due to poorly located supply and exhaust vents, inaccessible flow dampers, or minimal flow capacity. Based upon inspection of the controls, Ecotope estimated the most probable flow rate for systems with multi-speed fans. Running time was recorded by hour meters—usually 120 VAC instruments connected across the fans. Sometimes a pressure switch and battery powered timer were used in heat recovery ventilators where access to internal wiring would have voided the UL label.

Mechanical convection losses were broken into two separate components: balanced convection losses and unbalanced convection losses. The former are simpler to deal with because they do not interact with natural ventilation. However, they only occur in the AAHX systems, which have supply air fans as well as exhaust fans.

Mechanical ventilation systems affect the heat loss coefficient (UA) of RCDP homes. To assess this relationship, weekly on-time readings were multiplied by the most likely flow rate during operation. On-time instruments did not distinguish between various fan speeds. However, the control systems of multi-speed systems were usually configured so that high speed was only used for spot control less than an hour per day. Flows were measured at all fan speeds during the site visits. The flow used for assessing heat loss coefficient was based on the control system, and it was usually the low speed flow.

Mechanical UA is complicated by the fact that some mechanical ventilators were heat recovery devices. Based upon findings from RCDP Cycle I, an adjustment factor of 40 percent was used in the UA equation for AAHXs because it was assumed that 60 percent of the exhaust heat energy was recovered. No measurements were made for AAHX effectiveness in this sample of houses.

EAHPs were handled differently. Much of their recovered heat went toward water heating rather than space heating. Also, their heat recovery rate is related to demand and is totally insensitive to outdoor temperature. Attempts to represent their heat recovery as a factor applied to ventilation UA would be inappropriate. EAHPs more than pay back all the heat lost by inducing outside air during mild weather, and indeed can provide a net gain over the year in milder climates. It should also be remembered that all their input energy is recorded as water heating due to the sub-meter wiring. In summary, SUNDAY should tend to over-predict EAHP houses because it does not account for their heat recovery, and the metered space heat does not include some of the electric energy used for heating.

Mechanical ventilation UA was computed using Equation 2.

Equation 2

$$Mech UA = adj \cdot exflow \cdot vperday/24 \cdot C_p \cdot 60 \cdot \rho \cdot (1 - siteelev \cdot 3.458 \times 10^{-5})$$

where:

Mech UA = Mechanical heat loss coefficient in Btu/hr/°F

exflow = Exhaust flow rate during on time in ft³/min

vperday = Average on time in hr/day

siterelev = Site elevation in ft

C_p = Specific Heat of air = .24 Btu/lbm/°F

ρ = Density of air at sea level & 530 R = 0.0748 lbm/ft³

adj = Adjustment factor = 0.4 for AAHX's, otherwise 1.0

Natural Convective Losses. The natural ventilation losses were determined by using blower door testing and then using a computer model developed by Lawrence Berkeley Laboratories (LBL) to predict natural infiltration (Sherman and Grimsrud, 1980). The Ecotope Inc. analysis found that the model significantly over-predicted the effects of wind (Palmiter, Brown, and Bond, 1989). Indeed the stack effect part of the model, used alone, gave a much better correlation with infiltration measured by tracer gas testing. Average wind speed during the test was low, only 3.7 Mph. Therefore, this analysis used the stack model results as the natural infiltration predictor for computing UA. The LBL model used weather data as an input because wind speed and temperature differential affect ventilation. Ideally, this should have been actual year weather data. However, other uses for the ventilation data required typical meteorological year data be used.

UA from natural ventilation was computed using Equation 3.

Equation 3

$$Nat UA = ACH_{st} \cdot vol \cdot C_p \cdot \rho \cdot (1 - siteelev \cdot 3.458 \times 10^{-5})$$

where:

Nat UA = Natural Infiltration heat loss coefficient in Btu/hr/°F

ACH_{st} = ACH computed by the LBL stack model

vol = House volume in ft³

siterelev = Site elevation in ft

C_p = Specific Heat of air = .24 Btu/lbm/°F

ρ = Density of air at sea level & 530 R = 0.0748 lbm/ft³

For AAHXs only, the mechanical and natural ventilation were simply summed. This would overstate the combined ventilation in exhaust-only houses. Negative pressure induced by exhaust-only systems eclipses part of the natural exfiltration. The degree of eclipsing varies with time, depending upon temperature differential and the amount of induced negative pressure.

In the past, popular convention has been to compute total ventilation by adding unbalanced mechanical flow and natural ventilation in quadrature. This method was probably inspired by the knowledge that wind and stack induced pressure differentials are additive, and their resulting infiltration varies roughly as the square root of pressure differential across any leakage areas. Adding in quadrature is inappropriate when combining natural ventilation with mechanical because the mechanical impetus is a constant flow phenomenon. Fans exhaust through a dedicated port at a rate nearly independent of other wind and stack driving forces. The currently favored method for combining the two involves adding half the mechanical flow to the natural flow during hours of operation. This method was used in this study. The rationale and exact implementation of this is discussed in greater detail in a separate publication (Douglass, 1991).

Nine houses had faulty or missing mechanical ventilation or blower door data. In these cases, the UA was computed from defaults used in the code compliance software, WATTSUN.

The total heat loss coefficient for each structure is composed of conductive heat loss, mechanical ventilation heat loss, and natural convective heat loss. Equation 4 represents this figure. The mean heat loss coefficient per square foot of heated space was calculated for structures in each of the three climate zones. Table 4 summarizes these data.

Equation 4

$$UA_t = UA_c + UA_v$$

where:

UA_c = Overall conduction UA in Btu/hr/°F

UA_v = Combined natural and net mechanical UA in Btu/hr/°F

Table 4 Overall Heat Loss Coefficient per Square Foot for 120 Homes by Climate Zone (Btu/hr/°F)

Zone	n	Mean	Std. Dev.	Min.	Max.
1	57	379	99.4	232	677
2	39	362	116.5	234	872
3	24	341	73.4	202	484
All	120	366	101.2	202	872

Figure 2 is a percentage cluster pie chart representing the contribution of conduction, natural infiltration, and net mechanical ventilation to the total heat loss coefficient. While natural infiltration was approximately equal to expected values for each heat loss category, mechanical ventilation was used consistently less. Most mechanical ventilation systems had the capacity to adequately ventilate the homes, but systems were operated far less than had been hoped. Figure 3 contains a histogram by climate zone of average mechanical ventilation system on-time for the 120 houses.

Figure 2

Figure 3

Structural Heat Capacity

Structural heat capacity was modeled assuming three types of construction: light frame (crawl space); slab on grade; and basement construction. Light frame construction was assumed to contain $3.0 \text{ Btu/}^\circ\text{F ft}^2$; slab construction was assumed to contain $7 \text{ Btu/}^\circ\text{F ft}^2$; and homes with below grade walls were assumed to contain $11 \text{ Btu/}^\circ\text{F ft}^2$ (Ecklund and Baylon, 1984). Homes with more than one story that were built on a slab or basement were modeled with a combination of construction types. Table 5 describes different construction types found in the data set and their associated structural heat capacity. Crawl space homes have been further broken into two categories: vented and unvented. Basement homes have been further separated into full and daylight basements.

Table 5 **Structural Heat Capacity in Btu/°F**

Type of Foundation	n	Mean	Std. Dev.	Min.	Max.
Vented	50	5797	2876	2766	22560
Unvented	9	4994	1419	3912	7995
Slab	10	7475	2469	4000	13656
Basement	15	14864	5073	8064	25344
Daylight	34	11380	6809	3948	38976
Unknown	2	4417	638	3966	4868
Total	120	8569	5633	2766	38976

Thermostat Set Point

Daytime and nighttime thermostat set points were acquired from weekly occupant reporting cards. There were no temperature recorders in the Cycle II houses, so these could not be verified. These settings compare very closely to the Cycle I thermostat settings. The latter were obtained from the occupant survey since Cycle I occupants were not required to indicate weekly settings. In Cycle II, the day setting mean was 68.5°F with a standard deviation of 3.5°F . The night setting mean was 63.7°F with a 6.2°F standard deviation. Duration of nighttime setback was assumed to be 10 hours.

Many occupants indicated that the thermostat was set "off" at night. In most sites this was reported during milder weather with a specific setback reported during colder weather. In these cases SUNDAY (which accepts only one setback temperature for the entire year) was given the setback used in colder weather. An "off" setting in milder weather would have little effect on actual space heat. In this sample of low UA houses during milder months, indoor temperature floats down only a few degrees over night. This would rarely be enough to initiate nighttime heating during setback hours, so whether the thermostat was set back or "off" is moot.

Internal Heat Gains

Heat gains from appliances and occupants offset the need for space heat. SUNDAY requires that an hourly average internal heat gain be specified. This figure cannot be scheduled. The methodology used to calculate internal gains was identical to that used in the analysis of RSDP and RCDP Cycle II data (Byers and Palmiter, 1988; Downey, 1989). Average hourly internal heat gains were estimated from appliance load, appliance type, and the number of people in the structure. Equation 5 was used to calculate hourly internal heat gains and is derived from appliance performance estimates.

Equation 5

$$I = 0.8 \cdot (S - DHW) \cdot (3413/8760) - 20.8 \cdot W - 467 \cdot R - 311 \cdot F + 150 \cdot P + 284 \cdot H$$

where:

- I = Internal heat gains in Btu/hr
- S = metered space heat in kWh/yr
- DHW = metered domestic water heat in kWh/yr
- W = the number of well pumps
- R = the number of refrigerators located outside
- F = the number of freezers located outside
- P = the number of occupants
- H = the number of water heaters

The factor of 80 percent is applied to account for electrical appliance use outside the heated space in addition to those appliances explicitly accounted for in the equation. This figure is arbitrary and may introduce systematic bias into the analysis, but it is the same figure used by Byers and Palmiter, and Downey. Internal gains are summarized in Table 6 by UA category.

Table 6 Average Internal Gains by UA Category (Btu/hr)

bin	n	Mean	Std. Dev.	Min.	Max.
<250	9	2502	1000	1083	3690
250-299	15	2611	571	1389	3666
300-349	37	2810	1094	1031	6470
350-399	26	2949	1001	1245	4745
400-449	17	2654	941	1125	4502
450-499	7	3625	1592	2123	6931
>499	9	4189	2157	1820	7668
Total	120	2921	1195	1031	7668

Glazing Orientation and Transmittance

Glazing areas were extracted from construction blueprints. Orientation was also taken from blueprints when possible, or was extracted from the solar site survey completed during the site visit by contracted technicians. SUNDAY requires that each window have a solar multiplier that accounts for glazing transmissivity. For the purposes of this analysis, the solar multiplier for double pane and triple pane windows were 0.95 and 0.85, respectively. This assumes no shading from overhangs or vegetation.

Weather Data

Required SUNDAY weather inputs include daily average temperature, available insolation, and hours of daylight. Temperature data were constructed from actual daily maximum and minimum temperature recordings taken during the study period for 39 locations throughout the Pacific Northwest. These were processed into average daily temperatures with a cosine interpolation algorithm. Insolation data were not recorded at each locality, but were taken directly from typical meteorological year data (TMY) and are may not be representative of real insolation levels experienced by these homes. Hours of daylight were calculated with algorithms outlined in Lunde (1980).

Simulation Results

All of the variables discussed above were used as inputs into the simulation model. Space heat was simulated for 120 homes and is compared to monitored energy

consumption in Figure 4. A least squares regression analysis of these data indicated that 43.8 percent of the variation in monitored space heat is explained by the simulated data. Before beginning the analysis, all homes with evidence of bad data were excluded. For example, one excluded coastal home had a very low predicted space heat because the occupant consistently indicated that the normal daytime thermostat setting was 55°F. The actual space heat in conjunction with weather data suggests that an ordinary setting closer to 70°F was much more probable. Other houses were excluded because it was known that the occupants burned wood.

Figure 4

Unusual system configurations, extremes in architecture, extended vacations, and a broad range of occupant behavior have been observed in RCDP Cycle II, as in all the residential demonstration projects. These unique conditions exist over a range of extremity and it was not easy to decide which were sufficiently unconventional to warrant exclusion. It was decided to maintain objectivity at some cost in precision, by minimizing the number of excluded houses. If no evidence of faulty data was found, houses were not excluded just because of a large mismatch between predicted and monitored.

Monitored and predicted space heat were categorized by heat loss coefficient bin as summarized in Table 7. Differences between means of monitored and predicted space heat were examined with paired t tests for each category and two were significantly different than zero (probability). The greatest difference and greatest significance is the 25 percent over-prediction of the 300 to 349 bin. This was also the greatest over-predicted bin in the RCDP Cycle I analysis (16 percent over), although it was not shown to be statistically significant (probability was 0.1). This was the largest bin (i.e. contained the most houses) in both cycles of RCDP. These data are represented visually in Figure 5.

Table 7

Monitored vs. Predicted Space Heat by UA Bin

UA btu/hr/°F	n	Monitored kWh/yr	Predicted kWh/yr	Difference kWh/yr	Ratio P/M	Paired t Probability
<250	9	4,788	3,322	1,466	.69	.04
250-299	15	5,484	4,177	1,306	.76	.07
300-349	37	5,397	6,767	-1,371	1.25	.00
350-399	26	7,374	7,168	206	.97	.71
400-449	17	6,934	7,512	-578	1.08	.30
450-499	7	10,297	9,730	567	.94	.78
>499	9	13,764	11,996	1,768	.87	.35
Total	120	6,922	6,942	-21	1.00	.94

Figure 5

It is common knowledge that different electric heating systems vary in their energy usage. Several things can explain this. Systems with zonal control reduce energy usage by allowing some areas of the house to be kept cooler when unoccupied. Heat pumps augment electric energy input with a vapor cycle machine that actually "pumps" heat from the outdoor environment into the house. Conversely, ducted systems are vulnerable to energy losses through leaks because of room pressurization. Also, whenever ducts are routed outside the heated space, additional surface area of the ducts themselves is vulnerable to leakage and conduction losses.

SUNDAY treats all electric resistance heating systems equally and uses a default HSPF of 6.8 for heat pumps. In this analysis, the heat pump HSPF was adjusted by a factor of 0.87 to be consistent with WATTSON, which has been given this default factor, based upon experience, to account for duct losses.

Figure 6 illustrates how the different heating systems compared. The last two boxes, electric furnaces and heat pumps, were the only ducted systems. The other nonducted systems were usually zone controlled. Electric furnaces used a mean of 16 percent more heating energy than SUNDAY predicted, but this is inconclusive because there were only 10 in the sample population. With the 0.87 adjustment, SUNDAY predicted heat pump houses to use 6 percent more than was monitored; unadjusted, the prediction would have been 9 percent below that monitored. Radiant heated houses (mostly radiant slab) were too few to ascribe any meaning to the results.

Figure 6

Several variables known to impact space heat energy consumption are not included in the simulation model. The simulation model does not include heating system efficiency or house type—both of which have been shown by other researchers to affect space heat energy consumption (Byers and Palmiter, 1988). House size (conditioned floor area) is another variable that is not explicitly included in the simulation model but has been correlated with space heat. However, house size is positively correlated to heat loss coefficient, heat capacity, and internal heat gains—all of which are included in the simulation model.

An analysis of covariance model was used to examine those factors that are not explicitly included in the simulation model. Predicted space heat and house size were included as continuous variables and categorical variables were created for heating system type and house type. Heating systems were categorized as electric furnace, radiant, zonal, baseboard, and heat pump systems. House type was categorized by number of stories. A

separate variable classified foundation types as vented crawlspace, unvented crawlspace, slab on grade, daylight basement, or full basement.

There was considerable interest in SUNDAY's ability to predict accurately with the new ventilation systems, especially non heat recovery systems used in RCDP Cycle II. As indicated in Figure 7, there was no significant difference between the heat recovery and non heat recovery systems. This is not surprising given the low on time, thus small contribution to whole house UA made by the ventilation systems.

Figure 7

Other variables that were included in the simulation and were also examined with the analysis of covariance model included total UA, mass, internal gains, and effective solar glazing area. None of these variables, which were explicitly included in the SUNDAY model, were significant either by themselves or interacted with predicted space heat in the analysis of covariance model. This would suggest that the SUNDAY model adequately explained variation in energy consumption due to these variables.

Modification of the predicted space heat with this analysis of covariance model increases the coefficient of determination from 0.438 to 0.670; a 54 percent increase.

Equation 6

$$S_m = 1.487h + (a + b) \cdot S_p + 899.1$$

where:

- S_m = Modified Sunday predicted spaceheat in kWh/yr
- S_p = Sunday predicted space heat in kWh/yr
- h = House floor area in square feet

a = Heating System Type

baseboard = 0.085

wall mount = -0.157

radiant = 0.474

electric furnace = 0.183

heat pump = 0.085

b = foundation type

vented crawlspace = 0.475

basement = 0.354

slab on grade = 0.440

daylight basement = 0.443

The predicted is compared to modified predicted in the paired box plot of Figure 8. Most outliers are brought in considerably, but more importantly the span of the second and third quartiles are also shrunk.

Figure 8

As conservation standards increase, it is reasonable to ask if SUNDAY remains accurate. To investigate this, an index of conservation robustness was created. This involved simply normalizing whole house UA to conditioned floor area. By definition, houses with lower UA per square foot were more robust. The ratio of predicted to monitored was essentially constant across the bins of robustness. This sample provides no suggestion that the accuracy of SUNDAY is biased in either direction for houses with higher conservation levels.

Conclusions

The SUNDAY thermal simulation program was used to predict space heat energy consumption for 120 energy efficient homes. The predicted data were found to explain 43.8 percent of the variation in monitored space heat consumption. Using a paired Student's t test, no statistically significant difference could be found between mean predicted space heat and monitored space heat for the entire sample of homes. The homes were grouped into seven classes, sub-samples by total heat loss coefficient. An intermediate class ($UA = 300-350 \text{ Btu/}^\circ\text{F}$) was found to significantly over-predict space heat by 25 percent. The same class was over-predicted by 16 percent in the analogous Cycle I research, but the sample size was smaller and this was not found to be statistically significant.

Several variables that were not directly included as inputs to the simulation were examined with an analysis of covariance model for their ability to improve the simulation's prediction of space heat. The variables having the greatest effect were conditioned floor area, heating system type, and foundation type. The model was able to increase the coefficient of determination from 0.438 to 0.670; a 54 percent increase.

While the SUNDAY simulation program on aggregate is able to predict space heat consumption, it should be noted that there is a considerable amount of variation in both the monitored space heat consumption and the SUNDAY predictions. The ability of the program to accurately model an individual house will be constrained by both the quality of input variables and the range of occupant behavior. These constraints apply to any building model.

References

Baylon, D. and J. Heller. *Super Good Cents Heat Loss Reference Volumes I and II*. Ecotope Inc., Seattle, Washington. Prepared for the Bonneville Power Administration. October 1988.

Ryers, R. and L. Palmiter. *Analysis of Agreement between Predicted and Monitored Annual Space Heat Use for a Large Sample of Homes in the Pacific Northwest*. American Council for an Energy Efficient Economy (ACEEE), Summer Study on Energy Efficiency in Buildings. August 1988.

Douglass, J.G. *Residential Construction Demonstration Project Cycle II: Active Ventilation*. Washington State Energy Office, Olympia, Washington. Prepared for the Bonneville Power Administration. February 1991.

Downey, P.K. *Residential Standards Demonstration Program Case Studies*. Washington State Energy Office, Olympia, Washington. Prepared for the Bonneville Power Administration. September 1988.

Downey, P.K. *Analysis of Predicted vs. Monitored Space heat Energy Use in 83 Homes*. Washington State Energy Office, Olympia, Washington. Prepared for the Bonneville Power Administration. August 1989.

Ecklund, K. and D. Baylon. *Design Tools for Energy Efficient Homes*. Third Edition. Ecotope Inc., Seattle, Washington. April 1984.

Emory, A., Heerwagen, D., Heerwagen J., Kippenhan, C., and Varey, G. 1989. *Dynamic Response of Building Components in Residential Homes: Simulation Report*. University of Washington report to the Washington State Energy Office under Contract #86-34-02. January, 1989.

Hogan, J. *April 1987 Glazing Test Reports List*. Seattle Department of Construction and Land Use, Seattle, Washington. April 1987.

Lunde, P.J. *Solar Thermal Engineering: Space Heating and Hot Water Systems*. Jon Wiley & Sons, Inc., New York, New York. 1980.

Sherman, M.H. *Estimation of Infiltration from Leakage and Climate Indicators*. Lawrence Berkeley Laboratory, Berkeley, California. December 1986.

Yoder, R. *Comparison of Sunday — Predicted and Monitored Space Heat Energy Use*. Draft Report. Hood River Project Pacific Power and Light, Portland, Oregon. January 1987.

END

**DATE
FILMED**

6/15/92