DRAFT

**Development of a Retrofit Coal Combustor for
Industrial Applications**

**TECHNICAL PROGRESS REPORT
JULY - SEPTEMBER 1987**

Prepared For:

**U.S. Department of Energy
Pittsburgh Energy Technology Center**

DOE Contract DE-AC22-87PC79654

By:

MANAGEMENT AND TECHNICAL CONSULTANTS, INC.

P.O. Box 21, Columbia, MD 21045 (301)982-1292 Telex 292354 / MTCI UR

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PREFACE

A detailed description of the background, technology, and application for the Development of a Retrofit Coal Combustor for Industrial Applications was provided in the first quarterly report, December 1986 - March 1987. This material is omitted in this technical progress report.

During this quarter the tandem pulse combustors were assembled and several definition start-up tests were conducted on both single units and the tandem unit. The start-up tests indicated that several configuration modifications were required before the evaluation tests were initiated. The modifications were completed and both base-line performance for the single unit and the initial tests of the tandem unit were completed.

TABLE OF CONTENTS

	<u>Page</u>
1.0 <u>PROGRAM DESCRIPTION AND WORK STATUS.</u>	1
1.1 PROGRAM DESCRIPTION.	1
1.2 TASK DESCRIPTIONS.	1
1.3 STATUS	3
2.0 <u>TECHNICAL DISCUSSION OF WORK COMPLETED DURING THE REPORTING PERIOD.</u>	5
3.0 <u>PLANNED ACTIVITY FOR THE NEXT PERIOD</u>	14

LIST OF FIGURES

1 PROGRAM LOGIC FOR DEVELOPMENT OF A PULSE COAL COMBUSTOR FOR RETROFIT APPLICATIONS	2
2 TANDEM CONFIGURATION WITH EXHAUST PLENUM AND CYCLONE	6
3 AERODYNAMIC VALVES	6
4 NEW TANDEM CONFIGURATION WITH EXHAUST CYCLONE ONLY	7
5 5A: SINGLE UNIT RUNNING WELL 5B: SINGLE UNIT RUNNING POORLY . .	9
6 AERODYNAMIC VALVE INSERT	11

LIST OF TABLES

1 ANALYSIS FOR MICRONIZED COAL	10
2 SUMMARY OF THE RESULTS FOR SEPTEMBER TEST RUNS	12

SECTION 1.0

PROGRAM DESCRIPTION AND WORK STATUS

1.1 PROGRAM DESCRIPTION

The objective of this phase of the program for the development of a retrofit pulse coal combustor for industrial applications is to design, fabricate, test and evaluate advanced chamber designs at the laboratory scale utilizing several fuels (Task 1). The activities are structured to provide design criteria for scaling up to the pilot-scale level for the demonstration of a pulse combustor fired with coal-water mixtures for industrial boiler and process heater retrofit applications. The program logic is depicted in Figure 1.

The design data and information acquired during Task 1 of the initial phase will be used to develop scale-up design criteria for scaling the laboratory-scale design to pilot-scale including interface requirements for the field demonstration. The scale-up pilot unit design will be sufficiently developed to allow fabrication of the unit for testing in the existing test facility upon DOE exercising its option for the follow-on activities of this program. These follow-on activities will include the fabrication, test and engineering evaluation of the pilot-scale combustor and include technical and laboratory test support activities for reducing the technical risks and costs of development at the pilot-scale. Based on the information, test, data and technical support activities, a retrofit combustor system will be designed for field demonstration as shown on the left in Figure 1.

At the end of this phase of the program, a design for a retrofit combustor system for field demonstration will be completed with the exception of site-specific design details which will be provided after approval for the field demonstration at the subcontractor test site.

1.2 TASK DESCRIPTIONS

Task 1: Optimization of the Laboratory-Scale Combustor

The specific objectives of this task are to optimize the chamber design of the feasibility units developed under Contract No. DE-AC22-83PC60419 for optimized performance with coal and coal-water slurry fuels and to reduce performance sensitivity to variations in fuel specifications.

To meet these objectives, two advanced combustion chamber configurations will be designed and fabricated at the laboratory-scale (1 - 2 MMBtu/hr) size. Design options will include both bare metal and refractory-lined units to permit both air-cooled and adiabatic operation. These advanced designs will be fabricated and then tested to evaluate the performance with respect to the following parameters:

FIGURE 1:
PROGRAM LOGIC FOR DEVELOPMENT OF A PULSE
COAL COMBUSTOR FOR RETROFIT APPLICATIONS

- o Combustion intensity and heat release rates,
- o Staging capability,
- o Dry sulfur capture and ash rejection performance,
- o Carbon burnout efficiency,
- o NO_x emissions performance, and
- o Sensitivity to changes in fuel specifications.

Refractory-lined combustor tests will be conducted employing both the feasibility unit chamber design and one of the advanced chamber designs selected on the basis of the evaluation tests.

Task 2: Scale-Up Pilot Unit Design

The specific objective of Task 2 is to design a pilot-scale test unit for evaluation in the existing MTCI facility. To meet this objective, the data acquired under Task 1 will be utilized to develop design scale-up criteria for scaling the laboratory-scale design to pilot-scale. These criteria include consideration of the effect of scale-up on combustor operating frequency, firing intensity (in MMBtu/hr cu.ft.), and the intensity of pressure fluctuation with increased firing rate. The scale-up design also considers all the interface requirements of the pilot-scale development activities at the subcontractor test site. The design developed will be sufficiently detailed to permit the fabrication of the unit when approved by DOE.

1.3 STATUS

The fabrication and assembly of the refractory lined tandem pulse combustors was completed during this period. Initial tests on each of the two combustors indicated that their performance characteristics and behavior were similar with respect to pressure boost and operating frequency. Prior to testing the tandem unit, three aerodynamic valve configurations were also tested. Two of the configurations, the straight (in-line) and the 90° long-radius elbow operated at approximately seventeen inches of water pressure boost and at a frequency of 80 Hz. The 90° sharp tangential aerovalve performed poorly and led to difficult start-up conditions and unstable performance.

For initial testing of the tandem unit, the 90° long-radius valves were installed and the units fired on gas. The two combustors did not run out of phase as anticipated but rather, primarily, in phase. The units were modified by removing the exhaust plenum and both tailpipes were connected directly to the cyclone decoupler. The intake plenum was also replaced with a larger unit. The tangential cyclone decoupler was lined with three inches of refractory. In addition, the scrubber was modified by the installation of a by-pass line to reduce excessive back pressure which also appeared to affect the tandem combustor operation in the initial check-out test.

Combustor testing was initiated to determine the operating frequency for each combustor and to provide a data baseline against which to compare the performance of the tandem unit. The waveform signals were processed utilizing a Fast Fourier Transform (FFT) analysis.

The tandem unit was initially tested on gas up to 2.56 MMBtu/hr without any indication that the maximum capacity of the unit was exceeded at this fuel rate level. The transfer to dry ultrafine micronized coal for testing injector locations was readily accomplished. Three different injection locations were tested to determine the most stable configuration. At the three inch injection depth the unit exhibited the most stable operation on coal without the need for support gas. A final series of test runs were completed with this configuration and the combustor exhibited well behaved characteristics using the axial coal injector, operating at 1.73 MMBtu/hr and without the need for support gas.

A project review presentation was held at the Pittsburgh Energy Technology Center on October 2, 1987. A copy of this presentation is provided in Appendix A to this report. Task 2.0, Scale-up Pilot Unit Design, has been delayed pending completion of negotiations with Foster Wheeler Development Corporation (FWDC) (Subcontractor) and approval by the DOE Contracting Officer. The major problem appears to concern the modification requested by FWDC with respect to the DOE provision of liability limitations.

SECTION 2.0

TECHNICAL DISCUSSION OF WORK COMPLETED DURING THE REPORTING PERIOD

The work during this reporting period focussed upon the following tasks:

- 1.0 Lab-scale Optimization:
 - 1.2 Configuration Optimization,
 - 1.3 Evaluation Testing,
 - 1.4 Data Reduction and Analysis, and
- 3.0 Management and Reporting.

Task 1.1, Advanced Chamber Design and Fabrication, was completed during the last quarterly reporting period.

Task 1.2: Configuration Optimization.

The tandem pulse combustors, Figure 2, were assembled using conical tailpipes. The entire unit is made up of castable refractory material (Pyro-tab 3400 Alumina). The chambers are made in two sections each for ease of inspection. The tailpipes are made in one section each. The exhaust plenum is a rectangular box type (2'W x 3'L x 1'H) with two inlets on top and one exit in the bottom connecting to a cyclone. The cyclone is also refractory lined. The flue gases are sent to the scrubber before discharging. In the inlet side of the combustor, the coal fuel feed lines and the auxiliary flue (gas) feed lines for the two combustors were connected by "tees", as shown in the figure.

The flue gas scrubber described in the last quarterly report was also assembled and tested. This unit will service both the industrial retrofit program (DE-AC22-87PC79654) and the residential program (DE-AC22-86PC90278).

Each of the two refractory-lined pulse combustors were separately tested to verify that their performance characteristics were closely matched. Test results indicated similar performance behavior for each individual unit with respect to pressure boost and operating frequency. Based on this information, effective coupling of the tandem units was anticipated. However, before coupling the tandem units, several aerodynamic valve configurations were tested including: 1) straight, 2) 90° long radius elbow, and 3) 90° sharp tangential aerovalves. The configurations of these aerodynamic valves are shown in Figure 3. Both the straight and the 90° long-radius aerovalves exhibited similar performance characteristics operating with approximately 17 inches of water pressure boost and 80 Hz frequency. The tangential aerovalve did not perform well resulting in unstable combustion and difficult start-up. This result is thought to be attributed to the excessive flow resistances in the tangential valve due to the redirection of momentum during the air influx stroke.

Since practical coupling of the tandem units was simplified using bent aerovalves, the 90° long-radius valves were employed during initial testing. The tandem units were fired on gas at a rate of 0.9 million Btu/hr. Based on

FIGURE 2: TANDEM CONFIGURATION WITH EXHAUST PLENUM AND CYCLONE

FIGURE 3: AERODYNAMIC VALVES

information gathered from a duel trace oscilloscope, the two combustors did not appear to run out of phase. The data actually indicated that the two units were running largely in phase.

It is believed that coupling using the bent aerovalve operating at modest firing rates may not be sufficiently powerful to induce out of phase operation. Increasing the firing rate to the 2 million Btu/hr range may induce the desired out of phase behavior. Modifications to the fuel line were made to determine if improved fuel biasing can be achieved. Other means for augmenting coupling was also considered including the use of aerodynamic valve thrust enhancement.

Out-of-phase operation is required for proper fuel phasing and thus more complete combustion. One explanation for the undesirable operating behavior of the tandem unit is that weak coupling may have resulted from wave reflection in the restricted exhaust plenum. In order to alleviate this problem, the exhaust plenum was removed and both tailpipes were directly connected tangentially to the cyclone decoupler as shown in Figure 4. A larger intake plenum was also fabricated. The tangential cyclone decoupler was lined with 3" refractory. The refractory was a Lite Kastite 50 which has a temperature capability of 2400°F and is less dense than the Pyrotab used for the combustors and tailpipes.

In addition to the problems associated with the exhaust plenum, excessive back-pressure from the scrubber column also appeared to negatively impact combustor performance. In order to alleviate this problem, a spray quench, bypass line was installed around the packed scrubber. The bypass line system appears to be sufficient for knocking out entrained ash before the flue gases are vented.

FIGURE 4: NEW TANDEM CONFIGURATION WITH EXHAUST CYCLONE ONLY

To more quantitatively characterize the performance levels of the combustor and to distinguish good performance from poor performance, the pulse waveform signals were processed using Fast Fourier Transform (FFT) analysis. The signal from the combustor pressure transducers are converted from analog to digital form using a multichannel A/D converter. The A/D sampling frequency is 3000 Hz which is sufficient to accurately characterize the combustor fundamental frequency and first several harmonics. The digitalized data is then processed using a FFT algorithm.

The FFT analysis is used to separate the waveform into its individual frequency components. For instance, Figure 5A shows the frequency distribution for a combustor which appears by qualitative observation to run well. As can be seen, the frequency peaks are sharp and clear. In contrast, Figure 5B shows the frequency spectrum of a pulse combustor which was observed to run poorly. Here, the frequency components are poorly resolved. The FFT technique has proven to be quite useful in distinguishing and screening the performance and operation of the combustors tested.

Tuning of the new configuration was initiated for both single and tandem units. Single unit tests were focused on the determination of operating frequency and to provide baseline data for comparison with tandem configuration runs.

Task 1.3: Evaluation Tests

Evaluation tests for dry micronized coal were initiated to provide a baseline comparison of performance relative to slurry fuels. Standard grind coal will be used during the next period. The dry, ultrafine coal was received. An analysis for this coal is given in Table 1.

The combustors were again tuned prior to testing by modifying the aerodynamic valve inserts to vary the minimum diode diameter. Minimum diode diameters ranging from 1.5" to 2.25" were tested. The best results were obtained with a 1.77" diameter insert of the configuration shown in Figure 6. In addition, the coal injection location was modified somewhat compared to previous tests. The new injector is internally located along the axial centerline of the aerodynamic valve. Note that in previous tests, coal was injected in an orthogonal fashion just below the entrance of the aerodynamic valve. The new injector configuration gives increased flexibility since the depth of injection is easily varied. Furthermore, the new injector appears to give superior combustion performance.

The tandem unit was initially tested on gas. The gas input rate was increased to 2.56 MMBtu/hr without any indication that the fuel rate would exceed the maximum capacity of the pulse combustor at this level. Coal was then tested using several different injection locations. The first location employed a 3/4" opening that entered tangentially into the combustor approximately 1" below the aerodynamic valve. Although combustion performance was acceptable for this configuration, a minimum level of support gas was necessary to keep the combustor in operation.

FIGURE 5A: SINGLE UNIT RUNNING WELL

FIGURE 5B: SINGLE UNIT RUNNING POORLY

TABLE 1: ANALYSIS FOR MICRONIZED COAL

SAMPLE ANALYSIS SHEETCOAL I.D. UE3-123-MC0-C

COAL

DESCRIPTION: Upper Elkhorn #3 Seam - Deep Cleaned Coal Dry Micronized for
MTCI

PROXIMATE:

MOISTURE	<u>1.92%</u>
VOLATILE MATTER	<u>36.06%</u>
FIXED CARBON	<u>62.78%</u>
ASH	<u>1.16%</u>
SULFUR	<u>0.69%</u>
BTU/LB	<u>15016</u>

ASH CHEMISTRY:

SiO ₂	<u>40.30%</u>
Al ₂ O ₃	<u>27.80%</u>
TiO ₂	<u>1.65%</u>
Fe ₂ O ₃	<u>18.30%</u>
CaO	<u>3.45%</u>
MgO	<u>0.77%</u>
K ₂ O	<u>1.52%</u>
Na ₂ O	<u>1.52</u>
SO ₃	<u>2.40%</u>
P ₂ O ₅	<u>1.52%</u>
SrO	<u>0.48%</u> Est.
BaO	<u>0.45%</u> Est.
Mn ₃ O ₄	<u>0.02%</u> Est.
BASE ACID RATIO	<u>0.37</u>
T-250 TEMP.	<u>2450°F</u>

ULTIMATE:

CARBON	<u>85.12%</u>
HYDROGEN	<u>5.14%</u>
NITROGEN	<u>1.57%</u>

ASH FUSION: REDUCING

INITIAL	<u>2020°F</u>
SOFTENING	<u>2230°F</u>
FLUID	<u>2370°F</u>

FREE SWELLING INDEX:

6.5

HARDGROVE GRINDABILITY:

NA

FIGURE 6: AERODYNAMIC VALVE INSERT

Since the objective of this work is to develop a coal combustion system which requires no support gas, alternate injection points were also tested. It was then determined that coal could be directly injected through the axial centerline of the aerodynamic valve. Three different injection depths were tested including 8", 5", and 3". The 3" injection point exhibited the most stable combustion behavior without support gas. It is interesting to note that the 8" injector depth also provided unsupported coal combustion. However, peak-to-peak combustor pressures were diminished. For the 5" depth, unsupported coal combustion could not be sustained.

Test results for runs made in September are reported in the following subsection.

2.1 DATA REDUCTION AND ANALYSIS

Test results from five separate runs are summarized in Table 2. As can be seen, the final two test runs employing an axial coal injector were operated at 1.73 MM Btu/hr without support gas. For each of these test runs, the effluent gas analysis is reported along with a calculated carbon burn-out value.

The conventional means for determining combustion efficiency involves the collection of an ash sample from the flue gas effluent which is then measured for carbon content. Since the ash content of the original coal sample is known, a simple algorithm can be employed to calculate the percent carbon burn-out for the given sample. The validity of this method implicitly depends on obtaining a collected ash sample which is representative of the total ash rejected within the system.

In the case of the slagging pulse combustor, the bulk of the ash is rejected as molten slag, with a smaller portion being rejected as fly ash. The carbon content of the molten slag is very low. In contrast, the carbon content of the fly ash may be significant.

TABLE 2:
SUMMARY OF THE RESULTS FOR SEPTEMBER TEST RUNS

TEST DATE	9/11/87	9/17/87	9/18/87	9/28/87	9/28/87
FIRING RATE NATURAL GAS	1770000.00	935000.00	765000.00	0.00	0.00
FIRING RATE COAL	840000.00	1730000.00	1730000.00	1730000.00	1730000.00
TOTAL FIRING RATE	2610000.00	2665000.00	2495000.00	1730000.00	1730000.00
GAS ANALYSIS (2)					
O2 %	2.40	1.80	ND	8.60	8.60
CO2 %	11.00	13.00	ND	7.60	9.70
CO ppm	9900.00	45400.00	ND	31400.00	4400.00
NOx ppm	ND	ND	350.00	250.00	390.00
SO2 ppm	ND	ND	250.00	50.00	40.00
MAXIMUM TEMPERATURE °F	2516.00				
% CARBON BURNOUT (1)	95.4	98.2	97 (2)	92.2 (2)	95
ADJUSTED % BURNOUT (3)					
95% SLAG	98.99	99.64	99.85	99.61	99.75
80% SLAG	96.00	98.56	99.40	98.44	99.00
COAL INJECTION LOCATION	TANGENTIAL	TANGENTIAL	GAS INJECTOR	AXIAL	AXIAL

(1) BASED ON FLY ASH ONLY

(2) ANALYSIS AFTER TAIL PIPE

(3) ADJUSTED FOR SLAGGING (DATA AFTER TAILPIPE)

For a small scale combustion apparatus which is operated only for short periods of time, an accurate and continuous measurement of slag rejection is quite difficult. In contrast, fly ash sampling can be performed easily using a vacuum line and a collection filter. It is obvious that the carbon burn-out value based solely upon fly ash measurements is highly conservative since it does not account for the considerable quantities of carbon-free ash which is rejected as molten slag. To achieve a more realistic value for carbon burn-out, the calculated value should be adjusted for slag rejection.

In Table 2, the carbon burn-out is presented based on fly ash measurements only and also as corrected for slag rejection. For the latter calculations, two different parametric values for slag rejection efficiency were assumed; an 80% level and a 95% level.

In an attempt to experimentally quantify the amount of ash which is rejected as slag, a fly ash sample was collected while continuously monitoring the sampled flue gas volumetric flow rate. From this data, using a straight forward algorithm, the absolute percent of ash rejected as fly ash and slag can be derived. Using this method, it is estimated that slag rejection efficiencies were in the range of 95 - 98%. However, it should be stated that these numbers are only estimates and may contain a high degree of error.

Based on the above results, the parametric values used in Table 2 to calculate the corrected burn-out efficiencies are still conservative. As seen in the table, uncorrected carbon burn-out values typically range from 95 - 98%. For 80% slag rejection, the corrected burn-out values typically range from 98.5 - 99.4%. Data corrected for 95% slag rejection yield typical carbon burn-out values of approximately 99.6 - 99.9%.

The gas analyses for test runs on September 11, 1987, and September 17, 1987 indicate operation at very low oxygen concentrations. It should be mentioned that the oxygen concentration includes contributions from Argon which can not be resolved by the gas chromatograph. Argon typically accounts for one absolute percent. Therefore, it appears that these runs were conducted very near stoichiometric conditions.

The two separate test runs on September 28, 1987 appear to have been conducted at much higher oxygen levels corresponding to approximately 75% excess air. However, some air leakage into the sample vacuum lines was identified at a later date indicating that actual oxygen concentrations in the combustor may have been significantly lower. The high carbon monoxide level and low NO_x level for the first run on September 28, 1987 seems to indicate that the combustor had not yet attained a sufficiently high operating temperature. It is believed that the carbon monoxide and NO_x values for the second run (4400 ppm CO and 350 ppm uncorrected NO_x) are more truly indicative of the operating performance for this unit. Note that the NO_x value, corrected to 3% O_2 , is approximately 500 ppm.

The measured values for SO_2 appear to be too low based on the sulfur content of the coal. Absorption of SO_2 in the collection line, particularly in the condenser which may have contained alkaline material from previous experimental work, is suspected.

SECTION 3.0

PLANS FOR NEXT PERIOD

It is planned to continue configuration optimization, Task 1.2; Evaluation Testing, Task 1.3; and Data Reduction Analysis, Task 1.4, during the next period. Specifically, testing during the next period will utilize pulverized coal. At the completion of the first series of initial testing on pulverized coal, the tandem unfit will be dismantled for visual inspection. Dependent upon the test results, additional modifications may be considered, if necessary, to further optimize the unit.

APPENDIX A

DEVELOPMENT OF A RETROFIT COAL COMBUSTOR FOR INDUSTRIAL APPLICATIONS

DE-AC22-87PC79654

U.S. DEPARTMENT OF ENERGY

PITTSBURGH ENERGY TECHNOLOGY CENTER

PROJECT REVIEW PRESENTATION

MANAGEMENT AND TECHNICAL CONSULTANTS, INC.

9624 John St. Ste. 101, Santa Fe Springs, CA 90670 (213) 941-8267

OCTOBER 2, 1987

POTENTIAL INDUSTRIAL MARKETS FOR COAL-BASED ADVANCED COMBUSTION SYSTEMS

- **BOILER REPLACEMENT/RETROFIT**
- **PROCESS HEATER RETROFIT
(DIRECT AND INDIRECT-FIRED)**
- **COAL DRYING**
- **GLASS MELTING FURNACE**
- **CEMENT KILNS**

RETROFIT OF A PULSE COMBUSTOR TO A WALL-FIRED PROCESS HEATER

RETROFIT OF A PULSE COMBUSTOR TO A WATERTUBE BOILER

APPLICATION OF PULSE COAL COMBUSTOR FOR DIRECT FIRED DRYING

SMALL INDUSTRIAL BOILER REPLACEMENT/ RETROFIT APPLICATIONS

CAPACITY RANGE, MMBTU/HR

<10	10-25	25-50	50-100
-----	-------	-------	--------

% POPULATION

58

22

12

8

% FUEL
CONSUMPTION

12

15

27

46

MARKET

REPLACE

REPLACE/
RETRO

RETRO

RETRO

TYPE

FIRETUBE

FIRETUBE

WATERTUBE

WATERTUBE

TARGET MARKETS

PRIMARY

- GAS/OIL-FIRED, MEDIUM PRESSURE, WATER TUBE, INDUSTRIAL BOILER
- 25-100 MMBTU/hr
- RETROFIT

SECONDARY

- GAS/OIL-FIRED, LOW PRESSURE, FIRETUBE, INDUSTRIAL BOILER
- 3-10 MMBTU/hr
- REPLACEMENT

OPERATIONAL GOALS FOR INDUSTRIAL BOILER (25 MMBTU/HR)

• TYPE:	PACKAGED UNIT
• TURNDOWN:	4 : 1
• THERMAL EFFICIENCY:	>85%
• COMBUSTION EFFICIENCY:	>99%
• PHYSICAL SIZE:	<15'H x 30'L x 12'W
• LOAD CONTROL:	AUTOMATIC
• START-UP:	AUTOMATIC

EMISSION GOALS FOR INDUSTRIAL BOILER

<u>ITEM</u>	<u>(LB/MMBTU) EMISSIONS</u>	<u>PPMV (TYPICAL)</u>
• CARBON MONOXIDE	.04	35
• NITROGEN OXIDES	.5	265
• SULFUR OXIDES	1.0	380
• PARTICULATE	.05	

CANDIDATE FUELS FOR INDUSTRIAL BOILER RETROFIT

- **COAL-WATER MIXTURES**
- **CONVENTIONAL PULVERIZED COAL**
- **DRY ULTRAFINE COAL**

POTENTIAL OPTIONS FOR ACHIEVING OPERATIONAL AND EMISSIONS GOALS

<u>FUEL</u>	<u>COMBUSTOR</u>	<u>PRIMARY BARRIER</u>
• CLEAN COAL:		
CWM	BOILER FURNACE	VOLUMETRIC HEAT RELEASE
PC	BOILER FURNACE	VOLUMETRIC HEAT RELEASE
DUF	BOILER FURNACE	SAFETY, ECONOMICAL BENEFICIATION PROCESSES
• UNBENEFICATED COAL:		
CWM	ASCC/SULFUR SORBENTS	COMBUSTOR TECHNOLOGY
PC	ASCC/SULFUR SORBENTS	COMBUSTOR TECHNOLOGY
DUF	BOILER FURNACE	FUEL SULFUR CONSTRAINT FUEL ASH CONSTRAINT

MTCI ADVANCED COAL COMBUSTION OPTION

- **FUEL: COMMERCIALY AVAILABLE
UNBENEFICATED PC**
- **COMBUSTOR: ADVANCED SLAGGING
PULSE COMBUSTOR**
- **ASH REJECTION: FRONT-END SLAG TAP**
- **SULFUR REJECTION: FRONT-END
SORBENT INJECTION**
- **SUITABLE APPLICATIONS: RETROFIT OF
OIL/GAS FIRED BOILERS**

00987-39.CUT
FLS 092987

TANDEM ADVANCED REFRACTORY CHAMBERS

PROJECT DEVELOPMENT STATUS

- **COMPLETED DESIGN, FABRICATION AND TESTING OF OPTIMIZED CHAMBERS**
- **COMPLETED CONFIGURATION OPTIMIZATION TESTS**
- **PARTIALLY COMPLETED PERFORMANCE EVALUATION TESTS
USING STANDARD GRIND AND MICRONIZED COAL**
- **PARTIALLY COMPLETED DATA REDUCTION AND ANALYSIS**

LABORATORY-SCALE TECHNOLOGY DEVELOPMENT

SYSTEM COMPONENT DEVELOPMENT

- I - DEVELOPED DURING PHASE I
- II - DEVELOPED DURING PHASE II
- C - COMMERCIAL

C0987-50.CUT
GCM 093087

PULSE COMBUSTOR TEST FACILITY WITH SO₂ SCRUBBER UNIT

SUMMARY OF INDUSTRIAL COMBUSTOR DEVELOPMENT

- **CONCEPTUAL ADVANCED CHAMBER DESIGN**
- **FABRICATION AND TESTING OF ADVANCED
BARE METAL COMBUSTOR**
- **FABRICATION AND TESTING OF ADVANCED
REFRACTORY COMBUSTOR (ARC)**

WAS87-04.CMT

NOTICE: MTCI INTENDS TO FILE FOR PATENT RIGHTS TO THIS CHAMBER DESIGN AND TO SECURE THE RIGHTS TO THE PATENT TO THE EXTENT ALLOWABLE UNDER THE CONTRACT PROVISIONS WITH DOE. IT IS REQUESTED THAT THIS DESIGN INFORMATION BE TREATED ACCORDINGLY.

MTCI ADVANCED CHAMBER
CONFIGURATION

NOTICE: MCI INTENDS TO FILE FOR PATENT RIGHTS TO THIS CHAMBER DESIGN AND TO SECURE THE RIGHTS TO THE PATENT TO THE EXTENT ALLOWABLE UNDER THE CONTRACT PROVISIONS WITH DUE. IT IS REQUESTED THAT THIS DESIGN INFORMATION BE TREATED ACCORDINGLY.

FLOW CHARACTERISTICS DURING AIR INTAKE

NOTICE: HCCI INTENDS TO FILE FOR PATENT RIGHTS TO THIS CHAMBER DESIGN AND TO SECURE THE RIGHTS TO THE PATENT TO THE EXTENT ALLOWABLE UNDER THE CONTRACT PROVISIONS WITH DUE. IT IS REQUESTED THAT THIS DESIGN INFORMATION BE TREATED ACCORDINGLY.

FLOW CHARACTERISTICS
DURING CHAMBER EXHAUST

MTCI DIFFUSER BASED AERODYNAMIC VALVE

AERODYNAMIC VALVES

① STRAIGHT

② TANGENTIAL

③ 90 ELBOW

THRUST AUGMENTOR

FOR TANDEM UNIT WITH AERODYNAMIC VALVE COUPLING

PHASED COAL
INJECTOR

SUMMARY OF SYSTEM CONFIGURATION DEVELOPMENT

- **SINGLE COMBUSTOR:**
 - BARE METAL AND ARC
 - DOWN-FIRED AND HORIZONTAL-FIRED
 - WITH AND WITHOUT PHASED INJECTOR
- **TAILPIPE OPTIMIZATION:**
 - BARE METAL
 - REFRACTORY LINED
 - CONTINUOUSLY FLARED TAIL
- **TANDEM UNITS:**
 - AEROVALVE COUPLING
 - FUEL BIASING
 - DECOUPLING PLENUM
 - DECOUPLING EXHAUST CYCLONE

SIGNIFICANT HARDWARE

MILESTONES

- PREVENTION OF SLAG CHOKING AND BUILD-UP WITH FLARED TAIL PIPE
- DEMONSTRATED TANDEM UNIT OPERATION WITH 180° PHASE LAG BY AERODYNAMIC COUPLING
- DEMONSTRATED OPTIMIZED COAL INJECTION LOCATION AND FEED SYSTEM OPERATION
- DEMONSTRATED SLAG REJECTION IN CYCLONE

OPTIMIZED INDUSTRIAL UNIT

MECHANICAL DESIGN

FEATURES

- TANDEM CONFIGURATIONS
- AERODYNAMIC VALVE COUPLING
- REFRACTORY LINED COMBUSTOR AND TAIL PIPE
- FLARED TAIL PIPE
- MOLTEN SLAG REJECTION

MTCI TANDUM PULSE
INDUSTRIAL COMBUSTOR

0987-00101
15 092007

OPTIMIZED INDUSTRIAL UNIT

OPERATING CHARACTERISTICS

START-UP FUEL :	NATURAL GAS/OIL
OPERATING FUEL :	PULVERIZED/MICRONIZED COAL
FIRING RATE :	1.6 MMBTU/HR
HEAT RELEASE :	4.0 MMBTU/HR*FT ³
COMBUSTOR OPERATING TEMPERATURE :	2600° F

0907-49.C111
YS (01/01/07)

SUMMARY OF FUELS TESTED TO DATE

NATURAL GAS

MICRONIZED PITTSBURG #0 (13% ASH)

MICRONIZED UPPER ELKHORN #3 (1.2% ASH)

PULVERIZED PITTSBURG #0 (0.3% ASH)

SAMPLE OF INDUSTRIAL TEST RESULTS TO DATE

DATE	9/17/87	9/18/87	9/28/87
CHAMBER	ARC	ARC	ARC
CONFIGURATION	TANDEM/AERO	TANDEM/AERO	TANDEM/AERO
GAS FEED, BTU/HR	800,000	800,000	0
COAL TYPE	LOW ASH MICRO	LOW ASH MICRO	LOW ASH MICRO
COAL FEED, BTU/HR	1,730,000	1,730,000	1,730,000
FREQUENCY, HZ	83	83	83
PERCENT COMBUSTION (1)			
TAIL PIPE	92.8	96.5	94
EXHAUST PLENUM	98.2	97.0	95
FLUE GAS:			
O ₂ (2)	1.8	NA	8.6 (3)
CO, PPM	45,000	NA	4470

NOTE: (1) BASED ON FLY ASH ONLY

(2) INCLUDES ARGON

(3) AIR LEAKAGE INTO SAMPLE LINE SUSPECTED

DATA OF PULSE COMBUSTION OF COAL AND COAL-LIMESTONE MIXTURE

RUN NUMBER	1	2	3	4
Ca/S Ratio	0	0	1.5	1.5
Coal Firing Rate (Btu/hr)	676 K	676 K	271 K	575 K
Chamber Temperature(°F)	2200	2200	2210	2160
% Coal Combusted	>99	>99	>99	>99
% Excess Air	45	49	120	51
% Reduction Of SO ₂	0	0	74	75

LIMB TECHNOLOGY DATA (REF. EPRI CS-4178, 1985)

FLUIDIZED BED COMBUSTION DATA

(REF. CHANG, et al, AIChE Ann. Mtg. Nov. 1984)

HIGHLIGHTS OF EXPERIMENTAL RESULTS ON INDUSTRIAL UNIT

- **STABLE OPERATION WITH 100% COAL FEED**
- **OPERATING TEMPERATURES EXCEEDING 2800° F**
- **SLAG COLLECTION IN CYCLONE DECOUPLER DEMONSTRATED**
- **TYPICAL CARBON BURNOUT RANGE OF 95 - 98%
(BASED ON FLY ASH ONLY)**

PROJECTED RETROFIT ECONOMICS

(25 MMBTU/HR BOILER)

ITEM	INCREMENTAL CAPITAL COST (\$1000)
FUEL AND LIMESTONE DELIVERY AND STORAGE	300
PULSE COMBUSTOR	75
SLAG COLLECTION AND HANDLING	120
CONTROLS	60
ANCILLARY BOILER MODIFICATION	50
BAGHOUSE AND FLY ASH HANDLING	300
ENGINEERING	150
TOTAL INSTALLED COST	\$1,055

25 MMBTU/HR INDUSTRIAL BOILER RETROFIT: PROJECTED INCREMENTAL O&M COSTS*

VARIABLE:	\$/YEAR
-----------	---------

• LIMESTONE (15 \$/TON)	7,000
-------------------------	-------

• POWER	NEGL.
---------	-------

• ASH AND SLAG DISPOSAL (5 \$/TON)	9,500
------------------------------------	-------

FIXED:	
--------	--

• MAINTENANCE (4% INCREMENTAL CAPITAL)	42,000
--	--------

TOTAL O&M	58,500
-----------	--------

* FUEL EXCLUDED

RETROFIT PC WORKPLAN

OPTION 1

- PROCEED WITH PHASE II PER ORIGINAL SCHEDULE

OPTION 2

(CONSTRAINED BUDGET OPTION)

- DELAY PHASE II FOR ONE YEAR
- EXPAND PHASE I SCOPE
- LIGHT INDUSTRIAL/COMMERCIAL
RETROFIT BOILER APPLICATION

PHASE I

PHASE II

PHASE III

WORK BREAKDOWN STRUCTURE FOR DEVELOPMENT OF
PULSE COAL COMBUSTOR FOR RETROFIT APPLICATIONS

RETROFIT COMBUSTION TEST FACILITY

AT FOSTER WHEELER
PHASE II OPTION I

		FY 1988												FY 1989			
TASK NO.	DESCRIPTION	O	N	D	J	F	M	A	M	J	J	A	S	O	N	D	J
1.0	LAB-SCALE OPTIMIZATION																
2.0	PILOT UNIT DESIGN																
3.0	MANAGEMENT/REPORTING																
4.0	FAB & TESTING OF TANDEN PC FOR INDUSTRIAL RETROFIT																
5.0	DESIGN BOILER SIMULATOR SUBSYSTEM																
6.0	FAB & COM BOILER SIMULATOR SYSTEM																
7.0	BOILER CHECKOUT W/ COM FUEL																
8.0	PC INTEGRATION W/ BOILER SIMULATOR																
9.0	AUTO CONTROL SYS W/READBOX DESIGN																
10.0	AUTO CONTROL SYS INSTALL & CHECK																
11.0	ENGR & ECON ASSESSMENT																

END

DATE
FILMED
5/12/93