NOTICE

**CERTAIN DATA
CONTAINED IN THIS
DOCUMENT MAY BE
DIFFICULT TO READ
IN MICROFICHE
PRODUCTS.**

**ALTERNATE PARTICLE REMOVAL TECHNOLOGIES FOR THE
AIRBORNE ACTIVITY CONFINEMENT SYSTEM
AT THE SAVANNAH RIVER SITE (U)**

**DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION**

Reviewing
Official:

Philip G. Ellison
Philip G. Ellison

Date:

Oct 8th, 1991

JUL 2 1992

**Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808**

PREPARED FOR THE US DEPARTMENT OF ENERGY UNDER CONTRACT No. DE-AC09-89SR18035

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

WSRC-RP-91-0928

SARM
SEVERE ACCIDENT PROGRAM

**ALTERNATE PARTICLE REMOVAL TECHNOLOGIES FOR THE
AIRBORNE ACTIVITY CONFINEMENT SYSTEM
AT THE SAVANNAH RIVER SITE (U)**

by

John E. Brockmann, Carol L.J. Adkins & Fred Gelbard

Sandia National Laboratories
Albuquerque, New Mexico

Reviewed by

P.G. Ellison & M.L. Hyder
Westinghouse Savannah River Company
Aiken, South Carolina

September 1991

**Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808**

PREPARED FOR THE US DEPARTMENT OF ENERGY UNDER CONTRACT NO. DE-AC09-89SR18035

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PROJECT: Filter/Radionuclide Behavior

DOCUMENT: WSRC-RP-91-0928

TITLE: ALTERNATE PARTICLE REMOVAL TECHNOLOGIES FOR THE AIRBORNE ACTIVITY
CONFINEMENT SYSTEM AT THE SAVANNAH RIVER SITE (U)

TASK: Severe Accident Program Documentation

APPROVALS

Phillip G. Ellison
Derivative Classifier Phillip G. Ellison Date: 10-8-91

Phillip G. Ellison
Technical Review Phillip G. Ellison Date: 10-8-91

M.L. Hyder
Technical Review M.L. Hyder Date: 10/8/91

L.A. Wooten, Manager
Safety Analysis Group DZ Bell for L.A. Wooten Date: 10/8/91

M.J. Hitchler, Manager
Reactor Safety Research M.J. Hitchler Date: 10/8/91

CONTENTS

1.0	INTRODUCTION	1
2.0	AEROSOL SOURCE TERM DEFINITION	2
3.0	PARTICLE AND GASEOUS CONTAMINANT REMOVAL MECHANISMS ...	4
4.0	PARTICLE REMOVAL TECHNOLOGIES - AN OVERVIEW	9
5.0	CURRENT AACS	15
6.0	ISSUES IN AN AACS UPGRADE	17
7.0	REFERENCES	20
8.0	ALTERNATE PARTICLE REMOVAL TECHNOLOGIES	22
I.	WATER SPRAY SCRUBBERS	22
II.	WET BED SCRUBBERS	28
III.	VENTURIS	36
IV.	MULTI VENTURI SCRUBBER SYSTEM (MVSS)	43
V.	GLASS-FIBER DEEP BED FILTERS	50
VI.	METAL-FIBER HEPA FILTERS	56
VII.	METAL-FIBER DEEP BED FILTERS	64
VIII.	GLASS-FIBER DEEP BED FILTERS	69
IX.	BAGHOUSES	74
X.	GRANULAR MEDIA DEEP BED FILTERS	83
XI.	CYCLONES	89
XII.	ELECTROSTATIC PRECIPITATORS	97
9.0	LIST OF SELECTED GAS CLEANING TECHNOLOGY COMPANIES.....	105
10.0	CONCLUSIONS	106

FIGURES

3.1	Relative importance of deposition mechanisms as a function of diameter...	8
I.1	Schematic diagram of a spray tower scrubber	27
II.1	Schematic diagrams of packed bed scrubbers in cross flow, co-current flow, and counter-current flow configurations.....	34

II.2	Schematic diagram of a submerged bed scrubber (SBS)	35
III.1	Schematic diagram of a venturi scrubber	41
III.2	Multi-MicroVenturi scrubber	42
IV.1	Multi venturi scrubber system	49
VI.1	Metal fiber HEPA filter unit	61
VI.2	Metal fiber HEPA filter units combined in series	62
VI.3	Metal fiber HEPA filter units combined in parallel	63
VII.1	Schematic of metal fiber deep bed filter with moisture separator	68
VIII.1	Schematic diagram of a deep bed glass fiber filter	73
IX.1	Schematic of a typical baghouse	82
X.1	Schematic diagram of a granular media deep bed filter	88
XI.1	Typical tangential inlet vertical reverse flow cyclone	95
XI.2	Cyclone scrubber	96
XII.1	Schematic of a typical electrostatic precipitator	104

TABLES

II.1	Pressure Drop, Bed Depth, and Water Flow for Packed Bed Scrubbers	33
IV.1	Experimentally Determined Decontamination Factors for the MVSS	48
IX.1	Comparison of Bag Cleaning Methods	80
IX.2	Properties of Fiber Materials	81
XII.1	Advantages and Disadvantages of Electrostatic Precipitators	103
10.1	Performance Summary	107

1.0 INTRODUCTION

This report presents a review of the filtration technologies available for the removal of particulate material from a gas stream. It was undertaken to identify alternate filtration technologies that may be employed in the Airborne Activity Confinement System (AACS) at the Savannah River Plant. This report is organized into six sections:

1. a discussion of the aerosol source term and its definition,
2. a short discussion of particle and gaseous contaminant removal mechanisms,
3. a brief overview of particle removal technologies,
4. a discussion of the existing AACS and its potential shortcomings,
5. an enumeration of issues to be addressed in upgrading the AACS, and,
6. a detailed discussion of the identified technologies.

The purpose of this report is to identify available options to the existing particle removal system. This system is in continuous operation during routine operation of the reactor. As will be seen, there are a number of options and the selection of any technology or combination of technologies will depend on the design aerosol source term (yet to be appropriately defined) as well as the flow requirements and configuration. This report does not select a specific technology. It focuses on particulate removal and qualitatively on the removal of radio-iodine and mist elimination. Candidate technologies have been selected from industrial and nuclear gas cleaning applications.

2.0 AEROSOL SOURCE TERM DEFINITION

To specify the design of an aerosol filtration system adequately, the aerosol source term the system must handle should be defined. Aerosol mass concentration and chemical composition as a function of particle size and time define the source term. This includes any physical and chemical characteristics of the aerosol such as hygroscopicity, potential chemical reactions, and heat loads from radioactive decay. Additional information required for the design is gas flow rates, gas composition, humidity, liquid water content, and temperature.

Particles may have a wide range of size, shape, material density, and porosity. This variety of potential morphology necessitates the definition of equivalent diameters [Fuchs, 1964; Hinds, 1982]. Each particle removal mechanism is a function of some equivalent particle diameter. An arbitrary particle has the following equivalent diameters.

1. The mass-equivalent diameter is the diameter of a sphere with no voids that has the same mass as the arbitrary particle.
2. The volume-equivalent diameter is the diameter of a minimal circumscribed sphere that has the same volume (mass and void space) as the arbitrary particle. For an arbitrary particle with no void space, the mass and volume equivalent diameters are the same.
3. The aerodynamic-equivalent diameter is the diameter of a sphere with a material density of 1 g/cm^3 that falls with the same terminal velocity as the arbitrary particle.
4. The mobility-equivalent diameter is the diameter of a sphere that has the same dynamic mobility as the arbitrary particle. It also has the same diffusion coefficient and same electrical mobility as the arbitrary particle.

The equivalent diameters of a particle are a determining factor in how it is transported and collected and, as such, are an important element of the source term definition.

The existing airborne activity confinement system at Savannah River Plant was designed for the TID-14844 source term [DiNunno et al., 1962], which is a radiological source term and was formulated as a conservative estimate of the radiological release from a reactor accident. It assumes a release from the damaged portion of the reactor core of 100 percent of the noble gases (the design assumes 100 percent release of the tritium), 50 percent of the iodine as molecular iodine, and 1 percent of the remaining radionuclides as particulate. Its purpose was to evaluate the radiological consequences of a reactor accident and contains no estimate of the released particulate mass or size.

The use of this source term to estimate an aerosol mass release may lead to a serious underestimation of the aerosol mass source term. In their report to the Department of Energy, the National Research Council [1987] states: —

Research on severe accident source terms has been extensively pursued in connection with the regulation of commercial nuclear power reactors. This research has shown that source terms produced during reactor accidents will be quite different than hypothesized in the TID source term. The following points are among the more important research findings:

1. Iodine release from degrading reactor fuel will be nearly complete and may not be as iodine gas.
2. Release of radionuclides in particulate form can be greater than the one percent hypothesized in the TID Source Term.
3. Nonradioactive materials in particulate form will make a great contribution to the effluent produced in a reactor accident.

In order to properly assess the tradeoffs in the candidate particulate removal technologies, a design basis source term must be defined. The most significant of the parameters is the aerosol mass loading that the system will be expected to handle. Ahlfeld et al. [1986] have suggested that the "filter system must be capable of retaining a total solid load of up to 2500 lb."

3.0 PARTICLE AND GASEOUS CONTAMINANT REMOVAL MECHANISMS

The removal of particulate and gaseous contaminants from a gas stream is an ongoing area of research. Much of what is known about the performance of particle removal processes is empirical. The capability of models to predict performance is improving and these models are valuable in the design of systems and in assessing performance in regimes for which experimental data are sparse or nonexistent. Experimental testing and verification of performance is still required because of the interplay of a number of mechanisms that depend on the flow conditions, the actual filter media or removal system, and the particulate or gas being removed.

A particle removal device, such as a filter, wet scrubber, cyclone, or electrostatic precipitator, consists of a collecting surface across which particle-laden gas flows. Particles are removed by contact with the collector. Collectors may be the fibers in a High-Efficiency Particle Air (HEPA) filter, the granules in a sand bed filter, the water droplets in a spray tower, or a surface in a cyclone or electrostatic precipitator. Experimental and theoretical modelling efforts have identified a number of physical mechanisms by which particles are driven from a gas stream to the collector. The efficiency with which these various mechanisms remove particles depends on the particle size, the size and geometry of the collector, and the flow conditions. There are a number of references on particle removal and gas cleaning [Theodore and Buonicore, 1988; Ogawa, 1984; Bretschneider and Kurfurst, 1987; Brauer and Varma, 1981; Licht, 1988].

It is important to keep in mind that particles that have been collected can, under some circumstances, be re-entrained or resuspended into the gas stream. Mechanical shock or vibration can loosen particles from surfaces; changes in flow or pressure pulses can have the same effect. Particulate material suspended or dissolved in water can re-enter the gas stream by way of entrained water droplets.

Eight mechanisms of particle removal are discussed in the following sections.

3.1 SIEVING

When the particle-laden gas flows through the collector and a given particle's physical size is larger than the spacing between collectors, it is retained by the collectors. This mechanism requires the filter media be held in a fixed geometry. It depends on particle size and collector spacing, but is independent of flow. Examples are seen in the sieving of gravel with screens, or the collection of large particles by fiber filters or granular media filters.

3.2 GRAVITATIONAL SETTLING

All particles are affected by gravity. Under quiescent conditions this body force is counterbalanced by aerodynamic resistance so that particles attain a constant

settling velocity as shown in Figure 3.1. For particles larger than a few micrometers in size, this settling velocity dominates the other forces acting on the particle, such as Brownian or thermal motion and turbulent and convective gas motion (at least in a boundary layer), so that the particle has a net motion downward toward a collection surface. The collector may be a fiber, granule, or larger surface such as the floor of a settling chamber. For particles larger than about 100 micrometers, turbulence tends to reduce the rate of increase in settling velocity with respect to increasing size as shown in Figure 3.1. For small particles, typically submicrometer at normal temperatures and pressures, the settling velocity is smaller than or comparable to the velocities of turbulence, convection, and thermal motion, so that gravitational settling has a smaller effect on particle removal.

Examples of devices that rely on gravitational settling are gravitational settling chambers and gravitational settling in filters with downwardly directed flow. Particle collection efficiency in these devices increases with increasing aerodynamic equivalent particle size and with increasing residence time in proximity to the collector.

3.3 INERTIAL IMPACTION

Small particles with negligible inertia carried in a gas flow will follow the streamlines. Larger particles may cross streamlines to impact on the wall of a bend or an obstacle in the flow path. These particles are removed by impaction. Thus, particle collection efficiency increases with increasing aerodynamic equivalent particle size and flow, and with decreasing collector dimension. Examples of the mechanism of inertial impaction include large particle removal on a fiber, granular filter, venturi spray, or particle removal in cyclones.

3.4 INTERCEPTION

A particle that follows the gas streamlines may experience, because of its finite size, a grazing collision with a collector. This is interception. It differs from impaction since it does not require that the particle cross streamlines and is not as strongly dependent on gas flow. Interception depends on the relative size of the particle and the collector. It is the dominant collection mechanism for large particles in fiber or granular filters with low gas velocities. At high gas velocities, impaction may become the dominant collection mechanism.

Particle collection efficiency increases with increasing volume-equivalent particle size and with decreasing collector size. It is relatively independent of gas flow. Examples of interception are the collection of particles in fibrous or granular filter media.

3.5 DIFFUSION

Brownian motion causes particles to move with a net flux from areas of high to low particle concentration. The gas phase particle concentration at the surface of a collector is zero so that Brownian diffusion will cause particles to move toward the collector surface. Particle diffusion coefficients vary approximately inversely with particle diameter.

Particle collection efficiency increases with decreasing mobility-equivalent particle size and with increasing residence time in proximity to the collector (e.g., decreasing flow). It also increases with increasing collector surface area per unit flow volume. Examples of diffusion are the removal of small particles by fibrous and granular media and by water droplets. Gaseous contaminants can also be removed by diffusion to surfaces where they are physisorbed or chemisorbed.

3.6 ELECTROSTATICS

A particle can be electrically charged by the diffusion of ions to its surface, the deposition of ions onto the particle by an external electrical field, the breaking of contact with a surface or with other particles, and by radioactive decay causing it to lose electrons from the recoil of the nucleus. It can also acquire an induced dipole producing a local charge. An electrical field, produced by an externally imposed voltage difference or by static charges on a collector, can impose a force on charged particles. This force can act to move the particles toward or away from the collector depending on the sign of the charge and direction of the electric field. Dipolar particles are moved by electric field gradients. An induced charge on a particle by a statically charged collector acts to attract the particle to the collector. In devices designed to employ electrostatics to collect particles, particle charging and field direction are chosen to enhance collection. The electrostatic force on a particle depends on the mobility equivalent particle size, the charge on the particle, the particle's electrical properties, and the strength of the electrical field.

Particle collection efficiency increases with increasing charge on the particle, decreasing particle size, increasing electrical field strength, and increasing residence time in the proximity of the collector (e.g., decreasing flow). An example is the electrostatic precipitator.

3.7 THERMOPHORESIS

Particles suspended in a gas are seen to move down a thermal gradient, towards a cold surface and away from a hot surface. This phenomenon is generally not a mechanism that has been employed in particle removal systems. It can however contribute or detract from overall collection efficiency. A cold collection system may experience enhanced particle removal from a hot gas moving through it. Conversely, a hot collection system may experience degraded particle removal from a cold gas moving through it. The thermophoretic force on a particle

increases with increasing thermal gradient. It is not strongly dependent on particle size but can depend on the thermal properties of the particles and the carrier gas. Designers of a particle removal system should be aware of thermophoresis and how it may affect the operation of the system.

3.8 DIFFUSIOPHORESIS

Diffusion of gas vapor through a stagnant gas, as in the evaporation or condensation of water vapor, will affect the net flux of particles in the direction of the gas diffusion. Particles will be carried toward a surface where condensation is occurring and away from a surface where evaporation is occurring. Like thermophoresis, diffusiophoresis should be kept in mind by the designers of a particle removal system.

3.9 SUMMARY OF REMOVAL MECHANISMS

While these particle removal mechanisms act on particles at the same time, they act differently on different particle sizes. Sieving acts on the largest particles; impaction and interception act on particles on the order of a micrometer in size and increase in collection efficiency with increasing particle size; diffusion acts on particles on the order of a few tenths of a micrometer and increases in collection efficiency with decreasing particle size. This size dependence produces the phenomenon of the "most penetrating particle size." It is the particle size that is acted on comparably by more than one removal mechanism and not predominantly by any one mechanism. Generally this size occurs between one tenth and one micrometer in size. Figure 3.1 is a qualitative illustration of the interplay of the mechanisms in a particle removal system. These particle removal mechanisms are employed in several particle removal technologies. Four general technology types are discussed in Section 4.0.

The decontamination factor is defined as the concentration entering the system divided by the concentration leaving the system. It is the inverse of the fraction of particles penetrating the system. The total particle removal is the sum of the removal by all of the mechanisms which depend on the particle size. This yields a particle size dependent decontamination factor with a minimum at the size of maximum penetration.

Figure 3.1 Relative importance of deposition mechanisms as a function of diameter.

4.0 PARTICLE REMOVAL TECHNOLOGIES - AN OVERVIEW

There is extensive literature available on gas cleaning and particle removal technologies. Some of the references deal with systems employed in industrial and electrical power generation applications [Theodore and Buonicore, 1988; Ogawa, 1984; Bretschneider and Kurfurst, 1987; Brauer and Varma, 1981; Licht, 1988; Stern, 1977; Marchello and Kelly, 1975; Cheremisinoff and Young, 1977]. Others address nuclear air cleaning technologies that have been employed in nuclear materials processing [Sehmel, 1990; Reucker and Scott, 1987] and that are designed to be employed in the filtered venting of a reactor containment after an accident [Zaloudek et al., 1984; Postma and Hilliard, 1980; CSNI, 1988; Kovach, 1988]. The technologies reviewed in this report can be classified into four basic types:

1. Wet scrubbing, in which particles are collected on droplets or on wetted surfaces. This type of particle removal technology lends itself well to removal of gaseous contaminants and some wet scrubbing systems are designed primarily for gaseous contaminant removal.
2. Filtration, in which collectors are arranged in a matrix through which particle laden gas flows and particles are removed by coming into contact with the collectors.
3. Inertial separation, in which particles are removed from the gas flow by inertial forces when flowing gas is diverted over a curved surface.
4. Electrostatic collection, in which particles are removed from the gas flow by electrostatic forces.

4.1 WET SCRUBBING

Wet scrubbing removes particles by collecting them on a liquid surface by one or more of the particle collection mechanisms discussed earlier. Gaseous contaminants will be advected, i.e., will diffuse to the liquid surface, where they may be removed from the flow stream by absorption, and retained by chemical reaction or dissolution. Wet scrubbing humidifies the gas and may introduce water droplets into the gas flow. These droplets may contain particulate or gaseous contaminant material and can be removed by a variety of mist or droplet eliminators [Talavera, 1990]. Therefore, it is necessary to determine the effect of a saturated or nearly saturated gas stream on the performance of components downstream of the scrubber. Heaters can be used to raise the gas temperature and reduce the relative humidity. Wet scrubbing can also act to cool a hot gas and to condense steam. The phenomena of thermophoresis and diffusiophoresis may affect the collection of particles. Evaporation from the liquid surface can retard particle collection. To avoid this problem, wet scrubbing systems often employ an evaporation section or use part of a scrubbing section to saturate the gas before

passing it through the collection section. Condensation of steam can enhance particle removal as a result of the thermal gradient between a hot gas and a cool surface.

The removal of particulate and gaseous contaminants by wet scrubbing falls into three general types, or configurations. The first configuration involves the collection of particles on droplets (usually water, sometimes treated to enhance retention of absorbed materials) moving through the gas. Particles are collected by the droplets through the mechanisms of inertial impaction, interception, and diffusion. Thermophoresis and diffusiophoresis may affect the collection of particles but these phenomena are usually considered in the design. The droplets are usually much larger than the particles being collected so that interception is not a dominant mechanism for collection. The larger particles are collected by impaction on the droplets so that the relative velocity of the droplet and the particle-laden gas is a strong determinant of the collection efficiency; the higher the relative velocity, the higher the collection efficiency for a given particle size and the smaller the particle that can be collected at a given efficiency. Very small particles and gaseous contaminants are collected by diffusion. The number of droplets and the residence time of the gas in the droplet field are the principle determinants of the collection efficiency; the higher the droplet concentration and the longer the residence time, the higher the collection efficiency.

In spray columns, an example of the first configuration, gas flows through a spray of droplets and the relative velocity between the droplets and the particles is determined by the fall velocity of the droplets. These columns are more effective for removal of gaseous contaminants (given the relatively long residence time) than for particles. Typically, columns remove particles on the order of a few micrometers in size with an efficiency on the order of 90 percent; larger particles are removed more efficiently, smaller particles less so. To improve the collection efficiency of smaller particles the gas can be accelerated through the droplet field so that the relative velocity is determined by the gas velocity. This is typical of the operation of wet venturis in which a gas flow is accelerated through the throat of a venturi into which a spray of liquid droplets is introduced. This method lowers the particle size collected to less than a micrometer but at the cost of a higher pressure drop across the venturi and a lower collection efficiency for gaseous contaminants because of the decreased residence time.

The second configuration is a wet packed bed or submerged bed of granules. In this system a liquid, generally water, and the particle-laden gas flow simultaneously through a bed of collectors. This configuration can be thought of as a wet filter with the liquid acting as a collector. The presence of the liquid produces narrowed passageways that increase the gas velocities over those produced in a dry bed. The complicated physics of this process is difficult to model and the performance of this type of wet scrubber is usually determined empirically. Particles may be collected through the mechanisms of inertial impaction, gravitational settling, interception, and diffusion. Thermophoresis and diffusiophoresis may also be

active. Generally, particles on the order of a micrometer are collected with an efficiency on the order of 90 percent and larger particles are collected with higher efficiencies.

The third configuration consists of gas bubbles moving up through a liquid. This configuration has been modeled and its behavior tested extensively [Fuchs, 1964; Owczarski et al., 1983; Wassel et al., 1984; Paul et al., 1984; and Brockmann, 1985]. The specific mechanisms of particle collection include gravitational settling in the bubble, inertial impaction on the wall of the bubble during formation and from centrifugal force in the recirculating gas of the rising bubble, and diffusion to the walls of the bubble. Steam condensation enhances the collection of particles. Thermophoresis is not significant since the gas and liquid come to thermal equilibrium quickly. The smaller the bubble and the greater the pool depth through which the bubble rises, the higher the particle removal efficiency. This configuration occurs in the last part of a submerged bed scrubber and in the Multi Venturi Scrubber System.

4.2 FILTRATION

Classically, filtration is the removal of particulate material from a gas stream by flowing it through a matrix of fixed collectors. These collectors can be fibers, granules, or porous, permeable, or perforated membranes. The size of the collectors and the spaces between them range from micrometers to centimeters. The collectors may occupy a wide range of volume fractions in the filter and the filter may have a depth of fractions of an inch up to several feet.

Particles are collected by sieving, impaction, interception, and diffusion. Some filters have electrets, permanent electric dipoles, embedded in them to enhance collection by electrostatic forces while other filters contain charged wires to produce electric fields for electrostatic enhancement. Under wet conditions diffusiophoresis may affect particle removal. Thermophoresis may influence particle removal if a large temperature difference between the filter and the gas exists. Generally, diffusiophoresis and thermophoresis do not play a major role in particle collection in filters.

In filters with small, closely spaced collectors, typical of the High Efficiency Particle Air (HEPA) filters, most of the particle collection occurs at the filter surface initially presented to the gas flow and a far lesser amount in the depth of the filter. For this reason, this type of filter may be thin and still be effective in removal of particulate. Filters with larger collector spacing or larger collector size, typical of deep bed fiber filters and sand and gravel bed filters, demonstrate less of the surface filtration effect and more of a depth filtration effect. These filters have a greater depth in order to achieve high particle removal.

The velocity of the gas through the filter has a strong effect on filter performance. The velocity of the gas normal to the filter surface is called the face velocity.

Pressure drop in a filter is roughly linear with face velocity over the range of flows and pressure drops for which it is designed. Higher gas velocities will increase particle collection efficiency by impaction and will decrease particle collection efficiency by diffusion; gas velocity has little effect on a collection efficiency by interception. The general effect of increasing gas flow through a filter is to increase the pressure drop, increase the collection efficiency of particles on the order of a micrometer and larger in size, and decrease the collection efficiency of particles on the order of a tenth of a micrometer and smaller in size.

Collected particulate will increase the pressure drop across the filter. Depth collection of particulate acts to narrow the passages through which the gas flows and results in increased pressure drop across the filter. Surface collection builds up a cake of collected particulate through which the gas must flow and affects the pressure drop across the filter. In baghouses, cloth filters rely on this mechanism to improve the particle collection efficiency. The cake presents resistance to flow depending on the porosity and particle size of the collected material and regular cleaning in the case of baghouse filters is necessary to control the pressure drop. Indeed, baghouses require not only that cake buildup occur, but that it be easily removed upon cleaning. The efficiency and pressure drop behavior of a filter with loading cannot be determined independently of the physical and chemical characteristics of the particles being collected. Filters that exhibit strong surface filtration are more dependent on the particle characteristics than filters that exhibit stronger depth filtration; this is partly because surface loading concentrates the particles into a smaller volume. It should be noted that depth filters are also capable of surface loading. The collected surface material acts as a filter itself and, in some applications, is used to increase the filter collection efficiency.

Water or any other liquid can have a pronounced effect on the performance of a filter. Liquid wetting the filter media will narrow the flow paths so that the pressure drop increases for a given flow. The liquid affects the collected particulate by reducing porosity and densifying the cake, increasing the resistance to flow, and hampering the cleaning process. The filter media may become wet by collection of liquid droplets, by condensation of water on the media, or by hygroscopicity of the collected particle material. Liquid on a filter reduces the effectiveness of the filter. The liquid can be forced through the filter media by the gas flow. Collected material that is dissolved or suspended in the liquid and washed through the filter media may be entrained into the gas flow off the back side of the filter. This "breakthrough" defeats the purpose of the filter, providing a pathway for particle contamination through the filter.

4.3 INERTIAL SEPARATION

When a direction change is imposed on a particle-laden gas flow by impingement on a surface or by flowing through a bend or turn, particles possessing sufficient inertia are not able to follow the gas flow. They travel across streamlines toward a surface where they are trapped in the boundary layer or are collected by contact

with the surface. In some of these applications the collected or trapped particles settle to a collection area, or liquid washes the particulate buildup from the surface for retention.

In jet impingement systems, higher jet velocities increase the collection efficiency for a given aerodynamic-equivalent particle size and decrease the particle size collected with a given efficiency. Cyclone collectors, in which the gas flows along a curved surface, operate with higher collection efficiencies for smaller radii of curvature and higher gas velocities.

Inertial deposition of airborne particles is enhanced by increases in particle mass and gas velocity and inhibited by increases in gas viscosity. Since elevated gas pressures result in increased gas densities, the buoyant effect of the gas on the particle is increased; the effect is minor however. Gas viscosity increases significantly with increases in the gas temperature and affects the particle velocity toward the wall adversely. However, higher temperatures increase the gas inlet velocity, resulting in increased particle velocities toward the wall. Consequently, the two effects associated with a temperature increase tend to cancel each other in the normal operating range of 6 to 370°C. Above 540°C, viscosity effects predominate and the efficiency drops. Changes in the gas composition also affect both the gas viscosity and density.

4.4 ELECTROSTATIC PRECIPITATION

Electrostatic precipitators are used extensively in industry for removing small particles suspended in gases. Particle removal is accomplished by charging the particles while simultaneously subjecting the charged particle-laden gas to a strong electric field. The charged particles in the field migrate away from like-charged boundaries of the field. At least one boundary of the field terminates on a collecting plate having opposite polarity from the particles. It is on this collecting plate that the charged particles are deposited and lose their charge.

In a typical arrangement, vertically suspended wires are charged to thousands of volts, which produce a sufficiently high electric field strength that the adjacent gas molecules breakdown and form ions. This breakdown produces a bluish glow around the wires and is called a "corona". Negative coronas have been found to be more stable than positive. The negative gas ions produced by the corona migrate away from the corona wires and some collide with aerosol particles, charging them by field charging. For negatively charged wires, the particles attain a negative charge.

In either a positive or negative corona, the forces operating on particles are coulombic and viscous. The coulombic force pushes the particles away from the corona-forming surface, while viscous air drag limits particle acceleration. Since the particle mass is so small, particles quickly attain a steady-state migration velocity determined by the balance of coulombic and viscous forces. This velocity

increases with increasing particle charge, decreasing particle diameter, and increasing field intensity. Since the flow is generally turbulent in commercial electrostatic precipitators, the migration velocity is determined experimentally.

Electrostatic precipitators can be run using a water wash to remove collected particulate. The spray simultaneously cools the precipitator and absorbs gaseous contaminants.

5.0 CURRENT AACS

The current Airborne Activity Confinement System (AACS) employed on the Savannah River production reactors [Tinnes and Petry, 1986] consists of five aluminum filter compartments operating in parallel. They are independent of one another and may be individually detached and isolated from the exhaust flow. Each filter compartment consists of:

1. a parallel bank of 20 mist eliminators ("Demisters", the registered trademark of Otto H. York Co.) to remove liquid water, each rated at 1600 cfm with a 1 inch of water pressure drop,
2. a parallel bank of 32 HEPA filters each rated at 1000 cfm with a 1 inch of water pressure drop, and,
3. a parallel bank of 32 impregnated, activated carbon beds rated at 1000 cfm with a pressure drop between 0.1 and 1.1 inch of water.

Each of the filter compartments is rated at 32,000 cfm at 3.1 inches of water pressure drop. Normally the system is in continuous operation with all five filter compartments on line. Three filter compartments are required to be on line. A clean compartment is normally operated between 27,000 and 28,000 cfm and a dirty compartment (one in which particle loading on the components has caused the compartment to have the maximum flow resistance allowed by current operating procedures) is operated between 19,000 and 21,000 cfm at a pressure drop of about 2.7 inches of water.

The mist eliminators are of the woven-mat type and rated to remove 99 percent of the 1 to 5 μm diameter water droplets. These mist eliminators also act as an effective roughing filter, extending the life of the HEPA filters by reducing the loading under normal operation. While beneficial during normal operation, the high aerosol loading during a severe accident might result in loading of the mist eliminators, an increase in the pressure drop, a decrease in the flow, and may cause the total system flow rates to fall below the required minimum total flow of 40,000 cfm. Alternatively, the increased loading could cause failure of the mist eliminators producing a pressure pulse and possibly failing some of the HEPA filters. It is good practice to protect the HEPA filters, but the protection scheme should be able to handle the highest design loading without failing or exceeding the design flow resistance.

The water repellent glass fiber HEPA filters are highly effective in removing particulate. There are, however, three major drawbacks.

1. Sensitivity to pressure. These filters are designed for low pressure drop operation and as such, are generally not intended for use in operations where high pressure drops across the filter can occur. Pressure pulses

on the order of 10 inches of water can damage the filter and cause it to fail. Pressure pulses of this magnitude can arise from failure of a blocked upstream element, such as a prefilter or mist eliminator, or from hydrogen detonations or combustion upstream of the filter.

2. Limited loading capacity. The loading of HEPA filters produces an increase in pressure drop and, under some severe accident conditions, this loading and the accompanying pressure drop could be high. Loading of the filters could decrease flow to below the minimum design value and could result in filter failure. The loading capacity of a filter compartment is on the order of 70 to 110 pounds of material [National Research Council, 1987].
3. Adverse effect of water. Although the mist eliminators should remove most of the liquid water before it reaches the HEPA filters, saturated air and the possibility of some liquid water reaching the filters could result in wet operation. A water repellent filter media has been used and does improve performance over more conventional HEPA filters, but wet operation will still result in weakened filter media and a higher pressure drop with all the attendant problems.

The impregnated, activated carbon filters will remove the molecular iodine and several of the iodine compounds. As a result of radioactive decay, the collected iodine presents a heat source to the carbon in the filters and, at credible loadings for a severe accident, the gas flow through the filters must be maintained to cool them. If the flow drops below a level adequate to cool the carbon filters (possibly because of high mist eliminator and/or HEPA filter loading), the rising temperature of the beds would lead to thermal desorption of the collected iodine and possibly to the combustion of the carbon producing an even higher release.

6.0 ISSUES IN AN AACS UPGRADE

The issues to address in the upgrade of the particle removal system of the AACS are discussed below.

6.1 AEROSOL LOADING

Aerosol loading is the most pressing issue. The authors have not been given a design base aerosol source term; however evidence suggests that the capacity of the existing system is not high enough [National Research Council, 1987]. The loading capacity of the existing system (210 to 330 pounds) is an order of magnitude lower than the capacity suggested (2500 pounds) by Ahlfeld et al. [1986]. This issue may be addressed by increasing the size of the existing system. More robust filters with a higher loading capacity could be used but the higher particle loading would entail a penalty in increased flow resistance. Prefilter or roughing filter systems could be used to protect the HEPA filters from over loading but then blinding, or plugging, of these systems becomes an issue.

6.2 PRESSURE DROP

Each existing filter compartment is rated at 32,000 cfm with a clean pressure drop of about 3.1 inches of water, and is operated at about 2.7 inches of water [Tinnes and Petry, 1986]. Loading of this system produces an increase in flow resistance. The use of a more robust high efficiency filter than the current HEPA filter may allow increased loading capacity but at a higher pressure drop. Introduction of an additional or alternative particle removal system may increase the pressure drop requiring an upgrade of the air mover system.

In a filter system, the pressure drop can be linearly related to loading and to flow rate under some conditions. Other particle removal systems in which the gas does not flow through the collected particulate have little dependence of pressure drop on loading.

6.3 GAS FLOW RATE

Each existing filter compartment accommodates an air flow of 27,000 to 28,000 cfm when clean and 19,000 to 21,000 cfm when dirty. The existing system requires a minimum flow rate of 40,000 cfm to maintain all the process areas at a negative pressure. The normal operating flow is 120,000 cfm with all five filter compartments on line (3 clean, 2 dirty) [Tinnes and Petry, 1986]. In an alternate flow system the gas flow was recirculated and 2000 cfm was filtered and exhausted from the reactor process room (this accounted for leakage into the process areas kept at negative pressure) [Ahlfeld et al., 1986]. A broad range of flow rates is possible depending on the extent to which the existing system can be modified.

Filter loading, gas flow rate, and pressure drop are all related. Generally lower flow rates yield lower pressure drops in most systems. Higher filter loading yields lower flow at a given pressure drop or higher pressure drop at a given flow.

6.4 WATER AND MOISTURE

Liquid water can adversely affect the existing system: it increases the flow resistance of the filters and has a detrimental effect on the strength of the media so that the likelihood of failure is increased. Liquid water can wick through the media resulting in penetration of contaminant material through the filters. In order to mitigate these effects, the current system employs mist eliminators to remove the liquid water from the gas flow. The filter media itself is water repellent so that the detrimental effects of water on the current HEPA filters is reduced compared to more conventional HEPA filters. The presence of water in the gas flow must be considered because accidents in which steam is released or in which reactor room sprays are activated are part of the design base.

Approaches to handling the water in the AACs include mist eliminators (currently used), alternative mist elimination systems that may be part of alternative particle removal systems, or gas heating to evaporate the water droplets and drop the relative humidity.

6.5 GAS TEMPERATURE

The gas temperature may be 100°C or higher. The particle removal system must be able to handle these temperatures or be able to cool the gas or both. Systems that employ wet scrubbing have this potential.

6.6 DECAY HEAT

The decay heat of collected radionuclides, either as particulate such as cesium or as gas such as iodine, provides a heat load to the particle removal system. The system should be able to handle the heat load without failure. Reliance on flow to keep the system within an acceptable temperature range requires a high confidence that aerosol loading or fan failure will not hinder the flow. A system that has a high temperature handling capability requires less gas flow for cooling and may not require a continuing gas flow through the system for cooling.

The carbon beds that retain the radio-iodine rely on gas flow for cooling. This problem may be overcome by actively cooling the beds using water recirculation through cooling coils, or by decreasing the iodine loading of the beds. Some of the wet scrubbing alternate particle removal technologies have the capability for removing iodine and would act to decrease the decay heat load on the carbon beds.

6.7 RADIATION

The specifications for water repellent particulate filters in the AACS system analysis document [Tinnes and Petry, 1986] requires that the media be able to pass the water repellency and wet strength tests after exposure to 8×10^7 to 1×10^8 rads of gamma or beta radiation. Alternate technologies should also be able to function at this exposure level.

6.8 CONTINUOUS OR ON-DEMAND OPERATION

The existing AACS operates continuously, assuring that the system is on-line if needed. The relative passivity of the system (only the air moving system is active) facilitates this type of continuous operation. Alternative systems which entail higher pressure drops (and therefore greater demand on and cost of operation of the air moving system) and water recirculation will cost more to operate. The tradeoffs between assuring reliability in on-demand operation and the operating costs of continuous operation must be examined for the alternate technologies.

6.9 COMPATIBILITY WITH EXISTING SYSTEM

It would be desirable if a technology could be identified that would address all the shortcomings of the existing system and would be exactly interchangeable with the existing system. A one-for-one exchange with the current HEPA filters employing the same mounting hardware and filter compartments and operating within the same flow and pressure drop range. This does not appear to be achievable. The next most compatible system would offer a replacement to the filter compartment that is of the same size and weight and that will operate within the same flow and pressure drop range. As alternatives become less and less compatible, they become heavier or larger requiring more and more construction for the installation and higher and higher pressure drops necessitating a modification to the air moving system. They may also require a redesign of the flow system, or construction of separate facilities. Compatibility ranges from a one-for-one replacement to a completely different system. Elements of compatibility ranging from more to less are listed below:

- One-for-one replacement of HEPA filters in each compartment,
- One-for-one replacement of filter compartments,
- Retention of existing flow system.

This work does not specify a particle removal system. The following sections identify a number of alternative technologies that could be applied. Selection of an alternate system must be performed with regard to the above issues, specified flows and allowable pressure drops, and a well-defined design base aerosol source term.

7.0 REFERENCES

Ahlfeld, C. E. et al., 1986, Basic Data, Improved Reactor Confinement, RTW-234, E. I. du Pont de Nemours & Co., Savannah River Plant, Aiken, SC.

Brauer, H. and Varma, Y. B. G., 1981, Air Pollution Control Equipment, Springer-Verlag, New York.

Bretschneider, B. and Kurfurst, J., 1987, Air Pollution Control Technology, Elsevier, New York.

Brockmann, J. E., 1985, "Uncertainties in Aerosol Removal By Suppression Pool Scrubbing," Appendix E in Uncertainty in Radionuclide Release Under Specific LWR Accident Conditions, Mast, P. K. et al., SAND84-0410, Volume 4, Sandia National Laboratories, Albuquerque, NM.

Cheremisinoff, P. N., and Young, R. A., 1977, Air Pollution Control and Design Handbook, Marcel Dekker, New York.

CSNI, 1988, Proc. of the Specialists Mtg. on Filtered Containment Venting Systems, CSNI Report number 148, Paris, 17 and 18, May.

DiNunno, J. J., 1962, Calculation of Distance Factors for Power and Test Reactor Sites, TID-14844, U.S. Atomic Energy Commission, Washington, D.C.

Fuchs, N. A., 1964, The Mechanics of Aerosols, Pergammon Press, New York, p.240.

Hinds, W. C., 1982, Aerosol Technology, John Wiley and Sons, New York.

Kovach, J. L., 1988, "Review of Containment Vent Filter Technology," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conf., Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 21-97.

Licht, W., 1988, Air Pollution Control Engineering, 2nd edition, Marcel Dekker, Inc., New York.

Marchello, J. M. and Kelly, J. J., 1975, Gas Cleaning for Air Quality Control, Marcel Dekker, New York.

National Research Council, 1987, Safety Issues at the Defense Production Reactors. A Report to the U.S. Department of Energy, Committee to Assess Safety and Technical Issues at DOE Reactors Commission of Physical Sciences, Mathematics, and Resources and the Commission on Engineering Systems National Research Council, National Academy Press, Washington, D.C.

Owczarski, P. C., Postma, A. K., and Schrek, R. L., 1983, Technical Basis and User's Manual for SPARC -- A Suppression Pool Aerosol Removal Code, NUREG/CR-3317, PNL-4742, Pacific Northwest Laboratory, Richland, WA.

Ogawa, A., 1984, Separation of Particles from Air and Gases, Volumes I and II, CRC Press, Boca Raton, FL.

Paul, D. D. et al., 1984, "Radionuclide Scrubbing in Water Pools: Gas-Liquid Hydrodynamics," presented at ANS Topical Meeting on Fission Product Behavior and Source Term Research, July, Snowbird, UT.

Postma, A. K. and Hilliard, R. K., 1980, Evaluation of Air Cleaning Systems for FFTF Containment Margins, HEDL-TME-79-79, Hanford Engineering Development Laboratory, Richland, WA.

Ruecker, C. M. and Scott, P. A., 1987, Design Procedure for Sizing a Submerged-Bed Scrubber for Airborne Particulate Removal, PNL-6036, Pacific Northwest Laboratory, Richland, WA.

Sehmel, G. A., 1990, A Review of the Potential Alternatives for Air Cleaning at the Hanford Waste Vitrification Plant, PNL-7391, UC-721, Pacific Northwest Laboratory, Richland, WA.

Stumm, W., 1977, Water Pollution Engineering, Volume IV, Academic Press, New York.

Talavera, P. G., 1990, "Selecting Gas/Liquid Separators," Hydrocarbon Processing, Volume 69(6), pp. 81-84.

Theodore, L. and Buonicore, A. J., 1988, Air Pollution Control Equipment, Volumes I and II, CRC Press, Boca Raton, FL.

Tinnes, S. P. and Petry, S. F., 1986, System Analysis - Airborne Activity Confinement System of the Savannah River Production Reactors, DPSTSY-100-10, E. I. du Pont de Nemours & Co., Savannah River Plant, Aiken, SC.

Wassel, A. T. et al., 1984, "Scrubbing of Radionuclide Aerosols in Water Pools," presented at ANS Topical Meeting on Fission Product Behavior and Source Term Research, July, Snowbird, UT.

Zaloudek, F. R., Postma, A. K., and Winegardner, W. K., 1984, Fission Product Removal in Engineered Safety Feature (ESF) Systems, PNL-5050, Pacific Northwest Laboratory, Richland WA.

8.0 ALTERNATE PARTICLE REMOVAL TECHNOLOGIES

I. WATER SPRAY SCRUBBERS

Water spray scrubbers are a general type of gas cleaning device that uses a spray of water drops to clean a gas by removal of those particles larger than $10\ \mu\text{m}$ and gaseous contaminants by absorption by the water drops. Their use is better suited to gaseous contaminant removal than to aerosol removal although they can serve the function of a roughing aerosol filter. They have a low pressure drop and relatively high gas throughput but require a water handling system. These scrubbers are described in Theodore and Buonicore [1988], Ogawa [1984], Licht [1988], and Stern [1977].

I.1 DESCRIPTION

A typical spray tower is described in order to examine the performance of water sprays in the removal of aerosol particles and iodine from a flowing gas. The spray tower consists of a large volume with a water spray directed downward through the upflowing gas (see Figure I.1). The water droplet diameters range from 300 to 900 μm [Licht, 1988]. Water requirements are on the order of 3 to 20 gallons of water per 1000 ft^3 of gas scrubbed. The upward gas velocity is on the order of 100 to 300 fpm and residence times in the tower are on the order of 20 seconds [Theodore and Buonicore, 1988]. Mist elimination may be required.

Postma and Hilliard [1980] describe a spray chamber design of 34 ft in diameter and 25 ft high operating at a gas flow of 6500 cfm. This vessel has a volume of 22,700 ft^3 , or about 3500 ft^3 per 1000 cfm of gas. Water is recirculated from an 8000 gallon reservoir at a rate of 450 gallons per minute, about 70 gallons per 1000 ft^3 of gas scrubbed. The effective droplet diameter is specified at 1200 μm and the residence time is 0.5 minutes. The long residence time and high water flow (in excess of typical flow rates [Theodore and Buonicore, 1988]) was calculated to yield a 90 percent collection efficiency of an aerosol distribution with an aerodynamic mass mean diameter of 5.6 μm .

I.1.1 PRINCIPLES OF OPERATION

Collection of particulate by falling water drops occurs primarily by impaction and interception. The low relative velocity between the particles in the gas and the falling drops limits efficient collection by impaction to large particles. Also, the large (typically several hundred micrometers) collector size makes interception efficiency low for all but large particles. Evaporation and condensation may bring diffusiophoresis into play, but the gas and drops generally come to equilibrium on a time scale that is small compared to the residence time. Rimberg and Peng [1977] give a comprehensive review of aerosol collection by falling water drops.

The gaseous contaminant diffuses to the surface where it is absorbed. Iodine will be retained if the drop is buffered to a high pH. Increasing either the residence time or the water flow will increase the particle and iodine removal efficiencies as illustrated by the work of Postma and Hilliard [1980].

1.1.2 OPERATIONAL PARAMETERS

Flow Rate

Spray towers can be designed to accommodate high gas flow rates. Generally, gas velocities are on the order of 100 to 300 fpm. This will dictate the flow area that is required for a given volumetric flow. Lower gas velocities can be used but at higher flow areas and tower volumes.

Pressure Drop

The pressure drop in a spray tower is typically very low, about 1 to 2 inches of water. This does not include the pressure drop in a mist eliminator.

Removal Efficiency

The removal efficiency is typically 70 percent for 10 μm particles. Higher efficiencies can be realized with longer residence times and higher water flow rates.

Aerosol Loading

Aerosol loading of the spray tower is limited only by the ability of the water handling system to deal with the collected particulate. The system described by Postma and Hilliard [1980] was designed to accommodate a total loading of over 10,000 pounds of particulate.

Size

These systems are typically large with a sprayed volume on the order of 300 to 500 ft^3 per 1000 cfm of gas flow. While the structures are large, they do not contain much more than empty flow space occupied by spray nozzles. Sufficient water storage and pumping capacity is required for delivery of 3 to 20 gpm per 1000 cfm of gas flow.

Maintenance and Peripheral Equipment

Periodic inspection of the water quality, the condition of the nozzles, and the condition of the tank, as well as testing for performance, is expected maintenance. The water levels and pH must be monitored and maintained. Periodic cleaning of the water is required and this would entail the use of additional equipment. The pumps and water storage and handling facilities are required peripheral equipment.

Lifetime

The lifetime is expected to be comparable to that of the facility being serviced.

Waste and Waste Handling

The water cleaning and handling system may generate liquid waste. Waste water and the containing structural components would have to be dealt with upon decommissioning or in the event of use during an accident.

I.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Particle removal efficiency is not high in water spray scrubbers. It may not even be satisfactory as a roughing filter because the efficiency for 10 μm particles is only on the order of 70 percent and falls off with decreasing particle size. If the aerodynamic mass median size of the aerosol is much below this, little of the aerosol will be removed. Higher efficiency can be attained but at the cost of very large volumes (to increase residence time to the order of minutes) and high water flow rates.

Iodine Removal

Molecular iodine removal is performed by diffusion of the iodine to the drops. Retention of the dissolved iodine is accomplished by buffering the water to a pH of 9 to 11. Iodine removal efficiency is higher than the 50 to 80 percent removal achieved by a venturi scrubber.

Particle Loading Capacity

The particle loading capacity is high.

Pressure Drop

The pressure drop in the spray tower is 1 to 2 inches of water.

Gas Flow Capacity

The gas flow capacity of the spray tower is high. A high capacity system can be designed with a sprayed volume of 300 to 500 ft^3 per 1000 cfm of gas flow.

Radiation

Radiation exposure is not a problem for this system.

Temperatures

This system will cool a high temperature gas and condense steam. It will take high temperature inlet gas and reduce the temperature to within the operating limits of more sensitive downstream components.

Water and Moisture

The spray tower can handle wet systems and if the gas flow is kept low (below 300 fpm) liquid entrainment is not high. The exit gas will be close to saturation and downstream heaters may be necessary to reduce the relative humidity.

Other Caveats

The water is alkaline for retention of molecular iodine and may present a corrosion problem.

I.3 SUMMARY

The spray tower scrubber, with a typical removal efficiency of about 70 percent for 10 μ m particles, is not a strong candidate for aerosol removal in the AACS. Molecular iodine is removed moderately well at an expected level of about 80 percent. The system will cool the gas. The pressure drop is low but additional water pumping and handling equipment would be needed along with the increased maintenance and cleaning this would require.

I.4 REFERENCES

- Licht, W., 1988, Air Pollution Control Engineering, 2nd edition, Marcel Dekker, Inc., New York.
- Ogawa, A., 1984, Separation of Particles from Air and Gases, Volumes I and II, CRC Press, Boca Raton, FL.
- Postma, A. K. and Hilliard, R. K., 1980, Evaluation of Air Cleaning Systems for FFTF Containment Margins, HEDL-TME-79-79, Hanford Engineering Development Laboratory, Richland, WA.
- Theodore, L. and Buonicore, A. J., 1988, Air Pollution Control Equipment, Volumes I and II, CRC Press, Boca Raton, FL.
- Rimberg, D. and Peng, Y. M., 1977, "Aerosol Collection By Falling Droplets," in Air Pollution Control and Design Handbook. Part 2, Cheremisinoff, P. N., and Young, R. A. (eds.), Marcel Dekker, New York, pp. 729-746.

Stern, A. C., ed., 1977, Air Pollution, 3rd edition, Volume IV, Academic Press, New York.

Figure I.1 Schematic diagram of a spray tower scrubber.

II. WET BED SCRUBBERS

Wet bed scrubbers include packed bed scrubbers [Theodore and Buonicore, 1988; Brauer and Varma, 1981; MacDonald, 1977] and submerged bed scrubbers [Postma and Hilliard, 1980; Ruecker and Scott, 1987]. Both will be discussed in this section. They are similar in that each is composed of a bed of material such as rock, gravel, or ceramic packing, and each operates with water and gas flowing simultaneously through the bed. Both systems are effective in the removal of particulate larger than 3 to 5 μm [Theodore and Buonicore, 1988]. The submerged bed scrubber (SBS) removes 75 percent of particles on the order of 0.5 μm in diameter [Ruecker and Scott, 1987].

II.1 DESCRIPTION

A packed bed scrubber consists of packing material composed of ceramic or steel shapes designed to provide a high liquid-gas contact surface area (see Figure II.1). There are three basic flow configurations for packed bed scrubbers:

1. countercurrent flow - water flows down, gas flows up,
2. cocurrent flow - water and gas both flow down, and,
3. cross flow - water flows down, gas flows horizontally.

In some cross flow applications the water flows down from the top of the packed bed, and in others water is sprayed onto the "top" horizontal surface of the packed bed. The water washes the packing and removes the trapped particulate. Packed bed scrubbers are very effective in removing soluble gases like molecular iodine.

The submerged bed scrubber (SBS) was developed at Hanford Engineering Development Laboratory and Pacific Northwest Laboratory to clean exhaust gas from hypothetical reactor accidents involving sodium fires and the interaction of sodium with concrete. The SBS consists of a bed of nominally 1 inch gravel, 1.8 ft deep, submerged in a water pool with the top of the bed about 0.5 ft below the surface. The gas is introduced at the bottom of the bed and buoyancy forces the gas to rise through the bed (see Figure II.2). This causes recirculation of water through the bed in an action similar to a cocurrent flow packed bed except that the flow is up and there is much more water. The SBS does not require pumping or a water handling system as do other packed bed scrubbers.

II.1.1 PRINCIPLES OF OPERATION

The operating principle of these wet bed scrubbers is the same. Particles are removed by impaction and interception with the packing elements and the water surface, ligaments, and droplets. Gaseous contaminants are removed by diffusion to the water surface and dissolution in the water. Water is buffered to a pH of 9 to 11 to retain the dissolved molecular iodine.

II.1.2 OPERATIONAL PARAMETERS

Flow Rate

The flow rate through the SBS is low with a face velocity of 20 to 40 fpm. The flow rate through the packed bed scrubbers is higher at 180 to 400 fpm depending on the bed packing.

Pressure Drop

The pressure drop for the SBS is 35 inches of water. Pressure drop in the packed bed scrubbers depends on the bed depth, flow configuration and water flow. Typical pressure drop ranges for the three packed bed configurations are listed in Table II.1.

Removal Efficiency

The particle removal efficiency for the SBS is greater than 75 percent for particles between 0.3 and 0.7 μm in diameter, and much higher for larger particles.

The particle removal efficiency for the packed bed scrubbers depends on bed depth, packing material, size, and flow rate. They are generally able to collect on the order of half the particles at a few micrometers and better than 90 percent at about 5 μm .

Removal efficiency for molecular iodine in the SBS and packed bed scrubbers is approximately 90 percent.

Aerosol Loading

The integral loading capacity is high for the wet bed scrubbers. However, packed bed scrubber may have difficulty in handling inlet mass concentrations in excess of 15 to 25 mg/ft^3 [MacDonald, 1977]. A design base aerosol source term is essential. There is no limit on the inlet aerosol concentration for the SBS.

Size

The SBS has a face velocity of 20 to 40 fpm which is an order of magnitude lower than the effective face velocity of the HEPA filters in current use. The additional requirement of a comparable area of free water gives a large combined area of bed and free water.

At face velocities of 180 to 400 fpm, the flow area of packed bed scrubbers is comparable to that of the HEPA filters in current use.

Maintenance and Peripheral Equipment

Periodic inspection of the water quality, the condition of the bed and the tank, as well as testing for performance, are required maintenance. The water levels and pH must be monitored and maintained. Periodic cleaning of the water is required and this would entail the use of additional equipment. The pumps, water storage, and water handling facilities for packed bed scrubbers are required as peripheral equipment.

Lifetime

The lifetime of the wet bed scrubbers is comparable to that of the facility being serviced.

Waste and Waste Handling

The water cleaning and handling system may generate liquid waste. Waste water, the bed materials, and the containing structural components would have to be dealt with upon decommissioning or in the event of use during an accident.

II.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Particle removal efficiency is low for small particles. Wet bed scrubbers are, at best, useful as roughing filters for higher efficiency particulate filters.

Iodine Removal

The strong suit of wet bed scrubbers is molecular iodine removal. They could prove useful in reducing the heat load on activated carbon filters by reducing the amount of iodine in the process stream.

Particle Loading Capacity

The particle loading capacity is high for wet bed scrubbers. However, packed bed scrubbers may have trouble handling inlet concentrations over 15 to 25 mg/ft³.

Pressure Drop

The pressure drop of 35 inches of water for the SBS is an order of magnitude higher than the current filter compartment. Packed bed scrubbers have pressure drops comparable to the current system.

Gas Flow Capacity

Wet bed scrubbers can be designed to handle high flow capacity. Packed bed scrubbers have face velocities comparable to the current system. The SBS has a much lower face velocity and would be much larger in size for the same given capacity.

Radiation

These devices are not expected to be adversely affected by radiation

Temperatures

This system will cool a high temperature gas and condense steam. It will take high temperature inlet gas and reduce the temperature to within the operating limits of more sensitive downstream components.

Water and Moisture

The wet bed scrubber can handle wet gas systems and will remove large water droplets. The SBS can entrain water and a mist eliminator may be required. For the packed bed scrubbers operating at low face velocities, significant entrainment is not likely. The exit gas will be close to saturation and downstream heaters may be necessary to reduce the relative humidity.

Other Caveats

The water is alkaline for retention of molecular iodine and may present a corrosion problem.

II.3 SUMMARY

Wet bed scrubbers are moderately effective in removing particulate and very effective in removing iodine. The high pressure drop and low-to-moderate face velocity of the SBS make it less attractive than the packed bed scrubbers. Both types of wet bed scrubber have high loading capacities although the packed bed scrubber may have a practical upper limit on the aerosol concentrations it can handle. The packed bed scrubbers require water handling and pumping systems. The SBS does not require external pumping or water handling. These are robust systems that can operate in hot, wet environments.

II.4 REFERENCES

Brauer, H. and Varma, Y. B. G., 1981, Air Pollution Control Equipment, Springer-Verlag, New York.

MacDonald, J. W., 1977, "Packed Wet Scrubbers," in Air Pollution Control and Design Handbook, Cheremisinoff, P. N., and Young, R. A. (eds.), Marcel Dekker, New York, pp. 699-720.

Postma, A. K. and Hilliard, R. K., 1980, Evaluation of Air Cleaning Systems for FFTF Containment Margins, HEDL-TME-79-79, Hanford Engineering Development Laboratory, Richland, WA.

Ruecker, C. M. and Scott, P. A., 1987, Design Procedure for Sizing a Submerged Bed Scrubber for Airborne Particulate Removal, PNL-6036, Pacific Northwest Laboratory, Richland, WA.

Theodore, L. and Buonicore, A. J., 1988, Air Pollution Control Equipment, Volumes I and II, CRC Press, Boca Raton, FL.

TABLE II.1
PRESSURE DROP, BED DEPTH, AND
WATER FLOW FOR PACKED BED SCRUBBERS
[Theodore and Buonicore, 1988]

Configuration	Pressure Drop (inches H ₂ O/ft)	Bed Depth (ft)	Water Flow (gpm/1000 cfm)
Countercurrent flow	0.5 - 1	3 - 10	10 - 20
Cocurrent flow	1 - 4	3 - 10	7 - 15
Cross flow	0.1 - 0.5	1 - 6	1 - 4

Figure II.1 Schematic diagrams of packed bed scrubbers in cross flow, co-current flow, and counter-current flow configurations.

Figure II.2 Schematic diagram of a submerged bed scrubber (SBS).

III. VENTURIS

III.1 DESCRIPTION

Venturi scrubbers are the most widely used wet scrubber and are characterized by the presence of a constricted cross-section, or "throat," through which the gas is forced to flow at high velocity (see Figure III.1). Water is introduced either in the form of a spray ahead of the throat, or as a liquid feed that is atomized by the accelerated gas flow through the throat and particles are swept up by the water mist. The removal mechanisms include impaction and interception. The venturi itself is only a gas conditioner, and the wet, entrained particules are finally removed from the air by flowing through a cyclone. Venturi scrubbers are typically used when high collection efficiencies are required and when most of the particles are less than 2 μm in diameter. In a number of instances, a venturi scrubber is the only practical device for particulate removal. If the particles are sticky, highly corrosive, or flammable, electrostatic precipitators and fabric filters cannot be used [Flagan and Seinfeld, 1988]. Venturi scrubbers are also the only high efficiency particulate collector that can also remove gaseous contaminants simultaneously.

III.1.1 PRINCIPLES OF OPERATION

When liquid is introduced into the venturi throat, it is atomized into small droplets. Proper working of a venturi scrubber strongly depends on the water distribution in the throat [Brauer and Varma, 1981]. Typical gas velocities through the venturi throat range from 12,000 to 24,000 fpm. The high relative velocity between the particle-laden gas flow and the droplets promotes collection. Much of the particle collection occurs by inertial impaction within inches of where the liquid is atomized. Because of their high operational velocities, venturi scrubbers are physically small and can be economically made of corrosion-resistant materials. With no moving parts, venturis are the simplest scrubber configuration. Indeed, the associated separator is usually several times the size of the venturi scrubber.

Because liquid is injected into the process, venturi scrubbers are capable of cleaning high humidity process streams that would be virtually impossible to handle using fabric filters or dry cyclones. In addition, the cooling effect of the water injection makes the method compatible with "high" temperature operations. However, as the total operating gas pressure is increased, the collection efficiency decreases for a given scrubber pressure drop. For instance, the pressure drop across a venturi scrubber operated at 10 atm is 10 times that of the same scrubber operated at 1 atm pressure to achieve the same particle collection efficiency [Yung et al., 1984].

Venturi scrubbers are merely particulate conditioning devices. As a result of impaction and condensation, the wetted particles are of sufficient size that they can be collected effectively in a cyclone separator.

A number of innovative variations on the venturi scrubber have been designed. One of these is the Multi-MicroVenturi Scrubber (MMV) by Beco Engineering Company. The device is basically an array of staggered tubular elements arranged much like a bank of heat exchanger tubes (see Figure III.2). The tubes cause successive micro-venturi flows at the "necks" and also serve as both impingement targets and vortex flow generators. The MMV can also be used as a mist eliminator (re-entrainment velocity = 2450 fpm). Liquid flow rates ranging from 1-7 gal/1000 cfm are circulated through the system. Throat velocities range from 12,000-20,000 fpm, values typical of standard venturi scrubbers. The pressure drop for the unit is less than that of a standard venturi for similar collection efficiencies.

III.1.2 OPERATIONAL PARAMETERS

Flow Rate

The rate of water injection ranges from 6-10 gal/1000 ft³ of gas [Theodore and Buonicore, 1988]. At high liquid/gas ratios, the gas velocity at a given ΔP is reduced, while at low ratios, the gas velocity is increased [Flagan and Seinfeld, 1988]. Typical gas velocities in the throat range from 12,000 to 24,000 fpm. The operating parameters of an MMV system are similar to those of a standard venturi scrubber.

Pressure Drop

Pressure drops for a standard venturi range from 6-70 inches of water and 25-30 inches of water are common. The pressure drop in an MMV is lower for equivalent efficiencies.

Removal Efficiency

A 10 inch water venturi scrubber can remove particles as small as one micron with approximately 100% efficiency while a 60 inch water venturi will remove particles down to 0.1 μm . Collection efficiency is directly related to pressure drop [Theodore and Buonicore, 1988].

Aerosol Loading

Venturi scrubbers are well-suited to handling high loading capacities. Plugging of the water inlets might pose a problem.

Maintenance and Peripheral Equipment

A great number of the operating problems associated with a venturi scrubbing system are due to the auxiliary equipment rather than the scrubber itself. Regular maintenance would include inspection of the equipment for signs of erosion

and/or corrosion, particulate buildup at the wet/dry zone (e.g., Are there surfaces within the scrubber that are not being wetted adequately?), or particle entrainment as a result of improper separator function. If the liquid is filtered and recirculated, the filtration system will have to be inspected regularly for loading. A maintenance program identical to that of a standard venturi scrubber would be required.

Size

The venturi is typically smaller than its associated separator equipment. Multi-microventuri scrubber systems are small. A 60,000 cfm capacity scrubber has a cross-sectional area of 64 ft².

Lifetime

The lifetime of this equipment comparable to that of the facility being served.

Cost

The cost of an MMV is approximately \$500,000. This does not include the cost of the associated water circulation equipment.

Waste and Waste Handling

The water cleaning and handling system will generate waste. If recirculation of the liquid is chosen, the particulate filtered from the liquid must be dealt with. If fresh make-up water is used, the contaminated water has to be disposed of, and a system run continuously, as opposed to on-demand, could generate significant volumes. Waste water, particulate, and the structural components would have to be dealt with upon decommissioning or in the event of use during an accident.

III.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Venturi scrubber systems remove particles larger than 1 μ m with high efficiency. The efficiency is low for submicron particles.

Iodine Removal

The wet scrubbing action of the venturi scrubber system or MMV system could reduce the iodine load on downstream components. Treatment of the water (pH = 9-11) to enhance iodine absorption is possible.

Particle Loading Capacity

The particle loading capacity of venturi scrubbers is high. If the wash water is recirculated, an upper loading limit may be imposed by the water filtration units.

Pressure Drop

Typical pressure drops of 20-30 inches of water are an order of magnitude higher than the current filter compartments. Consequently, the increased load on the air moving equipment will necessitate increased power consumption. Lower pressure drops are generated using an MMV scrubber.

Gas Flow Capacity

Venturi scrubber systems can be designed to handle any flow volume. The MMV is a more compact device for an equivalent flow.

Radiation

These devices are not expected to be adversely affected by radiation

Temperatures

This system will cool a high temperature gas and condense steam.

Water and Moisture

These systems are capable of handling moisture-laden gas streams. Indeed, the outlet gas will be saturated with water vapor. It may be necessary to heat the output in order to reduce the humidity in downstream components. A mist eliminator may have to be used in conjunction with venturi scrubber systems.

Other Caveats

If alkaline water is used for the retention of molecular iodine, corrosion may present a problem. Erosion will also have to be addressed. Because the system is wet, the risk of an explosion from dry dust is minimized. An operating venturi is typically noisy.

III.3 SUMMARY

Venturi scrubbers are "aerosol conditioning" devices that, when used in conjunction with a separator such as a cyclone, are very effective in removing particulate greater than 1 μm in diameter. The water wash will remove some of the absorbed gases. High pressure drops are the major disadvantage associated with this device. Novel variations on the venturi principle, such as the Multi-

MicroVenturi scrubber or the Multi-Venturi Scrubber System (see Section IV), have been designed.

III.4 REFERENCES

The MMV Scrubber, Beco Engineering, Glenshaw PA. (Sales brochure)

Brauer, H. and Varma, Y. B. G., 1981, Air Pollution Control Equipment, Springer-Verlag, New York, pp. 107-148.

Flagan, R. C. and Seinfeld, J. H., 1988, Fundamentals of Air Pollution Engineering, Prentice Hall, Englewood Cliffs NJ, pp. 467-469.

Licht, W., 1988, Air Pollution Control Engineering, 2nd edition, Marcel Dekker, Inc., New York, pp. 432-463.

Theodore, L. and Buonicore, A. J., 1988, Air Pollution Control Equipment, Volume I: Particulates, CRC Press, Inc. Boca Raton, FL, pp. 101-132.

Yung, S. C., Calvert, S., and Duncan, M., 1984, "Performance of Gas-Atomized Spray Scrubbers at High Pressures," J. Air Poll. Control Assoc., Volume 34(7), pp. 736-742.

VENTURI SCRUBBER/MIST ELIMINATOR

Figure III.1 Schematic diagram of a venturi scrubber.

Figure III.2 Multi-MicroVenturi Scrubber [Beco Engineering Co.]

IV. MULTI VENTURI SCRUBBER SYSTEM (MVSS)

Sweden has developed an aerosol and iodine removal system known as the Multi Venturi Scrubber System (MVSS). It consists of several small venturi scrubbers, operating in parallel, submerged in a water pool [Elisson, 1988; Lindau and Elisson, 1988]. This system was developed to clean aerosol and molecular iodine from venting gas during the depressurization of a nuclear power reactor containment building after an accident [Lowenhielm et al., 1988; Elisson and Waltersten, 1988; Espefalt and Persson, 1990].

IV.1 DESCRIPTION

The Multi Venturi Scrubber System (MVSS) consists of 864 small venturis submerged in a water pool 10 to 16 ft deep. The flow through each venturi is about 20 cfm. They are mounted on inclined headers (see Figure IV.1) so that, as the gas flow increases, the water level is pushed further down the header bringing more venturis into play in order that the flow in each venturi is kept to within a narrow range for consistent, flow-invariant operation. Water for the wet scrubbing is supplied from the pool through inlets in the venturi throats. Entrained water from the surface of the pool is removed by gas flow through a gravel bed. The gravel bed mist eliminator for this unit consists of about 300 ft³ of nominally 1 to 1.4 inch crushed rock. Separated water is drained back into the pool.

IV.1.1 PRINCIPLES OF OPERATION

Particles are removed by the same mechanisms as in other venturis. The novel feature of the MVSS is that the venturis are submerged and the water from the surrounding pool is entrained through small holes in the throat so that no external water handling or pumping is required. The gas also exits under water and undergoes further scrubbing by bubbling through the remainder of the overlying water pool.

IV.1.2 OPERATIONAL PARAMETERS

Flow Rate

The flow rate of the unit consisting of 864 venturis is 18,000 cfm with all venturis operating. The unit will function at lower flows employing fewer venturis.

Pressure Drop

The pressure drop depends only on the depth of the water pool and ranges from 120 inches of water for barely submerged venturi exits to 200 inches of water for fully submerged exits. This is a high pressure drop for a system that relies on fan driven air moving equipment.

Removal Efficiency

Particle removal efficiency is high for larger particles and declines with decreasing particle size. Experimentally determined decontamination factors [McCormack et al., 1989; Lindau et al., 1990] are given in Table IV.1.

The removal efficiency of molecular iodine is fairly high with experimentally determined decontamination factors of 100 to 2000. The water must be buffered to a pH on the order of 9 to 11 to retain the removed iodine.

This system was designed for containment venting at a time when natural particle removal mechanisms within the reactor containment have been operating for some time and the airborne contamination in the vent gas has declined considerably. In an application in which the gas is continuously flowing from the accident site, additional cleaning of the exit gas may be required to remove submicron particles and remaining iodine and iodine compounds.

Aerosol Loading

Aerosol loading is potentially high but plugging of the water inlets to the venturi throats could occur at high loadings.

Size

The 864 venturis are contained in a cylindrical vessel about 23 ft in diameter and 39 ft high. The water pool is 10 to 16 ft deep. A unit of this size will handle 18,000 cfm of gas. Extrapolating to a unit size that would handle 32,000 cfm gives a pool surface area of about 740 ft² (about 31 ft in diameter) with 1540 venturis. The container height and pool depth remain the same.

Maintenance and Peripheral Equipment

Periodic inspection of the water quality and the condition of the venturis and the tank, as well as testing for performance, would be required maintenance. The water levels and pH must be monitored and maintained. Periodic cleaning of the water is required and would entail the use of peripheral equipment.

Lifetime

The lifetime of the MVSS is comparable to that of the facility being served.

Waste and Waste Handling

Waste may be generated from cleaning the water, the tank, and the venturis. Waste water and the containing structural components would have to be dealt with upon decommissioning or in the event of use during an accident.

IV.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

The MVSS removes large particles (supermicron) with better than 99.5 percent efficiency. However, the efficiency drops to less than 99 percent for particles under one micron.

Iodine Removal

Removal of molecular iodine is greater than 99 percent.

Particle Loading Capacity

The particle loading capacity has the potential to be high but plugging of the water inlets to the venturi throats may present a problem.

Pressure Drop

The pressure drop is very high at 120 to 200 inches of water. This would require a considerable enhancement of the air mover system.

Gas Flow Capacity

A unit or units could be built for a large flow capacity, but the size would be quite large. For 100,000 cfm, 4800 venturis would be required in a pool with a surface area of about 2300 ft² and a volume of 23,000 to 36,000 ft³.

Radiation

The MVSS should not be adversely affected by the potential radiation environment in the Savannah River Plant application. Evaporation or boiling of the water will accommodate the heat load of trapped radionuclides but makeup water must be added.

Temperatures

The MVSS is capable of high temperature operation. The water will cool the gas so that its exit temperature will be no higher than 100°C.

Water and Moisture

This system is capable of wet operation. The gravel bed mist eliminator of the MVSS will remove any entrained water droplets. The saturated gas may require heating downstream to lower the relative humidity.

Other Caveats

In a system with water at an elevated pH, corrosion may present a problem.

IV.3 SUMMARY

The MVSS exhibits a high collection efficiency for supermicron particles and high iodine removal capabilities. It has a potentially high loading capacity although care must be taken to avoid plugging of the water inlets to the venturi throats. It is capable of high temperature and wet operation. Its operation is essentially passive since there are no pumping requirements for the water. The collection efficiency for submicron particles is low. The pressure drop is very high and would entail a significant cost in air movers. As with any system using water, corrosion could be a problem. Mist elimination is necessary, especially since the water contains trapped particulate and iodine. Additional cleaning of the exit gas may be required to remove uncollected submicron particles and remaining iodine and iodine compounds.

IV.4 REFERENCES

- Elisson, K., 1988, "A Multi Venturi Scrubber System for Containment Venting," Proc. CSNI Specialists Mtg. on Filtered Containment Venting Systems, Paris, 17-18 May, CSNI Report 148, pp. 233-246.
- Elisson, K. and Waltersten, T., 1988, "Sweden Employs a Multi Venturi Scrubber for Containment Venting," Nuclear Engr. Intl., March, pp. 34-35.
- Espefalt, R. and Persson, I., 1990, "Developing Methods for Accident Mitigation in Sweden," Nuclear Engr. Intl. August, pp. 20-24.
- Lindau, L. and Elisson, K., 1988, "Filtered Containment Venting in Sweden," in Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conf., Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 695-707.
- Lindau, L., Larsson, A. C., and Ohlin, L., 1990, FILTRA-MVSS Results of Aerosol and Iodine Collection Tests, ACE-TR-A16, Electric Power Research Institute.
- Lowenhielm, G., Appelgren, E., and Espefalt, R., 1988, "Mitigating Measures at Ringhals Nuclear Power Plant - Accident Management From a Radiological Point of View," IAEA-SM-296/67, Intl. Symp. on Severe Accidents in Nuclear Power Plants, Sorrento, Italy, 21-25 March, International Atomic Energy Agency.

McCormack, J. D., Dickinson, D. R., and Allemann, R. T., 1989, Experimental Results of ACE Vent Filtration, Submerged Venturi Scrubber Tests, ACE-TR-A3, Electric Power Research Institute.

TABLE IV.1
EXPERIMENTALLY DETERMINED
DECONTAMINATION FACTORS FOR THE MVSS*
[McCormack et al., 1989 and Lindau et al., 1990]

Decontamination Factor	Particle Size
2000 to 4000	2 to 3 μm
500 to 1000	1.2 μm
50 to 100	0.54 μm

* This EPRI information should remain within the ACE Consortium membership.

Figure IV.1 Multi Venturi Scrubber System [Filtration MVSS, ABB Atom]

V. GLASS-FIBER HEPA FILTERS

Glass-fiber high-efficiency particulate air (HEPA) filters have been in use for decades and a considerable body of literature on their performance and application exists. They were originally developed for military use and were later applied to nuclear facilities for cleaning exhaust gas of hazardous or radioactive particulate. More recently, they have seen broad applications in clean room technology, manufacturing, and processing operations where airborne particulate can interfere with the activity [Anderson, 1989; Wilhelm, 1990]. They are fragile and easily damaged by improper handling, high dust loading, pressure excursions, and moisture. Work to improve the strength of HEPA filters and their resistance to pressure drop and water damage [Rudinger et al., 1990] has resulted in a High-Strength HEPA filter.

V.1 DESCRIPTION

Conventional glass-fiber HEPA filters fan-fold approximately 200 ft² of filter media into a 2 ft by 2 ft frame about 1 ft deep so that an actual 5 fpm face velocity for the filter media translates into 1000 ft³ per minute (cfm) and with an apparent face velocity of 250 fpm at a pressure drop of 1 inch of water. The filter is made of glass fibers or glass and asbestos fibers with diameters on the order of a micron. The fibers are bound together by a binder into a mat about 0.018 inch thick. This material is treated by silicone impregnation to make it water repellent for nuclear applications.

HEPA filters with higher flow capacities are made by increasing the filter surface area in the filter frame. This is done by increasing the number of folds [Allan, 1988]. These filters have 50 percent more interior filter surface and a commensurately larger flow capacity at the same pressure drop with the same frame size.

The strength issue has been addressed by work at the Kernsforschungszentrum Karlsruhe (KfK) Laboratory for Aerosol Physics and Filter Technology [Rudinger et al., 1990]. They have produced a HEPA filter with the same performance characteristics as the conventional HEPA but with improved structural strength. These High-Strength HEPA filters are currently being manufactured by three European filter manufacturers. The increased strength is achieved as a result of two important modifications to the conventional HEPA filter. The first is incorporation of glass fiber cloth reinforcement into the filter media that results in an order of magnitude increase in the dry tensile strength and two orders of magnitude increase in the wet tensile strength. The second modification is to increase the stability of the filter pack by the use of a special spacer that prevents deformation and shifting of the folded filter media; this more than doubles the wet and dry strength of the High-Strength HEPA filter compared to the conventional HEPA filter.

V.1.1 PRINCIPLES OF OPERATION

HEPA filters remove large particles primarily by interception (sieving for extremely large particles, several tens of microns). The face velocity of 5 fpm is low and impaction is not as important as interception. Small particles are removed by diffusion to the fibers. The fiber diameter plays an important role in the efficiency of the filter. Filter media with extremely high removal efficiencies are produced with submicron fibers [Anderson, 1989]. The particle size of maximum penetration for HEPA filters is between 0.1 and 0.3 μm depending on the fiber diameter; smaller diameter fibers give lower values of maximum penetration.

V.1.2 OPERATIONAL PARAMETERS

Flow Rate

The flow rate through a clean conventional or a clean High-Strength HEPA filter is rated at 1000 cfm at 1 inch of water pressure drop. The flow through a high flow capacity HEPA is rated at 1500 cfm at 1 inch of water pressure drop. Flow rate and pressure drop are related linearly.

Pressure Drop

The pressure drop at the rated flow is 1 inch of water. These filters may fail at excessive pressure drops. Failure of the conventional and high flow capacity HEPA filters occurs between 16 and 44 inches of water for dry operation and between 8 and 12 inches of water for wet operation [Rudinger et al., 1990; Ricketts et al., 1990]. The High-Strength HEPA filter experienced failure at 220 inches of water pressure drop in dry application and 60 inches of water pressure drop in wet application [Rudinger et al., 1990]. Aerosol and water loading of the filters will increase the pressure drop.

Removal Efficiency

The removal efficiency for particulate is extremely high. A HEPA filter is rated at a 99.97 percent removal (0.03 percent penetration) of 0.3 μm dioctyl phthalate (DOP) particles. More recent experimental capabilities have demonstrated the increasing collection efficiency for decreasing particle size by the diffusion mechanism [Anderson, 1989; Molter, 1988; VanOsdell, 1990]. These capabilities allow a clear experimental determination of the size dependence of collection efficiency and of the maximum penetrating particle size.

Aerosol Loading

HEPA filters are not designed for high mass loading of aerosol. Two to three pounds of material is generally as much as a conventional HEPA filter can hold before the pressure drop gets high enough to cause filter failure. The work of

Osaki and Kanagawa [1989] examine the relationship of filter loading, flow rate, and pressure drop in HEPA filters. The following relationship can be determined from their work for a conventional HEPA filter of the standard size addressed here under dry operation with particle loading of dry compact particles (e.g., no fibers, lint, liquid, etc.):

$$\Delta P = \frac{Q}{1000} \left\{ 1 + \frac{W}{0.36 \rho D} \right\}$$

where,

- ΔP = pressure drop (inches of water),
- Q = flow through the filter unit (cfm),
- ρ = density of the particulate (g/cm³),
- D = particle physical diameter (μ m), and
- W = particulate loading on the filter unit (lbs).

Therefore, pressure drop is directly proportional to the flowrate and mass loading, and inversely proportional to the collected particles. The loading is inversely related to the flowrate, and directly related to the particle size. The above equation quantitatively demonstrates the relationships among the various parameters discussed in the preceding section on filtration.

Size

The size of a HEPA filter is a 2 ft by 2 ft face by about 1 ft deep. Each unit weighs 40 to 50 pounds. This is a standard size and the conventional, high flow capacity, and High-Strength units are available in this size. Individual units are arranged in a matrix to handle different flows. Their effective face velocity is 250 fpm for the conventional and High-Strength units and 375 fpm for the high flow capacity units.

Maintenance and Peripheral Equipment

Required maintenance is periodic inspection and testing for performance. No peripheral equipment is required.

Lifetime

The lifetime of the HEPA filter depends on the type of service it sees. A typical HEPA filter in AACS service has a lifetime of 4 to 5 years. The lifetime for a high flow capacity or a High-Strength unit is expected to be the same.

Waste and Waste Handling

The waste and waste handling for the High-Strength or high flow capacity HEPA filters would be no different than for those now in service.

Cost

The cost of a conventional HEPA filter is on the order of 250 dollars per unit. The cost of the high flow capacity HEPA filters is slightly more than for conventional HEPA filters and the cost of the High-Strength HEPA filters is about twice that of the conventional.

V.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

HEPA filters exhibit extremely high particulate removal efficiency over the entire range of particle sizes. The minimum removal efficiency is greater than 99.9 percent.

Iodine Removal

HEPA filters effect no iodine removal.

Particle Loading Capacity

Particle loading capacity is not high. Conventional HEPA filters in the standard configuration considered here can handle 2.0 to 3.3 pounds per unit before increased pressure drop threatens filter integrity. The high flow capacity units should be able to handle a little more. The High-Strength units can handle two to four times the loading but at a cost in pressure drop. These units are designed to handle higher pressure drops without failure.

Pressure Drop

The pressure drop across a clean HEPA filter operating at the rated flow is 1 inch of water. Particle loading and moisture act to increase the pressure drop. The relationship between loading and pressure drop in a dry filter has been given in Section V.1.2. Wet filters would have a higher pressure drop at a given flow. The filter media is often impregnated with silicone to make it water repellent. Water drains off the media keeping the pressure drop lower than if the water collected on the surface. HEPA's function well as clean filters, but there is evidence that even light dust loadings counteract the effect of this water repellent treatment: water is retained and the pressure drop increases [Ricketts et al., 1990].

Gas Flow Capacity

The gas flow capacities are high with an effective face velocity on a standard size filter unit of 250 fpm for the conventional and High-Strength units and 375 fpm for the high flow capacity units.

Radiation

The conventional units used currently in the AACS have acceptable radiation handling capabilities. High flow capacity and High-Strength units could be manufactured to these specifications. High-Strength units are already seeing nuclear service in Germany [Rudinger et al., 1990].

Temperatures

The typical maximum operating temperature for a metal-framed HEPA filter is 240°C [Rudinger et al., 1990].

Water and Moisture

A wet filter experiences an increased pressure drop and the water acts further to weaken the media so that the pressure drop at failure is lower than for a dry filter. The High-Strength HEPA has a wet strength comparable to the dry strength of a conventional HEPA filter. In any case, wet operation should be avoided by the use of upstream mist eliminators and heaters to reduce the relative humidity. Water on the filter may provide the means whereby contaminants penetrate the filter by wicking and entrainment.

Other Caveats

Repeated mechanical or pressure shocks can cause particles to migrate through the filter and be re-entrained from the back side. Failure of the filter will resuspend already trapped particles.

V.3 SUMMARY

These filters have an extremely high particle removal efficiency and a low pressure drop when clean. Fan folding the medium into a frame gives a very high effective face velocity (250 fpm to 375 fpm) compared to the actual face velocity (5 fpm) through the medium. Because of their high efficiency and surface filtration, the pressure drop increases rapidly with loading. The increase in pressure drop not only taxes the air moving system but, because of the fragility of the conventional HEPA filter medium, it leads to filter failure. Water has a pronounced adverse effect on the conventional glass-fiber filter medium, increasing the flow resistance and decreasing the failure pressure drop by a factor of 2 to 4.

The High-Strength filter medium has a wet failure pressure drop on the order of the conventional medium's dry failure pressure drop. It shares the other advantages and disadvantages with the conventional medium.

V.4 REFERENCES

- Allan, T. T. and Singh, T. M., 1988, "Introduction of a New Generation of High-Capacity HEPA Filters and a Comparison of Their Performance to HEPA Filters Available On the Market," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp 898-903.
- Anderson, W. L., 1989, "Making Sense of HEPA Filtration," Filtration and Separation, November/December, pp. 439-442.
- Molter, W., 1988, "Fast, Automated Testing of HEPA and ULPA Filter Media," Filtration and Separation, November/December, pp. 417-418.
- Osaki, M. and Kanagawa, A., 1989, "Performance of High-Efficiency Particulate Air Filters Under Severe Conditions," Nuclear Tech., Volume 85, pp. 274-284.
- Ricketts, C. I., Rudinger, V., and Wilhelm, J. G., 1990, "Aspects of the Increase in Pressure Drop of High-Efficiency Particulate Air Filters Under Fog Conditions," Nuclear Tech., Volume 92, pp. 50-65.
- Rudinger, V., Ricketts, C. I., and Wilhelm, J. G., 1990, "High Strength High-Efficiency Particulate Air Filters for Nuclear Applications," Nuclear Tech., Volume 92, pp. 11-29.
- VanOsdell, D.W., Liu, B. Y. H., Rubow, K. L., and Pui, D. Y. H., 1990, "Experimental Study of Submicrometer and Ultrafine Particle Penetration and Pressure Drop for High Efficiency Filters," Aerosol Sci. and Tech., Volume 12, pp. 911-925.
- Wilhelm, J. G., 1990, "Development of Nuclear Gas Cleaning and Filtering Techniques," Nuclear Tech., Volume 92, pp. 9-10.

VI. METAL-FIBER HEPA FILTERS

The work at KfK [Rudinger et al., 1990] to improve the strength of HEPA filter media resulted in the High-Strength HEPA filter discussed above. Other work to obtain a high strength filter media for use in HEPA filtration has been undertaken. Bergman and Sawyer [1988] report on a composite filter medium of sintered quartz and stainless steel with 4 times the tensile strength and a higher operating temperature than the conventional glass-fiber HEPA filter medium. This new medium has the same filtration and pressure drop behavior as the conventional medium. It does not, however, appear to be in production. Incorporating the idea of including stainless steel fibers in the filter media, Pall Corporation (Cortland, NY) has produced a filter medium composed of sintered stainless steel fibers. The fiber diameters are on the order of $2\text{ }\mu\text{m}$, which is comparable to those in the glass fiber HEPA filter medium. The metal cloth filter media has the same flow, pressure drop, and particle removal performance as conventional HEPA filter medium [Ing et al., 1988; Scowen, 1990] in addition to a much higher strength.

VI.1 DESCRIPTION

The sintered stainless steel filter medium is not available from Pall in the standard 2 ft by 2 ft by 1 ft deep HEPA configuration. Instead, Pall manufactures cylindrical filter modules of pleated media designed to filter gas flowing radially from the outside to the interior of the cylinder. Each module contains 16 ft^2 of filter medium in a 6 inch diameter, 16 inch long cylinder. Figure VI.1 is a schematic diagram of one such unit. Each unit has a flow capacity of 80 cfm at a pressure drop of 1 inch of water giving an actual face velocity of 5 fpm, the same as for the glass fiber medium. The weight of each unit is 8 pounds. For higher flows, units are fitted together in series as shown in Figure VI.2, and, for still higher flows, several of these series assemblies are fitted together in parallel as shown in Figure VI.3. This assembly is housed in a container as shown in Figure VI.3. The filter assembly is able to withstand pressure drops of over three atmospheres and temperatures of 200°C .

VI.1.1 PRINCIPLES OF OPERATION

The principle of operation is the same as for the HEPA filters with the glass fiber medium.

VI.1.2 OPERATIONAL PARAMETERS

Flow Rate

The rated flow is 80 cfm per module at a 1 inch water pressure drop.

Pressure Drop

The pressure drop behavior is the same as for glass fiber HEPA filters; 1 inch of water at the rated flow. The metal fiber HEPA filter medium should exhibit the same dry pressure drop behavior as the glass fiber filter medium. It is expected that the metal fiber HEPA filter medium will exhibit the same wet pressure drop behavior upon loading as the glass fiber media [Ricketts al., 1990].

Removal Efficiency

The removal efficiency is the same as the glass fiber HEPA filters.

Aerosol Loading

Aerosol loading behavior is expected to demonstrate the same wet and dry pressure drop/flow/loading behavior as the glass fiber HEPA filters [Osaki and Kanagawa, 1989]. However, aerosol loading will not cause filter failure although it could cause the flow to become completely blocked.

It may be possible to clean the filters of surface loading with a pulsed jet of air in the reverse direction while the filters are in operation. This capability, should the manufacturer develop it, would give the metal fiber HEPA filters a very high effective particle loading capacity.

Size

An assembly of 400 modules with the same total flow rating and pressure drop (32,000 cfm at 1 inch of water) as the HEPA filters in a filter compartment of the SACS could be placed in a cylindrical housing 4 ft in diameter and 12 ft long. The filters would weigh about 3200 pounds.

Maintenance and Peripheral Equipment

Maintenance consists of periodic inspection and performance testing. These filter modules are cleanable and reusable. Periodic cleaning would be required and the necessary cleaning equipment would be peripheral equipment.

Lifetime

The lifetime of these modules is expected to be comparable to the lifetime of the facility being served.

Waste and Waste Handling

Cleaning the modules would generate some liquid waste. The pulsed air in-situ cleaning would generate a solid waste in the filter housing. The modules would constitute solid waste upon decommissioning or after an accident if they could not be adequately decontaminated.

Cost

The cost of a single module is about 4500 dollars and 400 module assembly (rated at 32,000 cfm at 1 inch of water) would cost 1.8 million dollars. This is exclusive of any pulsed jet cleaning capability.

VI.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Particle removal efficiency is extremely high. It is the same as the glass fiber HEPA filters.

Iodine Removal

These filters effect no iodine removal.

Particle Loading Capacity

The particle loading versus pressure drop relationship is the same as for glass fiber HEPA filters. The metal fiber HEPA filters will not fail as a result of loading, but they may plug. The particle loading capacity is determined by the pressure drop that the air mover system can accommodate.

If an in-situ cleaning scheme is realized, the loading capacity is limited only by the volume in the filter housing available to hold the blown-off particulate.

Pressure Drop

The pressure drop behavior is the same as for glass fiber HEPA filters. It is initially very low but rises with loading.

Gas Flow Capacity

The gas flow capacity is comparable to glass fiber HEPA filters. For the volume occupied by the filters, the gas flows are quite high.

Radiation

These filters would have no problem with the radiation levels they may experience in service at Savannah River Plant.

Temperatures

These filters can operate at 500°C.

Water and Moisture

Water does not have a short or long term detrimental effect on the filter medium. It will increase the resistance to flow and may provide a means whereby contaminants penetrate the filter by wicking and entrainment.

Other Caveats

Repeated mechanical or pressure shock to the filter could cause particles to migrate through the filter and be re-entrained from the back side.

VI.3 SUMMARY

These filters have an extremely high particle removal efficiency and a low pressure drop when clean. Pleating the medium into a cylindrical element gives a high effective face velocity (40 fpm through the surface of the module) compared to the actual face velocity (5 fpm) through the medium. The shape of the modules allows them to be fit into compact assemblies that effectively increase the face velocity. Because of their high efficiency and surface filtration, the pressure drop increases rapidly with loading. The increase in pressure drop may tax an air moving system but will not fail the filter medium. The metal fiber HEPA filter medium will show an increased flow resistance when wet. It shares the other advantages and disadvantages cited for the glass fiber medium.

VI.4 REFERENCES

- Bergman, W. and Sawyer, S. R., 1988, "Development of a High-Efficiency, High-performance Air Filter Medium," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 1130-1136.
- Ing, H. R., Gotlinsky, B., and Tousi, S., 1988, "The development of All-Metal Filters for Use in the Nuclear Industry," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 726-748.

Osaki, M. and Kanagawa, A., 1989, "Performance of High-Efficiency Particulate Air Filters Under Severe Conditions," Nuclear Tech., Volume 85, pp. 274-284.

Ricketts, C. I., Rudinger, V., and Wilhelm, J. G., 1990, "Aspects of the Increase in Pressure Drop of High-Efficiency Particulate Air Filters Under Fog Conditions," Nuclear Tech., Volume 92, pp. 50-65.

Rudinger, V., Ricketts, C. I., and Wilhelm, J. G., 1990, "High Strength High-Efficiency Particulate Air Filters for Nuclear Applications," Nuclear Tech., Volume 92, pp. 11-29.

Scowen, P.A., 1990, "Sintered Metal HEPA Systems Make Progress," Nuclear Engr. Intl., February, p. 52.

Figure VI.1 Metal fiber HEPA filter unit [from Pall Corp.].

Figure VI.2 Metal fiber HEPA filter units combined in series [from Pall Corp].

Figure VI.3 Metal fiber HEPA filter units combined in parallel [from Pall Corp.].

VII. METAL-FIBER DEEP BED FILTERS

Work at KfK [Dillmann, et al., 1990; Wilhelm and Dillmann, 1988] on the use of graded sizes of stainless steel fiber to assemble a deep bed prefilter-filter combination for application in nuclear power plant containment venting will be discussed here. This technique is being tested for use in containment venting of German reactors [Eckardt, 1988; Sawitzki, 1988].

VII.1 DESCRIPTION

The configuration discussed here is described by Dillmann et al. [1990] and Wilhelm and Dillmann [1988] (Figure VII.1). The filter consists of a prefilter section that removes large particles and water droplets, an impingement-type droplet separator to prevent entrained droplets from the prefilter being carried further, and a fine filter to remove the particulate. Filter sections are composed of stainless steel fiber fleece with the prefilter section containing a gradation of fleece with fiber diameters of 30, 22, 12, and 8 μm . The fine filter is composed of 2 μm diameter fiber fleece. A module with a flow area of 21.5 ft^2 is rated for 1180 cfm at a pressure drop of about 20 inches of water. The face velocity is 55 fpm.

VII.1.1 PRINCIPLES OF OPERATION

This deep bed metal fiber filter removes large particles primarily by interception and impaction (sieving for extremely large particles, e.g., several tens of microns). The face velocity of 55 fpm is high enough for impaction to play a role in particle removal and droplet removal. Small particles are removed by diffusion to the fibers. The fiber diameter plays an important role in the efficiency of the filter. The 2 μm diameter stainless steel fibers are on the order of the size of the fiber in HEPA filter media, and the particle removal efficiency of the deep bed metal fiber filter is comparable to that obtained with HEPA filters.

VII.1.2 OPERATIONAL PARAMETERS

Flow Rate

The flow rate through the module described above is 1180 cfm at a face velocity of 55 fpm.

Pressure Drop

The pressure drop across the module described above is 20 inches of water (clean filter) at the face velocity of 55 fpm. Pressure drop and flow are linearly related.

Removal Efficiency

Tests have verified that the particle removal efficiency is comparable to the high efficiency obtained with a HEPA filter [Dillmann et al., 1990].

Aerosol Loading

The prefilter is designed to remove water droplets and particles larger than a few microns with a range of 1 to 10 microns. It achieves better than 99 percent removal by the prefilter [Dillmann et al., 1990]. A loading of about 2 pounds per square foot of filter area would increase the pressure drop from less than an inch of water to about 4 inches of water. This applies to the prefilter only. Similar loading on the fine filter (with a clean pressure drop of 20 inches of water) gives a larger increase in pressure drop. These tests apply only to the test powder under dry conditions. It must be noted that the pressure drop as a function of loading depends on the particle size and whether water is present.

Size

A module handling 1180 cfm at 20 inches of water pressure drop has a face area of 21.5 ft². The weight of the filter media alone is 51 pounds.

Maintenance and Peripheral Equipment

Maintenance consists of periodic inspection and testing for performance. Periodic cleaning of the modules is required.

Lifetime

The lifetime of the filters is expected to be on the order of the facility being served. If the filter medium compacts in time with continuous operation, it may have to be replaced.

Waste and Waste Handling

Cleaning of the filters may generate liquid waste. Possible replacement may generate solid waste. Disposal after an accident would generate solid waste.

VII.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Particle collection efficiency is high, comparable to the level achieved with a HEPA filter.

Iodine Removal

The deep bed metal fiber filter does not effect iodine removal.

Particle Loading Capacity

The loading capacity is higher than a conventional glass fiber HEPA filter on a loading per unit flow area basis but at a high cost in pressure drop.

Pressure Drop

The clean filter pressure drop is moderate (20 inches of water) but considerably higher than that of the HEPA filters in current use.

Gas Flow Capacity

The face velocity of 55 fpm is about a factor of five lower than the 250 fpm effective face velocity of the current HEPA filters; this results in a factor of five greater required flow area at a much higher pressure drop.

Radiation

The stainless steel materials will be able to withstand the specified amount of radiation.

Temperatures

These filters can operate at over 200°C.

Water and Moisture

Water and moisture may have an adverse effect on flow resistance in the prefilter depending on the aerosol loading and the type of particulate. Water can be expected to penetrate to the fine filter. Water and moisture will have no long or short term effects on the filter media.

Other Caveats

Repeated mechanical or pressure shock can cause particles to migrate through the filter and be re-entrained from the back side. High flows, pressure loadings, or shocks may compact the filter media leading to a decrease in filtration efficiency [Kovach, 1988] and possible re-entrainment of collected material [Dillmann et al., 1990].

VII.3 SUMMARY

The deep bed metal fiber filter has a high particle removal efficiency and possibly a higher loading capacity than the HEPA filters in current use. The clean pressure drop is higher than the current filters and the potentially higher loading capacity will result in additional pressure drop. These filters are suitable for high temperature, wet operation. They are robust and can withstand pressure loads. The face velocity is moderate and would require a factor of 5 increase in the current flow

VII.4 REFERENCES

- Dillmann, H. G., Pasler, H., and Wilhelm, J. G., 1990, "Filtered Venting for German Power Reactors," Nuclear Technology, Volume 92, pp. 40-49.
- Eckardt, B., 1988, "Process Technology and Verification Program for PWR and BWR Containment Venting," Proc. CSNI Specialists Meeting on Filtered Containment Venting Systems, Paris, 17-18 May, CSNI Report 148, pp. 105-118.
- Kovach, J. L., 1988, "Review of Containment Vent Filter Technology," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 21-97.
- Sawitzki, M., 1988, "Containment Venting Systems Description Implementation Program," Proc. CSNI Specialists Meeting on Filtered Containment Venting Systems, Paris, 17-18 May, CSNI Report 148, pp. 119-142.
- Wilhelm, J. G., 1988, "Design, Construction and Testing of Filter Systems for Containment Venting," Proc. CSNI Specialists Meeting on Filtered Containment Venting Systems, Paris, 17-18 May, CSNI Report 148, pp. 81-103.

Figure VII.1 Schematic of metal fiber deep bed filter with moisture separator.

VIII. GLASS-FIBER DEEP BED FILTERS

Deep bed glass fiber filters have been used in the nuclear industry for reprocessing off-gas cleaning since 1950 [Kovach, 1988]. They are usually one-of-a-kind units designed and built for specific applications. Units are in existence at Hanford and the Idaho National Engineering Laboratory (INEL) [Sehmel, 1990]. The deep bed glass fiber filters are generally a large flow, high loading capacity, long lived filter. They are physically large with a nominal face velocity of 50 fpm.

VIII.1. DESCRIPTION

Deep bed glass-fiber filters are composed of beds of compacted fiberglass wool in steel trays held in place by screens (see Figure VIII.1). The fiber diameter of the wool varies from a micron to a couple hundred microns, so that a graded filter beginning with large particle diameter fibers and ending with small diameter fibers can be constructed. The overall depth of the bed can be up to 9 ft. This construction incorporates a roughing filter into the bed by providing a depth-dependent collection efficiency so that particles of various sizes will be removed throughout the bed, and a more uniform depth loading allows a higher loading capacity with minimal pressure drop. The flow is usually directed downward through the filter at a face velocity of 25 to 50 fpm.

VIII.1.1 PRINCIPLES OF OPERATION

The deep bed glass fiber filter removes large particles primarily by interception and impaction (sieving for extremely large particles, e.g., several tens of microns). The face velocity of 25 to 50 fpm is high enough for impaction to play a role in particle removal and droplet removal. Small particles are removed by diffusion to the fibers. The fiber diameter plays an important role in the efficiency of the filter. The gradation of fiber diameter from large to small causes larger particles to be removed earlier in the filter allowing the initial stages of the filter to act as a roughing filter to protect the later stages that remove fine particles from overloading. The small fiber diameters in the later stages are on the order of a micron in diameter. They are similar to the fibers in HEPA filter media and the particle removal efficiency of the deep bed glass fiber filter is comparable to that obtained with HEPA filters.

VIII.1.2 OPERATIONAL PARAMETERS

Flow Rate

The flow through a deep bed glass fiber filter has a face velocity on the order of 25 to 50 fpm. This is comparable to the flow through the deep bed metal fiber filter.

Pressure Drop

The pressure drop depends on the fiber diameters, the bed depth, the flow rate and the particle loading. Clean filter pressure drops range from 1.5 to 5 inches of water. Generally, higher removal efficiencies will have higher pressure drops.

Removal Efficiency

The removal efficiency depends on the fiber diameters, bed depth, and flow through the filter. Typical removal efficiencies are on the order of 90 to 99.9 percent for the maximum penetrating particle size.

Aerosol Loading

Sehmel [1990] refers to a deep bed glass fiber filter at INEL that sustained a loading of 3.5 pounds per square foot of filter flow area. The filter was a 150,000 cfm unit operated at 50 fpm (3000 ft² filter flow area) and had a total estimated dust loading of 10,500 pounds. The pressure drop went from 1.5 inches of water for clean operation to 8 inches of water for loaded operation. This filter was designed for 92 percent removal of 0.7 μm particles.

Size

At an operating face velocity of 50 fpm, 640 ft² of filter flow area would be required for a unit rated at 32,000 cfm like one of the filter compartments of the AACs. At a 9 ft bed depth, a filter media volume of 5760 ft³ is required, compared to a volume of 128 ft³ for the 32 HEPA filters used in the current filter compartment.

Maintenance and Peripheral Equipment

The maintenance required would be periodic inspection and performance testing. Periodic cleaning or replacement of the filter media would be required for units in continuous operation. Cleaning equipment would be necessary.

Lifetime

The lifetime of the filter would depend on whether or not it could be cleaned and on whether or not the fiberglass compacted under use. Sehmel [1990] states only a type of Owens Corning fiberglass with a permanent curl would not compress and mat under operation; unfortunately this type of fiberglass is no longer available.

Waste and Waste Handling

Liquid waste might be generated as a result of cleaning operations. Solid waste would be generated whenever the filters were replaced or if an accident occurred.

VIII.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

The deep bed glass fiber filter has a reasonably high particle removal efficiency. Properly designed and tested, efficiencies could be as high as for a HEPA filter. There are potential applications for use as a roughing filter or a prefilter, employing the graded fiber in the larger fiber diameters.

Iodine Removal

The deep bed glass fiber filter does not effect iodine removal.

Particle Loading Capacity

The particle loading capacity of the deep bed glass fiber filter appears to be on the order of 4 times that of the HEPA filters in current use.

Pressure Drop

The pressure drop ranges from 1.5 to 5 inches of water for clean operation depending on the face velocity and particle removal efficiency.

Gas Flow Capacity

The gas flow capacity is high: 100,000+ cfm units have been built. They are also large because of the 50 fpm face velocity.

Radiation

These units should be able to accommodate the same level of radiation as the HEPA filters in current use.

Temperatures

The temperature of operation has been close to ambient in reported experience. Behavior with temperature should be comparable to glass fiber HEPA filters.

Water and Moisture

Water and moisture may increase the flow resistance of the filter especially if collected in the region of small fiber diameters. Water should not damage the filter media itself, but, in units with downward-directed flow, could cause collected material to migrate to the stages with small diameter fibers and cause plugging. Upward-directed flow could eliminate this problem by allowing the water to drain

back counter to the flow. The 50 fpm face velocity may be of concern because it is roughly equal to the terminal settling velocity of a 10 μ m particle.

Other Caveats

High flow, loading, and water may produce flow resistance sufficient to compress the media, reducing the collection efficiency and possibly re-entraining collected material. Repeated mechanical or pressure shock could cause particles to migrate through the filter and be re-entrained from the backside. Liquid water could penetrate the filter carrying contaminant with it.

VIII.3 SUMMARY

The deep bed glass fiber filter can achieve particle removal efficiencies approaching those of a HEPA filter. It has a higher loading capacity than a HEPA filter and has potential as a roughing filter. The pressure drop is not much higher than the HEPA filters. This is not an off-the-shelf item, however, and would require a search for an appropriate fiber. The 50 fpm face velocity and 9 ft bed depth makes it considerably larger than the HEPA filters in current use. The filter may not handle water or pressure pulses well.

VIII.4 REFERENCES

Kovach, J. L., 1988, "Review of Containment Vent Filter Technology," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 21-97.

Sehmel, G. A., 1990, A Review of the Potential Alternatives for Air Cleaning at the Hanford Waste Vitrification Plant, PNL-7391, UC-721, Pacific Northwest Laboratory, Richland, WA.

Figure VIII.1 Schematic diagram of a deep bed glass fiber filter.

IX. BAGHOUSES

Filtration is one of the oldest and simplest methods for removing particulates. It is also one of the few technologies capable of meeting present particulate emission standards. Industrial-scale filtration is usually accomplished in a "baghouse," in which particle-laden gases are forced through fabric filter bags. High collection efficiencies for particles as small as $0.5\ \mu\text{m}$ are possible. Baghouse filtration is used extensively in coal-fired power plants and in the aggregates processing industries. A large volume of evidence indicates that collection efficiency and reliability are excellent [Carr and Smith, 1984].

IX.1 DESCRIPTION

Cloth fabric, or felt, is made into cylindrical tubes, on the order of 6-12 inches in diameter and 10-30 ft long. A number of these tube filters are suspended vertically and operated in parallel in a "baghouse" (see Figure IX.1). If a large number of tubes are required, they may be grouped into "compartments" of up to several hundred bags each. The essential differences between baghouses relate to: 1) the type of fabric; 2) the cleaning mechanism; 3) the equipment geometry; and 4) the mode of operation. Baghouses are typically identified by the method used to clean the filters: shaking (vibration), pulsed air jets, reverse flow, or a traveling ring.

IX.1.1 PRINCIPLES OF OPERATION

Two basic types of filtration occur in commercial fiber filters. The first is known as depth, or fiber, filtration and the second is surface, or "cake," filtration [Theodore and Buonicore, 1988]. In fiber filtration, the particulate is collected by the fibers themselves by settling, impaction, interception, and diffusion mechanisms. In cake filtration, the fiber acts merely as a support on which a layer of particulate forms a porous filter through which the gas must flow. Particles are removed by sieving as well as the previously mentioned mechanisms. Industrial baghouse filters use both methods, although cake filtration predominates after a new filter becomes impregnated with dust. Baghouse filters have not been described adequately theoretically because of the difficulty in modelling the behavior of the cake layer.

Fabric filters consist of woven or felted materials. Felted fabrics rely less on the formation of a cake and are more efficient dust collectors than woven fabrics. A brand-new woven filter cloth has fibers roughly $100\text{-}150\ \mu\text{m}$ in diameter with open spaces on the order of $50\text{-}75\ \mu\text{m}$. The initial collection efficiency of woven cloth is low and visible penetration results. As particulates are deposited, the efficiency increases to levels comparable with felted fabrics. Formation of the cake takes a few hours to several days, although times as long as a year to achieve stable pressure drops and efficiencies have been observed [Carr and Smith, 1984].

As the cake forms on the surface of a woven fabric filter, the filtration efficiency increases --- but so does the pressure drop across the filter. Therefore,

maintenance of a baghouse is a delicate balance between cleaning, to maintain a reasonable pressure drop, and formation of the filter cake. Particle removal is accomplished either by flexing the bag in some fashion, or by introducing a reverse flow of clean air. Table IX.1 compares the various bag cleaning methods. Mechanically shaking the bag usually works well with light, flocculent dusts [Theodore and Buonicore, 1988]. Sonic cleaning is recommended for use with heavy, dense dusts. In the pulse-jet method, a burst of compressed air is passed through the bag causing it to inflate and flex. Pulse-jet cleaning is done without interrupting the flow. Care must be taken not to overclean woven fabrics. If the filter cake is completely dislodged, efficiency will drop precipitously. Overcleaning of felted fabrics is generally impossible because significant amounts of dust will always be retained within the filter depth. Felted fabrics typically require more cleaning than do woven fabrics and are limited to pulsed-jet methods [Turner et al., 1987].

The choice of fabric is dependent on: 1) the temperature of the gas; 2) the physical and chemical characteristics of the dust; 3) the ability of the fabric to withstand the corrosive and erosive effects of the gas; 4) the mechanical strength of the fabric; 5) the moisture content of the gas; 6) the cost; etc. [Licht, 1988]. The temperature and humidity of the gas are extremely important. Baghouse filters do not work well in wet environments, and it may be necessary to filter at elevated temperatures to minimize condensation and formation of a "muddy" cake. Gas temperatures at least 10°C above the dewpoint are desirable [Licht, 1988]. Alternatively, if the gases are too hot for the fabric filters, a preheater is needed. Woven fabrics are available in a greater range of temperature and corrosion-resistant materials (see Table IX.1) than are felted fabrics and, therefore, cover a wider range of applications.

The design of fabric filter baghouses is very much an art, based heavily upon prior experience. The theoretical models describing the behavior of fabric filters are not sufficiently well-developed for use in designing baghouses. Therefore, correlations and rules-of-thumb must guide the design process. Once a fabric is chosen and the air-to-cloth ratio set (experience has generated tables of values that work well with various types of dust, see Turner et al., [1987]) the cleaning method must be chosen. Whether or not the method is continuous or intermittent will determine if additional filter area must be included. The cost of the bags is proportional to the gross total cloth area required. Sizing the bags is also a function of the cleaning mechanism chosen; shake/deflate technologies use medium length bags, reverse-flow uses long bags, and pulse-jet methods use short bags.

IX.1.2 OPERATIONAL PARAMETERS

Flow Rate

The air-to-cloth ratio (ACR) typically ranges from 1-5 actual cfm/ft² for woven fabric and 5-10 acfm/ft² for felted fabrics. The higher ratio for felted fabrics is offset by

their higher cost [Turner et al., 1987]. These values are also associated with particular cleaning methods; 4-6 fpm for pulsed-jet collectors and 1.5-3 fpm for reverse-gas and shake/deflate methods [Dean and Cushing, 1988]. Experience has shown that more cloth is needed at higher temperatures [Turner et al., 1987] and that ACR values less than 3 acfm/ft² work best for fine dusts or high loadings [Theodore and Buonicore, 1988].

Pressure Drop

The pressure drop associated with a baghouse ranges from 2 to 6 inches of water for woven filters and 6-10 inches of water for felts [Theodore and Buonicore, 1988]. Baghouses can typically withstand pressure variations of ± 25 inches of water [Turner et al., 1987]. There is no proven method for predicting the pressure drop [Carr and Smith, 1984] and indeed, the nature of the particulate can have a dramatic effect on its value [Felix et al., 1986].

Removal Efficiency

The removal efficiency for baghouses is very high, in excess of 99%, for particles larger than 0.1 μm . Changes in the dust loading have little effect on the efficiency. Prediction of the removal efficiency is extremely difficult since it depends on the point in time during the cleaning cycle and the interaction of the dust with the filter and filter cake. Design efficiencies ranging from 99.00 to 99.94% are typical in the utility industry [Plulle et al., 1986].

Aerosol Loading

Baghouses are capable of handling very high dust loadings. As a rule of thumb, dust loadings above 10 grains/ft³ (23 g/m³) have typically been treated with a precleaner such as a cyclone [Theodore and Buonicore, 1988]. Bench scale results, however, have shown that the use of a high efficiency precyclone resulted in a higher overall pressure drop [First, 1985]. A thin, low porosity dust cake formed. The fall of a heavy cake of ash actually helps clean the filter by producing a scouring action [Shilling et al., 1986].

Size

Baghouses are typically large facilities. The size of the baghouse is a function of the ACR. A representative value is 5 ft² cloth/ ft² of floor area.

Maintenance and Peripheral Equipment

Maintenance of baghouses includes cleaning of the filters. This may occur continuously (pulse-jet collectors) or periodically (shakers and reverse gas flow). Felted fabric must be cleaned more often than woven fabrics. Startup and shutdown are critical to the life of the fabric. Clean filters do not have a protective

cake and are sensitive to dust abrasion and the penetration of fine particles that can lead to permanent residual pressure drop. Filtering velocities should be kept low until sufficient dust cake has developed. This is indicated by a change of 1-2 inches of water in the pressure drop [Theodore and Buonicore, 1988]. Suction baghouses, or those with the fan located downstream of the filters, are more costly to construct and reinforce than baghouses with the fan located upstream. When dangerous gases are present, the suction baghouse has the advantage that outside air leaks in; the lifetime of the fan is also longer since it isn't exposed to the particle-laden gas [Turner et al., 1987].

Lifetime

Bag lifetimes range from over 4 years for reverse-gas flow baghouses to 2 1/2 years for shake-and-deflate baghouses. Clearly, cleaning the filters stresses them [Carr and Smith, 1984]. Typical causes of failure include abrasion, chemical attack, poor manufacture, poor gas distribution, and improper bag tensioning. Failure usually occurs in the lower half of the bag. High pressure drops (> 9 inches of water) contribute to increased failure rates. Failure rates in the utility industry have declined from a high of 7% in 1979 to < 2% in 1984 [Plulle et al., 1986]. Bag changeout times range from 15 to 30 minutes.

Waste and Waste Handling

The collected particulate is deposited on the filter bags and must be disposed of. Similarly, the worn-out bags must be dealt with on a regular basis. Upon decommissioning or in the event of use due to an accident, the bags, collected particulate, and the housing facility will have to be decontaminated.

Cost

The cost of a baghouse capable of filtering 40,000 scfm is on the order of \$1,000,000. Actual cost is extremely dependent on the filtering media chosen.

IX.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Baghouse filters operate at efficiencies comparable to those of HEPA filters once the cake is established. Felted materials may never achieve as high efficiencies, but there is no transient time required for cake buildup.

Iodine Removal

These filters do not effect molecular iodine removal.

Particulate Loading Capacity

These filters are capable of handling high dust loadings, and indeed, operate best at high loadings. The efficiency and pressure drop are unaffected by large changes in dust loadings for continuously cleaned filters.

Pressure Drop

Clean baghouse pressure drops are comparable to those of clean HEPA filters. Because the decrease in performance (the pressure drop increase) with time is measurable, effective cleaning cycles can be established. Felted filters require cleaning more frequently than do woven filters.

Gas Flow Capacity

Baghouses are capable of handling large flows. A flow rate of 32,000 cfm is a small unit. Face velocities are low to moderate.

Radiation

Depending on the material used, the bag fabric may be susceptible to radiation damage (some polymers degrade under low level radiation exposures). The filter housing should not be affected.

Temperatures

Operational temperatures must be compatible with the filter material. Excessively high temperature gas may have to be precooled before it is filtered.

Water and Moisture

Baghouses do not handle moisture-laden gases well. Moisture collecting on the filter, or densification of hygroscopic materials in the cake, will result in an increased pressure drop across the filter. In order to avoid condensation, filtering temperatures should be maintained approximately 10°C greater than the gas dewpoint; this may require insulating the baghouse.

Other Caveats

It is possible that dry dust concentrations may pose a fire or explosion hazard. The fabric filters must be watched for chemical attack by either the collected particulate or gaseous contaminants. Baghouse design is an "art." The nature of the particulate, both physical and chemical, affects the pressure drop. There is no proven method for predicting pressure drops in lieu of a pilot plant study.

IX.3 SUMMARY

Baghouses filters have extremely high particulate removal efficiencies and low pressure drops when clean. In-situ, filter cleaning techniques are designed into the filter housing. The high efficiencies associated with woven fabric filters are a result of the sieving effect of the filter cake. Generation of this cake occurs over a period of time. In an operation in which particulate is not expected to be routinely produced, lower collection efficiencies would be likely. In this case, felted fabrics would be more desirable. The primary problems associated with baghouse operation include caking, pluggage, leakage, and short bag life.

IX.4 REFERENCES

- Carr, R. C. and Smith, W. B., 1984, "Fabric Filter Technology for Utility Coal-Fired Power Plants," J. Air Poll. Control Assoc., Volume 31(3), pp. 281-293.
- Felix, L. G., Merritt, R. L. and Duncan, K., 1986, "Improving Baghouse Performance at the Monticello Generating Station," J. Air Poll. Control Assoc., Volume 36(9), pp. 1075-1086.
- First, M. W., 1985, "Gas Cleaning Systems for the High Temperature, High Pressure Fluidized Bed Coal Combustor," J. Air Poll. Control Assoc.,
- Flagan, R. C. and Seinfeld, J. H., 1988, Fundamentals of Air Pollution Engineering, Prentice Hall, Englewood Cliffs NJ, pp. 452-455.
- Licht, W., 1988, Air Pollution Control Engineering, 2nd edition, Marcel Dekker, Inc., New York, pp. 392-414.
- Plulle, W., Carr, R., and Lagomarsino, J., 1986, "Fabric Filters in the Utility Industry," J. Air Poll. Control Assoc., Volume 36(1), pp. 100-104.
- Shilling, N. Z., Murphy, K. R. and Gunzelman, C. P., 1986, "Performance of Fabric Filters on Cyclone Fired Boilers," J. Air Poll. Control Assoc., Volume 36(3), pp. 316-325.
- Stern, A. C., 1977, Air Pollution, 3rd edition, Volume IV, Academic Press, New York, pp. 149-162.
- Theodore, L. and Buonicore, A. J., 1988, Air Pollution Control Equipment, Volume I: Particulates, CRC Press, Inc. Boca Raton, FL, pp. 133-163.
- Turner, J. H., Viner, A. S., McKenna, J. D., Jenkins, R. E. and Vataavuk, W. M., 1987, "Sizing and Costing of Fabric Filters I. Sizing Considerations," J. Air Poll. Control Assoc., Volume 37(6), pp. 749-759.

TABLE IX.1 COMPARISON OF BAG CLEANING METHODS [Theodore and Buoncore, 1988]

Cleaning method	Uniformity of cleaning	Bag attrition	Equipment ruggedness	Type of fabric	Power Cost	Dust Loading	Submicron Efficiency
Shake	A	A	A	woven	L	A	G
Reverse flow, no flexing	G	L	G	woven	M-L	A	G
Reverse flow, w/collapse	A	H	G	woven	M-L	A	G
Pulse - compartment	G	L	G	felt, woven	M	H	H
Pulse - bags	A	A	G	felt, woven	H	VH	H
Reverse - jet	VG	A-H	L	felt, woven	H	H	VH
Vibration, rapping	G	A	L	woven	M-L	A	G
Sonic assist	A	L	L	woven	M	-	G
Manual flexing	G	H	-	felt, woven	-	L	G

Note: A = average; G = good; H = high; L = low; M = medium; VG = very good; VH = very high

TABLE IX.2 PROPERTIES OF FIBER MATERIALS [Stern, 1977]

Fiber	Physical characteristics					Relative resistance to:		
	Relative strength	Specific gravity	Normal moisture content (%)	Maximum usable temperature (°C)		Acid	Base	Organic solvent
Cotton	Strong	1.6	7	82		Poor	Medium	Good
Wool	Medium	1.3	15	99		Medium	Poor	Good
Paper	Weak	1.5	10	82		Poor	Medium	Good
Polyamide (nylon)	Strong	1.1	5	104		Medium	Good	Good ^a
Polyester (Dacron)	Strong	1.4	0.4	138		Good	Medium	Good ^b
Acrylonitrile (Orlon)	Medium	1.2	1	121		Good	Medium	Good ^c
Vinylidene chloride	Medium	1.7	10	99		Good	Medium	Good
Polyethylene	Strong	1.0	0	121		Medium	Medium	Medium
Tetrafluoroethylene	Medium	2.3	0	260		Good	Good	Good
Polyvinyl acetate	Strong	1.3	5	121		Medium	Good	Poor
Glass	Strong	2.5	0	288		Medium	Medium	Good
Graphitized fiber	Weak	2.0	10	260		Medium	Good	Good
Asbestos	Weak	3.0	1	260		Medium ^d	Medium	Good
"Nomex" nylon	Strong	1.4	5	232		Good	Medium	Good

^aExcept phenol and formic acid. ^cExcept heated acetone.

^bExcept phenol. ^dExcept SO₂.

Figure IX.1 Schematic of a typical baghouse.

X. GRANULAR MEDIA DEEP BED FILTERS

Granular media deep bed filters, also called sand bed or gravel bed filters have been used extensively and there is a large body of literature on their design and performance. Considerable work on modelling and experimental determination of their behavior has been performed [Otani et al., 1989; Tien, 1989]. Granular media deep bed filters are being studied or are in use as elements in nuclear power reactor containment venting schemes by Sweden [Hogberg, 1988; Lindau and Elisson, 1988; Holm, 1988; Johansson, 1988], France [Eric, 1988], and the United States [Dickinson et al., 1990]. They have been used for cleaning off-gas flows in reprocessing activities at Hanford and the Savannah River Plant [Sehmel, 1990; Kovach, 1988].

X.1 DESCRIPTION

A granular media deep bed filter is composed of small granules, often sand or gravel and graded in size (similar to the glass fiber deep bed filters), through which the gas flows in either an upward or downward direction. The granules range in size from inches to a few hundredths of an inch. Granule size has the same effect on particle removal efficiency as does the fiber size in fiber filters. The depth of the bed ranges from 2 to 9 ft depending on the design. The face velocity through the filter is typically on the order of 5 fpm with pressure drops of 10 inches of water.

X.1.1 PRINCIPLES OF OPERATION

The granules collect particles primarily by interception and diffusion. The larger particles are collected by interception. A 5 fpm face velocity is too low for impaction to have a strong effect on particle removal. However, at face velocities on the order of 20 fpm with grain sizes on the order of 0.02 inches, impaction may become significant. These conditions would give a high resistance to flow. Gravitational settling improves collection in downward flow beds and retards collection in upward flow beds. A low face velocity and high bed depth provide a long residence time for effective diffusion collection efficiency. The granules have a relatively high heat capacity and the bed can act as a heat sink, cooling gas and condensing steam. Small granules can hold a few percent of their weight in condensed water. This water acts to narrow the flow passages between the granules and increase the flow resistance. Larger granule sizes are less susceptible to this effect. Graded filters with upward flow can be effectively used to remove water from the gas.

X.1.2 OPERATIONAL PARAMETERS

Flow Rate

The flow rate depends on the bed design, that is the granule size, the gradation, the bed depth, and the pressure drop. An increase in loading or in water content

of the bed will increase the flow resistance. Large (25,000 to 210,000 cfm) graded granular media filters with bed depths on the order of 9 ft are operated at a face velocity of 5 fpm with a pressure drop on the order of 5 to 10 inches of water with removal efficiencies approaching those of a HEPA filter [Sehmel, 1990]. The sand bed filter being developed by France for reactor containment venting consists of 2.6 ft of 0.024 inch diameter sand operated at a face velocity of nearly 20 fpm at a pressure drop of nearly 40 inches of water [Eric, 1988]. The particle removal efficiency of this filter was greater than 99 percent at 1 μm . This filter was designed for flows of 8850 cfm.

Pressure Drop

The pressure drop depends on the design as discussed above under Flow Rate.

Removal Efficiency

The particle removal efficiency depends on the design as discussed above under Flow Rate.

Aerosol Loading

The aerosol loading of these filters can vary considerably. The French filter has a single small granule size with a high pressure drop. It would not be expected to have a high loading capacity and has been designed to handle 11 pounds of nominally 1 μm particles with a filter flow area of 452 ft². A graded granule size deep bed filter may be designed to handle particle loadings similar to deep bed glass fiber filters. The design of the filter is very important in determining its flow, pressure drop, removal efficiency, and loading capabilities.

Size

These filters are very large. A graded type filter with a 5 fpm face velocity and a 9 ft bed depth would require 6400 ft² to handle the same 32,000 cfm that is handled by a current filter compartment. The volume of the filter media itself would be 57,600 ft³. This is a box 80 ft on a side and 9 ft deep. The weight would be nearly 4000 tons.

Maintenance and Peripheral Equipment

Maintenance required is periodic inspection for leakage through the medium and testing for performance.

Lifetime

The lifetime of a granular bed filter is on the order of the facility being served.

Waste and Waste Handling

If the filter is cleaned by back flushing with liquid, a considerable amount of liquid waste is generated. The amount of solid waste from decommissioning or from an accident would be large.

X.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Granular media deep bed filters can have particle removal efficiencies comparable to HEPA filters

Iodine Removal

These filters do not effect molecular iodine removal.

Particle Loading Capacity

The particle loading capacity can be as high as the glass fiber deep bed filter.

Pressure Drop

The pressure drop is moderate at 5 to 10 inches of water. Water and moisture can increase this.

Gas Flow Capacity

The gas flow capacity can be very high but requires a very large filter flow area. The face velocity of 5 fpm is low.

Radiation

The sand and gravel media used in these filters have no difficulty in handling radiation.

Temperatures

Temperature is not a limiting factor of the granular bed filter in this application. The inlet temperature of the gas can be several hundred degrees and the heat capacity of the bed will cool the gas. This will also act to condense steam from the gas flow.

Water and Moisture

Water and moisture will not damage the media but may increase flow resistance. Properly designed, a granular bed filter can be used to remove liquid water and steam from a gas flow.

Other Caveats

These are robust filters and can withstand pressure shock without damage. Granular media will attenuate a shock. Resuspension of collected particulate is possible.

X.3 SUMMARY

Granular media deep bed filters are robust filter media capable of high filtration efficiency and high particle loading. The pressure drop is moderate, somewhat higher than for a HEPA filter. They act as a heat sink to cool the gas and remove water. These filters are not an off-the-shelf item. They have a low face velocity and a large size that presents a large potential waste volume.

X.4 REFERENCES

- Dickinson, D. R., McCormack, J. D., Allemann, R. T., and Andres, R. A., 1990, Experimental Results of ACE Vent Filtration: Sand Bed Filter Tests, ACE-TR-A11, Electric Power Research Institute.
- Eric, J., 1988, "Containment Venting System - Sand Bed Filter: Description, Operating Procedure, Implementation Program," Proc. CSNI Specialists Meeting on Filtered Containment Venting Systems, Paris, 17-18 May, CSNI Report 148, pp. 257-278.
- Hogberg, L., 1988, "The Swedish Program on Severe Accident Management and Release Mitigation," Intl. Symp. on Severe Accidents in Nuclear Power Plants, Sorrento, Italy, 21-25 March, IAEA-SM-296/106, International Atomic Energy Agency.
- Holm, C. G., 1988, "A Versatile Containment System," Proc. CSNI Specialists Meeting on Filtered Containment Venting Systems, Paris, 17-18 May, CSNI Report 148, pp. 163-174.
- Johansson, K., 1988, "FILTRA Retention of Aerosols and Iodine, Experimental and Analytical Results," Proc. CSNI Specialists Meeting on Filtered Containment Venting System, Paris, 17-18 May, CSNI Report 148, pp. 175-196.

- Kovach, J. L., 1988, "Review of Containment Vent Filter Technology," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 21-97.
- Lindau, L. and Elisson, K., 1988, "Filtered Containment Venting in Sweden," Proc. of the 20th DOE/NRC Nuclear Air Cleaning Conference, Boston, MA, Aug. 22-25, NUREG/CP-0098, pp. 695-707.
- Otani, 1989, "Experimental Study of Aerosol Filtration by the Granular Bed Over a wide range of Reynolds Numbers," Aerosol Sci. Technol. Volume 10/3, pp. 463-474.
- Sehmel, G. A., 1990, A Review of the Potential Alternatives for Air Cleaning at the Hanford Waste Vitrification Plant, PNL-7391, UC-721, Pacific Northwest Laboratory, Richland, WA.
- Tien, C., 1989, Granular Filtration of Aerosols and Hydrosols, Butterworths, Boston, MA.

Figure X.1 Schematic diagram of a granular media deep bed filter.

XI. CYCLONES

Cyclone separators are widely used in industry for the removal of particulates from gas streams. Centrifugal force is the primary particle collection mechanism although filtration, aggregation, and scrubbing may also play a role. The device is simple, inexpensive, has no moving parts, and can be built of most materials. As a class of air pollution control equipment, cyclones provide the lowest collection efficiencies and, therefore, often serve as precleaners for subsequent collection equipment. Increased removal efficiencies may be obtained using a water wash in conjunction with the cyclone.

XI.1 DESCRIPTION

A typical vertical reverse-flow cyclone with a tangential inlet is shown in Figure XI.1. The particle-laden gas stream enters the unit tangentially and is forced to follow the curved geometry of the cyclone. The inertia of the particles causes them to move towards the outer wall where they are carried by gravity and secondary eddy flows down to the dust outlet at the bottom of the cyclone for collection. The centrifugal force acting on the particles is typically an order of magnitude greater than gravity. Consequently, particle collection is substantially enhanced in a cyclone as compared to a gravity settling chamber. The gas makes several turns before reaching the bottom of the device where it reverses flow and passes up and out through the center of the unit.

XI.1.1 PRINCIPLES OF OPERATION

Inertial impaction and interception are the primary particle removal mechanisms acting in a cyclone. A considerable amount of effort has gone into modelling the flow in a cyclone. Actual cyclone performance is very complex and empirical formulas have been developed for use in cyclone design. Cyclones with high inlet velocities, small diameters, and long cylinders are usually found to be most efficient. Conventional cyclones having efficiencies of 80-95% in the 5-10 μm range, handle high throughputs at pressure losses between 2 and 6 inches of water. Body diameters are 4 to 12 ft. High efficiency (95-99%) cyclones are long and narrow and rarely have outer diameters greater than 3 ft. Pressure drops are, again, between 2 and 6 inches of water. High efficiency cyclones are often operated in parallel in order to increase the gas flow rate [Theodore and Buonicore, 1988].

The centrifugal force acting upon the particles in the cyclone results in a dust layer slowly swirling down the walls of the cyclone. Ideally, the particles should be collected and prevented from re-entraining in the upward gas flow. Smoothness of the cyclone walls is essential in preventing small eddies from forming and carrying the particles out into the main vortex flow.

The operating variables defining cyclone performance are gas temperature, pressure, and composition, and particle characteristics including shape, density, concentration, and size distribution. For operating temperatures between 10 and 400°C, a temperature change does not affect cyclone performance. At temperatures greater than 540°C, however, viscosity effects become significant and there is a decline in the cyclone efficiency. In general, efficiency increases with increasing particle size or density, gas inlet velocity, cyclone body or cone length, and ratio of body diameter to gas outlet diameter. Efficiency decreases with an increase in gas viscosity or gas density, cyclone diameter, gas outlet diameter, or inlet width or inlet area [Stern, 1977].

There is no upper limit to the particle loadings that can be handled in an ordinary cyclone. In fact, increased inlet dust loadings result in lower pressure drops and higher efficiencies. The pressure drop of a heavy dust load of 75-100 grains/ft³ (173-230 g/m³) is 75-80% that of clean air [Stern, 1977]. Movement of the large particles towards the cyclone wall sweeps some of the fine particles along. Impaction between large and small particles also increases. Small diameter cyclones are rarely used for heavy dust loads because plugging of the narrow passages is likely to occur.

Erosion, pluggage, and corrosion cause most problems in cyclones [Theodore and Buonicore, 1988]. Erosion is caused by the impingement and rubbing of dust particles on the cyclone wall. It is worse with high dust loadings, high inlet velocities, and large or hard dust particles. Flaws in the cyclone design that concentrate the dust will tend to accelerate erosion. There are two types of cyclone fouling --- outlet pluggage and wall buildup. Wall buildup is a function of the dust. The finer the dust, the greater the tendency for buildup [Theodore and Buonicore, 1988]. Smaller particles may also remain in the stagnant boundary layer. Moisture is another major cause of wall buildup. Hygroscopic particles may become sticky and cake on the wall. The problem then becomes self-perpetuating. Corrosion is minimized by using the proper material for cyclone construction.

There are many variations on the ordinary cyclone. Straight-through-flow cyclones, axial flow cyclones, impeller collectors, cyclones with water washes, etc. For instance, the cyclone separator developed by Pall Europe, Ltd. [Stallard et al., 1988] for use in nuclear gas cleaning systems, is an axial flow cyclone in which the vortex motion is induced by impeller vanes. The addition of a water spray to an ordinary cyclone increases the particle removal efficiency --- 95-99% for 5-50µm droplets [Stern, 1977]. These devices are often called "cyclone scrubbers" (see Figure XI.2). Cyclones operated wet for the collection of dry dusts improve efficiency, prevent wall buildup and fouling, reduce erosion, and scrub gas contaminants. Particles are trapped in a liquid film as they flow down the cyclone walls and are not easily re-entrained. Sufficient quantities of water must be used so that the cyclone walls are wet, not merely moist, otherwise caking and plugging will occur. One of the major disadvantages to wet operation is corrosion. The

presence of water aggravates the problem if corrosive dusts or gases are handled [Stern, 1977]. A second disadvantage is the additional cost of filtering and recirculating, or disposing of the water. If the water is recirculated, then heavy particle loads lead to filtering problems. Otherwise, the contaminated water must be dealt with.

XI.1.2 OPERATIONAL PARAMETERS

Flow Rate

Cyclones can be designed to handle any flow rate desirable. In order to achieve a desired minimum pressure drop, a number of small cyclones may be used in parallel. Face velocities are high.

Pressure Drop

The pressure drop within the cyclone determines the collection efficiency. Typical pressure drops for dry cyclone operation range from 2 to 6 inches of water. The pressure drop in a cyclone scrubber is slightly higher. Theoretically, pressure drop varies with the square of the inlet velocity, although deviations have been found.

Removal Efficiency

Cyclones should be used for the removal of large particles. The removal efficiency is only 50-80% in a high efficiency cyclone for particles less than 5 μm . Particles greater than 30 μm are removed with greater than 90% efficiency by most cyclones. Particles of high density are collected more efficiently than those of lower density. A water spray greatly enhances the collection efficiency for particles down to approximately 5 μm .

Aerosol Loading

There is no upper limit to the loadings that can be handled by an ordinary cyclone. Indeed, the pressure drop decreases and the efficiency increases at increased dust loadings. Small diameter cyclones may experience plugging at high loadings.

Size

Cyclones have diameters ranging from 6 inches to several feet. Lengths are typically 2 to 4 diameters. The length of the body of the cyclone, or the number of turns the gas makes, strongly influences the removal efficiency. Higher efficiencies require a longer cyclone.

Maintenance and Peripheral Equipment

Routine maintenance involves regular removal of material from the dust collection hoppers and inspection of the cyclone for signs of erosion, corrosion, or wall buildup. The cyclone should be kept air tight to operate effectively. Leakage disrupts the flow pattern in the cyclone and encourages entrainment --- up to 25% collection efficiency can be lost due to dust re-entrainment [Stern, 1977]. If a wet scrubber is used with water recirculation, the liquid filtering system will have to be inspected for plugging.

Lifetime

The lifetime of a cyclone is comparable to that of the facility being served.

Waste and Waste Handling

If the cyclone is operated dry, disposal of the particulate collected in the hopper is necessary. Wet operation, on the other hand, will require either disposal of the contaminated water, or filtering of the water if recirculation is used. Upon decommissioning or in the event of use as a result of an accident, equipment disposal will have to be considered.

XI.2 ADVANTAGES AND DISADVANTAGES

Particle Removal

Dry operation cyclones remove particles greater 10 μm in diameter with high efficiency. Efficiency drops off rapidly for smaller particles. The addition of a water wash increases the removal efficiency for 5 μm particles to approximately 95 percent. Cyclones should primarily be used as roughing filters for downstream components.

Iodine Removal

Dry cyclone operation will have no effect on the iodine loadings. Wet cyclone operation will scrub some of the iodine from the gas, particularly if the liquid wash is treated to enhance iodine retention (buffered to pH = 9-11).

Particle Loading Capacity

Ordinary cyclones are capable of handling very high particle loadings. Small diameter, high efficiency cyclones may experience outlet plugging. The use of a water wash increases the loading levels that can be handled. Cyclones are sensitive to variable dust loadings.

Pressure Drop

The pressure drop across a cyclone is low to moderate, on the order of 2 to 6 inches of water. Increased dust loadings actually decrease the pressure drop.

Gas Flow Capacity

The gas flow capacity of a cyclone is high.

Radiation

This device should experience no adverse effects as a result of radiation exposure.

Temperatures

Up to 400°C, temperature has little effect on the collection efficiency.

Water and Moisture

Moisture is often responsible for wall-buildup in a dry cyclone. Hygroscopic particles become sticky and cake on the wall. Therefore, cyclones should be operated at temperatures greater than gas stream dewpoint. This problem is eliminated if a wet cyclone scrubber is used.

Other Caveats

Cyclones can be made of almost any material. Particle re-entrainment is possible from either the walls or the hopper inlet. Corrosion is a potential problem and is aggravated by wet operation.

XI.3 SUMMARY

Cyclones are suitable for use as roughing filters. They remove large particulates very efficiently at relatively low pressure drops. If a water wash is combined with a cyclone, gas scrubbing is an additional benefit. The simplicity of design and maintenance make cyclones attractive devices. However, fine-tuning a cyclone's operation is very difficult since there are no moving parts. A cyclone should be initially designed to meet the criteria; it is very difficult to modify a cyclone to accommodate a poor design or operating conditions that have changed significantly.

XI.4 REFERENCES

Flagan, R. C. and Seinfeld, J. H., 1988, Fundamentals of Air Pollution Engineering, Prentice Hall, Englewood Cliffs NJ, pp. 402-411.

Licht, W., 1988, Air Pollution Control Engineering, 2nd edition, Marcel Dekker, Inc., New York, pp. 277-330.

Stern, A. C., 1977, Air Pollution, 3rd edition, Volume IV, Academic Press, New York, pp. 97-148.

Theodore, L. and Buonicore, A. J., 1988, Air Pollution Control Equipment, Volume I: Particulates, CRC Press, Inc. Boca Raton, FL, pp. 51-77.

Figure XI.1 Typical tangential inlet vertical reverse flow cyclone.

Figure XI.2 Cyclone scrubber.

XII. ELECTROSTATIC PRECIPITATORS

XII.1 DESCRIPTION

Electrostatic precipitators are one of the most widely used particle removal technologies, ranging from power plant flue gas cleaning to household air cleaners. They are used extensively in industry for removing small particles suspended in gases; this may be done to cleanse exhaust gas, to meet environmental regulations, or to recover products.

XII.1.1 PRINCIPLES OF OPERATION

In an electrostatic precipitator, particle removal is accomplished by charging the particles, and then subjecting the charged particle-laden gas to a strong electric field. In an electric field, the charged particles migrate away from like-charged boundaries of the field. At least one boundary of the field terminates on a collecting plate of opposite polarity of the particles. It is on this collecting plate that the charged particles are deposited and lose their charge.

In a typical arrangement, vertically suspended wires are charged to thousands of volts producing a sufficiently high electric field strength that the adjacent gas molecules break down and form ions (Figure XII.1). This breakdown produces a bluish glow around the wires and is called a "corona." The wires are in a single row spaced about a half foot apart. The field strength necessary for breakdown in air has been determined empirically and is given by [Hinds, 1982],

$$E_b = 30 + \frac{12.7}{\sqrt{d_{\text{wire}}}}$$

where,

$$\begin{aligned} d_{\text{wire}} &= \text{wire diameter (cm)}, \\ E_b &= \text{field strength (kV/cm)}. \end{aligned}$$

Most industrial electrostatic precipitators use a negative corona since they have been found to be more stable. The negative gas ions produced by the corona migrate away from the corona wires. Some collide with aerosol particles and thereby deposit charges on the particles. For negatively charged wires, particles attain a negative charge.

XII.1.2 OPERATIONAL PARAMETERS

The corona wires in a typical electrostatic precipitator are suspended between positively charged plates, which are located about 6 inch from either side of the wires. The plates are typically 9 ft wide in the direction of gas flow. The gas flow

is directed either horizontally or perpendicularly to the wires. Since the plate spacing is so large and the wires hardly obstruct the flow, the pressure drop is minimal and may be neglected.

One manufacturer [United McGill, Columbus, OH], however, uses a slightly different arrangement. Instead of using a row of suspended wires, a discharge plate, 3 ft wide, is suspended vertically between two 54 inch wide collecting plates. The collecting plates are separated by slightly over a half foot, with the discharge plate located midway between the collecting plates. Many sharp pointed needles arranged in a single column are attached to the two vertical edges of the discharge plate. Thus, a column of needles at one edge of the discharge plate points into the gas flow, and another column of needles points in the opposite direction at the other edge of the discharge plate.

A most important feature of this design is that the discharge plate is positively charged, producing a positive corona, and thus the particles are charged positively. This is important since it has been well-documented that particles containing either alpha or beta emitters are virtually always positively charged [Altman, 1988; Berezhnoi et al., 1977a; Berezhnoi et al., 1977b; Berezhnoi et al., 1978; Boisdron and Brock, 1970; Dua et al., 1978; Fish et al., 1965; Ivanov et al., 1969; Ivanov et al., 1972; Ivanov and Kirichenko, 1970; Kirichenko et al., 1973; Kirichenko et al., 1976; Reed et al., 1977; Shleien, B. and Terpilak, M. S., (eds), 1984; Suprun et al., 1976; Yeh et al., 1976; Yeh et al., 1978]. Therefore, instead of using the typical negative corona that counteracts the positive self-charging mechanism for radioactive particles, the United McGill design enhances the positive charging process. In addition, a positive corona produces less ozone.

In either a positive or negative corona, the forces operating on particles are coulombic and viscous. The coulombic force pushes the particles away from the corona-forming surface, while viscous air drag limits particle acceleration. Since the particle mass is so small, particles quickly attain a steady-state migration velocity determined by the balance of coulombic and viscous forces. This velocity increases with decreasing particle diameter, increasing particle charge, and increasing field intensity. Typical migration velocities are 0.1 fps for 0.5 μm diameter particles to 3 or 4 fps for 20 or 30 μm diameter particles [White, 1963]. Since the flow is generally turbulent in commercial electrostatic precipitators, the migration velocity must be determined experimentally.

The collection efficiency of an electrostatic precipitator may be given by the classical Deutsch Formula,

$$\eta = 1 - \exp(-vA/Q) = (S_{in} - S_{out})/S_{in}$$

where,

η = collection efficiency,
 A = area of collecting plates (m^2),
 v = particle migration velocity (m/s),
 Q = gas flow rate (m^3/s),
 S = particle concentration (kg/m^3).

The deposited particles form a coating on the collecting plates and thus must be somewhat conductive so as not to impede the flow of corona ions; otherwise sparking would result. The maximum allowable resistivity of the particle material is typically 2×10^{10} ohm-cm [White, 1963]. Particles deposited on the collection plate may be removed by rapping the plates, which causes the particles to fall into a hopper for later collection. An attractive alternative to rapping for radioactive particle removal is spray washing. Spray-washed or so-called "wet electrostatic precipitators" are available commercially [United McGill]. While washing the collecting plates, the spray may simultaneously cool the precipitator and absorb gaseous iodine.

XII.2 ADVANTAGES AND DISADVANTAGES

Although there is extensive, favorable industrial experience with electrostatic precipitators, no applications have been found for removing highly radioactive aerosols. Thus, it is difficult to assess the advantages and disadvantages of this device for application to Savannah River. No electrostatic precipitator manufacturer has been found who has used their product for radioactive particle removal, although many expressed interest in the problem. Some manufacturers argued that a negative corona may be able to counteract the natural positive self-charging mechanism [Yeh et al., 1976; Yeh et al., 1978] of radioactive aerosol particles.

Electrostatic precipitation has, however, been mentioned as a viable method for "selective trapping of hot beta-active aerosol particles using an electric field" [Ivanov and Kirichenko, 1970]. In a flow system, "when a radioactive gas moves along a pipeline, electric fields are produced near the wall because of the differences in diffusion speed between the different types of ions during recombination at the surface...Therefore, strong electric fields (sometimes up to breakdown level) arise in pipelines at high specific activity levels, and these cause rapid deposition of aerosol particles on the wall and may improve the performance in nuclear power station cleaning systems such as filters under emergency conditions." [Kolomeitsev et al., 1983]. Thus, the idea of using electrostatic precipitators for radioactive aerosol particle removal is not new, but reports have not been found for the flow conditions or radiation intensities envisioned in a nuclear reactor venting system under accident conditions.

Despite the lack of no reported experience with the device for the considered application, there are many obvious and important advantages if the system can

be shown to be effective in a high radiation field. A summary of these advantages and disadvantages is given in Table XII.1.

XII.3 SUMMARY

No experiments have been found that report radioactive aerosol removal by electrostatic precipitation for nuclear reactor venting systems. It is not known if high radiation fields introduce so many gaseous ions that aerosol particles are charge neutralized before they can be removed by such a precipitator. However, the work reported in the Soviet Union strongly suggests that electrostatic precipitation has great potential. The positive self-charging nature of alpha and beta emitters tends to support the idea of using a positive corona precipitator. This phenomenon is expected to affect electrostatic precipitator performance, but unfortunately, tests may not be very meaningful using nonradioactive surrogates. Therefore, a high radiation field may be required for testing. It is recommended that if testing an electrostatic precipitator system is possible, the United McGill positive-corona system be studied first. The high temperature and corrosion tolerance, high gas flow rate capability, and very low pressure drops typical of electrostatic precipitation provide strong motivation for considering this technology for radioactive aerosol removal.

XII.4 REFERENCES

- Altman, R. F., 1988, "ESP Performance with Atmospheric Fluidized-Bed Combustion," J. Air Pollution Control Assoc., Volume 38(11), pp. 1455-1458.
- Berezhnoi, V. M., Zubarev, V. V., Dunaeva, N. P., Kirichenko, V. N. and Academician I. V. Petryanov-Sokolov, 1977a, "Emission Electrification of β -active Aerosol Particles in an External Electric Field," Sov. Phys. Dokl., Volume 22(11), pp. 685-687.
- Berezhnoi, V. M., Dunaeva, V. V., Zubarev, N. P., Kirichenko, V. N. and Academician I. V. Petryanov-Sokolov, 1977b, "Influence of the Stopping Power of a Gaseous Medium on the Electrification of β -active Aerosol Particles in an External Electric Field," Sov. Phys. Dokl., Volume 22(12), pp. 771-772.
- Berezhnoi, V. M., Kirichenko, V. N., and Academician I. V. Petryanov-Sokolov, 1978, "Stationary Distribution of the Charges of β -active Aerosol Particles," Sov. Phys. Dokl., Volume 23(10), pp. 760-762.
- Boisdron, Y. and Brock, J. R., 1970, "On the Stochastic Nature of the Acquisition of Electrical Charge and Radioactivity by Aerosol Particles," Atmos. Environ., Volume 4, pp. 35-50.

- Dua, S. K., Kotrappa, P., and Bhanti, D. P., 1978, "Electrostatic Charge on Decay Products of Thoron," Amr. Industrial Hygiene Assoc. J., Volume 39(4), pp. 339-345.
- Fish, B. R. and Walker, R. L., 1965, "Aerosol Physics of Radioactive Particles," ORNL-P-1313.
- Hinds, W. C., 1982, Aerosol Technology: Properties, Behavior, and Measurement of Airborne Particles, John Wiley and Sons, New York.
- Ivanov, V. D., Kirichenko, V. N., Academician I. V. Petryanov, 1969, "Charging of Alpha-Active Aerosols by Secondary Electron Emission," Sov. Phys. Dokl., Volume 13(9), pp. 902-904.
- Ivanov, V. D., Kirichenko, V. N., Berezhnoi, V. M., and Academician I. V. Petryanov, 1972, "Effect of Intrinsic Sedimentation Velocity of Beta-Active Hot Particles on their Steady-State Electrical Charge in the Presence of an Impurity of a Contaminant Aerosol," Sov. Phys. Dokl., Volume 17(4), pp. 374-377.
- Ivanov, V. D., Kirichenko, V. N., 1970, "Spontaneous Unipolar Charging of Beta-Active "Hot" Aerosol Particles," Sov. Phys. Dokl., Volume 14(9), pp. 859-862.
- Kirichenko, V. N., Berezhnoi, V. M., and Academician I. V. Petryanov, 1973, "Kinetics of Unipolar Charging of Beta-Active "Hot" Aerosol Particles," Sov. Phys. Dokl., Volume 17(7), pp. 691-694.
- Kirichenko, V. N., Berezhnoi, V. M., Suprun, N. N., Zubarev, V. V., and Academician I. V. Petryanov-Sokolov, 1976, "Charging of Beta-Active Hot Aerosol Particles in a Variable Electric Field," Sov. Phys. Dokl., Volume 21(4), pp. 222-224.
- Kolomeitsev, G. Yu., Nakhutin, I. E., and Poluektov, P. P., 1983, "Features of a Radioactive Flow in a Pipeline," Atomnaya Energiya, Volume 55(3), pp. 183-184.
- Reed, L. D., Jordan, H., and Gieseke, J. A., 1977, "Charging of Radioactive Aerosols," J. Aerosol Sci., Volume 8, pp. 457-463.
- Shleien, B. and Terpilak, M. S., (Eds), 1984, The Health Physics and Radiological Health Handbook, Nucleon Lectern Associates, Inc., ISBN 0-917251-00-8.
- Suprun, N. N., Stepchenkov, V. I., Levasheva, N. P., Kirichenko, V. N., and Academician I. V. Petryanov-Sokolov, 1976, "Experimental Investigation

Figure XII.1 Schematic of a typical electrostatic precipitator.

9.0 LIST OF SELECTED GAS CLEANING TECHNOLOGY COMPANIES

ABB-Atom (MVSS)
Box 53 S-721 04
Vasteras, SWEDEN

Aercology Incorporated
Alan LaFontain, Manufactures
Representative
P. O. Box 77488
Tucson, AZ 85703-7488
(602) 299-2949

AirPol Inc.
Jorgen G. Hedenhag, Manager
Precipitator Division
32 Henry Street
Teterboro, NJ 07608
(201) 288-6441

Beco Engineering Company
Glenshaw, PA 15116
(412) 828-6080

JOY Western Precipitation Division
JOY Manufacturing Company
P. O. Box 2744, Terminal Annex
Los Angeles, CA 90051
(213) 240-2300

Pall Porous Metal Corporation
Cortland, NY 13045
(607) 753-6041

Raytheon Inc.
Standard Havens Division
8800 East 63rd St.
Kansas City, MO 64133
Richard Draheim
(816) 737-0400

Research-Cottrell
P. O. Box 1500
Somerville, NJ 08876
(800) 722-3780

United McGill Corporation
2400 Fairwood Avenue
P. O. Box 820
Columbus, OH 43216
(614) 442-0192

10.0 CONCLUSIONS

The particle removal devices reviewed in this report make use of one or more removal mechanisms --- sieving, gravitational settling, inertial impaction, interception, diffusion, electrostatics, thermophoresis, or diffusiophoresis --- and may be classed into one of the following general removal technologies --- wet scrubbing, filtration, inertial separation, or electrostatic collection. These general observations may be made (a more specific performance survey is presented in Table 10.1):

- 1) Inertial separation removes large particles with high efficiency but is ineffective at removing small particles. High loadings are handled well. These are very robust devices.
- 2) Filtration techniques remove large and small particles with high efficiency. Some filters are sensitive to the gas moisture content. Clean filters operate with low pressure drops. As the filter loading increases, so does the pressure drop. Filters tend to require increased maintenance.
- 3) Wet methods are capable of handling higher loadings than an equivalent dry method. They enjoy the added advantage of scrubbing the iodine from the gas and reducing the iodine load on downstream components.
- 4) Wet methods are more susceptible to corrosion problems.
- 5) All methods are particle size dependent.
- 6) Electrostatic precipitation can handle high loadings, operates at high efficiency for large and small particles, can be run in conjunction with a water wash, but has not been tested as a collection technology at high radiation levels.

Two facts are apparent. First, no one technology emerges as the technology of choice. Clearly a give-and-take will be necessary depending on the collection requirements. And second, definition of the aerosol source term is absolutely essential if any level of confidence regarding performance of the airborne activity confinement system is required. The particle size distribution, mass distribution, chemical composition, loading levels, and particle concentrations as a function of time, all strongly influence the removal efficiency for the technologies reviewed.

TABLE 10.1 PERFORMANCE SUMMARY

Technology	Particles (μm)	In-line	ΔP (inches H_2O)	Face velocity (fpm)	Operation
Spray scrubber	>10	yes	1-2	100-300	wet
Submerged bed scrubber	>1	es	35	20	wet
Packed bed scrubber	>1	es	2-10+	100-400	wet
Venturi	>1	es	10-80+	high	wet
Multi venturi scrubber system	>1	es	120-200	high	wet
Glass-fiber HEPA filter	yes	no	1	250	dry
Metal-fiber HEPA filter	yes	no	1	high	dry
Glass-fiber deep bed filter	yes	no	1.5-8+	50	dry
Metal-fiber deep bed filter	yes	no	20	50	dry
Baghouse	>0.1	no	2-6+	mod	dry
Granular media bed filter	yes	no	5-10+	5	dry
Cyclones	>10	yes/no	1-5+	high	wet/dry
Electrostatic precipitator	>0.1	yes/no	<1	100-500	wet/dry

WESTINGHOUSE SAVANNAH RIVER LABORATORY
INTERNAL DISTRIBUTION LIST

Allison, D.A.	773-41A
Brandyberry, M.D.	773-41A
Budnitz, R.J.	
Catton, I.	
Chow, S.	773-41A
Clare, G.	742-3A
Dickson, P.	703-A
Ellison, P.G. (2)	773-41A
Garrett, A.	773-A
Hitchler, M.J.	773-A
Hyder, M.L.	773-41A
Kernaghan, D.P.	773-41A
Kerr, W.	
Kress, T.	
Monson, P.R., (2)	773-A
Morgan, G.	703-42A
Norkus, J.K.	M.L. Augusta
O'Kula, K.R.	773-41A
Olson, R.L.	773-41A
Orth, D.	773-41A
Paddleford, D.F.	773-A
Pierpoint, J.D.	707-45B
Richardson, D.C.	773-A
Sharp, D.A.	773-41A
Shieh, P.	703-42A
Spencer, J.	773-A
Stubbs, B.	703-42A
Ward, D.A.	
Woody, N.D.	773-41A
Wooten, L.A.	773-41A
SRL Records (4)	773-A

END

**DATE
FILMED**

9 / 8 / 92