Do Not Destroy 9/9/75

(CLASSIFICATION)

DECLASSIFIED

HW-83812

SERIES AND COPY NO.

GENERAL ELECTRIC

HANFORD ATOMIC PRODUCTS OPERATION - RICHLAND, WASHINGTON

DATE

October 21, 1964

RESTRICTED DATA

THIS DOCUMENT IS DEFINED IN THE ACT OF 1954. ITS TRANSFER IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PROHIBITED.

TITLE

NUMERICAL RESULTS OF THE DUAL AREA TRIP-OUT OF B AND C REACTORS' PROCESS PUMPS

OTHER OFFICIAL CLASSIFIED INFORMATION

THIS MATERIAL CONTAINS INFORMATION AFFECTING THE NATIONAL DEFENSE OF THE UNITED STATES WITHIN THE MEANING OF THE ESPIONAGE LAWS, TITLE 18, U. S. C., SECS. 793 AND 794, THE TRANSMISSION OR REVELATION OF WHICH IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PROHIBITED BY LAW.

AUTHOR

S. A. Wood

ISSUING FILE

CIRC
RE

THIS DOCUMENT MUST NOT BE LEFT UNATTENDED WHERE AN UNAUTHORIZED PERSON MAY HAVE ACCESS TO IT. WHEN NOT IN USE IT MUST BE STORED IN AN APPROVED LOCKED REPOSITORY WITHIN AN APPROVED GUARDED AREA. IT IS YOUR RESPONSIBILITY TO KEEP IT AND TO RETURN IT TO THE ISSUING OFFICE OF THIS DOCUMENT AND FROM ANY UNAUTHORIZED PERSON. ITS TRANSFER, LOAN, AND STORAGE AT ANY PLACE OR FOR ANY PURPOSE IS PROHIBITED. IT IS NOT TO BE DUPLICATED. IF ADDITIONAL COPIES ARE REQUIRED, THEY MUST BE OBTAINED FROM THE ISSUING OFFICE. ALL PERSONS READING THIS DOCUMENT MUST SIGN IN THE SPACE PROVIDED BELOW.

ROUTE TO:

PAYROLL NO.

LOCATION

FILES ROUTE DATE

SIGNATURE AND DATE

RT Jaskie

902

~~1111H~~

12-15-64

BNW

70000

3760

1-1-65

D. W. Dragnich

34036

R0

5/15/75

DECLASSIFIED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Ma Clinton

DECLASSIFIED

Verified By Jerrie Maley 4-18-94.

NOTICE

DECLASSIFIED

DISTRIBUTION

1. AEC-RLOO-Attn: PM Midkiff	37. RT Jessen
2. AEC-RLOO-Attn: RL Plum	38. SS Jones
3. AEC-RLOO-Attn: CN Zangar	39. LM Keen
4. TW Ambrose	40. ER Keplinger
5. JT Baker	41. WH Koontz
6. JW Baker	42. CE Love
7. CR Barker	43. TH Lyons
8. JE Boyd	44. GL Madsen
9. LB Brinkman	45. AR Maguire
10. HM Burton	46. SL Nelson
11. LS Cave	47. MG Patrick
12. WH Clark	48. RS Peterson
13. MA Clinton	49. JR Pierce
14. RF Corlett	50. CF Quackenbush
15. PE Cunningham	51. JL Rand
16. G Fiorelli	52. RW Reid
17. JW Frymier	53. WJ Richardson
18. DK George	54. CM Salina
19. WL Goss	55. OC Schroeder
20. SM Graves	56. RM Scott
21. OH Greager	57. DE Sebade
22. AB Greninger	58. W Seeburger
23. CN Gross	59. RE Spicka
24. TM Hall	60. AP Vinther
25. AK Hardin	61. FF Vlacil
26. CE Harkins	62. RK Wahlen
27. Ralph Haynes	63. DF Watson
28. RC Haynes	64. GW Wells
29. HW Heacock	65. RW Wood
30. JW Hedges	66. SA Wood
31. RD Hickman	67. HA Zweifel
32. PJ Hollifield	68. RE Dunn
33. GR Hosak	69. 700 Files
34. IL Huffman	70. Record Center
35. RT Jaske	
36. RD Jensen	

DECLASSIFIED

TABLE OF CONTENTS

	<u>Page No.</u>
Figure 1 - Trip-Off to Steam Backup - C Reactor	8
Figure 2 - Trip-Off to Last Ditch - C Reactor	9
Figure 3 - Trip-Off to Steam Backup - B Reactor	10
Figure 4 - Trip-Off to Last Ditch - B Reactor	11
Figure 4A- Transient Pressures Observed During Trip-Off to Last Ditch at 105-B	12
Figure 5 - Trip-Off to Steam Backup - C Reactor	13
Figure 6 - Trip-Off to Steam Backup - B Reactor	14
Figure 7 - 184-B Steam Boiler Acceleration Trip-Off to Steam Backup	15
Figure 8 - Trip-Off to Last Ditch - C Reactor	16
Figure 9 - Trip-Off to Last Ditch - B Reactor	17
Figure 10- 182-Bldg. Export Manifold Pressures	20
Figure 11- 182-Bldg. Export Manifold Pressures	21
Figure 12- Top-of-Riser Pressure Vs. Reactor Flow, Corrected Curves	22
Table 1 - Sequence of Events, B-C Tripout Test	7
Table 2 - High-Tank Flow Data, Trip-Off to Last Ditch	18
Table 3 - 105-C Raw Data, Trip-Off to Last Ditch	19
Table 4 - 105-B Raw Data, Trip-Off to Last Ditch	28
Table 5 - 182-F and H Export Steam Pump Speeds, Trip-Off to Last Ditch	31

DECLASSIFIED

NUMERICAL RESULTS OF THE DUAL AREA TRIPOUT
OF B AND C REACTORS' PROCESS PUMPS

INTRODUCTION

The dual area tripout of B and C reactors' process pumps was performed on July 20, 1964. The first part of the test involved tripping off B and C reactors' process pumps with steam-pump backup, with all other equipment backed up by steam set for automatic operation. This test was done to evaluate the acceleration characteristics of the 184-B steam boilers in response to a sudden high-level demand for steam.

The second phase of the test involved tripping off the process pumps with the 190 steam turbines blocked out so that reactor flow would decay down to that provided by the last-ditch system. This was done for two purposes: first to provide current pressure decay curves for B and C reactors, and second to determine the amount of reactor flow provided by the modified export and high-tank system.

This report presents the numerical results of both tests. All adequacy evaluations based on these results will be presented in separate reports.

TEST I - TRIPOUT TO STEAM BACKUP

Three sets of data were generated by this test. First was the top-of-riser pressure (TORP) decay at B and C reactors. This was measured by taking motion pictures of Heise gauges connected to read the average riser pressure at each reactor. This data is presented in Figures 1 and 3. The C-reactor data was corrected by 14.4 psi for the elevation difference between the Heise gauge and the riser top, in addition to a -1 psi gauge zero correction. No correction was made to the B data since a 14.4 elevation correction was already set into the Heise gauge and no zero error was found when the gauges were checked for calibration after the test.

It was noticed during Test II that the timer at B reactor was running about five per cent slow compared to stopwatch time. Several sets of data were taken which permitted correction of the timer data for this test. It is not known whether this also occurred during Test I so that the times in Figure 3 could be about five per cent slow.

The steady-state TORP produced by the steam pumps was lower than expected at both reactors. At C reactor this was due to an auxiliary nozzle in each of the steam turbines being valved off, which is not normally the case. This was due to a misunderstanding on the part of the Power supervisor. At B, the low pressure was due to a malfunction which caused number 9 turbine steam control valve not to fully open. Subsequent tests on this turbine failed to reveal the cause of the malfunction. All other steam powered equipment functioned as expected.

The second set of data was pump discharge pressure and speed decay on number five process pump at 190-C and number 3 at 190-B. The 190 building steam

DECLASSIFIED

pressure was also recorded by the same equipment. These data are presented in Figures 5 and 6 along with the TORP decay curves for comparison.

The final data generated by Test I are the steam flows from numbers 2, 3, and 4 steam boilers in the 184-B building, which is presented in Figure 7. The steam boiler acceleration appeared to be quite smooth with little drop in system pressure during the test.

TEST II - TRIPOUT TO LAST-DITCH FLOW

The initial portion of the test involved TORP decay down to high-tank flow. These data are presented in Figures 2 and 4 with the same corrections used as for Test I except that the B time data were corrected as explained above.

One interesting phenomena observed shortly after the pumps were tripped off at B reactor was an apparent water-hammer type of effect in which fairly violent oscillations were indicated by the Heise gauge connected to the riser pressure sensing lines. A graph of these fluctuations is presented in Figure 4-A. Since no unusual sounds were heard by personnel in 105-B, it is not known whether these oscillations occurred in the reactor coolant system or in the riser pressure sensing lines. This effect, however, was not observed during the tripoff to steam backup at B or during either test at C reactor which would indicate that the pressure fluctuations were not exclusively due to some transient phenomena connected with the pressure sensing lines. It would be interesting to observe if this effect were repeated during any future tests.

After the high tanks cut in, water level in the high tanks were recorded at one-minute intervals. These data were used to calculate high-tank flow to the reactor. The results of these calculations are given in Table 2. These data along with the total reactor flow obtained from TORP data and reactor-demand curves allowed determination of the export flow during the export plus high-tank phase of the test. After these data were collected, the export flow was valved off and the reactors fed from the high tanks only. Calculated flows from this phase of the test were used to revise the reactor-demand curves given in HW-72699, "Reactor Process Flow Technical Data," for changes in reactor hydraulic characteristics. The revised demand curves are presented in Figure 12.

Following the high-tank phase only, the export system was valved back in and the high tanks valved off. Apparently the export system was valved in too quickly, causing a low pressure transient which cycled the export surge suppressors for the second time. After these closed and the high tanks valved off, data were taken to determine the export flow to B and C reactors from the two steam turbines at 182-F and H. Following this, the cone valves at 282-E and W were opened and data taken. When this was completed, the turbines at F and H were valved off to determine the reactor flow resulting from gravity flow only from the 200 area lines. Prior to this step, it was decided not to valve off the export surge suppressors in order to save time. It was believed that the suppressors had not reset after the second cycling so that they would not cycle with the shutting off of the steam turbines. Apparently the sup-

DECLASSIFIED

pressors at 182-F or H had reset and so cycled once more. After the pressure transients had damped out, a final set of data was taken.

The reactor flows from the export phase only of the test are given below:

	<u>B Reactor</u>		<u>C Reactor</u>	
	<u>TORP</u>	<u>Flow</u>	<u>TORP</u>	<u>Flow</u>
Export system normal	9.3 psi	4950 gpm	10.8 psi	7400 gpm
282 cone valves open	9.2 psi	4830 gpm	10.3 psi	6800 gpm
gravity flow only.	8.7 psi	4570 gpm	9.8 psi	6250 gpm

It has not been ascertained that the export line at 282-E and W was running full of water prior to the opening of the cone valves. If the lines were not full, it would diminish the effect of opening the valves.

Export manifold pressure data were continuously recorded throughout the test at 182-B, D, F, and H. These data, corrected to the centerline of the export manifold in the 182 buildings, are presented in Figures 10. and 11.

Considerable difficulty was experienced in returning export flow to the 200 area reservoirs after the test. Part of this was due to communication difficulty with 182-H which prevented determining whether their surge suppressors were back to normal, which was necessary before the export line could be repressurized. Once this was resolved, 182-B put all their electric export pumps on the line but no water was getting to the 200 areas. It was then discovered that B and C reactors' export Grove valves had not been reset, so 182-B was feeding most of its water to B and C reactors. This was corrected and water was finally pumped to the 200 areas after an uncomfortable delay.

After the tripout test was completed, a test was set up to determine the total amount of export flow being diverted from the reactors to 100-N, White Bluffs, and the Central Fire Station, all of which use water from the export system in addition to the 200 areas. This was done by setting the export flow status to these areas the same as during the tripout test, valving off flow to the 200 areas, and measuring the discharge pressure and speed of the steam turbine in 182-B and then correlating this to flow. This test indicated that 700 gpm was being fed to the above three areas during the tripout test.

Another set of data not directly related to the tripout test that was obtained was the time from BPA power tripoff until the contacts of the LXX relay in the #1 safety circuit opened. This was obtained from the photographic data and are as follows:

	<u>B Reactor</u>	<u>C Reactor</u>
Trip-off to steam backup	0.48 sec.	0.72 sec.
Trip-off to last ditch	0.42 sec.	0.78 sec.

DECLASSIFIED

TABLE 1SEQUENCE OF EVENTS, B-C TRIPOUT TESTI. Tripoff to Steam Backup

Start: 10:20

End: 10:39

II. Tripoff to Last Ditch

	<u>B Reactor</u>	<u>C Reactor</u>
Start	11:48	11:48
Stable High Tank Flow	11:52.3	11:52
Export Grove Valve Started Opening	12:04.7	12:02
Export Grove Valve Completely Open	12:06.7	12:04
Export Grove Valve Closed - Start	12:13	12:15.9
Export Grove Valve Closed - End	12:15	12:17.1
Export Grove Valve Opened - Start	12:23	12:22.6
Export Grove Valve Opened - End	12:25.1	12:24
High Tanks Valved Off	12:35	12:46.5
282 Cone Valves Completely Open		12:55
182-F and H Export Steam Turbines Off Line		1:03

DECLASSIFIED

DECLASSIFIED

FIGURE

150 200 250 300
Time after trip, seconds

DECLASSIFIED

FIG

RE 3 TRIP—OFF TO STEAM BACKUP
B REACTOR

DECLASSIFIED

1

DECLASSIFIED

DECLASSIFIED

FIGURE 5 TR.
C F

- OFF TO STEAM BACKUP
ACTOR

90 - C Steam pressure

No. 3 Process pump speed, rpm ± 10

No. 3 Process pump discharge pressure

0.5 - C Top of riser pressure

trip, seconds

DECLASSIFIED

160

180

200

220

240

260

280

300

FIGURE 6

RIP - OFF TO STEAM BACKUP
- REACTOR

90-B Steam pressure

DECLASSIFIED

05-B Top of riser pressure

100 110 120 130 140 150 160 170 180

300

250

200

150

100

50

0

Steam flow lbs. / hr. ÷ 1000

Total steam flow

FIGURE 7

Time (

184-B STEAM BOILER ACCELERATION
TRIP-OFF TO STEAM BACKUP

DECLASSIFIED

er trip, seconds

t

TRIP - OFF TO LAST DITCH
C REACTOR

ess pump speed

DECLASSIFIED

er trip, seconds

100 110 120 130 140 150 160 170 180

RE 9 TRIP - OFF TO LAST DITCH
B REACTOR

Pressure

80 100 120 140 160 180
Time after trip, seconds

DECLASSIFIED

TABLE 2

HIGH-TANK FLOW DATA
TRIP OFF TO LAST DITCH

<u>Time After Trip,</u> <u>Minutes</u>	<u>B-Reactor Total</u> <u>High Tank Flow, gpm</u>	<u>C-Reactor Total</u> <u>High Tank Flow, gpm</u>
17		12,100
18		12,100
19		12,100
20	9,510	11,300
21	9,510	12,100
22	7,860	10,490
23	10,340	12,910
24	9,000	12,100
25	9,924	12,100
26	9,097	10,490
27	10,340	12,100
28	8,270	12,100
29	11,580	14,530
30	9,097	11,300
31	9,924	14,530
32	10,340	
33	9,924	
34	9,510	
35	10,750	
36	9,510	
37	9,924	
38	9,510	

Results

	<u>B Reactor</u>	<u>C Reactor</u>
Average flow, high tanks plus export	9,349 gpm	11,810 gpm
Average TORP, high tanks plus export	24.1 psi	25.8 psi
Total flow from average TORP value	12,900 gpm	17,300 gpm
Export flow by difference	3,560 gpm	5,490 gpm
Average high tank flow, high tanks only	9,920 gpm	14,530 gpm
Average TORP, high tanks only	17.3 psi	20.8 psi
Conversion factor, high-tank level to flow	827 gal./ "H ₂ O	807 gal./ 1/16 Hg.

DECLASSIFIED

TABLE 3

105-C RAW DATA, TRIPOFF TO LAST DITCH

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>High Tank Level, Inches of Hg</u>		<u>High Tank Strainer ΔP, psig</u>		<u>Export Strainer ΔP, psig</u>	<u>Export Orifice Press, psi</u>
		<u>Near</u>	<u>Far</u>	<u>Near</u>	<u>Far</u>		
11:48	0	113-1/8	48-1/16	0	0		
11:49	1	113-1/8	48-1/16	0	0		
11:50	2	113-1/8	48	0	0		
11:51	3	112-9/16	47-3/8	2.5	0		
11:52	4	111-15/16	46-5/8	6.0	0		
11:53	5	111-1/4	45-7/8	7.5	6.5		
11:54	6	110-10/16	45-5/16	7.0	7.0		
11:55	7	110	44-5/8	7.0	7.0		
11:56	8	109-5/16	44	7.5	7.0		
11:57	9	108-11/16	43-3/8	7.0	6.0		
11:58	10	108-1/8	42-13/16	7.0	6.0		
11:59	11	107-1/2	42-1/4	6.5	6.0		
12:00	12	106-7/8	41-5/8	7.0	6.0		
12:01	13	106-5/16	41-1/16	7.0	6.0		
12:02	14	105-11/16	40-9/16	6.5	6.0		
12:03	15	105-3/16	40-1/16	6.5	6.0		
12:04	16	104-13/16	39-9/16	5.0	6.0		
12:05	17	104-3/8	39-1/16	4.0	6.0		
12:06	18	103-15/16	38-9/16	4.0	5.0	13	93
12:07	19	103-1/2	38-1/16	3.5	5.0		
12:08	20	103-1/8	37-9/16	4.0	5.5	11	90
12:09	21	102-11/16	37-1/16	4.5	5.0		
12:10	22	102-5/16	36-5/8	4.5	5.5	10	88
12:11	23	101-13/16	36-1/8	4.5	6.0		
12:12	24	101-3/8	35-5/8	4.5	6.0	9	87
12:13	25	100-15/16	35-1/8	5.0	6.0		
12:14	26	100-9/16	34-11/16	4.0	5.0		
12:15	27	100-1/8	34-3/16	4.5	5.0		
12:16	28	99-11/16	33-11/16	4.5	5.0		
12:17	29	99-1/8	33-1/8	4.5	5.0		
12:18	30	98-9/16	32-11/16	5.5	5.5		
12:19	31	98	32-1/8	6.0	7.0		
12:20	32	97-7/16	31-9/16	6.0	6.5		
12:21	33	96-15/16	31-1/16	6.0	6.5		
12:22	34	96-1/4	30-1/2	6.0	6.5		
12:23	35	95-11/16	29-15/16	5.5	7.0		
12:24	36	95-3/16	29-1/2	4.5	7.0		
12:25	37	94-11/16	29	3.5	6.0		
12:26	38	94-1/4	28-1/2	3.5	5.0	5	78
12:27	39	93-3/4	27-15/16	4.0	5.0		
12:28	40	93-1/2	27-1/2	3.0	5.0	6	53

DECLASSIFIED

[REDACTED]

FIGURE 10 182 - BLDG. EXPORT MANIFOLD PRESSURES

after trip, minutes

DECLASSIFIED

FIGURE 11 182 - BLDG. EXPORT MANIFOLD PRESSURES

DECLASSIFIED

DECLASSIFIED

TABLE 3 (Continued)

Time of Day	Time After Trip, Min.	Crossheader Δ P, Inches of Water			Bottom of Riser Press. psig	Bulk Outlet Temperature $^{\circ}$ C	Total Reactor Flow Mgpm
		<u>44</u>	<u>45</u>	<u>46</u>			
11:48	0				427	18.9	96.0
11:49	1				115	18.8	64.0
11:50	2	> 300	> 300	> 300	61	18.8	34.0
11:51	3				42	18.8	20.0
11:52	4				36.5	18.8	15.0
11:53	5				36	18.8	14.0
11:54	6				36	18.9	14.0
11:55	7	> 300	> 300	> 300	36	19.0	13.6
11:56	8				36	19.3	13.3
11:57	9				36	19.5	13.3
11:58	10				36	19.5	13.2
11:59	11				36	19.5	13.1
12:00	12	> 300	> 300	> 300	36	19.5	13.1
12:01	13				35.5	19.6	13.1
12:02	14				36	19.6	13.1
12:03	15				38	19.6	13.1
12:04	16				40	19.8	13.1
12:05	17	> 300	> 300	> 300	40	19.8	13.8
12:06	18				40	19.8	13.8
12:07	19				39	19.8	13.8
12:08	20				39	19.8	13.8
12:09	21				39	19.8	13.8
12:10	22	> 300	> 300	> 300	39	19.8	13.8
12:11	23				39	19.8	13.8
12:12	24				39	19.8	13.8
12:13	25				39	19.8	13.8
12:14	26				39	19.8	13.8
12:15	27	> 300	> 300	> 300	39	19.8	13.8
12:16	28				39	19.8	13.8
12:17	29				35	19.8	12.8
12:18	30				34	19.8	12.6
12:19	31				34	19.7	12.5
12:20	32	> 300	> 300	> 300	34	19.7	12.5
12:21	33				34	19.7	12.5
12:22	34				34	19.6	12.3
12:23	35				35	19.6	12.2
12:24	36				38	19.7	12.2
12:25	37	> 300	> 300	> 300	38	19.8	12.2
12:26	38				37	19.8	12.2
12:27	39				34	19.8	12.2
12:28	40				26.5	19.8	12.2

DECLASSIFIED

TABLE 3 (Continued)

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>Maximum Tube Outlet Temperature °C</u>	<u>High Tank Water Temperature, °F</u>	
			<u>Near</u>	<u>Far</u>
11:48	0	18.0	70°F	71°F
11:49	1	18.0		
11:50	2	18.0		
11:51	3	19.0		
11:52	4	20.0		
11:53	5	21.0		
11:54	6	21.0		
11:55	7	21.0		
11:56	8	21.0		68°F
11:57	9	21.0		
11:58	10	21.0		
11:59	11	21.0		
12:00	12	21.0		
12:01	13	21.0		
12:02	14	21.0		
12:03	15	22.0		
12:04	16	22.0		
12:05	17	22.0		
12:06	18	22.0		68°F
12:07	19	22.0		
12:08	20	22.0		
12:09	21	22.0		
12:10	22	22.0		
12:11	23	22.0		
12:12	24	22.0		
12:13	25	22.0		
12:14	26	22.0		
12:15	27	22.0		
12:16	28	22.0		
12:17	29	22.0		
12:18	30	22.0		
12:19	31	22.0		
12:20	32	22.0		
12:21	33	22.0		
12:22	34	22.0		
12:23	35	22.0		
12:24	36	22.0		
12:25	37	22.0		
12:26	38	22.0		
12:27	39	22.0		68°F
12:28	40	22.0		

DECLASSIFIED

TABLE 3 (Continued)

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>High Tank Level, Inches of Hg</u>		<u>High Tank Strainer P, psig</u>		<u>Export Strainer</u>	<u>Export Orifice</u>
		<u>Near</u>	<u>Far</u>	<u>Near</u>	<u>Far</u>	<u>P, psig</u>	<u>Press, psi</u>
12:29	41	93-7/16	27-1/4	1.0	5.0		
12:30	42	93-5/16	27-3/16	1.0	2.0	10	70
12:31	43	93-1/4	27-1/8	1.5	0.0		
12:32	44	93-1/8	27-1/16	1.5	0.0	10	71
12:33	45	92-15/16	27-1/16	0.5	0.0		
12:34	46					11	73
12:35	47						
12:36	48					13	75
12:37	49						
12:38	50					11	75
12:39	51	92-1/4					
12:40	52	92-1/8				11	75
12:41	53	91-7/8					
12:42	54	91-11/16				11	75
12:43	55	91-1/2					
12:44	56	91-7/16				12	75
12:45	57						
12:46	58					11	76
12:47	59						
12:48	60					12	75
12:49	61						
12:50	62					12	75
12:51	63						
12:52	64					12	75
12:53	65						
12:54	66					11	73
12:55	67						
12:56	68					11	72
12:57	69						
12:58	70					11	72
12:59	71						
1:00	72					8	80
1:01	73						
1:02	74					7	63
1:03	75						
1:04	76					8	62
1:05	77						
1:06	78					9	62
1:07	79						
1:08	80					9	61

DECLASSIFIED

TABLE 3 (Continued)

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>Crossheader ΔP, Inches of Water</u>			<u>Bottom of Riser Press. psig</u>	<u>Bulk Outlet Temperature °C</u>	<u>Total Reactor Flow Mgpm</u>
		<u>44</u>	<u>45</u>	<u>46</u>			
12:29	41				26	19.8	12.1
12:30	42	130	130	140	26	19.8	12.0
12:31	43				24	19.8	12.0
12:32	44				24	19.8	12.0
12:33	45				24	19.8	12.0
12:34	46				24	19.8	12.0
12:35	47	92	91	95	24	19.8	12.0
12:36	48				24	19.8	12.0
12:37	49				25	19.8	12.0
12:38	50				25	19.3	12.0
12:39	51				25	19.3	12.0
12:40	52	110	111	118	25	19.3	12.0
12:41	53				25	19.3	12.0
12:42	54				23.5	19.2	12.0
12:43	55				23.5	19.2	12.0
12:44	56				23.5	19.2	12.0
12:45	57	79	78	79	23.5	19.2	12.0
12:46	58				24.5	19.2	12.0
12:47	59				24	19.2	12.0
12:48	60				23.5	19.2	12.0
12:49	61				24	19.2	12.0
12:50	62	82	82	87	24	19.0	12.0
12:51	63				24	19.0	12.0
12:52	64				23.5	19.0	12.0
12:53	65				23.5	19.0	12.0
12:54	66				23.5	19.0	12.0
12:55	67	82	82	82	23.5	18.9	12.0
12:56	68				23.5	18.9	12.0
12:57	69				23.5	18.9	12.0
12:58	70				23.5	18.9	12.0
12:59	71				50	18.9	12.0
1:00	72	79	79	81	43.25	19.0	17.9
1:01	73				41	19.0	17.0
1:02	74				23	19.0	12.0
1:03	75				22.8	19.0	12.0
1:04	76				23.0	18.9	12.0
1:05	77	60	57	62	23.2	18.9	12.0
1:06	78				23.0	18.9	12.0
1:07	79						
1:08	80						

DECLASSIFIED

TABLE 3 (Continued)

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>Maximum Tube Outlet Temperature °F</u>	<u>High Tank Water Temperature, °F</u>	
			<u>Near</u>	<u>Far</u>
12:29	41	22.0		
12:30	42	22.0		
12:31	43	22.0		
12:32	44	22.0		
12:33	45	22.0		68
12:34	46	22.0		
12:35	47	22.0		
12:36	48	22.0		
12:37	49	21.0		
12:38	50	20.0		
12:39	51	20.0		
12:40	52	20.0		
12:41	53	20.0		
12:42	54	21.0		
12:43	55	21.0		
12:44	56	21.0		
12:45	57	21.0		
12:46	58	21.0		
12:47	59	21.0		
12:48	60	21.0		
12:49	61	21.0		
12:50	62	21.0		
12:51	63	21.0		
12:52	64	21.0		
12:53	65	21.0		
12:54	66	21.0		
12:55	67	21.0		
12:56	68	21.0		
12:57	69	21.0		
12:58	70	21.0		
12:59	71	21.0		
1:00	72	21.0		
1:01	73	21.0		
1:02	74	21.0		
1:03	75	21.0		
1:04	76	21.0		
1:05	77	21.0		
1:06	78	21.0		
1:07	79			
1:08	80			

DECLASSIFIED

TABLE 4

105-B RAW DATA, TRIPOFF TO LAST DITCH

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>High Tank Level</u>		<u>High Tank Strainer</u>		<u>Export</u>	<u>Export</u>
		<u>Feet of Water</u>		<u>ΔP, psig</u>		<u>Strainer</u>	<u>Orifice</u>
		<u>Near</u>	<u>Far</u>	<u>Near</u>	<u>Far</u>	<u>ΔP, psig</u>	<u>Press, psi</u>
11:48	0	32'0"	32'0"				
11:49	1	32'0"					
11:50	2	32'0"					
11:51	3	31'6"					
11:52	4	30'9"					
11:53	5	30'3"					
11:54	6	29'7"					
11:55	7	29'0"					
11:56	8	28'6"					
11:57	9	27'9"					
11:58	10	27'4"					
11:59	11	26'8.5"					
12:00	12	26'3"					
12:01	13	25'7.5"					
12:02	14	25'2"					
12:03	15	24'7.8"					
12:04	16	24'1.5"					
12:05	17	23'5.5"					
12:06	18	23'0"					
12:07	19	22'5.5"	22'10"			3	82
12:08	20	22'1"	22'4"	2.5	2.2	4	80.5
12:09	21	21'6.5"	21'11"	2.5	1.5	4	79.5
12:10	22	21'2"	21'6"	2.5	2.0	4	79.0
12:11	23	20'7.5"	21'0"	2.5	2.0	4	78.0
12:12	24	30'3"	20'6.5"	2.5	1.6	4	78.0
12:13	25	19'7.5"	20'1"	2.5	1.5		
12:14	26	19'3.5"	19'6.5"		2.0		
12:15	27	18'8"	19'1.5"	3.5	2.5		
12:16	28	18'3.5"	18'7.5"	3.5	2.0	0	151
12:17	29	17'8.5"	18'1"		1.7	0	198
12:18	30	17'3"	17'6.5"	3.0	1.7	0	170
12:19	31	16'8"	17'1.5"	3.0	1.7	0	181
12:20	32	16'3"	16'6.5"	3.0	1.7	0	185
12:21	33	15'8"	16'1.5"	3.0	1.8	0	187
12:22	34	15'2.5"	15'7"	3.0	1.8	0	187
12:23	35	14'8"	15'1"	3.0	1.8		
12:24	36	14'2"	14'7"	3.0	1.8		
12:25	37	13'9"	14'1.5"		0.5		
12:26	38	13'4"	13'8"		1.0		
12:27	39				2.2		
12:28	40					1.5	52.5

DECLASSIFIED

TABLE 4 (Continued)

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>Top-of-Riser Pressure, psig.</u>	<u>Bulk Outlet Temperature °C</u>	<u>Bulk Reactor Flow, Mgpm</u>	<u>High Tank Water Temperature, °C</u>	
					<u>Near</u>	<u>Far</u>
11:48	0	556	19.4	86.9	17	17.9
11:49	1	94				
11:50	2	42.5				
11:51	3	30				
11:52	4	22				
11:53	5	19.8				
11:54	6					
11:55	7					
11:56	8	19.3				
11:57	9	19.0				
11:58	10					
11:59	11	18.8				
12:00	12					
12:01	13					
12:02	14					
12:03	15					
12:04	16	18.1				
12:05	17					
12:06	18	18.0				
12:07	19	24.6	21.9			
12:08	20	24.4	22.1			
12:09	21		22.2			
12:10	22		22.1			
12:11	23	23.9	22.1			
12:12	24		22.2			
12:13	25		22.2			
12:14	26		22.2			
12:15	27	17.6	22.1			
12:16	28	17.4	22.0			
12:17	29		21.9			
12:18	30	17.3	21.9			
12:19	31	17.3	21.9			
12:20	32	17.2	21.9			
12:21	33	17.1	21.9			
12:22	34	17.1	21.9			
12:23	35	17.1	21.9			
12:24	36	22.0	21.9			
12:25	37	21.8	22.0			
12:26	38	21.8	22.2			17.5
12:27	39	19.6	22.2			
12:28	40	19.6	22.4			

DECLASSIFIED

TABLE 4 (Continued)

<u>Time of Day</u>	<u>Time After Trip, Min.</u>	<u>Export Strainer ΔP, psig</u>	<u>Export Orifice Pressure, psig</u>	<u>Top-of-Riser Pressure, psig</u>	<u>Bulk Outlet Temperature, °C</u>
12:29	41	3	75	20.6	22.2
12:30	42	3	69	21.6	22.2
12:31	43	3	69	21.6	22.6
12:32	44	3	70	21.6	22.6
12:33	45	3	70	21.6	22.5
12:34	46	4.5	63	10.6	22.5
12:35	47	4	64	9.6	22.5
12:36	48	4	64.5	9.4	22.5
12:37	49	4	65	9.4	23.0
12:38	50	4	65.5	9.3	23.2
12:39	51	4	65.5	9.3	23.7
12:40	52	4	66	9.3	24.0
12:41	53	4	66	9.3	24.4
12:42	54	4	66	9.3	24.6
12:43	55	4	66	9.3	24.9
12:44	56				
12:45	57				
12:46	58				
12:47	59				
12:48	60				
12:49	61				
12:50	62				
12:51	63				
12:52	64				
12:53	65				
12:54	66				
12:55	67			9.2	26.0
12:56	68	4	65		
12:57	69				
12:58	70				
12:59	71				
1:00	72				
1:01	73				
1:02	74			8.9	
1:03	75	4	56	8.7	26.8
1:04	76				27.1
1:05	77			9.0	27.3
1:06	78	4	58		27.6
1:07	79	4	57	8.7	27.8
1:08	80				

DECLASSIFIED

TABLE 5182-F AND H EXPORT STEAM PUMP SPEEDS
TRIP OFF TO LAST DITCH

<u>182-F</u>		<u>182-H</u>	
<u>Time, Min.</u>	<u>Pump Speed, RPM</u>	<u>Time, Min.</u>	<u>Pump Speed, RPM</u>
0	0	0	0
4	1745	4	1930
8	1738	8	1900
12	1738	12	1940
14	1738	16	1925
18	1734	20	1900
22	1725	24	1900
26	1721	28	1910
30	1725	32	1950
34	1725	36	1920
38	1715	40	1890
42	1721	44	1890
46	1724	48	1890
50	1725	52	1890
54	1724	56	1890
58	1724	60	1890
62	1724	64	1890
66	1718	65	1890
74	0		

DECLASSIFIED