AIIM

Association for Information and Image Management

1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910
301/587-8202

Centimeter

Inches

MANUFACTURED TO AIIM STANDARDS
BY APPLIED IMAGE, INC.

1 of 1

(CLASSIFICATION)

DECLASSIFIED

DOCUMENT NO.

HW-59056

SERIES AND COPY NO.

DATE

February 3, 1959

GENERAL ELECTRIC

HANFORD ATOMIC PRODUCTS OPERATION - RICHLAND, WASHINGTON

☒

RESTRICTED DATA

THIS DOCUMENT CONTAINS RESTRICTED DATA AS DEFINED BY THE ATOMIC ENERGY ACT OF 1954. ITS DISSEMINATION OR THE DISCLOSURE OF ITS CONTENTS IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PROHIBITED.

TITLE

PHYSICS EFFECTS OF WATER MIXING PIECES

☐

OTHER OFFICIAL CLASSIFIED INFORMATION

THIS MATERIAL CONTAINS INFORMATION AFFECTING THE NATIONAL DEFENSE OF THE UNITED STATES WITHIN THE MEANING OF THE ESPIONAGE LAWS, TITLE 18, U.S.C., SECS. 793 AND 794, THE TRANSMISSION OR REVELATION OF WHICH IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PROHIBITED BY LAW.

AUTHOR

G. R. PARKOS

RECEIVING FILE COPY
RECEIVED 1000 AREA

FEB 5 1959

RETURN TO

HANFORD TECHNICAL RECORD

TECHNICAL INFORMATION FILES

THIS DOCUMENT MUST BE LEFT UNATTENDED OR WHEN AN UNAUTHORIZED PERSON MAY HAVE ACCESS TO IT. WHEN NOT IN USE, IT MUST BE STORED IN A LOCKED REPOSITORY WITH AN APPROVED GUARDED AREA WHILE IT IS YOUR POSSESSION. UNTIL YOU HAVE OBTAINED A RECEIPT FROM CLASSIFIED FILES, IT IS YOUR RESPONSIBILITY TO KEEP IT AND ITS CONTENTS WITHIN THE LIMITS OF THIS OBJECT AND FROM ANY UNAUTHORIZED PERSON. IT IS PROHIBITED TO STORE IT AT YOUR PLACE OF RESIDENCE IS PROHIBITED. IT IS NOT TO BE REPRODUCED OR COPIED. IF ADDITIONAL COPIES ARE REQUIRED, OBTAIN THEM FROM THE ISSUING FILE. ALL PERSONS RECEIVING THIS DOCUMENT ARE REQUESTED TO SIGN IN THE SPACE PROVIDED BELOW.

ROUTE TO:

RAYROL NO.

LOCATION

FILES ROUTE DATE

SIGNATURE AND DATE

J. L. Benson

17843

1704K

2-23-59

Benson 2-23-59

E. E. Lutz

17847

1704K

OCT 19 1959

Lutz

S. M. Montague

17847

1704K

OCT 19 1959

Montague 7/19/61

J. F. JAKLEVICK

13751

105 DR

OCT 4 1959

Jaklevick

W. H. ASAN

14865

105 DR

OCT 4 1959

ASAN

COPY

Indefinite Retention

Disposal Date

Authority

Authority

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DECLASSIFIED

DECLASSIFIED

HW-59056

DISTRIBUTION

1. JL Benson	10. SL Nelson - TM Hall
2. RR Bloomstrand	11. GR Parkos
3. CE Bowers	12. RW Reid
4. RL Dickeman - R. Nilson	13. HG Spencer - RL Turner
5. EJ Filip - AP Vinther	14. RE Trumble - NR Miller -
FW VanWormer
6. FC Franklin	15. EC Wood - RE Hall
7. GC Fullmer	16. 300 File
8. RH Gay	17. Record Center
9. DE Goins	

RESTRICTED DATA

This document contains restricted data as defined in the Atomic Energy Act of 1954. The transmittal of the disclosure of its contents in any manner to an unauthorized person is prohibited.

Classification Cancelled and Changed To

DECLASSIFIED

By Authority of D S Lewis
CG-PR-2, 12-20-93By J E Savelly 1-6-94
Verified By J Mally, 1-21-94.

This document classified by

GC FullmerThis document consists of
9 pages. No. 1 of
17 copies. Series

February 3, 1959

PHYSICS EFFECTS OF WATER MIXING PIECES

INTRODUCTION

The effects of "water mixing" pieces on the axial flux distributions and reactivities of the K Reactors are discussed in this report. Two mixing piece configurations in the K piles are compared to provide a basis for determining the optimum configuration with respect to rupture control, reactivity cost and temperature cycling effects.

DECLASSIFIED

DECLASSIFIED

HW-59056
Page 2

SUMMARY AND CONCLUSIONS

The following chart summarizes the results of a study of the physics effects of water mixing pieces:

<u>Condition</u>	<u>Calculated Maximum Specific Power</u>	<u>Reactivity Effect</u>
No mixing pieces, current rod pattern	4% greater than the cosine maximum	--
One mixing piece per charge. Mixer located at pile center line, present rod pattern.	1% less than the cosine maximum	-112 ih
Two mixing pieces per charge. Mixers located at the outboard rod positions. Present rod pattern.	10% greater than the cosine maximum	-112 ih

No attempt is made to weigh the changes in pile stability and rupture potential associated with the changes in flux distribution.

DISCUSSION

Charging mixing pieces into the K Reactors is equivalent to introducing a slab(s) of water and aluminum lattice about 2.2 inches thick and perpendicular to the fuel channels. The effects of the mixing pieces on the flux distribution and reactivity will depend upon their number and locations. Two cases are considered here: (1) One mixing piece per charge. Mixer located at the pile center line. (2) Two mixing pieces per charge. Mixers located at the outboard rod position (~210 cm from the center line).

The method of evaluation used was developed by C. L. Miller for multi-region analyses. The reduction in lattice material buckling associated with the control rods and the mixing pieces is evaluated from the K pile start-up data. The effective buckling of a region is derived from:

$$(1) \quad B_1 = \frac{(B_n - B_c) \int_c \phi^2 dy + B_n \int_{\text{natural}} \phi^2 dy - B_{\text{mixers}} \int_{\text{mixers}} \phi^2 dy}{\int_{\text{Region}} \phi^2 dy}$$

$$(2) \quad b_1 = \sqrt{B_1 - B_{HW}}$$

B_1 = Buckling of i^{th} region

B_n = Natural uranium buckling

B_c = Buckling effect of controls

B_{mixers} = Buckling effect of mixers

B_{HW} = Horizontal and vertical buckling components = $(\pi/H)^2 + (\pi/W)^2 = 13.6 \mu b.$

DECLASSIFIED

DISCUSSION (Continued)

(2) H = Pile height, including augmentation distance.

W = Pile width, including augmentation distance.

The side-to-side and top-to-bottom flux distributions are assumed to be given by $\phi(x \text{ or } y) = \cos \frac{\pi(x \text{ or } y)}{(H \text{ or } W)}$. The axial flux distributions are given by: (From solutions of the expression $\nabla^2 \phi + b^2 \phi = 0$.)

(3) $\phi_1 = A_1 \sin(b_1 x + \alpha_1)$, or $\phi_1 = A_1 \cos(b_1 x + \alpha_1)$
 $b_1^2 > 0$.

(4) $\phi_1 = A_1 \sinh(|b_1| x + \alpha_1)$, or $\phi_1 = A_1 \cosh(|b_1| x + \alpha_1)$.
 $b_1^2 < 0$.

The following diagram and data are applicable to the conditions of interest.

DECLASSIFIED

HW-59056
Page 4

DISCUSSION (Continued)

$$\frac{\int_0^{P_1} \cos^2 \frac{\pi x}{H} dx}{\int_0^{H/2} \cos^2 \frac{\pi x}{H} dx} = 0.427$$

$$\frac{\int_0^{P_2} \cos^2 \frac{\pi x}{H} dx}{\int_0^{H/2} \cos^2 \frac{\pi x}{H} dx} = 0.757$$

$$\frac{\int_0^{P_3} \cos^2 \frac{\pi x}{H} dx}{\int_0^{H/2} \cos^2 \frac{\pi x}{H} dx} = 0.943$$

For the purposes of this evaluation the mixing pieces are assumed to be spread throughout the control regions. If the mixing pieces are located at the pile center line, they are assumed to be spread throughout region 1. If they are located at 210.8 cm, they are assumed to be spread throughout region 2.

The boundary conditions for a three-region problem are:

- (5) $\phi_1|_a = \phi_2|_a$
- (6) $\phi_2|_c = \phi_3|_c$
- (7) $\phi_1'|_a = \phi_2'|_a$
- (8) $\phi_2'|_c = \phi_3'|_c$
- (9) $\phi_1|_x = \phi_1|_{-x}$
- (10) $\phi_3|_{L/2} = 0$

These conditions result in the following expressions if $b_1^2, b_2^2, b_3^2 > 0$.

DECLASSIFIED

HW-59056

Page 5

DISCUSSION (Continued)

$$(11) - b_1 \tan b_1 a = b_2 \cot (b_2 a + \alpha_2)$$

$$(12) b_2 \cot (b_2 c + \alpha_2) = b_3 \cot \left[b_3 (c - L/2) \right]$$

$$(13) \cos b_1 a = A_2 \sin (b_2 a + \alpha_2)$$

$$(14) A_2 \sin (b_2 c + \alpha_2) = A_3 \sin \left[b_3 (c - L/2) \right]$$

For $b_1^2, b_3^2 > 0, b_2^2 < 0$, the expressions are:

$$(15) -b_1 \tan b_1 a = |b_2| \coth (|b_2| a + \alpha_2)$$

$$(16) |b_2| \coth (|b_2| c + \alpha_2) = b_3 \cot \left[b_3 (c - L/2) \right]$$

$$(17) \cos b_1 a = A_2 \sinh (|b_2| a + \alpha_2)$$

$$(18) A_2 \sinh (|b_2| c + \alpha_2) = A_3 \sin \left[b_3 (c - L/2) \right]$$

The method of solution of these expressions is as follows:

One of the B's is the unknown. Select a reasonable value and

(a) Compute the B_1 's and the b_1 's from equations 1 and 2.

(b) Substitute the b_1 's into equations 11 and 12, or 15 and 16. If 11 and 12 or 15 and 16 are satisfied then the B_1 's are the proper ones. If 11 and 12 or 15 and 16 are not satisfied, try different values of the unknown B. Continue this process until the conditions are satisfied.

(c) Once the proper B's and b's are determined, the constants may be determined from 13 and 14 or 17 and 18, and the fluxes computed from 3 and 4.

Since the flux distributions obtained above are normalized to $\phi = 1$ at $x = 0$, the areas (and hence the total power of tubes operating in these distributions) under the curves are different. The relative specific flux (power) is usually referred to a simple unperturbed flux distribution. Normalizing to the area under a cosine, relative specific power = $\phi(x) \frac{A'}{A}$.

$A' =$ Area under a cosine

$A =$ Area under the distribution of interest.

The normalized flux distributions calculated for the cases of interest are plotted in Figure 1.

CALCULATIONS AND RESULTS

A. The Effect of Mixing Pieces

$$\delta_{B_{\text{mixers}}} \int_{\text{mixers}} \phi^2 dA = \delta_{B_{\text{pile}}} \int_{\text{pile}} \phi^2 dA$$

$$\frac{\delta_{B_{\text{mixers}}}}{\delta_{B_{\text{pile}}}} = \frac{\int_{\text{pile}} \phi^2 dA}{\int_{\text{mixers}} \phi^2 dA} \approx \frac{R_p^2 J_1^2(2.40)}{R_m^2 \left[J_0^2 \left(\frac{2.40 R_m}{R_p} \right) + J_1^2 \left(\frac{2.40 R_m}{R_p} \right) \right]}$$

for a cylindrical pile.

δ_B = Change in material buckling

R_p = Effective pile radius

R_m = Effective radius of mixers

Since the mixers are 2.16 inches long, and extend the full height of the pile,

$$\frac{\text{Area of region}}{\text{Area of mixers}} = \frac{(140.5)(2)}{(2.54)(2.16)} \approx (2)(25.57) \text{ for mixers at the pile center line.}$$

$$\frac{\text{Area of region}}{\text{Area of mixers}} = 25.57 \text{ for mixers at the outboard rod positions.}$$

(In this evaluation the mixers are assumed to be spread uniformly throughout the control regions.) For the pile size used during the K-pile start-up tests*,

$$\frac{\delta_{B_{\text{mixers}}}}{\delta_{B_{\text{pile}}}} = 6.56 \text{ for mixers in region 1.}$$

$$\frac{\delta_{B_{\text{mixers}}}}{\delta_{B_{\text{pile}}}} = 12.76 \text{ for mixers in region 2.}$$

From the K-pile start-up test results:

Empty tube = -33.6 ih.

Wet SA = -22.1 ih.

If mixers are assumed to be half water and half SA,

Mixers $\approx$ -27.9 ih $\approx$ 1.368 μ b. ~~(-27.9 ih for SA)~~

Therefore, $\delta_{B_{\text{mixers}}} \approx (1.368)(6.56) \approx 9.0 \mu$ b for mixers at the pile center line,
and $\delta_{B_{\text{mixers}}} \approx (12.76)(1.368) \approx 17.4 \mu$ b for mixers at the outboard rod positions.

* HW-37158 PT 3, "K Pile Start-up Experiments Part III - Reactivity Effects of Fuel and Target Materials," C. L. Miller, 4-2-56.

CALCULATIONS AND RESULTS (Continued)

This is the reduction in lattice material buckling caused by mixing pieces charged with the densities indicated (51.14 and 25.57 LU² per mixer).

B. The Effect of Control Rods

The green, fully loaded K Reactors were held just sub-critical by about 18 HCR's (all rods except 6 and 15). $B_n = 61.5 \mu b$, $B_{HW} = 13.6 \mu b$. $B_c = 50.0 \mu b$ satisfies the appropriate conditions. Therefore, the reduction in lattice material buckling associated with the control rods is 50.0 μb .

C. No Mixers, Present Rod Pattern (2 and 19, 3 and 18, 10 and 11 in during equilibrium operation)

$$B_n = 34.0 \mu b \text{ satisfies the conditions}$$

$$b_1 = 3.96 \times 10^{-3}$$

$$b_2 = 1.23 \times 10^{-3}$$

$$b_3 = 4.52 \times 10^{-3}$$

$$\phi_1 = \cos 3.96 \times 10^{-3}x$$

$$\phi_2 = 1.91 \sin (1.23 \times 10^{-3}x - .63)$$

$$\phi_3 = -0.734 \sin [4.52 \times 10^{-3} (x-459)]$$

$$\frac{A'}{A} = 1.04$$

The calculated maximum flux is four per cent greater than the cosine maximum.

D. Mixers at the Pile Center Line (in Region 1), Present Rod Pattern

$$B_n = 39.5 \mu b$$

$$b_1 = 3.49 \times 10^{-3}$$

$$b_2 = 2.65 \times 10^{-3}$$

$$b_3 = 5.09 \times 10^{-3}$$

$$\Delta B_n = 5.5 \mu b \approx 2.93 \text{ mk} \approx 112 \text{ ih}$$

$$\phi_1 = \cos 3.49 \times 10^{-3}x$$

$$\phi_2 = -1.08 \sin (2.64 \times 10^{-3}x - 1.33)$$

$$\phi_3 = -0.743 \sin [5.09 \times 10^{-3} (x-459)]$$

$$\frac{A'}{A} = 0.99$$

DECLASSIFIED

HW-59056
Page 8

CALCULATIONS AND RESULTS (Continued)

The calculated maximum flux is one per cent less than the cosine maximum.

E. Mixers at the Outboard Rod Positions (Region 2), Present Rod Pattern

$$B_n = 39.5 \mu b$$

$$b_1 = 4.60 \times 10^{-3}$$

$$b_2 = 3.23 \times 10^{-3}$$

$$b_3 = 5.09 \times 10^{-3}$$

$$\Delta B_n = 5.5 \mu b \approx 2.93 \text{ mk} \approx 112 \text{ ih}$$

$$\phi_1 = \cos 4.60 \times 10^{-3}x$$

$$\phi_2 = -0.332 \sinh (3.23 \times 10^{-3}x - 2.06)$$

$$\phi_3 = -0.598 \sin [5.09 \times 10^{-3}(x-459)]$$

$$\frac{A'}{A} = 1.10$$

The calculated maximum flux is 10% greater than the cosine maximum.

G. R. Parkos

Operational Physics Operation
Research and Engineering
IRRADIATION PROCESSING DEPARTMENT

GR Parkos:mwe

Figure I

SPECIFIC POWER PROFILES FOR VARIOUS MIXING PIECE CONFIGURATIONS

DECLASSIFIED

**DATE
FILMED**

10/20/94

END