Analysis and Design of a High-Current, High-Voltage Accurate Power Supply for the APS Storage Ring*

M. Fathizadeh
Argonne National Laboratory
9700 South Cass Avenue, Argonne, IL 60439

Abstract

There are 81 dipole magnets contained in the storage ring at the Advanced Photon Source (APS). These magnets are connected in series and are energized by only one 12-phase power supply. The eighty-first magnet is located in a temperature-controlled room with an NMR probe to monitor the magnetic field in the magnet and provide a reference signal for correction of the field drift due to aging of the components. The current in the magnets will be held at 497 A. The required current stability of the power supply is ± 30 ppm, the current reproducibility is ± 50 ppm, and the current ripple is ± 400 ppm. The voltage required to maintain such a current in the magnets is about 1700 V. Different schemes for regulating current in the magnets are studied. Pspice software is used to simulate the behavior and the design of such a power supply under different conditions. The pros and cons of each scheme will be given and the proper power and regulating scheme will be selected.

I. INTRODUCTION

The storage ring of the Advance Photon Source (APS) at Argonne National Laboratory (ANL) contains 81 dipole magnets. These magnets are connected in series and fed by a 12-phase accurate and stable power supply. In order to provide a stable reference for the power supply, a 17-bit digital-to-analog converter (DAC) is programmed by the control computer. The 81st magnet is placed in a temperature-controlled room with an NMR probe to monitor the magnetic field in the magnet and provide the correction signal due to the aging of the components. The correction signal is sent to the DAC to modify the reference signal. The power supply is equipped with a passive L-C-R filter to reduce the ripple content of the output current. To regulate the current in the magnet, a high precision, low drift, zero flux current transducer is used. The transducer senses the magnet current and provides the controlling signals through the regulator. Several control loops are used to regulate the current in the magnet load. Fast correction for the line transient is provided by a relatively fast response voltage loop controlled by a high gain slow response current loop. Different design topologies are studied and will be given in the following.

II. POWER SUPPLY SPECIFICATION

The power supply must deliver 497 A continuously to a chain of 81 dipole magnets. The output voltage at full load operation is 1662 V [1].

*Work supported by U.S. Department of Energy, Office of Basic Energy Sciences under Contract No. W-31-109-ENG-38.

REGULATION ($\Delta I/I_{max}$)

Stability	$\pm 30 \times 10^{-6}$
Reproducibility	$\pm 50 \times 10^{-6}$
Current Ripple	$\pm 400 \times 10^{-6}$
Tracking Error	$\pm 100 \times 10^{-6}$

III. DESIGN AND TOPOLOGY

In order to provide current to the magnets, several types of power supplies are used. Phase-controlled thyristor rectifiers and switched-mode power supplies (SMPS) are the most common types used to energize the magnets. In phase-controlled power supplies a low pass filter is used to somewhat filter the ripple current. The accuracy and the response of the output current depends on the number of silicon-controlled rectifiers (SCRs) used in the power bridge and the low-pass filter frequency response. Due to the imperfection and imbalance in the power transformers, the output current may contain ripple content with the line frequency. Several techniques have been suggested in the past [2] and currently being employed to regulate the output current. To compensate for the load disturbance and ripple in the output current, active filters such as transistor banks or coupled reactors are used. The use of transistor banks means an inherent reduction in the output voltage and, consequently, lower efficiency. Use of coupled reactors can reduce the output current ripple, but reduces the tracking speed of the power supply.

The SMPSs, however, are highly efficient, quick to respond, and introduce high frequency ripple in the output current that can be filtered more easily than the low frequency ripples in the phase-controlled cases. On the other hand, the switched-mode power supplies can cause a high electromagnetic interference (EMI) due to their high di/dt and dv/dt [3]. In some cases, EMI filtering may be required to avoid perturbations to other equipment next to the power supply or the power line [4].

Another technique uses the phase-controlled and switched-mode power supplies in series combination. Usually the phase-controlled section delivers 90% to 95% of the output power and the SMPS delivers the rest. The 5% to 10% of the output which is delivered by the SMPS is required for the regulation. Phase-controlled power supplies have limited bandwidth depending on the number of the SCRs used in the power bridges. For instance, in a 12-pulse phase-controlled power supply the bandwidth is limited to 720 Hz while the switched-mode power supply can have very large bandwidth up to 500 kHz. The utilization of the SMPS allows fast and precise correction of the output current.

MASTER

The submitted manuscript has been authored by a contractor of the U.S. Government under contract No. W-31-109-ENG-38. Accordingly, the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or allow others to do so, for U.S. Government purposes.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

A second alternative to the above design is the use of switched-mode power supply in conjunction with the phase-controlled power supply. The phase-controlled part delivers the main power and the switched-mode part performs the regulation and the fine tuning of the output current. The switched-mode power supplies have a relatively larger bandwidth than the phase-controlled ones, thus the correction of the current is fast and a low ripple current can be obtained easily. For this scheme, usually about 10% of the output voltage must be delivered by the SMPS and the other 90% is delivered via the phase-controlled power supply. The switched-mode power supply must carry the output current which is a drawback of this scheme. The instantaneous output voltage of the total power supply is used to determine the transistor switching, while the output voltage of the SMPS is used to determine the firing angle of the thyristors. Since the output voltage of the SMPS is compared against a fixed voltage reference, the SMPS always maintains a certain portion of the output voltage. This configuration is shown in Figure 2. The switching transistor in the SMPS must be protected against the di/dt and dv/dt due to the output filter and the magnetic load. The SMPS in Figure 2 is fed from bridge rectifier with a typical R-L-C filter. The filter characteristic may cause oscillation in conjunction with the SMPS and its load. The filter is usually designed to be near critically damped to improve the overall efficiency. The R-L-C filter can give rise to low frequency oscillations at its output when it is subject to periodic load changes, e.g. when supplying power to an SMPS. In order to avoid such a problem, the inductance in the R-L-C filter must be reduced and the R and C increased [5].

Figure 2 Block diagram for storage ring power supply using phase-controlled and switched-mode power supply

V. CONCLUSION

Different configurations for the power supply of the storage ring dipole magnets were studied. In order to eliminate the output current ripple, an active filter was needed. Use of a pass transistor as the active filter was investigated and it was concluded that complicated control circuitries are needed to make such a scheme work. It was also concluded that under high output voltage, the pass transistor may fail. A prototype was built to investigate the operation of such a configuration, and the results indicate almost one order magnitude better performance than the required regulation.

The use of SMPS in conjunction with phase-controlled power supply was also investigated and the required control loops were shown. The SMPS may cause oscillation when the output filter inductance is relatively high. The switching transistor must be protected against di/dt and dv/dt due to the output filter and load inductances.

VI. REFERENCES

- [1] Advanced Photon Source Design Handbook Vol. II, Dec. 1989.
- [2] W. F. Praeg, "A high-current low pass filter for magnet power supplies," *IEEE Trans. Industrial Electronics and Control Instrumentation*, Vol. IECI-17, No.1, pp. 16-22, Feb. 1970.
- [3] N. Mohan, T. M. Underland, and W. P. Robinson, *Power Electronics Converters. Application and Design*. (New York: John Wiley & Sons, Inc. 1987).

- [4] J. A. Pomilo, D. Wisnivesky, and A. C. Lira, "A Novel Topology for the Bending Magnets Power Supply at LNLS," *IEEE Trans. on Nuclear Science*, Vol. 39, No. 5, pp. 1506-1511, Oct. 1992.
- [5] M. Fathizadeh, O. D. Despe, D. G. McGhee, "Analysis and Correction of Noise on Electronic Circuits in an Accelerator Environment," *Nuclear Science Symposium and Medical Imaging Conference*, Orlando, Florida, 1992.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

END

DATE
FILMED
10/5/93