June 1992

DE92 018704

INTEGRAL FAST REACTOR PROGRAM
ANNUAL PROGRESS REPORT
FY 1991

Argonne National Laboratory
9700 South Cass Avenue
Argonne, IL 60439

Y. I. Chang	General Manager, IFR Program
L. C. Walters	Director, Fuels and Processing Division
J. E. Battles	Associate Director, Chemical Technology Division
D. R. Pedersen	Associate Director, Reactor Engineering Division
D. C. Wade	Director, Reactor Analysis Division
M. J. Lineberry	Director, Fuel Cycle Facility Division

IFR TECHNICAL MEMORANDUM NO. 169

Results reported in the IFR-TM series of memoranda frequently are preliminary and subject to revision. Consequently they should not be quoted or referenced.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT.....	xi
I. IFR PROGRAM OVERVIEW.....	1
II. METAL FUEL PERFORMANCE.....	4
A. Irradiation Experience with HT9-clad Metallic Fuel.....	4
1. Introduction.....	4
2. Experimental Results.....	5
a. X425.....	5
b. X447.....	6
c. X441.....	6
3. LIFE-METAL Fuel Performance Code Modeling.....	8
a. X425 Modeling.....	8
b. X441 Modeling.....	10
4. Conclusions.....	11
B. Development of the Metallic Fuels Database.....	11
1. Need for a Database.....	11
2. Status of the Database.....	12
3. Database Architecture and Tables.....	13
4. Computer Software and Hardware.....	16
C. Characterizing and Monitoring Metallic Fuel Breaches.....	17
1. Fission-Gas Release Modes.....	17
2. Fission Gas Transport in EBR-II.....	18
3. Typical Fission Gas Release Signatures.....	21
4. Conclusions.....	24
D. Closure Welding of Oxide-Dispersion Strengthened Ferritic Cladding.....	24
1. Introduction.....	24
2. Weld Process Development.....	24
3. Weld Characterization.....	27
E. Postirradiation Test Results of the Zirconium-sheathed Fuel Testing.....	30
1. Introduction.....	30
2. Description of Experiment.....	30
3. Postirradiation Examination.....	33
a. Neutron Radiograph Examination.....	33
b. Contact Profilometry.....	33

TABLE OF CONTENTS (Contd.)

	<u>Page</u>
c. Gamma Scan.....	34
d. Fission Gas Analysis.....	34
4. Metallographic Examination.....	35
5. Discussion.....	38
6. Conclusions.....	40
References for Section II.....	41
III. PYROMETALLURGICAL PROCESS DEVELOPMENT.....	43
A. Process Flowsheet and Chemistry Studies.....	43
B. Process Development Studies.....	46
1. Zirconium Behavior Studies.....	46
2. Laboratory-Scale Electrorefiner.....	47
C. Engineering-Scale Process Development.....	49
1. Dissolution of Spent Fuel.....	49
2. Electrotransport to Solid Cathode.....	50
3. Electrotransport to Liquid Cadmium Cathode.....	51
4. Cover-Gas Treatment System.....	52
5. Equipment Testing.....	54
6. Zirconium Behavior in the Engineering-Scale Electrorefiner.....	54
D. Waste Treatment Processes.....	58
1. Salt Extraction.....	60
2. Salt Stripping.....	61
3. Salt Immobilization.....	62
a. Leach Resistance.....	63
b. Radiation and Thermal Stability.....	64
c. Alternative Salt Waste Forms.....	64
4. Metal Waste Handling.....	65
5. Waste Form Assessment.....	66
References for Section III.....	67
IV. SAFETY EXPERIMENTS AND ANALYSES.....	68
A. Lessons from the PRA for EBR-II.....	68
B. Passive Safety Characteristics of Low Sodium-Void-Worth Core Designs.....	73

TABLE OF CONTENTS (Contd.)

	<u>Page</u>
1. Unprotected Loss-of-Flow Results.....	73
2. Unprotected Transient Overpower Results.....	75
3. Unprotected Loss-of-Heat-Sink Results.....	76
4. Conclusions.....	77
C. Implications of Whole-pin Furnace Test Results on the EBR-II Mk-V Fuel Safety Case.....	77
1. Mk-V Fuel Design.....	78
2. Bounding Design Basis Transients.....	78
3. Whole Pin Furnace System.....	80
4. IFR Fuel Pin Behavior Codes.....	80
5. Description of Tests FM-4 and FM-5.....	81
6. Preliminary Results from Tests FM-4 and FM-5.....	83
7. LIFE-METAL and FPIN2 Calculations for Tests FM-4 and FM-5.....	84
a. LIFE-METAL Pretest Analysis of FM-4.....	84
b. FPIN2 Pretest Analysis of FM-4.....	85
c. FPIN2 Analysis of FM-5.....	86
D. Fuel Cycle Facility Safety Analysis.....	87
1. Safety Aspects of FCF Design.....	87
2. Analysis of Abnormal Events.....	90
a. Accident Analysis.....	91
b. Results.....	103
E. Tomographic Reconstruction-Nondestructive Examination of TREAT Experiments.....	106
1. Computed Tomography Technique.....	107
a. Neutron Radiography and Digitization.....	107
b. Reconstruction Technique.....	109
2. Example: Results from TREAT Test L07.....	110
3. Summary and Future Work.....	111
References for Section IV.....	112
V. CORE DESIGN DEVELOPMENT.....	115
A. Low Sodium Void Worth and Transuranic Burner Core Designs...	115
1. Design of Transuranic Burner Core.....	116
2. Design of Transuranic Self-Sufficient Core which Is Interchangeable with the Transuranic Burner Design.....	120

TABLE OF CONTENTS
(Contd.)

	<u>Page</u>
3. Summary and Conclusions.....	122
B. Basis for Assembly and Pin Designs for the EBR-II Mk-V Driver.....	122
References for Section V.....	126
VI. FUEL CYCLE DEMONSTRATION.....	127
A. Status of Facility Modifications.....	127
B. Status of Process Equipment Design and Fabrication.....	132
1. Fuel Element Chopper.....	132
2. Electrorefiner.....	134
3. Cathode Processor.....	135
4. Injection Casting Furnace.....	137
5. Fuel Pin Processor.....	138
6. Vertical Assembler/Disassembler.....	138
7. Other Process Equipment.....	139
C. Waste Handling and Processing.....	140
D. Process Control and Accountability.....	140
E. Preparations for Start of Operations.....	143
VII. LIQUID METAL REACTOR TECHNOLOGY RESEARCH AND DEVELOPMENT.....	144
A. Seismic Isolation.....	144
1. Furon Bearings.....	144
2. LTV Bearings.....	146
3. Rubber Consultants Bearings.....	149
4. Conclusions.....	150
B. Electromagnetic Pump Development.....	151
References for Section VII.....	157
VIII. LIST OF PUBLICATIONS.....	158

LIST OF FIGURES

	<u>Page</u>
II.1. Measured and Predicted Cladding Diametral Profiles of X425 Elements.....	9
II.2. Measured and Predicted Peak Cladding Diametral Strain of X425 Elements.....	9
II.3. Measured and Predicted Peak Cladding Diametral Strain in X441 Elements as a Function of Smear Density and Exposure Time.....	10
II.4. Hierarchy of Linked Database Tables.....	14
II.5. Corrected Kr-87 and Xe-133 Activities and Typical R/B Behavior Before and After Upper Weld (Plenum) Failure - July 1988.....	21
II.6. Typical R/B Data Sets for Plenum and Fuel Column Metal Fuel Breaches.....	22
II.7. Corrected Kr-87 and Xe-133 Activities and Typical R/B Behavior During RBCB Operation of Metal Fuel-Column Breach (X-482B) - August 1990.....	23
II.8. Cross Sectional Drawings of Transgun Models XCLTG-9608-5 (Top) and #CLTG-9636-15 (Bottom) Used for ODS Cladding Welding.....	25
II.9. Schematic of Configuration Used for ODS Cladding Welding...	26
II.10. Results of Finite Element Modeling of ODS Welding.....	27
II.11. Photomicrographs of Resistance Butt Welded ODS Cladding (MA957 Alloy) to HT-9 End Plug.....	28
II.12. Transverse Section of Zr-sheathed U-20.5Pu-3Zr of Pin K025 at X/L = 0.78.....	35
II.13. Longitudinal Section of Zr-sheathed U-20.5Pu-3Zr K025 Pin at X/L = 0.50.....	36
II.14. Longitudinal Section of Zr-sheathed U-20.5Pu-3Zr K025 Pin at X = 1.0.....	37
III.1. Distribution Coefficients of Selected Elements as a Function of Oxidation State.....	45
III.2. Cut Section of Product Ingot Showing Cd ₂ Zr on Top of Cadmium.....	48
III.3. Typical Deposit Obtained with Zirconium.....	48
III.4. Configuration of Liquid Cadmium Cathode in Engineering-scale Electrorefiner.....	51
III.5. Side View of Harvested Uranium Deposit.....	55
III.6. Samples Taken from Deposits on Components Immersed in Engineering-scale Electrorefiner.....	56
III.7. Corrosion Sample from Engineering-scale Electrorefiner with Adhering Salt, Uranium, Cadmium, and Zirconium.....	57

LIST OF FIGURES
(Contd.)

	<u>Page</u>
III.8. Reference Flowsheet for Treatment Salt and Metal Waste Streams in the IFR Pyroprocess.....	60
IV.1. Simple Generic LMR Event Tree.....	69
IV.2. Power, Flow, Reactivities, and Core Temperatures as a Result of a ULOF Accident in a Low Sodium-Void-Worth Actinide Burner Using Metallic Fuel.....	74
IV.3. Comparison of the Measured Temperature at the Top of the Fuel in the FM-5 Test with the UN-1 Peak Cladding Temperature History.....	82
IV.4. Schematic of Safety Exhaust System.....	88
IV.5. Schematic of Argon Cell Confinement Boundary and Potential Breaches.....	92
IV.6. Heavy Metal Consumed Following Design Basis Earthquake.....	97
IV.7. CT Reconstruction of Axial Slice through the L07 Test Assembly.....	111
V.1. Low Void Worth Actinide Burner Core Layout.....	118
VI.1. Fuel Cycle Facility Safety Equipment Building.....	127
VI.2. Installation of a Diesel Generator into the Safety Equipment Building.....	128
VI.3. Biologically-shielded and Unshielded Equipment Remote Repair Glovewalls of the New FCF Basement Hot-Repair Facility.....	129
VI.4. FCF Personnel Suited-entry Repair Area in New Basement Hot-Repair Facility.....	130
VI.5. FCF Equipment Decontamination Spray Chamber, Interior View Looking Outward Toward Chamber Remote Operating Station.....	131
VI.6. Element Chopper Prior to Installation in the FCF.....	
VI.7. FCF Remote Electrorefiner (basic structure).....	135
VI.8. FCF Remote Electrorefiner (partial assembly).....	135
VI.9. Cathode Processors Mounted on Support Stands.....	136
VI.10. Cathode Processor Internals.....	136
VI.11. Casting Furnace During Initial Qualification Testing.....	137
VI.12. Pin Processor During Checkout.....	138
VI.13. FCF Remote Fuel-element Closure Welding System.....	139
VI.14. FCF Process Control System.....	141
VII.1. Ovens for Testing Bar Samples and Pump Coils.....	153
VII.2. EM Pump Stator Segment Test Article.....	154

LIST OF TABLES

	<u>Page</u>
II.1. Design Data for the X425, X441, X447 HT9-clad Elements.....	5
II.2. Summary of X441 Cladding Strain Data.....	7
II.3. Typical Database Table Format.....	15
II.4. Burst Test Results for ODS Weld Sample Tubing.....	29
II.5. Nominal Design Parameters for Zr-sheathed Fuel Irradiation Experiments.....	32
II.6. Ranges of Peak Centerline and Peak Inner Clad Temperatures for Zr-sheathed Fuel Irradiation Experiment.....	32
II.7. Summary of Axial Growth Results for Zr-sheathed and Standard-cast Elements.....	33
II.8. Gas Release Characteristics for Zr-sheathed and Standard-cast Elements.....	34
III.1. Results from Electrotransport to Single-Mandrel Solid Cathodes.....	50
III.2. Zirconium and Uranium Content of Filtered Cadmium Samples....	58
IV.1. Comparison of As-Fabricated Fuel Pin Parameters and Burnup.....	79
IV.2. Comparison of LIFE-METAL and FPIN2 Calculations with the Preliminary Results from WPF Tests FM-4 and FM-5.....	84
IV.3. Heavy Metal and Pu Burning Following DBE.....	94
IV.4. Heavy Metal and Pu Mass Burned in Critical Burn Time.....	98
IV.5. Radionuclides in Waste Can and Committed Effective Dose Equivalents.....	100
IV.6. Atmospheric Dispersion Parameters for FCF Accident Assessments.....	104
IV.7. Source-Reduction Factors for Releases from Fires.....	105
IV.8. Fuel Cycle Facility Radiological Dose Consequence Guidelines.....	106
IV.9. Summary of Design Basis Accidents and Consequences.....	108
V.1. Comparison of Calculated Performance Characteristics for Low Void Worth Interchangeable Burner and Breeder Designs.....	119
V.2. Design Criteria for Mk-V Fuel (HT9 Clad).....	125
VII.1. Accelerated Aging Tests with Small Bar Samples.....	155
VII.2. High Temperature and Voltage Tests on Full-size Coils.....	156

INTEGRAL FAST REACTOR
ANNUAL PROGRESS REPORT
FY 1992

ABSTRACT

This report summarizes highlights of the technical progress made in the Integral Fast Reactor (IFR) Program in FY 1991. Technical accomplishments are presented in the following areas of the IFR technology development activities: (1) metal fuel performance, (2) pyroprocess development, (3) safety experiments and analyses, (4) core design development, (5) fuel cycle demonstration, and (6) LMR technology R&D.

I. IFR PROGRAM OVERVIEW

The Integral Fast Reactor (IFR) development covers the entire reactor system, not only the reactor itself, but also its fuel cycle, both fuel refining and fabrication, and waste management as well. The goal is to develop a reactor system that answers the questions facing the next generation of nuclear power plants with respect to economics, safety, and waste disposal. The program emphasis has shifted each year as the development has proceeded.

Initially, the focus was placed on demonstration of passive safety characteristics. The loss-of-flow without scram and loss-of-heat-sink without scram tests at EBR-II were a spectacular demonstration of the inherent passive safety potential of the IFR concept. The emphasis then shifted to development of a fuel performance and pyroprocessing technology database, and rapid progress has been made during the past two years.

The high burnup potential of the new IFR fuel alloys has been demonstrated. EBR-II is now fully converted with the IFR fuel alloys and statistically significant fuel performance data are being generated. A new whole-pin furnace experimental facility allowed in-depth evaluation of fuel failure mechanisms over a broad range of temperatures and transient conditions to establish the safety database required for licensing. Electrorefining experiments to develop a key element in fuel cycle closure are now routinely carried out on a 10-kg engineering scale. Anodic dissolution was successfully demonstrated, speeding dissolution, which had previously slowed the production rates in the IFR pyroprocesses.

The focus is now on the demonstration of the entire IFR fuel cycle. The next key milestone is to complete the refurbishment of the original EBR-II Fuel Cycle Facility. All environmental permit processes have been successfully completed. Rapid progress is being made on the facility modifications as well as the fabrication of process equipment modules.

The IFR Program has now entered the demonstration phase, with priority on the following tasks:

- Completion of Fuel Cycle Facility refurbishment and subsequent operation for prototype demonstration of the entire IFR fuel cycle.
- Conceptual design of a commercial-scale fuel cycle facility.
- Development of waste processing technology and initiation of the NRC high-level waste certification process.
- Fuel performance demonstration of recycled IFR fuel alloys up to 15% burnup.
- Development of safety licensing database and demonstration tests at EBR-II, as required.

The University of Chicago Special Advisory Committee for the IFR continues to be enthusiastic about the potential of the IFR and is highly impressed with the technical progress as indicated by the following excerpts from the executive summary of the Committee report:

"The Committee continues to be very impressed with the progress in the IFR (Integral Fast Reactor) development program."... "We believe the IFR should be elevated from an interesting and promising concept to a definite and very important part of the U.S. long-term strategy for supplying an ever-increasing demand for electricity; we reaffirm that belief. We recommend the design and initiation of construction of a demonstration IFR plant within this decade. This first plant, with government subsidies as necessary, should be followed at appropriate intervals by other demonstration plants, each plant benefitting from what was learned in preceding plants and involving progressively more private utility involvement. A further objective should be to have a standardized, and certified, design available for commercial exploitation on a broad scale a few decades from now in the U.S. and throughout the world."

"The potential advantages of the IFR visualized in past years continue coming closer to reality. These include enhanced safety; proven, very high fuel burnup; proliferation resistance; reduced waste-disposal problems; an integral, self-contained, and potentially lower-cost fuel cycle; and a nearly inexhaustible supply of fuel. This Committee sees little likelihood that any serious technical problems will emerge that would eliminate the IFR as the front-runner for supplying nuclear electricity when light water reactors become uneconomic as a result of finite uranium supplies. The Committee believes the cost of developing the IFR to a state of readiness is small compared to the benefits of having an assured, uninterrupted supply of electricity at predictable cost."

"The Committee believes it is timely to initiate steps towards international collaboration and joint funding of the demonstration plants discussed above. Such a program, including the relevant R&D and component development, will require substantial financial resources."

II. METAL FUEL PERFORMANCE

A. Irradiation Experience with HT9-clad Metallic Fuel

1. Introduction

Since February 1986, a series of experiments have been carried out in the EBR-II reactor to obtain performance data relevant to HT9-clad U-Pu-Zr fuel. Tests of D9-clad U-Pu-Zr fuel were run in parallel and their good performance characteristics have recently been reported.¹ In February 1986 the lead experiment, X425, was initiated. The objective of this test was to obtain scoping data which could be compared directly to the lead D9-clad experiments initiated one year earlier.

In November of 1987, two follow-on tests were initiated. The X447 test was designed to verify the high temperature stress rupture capabilities of HT9 cladding with metallic fuel and was orificed to operate at a peak inside cladding temperature (PICT) of 660°C at beginning-of-life (BOL). This temperature is considered an extreme challenge to the creep rupture strength of the HT9 alloy and would be avoided for normal operation.² Binary fuel (U-10Zr) was chosen because a binary metallic fuel core was at that time being pursued for the Fast Flux Test Facility (FFTF) in Richland, WA.

To investigate the effects of individual design variables on integral pin performance, a design parameter test, X441, was conducted. In addition to control pins with nominal design features (i.e., U-19Pu-10Zr fuel, 75% smear density, and 1.5 plenum to fuel volume ratio), pins with 6 wt. % or 14 wt. % Zr fuel, 70% or 85% smear density and 1.1 to 2.1 plenum-to-fuel volume ratio were irradiated in the assembly.

Fuel designers are in the process of using the results from these lead experiments to support conversion of the EBR-II core from austenitic-clad U-10Zr fuel (Mk-III, -IIIA) produced in the "cold" fuel manufacturing facility to HT9-clad U-20Pu-10Zr fuel (Mk-V) which will be remotely manufactured in the "hot cells." The complete IFR fuel-cycle will eventually be demonstrated at the Idaho site by irradiating reprocessed Mk-V fuel to high burnup. The results

summarized herein are the first data reported on the steady-state behavior of HT9-clad U-Pu-Zr metallic fuel.

2. Experimental Results

Table II.1 is a summary of the operating and design parameters for the three experiments.

TABLE II.1. Design Data for the X425, X441, X447 HT9-clad Elements

	X425	X441	X447
Linear Power kW/m (Peak Core Midplane)	40	51	33
Peak Inside Cladding Temperature (~BOL)	590°C	600°C	660°C
Element Length, cm	63.8	74.9	74.9
Plenum Volume/Fuel Volume	~1.0	~1.1-2.1	~1.5
Clad Wall Thickness, mm	0.38	0.38	0.38
Clad Outer Diameter, mm	5.84	5.84	5.84
Fuel Alloy, wt. % (U-xPu-yZr)	x=0,8,19 y=10	X=19 y=6,10,14	X=0 y=10
Fuel Smeared Density, %	72	70,75,85	75

a. X425

Cladding integrity has been demonstrated in this subassembly to peak burnups exceeding 19.2 at. % with no cladding failures to date. It was found that fuel swelling and fission gas release behavior were consistent with the austenitic-clad fuel behavior reported previously.¹ However, cladding performance differences were significant at all burnups due to the absence of irradiation-swelling effects in the HT9 steel. Maximum diametral strains occurred near core midplane. Section 3.a below summarizes the spiral contact profilometry data obtained during interim exams. This test will be continued to its first breach or to the administrative burnup limit of 20 at. %.

b. X447

One interim postirradiation examination was completed at 4.7 at. % peak burnup. Cladding strain was negligible except at top-of-core where typical peak diametral strain was approximately 0.8%. Because fuel-cladding mechanical interaction is negligible at this smear density (75%) and burnup and cladding irradiation swelling is nil, the localized strain resulted from fission gas loading at this high temperature region of the pin.

Post-irradiation examinations of X447 elements at 10 at. % peak burnup is currently in progress. Fission-gas pressure data has been analyzed and shows about 75% release, with an estimated in-reactor plenum pressure of 6.5 MPa. Cladding strain behavior at 10 at.% peak burnup was found to be consistent with that at the lower burnup. Negligible strain was found in the fuel column below $X/Lo = 0.70$. The peak strain occurred at the top-of-core and averaged 1.6% in unbreached elements.

Two elements have breached in the X447 test at 9.5 at. % peak burnup. For the one breach where good fission gas signals were obtained, a delayed neutron (DN) signal spike was recorded that rose to 135 cps above background and returned to normal levels after 15 min. This is typical behavior for metallic fuel breach.³ The average strains measured at the breach sites are 1.6% and 4.1%, which fall in the range of normal failure strains for HT9. Destructive examinations of the breach sites are not yet underway, but a preliminary visual examination suggests that the crack opening is not great; this is consistent with the small delayed neutron spike.

c. X441

The X441 test was expressly designed to benchmark the fuel performance code LIFE-METAL. The X441 test was terminated at a peak burnup of 12.7 at. %. No cladding breaches had occurred. For each of the seven types of elements tested, only one design parameter was varied from the control (U-19Pu-10Zr, 75% SD, P/F=1.5) to provide unobscured results. Pin performance data collected during an interim reconstitution at 6 at. % and during the final examination showed excellent behavior of the HT9 cladding. Table II.2 summarizes

TABLE II.2. Summary of X441 Cladding Strain Data

% Smear Density	Fuel Alloy	Plenum/Fuel Ratio	% Diametral Clad Strain
75	U-19Pu-10Zr	1.1	0.32
75	U-19Pu-10Zr	1.5	0.28
75	U-19Pu-10Zr	2.1	0.17
75	U-19Pu-6Zr	1.5	0.27
75	U-19Pu-14Zr	1.5	0.25
70	U-19Pu-10Zr	1.5	0.22
85	U-19Pu-10Zr	1.3	1.66, 2.28

the observed maximum cladding strain measured with linear laser profilometry taken every 30° and averaged. The data in Table II.2 are from eight representative elements, all chosen from the inner rows of the 61-position bundle.

The end-of-life diametral cladding strain in all but the high smear density group was small (0.17% to 0.32%), indicating: (1) negligible fuel/cladding mechanical interaction and (2) adequate plenum volume to accommodate the fission gas at low pressure. The fact that even the small plenum pins exhibited negligible strain suggests the burnup potential of the control pins may be significantly greater than that attained in the experiment. While a small increase in strain was observed in going from 70% to 75% smear density, the 85% smear density fuel showed significant cladding strain, much of which was induced by fuel/cladding mechanical interaction. The zirconium content of the fuel had minimal effect on the mechanical behavior of the cladding; its effect on fuel/cladding chemical interaction is currently being determined. The planned core conversion of EBR-II to the Mk-V driver fuel now has a strong technical base, as design and operating parameters are very similar to that of the X441 control elements.

3. LIFE-METAL Fuel Performance Code Modeling

Paralleling the irradiation test program is the development of the LIFE-METAL code for the prediction of the nuclear, thermal, and mechanical performance of metallic fuel pins under normal steady-state reactor operating conditions. Good agreement between code calculations (particularly cladding strain) and postirradiation data has been obtained and reported for D9-clad metallic fuel.¹ The results of recent LIFE-METAL validation to the experimental HT9 data base provided by postirradiation examinations of the X425 and X441 elements are presented below. Particular emphasis has been placed on the modeling of cladding strain as a function of as-fabricated fuel smear density and burnup. This provides an indirect validation of the fuel mechanical property models and an assessment of the relative contributions of released fission gas and fuel mechanical loading of the cladding.

a. X425 Modeling

Figure II.1 shows the cladding diametral strain profiles measured by spiral contact profilometry on two U-19Pu-10Zr fuel elements from the X425 test at 15.5 at. % peak burnup (T473) and 15.9 at. % peak burnup (T470). Also shown is an average profile at 15.7 at.% burnup as predicted by the code. Good agreement with the data is obtained in the lower half of the fuel column, with an over-prediction above core midplane, where the dominant loading mechanism is fission gas pressure. This discrepancy is currently being investigated. Possible causes would be a flux profile that falls off more rapidly than is believed, an erroneously high prediction for plenum pressure, or HT9 creep correlations that are in error for these stress and temperature conditions.

The solid line in Fig. II.2 shows the predicted peak strains for the X425 test as a function of burnup. The code prediction agrees well with the (average) data obtained at the two burnup levels. The sharp rise in strain beyond 15 at. % burnup is due to the increase in solid fission product swelling of the fuel, which increases the fuel/cladding mechanical interaction. The curve shown was obtained with an assumed swelling factor of 1.68 volume %/% burnup due to solid fission products. Data taken at the termination of the X425 experiment will serve to validate this assumption.

Fig. II.1. Measured and Predicted Cladding Diametral Profiles of X425 Elements

Fig. II.2. Measured and Predicted Peak Cladding Diametral Strain of X425 Elements

b. X441 Modeling

The smear density variations in the X441 test are an ideal vehicle for validating the fuel/cladding mechanical interaction (FCMI) model in LIFE-METAL. Figure II.3 shows the predictions (lines) versus data (points) as a function of smear density for two different exposures (0.59 full power years and 1.25 full power years). The agreement is good for all of the low burnup data. However, for high burnup, the code overpredicts the strain in the 85% smear-density elements. Adjustments to the fuel swelling model or the fuel creep/ hot-pressing model could be attempted. However, any attempts to soften the fuel by increasing its creep rate would result in an increase in the axial growth value well above the measured expansion of only 1.3%. Future efforts will concentrate on improving the gaseous fission product swelling model to bring the code predictions into agreement for the whole range of smear densities and burnups investigated.

Fig. II.3. Measured and Predicted Peak Cladding Diametral Strain in X441 Elements as a Function of Smear Density and Exposure Time

4. Conclusions

HT9-clad metallic fuel shows excellent performance characteristics over a wide range of operational and design conditions. The reliability of future U-Pu-Zr cores in EBR-II and future advanced liquid metal reactors appears high. The LIFE-METAL code does well in predicting the cladding behavior for typical driver fuel conditions (i.e., 75% smear density) but needs improvement for high smear density applications.

B. Development of the Metallic Fuels Database

1. Need for a Database

Over the last decade a large amount of information has accumulated on the behavior of LMR metallic fuel elements⁴ and much more will accrue over the next 3-5 years. This fuels experience exists in a variety of media, formats and locations: from raw data on magnetic tape, radiographic film, photomicrographs, and tables of numbers stored on computer at one extreme, to fully interpreted data in circulated memoranda, conference proceedings, and refereed papers at the other extreme. Comparatively little of this information is readily retrievable and some raw data may soon deteriorate or be irretrievably lost. The IFR Technical Memoranda series and the Metal Fuels Handbook⁵ are, of course, sizeable repositories of this metal fuels information but even they contain only a small fraction of the total database.

As Mk-V fuel is fabricated, irradiated, examined, reprocessed and refabricated in FCF and EBR-II, new data will proliferate. As IFR licensing approaches, the need to review old data and to marshall new experience becomes paramount. Many data will be obtained electronically from existing apparatus or new equipment, like the gamma scanner and pin processor, or will already exist as input files to computer codes like REBUS-3 and MTG and need not be newly generated for other purposes. There is thus a clear need for an efficient information management tool, a relational database system, that can conveniently access all aspects of this experience, whether on fuel and cladding properties, fabrication data, reactor conditions and test results, reprocessing data, or simply bibliographies of published work.

At the most primitive level, information could simply be readings of mass and diameter from the pin processor workstation. At an intermediate level it might comprise tables of as-loaded fissile weights of a subassembly, i.e., partly processed data, which are used in reactor physics calculations. In its most advanced form it might appear as the output of LIFE-METAL or ORIGEN computer code runs; or as a fully critiqued correlation in an upgraded version of the Metal Fuels Handbook. The database must be set up in a way that assures security of the information while archiving it in a format which will be convenient for licensing.

2. Status of the Database

From July through September 1991, several meetings were held to discuss the specific applications for a metals fuels database (MFDB). Representatives from divisions in ANL East and West working in IFR fuels development attended. The concept was also reviewed and endorsed by the University of Chicago Special Advisory Committee for the IFR technical subcommittee on fuels performance. An integrated effort is upgrading the Metal Fuels Handbook, which is being incorporated into the MFDB. A primary concern is the way in which IFR data and data correlations will be critiqued before inclusion; methods used for similar compilations, e.g., the Nuclear Systems Materials Handbook, are being considered for use in the IFR context.

The specific applications for the MFDB were considered to be: (1) efficiently storing and accessing information for ANL experimenters and analysts, (2) sharing data with outside contractors, (3) helping to assure configuration control for FCF/EBR-II operations, and, most importantly (4) eventual licensing of IFR fuel. Some important concerns were: efficient use of available data and resources, data integrity and security, and traceability (QA) of records.

Also discussed were the categories of information to be stored in the MFDB. Categories include: (1) reactor conditions (e.g., run history); (2) subassembly/element data (e.g., design details and fissile contents); (3) irradiation history (e.g., dose/temperature, fission gas/delayed neutron data); (4) postirradiation examination (PIE) data (e.g., Nrad dimensions, gamma

scans, metallography results); (5) materials thermophysical properties (e.g., handbook data, LIFE-METAL input values); (6) IFR documentation (e.g., technical memoranda organized in a keyword search format); and (7) frequently used codes like LIFE-METAL.

Development of the database has progressed to the point of (a) completing the design of the database architecture and tables, (b) installing developmental computer hardware and software, and (c) outlining strategies for data transferral.

3. Database Architecture and Tables

Information stored in the MFDB will be of three types: (1) data which consist of numerical values or predefined text such as reactor startup date, (2) documents and reports which are a combination of graphs and text, and (3) conventional executable programs.

The first type of information will be stored in tabular form. This information type represents the bulk of the data because they are collected in real time. A three-tier, hierarchical and semantically-linked design has been selected for the organization of the tables, as shown in Fig. II.4. The table in the first level contains general information on a reactor run. It also contains the computer address of the files in which the real-time data such as 10-min interval fission gas activity from DAS are stored. In the second level, subassembly information is stored, classified into time-dependent and time-independent data. The third information level pertains to fuel elements in time-dependent and independent forms. Subassembly and element data were separated into time-dependent and -independent for conserving storage space.

A typical listing of items in one of the tables is given in Table II.3. This architecture is analogous to the one employed in the mass-tracking-system database used in FCF, thus assuring compatibility between the two. The only difference will be that the MFDB will include all PIE information. This architecture allows for expansion of the database by simply adding a column to the appropriate table or by introducing sublevels of information.

Fig. II.4. Hierarchy of Linked Database Tables

This hierarchical design is chosen because the general information (higher levels) are inquired about more frequently. To improve search efficiency, the entire database "knowledge space" can be represented as a "node-and-link" space where nodes represent data items and the links are relationships between the data items. For example, all information on the fuel-cladding compatibility can be linked. If the inquiry is "provide data on the compatibility studies between HT9 cladding and Mk-V fuel" then all of the nodes (data items) that are linked by the relationship "compatibility" will be presented to the user.

Hypermedia technology will be employed to incorporate the second type of information. Hypermedia refers to the use of multimedia presentations including hypertext, graphics, and videodisc data files. These are typically accessed through a user-friendly interface employing pull-down menus, mouse or key selection of "buttons," and help and information screens. Hypertext, which allows nonlinear reading (skipping around in a document) of a source, is appropriate for text-intensive user displays. Graphics and videodisc

presentations are needed to display information to the user in the form of graphs, pictures of materials samples, and other visual data.

TABLE II.3. Typical Database Table Format

Time Dependent Element Information Per Run
RUN ID
SUBASSEMBLY ID
PREVIOUS SUBASSEMBLY ID
INCREMENTAL IRRADIATION TIME
INCREMENTAL BURNUP
INCREMENTAL TIME
MIDPLANE POWER
U235 FISSION RATE
U238 FISSION RATE
PU239 FISSION RATE
TOTAL FISSION RATE
FISSION GAS PRODUCTION
CLAD HOOP STRESS
PEAK FUEL SURFACE TEMPERATURE
PEAK CENTERLINE TEMPERATURE
PEAK CLAD INNER DIAMETER
PEAK CLAD OUTER DIAMETER
EXIT COOLANT TEMPERATURE
PEAK EXIT COOLANT TEMPERATURES
TOTAL POWER
ELEMENT POSITION WITHIN SUBASSEMBLY
POSITION OF SUBASSEMBLY WITHIN CORE
ELEMENT ID
ISOTOPIC MASSES AT TIME T (calculated values; many columns)
BURNUP AT TIME T (column for each fissile isotope)
TAG GAS INFORMATION (several columns)
PEAK LINEAR HEAT RATE
MIDPLANE FLUX
INCREMENTAL FAST FLUENCE

The reason for including analytical computer codes such as LIFE-METAL as a part of the database, and not their output files, is the realization that data storage space can be traded against computational processing time: executing these codes with the same input file will give the required output, alleviating the need to store output files. A user interface for creating the input file of the codes will be developed to facilitate execution; such an interface is already developed for LIFE-METAL. Access to the user-interface of these computer codes and the codes themselves will be incorporated in the menu-driven mechanisms of the MFDB.

4. Computer Software and Hardware

The MFDB is being developed using Oracle,⁶ BMI Prolog, IXL, and DataViews software. Oracle is a relational database system that has already been successfully used for the EBR-II PRA. One of the main issues for the MFDB is data security. Security will be insured by a combination of passwords, user names, and login accounts. Information types will have a unique accessibility rank for different users, and only users with the appropriate permission to the inquired data item will be allowed to access the item.

BMI Prolog is being used to allow intelligent searching of the database, i.e., semantic-network representation of the knowledge base. DataViews is being used for graphical display. DataViews is commonly used to represent data that are generated in different engineering processes, a feature that aids eventual use of the MFDB to present real-time data for EBR-II and FCF. IXL is an automatic discovery system which analyzes large databases and discovers patterns, rules and often unexpected relationships. It uses statics and machine learning to generate procedures which characterize data, providing insight and understanding in a variety of fields.

The database is being developed for a network of Sun SparcStations with large storage capability. Final hardware is likely to include a SparcStation 2 at ANL-W and ANL-E, with scanner and high-quality printer attachments; such a configuration will allow data entry at both sites and will ensure systematic storage and retrieval of all PIE data, particularly metallographic information which otherwise is notoriously difficult to access.

C. Characterizing and Monitoring Metallic Fuel Breaches

Scoping tests have shown that artificially defected metallic fuel elements exhibit totally benign RBCB behavior and give characteristic delayed neutron and fission gas signals.³ Natural breaches and weld defects in lead IFR irradiations also appear to be benign events.⁷ The most recent phase of the RBCB program has involved a more thorough characterization of the fission gas release behavior with regard to breach type. This has involved analysis of archived fission-gas-activity data from EBR-II for the period 1986-1991. The goal of the work is to develop an on-line diagnostic tool as a quick and accurate means of determining exactly what type of and how many breaches are active in an IFR core at any given time.

1. Fission Gas Release Modes

Fission gas will be released from a breached element by one or more of three basic mechanisms: pressure-driven release of stored gas, diffusional release through the fuel structure, and recoil from the fuel surface. For the i -th radioactive gas species with decay constant λ_i , the release-to-birth ratio R_i/B_i for these mechanisms are given by the expressions:⁸

$$\frac{R_i}{B_i} = \lambda_i \left(\frac{1 - \exp(-\lambda_i t)}{\lambda_i} \right)$$

for stored gas release;

$$\frac{R_i}{B_i} = 3 \left(\frac{D_i}{\lambda_i a^2} \right)^{1/2}$$

for diffusional release; and

$$\frac{R_i}{B_i} = \frac{kSL_i d}{4W_j}$$

for direct recoil release, where:

- λ_e = Effective escape-rate coefficient, s^{-1} ,
 t = Irradiation time, s,
 D_i = Diffusion coefficient, cm^2/s ,
 a = Radius of the equivalent sphere of fuel, cm,
 k = Enhancement factor, dimensionless,
 S = Geometric defect area, cm^2 ,
 L_i = Recoil range of i -th species, cm,
 d = Effective escape-rate coefficient, s^{-1} , and
 W_j = Mass of fissile isotope j in breached element, g.

The dominant mode of gas release at any one time can then be identified by determining the slope of the $\log(R_i/B_i)$ versus $\log(\lambda_i)$: a slope of -1 will indicate release of stored gas; a slope of $-\frac{1}{2}$, diffusional release; and a slope of zero, recoil release. Gas release will seldom be entirely due to one mechanism.

2. Fission Gas Transport in EBR-II

The use of measured fission-gas isotope activities in the EBR-II cover gas for determining the mode of gas release from a breached element involves correction of release rate R_i for transport through the primary sodium, for disengagement from the sodium to the cover gas, and for operation of the cover-gas cleanup system. The treatment used was that of Nomura,⁹ which assumes ideal mixing of gas in primary sodium, gas disengagement from the sodium that is proportional to gas concentration, and that fission-product decay is adequately described by considering only parent, metastable daughter, and daughter species. For these assumptions the buildup of Xe and Kr isotopes is given by:

$$\begin{aligned}
 \frac{d[2]_{CG}}{dt} &= [2]_{Na}\lambda_d - [2]_{CG}(\lambda_2 + \lambda_L + \lambda_P) \\
 \frac{d[3]_{CG}}{dt} &= [3]_{Na}\lambda_d + f_{23}[2]_{CG}\lambda_2 - [3]_{CG}(\lambda_3 + \lambda_L + \lambda_P),
 \end{aligned}$$

where

[2] = number of metastable ^{85m}Kr , ^{88}Kr , ^{87}Kr , ^{135m}Xe and ^{138}Xe atoms,

[3] = number of ^{133}Xe and ^{135}Xe atoms,

λ_i = decay constant, s^{-1} ,

λ_d = disengagement-rate constant, s^{-1} ,

λ_L = cover-gas-leak-rate constant, s^{-1} ,

λ_p = cover-gas-purge-rate constant, s^{-1} ,

[]_{Na} = sodium phase,

[]_{CG} = argon-cover-gas phase, and

f_{23} = branching fraction.

In these equations, cold trapping of iodine and bromine parents and holdup of fission gas in the sodium, cover-gas leakage, and the effects of CGCS operation are accounted for by the constants, λ_d , λ_L , and λ_p , respectively. The values of $([2]_{\text{Na}}\lambda_d)$ and $([3]_{\text{Na}}\lambda_d + f_{23}[2]_{\text{CG}}\lambda_2)$ are the isotope-production terms, denoted as P_j . By assuming a linear approximation for an appropriate time interval during CGCS operation, the P_j values can be calculated by:

$$P_j = \frac{dC}{dt} + C_j(\lambda_i + \lambda_L + \lambda_p),$$

where

dt = time interval between t_j and t_{j+1} , s ,

dC = activity difference of gas isotope i at the time interval dt , i.e., $C_{j+1} - C_j$,

C_j = measured value of activity at t_j , nCi/mL ,

λ_i = decay constant of gas isotope i , s^{-1} .

The equation for no CGCS operation can similarly be derived by excluding the term λ_p :

$$\frac{dC^*}{dt} = P_j - C^*(\lambda_i + \lambda_L)$$

where

dC^* = activity difference of gas isotope i at the time interval dt for no purging, i.e., $C_{j+1}^* - C_j^*$.

The release rate R_i of the i -th isotope is then given by:

$$R_i = 37 V \left(\frac{1}{\lambda_i} \frac{dC_i^*}{dt} + C_i^* \frac{\lambda_i + \lambda_L}{\lambda_i} \right) \left(\frac{\lambda_i + \lambda_d}{\lambda_d} \right)$$

for ^{85m}Kr , ^{87}Kr , ^{88}Kr , ^{135m}Xe , and ^{138}Xe ; and

$$R_i = 37 V \left(\frac{1}{\lambda_i} \frac{dC_i^*}{dt} + C_i^* \frac{\lambda_i + \lambda_L}{\lambda_i} - C_2^* \frac{f\lambda_i - 1}{\lambda_i} \right) \left(\frac{\lambda_i + \lambda_d}{\lambda_d} \right)$$

for ^{133}Xe and ^{135}Xe .

The birth rate of the i -th isotope is given by:

$$B_i = Y_{ij} F_j W_j$$

where

f = branching factor,

V = cover gas space, cm^3 ,

Y_{ij} = cumulative fission yield of isotope i , fraction, and

F_j = specific fission rate for fissile isotope j .

By defining release rates in terms of changes in measured cover-gas activities, the complex processes of iodine and bromine precursors, trapping by the cold trap, and decay of solid precursors are avoided. The above equations have been used to calculate the behavior of $\log(R_i/B_i)$ with time for gas release during RBCB operation.

3. Typical Fission Gas Release Signatures

In theory, when the release mechanism is simple recoil the slope should be zero; in practice, recoil occurs in conjunction with knockout of gas and this mixed mode of release exhibits a non-zero slope. The normal background fission-gas activities in the EBR-II cover gas due to fissioning of "tramp" uranium in the primary circuit give rise to such a mixed mode release signature with a broad band of R/B slope values between 0 and -0.35. This type of behavior is illustrated in the lowermost plot of Fig. II.5 for the time interval July 1-18, 1988. Fission gas release from all types of element failure are clearly detected against such a background.

The gas release characteristics from a plenum failure are easily recognized: an initial R/B value of -1.0 is followed by a steady decline over 15-25 days to the tramp signature. This behavior has been observed a number of times

Fig. II.5. Corrected Kr-87 and Xe-133 Activities and Typical R/B Behavior Before and After Upper Weld (Plenum) Failure - July 1988

from 1987 to 1990 and identified with specific upper weld failures in lead IFR experiments (X419 and X420) when good tag gas information was available.⁷ Figure II.5 illustrates the case of an untagged driver failure due to a defective upper closure weld for the time interval July 18-31, 1988. Figure II.6 illustrates typical data sets from which the characteristic slopes were derived. The triangles correspond to the weld failure soon after initial release, with a slope of -0.91 . The predominant gas activity is due to the longer-lived isotopes ^{133}Xe and ^{135}Xe . Weld failures will occasionally "burp" fission gas but do not give rise to any increase in delayed neutron (DN) signal during their time in reactor because DN-emitters decay completely before reaching the release point.

The R/B signature for a fuel column breach is similarly very recognizable. If bond expulsion is rapid enough, I and Br precursors in the sodium give rise to a characteristic DN signal spike. Subsequently, R/B values rise rapidly to -1.0 , indicating release of stored fission gas in the plenum by way of the breach site. Over 3-5 days the values decline to approximately -0.5 , corresponding to diffusional release via the interconnected porosity of the metal fuel. Thereafter, occasional bursts of short and long-lived gas from the fuel interior appear as momentary changes about the -0.5 level.

Fig. II.6. Typical R/B Data Sets for Plenum and Fuel Column Metal Fuel Breaches

Figure II.7 illustrates the gas release behavior in the latter stages of a fuel column breach when stable diffusion through the fuel is occurring and the slope of the R/B curve is -0.5 . The data shown are from the HT9 clad U-19Pu-10Zr element in X482B which had been artificially defected at 10.5% burnup and eventually operated in 1990 for 150 full power days after breach; the time period is approximately three months after breach, the circles in Fig. II.6 correspond to this period. The machined defect was severe enough to have caused breach in the storage basket at 370°C prior to full power operation so that no DN signal was observed. The usual DN signal from a metal fuel breach (natural or induced) is a spike of short duration (<20 min) and magnitude (<1000 cps).

Fig. II.7. Corrected Kr-87 and Xe-133 Activities and Typical R/B Behavior During RBCB Operation of Metal Fuel-Column Breach (X-482B) - August 1990

4. Conclusions

Fuel column breaches and weld (or plenum) failures in metallic fuel elements appear to be distinguishable by their fission gas release characteristics. Both types of failure exhibit an initial "stored gas" type of release. Subsequently, fuel-column failures exhibit a stable diffusional release of gas which is clearly discerned from the "tramp" uranium signature in the EBR-II core.

D. Closure Welding of Oxide-Dispersion Strengthened Ferritic Cladding

1. Introduction

Oxide dispersion strengthened (ODS) versions of ferritic stainless steels are being considered as potential IFR cladding alloy alternatives to martensitic HT9. They promise to be more swelling resistant and they may have the strength and creep resistance¹⁰ required to withstand sustained operation >650°C that follows loss of decay heat removal capability. Yttria is the oxide dispersoid in two alloys being used: MA957, developed by the International Nickel Company (INCO),¹¹ and DT2203Y05 an ODS alloy developed by the Dour Metal Corporation of Belgium.¹²

Satisfactory welding is difficult with these advanced alloys and a resistance butt-welding procedure has been successfully developed as a simple alternative to pulse magnetic welding. The process has been qualified for joining the claddings to HT9 end caps. With adequate parameter control the weld is formed without a residual melt phase and its strength approaches that of the cladding. It requires a new design of end cap and weld joint.

2. Weld Process Development

These alloys achieve their high temperature properties from the finely dispersed yttria that retards recrystallization. The alloys are made by mechanical alloying, which starts with powders and distributes the alloy ingredients on a very fine scale. If conventional fusion welding is used, restructuring in the melt and heat-affected regions redistributes the yttria. A resistance butt-welding process¹³ was, therefore, selected in order to obtain a

solid state weld without recrystallization. In common with pulse magnetic welding, this process produces solid state welds without fusion in typically a few milliseconds or less.

The equipment selected was a pair of Voltza Transguns designed and built by Centerline Windsor Ltd., Windsor, Ontario, Canada. Both transguns, #CLTG-9608-5 and #CLTG-9636-15 are powered by an 80 kVA transformer. The welding units are operated by a modified Square D model 3857-004-802 controller. One transgun is a "C" style for laboratory use, and the other is an "X" style that enables welding to be performed more readily in a glove box. The transguns are shown in Fig. II.8. The key component in the design of these transguns is the patented OHMA cylinder used as the activator. The electrodes were modified to clamp the cladding and end plug components, and the scissors unit is being installed in the EFL through a standard glove port. The uniform application of

Fig. II.8. Cross Sectional Drawings of Transgun Models #CLTG-9608-5 (Top) and #CLTG-9636-15 (Bottom) Used for ODS Cladding Welding

pressure by the electrodes is critical to the deformation welding part of the process and was a principal factor in selection.

The design of the weld joint was based on input from modeling, fuel pin design criteria, and a series of welding tests. Finite Element Modeling (FEM) with the ANSYS code was used to identify the effect on the welding process of both material property variations and weld geometry. The analysis showed that variations in either the electrical resistivity of the cladding, due to variations in forming history, or the amount of cladding material protruding from the electrode clamps (stick-out) significantly affected the heating profile during welding, which, in turn, impacted weld quality. The final weld design consisted of the cladding butted to a right solid cylinder end plug that had a diameter approximately 0.1 mm larger than the cladding. A schematic showing the welding setup and pre-weld and post-weld configurations is shown in Fig. II.9. The welding parameters were a 4.5 kN load with 11 ka current for 3.33×10^{-2} s.

The welding process was also analyzed thermomechanically by running an FEM analysis in which the elastic-plastic and transient thermal responses were coupled during the welding process.¹⁴ This analysis showed that the process involved two phases: a flash phase of short duration (1.5×10^{-6} s) followed by a deformation welding (forging) phase. The flash phase heats the relatively massive end plug and initiates mating of both components with the expulsion of

Fig. II.9. Schematic of Configuration Used for ODS Cladding Welding

some cladding material. Figure II.10(a) shows the temperature contour map of the weld joint just prior to material expulsion at $t = 5 \times 10^{-7}$ s. Peak temperature occurred in the end of the cladding. By the end of the flash, ($t = 1.5 \times 10^{-6}$ s) the cladding had deformed significantly, as shown in Fig. II.10(b). The joint bonding occurred by deformation welding (forging) of the end plug and cladding butt end during the remaining portion of the time (two cycles or 3.3×10^{-2} s). In effect, the consistent loading (4.5 kN) kept the electrical resistance constant, thereby, controlling the temperature between the cladding and end plug. A momentary decrease in loading causes very rapid resistive overheating, which leads to either recrystallization and grain growth or excessive expulsion. Upset during the welding cycle was 2 mm, with 1.2 mm occurring by cladding extrusion.

3. Weld Characterization

Metallographic analysis of the welds revealed a bond line that was 30% longer than the cladding wall thickness (see Fig. II.11). The deformation

Fig. II.10. Results of Finite Element Modeling of ODS Welding
 (a) Temperature Map at 5×10^{-7} s
 (b) Deformation Map at 1.5×10^{-6} s

Fig. II.11. Photomicrographs of Resistance Butt Welded ODS Cladding (MA957 Alloy) to HT-9 End Plug

flow lines were readily apparent and there was no indication of recrystallization. A preliminary SEM/EDS analysis of a polished sample verified the absence of recrystallization and showed no evidence of yttria agglomeration, migration, or significant redistribution. Some particles in the weld seam did contain Ti and Y, which may be in the form of Y_2TiO_5 .¹⁵

The mechanical strength of the weld was determined by bend, tensile and burst testing. All mechanical test specimens other than those for the bend tests were machined prior to testing to remove the external upset material from the welding process. Bend testing was used primarily as a benchmark for strength and weld quality during process development; i.e., fracturing in the weld was not acceptable. The room temperature bend tests were cantilevered from the end cap and loaded at 15 cm from the weld until weld failure or tube collapse was observed. For acceptable welds, the clad failures or buckling must occur well away from the weld zone.

The tensile tests were performed at room temperature by inserting a mandrel in the tubing end and straining at 3.5×10^{-3} mm/s. Fracture occurred primarily in the tubing with occasional propagation into the weld joint, which indicates that the welds are stronger than the cladding. Tensile testing of the DT2203Y05 cladding weld is to be performed.

Biaxial burst testing was also performed to verify the strength of the welds. The burst capsules were fabricated with 60-mm lengths of ODS tubing. End plugs of HT9 were welded to each end of the tube section. One end was drilled out to receive inlet tubes of 304 stainless steel for pressurization with argon. The specimens were tested in retorts sealed from the surrounding atmosphere with Swagelok fittings at the inlet tubes.

The burst tests were performed at 550°, 650°, and 750°C in flowing argon, with the specimens allowed to equilibrate at test temperature for one hour before pressurization. The tests were performed by pressurizing each specimen in an increasing pressure ramp at a rate of approximately 0.5 MPa/s. Failure pressures were monitored by the motion of the needle in the pressure gage. The burst pressures are listed in Table II.4. The wide variance in burst pressure is assumed to be due to variations in the tubing. Biaxial creep rupture tests are being performed at the same temperatures as the burst tests.

TABLE II.4. Burst Test Results for ODS Weld Sample Tubing

Capsule Number	Temperature °C	Burst Pressure, kPa	Hoop Stress, MPa
1	547	74	657
5	551	103	914
2	648	61	544
4	652	70	625
3	758	21	187
6	760	31	278

E. Postirradiation Test Results of the Zirconium-sheathed Fuel Testing

1. Introduction

Current plans call for IFR fuel to be cast into quartz molds after reprocessing in the IFR Fuel Cycle Facility. Because the quartz molds are destroyed during the fuel demolding process, the quartz residue must be treated as contaminated waste and is part of the IFR Fuel Cycle waste stream. Alternatively, if the fuel could be cast into molds that can remain intact as an integral part of the fuel slugs (i.e., if the fuel can be left inside the molds for irradiation), then the quartz mold contribution to the waste stream will be eliminated.¹⁶

This possibility is being addressed in an on-going effort to evaluate the irradiation performance of fuel cast into zirconium tubes or sheaths rather than quartz molds. Zirconium was chosen as the sheath material because it is the component of the U-Pu-Zr fuel alloy that raises the alloy solidus temperatures and provides resistance against fuel-cladding chemical interaction (FCCI).¹⁷ Thus, the Zr sheath was expected to provide a compatible barrier to FCCI as well as a mold alternative. This report presents and discusses the irradiation performance of Zr-sheathed fuel elements irradiated in subassembly X492 to 1.8 at.% burnup in EBR-II.

2. Description of Experiment

Binary (U-3Zr) and ternary (U-20.5Pu-3Zr) fuel alloys were cast into Zr tubes in fuel fabrication facilities at ANL-W. The Zr tubes had an OD of 0.174 in. (similar to that of a standard-cast fuel element) with a 0.008 in. wall thickness; thus the sheathed slugs had dimensions similar to standard-cast slugs. The Zr content of the melt was reduced to account for the Zr in the sheath, giving the sheathed slugs the same Zr content as that in a standard-cast slug. Similarly, the Pu content of the melt was adjusted to give a Pu content of 19 wt% in the slug. Metallography of the as-cast fuel showed that the fuel alloy and the Zr sheath interacted to form a metallurgical bond. The interaction layer extended roughly 12.7 μm (0.0005 in.) into the Zr sheath.

The fuel elements made from the sheathed slugs were fabricated to Mk-IIIA driver fuel parameters, using 316 SS cladding tubes. The Zr-sheathed fuel elements were then loaded with standard-cast binary and ternary elements (also fabricated to Mk-IIIA parameters) into a 61-element subassembly (X492) for irradiation in EBR-II. All of the ternary Zr-sheathed elements and approximately half of the binary Zr-sheathed elements were made from two half-length fuel slugs rather than a single full-length slug. The remaining Zr-sheathed elements as well as the standard-cast elements contained a single full-length slug. The nominal design parameters for the four types of elements loaded into the subassembly are listed in Table II.5.

The subassembly was irradiated in EBR-II core position 4A1 to a peak burnup of 1.95 at. %. A pretest analysis indicated that peak fuel center line temperatures would range from 600 to 682°C and peak inside cladding temperatures would range from 502 to 551°C depending on element position in the bundle. Table II.6 lists the range of temperatures expected for each type of element. The peak fast fluence for the subassembly was calculated to be 1.7×10^{22} n/cm².

After removal from the reactor, the subassembly was taken to the Hot Fuel Examination Facility (HFEF) where each of the 61 fuel elements was removed from the assembly and radiographed. The lengths of the fuel slugs were measured from the radiographs and compared to the as-fabricated slug lengths. From these measurements, axial growth was determined. After radiography, six elements were chosen for destructive examination, while the remaining elements were reconstituted into subassembly X492A for further irradiation.

The six elements removed from the subassembly include two binary elements, two ternary-sheathed elements, a standard-cast binary element and a ternary element. The strains for five of these pins [one ternary sheathed element was sent to the Alpha Gamma Hot Cell Facility (AGHCF) at ANL in Illinois for metallographic examination] were measured using helical contact profilometry. Axial fission product distributions were found using axial gamma spectrometry. Following those non-destructive exams, each element was punctured and back-filled using the HFEF gas sampling system. This allowed calculation of the plenum pressures and volumes in the elements.

TABLE II.5. Nominal Design Parameters for Zr-sheathed Fuel Irradiation Experiments

Element Type	Binary Std. Cast ¹	Binary Zr-sheathed	Ternary Std. Cast	Ternary Zr-sheathed
Fuel Alloy (wt. %)	U-10Zr	U-3Zr	U-19Pu-10Zr	U-20.5Pu-3Zr
Cladding and Wire	316 SS	316 SS	316 SS	316 SS
Bond	Na	Na	Na	Na
Clad OD (in.)	0.230	0.230	0.230	0.230
Clad Wall (in.)	0.015	0.015	0.015	0.015
Element Length	29.5	29.5	29.5	29.5
Fuel Slug OD ² (in.)	0.173	0.174	0.173	0.174
Zr-sheath Wall (in.)	-	0.008	-	0.008
Slug Length (in.)	13.5	13.5/2@ 6.75	13.5	2@ 6.75
Smear Density	75%	76%	75%	76%
Plenum/Fuel Volume Ratio (as-built)	1.45	1.42	1.45	1.42

¹Standard Mk-IIIA driver elements.

²Sheath OD for Zr-sheathed elements.

TABLE II.6. Ranges of Peak Centerline and Peak Inner Clad Temperatures for Zr-sheathed Fuel Irradiation Experiment

Element Type	Binary Std. Cast	Binary Zr-sheathed	Ternary Std. Cast	Ternary Zr-sheathed
Peak Centerline (°C)	604-678	603-671	605-682	600-680
Peak Inner Clad (°C)	511-544	503-551	502-551	502-551

3. Postirradiation Examination

a. Neutron Radiograph Examination

Examination of neutron radiographs of these elements revealed two interesting characteristics. First, fuel material apparently grew out of the ends of the Zr sheaths. Thus, the tops and bottoms of the fuel slugs as well as the interface between the segmented slugs appear to have fuel in position to contact the cladding. Second, measurements taken from neutron radiographs indicate that Zr-sheathed elements experienced significantly less axial growth than did standard-cast elements. For both the sheathed and standard-cast elements, the binary alloy slugs grew more than did the ternary slugs, consistent with previous results.¹⁷ The axial growth measurements are summarized in Table II.7.

b. Contact Profilometry

Helical contact profilometry of the five elements (one element of each type plus an extra binary Zr-sheathed element) showed the cladding strains to be similar for each type of element. The dilations are small, as expected for low burnup fuel elements. The maximum for all elements is approximately 0.020 mm (0.0008 in.) above the nominal diameter (0.35% diametral strain).

TABLE II.7. Summary of Axial Growth Results for Zr-sheathed and Standard-cast Elements

Element Type	No. of Elements	Avg. % Axial Growth	Standard Deviation
U-3Zr Zr-sheathed Segmented	15	1.79	0.39
U-3Zr Zr-sheathed Unsegmented	13	1.34	0.24
U-10Zr Unsegmented	13	8.07	0.51
U-20.5Pu-3Zr Zr-sheathed Segmented	12	1.23	0.22
U-19Pu-10Zr Unsegmented	8	4.93	0.38

c. Gamma Scan

Only a few notable features were observed in the axial gamma scans of the fuel elements. The Zr-sheathed pins had Cs-137 spikes at the top and bottom of the fuel column and (for two of the three pins) at the interface between the slugs at core midplane. The Zr-sheathed fuel elements had narrow regions of relatively low Zr-95 and Nb-95 activity near the core midplane level, probably due to the separation of the two sheathed slugs at the slug interface.

d. Fission Gas Analysis

An analysis of fission gas sampled from four elements (one of each type) indicates that the fission gas released to the plenum of each element contains roughly 88% Xe (mole percent) and 12% Kr. The sheathed pins exhibited essentially the same gas release behavior as the unsheathed pins (see Table II.8), with release fractions similar to those reported by Pahl et al.,¹⁷ for low burnup elements. The two ternary elements did have slightly higher gas release fractions than did the binary elements. A similar relation between Pu content and fractional gas release has been previously reported.¹⁸

TABLE II.8. Gas Release Characteristics for Zr-sheathed and Standard Cast Elements

Element ID	Description	Peak Burnup (at.%)	Plenum Pressure ¹ (psig)	Percent Fission Gas Release ²
M918	U-10Zr Standard Cast	1.8	60	46
L490	U-3Zr Zr-sheathed	1.9	62	49
K067	U-19Pu-10Zr Standard Cast	1.8	66	53
K082	U-20.5Pu-3Zr Zr-sheathed	1.9	68	59

¹Temperature at approximately 30°C. Includes tag, fill, and fission gas.

²Assumes 0.25 atoms fission gas per atom fissioned.

4. Metallographic Examination

To date, one element (I.D. No. K025, ternary Zr-sheathed) has been metallographically examined. Transverse sections at $X/L = 0.23$ and 0.78 (see Fig. II.12) reveal wedge-shaped longitudinal cracks, presumably running down the length of each of the two slugs. In each section, the Zr sheath appears to have necked before splitting. The cracks appear to be similar to those observed previously in U-19Pu-10Zr fuel elements irradiated to 2 at. % burnup.¹⁸ Electron microprobe WDX analysis determined the Zr concentration of the dense zone in the center of the element to be roughly 0.5 wt. %, depleted from the 3 wt. % Zr content for the fuel alloy. Although the two transverse sections show no fuel-clad contact through the opened crack, the fuel approaching the cladding through the crack was determined to have as little as 1.1 wt. % Zr.

Fig. II.12. Transverse Section of Zr-sheathed U-20.5Pu-3Zr of Pin K025 at $X/L = 0.78$. The dark patches in the Zr sheath are artifacts from grinding and polishing of the soft Zr material.

Although the interaction between the fuel and the Zr sheath appears to be small in Fig. II.12, the transverse section at $X/L = 0.23$ and the longitudinal sections at $X/L = 0.0$ and 0.5 (see Fig. II.13) show regions of extensive interaction. In fact, the longitudinal section in Fig. II.13 shows a region where the entire Zr sheath has reacted with fuel. The Zr content at these peripheral regions varies from 100 wt. % in the unreacted Zr sheath to 30 wt. % at the inner portion of the reacted Zr sheath. The porous fuel lying between the Zr sheath and the dense center zone typically has Zr contents of 5 to 6 wt. %, although values of 11 wt. % and 3 wt. % were measured at the porous fuel-reacted Zr sheath interface and the porous fuel-dense fuel interface, respectively. The fuel material next to cladding at the slug interface in the longitudinal section of Fig. II.13 was found to contain 6 wt. % Zr.

Fig. II.13. Longitudinal Section of Zr-sheathed U-20.5Pu-3Zr K025 Pin at $X/L = 0.50$

Although neutron radiography indicated that fuel had extruded through the ends of the Zr sheaths and possibly contacted the cladding at the top, bottom, and middle of the fuel column in the element, longitudinal sections revealed FCCI only at the slug interface at the $X/L = 0.5$ elevation. This interaction involved only a small area, but penetrated $21\text{ }\mu\text{m}$ (0.0008 in.) into the cladding. This depth of interaction is significant compared to previous tests, since it occurred at low burnup at an elevation where moderate temperatures occurred. The extrusion of fuel at the bottom of the fuel column raised the lower fuel slug approximately 0.8 mm (0.031 in.) above the lower end plug. Similarly, extrusion through the ends of the Zr sheaths at the fuel slug interface (see Fig. II.13) separated the two slugs by about 2.3 mm (0.091 in.). The extrusion at the top of the fuel column (see Fig. II.14) was less severe, extending about 0.6 mm (0.024 in.) above the top of the sheath.

Fig. II.14. Longitudinal Section of Zr-sheathed U-20.5Pu-3Zr K025 Pin at $X = 1.0$

5. Discussion

The two most striking results of the postirradiation examination of the Zr-sheathed fuel are the reduced axial growth and the wedge-shaped cracks observed in the Zr-sheathed elements. Those results will be discussed first followed by discussion of zone formation and the implications of the results.

The fuel/Zr-sheath interaction seen in the transverse section of the as-cast fuel slug indicates that the bond between the fuel and the sheath is a diffusion bond that is uniform around the circumference. This is probably the characteristic of the Zr-sheathed fuel that restricted axial growth. Of the 5.2 mm (0.205 in.) axial growth on the Zr-sheathed element used for the metallographic exam, 3.7 mm (0.146 in.) was due to the displacement of the slugs upon extrusion of fuel through the ends of the sheaths. The Pu-containing slugs exhibited less growth than the binary slugs. This observed relation between axial growth and Pu content for both the sheathed and standard-cast pins is consistent with previously reported results.¹⁸

One may have expected the Zr sheaths to act as barriers for fission gas, thus causing the Zr-sheathed slugs to retain more fission gas. However, the gas release fractions were the same for the Zr-sheathed elements as for the standard-cast elements. If the wedge-shaped cracks did in fact extend the length of the slugs, then the cracks may have provided a path for fast release. Whether the path for gas release was through axial wedge-shaped cracks or simply through the exposed fuel at the open ends of the Zr sheaths, the implication is that the fuel porosity was interconnected sufficiently to allow gas release similar to that of a non-sheathed fuel slug, which does exhibit interconnected porosity at this burnup.

The origin of the wedge-shaped crack is not obvious from the metallography. Wedge-shaped cracks have been found in standard-cast U-19Pu-10Zr fuel slugs irradiated to 2 at. % burnup.¹⁹ So, the crack in the sheathed pin may have formed first in the fuel and then strained the Zr sheath to failure as the crack opened wider. However, the crack may have formed first in the Zr sheath as the fuel swelled radially; thus the fuel swelling would have split the sheath, and the crack in the fuel would have formed as the split sheath opened wider to accommodate further swelling.

Metallographic examination of a binary Zr-sheathed element will help resolve this issue. No wedge-shaped cracks have yet been found in standard-cast binary fuel. Therefore, any cracks present in Zr-sheathed binary fuel will originate from a split in the sheath induced by radial fuel swelling. If the Zr-sheathed binary fuel has no wedge-shaped cracks, then the crack in the sheath of the ternary Zr-sheathed fuel arose from fuel cracking. Similarly, the absence of cracks in the Zr-sheathed binary fuel, which had a gas release fraction similar to standard-cast binary fuel, will imply that porosity is sufficiently interconnected to allow for substantial gas release through fuel at the open ends of the Zr sheaths.

The metallographic sections of the Zr-sheathed ternary element at both $X/L = 0.78$ and $X/L = 0.23$ show the fuel to have a two-zone structure. The inner (or center) zone is noticeably dense and has a Zr content of around 0.5 to 1 wt. %. The outer zone lies between the center zone and the Zr sheath and consists of porous fuel enriched in Zr (roughly 5 wt. %). This type of two-zone formation is similar to that seen in U-19Pu-10Zr elements at cooler axial locations, such as near the top and bottom of the element.¹ The hotter portions of the elements tended to form three-zone structures, with a somewhat porous Zr-enriched zone in the center, a dense Zr-depleted zone near mid-radius, and a porous slightly Zr-enriched zone lying radially outward.

That the Zr-sheathed fuel formed a two-zone structure rather than a three-zone structure at a relatively hot axial location ($X/L = 0.78$) does not necessarily imply that this element was irradiated at cooler temperatures, however. The Zr-sheathed fuel contains significantly less Zr in the as cast alloy and, therefore, may have different phases stable at irradiation temperatures than does fuel containing 10 wt. % Zr. A pretest thermal analysis indicated that the centerline temperature for the sectioned element should have been around 670°C. Ternary phase diagrams for U-Pu-Zr²⁰ show that at 660°C, for example, the 10 wt. % Zr alloy exists predominantly in the $\gamma_1 + \gamma_2$ phases while the 3 wt. % Zr alloy has $\gamma + \zeta$ phases stable. At 670°C both alloys lie in a predominantly γ region of the phase diagram, while at 650°C both lie in the $\gamma + \zeta$ region. Therefore, the Zr-sheathed element was likely to have little or no γ phase present at its center, while a 10 wt. % Zr alloy would. This is

significant, in that the $\gamma + \zeta$ two-phase region has previously been identified as the Zr-depleted zone of a U-19Pu-10Zr element with three zones.²¹ The present results consistently show that a zone (i.e. the center zone) expected to have the $\gamma + \zeta$ phases stable at irradiation temperatures is also Zr-depleted.

Although the results show that Zr sheaths, in the form tested here, cannot be a reliable barrier to FCCI due to cracking, two other advantages hold promise for the concept. First, fuel slugs can be cast into Zr tubes, eliminating the need for quartz molds. Second, the Zr sheaths appear to reduce axial growth to strains below 2%. If the low Zr fuel in the sheathed elements does in fact interact with cladding in a manner that causes premature failure, then variations of the concept can still be pursued. For example, the Zr content of the fuel alloy can be increased to, say, 6 wt. %. Such a fuel alloy is currently being tested in other irradiation experiments, so we may not need to rely on a Zr sheath to ensure fuel/cladding compatibility. Thus, if the sheath around a 6 wt. % alloy cracked, there may be no consequence. If fuel can be cast into thinner Zr tubes, then the "smeared" composition of 10 wt % Zr can be retained by casting 6 wt. % Zr fuel into Zr tubes with 0.003 to 0.004 in. walls.

6. Conclusions

1. A 0.203 mm. (0.008 in.) thick Zr sheath around a U-20.5Pu-3Zr fuel alloy does not provide a reliable barrier against FCCI under irradiation.
2. Zr-sheath fuel elements irradiated to 1.8 at.% burnup exhibit significantly less axial growth than standard-cast fuel elements. This is beneficial for reactor reactivity considerations.
3. The prospects of reduced axial growth or eliminating quartz debris from the FCF waste stream may be sufficient incentive to warrant further investigation of the sheathed fuel concept.

References for Section II

1. R. G. Pahl, R. S. Wisner, M. C. Billone and G. L. Hofman, "Steady-state Irradiation Testing of U-Pu-Zr Fuel to >18 at.% Burnup," Proc. of the 1990 Intl. Fast Reactor Safety Mtg., IV:129, Snowbird, UT (August 12-16, 1990).
2. G. L. Fox, "Design Limits for HT9 Cladding Using Stress-Induced Aging Data," Proc. of the Intl. Conf. on Reliable Fuels for Liquid Metal Reactors, Sect. 6, p. 5-135, Tucson, AZ (September 7-11, 1986).
3. G. L. Batte' and G. L. Hofman, "Run-Beyond-Cladding Breach (RBCB) Test Results for the Integral Fast Reactor (IFR) Metallic Fuels Program," Proc. of the 1990 Intl. Fast Reactor Safety Mtg., IV:207, Snowbird, UT (August 12-16, 1990).
4. B. R. Seidel and L. C. Walters, "A Decade of Advances in Metallic Fuel," Trans. Am. Nucl. Soc., 62:620, Washington, DC (November 11-15, 1990).
5. G. L. Hofman et al., "Metallic Fuels Handbook," IFR-TM-29 (November 1985).
6. T. Hoechst et al., Guide to ORACLE, Intertext Publications, McGraw-Hill (1990).
7. Section II.C, "Breach Characteristics of Lead D9 Clad Fuel Elements," Argonne National Laboratory Report, ANL-IFR-149, pp. 19-34 (May 1991).
8. D. R. Olander, "Fundamental Aspects of Nuclear Reactor Fuel Elements," TID-26711-pl, p. 287 (1976).
9. S. Nomura, K. C. Gross, and J. D. B. Lambert, "Breached Pin Diagnosis by Fission Gas Analysis in the EBR-II RBCB Program," Proc. Intl. Conf. on Reliable Fuels for Liquid Metal Reactors, pp. 6-105/6-118, Tucson, AZ (September 7-11, 1986).
10. R. W. Powell, G. D. Johnson, M. L. Hamilton, and F. A. Gardner, "LMR Cladding and Duct Materials Development," Proc. of Intl. Conf. on Reliable Fuels for Liquid Metal Reactors, pp. 4-17/4-29, Tucson, AZ (September 7-11, 1986).
11. J. J. Fisher, "Dispersion Strengthened Ferritic Alloy for Use in Liquid Metal Fast Breeder Reactors (LMFBRs)," U.S. Patent 4,075,010 (February 1978).
12. S. Nomura, et al., "Development of Long Life Core Materials," Proc. Intl. Conf. on Fast Reactor and Related Fuel Cycles, 1:7.4-1, Kyoto, Japan (October 28-November 1, 1991).
13. S. de Burbure, "Resistance Welding of Pressurized Capsules for In-pile Creep Experiments," Welding Journal, 33:11 (1978).
14. C. L. Tsai, O. A. Jammal, and D. W. Dickinson, "Study of a Nugget Formation in Resistance Spot Welding Using Finite Element Method," 2nd

Intl. Conf., Amer. Soc. of Metals, pp. 43-53, Gatlinburg, TN (May 14-18, 1989).

15. M. L. Hamilton, et al., "Technological Development of the Oxide Dispersion Strengthened Alloy MA957 for Use as Fast Flux Test Facility Components," Westinghouse Hanford Company Report, WHC-SP-0655 (May 1991).
16. B. R. Seidel, D. B. Tracy, and V. Griffiths, "Apparatus for Injection Casting Metallic Nuclear Energy Fuel Rods," U. S. Patent No. 5,044,811 (September 3, 1991).
17. R. G. Pahl, D. L. Porter, C. E. Lahm, and G. L. Hofman, "Experimental Studies of U-Pu-Zr Fast Reactor Fuels in the Experimental Breeder Reactor-II," Met. Trans. A, 21A:1863 (1990).
18. R. G. Pahl, C. E. Lahm, R. Villarreal, W. N. Beck, and G. L. Hofman, "Recent Irradiation Tests of Uranium-Plutonium-Zirconium Metal Fuel Elements," Proc. of Intl. Conf. on Reliable Fuels for Liquid Metal Reactors, pp. 3-36/3-56, Tucson, AZ (September 7-11, 1986).
19. G. L. Hofman, R. G. Pahl, C. E. Lahm, and D. L. Porter. "Swelling Behavior of U-Pu-Zr Fuel," Met. Trans. A, 21A:517 (1990).
20. D. R. O'Boyle and A. E. Dwight, "The Uranium-Plutonium-Zirconium Alloy System, In Plutonium 1970 and Other Actinides, Nuclear Metallurgy, 17, Part 2:720, William N. Miner, Ed. (1970).
21. D. L. Porter, C. E. Lahm, and R. G. Pahl, "Fuel Constituent Redistribution During the Early Stages of U-Pu-Zr Irradiation," Met. Trans. A, 21A:1871 (1990).

III. PYROMETALLURGICAL PROCESS DEVELOPMENT

A. Process Flowsheet and Chemistry Studies

The IFR pyrochemical process flowsheet accepts any mix of spent fuel from the reactor, removes fission products and cladding, and yields a product from which fresh fuel can be fabricated. Details of the process flowsheet, process chemistry, and operation of the electrorefiner have been provided in previous reports, but the IFR electrorefining process may be summarized as follows: Spent fuel in its stainless-steel cladding is chopped into approximately quarter-inch lengths and placed in a basket that is introduced into molten salt (LiCl-KCl) at 500°C in an electrorefining vessel. The basket is connected to a dc power supply and made anodic; nearly pure uranium is removed from the spent fuel by electrotransport to solid cathodes, then the plutonium and any remaining uranium in the feedstock are electrotransported to liquid cadmium cathodes. During electrorefining, noble metal fission products mostly remain in the basket, but some fall as particulate to the bottom of the electrorefiner. The alkali and alkaline earth metals in the spent fuel are oxidized and remain in the electrorefiner salt, as do most of the rare-earth fission products.

Experiments have demonstrated that separation of actinides from all fission products except the rare earths is excellent, but because sufficient quantities of most rare earths remain in the mixed uranium-plutonium product from the liquid cadmium cathode, this product requires remote handling. As fuel batches pass through the electrorefiner, the rare earth level builds up in the product and the salt. Because the radiation level and heat release in the electrorefiner also increase, the electrorefiner salt has to be processed from time to time to remove the rare earths.

To predict the product composition in the liquid cadmium electrode and to design and control the rare-earth removal process, we must first understand the partition of the rare earth and actinide elements between molten salt (where they exist as chloride compounds) and liquid cadmium (where they exist as metals in solution). We are therefore measuring the separation factor for pairs of the rare earth elements up to atomic number 64 (gadolinium) and for neodymium vs. plutonium. These separation factors are being determined by measuring the concentrations of pairs of the rare earth elements in molten LiCl-KCl eutectic salt and liquid cadmium phases at 500°C .

We define the distribution coefficient as the ratio of the weight percent of an element in the salt phase (as the element, not its chloride) to the weight percent of the element in cadmium. Because most of the elements of interest (actinides and most lanthanides) are present in the salt as trichlorides, it is convenient to define the separation factor as the ratio of the distribution coefficients of two (trivalent) elements. For elements that form dichlorides or trichlorides, this leads to a definition of the distribution factor that is slightly more complex. The general reaction and separation-factor definition, regardless of oxidation state, for two elements are:

and

$$\text{SF} = \frac{[\text{M}']^{3/Y} [\text{MCl}_X]^{3/X}}{[\text{M}'\text{Cl}_Y]^{3/Y} [\text{M}]^{3/X}} \quad (2)$$

Unless the chlorides of both elements have the same oxidation state, the distribution coefficient of one element in a pair will depend in a nonlinear fashion on the distribution coefficient of the other element. Nonetheless, this approach allows us to "chain" separation factors and form a self-consistent set of separation factors from measurements on a minimum number of element pairs. Self-consistency is of critical importance for calculations as the separation factor becomes larger than 25, because it soon becomes difficult if not impossible to precisely measure at least one member of the smaller pair of concentrations (for example, the uranium in the salt or the yttrium in the metal for the uranium-yttrium pair). By "chaining" more easily measured separation factors, though, we can estimate, for example, the separation factor of the uranium-lithium pair (7×10^{12}), even though it is clearly impossible to measure this separation factor directly.

It is easiest to envision the relative distribution of the elements as the oxidizing state of the system is changed, if the distribution coefficients of all the elements are plotted as a function of the distribution coefficient of one element. In Fig. III.1, distribution coefficients (calculated from the appropriate separation factors) are plotted against the logarithm of the distribution coefficient of uranium. The separation factors used are the best presently known values; measurement and data analysis are still in progress. A

Fig. III.1. Distribution Coefficients of Selected Elements as a Function of Oxidation State

logarithmic scale was used to accommodate the large range of oxidizing conditions from the very reducing state, where the concentration of UCl_3 is small and only europium and samarium are present as chlorides, to the highly oxidizing state (relative to the IFR process conditions), where nearly all the rare earth and actinide elements are found in the salt phase.

The behavior of the most metallic (readily oxidized) rare earth elements is of interest in the salt purification steps, where the salt is treated with lithium or uranium in cadmium to recover the transuranics and separate them from the rare earths. A computer code has been developed to simulate countercurrent extraction with salt and metal, where no solid phases are formed. This code uses the set of separation factors to calculate the distributions of the rare earth and actinide elements in the extraction process; it is being used in designing the salt-treatment part of the pyroprocess flowsheet.

B. Process Development Studies

Work in this area includes experiments to study zirconium behavior in an electrorefiner and fabrication of a new laboratory-scale electrorefiner for use in process-development experiments.

1. Zirconium Behavior Studies

Zirconium constitutes about 30 vol % of IFR fuel. In the normal transport of uranium to a solid cathode and U-Pu to a liquid cathode, the bulk of the zirconium is not transported but is left in the electrorefiner. With repeated cycles, this zirconium accumulates in the cadmium anode pool.

Laboratory studies were continued to determine the behavior of zirconium in electrorefiner operations and to devise methods for zirconium removal from the cadmium anode pool. Although the site of zirconium deposition during anodic dissolution of the fuel is not altogether clear, examination of our engineering-scale electrorefiner indicated that some, if not all, of the zirconium deposits on the crucible wall (see Sect. III-C.6). A similar finding was made during examination of laboratory-scale crucibles (15-cm dia) and stirrers used in small-cell tests. To clarify where zirconium deposits, several small electrorefining cells (housed in 5-cm dia crucibles with capacity of 300 g cadmium) were operated, then their crucibles were cut apart and examined to determine where the zirconium had deposited.

In typical tests, cells of the type $\text{Zr/LiCl-KCl-ZrCl}_x/\text{Cd(Zr)}$ were operated at 500°C . No uranium was used, and zirconium was transferred electrochemically from a zirconium anode rod to a cadmium pool cathode. The cell electrolyte was prepared by adding CdCl_2 to oxidize zirconium metal to ZrCl_x (species not determined). The electrolyte, LiCl-KCl eutectic, contained an estimated 1 wt. % Zr. The zirconium anode rod was easily anodized at a current density of 100 mA/cm^2 and low voltage. Visual examination of the cross-sectioned crucibles after the test indicated that the solids had piled up on top of the cadmium pool cathode. The cell stirrer was not adequate to break up this deposit.

In these tests, deposits of Cd_2Zr (identified by X-ray diffraction) were found on the zirconium anode rod. Since this formation was likely due to "splashing," in the stirred cell, of cadmium onto the zirconium rod, we needed to determine if the zirconium would be chemically attacked by cadmium. The objectives of the next two tests were to determine (1) how much Cd_2Zr would actually be formed, and (2) whether or not the zirconium could be removed from this cadmium phase electrochemically. Results from these two tests revealed the following: (1) 37 g zirconium dissolved in 307 g cadmium over a seven-day period at 500°C , and (2) the cadmium phase with this much zirconium appeared to be nearly solid at 500°C . (The solubility of zirconium in liquid cadmium is about 0.2 wt. %.)¹ The zirconium from the cadmium phase was transported electrochemically onto a mild steel rod. However, we could not establish whether the cathode product was zirconium metal, a zirconium salt, or a combination of both. A relatively low voltage (<0.3 V) was required to facilitate this transport.

Typical cross sections of a crucible after zirconium deposition onto cadmium shows an irregular boundary between the white salt phase and the dark cadmium phase. Before deposition of zirconium, this interface was a flat plane, as expected between two immiscible liquids. Figure III.2 shows a Cd_2Zr -rich phase on top of a cadmium ingot removed from a crucible, indicating that the upper phase contained solids (Cd_2Zr intermetallic) at the operating temperature (500°C). This phase was located between the liquid cadmium and the salt (not shown in this photograph). Figure III.3 shows a zirconium-bearing electrodeposit obtained on an iron cathode from a cell which had a zirconium-rich cadmium anode. The deposit appears to contain some metal crystals encased in salt. Analysis of similar cathode deposits revealed both zirconium metal and a zirconium salt.

This work indicates that zirconium can be electrotransported to a cathode, and is readily dissolved by direct attack of cadmium metal or by electrolytic anodic dissolution. Accordingly, these methods should be candidates for removing the alloy zirconium from the electrorefiner.

2. Laboratory-Scale Electrorefiner

A new, laboratory-scale electrorefiner has been designed and fabricated. The major design change, compared to the electrorefiner in use earlier, is in the cadmium cathode. The new impeller design for the cathode

Fig. III.2. Cut Section of Product Ingot Showing Cd_2Zr on Top of Cadmium (ANL Neg. No. 10384, Frame 21)

Fig. III.3. Typical Deposit Obtained with Zirconium (ANL Neg. No. 10384, Frame 20)

provides for axial as well as rotational motion. Our work with the old design showed that the actinide solids, found in the cathode, tended to build up on the rotating blades of the impeller instead of sinking into the liquid cadmium. The added axial motion should force the solids downward into the cadmium phase. The apparatus was assembled outside the plutonium glovebox and was operated cold, and certain initial deficiencies were found and corrected. The apparatus was then moved into the plutonium glovebox, and further shakedown tests completed. The electrorefiner is now being loaded with processing reagents (cadmium and LiCl-KCl electrolyte) prior to heatup. After the electrorefiner is charged with uranium and plutonium, experiments will be conducted to establish process parameters and electrochemistry for transport to liquid cadmium cathodes.

C. Engineering-Scale Process Development

The key steps in the pyrochemical processing of spent fuel are dissolution and product recovery by electrodeposition using either solid or liquid cathodes. Progress made in developing each step is discussed below. Also reported are results from tests of a system to reduce cadmium-aerosol release from the electrorefining process, a device for harvesting the uranium deposit from a steel cathode, and zirconium behavior. All tests were conducted in our engineering-scale electrorefiner (0.9-m dia crucible).

1. Dissolution of Spent Fuel

Anodic dissolution of chopped, clad U-Zr alloy pins at the engineering-scale level (10 kg batch size) has become a routine operation. To date, 200 kg uranium has been anodically dissolved in the engineering-scale electrorefiner. Dissolution of 10 kg batches is typically achieved in less than 30 h. After an anodic dissolution run, the baskets are rotated in the gas phase above the salt in the electrorefiner to reduce the amount of salt on the cladding hulls and basket. Measurements were made to determine the effect of the basket rotation speed on the weight of salt retained in the baskets. Approximately 60, 130, and 144 g of salt were retained on the baskets and hulls after basket rotation at speeds of 250, 125, and 0 rpm, respectively. Based on these results and the fact that the maximum basket rotation speed for the system is 250 rpm, this rotation speed is recommended for salt removal from baskets.

Future efforts will be directed to the development of improved anodic basket designs for direct transport of dissolved uranium from the basket to a solid cathode and for increased throughput rate.

2. Electrotransport to Solid Cathode

Electrotransport of 10 kg uranium from a cadmium pool anode to a single mandrel cathode has also become a routine operation. In the most recent electrotransport tests (Runs 43, 45, 51, 52, and 54), 9.5, 9.3, 8.2, 10.0, and 8.6 kg of uranium were electrodeposited on a single mandrel cathode in 37, 26.5, 30, 46, and 30 h, respectively. These and other test results are given in Table III.1. The optimal operating conditions required to produce a 10 kg uranium deposit have been determined from the test results.

An important operating condition is that the salt and cadmium mixing must be sufficient to ensure the electrotransport of uranium from the cadmium anode pool to the solid mandrel cathode. However, the mixing must be controlled after a deposit weight of about 5 kg has been produced to reduce mechanical losses as the weight of the deposit is increased to 10 kg. This is accomplished by turning the salt mixer off halfway through the run and by not using the cadmium mixer.

TABLE III.1. Results from Electrotransport to Single-Mandrel Solid Cathodes

Run No.	43	45	51	52	54
Wt. Uranium Deposit, kg	9.5	9.3	8.2	10.0	8.6
Deposition Rate, kg/h	0.26	0.35	0.27	0.22	0.29
Collection Efficiency, %	39	39	42	42	48
Average Current, A	222	302	219	111 ^a 254 ^b	200
Time, h	37	26.5	30	25 ^a 21 ^b	30

^aUranium was electrotansported directly from the anodic dissolution baskets to the cathode.

^bElectrotransport from the cadmium pool anode to the cathode.

As shown in Table III.1, the collection efficiency for the above tests was 39 to 48%. The throughput rate could be nearly doubled by increasing the collection efficiency to about 80%. Future efforts will include tests to increase the collection efficiency.

3. Electrotransport to Liquid Cadmium Cathode

Tests were continued to determine the operating conditions required to electrodeposit 3 kg uranium in a liquid cadmium cathode (LCC). (Because the glovebox in which these tests are carried out is not a plutonium facility, uranium is used as a stand-in for plutonium.) Figure III.4 is a schematic of the LCC in the engineering-scale electrorefiner. The tests conducted during this reporting period were designed to determine the effect of the following variables on the performance of the LCC:

Fig. III.4. Configuration of Liquid Cadmium Cathode in Engineering-scale Electrorefiner (LCC Crucible Elevation at 0 in.)

1. Cadmium height in LCC crucible
2. Electrode area of LCC
3. Freeboard in LCC crucible
4. Electrode distance between LCC and cadmium anode pool
5. Height of salt above the LCC crucible

Electrode area, freeboard of the LCC crucible, and the electrode distance between the LCC and cadmium anode pool were found to have a major effect on the cell resistance. To date, resistance has been measured for reference conditions and with a 20% increase in the electrode area, 50% increase in the freeboard, and 50% increase in the distance between the electrodes. The resistance tripled as a result of the increase in these variables. Further testing is needed to determine the contribution of each variable to this increase in cell resistance.

In one liquid cadmium cathode test (Run AD-LCC-7/7A), uranium was electrotransported directly from the anodic dissolution baskets to the LCC. During the run, the electrodeposition was interrupted after about 250 Ah; the front edge of the dendrite breaker was positioned below the surface of the cadmium in the LCC to compact the uranium dendrites; and the dendrite breaker was then raised above the LCC and rotated at 150 rpm to remove uranium dendrites from the breaker and upper surfaces of the LCC crucible. These operations were repeated until the run was terminated. The average current for this run was 62 A, and the electrodeposition time was 59.4 h.

Based on chemical analysis of samples taken from the LCC product, the product contained 66.8 wt. % cadmium, 33.2 wt. % uranium, and negligible amounts of salt and zirconium. The weight of uranium in the LCC was 4.2 kg. If similar results can be obtained with U-Pu mixtures (i.e., about 4 kg heavy metal in about 9 kg cadmium), this would meet our goals for the LCC needed for the electrorefiner in the Fuel Cycle Facility. The data from these experiments will be useful in designing the liquid cathode for testing with U-Pu mixtures in the Fuel Cycle Facility.

4. Cover-Gas Treatment System

During testing with the engineering-scale electrorefiner, we observed the release of cadmium aerosols to the glovebox. These aerosols deposit

on the interior of the glovebox windows and equipment and could cause problems in the argon cell of the Fuel Cycle Facility if similar releases were to occur. A cover-gas treatment system (CGTS) was developed to reduce such releases from the engineering-scale electrorefiner and, in principle, should be usable with the electrorefiner for the Fuel Cycle Facility. In this system, a portion of the cover gas is withdrawn and passed through a mass transfer unit (MTU) that removes cadmium by vapor condensation. The unit is in the form of countercurrent flow heat exchanger trays, which are fabricated from 5-mm high corrugated internal passages. The gas temperatures are carefully controlled to suppress the onset of homogeneous nucleation and, thus, to prevent formation of cadmium aerosols, which would be very difficult to remove from the gas stream.

In the system, a portion of gas is withdrawn from the cover gas region of the electrorefiner through a heated pipe connecting the electrorefiner to the MTU. The gas is passed through the MTU and then through a gas cooler of similar construction to the MTU. The cleaned gas is returned through the opposite side of the MTU and then back to the electrorefiner close to the prevailing cover gas temperature. A bleed-and-feed subsystem allows one to purge a fraction of the cleaned gas and to maintain a constant cover-gas pressure. Capability exists for obtaining samples of the inlet and exit gas from the MTU. The system can be heated periodically to melt and drain the trapped cadmium from the system at periodic intervals. The MTU and cooler assembly were installed in a liner, and the complete system was placed in a well adjacent to the electrorefiner for testing.

The cadmium concentration in the cover-gas space (untreated) above the salt in the electrorefiner was determined to be in the range of 2000 to 4000 ppm by weight (ppmw). In tests with the CGTS, the MTU achieved very high collection efficiencies (99.38 to 99.99%) for testing periods where stable operation was achieved. The cadmium concentration in the gas exiting the MTU was significantly less than 1 ppmw. At gas recirculation rates of $5 \times 10^{-4} \text{ m}^3/\text{min}$ (1 scfm), the MTU reduced the cadmium concentration in the electrorefiner from the undisturbed level of 2000 to 4000 ppmw to less than 100 ppmw.

The CGTS was regenerated twice by heating the unit and melting the collected cadmium into a collector pot attached to the bottom of the unit. We collected two ingots of cadmium, which together weighed about 17 kg. This

compares favorably with an estimated 20-25 kg of cadmium contained in the gas entering the unit based on samples from the inlet gas. The testing of the CGTS has been completed, and the unit is being disassembled.

5. Equipment Testing

Testing of a device to harvest the uranium deposit collected on a steel mandrel cathode in the engineering-scale electrorefiner was continued.² The main elements of this device are a machined die mounted on backing plates, which are attached to a unistrut framework, welded to the glovebox floor. A bolted collar is attached to the cathode assembly, and the die positioned around a clean portion of the cathode mandrel, above the deposit. The mandrel is pulled through the die, and the stripped uranium deposit is collected in a steel basket. The main additions to the device included a screw-actuated harvester that employs a torque device to pull the mandrel out of the uranium deposit and a thin steel cylindrical sleeve to limit the diameter of the harvested deposit.

We tested a torque wrench, an impact wrench, and a modified power pipe threader for their ability to provide the needed stripping force. The impact wrench was not able to strip the uranium deposit from the steel mandrel cathode, while the other two components were. The torque wrench harvested a deposit that weighed 11.1 kg (9.3 kg uranium) and had a composition of 83.5 wt. % uranium, 10.4 wt. % salt, 0.9 wt. % zirconium, and <0.01 wt. % cadmium. A maximum force of 15, 670 N (3524 lb-f) was needed to strip the deposit. Figure III.5 shows a side view of the harvested deposit after removal of the steel cylindrical sleeve. The length of this deposit was 21 cm. The modified power pipe threader stripped a 10.6 kg deposit from the steel mandrel in 51 s.

The above tests have provided sufficient data to design a harvester device for the Fuel Cycle Facility. No further tests of the harvester are planned.

6. Zirconium Behavior in the Engineering-Scale Electrorefiner

The investigation of the zirconium behavior in the engineering-scale electrorefiner has continued (see also Sect. III.B.1). During this report

Fig. III.5. Side View of Harvested Uranium Deposit
(ANL Neg. No. 10407K, Frame 12)

period, samples were taken from deposits that formed on components immersed in the electrorefiner for various periods of time (see Fig. III.6 for locations). Samples were also taken of molten material trapped on the horizontal surfaces of the salt stirrer assembly when it had to be removed from the electrorefiner for maintenance purposes. The above samples were found to have a relatively high zirconium concentration. This suggests that "unaccounted" zirconium may be accumulating on the interior surfaces of the electrorefiner.

The first component to be removed and sampled was a corrosion rod to which two metal coupons were attached and immersed in the salt and cadmium, as shown in the Fig. III-6. This corrosion rod and coupons had been immersed in the electrorefiner for approximately one year (two 6-month periods). When removed from the electrorefiner, the corrosion rod was covered with a fairly thick deposit. (No significant deposit was observed on the corrosion rod after the first 6-month period.) Figure III.7 is a photograph of the corrosion rod. Little or no deposit was observed in the lower 5 cm, which was immersed in the cadmium. The deposit was extensive throughout the portion immersed in the salt

Fig. III.6. Samples Taken from Deposits on Components Immersed in Engineering-scale Electrorefiner

and decreased to zero above the salt. The deposit varied from about 0.6- to 1.3-cm thick. Samples A1 to A4 were taken from the rod. As shown in Fig. III.6, the zirconium content of the deposits ranged from 10.1 to 13.8 wt. %. The uranium content was about 3 wt. % except for sample A1 (used to obtain information on the possible rate of deposit accumulation in the intended location of the stirrer for the Fuel Cycle Facility electrorefiner. This rod had been immersed for two weeks and had only a thin coating on it. Samples B1 to B4 were scraped off the rod. Despite the small amount of material on this rod, these samples also showed a high zirconium content, 5.4 to 7.6 wt. %.

The third component to be removed from the electrorefiner was the salt stirrer assembly, which had to be removed to replace its motor. At that time, samples C1 to C5 were obtained. Samples C1 and C2 were deposits that had formed on the support rods; sample C3 was a deposit from the blade of the stirrer; and samples C4 and C5 were obtained from molten material that was trapped on the horizontal top surfaces of the heat baffle and the bottom plug, respectively. These samples also had high zirconium contents, ranging from 4.3 to 12.9 wt. %.

Fig. III.7. Corrosion Sample from Engineering-scale Electrorefiner with Adhering Salt, Uranium, Cadmium, and Zirconium. (ANL Neg. No. 9871K)

The above analyses indicate that deposits containing significant amounts of zirconium had built up on certain components in the electrorefiner. Because the surfaces of these components are at cathode potential during the fuel dissolution process, this behavior is not unexpected. An attempt was made to quantify the amount of zirconium on the interior wall of the electrorefiner. The amount of deposit collected on the corrosion rod and coupons was about 500 g. If a similar deposit thickness to that of the rod and coupons were formed on the

inner wall of the electrorefiner, then the amount of zirconium contained in this deposit would be 4-5 kg. This quantity represents a major portion of the 7 kg of zirconium "unaccounted for" during the many tests run with this electrorefiner.

Filtered samples were taken from the cadmium and salt several days after the above components were sampled. The results, shown in Table III.2, indicate that the cadmium was saturated with zirconium and slightly below the saturation value for uranium. As usual, the salt showed very small amounts of zirconium. Thus, the excess zirconium appears not to be mobile but attaches itself to cathodic surfaces. In a future drawdown run (i.e., electrochemical removal of all uranium present), attempts will be made to electrochemically remove the zirconium from the electrorefiner.

D. Waste Treatment Processes

Processes are being developed to treat the spent salt and metal from the electrorefiner to achieve desired levels of recovery of TRU elements and then to convert the treated salt and metal into disposable high-level waste forms. The spent salt contains the alkali metal, alkaline earth, rare earth, and halide fission products. It also contains small, but significant amounts of uranium and TRU elements. The spent metal consists of cadmium from the electrorefiner pool, which contains zirconium and noble metal fission products, and the cladding hulls. Efforts have been concentrated on developing the processes needed to treat and immobilize salt, and work has been initiated on developing methods for metal waste treatment and consolidation.

TABLE III.2. Zirconium and Uranium Content of Filtered Cadmium Samples

Sample ID	Phase	Wt. %	
		Zr ^a	U ^a
S514	Salt	<0.01	6.87
S155	Salt	<0.01	6.73
M210	Cadmium	0.23	1.93
M211	Cadmium	0.22	1.99

^aUranium solubility limit in cadmium, 2.35 wt. %;
zirconium solubility limit in cadmium, 0.22 wt. %.

The reference flowsheet for treating spent salt and metal is shown in Fig. III.8. The main process steps are as follows:

- The spent salt is passed through a multistage, countercurrent extraction process, the salt extraction step, where it is contacted with a Cd-2.2 wt. % U solution. With the proper metal/salt ratio and number of equilibrium stages, more than 99% of the TRU content is transferred to the metal phase by exchange with uranium, while more than 70% of the rare earths remain in the salt. The TRU-rich metal product is returned to the electrolyrefiner.
- Essentially all of the uranium, any residual TRU elements, and most of the rare earths are removed from the salt raffinate by contact with a Cd-0.1 wt. % Li alloy in a salt stripping step. The stripped salt, now a waste salt, contains all of the alkali metal, alkaline earth, and halide fission products; some rare earths (Y, Sm, Eu); and only trace amounts of actinides (<100 nCi/g).
- The cadmium solution from the salt stripping step is combined with spent metal from the electrolyrefiner and cladding hulls, and the excess cadmium is removed by distillation and returned to the electrolyrefiner. The remaining waste metal contains noble metal and rare earth fission products, as well as zirconium from the ternary metal fuel alloy.

Several techniques are being explored for immobilizing the treated salt and metal and converting them to high-level waste forms. To immobilize and convert the waste salt, it will be sorbed into a zeolite, and the salt-zeolite compound will be hot-pressed into a solid waste form. The metal wastes will be combined with a matrix metal or alloy (e.g., Cu, Ni, Zr-Fe, Al), yet to be selected, and pressed or melted to produce a final waste form.

Fig. III.8. Reference Flowsheet for Treatment of Salt and Metal Waste Streams in the IFR Pyroprocess (NM = noble metals, RE = rare earths, TRU = transuranics)

1. Salt Extraction

A test facility with a high-temperature centrifugal contactor (pyrocontactor) is being developed to separate elements from the rare earths in the IFR fuel cycle. This pyrocontactor is similar in configuration to the ANL centrifugal contactors developed for aqueous/organic solutions. The development work includes the design, fabrication, and assembly of a pyrocontactor and the associated processing equipment, to be housed in an argon-atmosphere glovebox test facility. Experiments will be conducted in this facility to determine the performance and extraction efficiency of the contactor with molten cadmium and chloride salts at 500°C. The ultimate goal is to develop a continuous liquid metal-salt extraction process that uses multistage, countercurrent pyrocontactors to recover the TRU elements from the waste salts produced in the Fuel Cycle Facility.

Progress toward building the test facility is summarized as follows:

- a. The pyrocontactor (made of Type 304 stainless steel) was designed and fabricated. A pretest of the contactor at room temperature without liquids was successful.
- b. The metal and salt feed tanks will be two horizontal tanks made of Type 304 stainless steel, with about 7 gal (26.5 L) capacity each. These feed tanks, along with their associated heaters and support brackets, were designed. Procurement and fabrication of the tanks and the accessories were initiated.
- c. The raffinate and treatment tanks for metals and salts, which have a liquid volume of 7 gal (26.5 L) each, were designed, fabricated, and installed. Shakedown tests are nearly complete.
- d. The design work to modify an existing glovebox (1.7-m high, 1.4-m wide, and 4.1-m long) for pyrocontactor testing is complete. Nearly completed is the assembly of this glovebox, including floor wells for the raffinate and treatment tanks, electrical and mechanical feedthroughs, end plate with electrical fittings, and gas ducts connecting the main purification system. The environmental control system for the glovebox includes a main purification system with pressure-control, emergency-control, and gas-cooling subsystems. This system will provide dry (<15 ppm H_2O) and oxygen-free (<15 ppm O_2) argon at a rate of $0.02 \text{ m}^3/\text{min}$ (40 cfm) to the glovebox. This system is also nearly assembled.

2. Salt Stripping

A prototype of the salt stripper system to be installed in the Fuel Cycle Facility has been designed and is being fabricated. The system includes the stripper vessel and a pump-and-transfer line to move salt between the engineering-scale electrorefiner and the stripper vessel. The stripper is equipped with an agitator capable of imparting mixing power densities up to 7 hp/1000 gal (1.4 kW/m^3) in the salt and 30 hp/1000 gal (5.9 kW/m^3) in the metal phase. Ports for sampling and charging materials and fittings for instrumentation, such as liquid level probes and reference electrodes, are provided.

Several small-scale experiments were done to support development of the salt stripper. In these experiments, the salt from the laboratory-scale electrorefiner was stripped to recover the heavy metals. In total, 4200 g of molten salt was contacted with Cd-Li solutions in five stripping runs. The actinides (U, Pu, Am) and rare earths (Ce and Nd) were almost completely removed from the salt solution. Nevertheless, difficulties were encountered in dissolving the reduced actinides and rare earths in the cadmium, probably because the rapid reduction from the salt resulted in the formation of slowly dissolving intermetallic compounds at the salt-metal interface. In two runs, an attempt was made to dissolve the intermetallic compounds by reducing the lithium addition rate to the metal phase (the Cd-Li was added in three steps rather than one). This completely dissolved the reduction products, but some evidence suggested that the reduction rate exceeded the dissolution rate during certain periods. The intermetallic compounds were also dissolved by raising the melt temperature from 500 to 550°C.

Experiments will be conducted with the prototype salt stripper to measure stripping rates as functions of mixing intensity, to assess the effectiveness of various filters, to determine the characteristics of insolubles, and to evaluate the performance of various components and instruments.

3. Salt Immobilization

Although the treated salt will contain only trace amounts of actinides and very small amounts of rare earth fission products, it will contain Cs and Sr and is, therefore, a high-level waste according to the definition in the Code of Federal Regulations (Title 10, Part 60). As such, it must be disposed of in a geologic repository for high-level waste. A waste form that will meet the acceptance criteria for the repository must be developed for the IFR waste salt. Although the exact acceptance criteria have not been specified, some guidance has been obtained from the Waste Acceptance Preliminary Specifications for high-level waste glass being prepared at the Savannah River Site and the West Valley Demonstration Project. Qualitatively, the waste form for IFR waste salt must be strong, leach resistant, and stable with respect to radiation and radiogenic heating. In addition, the process for producing the waste form must be amenable to remote operation and compatible with other IFR pyroprocessing operations.

With these guidelines in mind, it is proposed to use zeolite powders as an immobilization matrix for IFR waste salt. Densified salt-occluded zeolite monoliths, possibly with added strengtheners, have been proposed as the corresponding waste form. The experimental program for testing this concept has been focused on measuring the leach resistance and radiation and thermal stability of salt-occluded zeolites.

a. Leach Resistance

The leach resistance of a waste form is of paramount importance because leaching by groundwater is the most likely mechanism by which radionuclides will reenter the accessible environment. The leach resistance of waste-bearing (simulated IFR waste salt) zeolite A was measured at room temperature with deionized water as the leachant. The ratio of the volume of leachant to the mass of solid was 200 mL/g. The duration of the tests varied from 2 to 25 days. The leachability [L , in units of $\text{g}/(\text{m}^2 \cdot \text{day})$] was determined from the equation:

$$L = C_i \cdot V / (F_i \cdot SA \cdot d)$$

where C_i is the concentration of species i in the leachate (g/mL), V is the volume of the leachant (mL), F_i is the weight fraction of species i in the sample, SA is the surface area (m^2), and d is the duration of the leach test in days. Because the SA was calculated from the literature value for the average particle size ($1.39 \mu\text{m}$) and from an estimated value of the density ($2.10 \text{ g}/\text{cm}^3$), these leach test results must be considered preliminary. The leachate was analyzed for strontium by inductively coupled plasma spectroscopy and for cesium by atomic emission spectroscopy.

The leachabilities for Cs and Sr in the short-term (2-5 day) tests averaged about 10^{-3} and $10^{-5} \text{ g}/(\text{m}^2 \cdot \text{day})$, respectively. The leachability for both Cs and Sr in the 25-day test was on the order of $10^{-5} \text{ g}/(\text{m}^2 \cdot \text{day})$. Two conclusions were reached from these data: cesium is released more readily than strontium from the zeolite matrix, and leachability decreases with time. These leachability data compare favorably with the "initial" (i.e., leach period of less than 28 days), room-temperature leachabilities given for borosilicate glass,

i.e., 10^{-1} to 10^{-3} g/(m²·day).³ Also, the same time dependence of leachability is observed in tests with borosilicate glass.

However, effects on leachability, if any, of the differences in the SA/V ratios, i.e., 0.1 cm⁻¹ in the borosilicate glass and 50 cm⁻¹ for the salt-occluded zeolite, were not considered in this comparison. Notwithstanding, the leachability of the salt-occluded zeolite is well within the range that would be acceptable for repository disposal. These studies are continuing.

b. Radiation and Thermal Stability

The radiation and thermal stability of salt-occluded zeolite A has also been investigated. In these tests, three salt-occluded zeolite samples were subjected to one of the following conditions: (1) heated to 200°C (no irradiation); (2) irradiated to 8.0×10^8 rad at a dose rate of 0.63 Mrad/h in a gamma facility at room temperature (about 30°C); and (3) irradiated to 9.3×10^8 rad at a dose rate of 0.73 Mrad/h and heated to 200°C. Also included in this study was a baseline sample (no radiation or thermal treatment). After irradiation, all samples were examined with X-ray diffraction and infrared spectroscopy. Samples were also leached in deionized water at room temperature for seven days.

The results of these tests indicated that neither heat nor irradiation affected the crystal structure or the leach resistance of the salt-occluded zeolite. X-ray diffraction and infrared spectra for the four samples were nearly identical. The leachability results for all of the samples tested were the same within experimental error. The concentrations of Cs and Sr in all of the leachates were at or below detection limits. (The concentrations of Cs and Sr initially present in the salt-occluded zeolite were 1.96 and 0.965 wt. %, respectively.) The pH values of the various leachates were also the same within experimental error. It is concluded that, for the conditions tested, the salt-occluded zeolite is stable with respect to radiation and heat.

c. Alternative Salt Waste Forms

Salt immobilization methods other than use of zeolites are also being explored, including the conversion of salt into ceramic or vitreous waste

forms. A preliminary literature survey indicated that titanates and zirconates would also be attractive alternatives to zeolites. Several areas of concern with respect to these waste forms were addressed. One concern is whether ceramic waste forms could retain the cations predominant in IFR salt waste. Evaluators in several countries are considering a parallel question with respect to PUREX wastes. Some conclude that ceramics would be a superior waste form, while others disagree. Another concern is what processes could be used to extract the radioactive cations from the salt and incorporate them into titanates, zirconates, oxides, or silicates. Several reports describe carrying out such processes to prepare materials for various non-nuclear applications. Analysis of such literature will enable an evaluation of the applicability of these candidate waste forms to IFR wastes and help to identify conceptual processes for transforming the salt waste into these forms.

A second literature survey focused on finding insoluble chloride compounds, especially those that occur in nature. It was found that only silicates form complexes with chlorides that are not readily water soluble. One class of highly insoluble chloride-silicate minerals is sodalite, $\text{Na}_6[\text{AlO}_2]_6[\text{SiO}_2]_6 \cdot 2\text{NaCl}$, in which the halide salt is an essential constituent. This mineral has a crystal structure with a molecular cage similar to zeolites, and its Al/Si ratio is the same as that for zeolite A. Work to develop techniques for synthesizing monolithic sodalite structures containing IFR waste salt was initiated.

4. Metal Waste Handling

The initial work in this area has been focused on the use of copper as the matrix for immobilizing metal wastes. The main effort has involved the preparation of copper alloy specimens containing Cd and La in a laboratory-scale distillation unit. These have been prepared by dissolving Cu and La in cadmium and distilling off the excess cadmium. During these preparations, data were obtained on cadmium vaporization into a flowing argon stream as a function of cadmium content (50 to 75 wt. %), argon flow rate (30 to 500 mL/min), temperature (600 to 800°C), and pressure (atmospheric to 27 kPa). These data will be used to design a waste-metal distillation unit.

It was found that the cadmium vaporization rate was primarily controlled by diffusion in the condensed phase and was strongly affected by temperature and surface oxidation. The rate was less affected by pressure or argon flow rate. The cadmium vaporization rate was found to be linearly dependent on the vapor pressure of pure cadmium. Assuming ideal solutions, which is a good assumption for a Cu-Cd system, the data can be extrapolated to mixtures with nonvolatile components (e.g., copper) to determine the vaporization flux. With the assistance of computer modeling and the experimental data, a temperature-time profile was developed for a distillation run which optimizes efficiency and prevents splattering and solidification by keeping the effective vapor pressure within a prescribed range. This profile was used in the preparation of Cu-Cd and Cu-Cd-La alloys, but more experiments are needed to gain a better understanding of the relationship between the vapor pressure and cadmium vaporization from more complex metal mixtures. A conceptual design of a waste-metal distillation unit has been started. Materials of construction and operating parameters have been identified with the knowledge gained from the laboratory-scale tests.

Because the Environmental Protection Agency (EPA) has identified cadmium as a toxic material, one of the early objectives has been to show that a Cu-Cd waste form would not be classified as a hazardous waste. Several Cu-Cd alloys (10 to 80 wt. % Cd) have been subjected to the Toxicity Characteristic Leaching Procedure (TCLP), which is used to determine if a waste containing a toxic component is hazardous. The alloy samples specified for the TCLP must be less than 9.5 mm in diameter. These samples are tumbled for 18 hr in an acetic acid solution (pH = 5). In these TCLP tests, the milling of the brittle Cu-Cd alloys produced fine particles, from which cadmium was rapidly leached so that the leachate contained more than 1 mg/L of cadmium, which is considered a threshold hazardous level. However, the test results, when extrapolated to copper alloys with only a few percent cadmium (the expected level in IFR waste forms), indicated that such alloys would pass the TCLP and thus would be considered by the EPA as nonhazardous with respect to cadmium content.

5. Waste Form Assessment

Regulations and publications on acceptance of high-level waste for disposal were reviewed to obtain foresight on requirements for acceptance of IFR

waste. The perceptions resulting from this review were that acceptance would probably depend on (1) specifications devised in agreement with DOE Office of Civilian Radioactive Waste Management (OCRWM) during waste form development and production, (2) judgment by the repository licensee (DOE-OCRWM), and (3) the final waste acceptance specifications that evolve in the repository-licensing process.

To assess the performance of a geologic repository, with particular emphasis on the containment of long-lived radioisotopes such as ^{99}Tc , the literature on the release rates of technetium from various waste forms and the behavior of technetium in a geologic environment was reviewed. The experimental data reported by various investigators indicate that a source term for computer predictive modeling of IFR waste performance may be established if congruent dissolution and congruent leaching are assumed. A number of geochemical and performance assessment codes may be used to calculate a source term for a specific geologic environment and the subsequent migration of technetium through the geosphere. However, because the pyroprocessing of the IFR waste is still in the developmental stage, it is premature to select a performance assessment code at this time. Nevertheless, for conceptual development of an IFR waste form, the EQ3/6 computer code⁴ is being acquired to study the interaction of groundwater with the IFR waste form. This code will be used to establish the source term for the important radionuclides present in the IFR waste and to support performance assessment of the IFR waste forms under conditions of deep geologic disposal.

References for Section III

1. I. Johnson, K. E. Anderson, and R. Claypol, "Chemical Engineering Division Summary Report--July, August, and September 1960," Argonne National Laboratory Report, ANL-6231, p. 67 (1960).
2. M. J. Steindler, "Chemical Technology Division Annual Technical Report, 1990," Argonne National Laboratory Report, ANL-91/18, p. 117 (1991).
3. "Environmental Assessment Waste Form Selection for SRP High-level Waste," U.S. Department of Energy Report, DOE/EA-0179 (July 1982).
4. W. L. Bourcier, "Geochemical Modeling of Radioactive Waste Glass Dissolution Using EQ 3/6: Preliminary Results and Data Needs," Lawrence Livermore National Laboratory Report, UCID-21862 (1990).

IV. SAFETY EXPERIMENTS AND ANALYSES

A. Lessons from the PRA for EBR-II

The EBR-II Probabilistic Risk Assessment (EBR-II PRA) was recently completed. It was a level 1 PRA directed at analysis of systems to identify accident sequences in the reactor plant which would lead to core damage in some sense (even mild core damage). The analysis stopped at core damage, and did not extend to the analysis of subsequent scenarios for release of radioactive materials to and beyond the containment. The scope of the EBR-II PRA included shutdown accidents and external events, (the seismic portion is not yet complete). Passive safety response--both passive reactivity shutdown and passive decay heat removal--was explicitly accounted for in the event trees.

The risk of operation of EBR-II was found to be very low, (of the order of 10^{-6} per reactor year for even mild core damage), with no one accident or class of accidents dominating the risk profile. The value of this result lies not in the low numerical value of the accident frequency as it compared with other plants but in having extracted the underlying causes of this favorable result in terms of quantifying the payoff of the specific sound engineering design principles which led to the low damage frequency. These lessons learned can now be applied to the future IFR design refinements.

Figure IV.1 shows a simple event tree which describes the basic requirements for safe shutdown of EBR-II (or any reactor), given an initiating event, the scram event and the decay heat removal event. If this sequence is accomplished safely, then no damage to fuel will occur. Two classes of accident sequences are shown in Fig. IV.1; the first arises after successful scram when the decay heat removal function fails, the second occurs in the event of failure to scram. The primary issues for EBR-II PRA are then the reliability of the Reactor Shutdown System (RSS), and the reliability of Decay Heat Removal. In the case of EBR-II added protection is provided by the fact that, even if scram is not successfully carried out, the passive feedbacks are such that the resulting unprotected accident may not lead to core damage--a demonstrable feature of EBR-II and the IFR. Similarly, a decay heat removal path at EBR-II relies on passive rather than electrically-driven equipment so that even if the designed heat removal paths fail, a passive backup remains in operation.

Fig. IV.1. Simple Generic LMR Event Tree

Consider first the initiating events which require reactor scram. The PRA for EBR-II identified about four per year as the estimated frequency based upon a conservative analysis of the last 15 years of EBR-II operation. The scram reliability for EBR-II was typically estimated at 5×10^{-6} per demand (the actual value is initiating-event dependent). This result depends greatly upon hypothetical common cause events in the fault tree analysis.¹ (Note that a modern scram system can achieve much higher reliability than this, $0(10^{-7})$, as long as the design has sufficient redundancy and diversity.) The probability of an unprotected accident sequence at EBR-II is approximately 2×10^{-5} per year; the vast majority of these sequences lead, however, to an absolutely benign outcome because of the passive reactivity feedbacks. Even adopting the extremely conservative definition of damage which was used in the EBR-II PRA, (the definition classifies all temperatures which exceed the Technical Specification Limits as damage), fully 93% of the sequences, given failure to scram, lead to no damage to driver fuel. The conclusion is that about 1.0×10^{-6} per year is the probability that an unprotected accident sequence leading to driver fuel temperatures exceeding EBR-II Technical Specification Limits will occur. If

desired, this risk at EBR-II could be reduced by at least an order of magnitude for a modern LMR by using a modern scram system design, which can be shown to be immune to common cause events.

In the case of those accidents arising from loss-of-decay heat removal capability, the PRA identified about 11 initiating events per year. (Even a routine shutdown requires the decay heat removal system to be functional and so the seven routine shutdowns a year at EBR-II are included and summed with the four scram events). EBR-II is designed with passive redundant decay heat removal capability through both the Balance-of-Plant and through two shutdown coolers. Through careful design these systems are able to perform their functions without electrical power, which removes an important factor observed in the risk of LWR power plants, namely, electrical dependencies of the decay heat removal function. The mission time for decay heat removal was taken to be 45 days in order to include all the shutdown risk and, even in those circumstances, the probability of failure was estimated to be about 2×10^{-8} per demand, with failure being defined as the sodium pool reaching a temperature of 1000°F (a Technical Specification limit on internal structural components). The resulting overall damage frequency is 2×10^{-7} per year. This result serves to emphasize the value of passive decay heat removal from the vessel, natural circulation cooling of the core, and a design which provides redundant means of accomplishing this without the requirement for electrical power, thus removing many sources of risk through lack of diesel power, human error, etc. This feature is also important in the external event analysis.

The remaining contributions to the risk of operation of EBR-II, and by extension to any LMR, arise from those rare but conceivable events which are inherently difficult to quantify. These rare events include steam generator tube ruptures, major structural failures, and local faults. Structural failure is a very low probability event, $< 10^{-7}$ per year; however, a causative mechanism was identified in EBR-II which allowed for a meaningful evaluation. The hypothetical cause involved over-pressurization of the cover gas by a failure of the argon supply regulating system--combined with undetected blockages of the relief systems due to sodium condensation. Though not a prominent contributor to risk, this event was judged to be sufficiently important to highlight a generic "lesson learned" requirement for support systems to be designed with the same regard to

inherent limitation, (in this case limitation of the ability to over-pressurize) as is used on design of IFR primary systems.

Because of the violent chemical reactions possible in the Na-H₂O-O₂ system, steam generators in LMRs have traditionally been a source of much design effort to minimize the chance for Na-H₂O contact. Even so, LMRs in Russia and the United Kingdom have experienced energetic events. The steam generators at EBR-II are of a double-wall design, and have proved to be trouble-free for 25 years of operation. Despite this, steam generator tube ruptures are in general still important contributors to risk--in the EBR-II case primarily because of the absence of fast-acting water and sodium dumps--which absence renders the EBR-II IHX vulnerable in the event of an energetic reaction in the steam generator. Thus, the lesson learned here is that effort must be applied on the design of the steam generators and pressure relief systems so as to ensure that the consequences of energetic events do not impair the IHX or primary system integrity.

In all cases of rare events discussed above, a fundamental principle can be extracted. First, in conducting a PRA one can almost never totally eliminate a rare event on the grounds of its probability of occurrence because its probability is poorly known; and the best one can hope for is by intelligent design, which is consciously addressed at each such identified rare event, to reduce the initiating probability to small values ($<10^{-7}$ per year); Therefore, one must in addition take additional measures to reduce the consequences of the rare events with appropriate mitigative systems.*

The external event analysis can be divided into two parts, again by reference to Fig. IV.1, those which require a scram and those which challenge the decay heat removal capability. EBR-II has a seismic scram, set at 0.005 g, and detailed analysis confirmed that drop of the control rods was extremely reliable. (Note that an effective seismic scram also removes concerns about reactivity insertion through seismically-induced oscillations of the core support.) Indeed,

*Even though a rare event may lead to no core damage whatsoever, regulatory or political consequences may be quite severe and thus in the design of a modern LMR the focus should be on the first goal--must seek to minimize the probability of rare initiating events by intelligent design.

because of the seismic scram system and the fact that only one or, at most, two control rods are required to be dropped for shutdown to take place, no external event which could impair the scram function was found. In particular no way was identified in which a fire or flood could lead to a situation in which all the control rods remained energized.

The effect of external events on the decay heat removal function for reactors is usually via electrical power, with fires and/or floods leading to disablement of electrical power supplies. In the case of EBR-II, electrical power is not required for decay heat removal. Overall the risk-dominant non-seismic external event for EBR-II is a liquid-metal fire under the deck plates disabling all decay heat removal. The consequences of such an event could be minimized in future IFR designs by argon inert systems and good physical separation of the various decay heat removal paths. Though the seismic PRA for EBR-II is not yet complete, the currently anticipated dominant seismic event is a massive structural failure of the primary tank support system at a median of 0.7 g--leading to failure of the decay heat removal function. (This would be equivalent to failure of seismic isolation in a modern seismically-isolated IFR plant.)

In Probabilistic Risk Assessment, the assessment is intended to be "best-estimate" with engineering conservatism removed. Nonetheless, it is inevitable in the early stages of a PRA that "damage" is assessed conservatively, that is to say, accident sequences whose end states cannot unambiguously be shown to be benign are included in the damage category. The EBR-II PRA is no exception. Equally, in evaluating the probabilities associated with system response, excessive conservatism can be introduced through, for example, the treatment of common cause. A good example of how uncertainty can serve to mask results is in comparison of seismic PRA results with conventional PRA results where the uncertainty about the frequency of very large earthquakes distorts the hazard curves and leads to seismic risk values of $O(10^{-5})$ for a plant whose median fragility is 0.7 g. Thus even though the seismic PRA for EBR-II is not yet complete it is already known that seismic risk will dominate the results because of the shape of the hazard curve--the risk resulting from the shape of the hazard curve is dominated by uncertainty in the return frequency of very large earthquakes. Thus, the EBR-II PRA results inevitably over-estimate the numerical value of risk of operation of EBR-II.

The EBR-II PRA effort has provided invaluable guidance in the form of lessons learned which may be applied to design issues for future LMRs.

B. Passive Safety Characteristics of Low Sodium-Void-Worth Core Designs

A low sodium-void-worth actinide burner core design using metallic fuel has been developed which has a flat annular geometry and a core power of 1575 MWth. The core design is discussed in detail in Sect. V.A. In this section, the transient performance of this reactor core in response to several types of unprotected, i.e. unscrammed, accidents is reviewed. The transient response has been calculated using the SASSYS LMR Systems Analysis Code, Version 2.1. The emphasis in the analysis was to quantify the minimum margin to coolant boiling and fuel/cladding eutectic penetration during the transient. The reactor response was governed entirely by passive reactivity feedback mechanisms. The analyses considered three accident sequences: an unprotected loss-of-flow (ULOF) in which electric power to all pumps is lost; an unprotected transient overpower (UTOP) in which one or more inserted control rods are inadvertently withdrawn; and an unprotected loss-of-heat-sink (ULOHS) in which all normal heat removal capability is lost without reactor scram. The initial conditions for all transients were taken to be the normal full-power operating conditions at the end of an equilibrium burnup cycle (EOEC). All analyses were conducted on the basis of best-estimate modeling assumptions.

1. Unprotected Loss-of-Flow Results

The unprotected loss-of-flow accident is initiated by a loss of electric power to all coolant pumps with failure to scram the reactor. The coolant pumps coast down according to their inertial characteristics, which for this study provided an initial flow-halving time of 6 s. As a result of the change in flow, the core temperatures increase, generating reactivity feedback. This in turn changes the reactor power. The results for the changes in power and flow are shown in Fig. IV.2, which indicates that both power and flow drop rapidly. The peak in the power-to-flow ratio occurs at about 20-30 s after the start of the transient. By 120 s, the power-to-flow ratio has returned nearly to a value of 1.0. The reactivity feedbacks and the core temperatures are also shown in Fig. IV.2. The major reactivity feedback mechanisms are radial expansion

Fig. IV.2 Power, Flow, Reactivities, and Core Temperatures as a Result of a ULOF Accident in a Low Sodium-Void-Worth Actinide Burner Using Metallic Fuel

of the core and control rod driveline expansion. The radial core expansion mechanism is dominant early in the transient due to its short time constant compared to control rod driveline expansion. After about 60 s, expansion of the control rod driveline becomes dominant. The only positive reactivity feedbacks are from fuel Doppler and axial contraction of the fuel as the fuel temperature is reduced. The magnitude of the positive feedback is much less than that of the negative reactivity feedback.

As a result of the large net negative reactivity feedback, the power reduces rapidly in response to the flow coastdown and the mismatch in power and flow is not great. The maximum coolant temperature in the core peaks at 721°C at 27 s after the start of the transient. The margin to the coolant saturation temperature is over 200°C. The coolant temperature drops rapidly after the peak, down to less than 600°C by 100 s. The cladding temperature peaks at 730°C, over the threshold for formation of fuel/cladding eutectic material, but perhaps 150-200°C below the threshold for rapid formation and cladding penetration. The total time that the cladding is above the formation threshold is less than 1 min, and should result in negligible cladding damage. These results are consistent with the results obtained previously for a 3500 MWth core, which had nearly the same core diameter, but with a positive sodium void worth.² The peak temperatures for the low sodium-void-worth core are approximately 100°C lower.

2. Unprotected Transient Overpower Results

The unprotected transient overpower accident is initiated by an uncontrolled withdrawal of one or more control rods, with failure to scram the reactor. Nominal coolant flow is maintained. The increase in power causes an increase in core temperatures, generating reactivity feedback, which in turn modifies the power. For this core, the maximum single control rod worth, including a rod interaction factor, is \$0.78. For the purposes of this analysis, the reactivity addition rate is assumed to be 0.01 \$/s. The core power increases until all of the reactivity from the withdrawing rod has been added, at 78 s. The core power peaks at 165% of nominal power, and then drops to 150% of nominal power by 100 s after the start of the transient. The major negative reactivity feedback mechanisms counteracting the reactivity addition are control rod

driveline expansion and radial expansion of the core. All other reactivity feedback components are near zero.

Due to the increase in core power, the maximum coolant temperature in the core peaks at 675°C at 78.5 s, and then decreases to 650°C by 100 s, stabilizing at that value. The peak cladding temperature is 712°C, which drops to 685°C by 100 s. The minimum margin to coolant boiling is over 300°C in this case. After 100 s, the reactor appears to have reached a new equilibrium state, under the assumption that the core inlet temperature remains constant throughout the transient. While this may be true during the early stages of the transient, the heat exchangers are probably not capable of continuously rejecting 150% of nominal power, and some core inlet heating will occur. The elevated power may cause a loss-of-heat-sink at the steam generators. These accident consequences are also consistent with the results obtained previously with the 3500 MWth core design, but the peak core temperatures are approximately 75-100°C higher for the low sodium-void-worth design due to the much greater control rod worth.

3. Unprotected Loss-of-Heat-Sink Results

The unprotected loss-of-heat-sink accident is initiated by the loss of the main heat sink at the steam generators, with failure to scram the reactor. The coolant flow is maintained. As a result of the loss of the main heat sink, the core inlet temperature starts to rise shortly after the start of the transient, at about 50 s. This increases the core temperatures, introducing negative reactivity feedback, which in turn reduces the core power. The negative feedback is dominated by radial expansion of the core. The negative feedback is large enough such that the power and the coolant temperature rise through the core is decreasing faster than the inlet temperature is rising. The result is that there is no increase in the maximum core temperature. Rather, the peak core temperatures decrease monotonically to a new level below the initial steady-state value. At the same time, the core temperatures in the lower part of the core are increasing, and the core temperature rise through the core decreases to only a few degrees. The new "equilibrium" state, which is reached by about 1000 s after the start of the transient, has an almost uniform core temperature of 510°C. The reactor power is at decay heat levels, with the net reactivity being subcritical and becoming more negative with time. The margins to coolant boiling and

fuel/cladding eutectic penetration are larger than at steady-state conditions. These results are also consistent with the results obtained for the 3500 MWth core, although the "equilibrium" state temperatures are approximately 65°C lower with the low sodium-void-worth core.

4. Conclusions

The passive response of a low sodium-void-worth actinide burner to various unprotected accidents has been analyzed. The margins to coolant boiling and fuel/clad eutectic formation for the ULOF and the ULOHS are greater for the low sodium-void-worth core than for the 3500 MWth core previously analyzed, due to the larger reactivity feedback obtained from the control rod driveline and radial core expansion. The favorable safety characteristics of metallic fuel, which have been demonstrated previously for "conventional" reactor designs where the sodium void worth is not zero, are also effective for the low sodium-void-worth design. The margins to coolant boiling and fuel/clad eutectic formation are smaller for the UTOP accident with the low sodium-void-worth core due to the much larger worth of the single control rod initiator.

C. Implications of Whole-pin Furnace Test Results on the EBR-II Mk-V Fuel Safety Case

A Safety Analysis Report is being written for the conversion of EBR-II to Mk-V driver fuel. The Mk-V driver is a plutonium-bearing fuel which will be fabricated in the Fuel Cycle Facility (FCF). Whole Pin Furnace tests FM-4 and FM-5 have been conducted specifically to support the safety case that is being developed for this fuel. The present section provides the preliminary results from these tests along with an assessment of the implications of the test results on the safe operation of EBR-II with Mk-V fuel.

An important part of the Mk-V safety case is the analysis of fuel pin behavior during normal operation and during off-normal transients. The LIFE-METAL and FPIN2 computer codes are playing a key role in these analyses by providing state-of-the-art tools for calculating the neutronic thermal and mechanical response of the fuel pins. The Whole Pin Furnace test results are being used as part of the database to validate the application of these codes to

the Mk-V fuel. Consequently, also included here are descriptions of these codes along with the results of pretest predictions for Tests FM-4 and FM-5.

An earlier Whole Pin Furnace test, FM-2, was conducted on a 3 at.% burnup, U-19Pu-10Zr/HT9 fuel pin with more aggressive design parameters (i.e., smaller plenum) than the Mk-V fuel. The thermal conditions of the FM-2 test (820°C peak cladding temperature) and duration to pin failure (112 min.) were also more severe than for the worst-case reactor accident scenario that has been identified for the Mk-V design basis. The results from the FM-2 test are important to the Mk-V safety case because they show that low burnup pins will have a considerable margin to failure. This test has also contributed to the data base for validation of LIFE-METAL and FPIN2. Although some discussion of the FM-2 test is included here, the present section concentrates on the preliminary results from the FM-4 and FM-5 tests on high burnup fuel. The fuel burnup and test parameters for these experiments envelope the most severe duty cycle conditions for Mk-V fuel.

1. Mk-V Fuel Design

The reference Mk-V fuel pin design uses a U-20Pu-10Zr metallic fuel slug with HT9 cladding. A design variation (Mk-VA) with Type 316 Stainless Steel is also being included in the safety case. However, the initial Whole Pin Furnace tests, which are discussed here, have concentrated on HT9-clad pins. A comparison of the as-fabricated parameters and burnup of the Mk-V fuel with those of the FM-4/FM-5 and FM-2 test pins is given in Table IV.1. The interim goal burnup that is being requested for the Mk-V fuel is 10.0 at.% (peak).

2. Bounding Design Basis Transients

Part of the Mk-V fuel safety case has been the analysis of the neutronic/thermal/mechanical response of the fuel to the EBR-II duty cycles for normal and off-normal operation during the fuel lifetime. The off-normal transients have been grouped into categories having similar thermal behavior. Each category has been characterized by an "umbrella" (bounding) transient, which is the most severe transient of that group. The most severe of these umbrella transients, in terms of duration at elevated cladding temperature, is the UN 1

TABLE IV.1. Comparison of As-Fabricated Fuel Pin Parameters and Burnup

Parameter	Mk-V	FM-4/FM-5	FM-2
Element/Subassembly	---	DP22/DP15/X441A	T461/X425
Cladding Type	HT9	HT9	HT9
Pu, wt. %	20.0	19.0	19.07
Zr, wt. %	10.0	10.0	9.78
Smear Density, %	75.0	74.0	72.5
Fuel Slug Diameter, in.	0.168	0.172	0.170
Fuel Slug Length, in.	13.50	13.56	13.56
Cladding Outer Diameter, in.	0.230	0.230	0.230
Cladding Thickness, in.	0.018	0.015	0.015
Plenum Volume, cm ³	7.1	7.48	4.95
Plenum-to-fuel Volume	1.45	1.45	0.98
Sodium Volume, cm ³	2.0	1.95	2.09
Peak Burnup, at. %	10.0	11.4	2.7

Unlikely Loss-of-Flow (LOF) event. Because cladding damage (both mechanical and eutectic attack) is a very strong function of time-at-temperature, this transient was chosen as the reference "worst-case" transient for the FM-4 and FM-5 simulations.

3. Whole Pin Furnace System

The Whole Pin Furnace (WPF) system³ is in operation in the Alpha-Gamma Hot Cell Facility (AGHCF) at Argonne National Laboratory. The system simulates the response of fuel pins to reactor transients by heating intact, irradiated fuel pins in a computer-controlled infrared radiant furnace. The major components of the WPF system are an in-cell furnace rig, a furnace control and data collection system, and a fission-gas measurement system. Ancillary components of the WPF system include a glycol/water heat exchanger for cooling the furnace body and nitrogen and helium gas supplies for lamp cooling and environment control.

4. IFR Fuel Pin Behavior Codes

The LIFE-METAL and FPIN2 computer codes have been developed to model the thermal-mechanical behavior of IFR metallic fuel pins. These codes are intended to provide the "state-of-the-art" understanding of metal-fuel damage and provide reference analyses against which simpler, but less general, models may be tested.

The LIFE-METAL code⁴ is used for the analysis of metallic fuel pins under operational conditions, while FPIN2⁵ is used to analyze accident conditions. Although there is some overlap in capabilities for handling off-normal conditions, the emphasis in the development and validation of the codes is very different. LIFE-METAL has focused on steady-state fuel behavior, while FPIN2 has focused on transient fuel behavior. The codes use different numerical analysis methods, but LIFE-METAL and FPIN2 share a common set of material properties. LIFE-METAL incorporates detailed models for predicting steady-state fuel behavior, but does not include detailed high-temperature fuel behavior models for accident analysis (e.g., fuel melting). FPIN2 incorporates models related to accident analysis but requires the user to provide input data describing the pretransient/steady-state conditions. This input can be obtained from LIFE-METAL calculations as is the case here, or data (e.g., fuel geometry, fuel microstructure, fission gas remaining in the fuel) from sibling pins. Both FPIN2 and LIFE-METAL are being used to make pretest predictions for the WPF tests.

5. Description of Tests FM-4 and FM-5

During FY 1991, two WPF tests, FM-4 and FM-5, were conducted specifically to support the Mk-V safety case. Both tests used U-19Pu-10Zr/HT9 fuel pins with design parameters that are essentially the same as the Mk-V fuel, except for the thinner cladding (0.015 vs. 0.018 in. for the Mk-V). Table IV.1 provided a comparison of the as-fabricated conditions for the two fuels. The WPF test pins, DP-22 and DP-15, were irradiated in EBR-II Subassembly X441A to a peak burnup of 11.4 at.%, which is higher than the Phase-I burnup goal (10 at.%) for the Mk-V fuel. The peak power in these pins (15 kW/ft) and peak cladding temperature (600°C) at the beginning of life during the EBR-II irradiation encompass the proposed Mk-V driver operating envelope in EBR-II. The results from WPF tests FM-4 and FM-5 are therefore conservative from the standpoint of Mk-V performance.

The two WPF tests were conducted as a pair with complementing objectives. Test FM-4 was conducted as a run-to-cladding-breach test to demonstrate the safety margin of a high burnup, Mk-V-type fuel pin in a simulated loss-of-flow (LOF) event in EBR-II. Test FM-5 was conducted as a proof test to demonstrate that a high-burnup, Mk-V-type fuel pin can endure the simulated LOF event with only minor incremental cladding strain and wastage, and no cladding breach. The LOF event chosen for temperature simulation was the UN-1 event which, as discussed above, results in the highest cladding temperatures for the longest duration among the various design basis transients.

The calculated peak cladding temperature history upon which the FM-4 and FM-5 simulations were based is shown by the dashed curve in Fig. IV.3. This history was calculated for an EBR-II Technical Specification Limiting Row 6 Subassembly temperature rise of 340°F (189°C). The temperature history shows two temperature peaks; the lower peak, 678°C, occurs at 4 s and the higher peak, 780°C, occurs at 40 s following the initiation of the LOF event. The first peak occurs when the reactor is scrammed while the second peak occurs when the flow is minimum. After reaching the second peak, the cladding temperature drops below 600°C at 90 s and remains low thereafter. Since the 600°C temperature is at the level comparable to the peak cladding temperature of the pin during steady-state operation, one might consider the temperature excursion in this worst-case UN-1 event to be effectively over in less than 2 min.

Fig. IV.3. Comparison of the Measured Temperature at the Top of the Fuel in the FM-5 Test with the UN-1 Peak Cladding Temperature History

In designing the thermal conditions for test FM-4 and FM-5, the detailed UN-1 cladding temperature history in Fig. IV.3 was not followed. Instead, the furnace was programmed to provide a cladding temperature-time condition that would envelope the calculated temperature history. Test FM-4 was designed as a run-to-cladding-breach test using a ramp-and-hold temperature history similar to that used in the previous FM-1, FM-2 and FM-3 experiments. A hold temperature of 780°C was selected in order to demonstrate that Mk-V fuel could survive the worst-case transient for longer than the transient duration even if the cladding temperature were to remain at its maximum value. The actual FM-4 test temperatures at the top of the fuel rose to 790°C during the heatup, then dropped to 760°C, followed by a slow rise to a steady-state temperature of 770°C.

Test FM-5 was designed as a proof test to demonstrate that a transient similar to the UN-1 LOF event would not damage the pin beyond the limits established by the Mk-V design criteria. As shown in Fig. IV.3, the FM-5 temperature history effectively enveloped the UN-1 temperature history for the time over which transient damage might be expected.

6. Preliminary Results from Tests FM-4 and FM-5

Preliminary results from FM-4 and FM-5 include measured temperature histories, cladding breaching threshold (FM-4 only; the FM-5 pin endured the simulated LOF event with no cladding breach), gamma scanning, neutron radiography (FM-4 only), and diametral profilometry (FM-5 only). The pressure transducer output in FM-4 behaved like a step function near the end of the test; the capsule pressure remained low until the cladding breached at 4094 sec (68.2 min) into the test. Almost instantaneously, the fission gases released from cladding breaching raised the capsule pressure from a background of 1.1 psia to a peak of 19.8 psia. The furnace was automatically tripped, as planned, when the pressure exceeded the trip setpoint of 2.1 psia.

Pre- and posttest Zr/Nb⁹⁵ gamma scans of the fuel pins showed a slight fuel-column elongation in FM-4 and no discernible change of fuel column height in FM-5. Neutron radiography of FM-4 at HFEF confirmed the fuel elongation, a modest 0.9% based on as-irradiated fuel column height of 13.81 in. Neutron radiography of FM-4 revealed no sign of fuel debris outside the cladding in the fuel column region; however, a substantial portion (3.5 in.) of cladding in the plenum region had increased in diameter with an estimated strain of 10%.

The FM-5 fuel pin survived the simulated LOF event with no cladding breach. Contact profilometry of the pin showed peak incremental cladding strains to be $\leq 0.1\%$ in the entire fuel region and 2.7% in the upper plenum (21 in. from the fuel bottom). The peak temperatures within these two regions during the test were 780 and 870°C, respectively. The 780°C peak temperature at the fuel top was the desired test condition for FM-5 (see Fig. VI.1); the 870°C peak temperature in the plenum was non-prototypical because of external heating and the transient nature of the test. (In the plenum region, due to the reduced thermal inertia, the temperature ramp was more severe than in the fuel region.) In future WPF tests with temperature transients similar to FM-5, additional measures will be taken to reduce this nonprototypicality.

7. LIFE-METAL and FPIN2 Calculations for Tests FM-4 and FM-5

Pretest predictions for WPF test FM-4 were performed using the LIFE-METAL and FPIN2 computer codes. These calculations used the planned thermal history for the test to input the cladding surface temperatures as a function of time. The thermal and mechanical response of the fuel pin to the FM-4 transient was then calculated using the same versions of the codes as those being used for the Mk-V safety case. Pretest predictions for test FM-5 were not reported. However, preliminary FPIN2 posttest analyses have been performed and the results are reported here. A summary comparison of calculated results with measured results for tests FM-4 and FM-5 is given in Table IV.2.

a. LIFE-METAL Pretest Analysis of FM-4

The LIFE-METAL WPF test calculations used the same version of the code and the same material behavior models as were used here to predict the pre-transient characterization of the test fuel. Predictions of fuel pin failure during the WPF tests were based on one of several failure criteria that are monitored within the code. The three failure criteria for HT9 cladding are: (1) a steady-state cumulative damage fraction (LMSS) based on long-time,

TABLE IV.2. Comparison of LIFE-METAL and FPIN2 Calculations with the Preliminary Results from WPF Tests FM-4 and FM-5

TEST	Failure Time, min			Eutectic Penetration, %			Failure Strain, %		
	FPIN	LIFE	TEST	FPIN	LIFE	TEST	FPIN	LIFE	TEST
FM-4	4.4 ³ 16.0 ¹	9.0 ¹ 15.0 ²	68.2	2.0 ³ 8.0 ¹	3.0 ¹ 5.0 ²	-	6.0 ³ 15.0 ¹	0.7 ¹ 2.0 ²	~ 10
FM-5	No failure ³ No failure ¹	-	No failure	0.15	-	-	0.6 ⁴	-	< 0.1 ⁴

¹Transient cumulative correlation.

²2% cladding strain criterion.

³6% cladding strain criterion.

⁴Peak strain in fuel column region.

steady-temperature, steady-pressure stress-rupture tests; (2) a 2% thermal creep strain limit (LMD) calculated using a correlation for long-time creep deformation of alloy HT9 and (3) a transient cumulative damage fraction (LMTR) based on FCTT⁶ transient burst tests of pressurized HT9 cladding tubes heated at a constant temperature ramp rate. In addition, the code contains a formalism for reducing the effective load bearing cladding thickness due to carbon depletion or liquid eutectic penetration. The rate of liquid eutectic penetration into the cladding was based on FBTA⁷ data from tests on siblings to the WPF test pins.

The planned FM-4 transient was a 6°C/s ramp from 500°C up to a peak cladding surface temperature of 780°C, followed by a hold at constant temperature until fuel pin failure was detected. For these conditions the transient cumulative damage fraction calculation in LIFE-METAL predicted that the test pin would fail at about 9 min (540 s) into the transient. If the thermal creep strain criterion were used, the predicted failure time would be about 15 min (900 s). The primary cause of failure at either time is stress rupture and not eutectic thinning of the cladding. The total predicted penetration at the two failure times was only from 12 to 19 microns, or 3-5% of the cladding thickness. Results using the steady-state cumulative damage fraction are not given in Table IV.2 because it was recognized from the results of the FM-1 and FM-2 tests that this criterion is not valid for the FM-4 and FM-5 test conditions.

b. FPIN2 Pretest Analysis of FM-4

Because FPIN2 is a transient analysis code, the cladding failure criteria that are contained in the code are based on transient failure data. The two criteria for HT9 cladding that have been used in analyzing the WPF tests are a transient cumulative damage fraction (the same as LMTR criterion in LIFE-METAL) and a 6% plastic strain to failure. Both of these criteria were derived from the results of the HEDL FCTT transient burst tests. It should be noted that one of the differences in the modeling between FPIN2 and LIFE-METAL is that FPIN2 uses a cladding deformation constitutive model that is based on the results of high-temperature tensile tests while the cladding deformation model in LIFE-METAL is based on the results of longer-time creep tests. The FPIN2 model generally predicts larger strains. A second difference is in the

calculation of cladding eutectic penetration. LIFE-METAL used FBTA data from sibling pins to analyze the eutectic penetration in the WPF tests while FPIN2 used the "ANL" correlation.⁸ This correlation, which was derived primarily from earlier dipping test data on uranium and iron, is known to over-predict the penetration rate for most of the FBTA tests on IFR fuels. For instance, the penetration rate predicted by this equation at the 780°C temperature of the FM-4 test is 0.034 micron/s; the predicted rate for the LIFE-METAL correlation based on sibling pin data is 0.020 microns/s.

A summary of the FPIN-2 calculated fuel pin failure conditions is given in Table IV.2. If the 6% failure strain criterion (0.06) is used, the predicted failure time is 265 s (4.4 min). At that time the eutectic penetration fraction is only about 0.02 (2% of the wall) and the cumulative damage fraction is 0.34. If there were perfect correspondence between the cladding strain criterion and the cumulative damage criterion, one would expect a life fraction of 1.0 at this point. However, a life fraction of 0.34 is within one standard deviation of the FCTT data so this inconsistency is not great. If failure is assumed to occur when the cumulative damage fraction equals 1.0, the predicted failure time is 935 s (15.6 min). The cladding strain at this point has reached 15%. This large of cladding failure strain is not outside of the FCTT data base. The eutectic penetration at 935 s is again small (8% of the wall) so the primary cause of failure is stress-induced rupture.

c. FPIN2 Analysis of FM-5

The cladding surface temperatures during the FM-5 test were obtained from the thermocouple measurements along the length of the test pin. The cladding surface temperatures were inserted into the FM-4 input data set and the FPIN2 calculations repeated for the FM-5 transient. The resulting values of the peak cumulative damage fraction, the peak cladding plastic hoop strain and the peak fractional eutectic penetration at the top of the fuel column are given in Table IV.2. In the FM-5 test, which simulated the temperature history in the worst-case design basis accident (UN-1) for Mk-V fuel, the peak cumulative damage fraction, cladding strain and eutectic penetration only reached 0.029, 0.64% and 0.143%, respectively. Comparison of the calculated results of the FM-5 tests with the Mk-V fuel transient design criteria shows that the criteria are

satisfied with sufficient margin for this worst-case unlikely event so that any additional damage for the anticipated events (which are much more benign) could be tolerated.

D. Fuel Cycle Facility Safety Analysis

In parallel with the modifications of the former Hot Fuel Examination Facility/South (HFEF/S), now renamed Fuel Cycle Facility (FCF), and the design of process equipment to carry out the IFR fuel cycle demonstration program (discussed in Sect. VI), an extensive safety analysis program was undertaken, culminating in the production of the FCF Final Safety Analysis Report (FSAR). This section presents a summary of the major safety-related issues that were addressed in the FSAR.

1. Safety Aspects of FCF Design

The argon and air hot cells are surrounded by operating areas that are served by an exhaust ventilation system that is separate from the hot cell ventilation exhaust and off-gas systems. This results in a minimum of two separate confinement barriers except in a limited area of the air and argon cell roof. The hot cell atmosphere pressures are maintained negative with respect to the operating areas to prevent the backflow of contamination. In addition, all ventilated areas containing loose contamination are provided with high efficiency particulate air (HEPA) filters at ventilation inlets. The argon cell is cooled with recirculated argon that is refrigerated in the out-of-cell portion of recirculation loops. There are two such cooling loops, each with a capacity approximately equal to the expected heat load in the cell, so that even if one loop failed, hot-cell operations are unlikely to be seriously impacted. The cooling loop design is such that the cell atmosphere is exchanged every 6 or 7 min which, combined with full-flow HEPA filtration, keeps suspended particulates in the cell atmosphere at very low levels. This is important in minimizing the particulate release that accompanies the small purge of argon atmosphere necessary to control nitrogen levels for fuel processing.

The FCF modifications were conducted in accordance with the Department of Energy (DOE) General Design Criteria Manual,⁹ the codes and

standards guide developed by the Brookhaven National Laboratory (BNL),¹⁰ and the mandatory DOE standards.¹¹ Earthquake analyses of the cells, foundations, and building were conducted by dynamic methods using the finite-element ANSYS code.¹² DOE-sponsored guidelines for site-specific natural phenomena¹³ were utilized in this effort. Although the FCF is classified as a moderate-hazard facility under DOE guidelines, it was modified using seismic loadings recommended for application in high-hazard facilities. Furthermore, for added conservatism the only new structure being built for the FCF was designed for even higher seismic loadings.

The original FCF hot cells were designed using static load methods, and with less severe earthquake accelerations than are presently required for nuclear facilities. It was necessary to reanalyze their seismic response using dynamic analysis methods, as now preferred by the DOE. These new analyses showed that the basic structural integrity of the cells and their foundations is adequate. However, a Safety Exhaust System (SES) was added to maintain adequate inward flow through any breaches that might occur in the cell boundary, because of numerous cell boundary penetrations and a DOE requirement for no unfiltered release, even in a design basis earthquake. This special exhaust system (see Fig. IV.4) was designed to applicable safety-class standards.

Fig. IV.4. Schematic of Safety Exhaust System

Following postulated breaches in the argon cell boundary, it must be presumed that air will enter the cell, resulting in the eventual combustion of exposed hot process metals, primarily heavy metal. Such combustion would cause the oxides of fission products and transuranic metals to become airborne. It is the primary requirement of the SES to prevent unfiltered release of these radioactive materials through such breaches by maintaining inflow and exhausting the cell atmosphere through two sets of HEPA filters in series. It does this by maintaining particulate capture velocities >0.635 m/s across the breach area. To assure this capability under design-basis metal-fire accident conditions, the exhaust system must remove cell atmosphere at a rate that accommodates expansion of cell gas due to heatup (i.e., from the sensible heating effects of the in-cell metal fire, radioactive decay of fuel and waste in storage, and heat transfer from the cell liner and from process equipment). To minimize the burden on the SES, all electrically powered heat loads are automatically shed when the SES is activated.

The FCF contains a "hot repair" area in the basement, with two confinement levels, in which equipment can be washed/decontaminated and subsequently repaired, either by suited-entry hands-on maintenance, or by use of a glove wall to protect the operator from excessive radiation exposure. All contaminated waste water from washing (and all other minor streams of contaminated water generated in the facility) is evaporated so that no contaminated liquid waste is released to the environment.

Achieving passive safety in the FCF was a primary objective. The protection provided personnel by the highly shielded hot cell walls, natural-circulation/radiation coolability of all fuel and waste in storage, natural-circulation/radiative cooling of fuel subassemblies if forced cooling is lost, and finally passive cooling of process equipment such as the electrefiner are ways in which passive safety is achieved. The passive cooling of waste cans located in the pits in the argon cell is a particularly difficult requirement to address. The desire to maximize heat in the can in order to minimize storage volume requires realistic, if not conservative, heat transfer analyses under conditions that are difficult to analyze, conditions involving combined natural convection and radiation. The can, when removed from the argon cell, must also be able to meet acceptance criteria of a local temporary dry-tube storage

facility. These acceptance criteria impose a requirement that salt and cadmium metal wastes remain in a solid state without forced cooling, which places additional constraints on the waste can design.

To ensure its passive cooling when it is received in the FCF, an EBR-II fuel subassembly must be cooled approximately 100 days or longer for the anticipated fuel burnup. This cooling period also allows adequate time for decay of the ^{131}I and other short-lived fission products so that they need not be considered contributors to accidental radiological doses. The primary remaining gaseous radioisotope is ^{85}Kr . Initial plans were to collect a portion of the ^{85}Kr gas at the fuel chopping station at the time of fuel-element puncturing. In addition, a recovery system was planned for ^{85}Kr released to the cell atmosphere. Subsequent analysis established that the ^{85}Kr radiological doses would be sufficiently low, for the approximate 4×10^{14} Bq annual normal release, that the recovery of krypton would be unnecessary. Therefore fission gas recovery is being treated only as a desirable option, to be implemented as a demonstration after initial startup if deemed appropriate.

2. Analysis of Abnormal Events

A wide spectrum of abnormal events (or accidents) was analyzed to show that the operation of FCF presented no undue risk to the public or the operating staff. This showing consisted of developing a scenario for each accident considered, estimating radiological doses at the site boundary and at the on-site bus-staging area, and comparing those doses with guideline values developed for FCF using several relevant and authoritative sources. In addition, the collective subjective judgments of project staff were tapped to categorize each accident by likelihood of occurrence. The following paragraphs summarize some of the accidents analyzed in the FSAR.

a. Accident Analysis

Fission Gas Release From Argon Cell

There are several events that might lead to the abnormal release of fission gas from the argon cell. These are:

1. Over-pressurization of the argon cell due to loss of cell cooling and subsequent heatup of cell atmosphere, with the pressure buildup relieved by activation of the safety exhaust system (SES).
2. Over-pressurization of the argon cell due to inadvertent activation of argon gas supplies to the cell and subsequent release of cell gas to the environment through the normal cell pressure control system or the SES.
3. Loss of normal electrical power which has the same qualitative effect as item (1) above, except there is a time delay for activating the SES using the emergency power supply.
4. Accidental evacuation of cell gas using a vacuum pump intended for gas-lock purging.

Each of the above events was analyzed; however, the dose results are bounded by the doses calculated for the assumed release of all the ^{85}Kr in the cell at the time of the equipment malfunction(s). That quantity is calculated from conservative estimates of (a) the facility throughput (50% greater than planned), (b) fuel burnup (80% greater than planned), and (c) normal cell atmosphere purge rate (1/3 smaller than expected), and amounts to about 7×10^{13} Bq.

Breach in Argon Cell Boundary

As noted above, the processing of hot metals in the argon cell leads to the possibility of spontaneous ignition and a metal fire if sufficient air leaks into the cell. A number of potential accidents could result in a cell boundary breach. However, a design-basis earthquake (DBE) was identified as a

potential initiator that might result in the largest breaches in the argon cell and in the subcell volumes, thereby bounding the consequences of accidents involving smaller breaches. As previously discussed, the SES is installed as a safety-class system to filter any airborne particulate products that result from this postulated event. In addition, as a "defense-in-depth" measure, confinements for individual process furnaces are designed to survive a DBE. This concept is discussed more fully below.

A computer code was written to analyze this problem, incorporating the various physical phenomena and models that determine the cell response and ultimately the source term needed to estimate the radiological consequences of this event. Figure IV.5 is a schematic diagram of a vertical section through the cell structure, showing the SES flow paths and potential breach locations. The walls, ceiling, and floor of the argon cell are constructed from reinforced concrete with thicknesses ranging from 1.2 to 1.5 m (4 to 5 ft). It also has a gastight steel lining. The cooling system cubicles, although not lined, are built with three thick reinforced concrete walls and one

Fig. IV.5. Schematic of Argon Cell Confinement Boundary and Potential Breaches

of metal. It is therefore very unlikely that air would be introduced by a breach in either cell structure. However, in a severe seismic event, failures in some feedthroughs and gas lines might occur in the argon cell and subcell confinements. Such failures were studied for the DBE and the resulting breach areas calculated. The calculated area sums of these potential breaches are 1.08×10^{-2} and $6.1 \times 10^{-2} \text{ m}^2$ (0.11 and 0.66 ft^2) in the argon cell and in the subcell cooling system cubicles, respectively.

During a DBE it is possible that the argon cooling system recirculation ducts could fail. Such failures would not constitute additional violations of the containment boundary but could cause the cooling system cubicles to communicate with the argon cell through large holes in the argon cell floor, shown in Fig. IV.5 as a "potential floor hole". For such events it is conservatively assumed that the air in the cooling system cubicles instantly and uniformly mixes with the argon cell atmosphere; subsequent SES operation causes air to enter the system through breaches in the cubicles, thereby preventing outflow.

A number of cases were studied in which the breach locations were varied. Two worst-case scenarios were identified:

- (a) a breach in the argon cell and a breach in the south (subcell D) cooling system cubicle only, with one SES train operating, and
- (b) breaches in the argon cell and both cooling system cubicles, with both SES trains operating.

As will be seen shortly, Case (a) has the least margin against unfiltered release of radioactive material through the breaches (outflow), which, it will be recalled, the SES is designed to prevent. Case (b) has a larger margin against outflow, but results in a greater source term, and hence greater consequences.

A significant element in limiting the amount of heavy metal (HM) that might burn in case of a cell breach (called material-at-risk) is the concept of "defense-in-depth", mentioned earlier. It is considered that only

material that is outside the defense-in-depth seismic-hardened process confinements might be involved in a fire. Any material above the salt in the electrolyzer (ER) is also counted as "at risk" since the salt is the upper boundary of the ER defense-in-depth boundary. As a conservative assumption, ER cathodes (solid uranium and ternary Pu-U-Cd) are included in the inventory of pyrophoric materials, although it is believed that the ternary cathodes would not ignite. With these assumptions the materials at risk are given in Table IV.3. Each entry in the table contains two values in the format XX/YY, where XX is the maximum amount of heavy metal that would be at risk (considering both binary and ternary operations), and YY is the amount of Pu that would be at risk for ternary operations. Note that the total HM assumed to burn was determined by the limiting Case (a) above; if more material were permitted to burn, and if Case (a) conditions prevailed, then an unfiltered release would occur in violation of the basic SES design criterion. Also, although experiments have shown that liquid cadmium at a temperature as high as 884 K (1132°F) will not burn in normal air,¹⁴ its inventory in ternary cathodes (30 kg each) is assumed to be consumed in

TABLE IV.3. Heavy Metal and Pu Burning Following DBE

Items at Risk	Mass of Material Burning in Scenario, ^a kg					
	A	B	C	D	E	F
Chopped fuel from chopping until immersed in salt	20/6	10/3	0/0	20/6	0/0	0/0
Cathodes out of salt and cathode processor	25/6	25/6	25/6	25/6	25/6	47/12
TOTAL	45/12	35/9	25/6	45/12	25/6	47/12

- ^aA - ER run complete, cathodes being processed, and next ER batch being prepared.
 B - One anode loaded in ER, one anode in preparation, one cathode remaining in ER, and one cathode being processed.
 C - ER ready for next batch, and cathodes in process and transit.
 D - ER run complete, cathodes remain in ER (above salt), and next ER batch being prepared.
 E - ER reloaded with chopped fuel but cathode processing just starting. Casting is in progress.
 F - Delay in cathode processing beyond completion of next ER run. Cathodes remain in ER (above salt) and reload has started.

addition to the U and Pu that contacts it. The main effect is to add a cell heat source, which is not significant.

For the DBE reference (worst-dose) case, scenarios A or D are appropriate. They maximize the fission product and Pu inventory, and the material burn rate is high because both contain 20 kg of chopped fuel with a large surface area potentially exposed to oxygen. The remaining 25 kg of heavy metal comprises two solid uranium electrorefiner cathodes, each with 8.5 kg of U, and two liquid cadmium ER cathodes (U-Pu-Cd), each containing 3 kg Pu and 1 kg U. The modeling is insensitive to the number of solid cathodes as long as the total mass does not exceed 17 kg, a conservative value for ternary fuel (Pu-U-Zr) processing.

It is conservatively assumed that when the oxygen concentration in the cell becomes 4% fuel ignition occurs. At this point the buildup of oxygen in the cell is diminished by the rate of its consumption in the burning process. For the fuel alloy, the rate is based on the data of Baker and Fischer¹⁵ for the ternary alloy of U-20 to 25 w/o Pu-2.5 w/o Mo in air. While this rate is not for a zirconium alloy (as will be processed in the FCF), it should provide a reasonable basis for determining rates of burning for assessing the consequences of an argon cell fire. These data were also used in the FSAR for ZPPR.¹⁶ Baker and Fischer also cite comparative rate data for U and Pu metals; these are used for the burning of cathode materials except for the cadmium, which is considered to burn at the higher rate attributed to the fuel alloy. These rates, r , are:

$$r = \begin{cases} 1.83 \times 10^{-3} \text{ kg O}_2/\text{m}^2 \cdot \text{s} & \text{for ternary alloy (U-Pu-Zr) and Cd} \\ 3.33 \times 10^{-4} \text{ kg O}_2/\text{m}^2 \cdot \text{s} & \text{for U and Pu metal.} \end{cases}$$

The heat generation rate is obtained by multiplying r from the above equation by the heat of formation for the particular oxide being formed¹⁷ and dividing by 0.032 kg O₂/gm-mole. Note that the burning rate is expressed on the basis of unit area of exposed material. The rate of material consumption, therefore, depends upon its exposed surface area. Thus the computations depend upon the geometry of the individual materials at risk; areas are calculated or estimated for chopped fuel pellets and ternary and solid electrorefiner cathodes.

During normal operation heat is added to the argon cell; its lights, miscellaneous electrical loads, process equipment, and fission product decay are the significant sources. In the event of a DBE resulting in a cell pressure rise, electrical power is automatically interrupted simultaneous with SES activation, so the only residual active heat sources are the decay heat and emergency lights. However, process equipment will add heat during cooldown to a temperature level equal to that of the gas. That heat is dissipated to the cell gas subsequent to electric power interruption and is calculated separately; those heat sources are included in this model as time-dependent functions. Decay heat is input as a constant for the duration of these transients.

Experiments conducted in the argon cell show that 2/3 of the radiant energy from the lights is absorbed in the gas with the remainder deposited in the steel liner. Thus, during normal operation, the liner is hotter than the gas and the heat deposited in it is convected to the gas and conducted to the concrete walls. For a DBE-induced fire, the normal lighting is shut off and the attendant smoke causes all emergency light energy to be absorbed in the gas.

Combining the above considerations, and solving mass and energy balance equations, the following computations are performed:

- heat transfer and pressure and temperature levels in the cell
- relevant SES system dynamics and flow rates
- flow rates through breaches
- argon and air mixture concentrations and their needed thermophysical properties
- fire ignition times and burning rates of the various materials at risk.

As noted above, the worst case for the dose-consequence analysis involves both SES trains operating, although that is not the planned operating mode. This results in a total SES flow rate of $1.9 \text{ m}^3/\text{s}$ (4000 cfm), with 60% exhausting the argon cell and the balance exhausting both cooling system cubicles.

One of the main results is given in Fig. IV.6. This figure shows that fires begin at slightly more than 3 min after the breaches occur; the consumption history of each material involved is also shown. The chopped fuel and solid cathodes burn rapidly because of their large exposed surface area; all material is consumed within approximately 2000 min after ignition. The results of this calculation were used to determine the amounts of each material that burn in a "critical burn time" (CBT). That time is the longest burn time for which a receptor at a given dose point would be affected for a prescribed time after the accident begins, taking into account the plume transport time to the receptor. For FCF, those CBTs are 9.5 and 27 min for the bus-staging area (230 m away) and the site boundary (5 km), respectively, derived from the corresponding residence times of 15 min and 2 h. The results of this calculation are given in Table IV.4. The plutonium burned and the fission products from the burning of the chopped pellets constitute the source term used in the consequence assessment.

Fig. IV.6. Heavy Metal Consumed Following Design Basis Earthquake

TABLE IV.4. Heavy Metal and Pu Mass Burned in Critical Burn Time

Constituent	Heavy Metal Burned in CBT, kg			
	Bus-staging Area		Site Boundary	
	Heavy Metal	Pu	Heavy Metal	Pu
Chopped pellets	4.1	1.1	15.2	4.1
Liquid cadmium cathodes	0.06	0.06	0.23	0.23
Solid uranium cathodes	3.4	0	12.7	0
Total	7.56	1.16	28.13	4.33

Waste Can Drop

Process wastes from the electrowinning furnace and from other process streams are handled in the FCF argon cell in sealed cans, known as waste cans. In handling the waste cans, the possibility of a can being dropped and breached and its contents dispersed cannot be ruled out. The path of a loaded and sealed waste can is normally from the argon cell to the air cell, and eventually into a container through a bagged-transfer device that maintains an atmosphere seal between the air cell and the transfer cask in the tunnel beneath. During the handling of the waste can within the air cell, some handling mishaps can be assumed to occur in which the can loses its integrity, resulting in the exposure of its contents and the release of some fraction of plutonium and fission products from a dropped salt-waste can or of cadmium from a dropped metal-waste can.

The bases for defining the source are the Waste Isolation Pilot Plant (WIPP) criteria.¹⁸ The relevant criteria for this accident assessment are:

Maximum waste package thermal power = 300 W.

Maximum fissile or fissionable nuclide content in waste package = 600 g (in ²³⁹Pu fissile gram equivalents).

Maximum ²³⁹Pu equivalent activity in waste package = 3.7×10^{13} Bq.

In order to specify a conservative (i.e., bounding) fission-product source term for either a salt- or cadmium-waste can, four types of wastes were defined to cover all operational possibilities. Those types are:

Type 1 = alkali metals + alkaline earths

Type 2 = alkali metals + alkaline earths + rare earths

Type 3 = rare earths + noble metals

Type 4 = noble metals

Type-1 and Type-2 wastes are in the salt waste; the former has had the rare earths stripped out, the latter has not. Type-3 waste is the result of chemically reducing the rare-earth elements into the cadmium pool without removing the insoluble noble metals. Type-4 waste is the insoluble noble metal fission products filtered out of the cadmium pool.

Detailed calculations showed, first, that the Type-1 waste has the greatest hazard potential for a given heat content. Second, the ternary (U-Pu-Zr) fuels have a slightly greater hazard potential than do the binary fuels. Third, burnup has no effect on hazard potential. Finally, the hazard potential increases with cooling time, for constant heat content. Therefore, the fission-product source term was taken from Type-1 waste from processing 18% burnup ternary fuel with 10-y cooling. The waste transuranic content was assumed to arise from the same subassembly type. The nuclides relevant to the dose assessment are given in Table IV.5.

A key parameter necessary in the calculation of the dose commitment for this accident is the release fraction of the strontium and cesium to the air cell atmosphere following the waste can drop. That fraction was evaluated as follows. Solidified electrorefiner salt is classified as a brittle material, because, like concrete, glass, or ceramics, the material breaks or chips when subjected to shock loading. The particle size distribution generated from dropping brittle materials was studied; it was found that impacting brittle materials generates a predictable size distribution of particles.¹⁹ The mass fraction of particles formed with size $<10^{-5}$ m was correlated with impact energy and material. (For the purpose of this assessment, particles of size $>10^{-5}$ m are of no interest, since they will have settled out long before they could reach

TABLE IV.5. Radionuclides in Waste Can and Committed Effective Dose Equivalents

Nuclide	Mass for 600-g ^{239}Pu Equiv., g	Activity in 500-W ^a Waste Can, Bq	Committed Effective Dose Equivalent	
			Sv/Bq inhaled ^b	Total dose content of waste can, Sv
^{238}Pu	0.33	-	1.2×10^{-4}	2.6×10^7
^{239}Pu	569	-	1.4×10^{-4}	1.8×10^8
^{240}Pu	176.9	-	1.4×10^{-4}	2.1×10^8
^{241}Pu	10.0	-	2.7×10^{-6}	1.1×10^8
^{242}Pu	5.1	-	1.3×10^{-4}	9.7×10^4
^{241}Am	7.5	-	1.4×10^{-4}	1.3×10^8
^{90}Sr	-	2.2×10^{15}	3.5×10^{-7}	7.7×10^8
^{134}Cs	-	3.4×10^{13}	1.2×10^{-8}	4.1×10^5
^{137}Cs	-	3.3×10^{15}	8.8×10^{-9}	2.9×10^7

^aIncreased for conservatism from 300-W WIPP limit.

^bFrom Ref. 20.

a receptor outside the FCF.) For the design can-drop height of 1.2 m (4 ft) and the salt density of 1700 kg/m^3 , the energy density on impact is approximately $2 \times 10^4 \text{ J/m}^3$. Assuming that the behavior of solid salt is similar to that of concrete, and further assuming that the metal container has no effect, the above noted correlation, extrapolated to this energy density, yields a release fraction of 10^{-4} for particles $<10^{-5} \text{ m}$ in size. This fraction is used to determine the mass of the can contents available for release to the environment.

The release fraction of plutonium from the dropped salt-waste can and of cadmium from the dropped metal-waste can was assumed to be the same as that from an in-cell fire, namely 5×10^{-4} ; this assumption is conservative because a waste-can drop should not result in the same level of atmospheric turbulence that would be associated with a fire. Further, the waste-can contents are solid, because planned storage sites outside the argon cell do not accept liquid wastes; nevertheless, for added conservatism the contents were assumed to

be liquid and "spill", thereby promoting the release of radioactive species or cadmium to the air cell atmosphere.

Waste Evaporator Rupture

The radioactive liquid waste processing system includes a pot evaporator located in the heavily shielded spray chamber. A scenario can be conceived in which multiple filters in the evaporator exhaust line are plugged and pressure relief blocked while the liquid feed to the unit and evaporation continue. With the assumed failure of all controls and safety devices and lack of human intervention, the pressure inside the evaporator increases until it ruptures, dispersing the contained radioactivity throughout the spray chamber. Such an event was analyzed for the FSAR.

The pot evaporator is assumed to have been operating for a sufficiently long time to have built up a level of solids having a significant radioactivity content. Then, following a combination of human and/or equipment malfunctions, liquid waste continues to be evaporated while vapor exhaust and pressure relief are blocked. The result is overpressurization and rupture of the vessel, with the radioactive contents being spewed around the spray chamber and drawn into the air-cell exhaust system that serves the chamber.

Since the plan is to ship the loaded evaporator to the Waste Isolation Pilot Plant (WIPP) for disposal, it was assumed that the evaporator and its contained radioactive materials satisfy the current WIPP criteria.¹⁸ Those criteria require, inter alia, that the dose rate at the package surface be no greater than 10 Sv/h (1000 rem/h). This is in addition to the criteria relevant to the waste-can accident, namely that the fissile and fissionable content be no greater than 600 g of ²³⁹Pu or equivalent, and that the heat load be limited to 300 W.

However, operational requirements dictate that the actual fission-product and actinide accumulations in the evaporator be substantially less than the WIPP limits. In particular, the dose rate at the evaporator surface (not the WIPP package surface) will be no greater than 0.077 C/kg·h (300 R/h). To account for possible measurement error, this limit was

conservatively increased to 0.13 C/kg·h (500 R/h). This dose rate assures that the above noted WIPP limit is met even with no shielding credit given for the shipping package. Similarly, the WIPP criticality limit of 600 g of ^{239}Pu fissile-equivalent is much greater than is operationally permissible or acceptable. That limit was accordingly reduced to the still conservative value of 50 g.

The fission-product inventory for a binary-fueled subassembly irradiated at 0.76 MW to an average heavy-metal burnup of 18% and cooled for one year was calculated using the ORIGEN code. The cooling time is a very conservative estimate, since there is little likelihood that the liquid waste system could accumulate the activity required to fill the evaporator to its design limit in such a short time. A binary-fueled subassembly is used as the reference because the fission yields for the most biologically significant nuclides are higher for uranium than for plutonium. A shielding calculation yielded a correction factor to apply to the subassembly source to achieve the desired surface dose rate. The TRU source was taken as the same as in Table IV.5 but multiplied by 1/12 (50/600). This is an added conservatism since the longer cooling time associated with the Table IV.5 values (i.e., 10 y) results in a higher unit toxicity than is the case for one-year cooled fuel. Finally, the fraction of radionuclides remaining airborne in the spray chamber and available for release was taken to be 0.01, in accordance with the LANL recommendation for an explosive release.²¹

Other Accidents

The accidents described in some detail above are examples of the kinds of analyses that were necessary in order to assure that the FCF could be operated safely. A number of other accidents were also considered but are not reported here. They are:

- loss of subassembly forced cooling in air cell
- dropped subassembly in air cell
- subassembly stuck in air cell transfer port
- spent fuel or waste can stuck in small transfer lock
- waste box fire

- subassembly rupture after dropping cask
- air cell exhaust system flow reversal
- fuel element failure during washdown.

Except for the accident involving a heat-generating source becoming stuck in the small transfer lock, all of the above abnormal events resulted in the release of radioactive materials to the environment. The analyses required the development of source terms for each case and the calculation of downwind doses using standard techniques for atmospheric dispersion estimates.

b. Results

The calculation and evaluation of the consequences of the accidents discussed above involved the following considerations:

- atmospheric dispersion parameter, χ/Q
- source term release fraction
- particulate filter efficiency
- dose guidelines

These are discussed separately below.

Atmospheric Dispersion

The essence of the consequence analysis is the determination of the 50-y dose commitments to a stationary observer located at the site boundary, 5 km distant from the facility, for two hours following the onset of the accident. This criterion follows directly from the "exclusion area" concept of the USNRC; the area between the FCF and the site boundary is analogous to the NRC-defined exclusion area. In addition to the site-boundary dose, doses were also calculated at the bus-staging area, 230 m distant, so that exposure during employee evacuation can be evaluated.

The 61-m (200-ft) facility stack is shared by the FCF and EBR-II. Although the SES discharges into the stack, under design-basis-earthquake conditions the filtered SES exhaust may recirculate to the FCF (or to EBR-II)

instead of discharging up the stack directly to the environment. In that event, release from the facility was assumed to be at ground level. Otherwise, a stack release was postulated. However, in one sector near the closest approach to the site boundary there is a terrain rise whose elevation approximates that of the stack. Under stable (i.e., inversion) conditions, the effective plume height should be reduced by the rise height; in this case, the plume height was taken conservatively as zero, effectively converting what would otherwise be an elevated release to a ground-level release. Therefore, the accident analyses assume a ground-level release for site-boundary calculations and either an elevated or ground-level release for calculations at the bus-staging area, depending on the accident scenario.

The U.S. Nuclear Regulatory Commission guidelines for determining atmospheric dispersion factors (Regulatory Guide 1.145)²² were used as the bases for the FCF analyses. According to RG 1.145, if a stack release is postulated, then a fumigation condition should be assumed to exist at the time of the release and continue for 1/2 h. Because stack releases are relevant only to the bus-staging area, and because evacuation times of 1/4 h or less have been routinely demonstrated, fumigation was considered the only applicable diffusion process for all dose commitment assessments at the bus-staging area resulting from elevated releases. This approach also assures conservative results.

Using wind speed and stability data for the ANL-W site, the characteristic dispersion parameter χ/Q was determined for each of the various possible accident scenarios. The results are given in Table IV.6.

TABLE IV.6. Atmospheric Dispersion Parameters for FCF Accident Assessments

Location	Type of Release	χ/Q , s/m ³
Bus stop	Stack, fumigation, full stack exhaust rate ^a	3.3×10^{-5}
Bus stop	Stack, fumigation, only SES flow up stack	5.9×10^{-5}
Bus stop	Ground	2.3×10^{-3}
Site boundary	Ground	4.1×10^{-5}

^a χ/Q depends upon the stack exhaust velocity; the normal exhaust flow rate was conservatively assumed to be only 24 m³/s (51,000 cfm) about 10% less than expected.

Source Term Release Fractions

For the release of radioactive materials from fires, the release fractions are given in Table IV.7. These fractions are all numbers previously used in safety analyses.²³ The plutonium and cesium release fractions were investigated to assure that they are reasonable and near the upper limit of applicable experimental data. The release fractions given in Table IV.7 were used also in accidents other than fires when it was considered conservative to do so. In addition, 50% of the released materials was generally assumed to plate out on internal FCF surfaces.

Filter Efficiency

Although recent guidelines recommend the use in safety analyses of HEPA filter efficiencies as high as 99.9%,²¹ for FCF only 99% was assumed based on earlier DOE guidance.²⁴ In addition to the SES, the normal ventilation systems include the building exhaust system which ventilates the non-suspect areas of the FCF and the air cell exhaust system which serves those areas known or suspected to be contaminated. The former has one HEPA filter bank with an assumed efficiency of 99% and the latter has two such banks in series with an assumed combined efficiency of 99.99%.

TABLE IV.7. Source-Reduction Factors for Releases from Fires

Nuclide	Fire Release Fraction
Pu	0.0005
Cs	0.35
Other solid fission products	0.0005

Dose Guidelines

In order to assess the impact of calculated doses on workers and the public, guidelines were developed for both categories of people using the best available sources,^{21,25-27} since no such guidelines existed. The FSAR describes the rationale for the guideline development in some detail. The results are given in Table IV.8.

The results of the accident analyses are given in Table IV.9. In each case, the calculated accident dose is a very small fraction of the relevant guideline value. In terms of the closest approach to a guideline value, the worst case is less than 0.02% of that value. On the basis of these analyses, it was concluded that the planned FCF operations presented no undue risk to the public or the operating staff.

E. Tomographic Reconstruction-Nondestructive Examination of TREAT Experiments

A computed tomography (CT) system is now being developed to complement the post-test destructive examination and metallography that is normally performed on the test trains used in TREAT experiments. When fully operational, CT will be used not only as a guide to locate optimal sectioning positions, but also to provide cross sectional images at more locations than would be possible with destructive sectioning. The code system has been used to analyze parts of the final configurations of PFR/TREAT tests L05, L06 and L07, seven-pin assemblies subjected to overpower transients in the TREAT reactor and will be used on future metal fuel experiments in TREAT.

TABLE IV.8. Fuel Cycle Facility Radiological Dose Consequence Guidelines

Accident Classification	Committed Effective Dose Equivalent Guideline, mSv	
	Public	Worker
Anticipated	<1	<50
Unlikely	3	150
Extremely unlikely	125	625

1. Computed Tomography Technique

The underlying principle of CT is that a two-dimensional image of an object can be reconstructed from a number of one-dimensional rays or projections through the object. For the fuel bundle CT, the projections are the measured intensities (or equivalently, measured attenuation) of parallel neutron beams passing through the assembly at multiple viewing angles. Whereas X-ray systems use detectors to directly measure beam intensity, neutron CT as it is currently performed requires an intermediate step. A radiograph is made whose density at any spatial point is a measure of the neutron intensity at that point.

a. Neutron Radiography and Digitization

Radiography for the CT is performed at the Hot Fuel Examination Facility (HFEF) at Argonne-West using the NRAD facility. The beam port is positioned to enable a large percentage of epithermal neutrons to be used. The beam is shaped by a scraper to a rectangular opening of 432 by 254 mm. This results in a near-parallel beam configuration with only a 1.5% magnification factor at the image plane.

The fuel pin bundle to be examined is positioned between the reactor beam port and a neutron detector. The test object, typically nearly 2-m long and 100-mm diameter, is suspended by a fixture capable of precisely rotating the test trains in small angular increments. The detector device consists of a package of two foils: a 0.5-mm thick cadmium foil to attenuate thermal neutrons and an indium foil to capture epithermal (1.45 eV) neutrons. After an exposure time of about 30-60 min, the indium foil is removed and placed in contact with a sheet of photographic film. After the decaying indium exposes the film, it is processed and prepared for digitization. This procedure is repeated for each angular position, normally 76 views over a range of 180°.

Digitization is performed on a scanning micro-densitometer with an adjustable aperture. The aperture in the horizontal scanning direction and the number of angles at which the projections are made determine the final minimum spatial resolution of the reconstructions, while adjusting the vertical aperture determines the axial resolution of the sections. Apertures as large

TABLE IV.9. Summary of Design Basis Accidents and Consequences

Accident	Classification ^a	Committed Effective Dose Equivalent ^b	
		Bus-staging Area	Site Boundary
Argon cell atmosphere release due to equipment malfunctions	A	$5 \times 10^{-3} / 1 \times 10^{-2}$	$2 \times 10^{-4} / 2 \times 10^{-2}$
Breach in argon cell boundary	E	$0.11 / 1.8 \times 10^{-2}$	$7.6 \times 10^{-3} / 6.1 \times 10^{-3}$
Loss of subassembly forced cooling in air cell	U	$6.2 \times 10^{-6} / 4.1 \times 10^{-5}$	$7.8 \times 10^{-6} / 2.6 \times 10^{-4}$
Dropped subassembly in air cell	A	$3.1 \times 10^{-5} / 6.2 \times 10^{-5}$	$3.8 \times 10^{-5} / 3.8 \times 10^{-4}$
Subassembly stuck in air cell transfer port	E	$6.2 \times 10^{-6} / 1 \times 10^{-6}$	$7.8 \times 10^{-6} / 6.2 \times 10^{-6}$
Waste can drop	E	$2.4 \times 10^{-4} / 3.8 \times 10^{-5}$	$2.9 \times 10^{-4} / 2.3 \times 10^{-4}$
Spent fuel or waste can stuck in small transfer lock	NA	0 ^f	0 ^f
Waste box fire	U	$8.3 \times 10^{-7} / 5.5 \times 10^{-7}$	$1 \times 10^{-6} / 3.3 \times 10^{-5}$
Waste evaporator rupture	E	$6.3 \times 10^{-4} / 1 \times 10^{-4}$	$8 \times 10^{-4} / 6.4 \times 10^{-4}$
Subassembly rupture after dropping IBC	E	$1.3 \times 10^{-2} / 2 \times 10^{-3}$	$1.6 \times 10^{-2} / 1 \times 10^{-2}$
Air cell exhaust system flow reversal	E	NC ^g	$1.3 \times 10^{-2} / 1 \times 10^{-2}$
Fuel element failure during washdown	A	$3.1 \times 10^{-5} / 6.2 \times 10^{-5}$	$3.8 \times 10^{-5} / 3.8 \times 10^{-3}$

^aA = anticipated; U = unlikely; E = extremely unlikely; NA = not applicable - no release.

^bmSv/percent of FCF guideline (see Table IV.8).

^cEffective submersion dose for worst case considered.

^dDoes not include submersion dose.

^eEffective submersion dose.

^fNo release expected.

^gNot calculated.

as 200 x 400 μm and as small as 50 x 400 μm have been tested, and ideal resolution parameters are still being studied.

b. Reconstruction Technique

Because the large assembly cannot be rigidly fixed parallel to the axis of rotation, there is some wobble as the holder is rotated. An alignment process is necessary before CT analysis can be performed. An edge finding routine determines the tilt of the test train for each view and rotates the image on a pixel-by-pixel basis so that all views are aligned to a common angle. In addition, any vertical misalignment of the foil cassette is included in the correction using a standard density wedge attached to the foil holding mechanism.

The mathematical formulation of CT reconstruction has been implemented using the filtered back-projection (FBK) method. Using the FBK method, the data from each axial elevation of each view (one digitized radiograph row) is Fourier transformed, multiplied by a filter, inverse transformed, then combined with geometric weighting factors to produce the transverse section data. The filter is needed to reduce slowly varying components such as non-uniform background, and reduce the noise caused by statistical fluctuations in the data. The ideal filter minimizes statistical noise (graininess) and artifacts without removing significant details.

The FBK process produces a two-dimensional array of CT numbers (attenuation coefficients) describing the x-y distribution of material densities at a given axial elevation along the test section. When these CT numbers are mapped to either colors or grey scales and displayed, the result is a transverse section image. The transverse sections are useful for determining the mixture of fuel and steel debris, the extent of flow tube blockage and final fuel pin condition.

These transverse sections can be stacked to create a three dimensional array of data, containing a full description of the entire test assembly that was within the field of view of the radiographs. Vertical planes can be defined through the length of this region, and the appropriate pixels

(data points) can be selected to produce longitudinal slices at any azimuthal angle and any offset from the center of the assembly. In one image, a longitudinal slice reveals fuel pin bowing and dislocation, as well as voided and blocked regions in the flow tube, highlighting those axial locations where destructive examination would be useful for further analysis.

2. Example: Results from TREAT Test L07

Test L07 is one of a series of experiments designed to study the effects of a combined undercooling and overpower excursion on a seven-pin bundle of irradiated stainless steel-clad ceramic fuel pins. Unenriched blanket pellets were contained in each pin above and below the fuel region. In each of the tests, seven pins were supported by grid spacers and installed in a flowing-sodium loop with stainless steel flow tube, outer wall and loop wall. The fuel pin clad had an outer diameter of 5.84 mm and was 0.38 mm thick. The fuel pellets had a central hole diameter of 1.52 to 1.78 mm. The tri-fluted flow tube had an outer diameter of 26.0 mm and a wall thickness of 0.89 mm.

Following the test, there were large voided regions near the center of the fueled section and accumulations of debris near the top and bottom of the original fuel column and near some of the grid spacers. One of the regions selected for CT study was near the bottom of the original fuel column. The transverse CT sections show good agreement with destructive examination sections at the same elevations, but still cannot reliably distinguish fuel and steel quantitatively, especially in melted mixtures. They can be used, however, for interpolating between the cut sections, and eliminate the need for sectioning in regions of minimal interest.

Using the reconstructed data, longitudinal sections can be created as shown in Fig. IV.7. Longitudinal destructive examination sections are rarely done because of the difficulty, and the CT images provide details of the equivalent PTE with reasonably good accuracy, showing spatial material distributions and effects such as fuel-pin bowing and the locations of debris accumulation and voided regions.

Figure IV.7 shows the CT axial reconstruction of a lower section of the L07 test train from about 50 mm below to 300 mm above the original bottom of the fuel column. This image represents a thin slice through the assembly, and does not contain any interference from structure in front of or behind this slice as would be present in a radiograph. The reconstructed density values have been binned into shades of gray, with darker shades representing more dense material. Below 200 mm, the remnants of the annular pins are clearly visible and show extensive melting and slumping. Large amounts of steel and/or fuel have flowed downward into the regions below 0 mm and forced the pins from their original positions. Above 200 mm, refrozen steel has accumulated on the flow tube walls and a large region of fuel and steel with voids nearly fills the flow tube. Molten material has also accumulated between the grid spacers and the flow tube at elevations near 10 mm, 100 mm and 190 mm.

3. Summary and Future Work

The results of the CT work to date, especially the comparisons with the destructive examination results, prove that computerized tomography using digitized neutron radiographs can now be considered a standard tool for the analysis of fuel bundles, to be used as a supplement to traditional examination methods. At this stage of its development, CT analysis provides a good overview of the material relocation following the transient tests, clearly showing the accumulations of fuel and steel.

L07 Lower Set, 0-Degree Longitudinal

Fig. IV.7. CT Reconstruction of Axial Slice through the L07 Test Assembly

Development work is now aimed at three specific areas: digitization, material recognition and quantitative analysis. Because of the number of radiographs needed to produce the required resolution, a faster digitization system is being considered. Characterization of the data in the transverse section images into fuel, steel, sodium and void regions is the next priority in the CT studies. Refinement of the filters used in the reconstruction method is needed to enhance the contrast between different materials without introducing edge effects and artifacts. Further study will determine if filter refinement can extract enough information to identify materials, or if the material neutron absorption properties are too nearly identical to separate. Once separate materials can be identified, quantitative analysis programs will be able to determine void, fuel and steel fractions for use in validating fuel behavior models, and CT analysis will advance beyond qualitative material distributions to become a powerful tool for quantitative analysis of disrupted fuel elements.

References for Section IV

1. S. A. Kamal and D. J. Hill, "Fault Tree Analysis of EBR-II Reactor Shutdown System," Trans. Am. Nucl. Soc., 64, 403 (1991).
2. R. A. Wigeland, Argonne National Laboratory, personal communication, (September 1990).
3. Y. Y. Liu et al., "Whole-pin Furnace System: An Experimental Facility for Studying Irradiated Fuel Pin Behavior under Potential Reactor Accident Conditions," Proc. of the Intl. Fast Reactor Safety Mtg., I:491, Snowbird, UT (August 12-16, 1990).
4. M. C. Billone, Y. Y. Liu, E. E. Gruber, T. H. Hughes, and J. M. Kramer, "Status of Fuel Element Modeling Codes for Metallic Fuels," Proc. ANS Intl. Conf. on Reliable Fuels for Liquid Metal Reactors, 5-77, Tucson, AZ (September 7-11, 1986).
5. T. H. Hughes and J. M. Kramer, "The FPIN2 Code--An Application of the Finite Element Method to the Analysis of the Transient Response of Oxide and Metal Fuel Elements," Conf. on the Science and Technology of Fast Reactor Safety, 2:427, Guernsey, Great Britain (May 12-16, 1986).
6. M. L. Hamilton et al., "Mechanical Behavior of Irradiated Fuel Pin Cladding Evaluated under Transient Heating and Pressure Conditions," Dimensional Stability and Mechanical Behavior of Irradiated Metals and Alloys, British Nuclear Energy Society, 1:211 (1983).

7. H. Tsai, "Fuel/Cladding Compatibility in Irradiated Metallic Fuel Pins at Elevated Temperatures," Proc. of the Intl. Fast Reactor Safety Mtg., II:257, Snowbird, UT (August 12-16, 1990).
8. T. H. Bauer, G. R. Fenske, and J. M. Kramer, "Cladding Failure Margins for Metallic Fuel in the Integral Fast Reactor," Trans. of the 9th Intl. Conf. on Structural Mechanics in Reactor Technology, C:31, Lausanne, Switzerland (August 17-21, 1987).
9. "General Design Criteria Manual," U. S. Department of Energy, DOE Order 6430.1A (1989).
10. W. J. Brynda et al., "Nonreactor Nuclear Facilities: Standards and Criteria Guide," Brookhaven National Laboratory Report, BNL-51444, Rev. 1 (September 1986).
11. "Environmental Protection, Safety, and Health Protection Standards," U.S. Department of Energy, DOE Order 5480.4 (1984).
12. "ANSYS Engineering Analysis System User's Manual," ANSYS Rev. 4.4, Vols. I and II, Swanson Analysis Systems, Inc., Houston, PA 15342 (May 1, 1989).
13. R. P. Kennedy et al., "Design and Evaluation Guidelines for Department of Energy Facilities Subjected to Natural Phenomena Hazards," Lawrence Livermore National Laboratory Report, UCRL-15910 (June 1990).
14. J. D. Gabor, Argonne National Laboratory, personal communication (June 1990).
15. L. Baker, Jr. and D. F. Fischer, "Burning Tests with Uranium-Plutonium-Molybdenum and Uranium-Plutonium-Titanium Ternary Alloys," Argonne National Laboratory Report, ANL-7225, 204-213 (November 1966).
16. H. Lawroski et al., "Final Safety Analysis Report on the Zero Power Plutonium Reactor (ZPPR Facility)," Argonne National Laboratory Report, ANL-7471 (June 1972).
17. A. Glassner, "The Thermochemical Properties of the Oxides, Fluorides, and Chlorides to 2500°K," Argonne National Laboratory Report, ANL-5750 (1957).
18. "TRU Waste Acceptance Criteria for the Waste Isolation Pilot Plant," Westinghouse Electric Corporation Report, WIPP-DOE-069, Rev. 3 (January 1989).
19. L. J. Jardine et al., "Final Report of Experimental Laboratory-scale Brittle Fracture Studies of Glass and Ceramics," Argonne National Laboratory Report, ANL-82-39 (October 1982).
20. "Limits for Intakes of Radionuclides by Workers," International Commission on Radiological Protection Publication, ICRP Publication 30, Pergamon Press, New York, New York (1978).

21. J. C. Elder et al., "A Guide to Radiological Accident Considerations for Siting and Design of DOE Nonreactor Nuclear Facilities," Los Alamos National Laboratory Report, LA-10294-MS (January 1986).
22. "Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, Regulatory Guide 1.145, Rev. 1 (November 1982).
23. J. C. Courtney et al., "Radiological Safety Analysis of the Hot Fuel Examination Facility/South," Nucl. Tech., 73 (April 1986).
24. R. H. Bauer, Energy Research and Development Administration, personal communication (January 26, 1977).
25. "Radiation Protection of the Public and the Environment," U.S. Department of Energy, DOE Order 5400.5 (February 8, 1990).
26. "Radiation Protection for Occupational Workers," U.S. Department of Energy, DOE Order 5480.11 (December 21, 1988).
27. "The Principles and General Procedures for Handling Emergency and Accidental Exposures of Workers," International Commission on Radiological Protection Publication, ICRP Publication 28, Pergamon Press, New York, New York (1978).

V. CORE DESIGN DEVELOPMENT

A. Low Sodium Void Worth and Transuranic Burner Core Designs

In the ongoing evaluations of IFR technical options, trade studies on several key IFR core design features were performed. In particular, alternatives in the transuranic management and sodium void worth characteristics of IFR cores were investigated. Various transuranic management strategies can be used in an IFR fuel cycle ranging from the conventional fissile self-sufficient cycle to either net breeding or net burning cycles. Because LWR spent fuel disposal has received increased attention in recent years and since transuranics dominate the long-term toxicity of LWR spent fuel, the usefulness of transuranic burning is again being evaluated from a waste management viewpoint. Various concepts for burning transuranics, ranging from accelerators to thermal reactor recycle, have been proposed. However, the IFR closed fuel cycle offers a number of favorable features regarding management of man-made actinides. The pyrochemical processing techniques and hard neutron energy spectrum facilitate transuranic burning as described in Ref. 1. Therefore, an IFR fuel cycle which is a net consumer of transuranics (low breeding ratio) may have advantages relative to the other burner options; this transuranic burning fuel cycle is a significant departure from conventional IFR designs with their high internal conversion ratio and fissile self-sufficient fuel cycle.

Recent investigations have also focused on design options for reducing the sodium void worth of LMR cores. Although large margins between the peak coolant temperature and the sodium boiling temperature have been demonstrated to exist for various unprotected transients, there remains a non-zero probability of at least a limited amount of sodium boiling in a LMR. Large-scale voiding, in response to extremely unlikely events, would introduce substantial reactivity (\$4 to \$6) in conventional IFR designs and may present a significant licensing issue because of the potential for severe reactor damage and of the resulting risk to the public. For this reason, there remains an incentive to reduce the reactivity (ideally to a negative value) that can be added when sodium voids and, thus, to minimize the consequences of coolant voiding in the extremely unlikely event that it takes place. Various techniques for reducing the void worth were analyzed in Ref. 2; to obtain a significant void worth reduction, substantial modifications of conventional IFR cores are required.

1. Design of Transuranic Burner Core

For a core to be a net burner of transuranics, the consumption rate by fission must exceed the transuranic production rate (U-238 capture which produces Pu-239). This criterion is roughly realized when the breeding ratio is less than one. The trade studies in Ref. 2 indicate that most design options which decrease the breeding ratio also allow a decrease in sodium void worth; therefore, low void worths are more readily achievable in transuranic burning (low breeding ratio) core designs. Various low void worth, transuranic burner design options were evaluated in a series of trade studies; some design constraints applied in these studies were:

1. Enrichment. The maximum plutonium content being investigated in the current U-Pu-10Zr fuels program is about 25 wt. %; this corresponds to a heavy metal (HM) enrichment of 28 wt. % Pu/HM. The minor actinides are expected to have chemical behavior similar to plutonium in the metal fuel system; thus, an enrichment limit of 28 wt. % TRU/HM is targeted.
2. Power Output. Conventional IFR core designs, such as PRISM³, are small, modular designs; for this analysis, a larger 1575 MWt (600 MWe gross) power level is targeted.
3. Heat Rating. A prototypic peak linear power limit of 15 kW/ft is assumed.
4. Cycle Length. A prototypic cycle length of one year is assumed.
5. Discharge Burnup. A prototypic assembly average discharge burnup of 100 MWd/kg is targeted.

In Ref. 2 where the variation of performance characteristics with void worth was investigated in detail, it was shown that the void worth and breeding ratio can both be reduced (as compared to conventional designs) by several methods: substitution of moderator for fuel, geometric spoiling (e.g.,

core height-to-diameter (H/D) ratio reduction), and high sodium fractions (especially for "pancaked" cores). However, of these design options, geometric spoiling appears to give the best trade-off between void worth and enrichment. It appears that a near-zero void worth would be difficult to achieve with any of the other methods using prototypic enrichments.

One method for spoiling the core geometry is to decrease the height-to-diameter ratio; H/D ratio reduction can be achieved by reducing the height of the active core region and adding additional driver assemblies to the outer core edge. Parametric studies indicated significant reductions in void worth and breeding ratio are achieved for such pancaked cores. However, significant increases in enrichment were observed; and large increases in the burnup reactivity swing were also observed. At the target enrichment limit, a sodium void worth near \$2.0 was observed; further reductions in the void worth require nonprototypic enrichment levels or alternate means for spoiling the core geometry.

Another option for spoiling the core geometry is the introduction of a central sink region (creating an annular active core). The performance effects of introducing central regions of varying size and composition were evaluated. The placement of blanket, reflector, sodium, and absorber materials into the central region were evaluated. Since the void worth reduction effects require the central zone to behave as a neutron sink (little reflection back into the core), the presence of absorber in the central zone was found to be most effective in reducing the driver void worth.

Performance evaluations indicate that use of a central absorber zone gives a significant reduction in void worth and breeding ratio; in addition, the presence of a central absorber zone removes the radial power peak, and allows a mitigation or elimination of the radial enrichment zoning. Thus, some combination of H/D reduction and a central absorber zone appears to be attractive for void worth reduction at "target" enrichments. Therefore, flat annular core designs were investigated in greater detail. Performance comparisons indicate that reflector assemblies can be used in the interior of the central zone; the relatively expensive absorber assemblies are needed only in the outer row of the central absorber zone. In addition, a mid-cycle assembly exchange in the central

absorber zone can be utilized to allow a mid-cycle reactivity insertion. By exchanging the absorber assemblies which lie next to the inner core radius with reflector assemblies at mid-cycle, a 1.5 % Δk reduction in burnup reactivity swing was achieved; thus, the initial excess reactivity and control rod reactivity compensation requirements are reduced.

The refined flat annular core configuration is shown in Fig. V.1; the core height is 45 cm with a diameter of 363 cm and a four row central absorber/reflector zone. The neutronic performance characteristics are summarized in Table V.1. The breeding ratio is 0.50 with a sodium void worth of \$0.15; thus,

Fig. V.1. Low Void Worth Actinide Burner Core Layout

TABLE V.1. Comparison of Calculated Performance Characteristics for Low Void Worth Interchangeable Burner and Breeder Designs

Core Concept	Burner	Breeder
Breeding Ratio	0.533	1.067
Sodium Void Worth, \$ ^a		
Total ^b	0.15	1.10
Core		
Spectral	6.40	6.05
Planar Leakage	-0.95	-0.84
Axial Leakage	-2.88	-2.31
Total	2.86	3.17
Plenum	-2.71	-2.07
Burnup Swing, % Δk^c	4.17	2.53
Ave. Discharge Burnup, MWd/kg	82.6	72.8
Peak Linear Power, W/cm (kW/ft)	495(15.1)	453(13.8)
Enrichment, wt. % TRU/HM	25.8	24.8
Net Transuranic Consumption, kg/y	250	0
Heavy Metal Mass Flows, kg/y		
Total	5791	16728
Driver	5791	5781
Axial Blanket	-	6552
Radial Blanket	-	3377
Central Blanket ^d	-	1018

^aDelayed neutron fraction is 3.47 E-3.

^bTotal includes active driver as well as plenum region.

^cAbsorber assemblies in outer row of central zone are exchanged for reflectors at mid-cycle.

^dBlanket assemblies in the interior three rows of the central zone.

a near-zero sodium void worth is achieved with a net transuranic consumption rate of 250 kg/y at the 1575 MWt power rating. The neutronic performance and reactivity coefficients of this design are evaluated in more detail in Ref. 4; and the passive safety properties are discussed in Sect. IV.B of this report.

Several other low void worth burner core options were also investigated. For high leakage configurations, the void worth can be reduced by increases in the fuel pin P/D ratio (higher sodium fraction) for a subset of the fuel assemblies in the core; if the core is sufficiently flat, the void worth

reduction caused by the enhanced leakage effects dominates the void worth increase resulting from the larger core volume. However, severe penalties in vessel diameter, heavy metal mass flow, and fuel management complexity are anticipated. Design options for using thorium (instead of uranium) as a fertile material were also evaluated; significant reductions in void worth and transuranic production (fissile U-233 is created instead of Pu-239) can be achieved using a thorium fuel cycle. However, low void worths were only achieved at high fuel enrichment levels; and metal fuel material studies^{5,6} indicate it is doubtful that transuranic enrichment levels above 10% can be achieved in a metal thorium matrix at a reasonable solidus temperature.

2. Design of Transuranic Self-Sufficient Core which Is Interchangeable with the Transuranic Burner Design

Because there is a large inventory of LWR spent fuel and a significant current production rate, it is conceivable that operating advanced LMRs in a transuranic net consumption mode would be preferred in the short term; however, since the ultimate utility of LMRs is in resource extension it is desirable to allow flexibility in the breeding characteristics. With breeding ratios greater than one, the transuranic inventory can be maintained or increased based on future demand levels. Thus, an alternate core model which achieves fissile self-sufficiency (breeding ratio greater than 1.0) while maintaining the low sodium void worth has been developed. The alternate self-sufficient core was designed to be interchangeable with the proposed low void worth burner core described above and shown in Fig. V.1; the core diameter (number of assemblies), assembly dimensions, control rod positions, and power level of the burner design are maintained in the self-sufficient design.

Different material configurations are required for a self-sufficient core with a low void worth; significant amounts of fertile material must be added to the burner design to achieve fissile self-sufficiency. The design approach for increasing the breeding ratio while maintaining the low void worth is based on interpretation of results given in Ref. 2 where the variation of performance characteristics with void worth was investigated in detail. As discussed in Ref. 2, the same physical phenomena which provide for internal breeding also lead to positive sodium void worth. Therefore, if low sodium void worth is a design goal, then external breeding is preferable to internal breeding.

Fuel cycle calculations were performed with fertile material added externally using radial, axial, and central blanket regions. The radial and central blankets utilize a conventional blanket assembly design; a higher fuel volume fraction is achieved by using thicker pins packed more closely than in the driver. In these blanket assemblies, the fueled region extends 30 cm above and below the active core. Axial blankets are placed within the driver pins; axial blankets may be placed above and/or below the active driver zone. With a single row of radial blanket and 30 cm of axial blanket above and below the core, the breeding ratio can be increased from its value of 0.5 to roughly 1.10. However, a marked increase in the sodium void worth (to \$3.0) was observed, as compared to \$0.15 in the burner case. This higher overall void worth is largely due to the reduced axial leakage; because of reflection from the axial blankets, neutrons do not leak from the core as readily. In addition, the negative upper plenum voiding effect is severely reduced by the presence of the upper axial blanket.

Therefore, in order to retain a low value of the sodium void worth it is particularly desirable to remove the upper axial blanket and to suffer the concomitant decrease in the breeding ratio (since most of the external breeding occurs in the axial blankets). To achieve fissile self-sufficiency while maintaining a low sodium void worth, a quite thick lower axial blanket, a single row of radial blankets, and central blanket assemblies in the inner three rows were utilized; the performance results for this core design are summarized in Table V.1. A breeding ratio of 1.07 is observed with a void worth of \$1.10. By using a thick (45 cm) lower axial blanket this core achieves fissile self-sufficiency while maintaining an acceptably low void worth. The \$1.00 increase in void worth (compared to the burner core, see Table V.1) is caused by a downward shift in the axial power shape; this can also be viewed as a larger effective core height. The self-sufficient design requires much higher heavy metal mass flows through the fuel cycle facility (over three times the burner core rate) to process the large amounts of fertile material. Because of the additional breeding, the burnup reactivity swing is lower (2.5 % Δk as compared to 4.6 % Δk for the burner core). The enrichment and peak linear power are slightly lower for the self-sufficient design because of the larger "effective" core volume which includes some power production in the axial and radial blankets.

Other options for introducing fertile material were also evaluated. The use of internal blanket assemblies in radially heterogeneous configurations allows fertile blanket assemblies to displace driver assemblies. This allows breeding ratios above 1.0 to be achieved at void worths near \$1.0; however, because of the displaced driver assemblies, excessive increases in transuranic enrichment are required which result in enrichment levels beyond the range of the IFR fuels testing program. The use of mixed-pin bundles, containing both driver and fertile pins, was also evaluated. The mixed-pin assembly is not as effective as an internal blanket assembly for increasing the breeding ratio because with the blanket pin size set at the driver pin diameter less fertile material is introduced; thus, a **very large** number of mixed-pin assemblies would be required to achieve a significant increase in the breeding ratio. Modular configurations, where a favorable void worth is achieved by creating multiple small cores with high neutron leakage fractions, were also evaluated. However, radially and axially modular concepts require substantial modifications of the core geometry; thus, they would not be interchangeable with the burner design shown in Fig. V.1.

3. Summary and Conclusions

The fuel cycle processing techniques and hard neutron spectrum of the Integral Fast Reactor (IFR) metal fuel cycle have favorable characteristics for the management of transuranics; and the wide range of breeding characteristics available in metal fueled cores provides for flexibility in transuranic management strategy. Numerous trade studies have been performed to assess various design options for a low void worth transuranic burner core. A flat annular core configuration appears to be a promising option; the high leakage geometry yields a low breeding ratio and a low sodium void worth. A transuranic burner core and a transuranic self-sufficient core design which is interchangeable with the burner core and maintains a low sodium void worth were developed.

B. Basis for Assembly and Pin Designs for the EBR-II Mk-V Driver

The Mk-V driver fuel for EBR-II will use the recycled fuel from the Fuel Cycle Facility with HT9 cladding and duct and will provide for the development

of a statistically-significant irradiation data base for prototypic fuel for an IFR. Variant forms will include 316SS cladding and ducts. The main differences of Mk-V fuel when compared to recent EBR-II driver fuels are the presence of plutonium (20% by weight), remote fabrication and accumulated fission products retained in the fuel after recycling. Physically the EBR-II fuel is similar to the current Mk-III and Mk-IIIA fuel pin designs, 61 pins per assembly, 0.230 in. outer diameter cladding with an element length of 29.5 in. and fuel column length of 13.5 in. The U-20Pu-10Zr fuel has a smear density of 75%. Other design parameters are essentially the same as the Mk-III fuel. One important effect of using the two different cladding materials arises from the thickness of the available tubing, HT9 at 0.015 in. and 316SS at 0.018 in. Because it has been decided to remain with 75% smear density in both cases in order to lie within the majority of the fuels irradiation data base, the Fuel Cycle Facility will be required to fabricate two sizes of fuel slug.

The basis for the fuel pin design is embodied in the design criteria applied and these in turn are derived from more general functional requirements.

The fuel and blanket subassemblies used in EBR-II are being designed to satisfy the general performance and safety limits presented in the EBR-II Technical Specifications by performing their respective functions in a safe and reliable manner over their design lives. The fuel element and fuel subassembly designs, including geometry, choices of materials, and fabrication requirements, must meet certain functional requirements. These functional requirements are:

1. To maintain a coolable geometry within both the fuel element and the fuel element bundle for the useful lifetime of the subassembly, and during off-normal events. A performance assessment demonstrates the adequacy of the fuel element design in regard to fuel element dilation and distortion over a prescribed lifetime and subsequent to breach.
2. To ensure that sufficient fuel element reliability is maintained so as to statistically prevent a "significant" number of fuel element breaches during steady-state and off-normal reactor operation (up to and including unlikely events). A "significant" number of breaches

may be defined as that which challenges the safe operation or performance goals of the EBR-II reactor. This has previously been defined as ensuring that no more than one fuel element breach is expected per core loading. In other words, a 95% confidence that no more than one in about 3000 elements will breach.

The achievement of this requirement is demonstrated through an analytical performance assessment and a follow-on in situ fuel qualification program. The calculable performance guidelines presented below have been designed to ensure this reliability requirement. Factors involved in the assessment and guarantee of reliability are 1) prevention of stress-rupture of the cladding, which involves fuel element materials choices that ensures a minimum fuel/cladding eutectic temperature for steady-state operation and a burnup limit at which point creep damage caused by fuel and fission-product induced stress does not compromise cladding integrity, and 2) a fuel design and fabrication specification which will statistically eliminate manufacturing defects sufficient to cause reduced reliability. The latter is ultimately demonstrated by the qualification program.

The detailed design criteria for Mk-V fuel are derived from these general requirements and have been formulated in such a way so as to provide a representative set of design criteria for any metal-fueled reactor, e.g., ALMR's. The criteria set limits upon strain, stress, cumulative damage function and temperatures as shown in Table V.2 for HT9 cladding. The classification of anticipated, unlikely and extremely unlikely events is taken from the existing EBR-II documentation.

In some cases the limits chosen may be overly conservative for other reactor designs. This is necessary for continuity with the existing EBR-II safety position, e.g. the limit of a maximum cladding eutectic penetration of 5% is embodied in the existing EBR-II Safety Analysis Report. In addition, a criterion of no fuel melting in all anticipated and unlikely events has been adopted for consistency with previous EBR-II safety analyses. This is not necessarily applicable to advanced reactor types.

TABLE V.2. Design Criteria for Mk-V Fuel (HT9 Clad)

DESIGN CRITERIA	DESIGN BASIS EVENTS			
	Normal Operation	Anticipated Events	Unlikely Events	Extremely Unlikely Events
1.0	$\epsilon_{THN} < 1\%$			
2.0	$CDF_N < 0.05$			
3.0	No fuel melting			
4.0	No eutectic liquefaction at the fuel-cladding interface			
5.0	$\bar{\sigma}_H < 150 \text{ MPa}$			
6.0		Maximum cladding eutectic penetration $< 5\%$ wall thickness		
7.0		$\sum_1^M \sum_1^N (CDF_A + CDF_U) < 0.1$		
8.0		$\sum_1^M \sum_1^N (\epsilon_{HA} + \epsilon_{HU}) < 1\%$		
9.0	$T < T_{\text{boil}}$			

ϵ_{THN} = Thermal component of plastic hoop strain during normal operation.

CDF_N = Cumulative damage fraction during normal operation.

$\bar{\sigma}_H$ = Average hoop stress across cladding thickness.

$\sum_1^M \sum_1^N CDF_A$ = Cumulative damage fraction during all M anticipated events and all N occurrences.

CDF_U = Cumulative damage fraction during single most damaging unlikely event.

$\sum_1^M \sum_1^N \epsilon_{HA}$ = Total plastic hoop strain for all M anticipated events and all N occurrences.

ϵ_{HU} = Plastic hoop strain for single most damaging unlikely event.

T = Peak sodium coolant temperature.

T_{boil} = Sodium boiling temperature.

The assessment against these requirements is primarily carried out by detailed analysis using the ANL codes LIFE-METAL, FPIN2 and SASSYS-1 which address fuel performance during steady-state irradiation, fuel performance during transient (off-normal) events and coupled system thermal-hydraulic neutronic behavior respectively. These codes have been extensively validated against results from EBR-II experimental irradiations, Whole-Pin Furnace Tests (WPF), Fuel Behavior Tests Apparatus (FBTA) experiments and TREAT tests. (Sect. IV.C.5 describes the results of recent WPF experiments).

The results of the analytic performance assessment, based upon the extensive experimental database, have shown that the Mk-V fuel design is suitable for selection as the next driver fuel for EBR-II. The irradiation of the Mk-V fuel in EBR-II and its subsequent recycling in Fuel Cycle Facility will provide an integral demonstration of the closure of the fuel cycle and the operation of EBR-II as an IFR prototype.

References from Section V

1. R. N. Hill, D. C. Wade, E. K. Fujita, and H. Khalil, "Physics Studies of Higher Actinide Consumption in an LMR," Proc. of Intl. Conf. on the Physics of Reactors: Operation, Design, and Computation, I:I-83, Marseille, France (April 23-27, 1990).
2. H. S. Khalil and R. N. Hill, "Evaluation of LMR Design Options for Reduction of Sodium Void Worth," Nucl. Sci. and Engng., 109:221 (November 1991).
3. R. C. Berglund, F. E. Tippets, and L. N. Salerno, "PRISM, A Safe, Economic, and Testable Liquid Metal Fast Breeder Reactor Plant," Proc. Intl. Topical Mtg. on Safety of Next Generation Power Reactors, 599, Seattle, WA (May 1988).
4. Y. I. Chang et al., "Core Concepts for Zero-Sodium-Void-Worth Core in Metal Fueled Fast Reactor," Proc. Intl. Conf. on Fast Reactor and Its Fuel Cycle, II:14.5-1, Kyoto, Japan (October 28-November 1, 1991).
5. B. Blumenthal, J. E. Sanecki, D. E. Busch, and D. R. O'Boyle, "Thorium-Uranium-Plutonium Alloys as Potential Fast Power-Reactor Fuels, Part II: Properties and Irradiation Behavior of Thorium-Uranium-Plutonium Alloys," Argonne National Laboratory Report, ANL-7259 (October 1969).
6. B. Blumenthal, J. E. Sanecki, and D. E. Busch, "Thorium-Uranium-Plutonium Alloys as Potential Fast Power-Reactor Fuels, Part I: Thorium-Uranium-Plutonium Phase Diagram," Argonne National Laboratory Report, ANL-7258 (September 1968).

VI. FUEL CYCLE DEMONSTRATION

A. Status of Facility Modifications

The embedments, rebar, and forms were installed and the concrete was placed for the floor of the safety equipment building (SEB) in February. The walls and floor of the SEB were completed in March. The concrete roof of the SEB was completed in April. The safety equipment building envelope was basically completed by May. Roof weather protection was installed on the SEB during December. Figure VI.1 shows the SEB as it nears completion.

The two safety class diesel-generator sets were delivered for the emergency power system in March. Upon the completion of the design and testing of the necessary lifting beams, the diesel storage tanks and diesel-generator sets were set in place during December. Figure VI.2 shows the installation of the diesel generators.

Fig. VI.1. Fuel Cycle Facility Safety Equipment Building (new construction)

Fig. VI.2. Installation of a Diesel Generator into the Safety Equipment Building (SEB)

The glove walls were installed in the suited entry repair area (SERA). The shielded glove wall has 3-in.-thick leaded glass windows. The unshielded portion of the glove walls have laminated glass and lexan windows. They also have a rolling shield door to protect the operator from radiation sources within the SERA. Figure VI.3 shows the rolling shield door in the open position.

The installation of the decon spray chamber liner and equipment continued throughout the year. All of the work on the spray chamber liner, shroud doors, and exhaust duct work were completed in December. The confinement boundary will be complete when the slaves, window, and liquid sump have been completed. The criticality-safe liquid sump is being fabricated in the ANL-W shops. Figure VI.4 shows the location of the spray chamber with respect to the SERA and Fig. VI.5 shows the current status of the spray chamber.

Fig. VI.3. Biologically-shielded and Unshielded Equipment Remote Repair Glovewalls of the New FCF Basement Hot-Repair Facility

The installation of the transfer tunnel overhead movable shield was completed and made operational during March. The transfer tunnel cart system fabrication was completed in March. The transfer tunnel carts and drive accessories, two transfer tunnel hydraulic rams, and two ram pit liners were delivered in April. Sufficient transfer tunnel preparations were completed to allow the element chopper to be moved into the argon cell during August. The pit liners and hydraulic rams were installed in the transfer tunnel in November. The transfer tunnel cart was installed, connected to temporary power, and the drive mechanisms tested during December. Figure VI.5 shows one of the transfer tunnel carts (the open center platform) within the spray chamber.

A mockup assembly of the safety exhaust system (SES) seal pot was used to test seal pot performance. The results indicated that the seal pots would meet the necessary functional design criteria. Based on these test results, the seal pots were ordered and received. Final design reviews were held on the safety

Fig. VI.4. FCF Personnel Suited-entry Repair Area (SERA) in New Basement Hot-Repair Facility (decon spray chamber is at left rear)

exhaust system (SES) mechanical design in April. Pressure drop tests on the SES safety class backdraft dampers were successfully completed during September.

During installation tests in January, the hot repair area crane exhibited abnormal noise and vibration. The crane was removed and returned to the crane manufacturer for repairs. The vendor located the problems and the crane was repaired and returned by March.

Analysis of the seismic loadings of the Argon Cell cranes and electromagnetic manipulators was completed during February to show that the bridge structures meet the load combinations for the safety-class AISC-N690 code. No modifications to these structures will be required.

Fig. VI.5. FCF Equipment Decontamination Spray Chamber, Interior View Looking Outward Toward Chamber Remote Operating Station (new construction)

Refurbishment of Room 20 was completed during the year. Room 20 had been previously used for fuel casting prior to construction of the fuel manufacturing facility (FMF). The highly contaminated casting furnaces were removed from Room 20, boxed, and prepared for waste disposal in May. The removal of equipment and the waste disposal was completed in June.

Work on the installation of fire sprinklers throughout FCF began in January. Work throughout the year included drawing review, vendor selection, and bid negotiations. Installation of the sprinkler system began in September and was nearly completed by December.

Plans for upgrading the operations office were completed early in the year. The contractor started work on the project during November. The erection of concrete block walls was completed in the Operations Office during December.

A variety of components were procured and installed for the electrical system. The 480 volt normal power panels were delivered in February. The motor control centers for the normal and emergency (except Class IE) power systems were delivered during April. Dual power feeds to the condensate and industrial waste sumps were completed in May. The new normal power motor control centers were received during May. The normal power panel, the building envelope lightning protection, and electrical receptacle checkout and ground fault interrupter installations were completed in June. Argonne staff witnessed the class IE automatic transfer switch tests at the vendor in June. Motor control centers (MCC) F2, F4, and E2 were mounted and MCC-F2 was energized during December.

Installation of lighting assemblies in the air cell was started in January and completed by March. Selected argon cell lights were replaced with new high pressure sodium lamps during April for testing. This lamp has an improved starting transient and lower voltage spikes when compared to the old style lamp. They will reduce the heat load in the argon cell due to higher efficiency.

A contract was awarded for the argon cell cooling system freon leak detector in April. Drawings for the purification system instrumentation (including the instrument cabinet) have been completed. Design of the hydrogen injection system was near completion by the end of December, and the hydrogen monitor had been delivered. Suppliers for seismically-qualified, solenoid-operated isolation valves, an integral part of the hydrogen injection system, were being sought at the end of December.

Final designs were completed for the radioactive liquid waste system (RLWS). Equipment procured for the RLWS included three major tanks, evaporator heater and controls, vapor condenser, intermediate cooling system, evaporator/condenser test system components.

B. Status of Process Equipment Design and Fabrication

1. Fuel Element Chopper (EC)

Out of cell qualification for the EC was completed in August. While the qualification was being completed, time was spent on the procedures for

installing the chopper and supporting electrical equipment into the cell, and preparing the argon cell and subcell for the transfer. Figure VI.6 shows the EC prior to installation in-cell.

The fuel element chopper and the feedthroughs were transferred into the argon cell during September. The fuel element chopper was then remotely assembled and operated. Steel rods were initially used to check out the operation of the chopper. Sodium-bonded depleted uranium fuel elements and irradiated fuel elements are scheduled to be chopped during 1992. Operation of the element chopper in the Argon Cell marks a significant milestone in the IFR Fuel Cycle Demonstration Project. This milestone signals the beginning of the in-cell/remote qualification of the fuel cycle process equipment.

Fig. VI.6. Element Chopper Prior to Installation in the FCF

2. Electrorefiner (ER)

Torque-speed testing of the prototype electrode assembly (EA) was completed during January. All the components for the heater assembly were received by February. The heater support can and the first of two electrorefiner crucibles were received in March. After receipt of these components, tests were successfully conducted to check the fit between these components and the support structure. During April, the second of two electrorefiner crucibles and the cover plate for the electrorefiner were received.

Several final design reviews were held during the year. Final design reviews for the elevator and rotator assemblies (ERA), the electrode assemblies, the primary vessel internals, and the valve and latch assembly were held during April. During May, final design reviews were held for the bracket and latch assembly (BLA), the valve latch assembly (VLA), the cadmium and salt stirrer assembly, control circuits, data circuits, and electrical support hardware. Final design reviews for the ball valve (used with the sampling system and pellet insertion system), vessel sensors and the various port plugs of the electrorefiner were held in June. In September, a final design review was held for the bulk reagent loading system, the pellet insertion system, the sampling systems, and the instrument assembly. The final design review for the electrorefiner cover gas system was held in December.

The construction of ER Cabinet No. 3, which contains the ER heater controls was completed in August. A test of the electrorefiner heater control system was conducted during September and October. The primary vessel was heated to 250°C with no observable operational problems.

Fabrication of the valve and latch assemblies and 23 fuel dissolution baskets were completed during October. The mechanical assembly of Cabinet No. 1 (port mechanisms) was also completed.

Two of the elevator and rotator assemblies (ERA) were received in November. Fabrication of the last two ERA was completed in December. The Phase I Qualification Plan for the ERA mechanical assembly and check out on the electrorefiner was also completed in December.

Assembly and QA inspection of Cabinet No. 1 (port mechanism controls) was completed in December. The mechanical assembly of Cabinet No. 4 (electrode power supply systems) was completed in December. Figures VI.7 and VI.8 show the basic structure of the ER.

3. Cathode Processor (CP)

Hardware receipts during January included the trolley assembly, the o-ring assemblies for the CP vessel, and the motor controllers for the lift and translate motors. The CP furnace liners, the graphite process crucibles and the condenser seal assemblies were delivered during February. In April, the CP vessel shell, cover flanges, furnace transition pieces, and bottom blind flanges

Fig. VI.7. FCF Remote Electrorefiner
(basic structure)

Fig. VI.8. FCF Remote Electrorefiner
(partial assembly)

were delivered. The construction of structural components for the prototype test facility enclosure were also completed. Figure VI.9 shows the in-cell CP and out-of-cell development CP during assembly. Figure VI.10 shows the internal assembly consisting of the condenser, the heat baffles and the process crucible.

The CP cover flange assembly and the furnace liner assembly components were assembled in May. The last of the major components, the copper shield assembly, was received in May. Assembly of the identified development testing unit and in-cell remote processing unit continued throughout the year and was near completion in December.

Fig. VI.9. Cathode Processors (in-cell and prototype units) Mounted on Support Stands

Fig. VI.10. Cathode Processor Internals

In June, wiring for the PLC interface cabinet for the prototype system was completed. The wiring on the PLC interface cabinet for the in-cell apparatus was completed in October.

The assembly activities specified in the CP Qualification Plan were completed in November for the crucible assembly.

4. Injection Casting Furnace

Heat-up tests at full power were conducted during January. A high temperature test of the vessel was successfully complete during May. Final software coding and informal software testing was completed in August. The casting furnace was reassembled as part of the qualification process in September. Phase I of qualification, and the control system checkout, was completed during December. Figure VI.11 shows the casting furnace during the final stages of Phase I qualification.

Fig. VI.11. Casting Furnace During Initial Qualification Testing

5. Fuel Pin Processor

Connection of the operator control station (OCS) to the control system was successful in January. By June, the programmers had completed the coding of the individual PLC and OCS modules.

Initial tests of the pin demolder and shearer during April resulted in breakage of simulated ternary alloy fuel. A design modification for removal of the demolder was approved and the parts were completed in December. The pin processor is shown in Fig. VI.12.

6. Vertical Assembler/Disassembler (VAD)

The VAD cooling system fabrication was completed and is awaiting qualification checkout. An Installation and Test Instruction (ITI) was completed and sent out for review to install the VAD pneumatic and flow test assemblies. The VAD table is currently being assembled and qualified in the mockup area.

Fig. VI.12. Pin Processor During Checkout

7. Other Process Equipment

In April, Phase II of the final design review for the element welder was held. This phase of the design review covered the vision system and xenon tag gas assemblies. The last portion of the final design review was held in June. Assembly of the element welder began in the mockup area during September and was completed before January (see Fig. VI.13).

The motors and translators for the element fabrication magazine rotate and positioning table were received and accepted in October. An X-ray machine was selected for the inspection station during November. Delivery of the X-ray system is expected in early 1992. The gripper has been fabricated and will be assembled and tested in 1992.

Drawings, process and instrument diagrams, and electrical schematics were completed for the final design of the element settler.

Fig. VI.13. FCF Remote Fuel-element Closure Welding System
(in cold checkout phase)

C. Waste Handling and Processing

The storage strategy for the FCF wastes and interim process materials was finalized and detailed in the final safety analysis report. A paper detailing the design approach that was taken to develop this strategy was presented at the Second Annual International High Level Radioactive Waste Conference in Las Vegas.

The thermal models that were being developed to investigate different storage options for the waste were finalized. For the in-cell storage of high thermal content waste, the design of the equipment that provides convective cooling of the waste cans was completed. Prototypes of the systems were fabricated and are being installed so the thermal models and equipment configuration can be verified. Waste can designs were finalized and are awaiting the results of the thermal test before fabrication.

D. Process Control and Accountability

The fuel cycle facility control system was finalized to use a distributed control system for the automatic control and monitoring of the different process and facility systems. As shown in Fig. VI.14, each in-cell process has a programmable logic controller (PLC) and operator control station (OCS) that provides independent control of the equipment. The facility configuration uses a central PLC that collects data and sends commands to and from remote input/output (I/O) modules. The remote I/O modules help to minimize the wiring requirements between the field sensors and the control system. The main PLC also communicates to two redundant PLCs that control systems where extra reliability is desired. Under normal operating conditions the two redundant PLCs load share the control and monitoring functions. If one fails, their entire function can be assumed by the remaining system. This extra reliability is being used for the argon cell pressure control and argon recirculation systems. For the facility systems, the operators can access monitored data and control functions through five OCS located throughout the facility as follows: two in the operations office, one in the main operating corridor where the transfer locks can be seen, one outside the hot repair in the basement and one in the health physics office.

Fig. VI.14. FCF Process Control System

The distributed PLCs and OCSs are interconnected by four different local area networks: ethernet, Allen-Bradley Data Highway, Allen-Bradley Data Highway Plus, and Allen-Bradley remote I/O network. The ethernet network also provides connection to the in-cell balances and the mass tracking system which operates on two SUN computers. The network system has completed its final design review and the procurement of the major hardware pieces has been completed. The installation packages for the networks have been drafted and cable tray installation has started.

The control software for all systems follows a stringent software development procedure where preliminary design and final design reviews establish the requirements for the individual systems. After the final design review, the software coding is done and systems start a testing phase. During the assembly of process equipment, the PLC and OCS software is tested by the responsible

software engineers working in conjunction with the various hardware engineers. After completion of the assembly testing phase, the software is placed in configuration control and the software is tested by independent people during the out-of-cell qualification testing of the equipment. After the out-of-cell testing, the equipment is installed in-cell and tested again. Since each processor is independent in control functions, the software development proceeds in parallel with the individual process equipment and facility systems. An overall integrated system test will be completed when all systems are installed.

During 1991, the element chopper PLC and OCS software completed its coding and was successfully tested during the equipment assembly and out-of-cell qualification. The casting furnace control software has been completed and tested through the assembly phase. Pin processor software is essentially complete and is ready for assembly testing. The final design review for the element welder, element settler, and cathode processor PLC and OCS software were completed and the coding has begun. Approximately 60% of the electrowinner and facility control software has completed their final design reviews. Portions of their coding has started.

The mass tracking system (MTG) provides computerized support for a variety of functions including materials control and accountability (MC&A), criticality safety and OCS operations. The second phase of the final design review for the MTG system was held in September. Designs have now been approved for the basic database design, the servers that control the MTG system and its communications with other computer systems, and program modules that support MC&A calculations, criticality safety, zone-to-zone and container-to-container transfers, radioactive decay calculations, weighing operations, the fuel-element chopper and casting operations. Coding has been completed on all servers and on prototypes for most of the program modules for which there are approved designs. All servers have been thoroughly tested, and coded program modules that support the OCSs are ready for testing as the corresponding OCS coding is completed. A terminal session program which starts, stops and suspends the MTG servers has also been written and tested. All of the software that supports MC&A, from the MTG system database through the MAWST code that will be used to compute variance propagation, is currently in test.

E. Preparations for Start of Operations

There were several activities important to the start of operations. These included the development of operating procedures, maintenance instructions, and the development of a training program for the operation of the fuel cycle facility. The planning included the identification of procedures necessary for startup and the development of a schedule to insure procedures are available when new process equipment is installed. The training of FCF operational personnel will be based on individual training plans.

VII. LIQUID METAL REACTOR TECHNOLOGY RESEARCH AND DEVELOPMENT

A. Seismic Isolation

ANL has an experimental test program on seismic isolation bearings. The purpose of the test program is to determine the performance characteristics of laminated elastomeric seismic isolation bearings under a wide range of loadings and to develop a solid technology base which will permit the use of base isolation as a new seismic design strategy for future ALMRs.

Three types of bearings, each procured from a different manufacturer, have been tested: (1) high shape factor-high damping-high shear modulus bearings (purchased from Furon Structural Bearings Division of Texas); (2) medium shape factor-high damping-high shear modulus bearings (purchased from LTV Energy Products Co. of Texas); and (3) medium shape factor-high damping-low shear modulus bearings (purchased from Rubber Consultants of Malaysian Rubber Producers Association of UK). The Furon, LTV, and Rubber Consultants bearings were all designed by ANL and made specifically according to ANL specifications. The tests described in this report were performed at the Earthquake Engineering Research Center (EERC) at the University of California, Berkeley,¹⁻³ under the technical direction of ANL staff. The bearing configurations, test types, and test results are described below.

1. Furon Bearings

Furon bearings are made of a high damping-high shear modulus rubber compound. The bearings were designed with a shape factor (SF) of 24, which is considered to be in the high range. The high shape factor of the bearing provides a very high vertical stiffness and a very high vertical frequency for the isolated structure. This is desirable because it provides the least amount of vertical amplifications to reactor structures. For example, the General Electric Company Power Reactor Inherently Safe Module (PRISM) (which uses seismic isolation) currently under development by GE requires a vertical frequency of 24 Hz.

The Furon bearings were procured by ANL and installed in a full-size test building facility in Sendai, Japan as part of a joint ANL/Shimizu (Japan) study which was recently completed. ANL's efforts in this study were funded by the National Science Foundation (NSF). Thus, the test program of Furon bearings was specifically designed to replicate the loading conditions of the bearings installed in the Sendai test building. The bearings were tested in the large scale bearing test machine at EERC. The machine tests four bearings at a time and can produce a vertical load up to 1 million pounds per bearing. It can also produce a maximum horizontal displacement of 18 in. The maximum horizontal load it can apply to a bearing is 250 kips. The horizontal and vertical loads are entirely self-equilibrated and the machine is free standing, independent of strong walls or strong floors. The disadvantage of the machine is that it is only capable of testing at slow rates.

Four bearings were placed in the test machine with the vertical load set to 83.2 kips. Each displacement cycle ($\pm 3.15\%$, $\pm 6.25\%$, $\pm 12.5\%$, $\pm 25\%$, $\pm 50\%$, $+75\%$ - 50% shear strain) was repeated three times and data collected for all three cycles. The vertical load was increased to 115.1 kips and the test program repeated. The bearings were then subjected to displacement cycles of $\pm 100\%$ and $\pm 125\%$ at the larger vertical load. It was observed that during the $\pm 125\%$ cycle one bearing showed signs of distress. This bearing and its partner on that side of the test machine were immobilized by a strong-back, and the testing was continued with displacement cycles corresponding to $\pm 150\%$ and $\pm 200\%$ shear strain. No further evidence of damage was visible, and it was concluded that the other two bearings tested performed satisfactorily to $\pm 200\%$ strain. The distressed bearing was cut in half and it was found that the bond between the rubber and the top end plate had failed.

The test results indicate that the bearings are somewhat stiffer than anticipated in the design. The system frequency at 50% strain is 0.80 Hz. For small displacements generated by minor earthquakes, the frequency will be even higher. For example, at around 10% strain, the response will be of the order of 1.2 Hz. The damping in the bearings is also consistently high. Over the range of strains, from 3% to 50%, the average damping is 15.5%. Thus, for small to moderate earthquakes, structures using this high-shape factor bearing do not perform well (i.e., these bearings are not very effective in reducing amplification of the input acceleration).

The bearing that performed badly experienced a bond failure at the top end plate. The failure was indicated by a dislocation of the bearing in the region of the top end plate. Evidence of the failure was first noticed during the 125% shear strain loading cycle. The shear forces induced at the 125% strain level were sufficient to break the bond completely and overcome the friction resistance between the end plate and the rubber. Thus, during the test the end plate moved back and forth across the top of the bearing. The only remaining connection between the bearing and the end plate was provided by the rubber cover layer. There was, however, no catastrophic collapse of the upper load beam and the bearing continued to support the axial load. These observations indicate that this type of failure mechanism is gradual and not sudden, but they also reveal the difficulty of detecting a poor bond in bearings. Clearly the standard testing procedure of 50% shear strain tests along with high vertical loads as acceptance test will not reveal the presence of a poor bond. (Friction will mask the lack of adequate bond.) It remains, therefore, necessary to develop a test procedure that will detect this. One way to better assure acceptable bonding is to subject the bearings to large horizontal displacements while the vertical load on the bearing is reduced to essentially zero, thus eliminating the friction factor.

2. LTV Bearings

LTV bearings are medium shape factor-high damping-high shear modulus bearings. The motivation to design and test moderate shape factor bearings include a desire to achieve a bearing design that facilitates fabrication to high quality standards, has highly predictable behavior and is efficient in reducing acceleration levels throughout the structure. ANL developed four different designs for manufacture by LTV Energy Products Company. Two different rubber compounds (259-62 and 257-71) and two shape factors (9 and 18) were used to give the following four types of design: Type 1, SF = 9 with compound 259-62, Type 2, SF = 18 with compound 259-62, Type 3, SF = 9 with compound 257-71, and Type 4, SF = 18 with compound 257-71. The bearings were sent to EERC at the University of California, Berkeley for testing and evaluation of their dynamic characteristics and the failure mechanisms. This particular test program is very important to the DOE's seismic isolation program, because it provides data over a wide range of shape factors. It should be mentioned that GE's PRISM and

Rockwell International's SAFR bearings tested at EERC were high and low shape factor bearings, respectively.

Each bearing design was subjected to seven different types of tests, making a total of 28 bearings tested. Each type of isolator was subjected to five different failure tests in which the axial and the shear loads were changed in order to obtain an axial-shear load interaction diagram. The five tests are: (1) compression failure ($P > 0$, $S = 0$) where P is the axial load and S is the horizontal shear load, (2) shear failure with a compressive design vertical load ($P = \text{design load}$, $S > 0$), (3) shear failure with no axial load ($P = 0$, $S > 0$), (4) shear failure with a tensile design vertical load ($T = \text{design}$, $S > 0$), and (5) tension failure ($T > 0$, $S = 0$). Fatigue tests were carried out at two different shear strain levels: one at 100% and the other at 150%. The purpose of the fatigue tests was to study (1) the response of the isolators to a long time duration of cyclic dynamic loads, (2) the loss of stiffness under cyclic loading, and (3) the failure mechanisms. This is the most intense and extensive isolation bearing test program ever undertaken in the United States.

The compound used in Types 1 and 2 bearings has a nominal shear modulus of 120 psi at 100% shear strain; the compound used in Types 3 and 4 bearings has a shear modulus of 150 psi at 100% shear strain. The nominal vertical load of 62.5 tons corresponds to 812 psi vertical pressure for bearing Types 1 and 2, and 1105 psi vertical pressure for bearing Types 3 and 4. These isolators were designed to provide a horizontal frequency of 0.50 Hz at 100% shear strain. The vertical frequency of a rubber isolator is controlled by the ratio of the diameter to the thickness of the individual rubber layers. This is expressed by the shape factor. As mentioned earlier, the shape factor for bearing Types 1 and 3 is 9, and that for bearing Types 2 and 4 is 18. It should be mentioned that these shape factors are considered to be moderate in comparison with the low shape factor of 2.25 used for the SAFR isolation system and the high shape factor of 24 of the PRISM isolation system.

The original test program for the fatigue tests was to test each type of bearing to a cyclic displacement corresponding to 50% and 100% shear strains until failure occurred while carrying the design load of 62.5 tons (125 kips). The tests were run in increments of 40 cycles. However, after the first fatigue

test was performed, bearing Type 3 resisted 2880 cycles without a sign of failure. The testing machine itself could not sustain that many cycles, and as a result, various machine components had to be replaced several times. A decision was made to modify the test program to shear strain levels of 100% and 150% and only bearing Types 1 and 3 were tested.

The LTV bearings performed well during the fatigue tests, especially those run at 100% shear strain, in which one bearing sustained over 2880 cycles while carrying the design load without failure. The results show that neither the shape factor nor the rubber compound had any apparent influence on the loss of stiffness and the energy dissipated for each set of 40 cycles. The change to 150% shear strain was intended to induce failure, thus making it possible to evaluate the failure mechanisms. The bearings tested in fatigue at 150% shear strain sustained up to 1120 cycles before failing (equivalent to 30 minutes of severe ground shaking). Bearing Type 3 sustained only 515 cycles due to a fissure caused by the expulsion of an air bubble entrapped in the bearing. These results, however, are more than satisfactory when considering that no earthquake will generate so many cycles all with large displacements. For example, an earthquake of two (2) minutes duration (which is very high) would have about 200 cycles, of which only a fraction would be of the higher displacement motion.

The compression tests revealed that the mechanism of failure under this type of loading is yielding and tearing of the reinforcing steel shim plates. The plates are loaded by surface shear stresses as they act to prevent lateral distortion of the bearing under the vertical load. It was demonstrated that the elastomer and the rubber steel bond are able to sustain shear stresses that are large enough to yield the steel in a type of all around tension. The vertical pressure on the bearing when the steel reinforcing plates failed depended on the shape factor, but was in every case so much larger than the design vertical pressure or a possible overload to be induced by seismic or other events as to be beyond significance.

The buckling capacity of the isolators was also shown to be very much above design load levels and also capable of being accurately predicted by simple analysis. The critical buckling load was found to be 1672 kips equivalent to 10,861 psi, a value 13 times greater than the design vertical load. The predicted critical load was 1690 kips.

3. Rubber Consultants Bearings

A new compound developed by the Malaysian Rubber Producers Research Association (MRPRA) has a shear modulus that is about half that of the shear modulus of the high damping rubber developed by LTV. Also, the value of the shear modulus is less dependent on shear strain. Bearings made from this low shear modulus compound may improve the response of the test building during small earthquakes. In July 1990, ANL contracted with Rubber Consultants of the United Kingdom to manufacture 10 bearings using MRPRA's newly developed compound. Eight bearings made by Rubber Consultants were shipped to Japan in October 1990: six for installation in the Sendai test building and two for laboratory tests in Japan. The remaining two were sent to EERC at the University of California, Berkeley for laboratory testing in the USA. The following section describes the results of the tests by EERC of the medium shape factor-low modulus-high damping bearing made by Rubber Consultants.

The test plan consists of three types of tests: (1) horizontal tests, (2) vertical tests, and (3) failure tests. In the horizontal tests, the bearing was subjected to two sequences of horizontal displacement cycles. Each sequence included three cycles of displacement at the following strain levels: Sequence 1: $\pm 5\%$, $\pm 10\%$, $\pm 25\%$, $\pm 50\%$, $\pm 75\%$, $\pm 100\%$; Sequence 2: $\pm 125\%$, $\pm 150\%$, $\pm 175\%$, $\pm 200\%$.

In the vertical tests, the bearing was subjected to five cycles of vertical loading centered around 500, 625, 1000, and 1500 psi of vertical pressure. The variation in the vertical load in each of these tests corresponded to about ± 100 psi. This particular test series is close to the limits of the test system capability at EERC.

The horizontal tests in Sequence 1 were carried out at frequencies of 0.1 Hz and 0.5 Hz. The horizontal tests in Sequence 2 and the vertical tests were carried out only at a frequency of 0.1 Hz. After the completion of the horizontal and vertical tests a failure test was performed. In the failure test, the bearing was loaded monotonically in shear at a rate of 2.5 in./min.

The results of horizontal shear tests show that the shape of hysteresis loops change with the magnitude of vertical pressure loads. The loops change from narrow-elongated to wide-elliptical as vertical pressure increases. The results of vertical tests show that the bearing stiffness varies with the pressure level around which the cycles are centered and they are much higher than the so-called tangent stiffness of the monotonic loading curve. The most important results of the failure test is the fact that the bearing was able to sustain horizontal shear displacements to exceed the diameter of the bearing while under the design vertical load. The maximum shear strain developed at the limit of the actuator displacement is very large, about 412%, which is at least a factor of four beyond the design displacement level.

4. Conclusions

All three types of bearings have shown that they are capable of having extremely large shear strains before failure occurs. The most common failure mechanism was the debonding of the top steel plate from the isolators. The root cause of this debonding is poor quality control on some of the bearings. It should be noted that as the manufacturer gained experience with these rubber compounds, the test results became more consistent and indicated high quality bearings. For example, some LTV bearings had to be tested up to four times in pure tension until they finally failed. LTV bearings tested in fatigue at 150% shear strain sustained up to 1120 cycles before failing. This is roughly equivalent to about 30 min of extremely strong ground shaking. These results are more than satisfactory when considering that no earthquake will generate so many cycles with 150% strain of large displacements. This indicates that high quality bearings can be manufactured.

The most important result of the failure test of the isolators is the fact that bearings can sustain large horizontal displacement, several times larger than the design value, without failure. In the case of the Rubber Consultants' bearing, the maximum shear strain developed at the limit of the actuator displacement is 412%. This is equivalent to a maximum displacement of 19.6 in. with a maximum shear stress of 355 psi. If we accept that the design level is 200% shear strain, which is already twice the common design practice, then the corresponding shear stress is 50 psi. A shear stress of 50 psi and a

vertical bearing pressure of 625 psi correspond to a base shear coefficient of 0.08. Thus, to produce a maximum shear stress of 355 psi in the bearing, it would correspond to a base shear coefficient of 0.568. If the superstructure is designed to a standard base shear coefficient, 0.2, there can be no circumstances under which the bearings will fail before the structure.

The results of these test programs should give the designer confidence that base isolated structures can be designed and built with more than adequate safety margins. Their performance in moderate and strong earthquakes will be far superior to conventional structures. More importantly, the isolation system will significantly reduce damage to the structure and to internal equipment and other contents.

B. Electromagnetic Pump Development

The current ALMR concept being developed by General Electric requires that several large electromagnetic (EM) pumps operate submerged in the reactor vessel to pump the primary system sodium. These pumps are designed to operate without an active cooling system relying instead on the pumped and surrounding sodium to remove internally generated heat. The electrical windings of these self-cooled annular linear induction pumps will reach temperatures near (538°C) 1000°F. Conventional high voltage coil winding insulation is limited to about 200°C. An insulation system for an EM pump is required that can operate continuously at 538°C for 40 years at 1000 volts A.C., and be commercially available. These insulation systems are very sensitive to total insulation thickness, voltage gradient, and mechanical effects causing cracking. A program to develop and test this insulation system has been in progress since 1985. The program has consisted of the following components

- a) Small bar sample tests for materials evaluations,
- b) Tests on prototypic EM pump coils, and
- c) Prototypic testing of a full diameter-1/4 length EM pump.

Initial work was directed at screening of candidate materials by testing small bar samples at operating temperature and voltage. As a result of the bar sample tests several promising materials including woven Fiberglas-reinforced mica tape and woven ceramic fiber tape were selected. The glass/mica tape was

selected for further testing due to space and cost reasons. A program was initiated to determine the estimated lifetime of the glass/mica tape insulation at 538°C by accelerating the chemical aging of bar samples with the application of over-temperature at voltage. The lifetime at 538°C, the normal operating temperature, can be determined by running selected higher temperature accelerated aging tests to failure and using the Arrhenius Principle to predict the lifetime at 538°C.

The thickness of the insulation has been established at about 1.9 mm (0.075 in). This insulation thickness is a trade-off between an acceptably low voltage gradient and adequate heat transfer from the high temperature pump windings to the cooler magnetic iron stator. Generally mica has a poor thermal conductivity. Both bonded and unbonded glass/mica tape layers have been studied. Binders such as mono-aluminum phosphate and ceramic cements have shown acceptable electrical performance. These binders are applied to the tape by brush as the tape is wrapped on the bar sample with up to 15 tape layers on straight test bars of copper. Due to the large water content of these binders care must be taken to slowly heat the insulated bar to remove the water before applying significant voltage to the samples. After this curing operation, samples are tested at 680-750°C and a voltage of 1500-2500 volts at 60 Hz applied between the copper bar and an external electrode. Data on the leakage current through the insulation is taken and the time-to-failure recorded. The times-to-failure have extended from a few hundred hours to about 50,000 h. Based upon the high temperature accelerated aging tests of the bar samples the estimated lifetime at the normal operating temperature (538°C) is estimated to be in excess of 100 years.

This insulating technique was next applied to prototypic EM pump coils having shown the feasibility of glass/mica tape insulation of bar samples. Four small ovens are used for testing bar samples and four large ovens are used for testing the large prototypic pump coils. These ovens are shown in Fig. VII.1. The full-size EM pump coils are prototypic of planned ALMR pumps and are about 58.4 cm (23 in.) OD, 40.6 cm (16 in.) ID, and 2.54 cm (1.0 in.) thick. A series of coils were insulated using mono-aluminum phosphate and ceramic cement binders. These coils were tested at both ultra-high temperature (730°C) and at near normal operating temperature (550°C). The results showed that both binders tended to crack at the ultra-high temperature but performed satisfactorily at normal temperature.

Fig. VII.1. Ovens for Testing Bar Samples and Pump Coils

Oven testing of both samples and coils addresses the chemical effects of high temperature and voltage on the materials but did not address the mechanical stresses imposed on the materials in an actual EM pump. For this reason the General Electric Company designed and built a test article EM pump which would provide the mechanical stress conditions expected in an ALMR. The test article EM pump was 1/4 the length of a prototypic pump but of full-diameter. This test article EM pump is shown in Fig. VII.2. The pump was tested in the small sodium test facility constructed of 5.08 cm (2 in.) diameter pipe at ANL-E. The pump operated at prototypic current density and magnetic flux density; subsequently, each of the 24 coils in the pump was subjected to prototypic electrical, thermal, and mechanical stresses. Unlike conventional annular linear induction pumps, the coils of this pump can be easily removed. The initial coils were insulated with unbonded glass/mica tape. A test of 2047 h between August 1988 and March 1989 showed that this unbonded insulation system was unsatisfactory due to shrinkage resulting in loosening of the coils in the pump stator and subsequent coil vibration, insulation abrasion, and coil failure. Shrinkage was caused by the loss of the Fiberglas woven backing for the mica at temperatures higher than normally allowable for Fiberglas.

Fig. VII.2. EM Pump Stator Segment Test Article

This pump was re-built with a second set of coils. These coils were insulated at ANL with glass/mica tape bonded with a ceramic cement which does not shrink at high temperature. Earlier ANL oven tests had confirmed the good electrical performance and stability of the ceramic cement bonded coils. The ceramic cement was applied to fill all the voids in the open Fiberglas woven fabric backing of the tape. When cured and operated at high temperature the Fiberglas deteriorates but the multi-layered tape structure remains intact due

to the solid ceramic cement. Other improvements were made to the pump including additional ground fault insulation and better radial and axial clamping arrangements to prevent stator vibrations. These pump modifications were performed by ANL with GE consultation.

The test of the modified pump began in July 1989 on a 24-h per day, 5-day per week schedule. With the exception of two visual examinations of the stator, this schedule was continued through March 1990 with a total accumulation of 3611 h of operation. There was no evidence of any electrical fault or malfunction during this time. The ground leakage current, an important measure of coil performance, did not vary indicating no observable aging effects. Also, visual examinations showed no significant deterioration of the insulation. Some loosening of the radial clamping bands was observed but pump vibrations were minimal. The weekly schedule of pump operation required a temperature cycle once per week between 205 and 482°C (400 and 900°F) with a total of 33 thermal cycles over the testing period. The severe thermal cycling (33 cycles) represented a very significant mechanical stressing of the pump. These tests have successfully demonstrated the feasibility of fully developing a high temperature electromagnetic pump without an active cooling system.

The accelerated aging tests employing the small bar samples and the full-size coil tests have continued through Fiscal Year 1991. The results of the accelerated aging tests with the small bar samples are shown in Table VII.1. The oven internal air temperature and continuous 60 Hz voltage impressed across the insulation are illustrated. The original loadings of these ovens included

TABLE VII.1. Accelerated Aging Tests with Small Bar Samples

Oven Number	Temp., °C	Continuous Voltage	Number & Types of Samples on Test		Total Hours
			Original	Remaining	
1	680	150	5 dry & 5 Secon	3 dry & 5 Secon	24886
2	730	1500	5 dry & 5 Secon	0 dry & 5 Secon	25084
3	680	1500	12 MAP	0 MAP	*
4	730	2500	20 Secon	9 Secon	11040

*The Oven 3 heater control failed on 7-1-91 after 49890 h of testing. Three MAP samples remained on test at the time of heater control failure.

samples which were unbonded (dry), bonded with Secon 5 ceramic cement (Secon), and bonded with mono-aluminum phosphate (MAP). The numbers of bar samples which remain on test, having not experienced failure, are presented. Extrapolation of these data for the bonded bar samples in Ovens 1 and 2 indicate an expected time-to-failure at 538°C of over 1×10^6 h. Oven 3 has been taken out of service. The Oven 4 Secon 5 bonded samples being tested at 2500 volts at 730°C have had many failures but the higher test voltage prevents using this data in combination with 1500-volt data to make lifetime predictions. Also, since the data is all from samples at one temperature it cannot by itself allow an Arrhenius prediction of the insulation lifetime. These 2500-volt samples at 730°C are failing at a faster rate than similar samples at 1500 volts and 730°C. This data supports the view that the ALMR pump voltage should be kept to a minimum.

High temperature and voltage tests on full-size (23-in. diameter) EM pump coils have continued through Fiscal Year 1991 to determine both the electrical and mechanical performance of prototypic coils, individually. Six full-size coils continued on test and no failures were experienced during Fiscal Year 1991. Table VII.2 summarizes the test results with the six full-size coils. All coils exhibited steady leakage current during this period indicating acceptable electrical performance.

TABLE VII.2. High Temperature and Voltage Tests on Full-size Coils

Oven Number	Temp., °C	Continuous Voltage	Number & Types of Samples on Test	Total Hours
5	550	1500	Coils 17 & 18 - Secon	23870
6	550	1500	Coil 16 - MAP	34930
7	500	1500	Coil B - Secon	21754
8	500	1500	Coils 19 & 20 - Secon	22594

References for Section VII

1. J. M. Kelly, I. D. Aiken, and D. Clyde, "Performance Evaluation of ANL Sendai Bearings," ANL/Shimizu, ANL-002 (September 1989).
2. J. M. Kelly and E. Quiroz, "Mechanical Characteristics and Failure Mechanisms of Moderate Shape Factor Isolation Bearings," Argonne National Laboratory Report, ANL/NPR-91/4 (June 1991).
3. J. M. Kelly, "Mechanical Characteristics of Low Modulus High Damping Natural Rubber Isolators for a Base Isolated Demonstration Building," ANL/Shimizu, ANL-004 (June 1991).
4. R. A. Jaross, Argonne National Laboratory, personal communication (November 1990).

VIII. LIST OF PUBLICATIONS

The technical papers on the IFR Program activities, which have been published through the end of FY 1991 are listed below. The publications are categorized into the following subject areas: IFR Concept, Metal Fuel Performance, Pyroprocessing, Safety, Neutronics and Core Design, and Fuel Cycle Demonstration.

IFR Concept

1. Y. I. Chang, "Desirable LMR Design Features: Lessons Learned from EBR-II Operating Experience," presented at Intl. Spec. Mtg. on Potential of Small Nuclear Reactors for Future Clean and Safe Energy Sources, Tokyo Institute of Technology, Tokyo, Japan (October 23-25, 1991).
2. C. E. Till and R. Avery, "Advanced Reactor Development: The LMR Integral Fast Reactor Program at Argonne," Intl. Conf. on Emerging Nuclear Energy Systems 1991, 20(4)Part 2:573, Monterey, CA (June 16-21, 1991).

Metal Fuel Performance

1. G. L. Batte, R. G. Pahl, and G. L. Hofman, "Current Status of the Run-Beyond-Cladding-Breach (RBCB) Tests for the Integral Fast Reactor (IFR) Metallic Fuels Program," J. Nucl. Tech., in press (1990).
2. L. Leibowitz and R. A. Blomquist, "Thermodynamics and Phase Equilibria of the Iron-Uranium System," J. Nucl. Mater., 184:47 (1991).
3. L. Leibowitz, R. A. Blomquist, and A. D. Pelton, "Thermodynamic Modeling of the Phase Equilibria of the Plutonium-Uranium System," J. Nucl. Mater., 184:59 (1991).
4. B. R. Seidel, G. L. Batte, N. E. Dodds, G. L. Hofman, C. E. Lahm, R. G. Pahl, D. L. Porter, H. Tsai, and L. C. Walters, "A Decade of Advances in Metallic Fuel," ANS Winter Mtg. 1990--Special Cluster Sessions, "LMR A Decade of LMR Progress and Promise," 196, Washington, DC (November 11-15, 1990).
5. B. R. Seidel, G. L. Batte, N. E. Dodds, C. E. Lahm, R. G. Pahl, and H. Tsai, "Recent Progress in the Development of Metallic Fuel," Proc. ANS Mtg. on the Safety, Status, and Future of Non-commercial Reactors and Irradiation Facilities, 359, Boise, ID (September 30-October 4, 1990).
6. B. R. Seidel and L. C. Walters, "A Decade of Advances in Metallic Fuel," Trans. Am. Nucl. Soc., Washington, DC (November 11-15, 1990).

Pyroprocessing

1. J. E. Battles, W. E. Miller, and E. C. Gay, "Pyrometallurgical Processing of Integral Fast Reactor Metals Fuels," Proc. of the Third. Intl. Conf. on Nuclear Fuel Reprocessing and Waste Management, RECOD'91, 1:342, Sendai, Japan (April 14-18, 1991).
2. W. H. Hannum, J. E. Battles, T. R. Johnson, and C. C. McPheeters, "Actinide Consumption: Nuclear Resource Conservation without Breeding," Proc. of the 53rd Annual Mtg. of the Am. Power Conf., 53-II:1308, Chicago, IL (April 29-May 1, 1991).
3. T. R. Johnson and J. E. Battles, "Waste Management in IFR Fuel Cycles," Waste Management Conf., 1:815, Tucson, AZ (February 24-28, 1991).
4. R. D. Pierce, J. P. Ackerman, G. K. Johnson, T. P. Mulcahey, and D. S. Poa, "Recycle of Light Water Reactor Actinides to an Integral Fast Reactor," Proc. of the Third Intl. Conf. on Nuclear Fuel Reprocessing and Waste Management, RECOD'91, 1:336, Sendai, Japan (April 14-18, 1991).
5. D. S. Poa, G. K. Johnson, T. P. Mulcahey, and R. D. Pierce, "Electrochemical Recovery of Pyrochemical Reduction Salt," 180th Electrochem. Soc. Mtg., 283, Tucson, AZ (October 13-17, 1991).
6. Z. Tomczuk, J. P. Ackerman, R. D. Wolson, and W. E. Miller, "Electrorefining of Metallic Fuel from a Cadmium Anode," 180th Electrochem. Soc. Mtg., 278, Tucson, AZ (October 13-17, 1991).
7. J. L. Willit, Z. Tomczuk, E. C. Gay, and W. E. Miller, "Fundamental and Applied Aspects of Actinide Electrodeposition at Liquid Metal Electrodes," 180th Electrochem. Soc. Mtg., 282, Phoenix, AZ (October 13-17, 1991).

Safety

1. R. W. Benedict, R. D. Phipps, and D. W. Condiff, "Interim Waste Storage for the Integral Fast Reactor Fuel Cycle Demonstration," Proc. of the Intl. Conf. on High-level Radioactive Waste Management, 2:1688, Las Vegas, NV (April 23-May 3, 1991).
2. R. J. DiMelfi, E. E. Gruber, and J. M. Kramer, "Microstructural Evolution in a Ferritic-Martensitic Stainless Steel and Its Relation to High-Temperature Deformation and Rupture Models," Modeling the Deformation of Crystalline Solids, Ed. by T. C. Lowe, A. D. Rollet, P. S. Follensbee, and G. S. Daehn, The Minerals, Metals and Materials Society, Warrendale, PA, pp. 647-664 (1991).
3. R. F. Kulak and T. H. Hughes, "Mechanical Characterization of Seismic Base Isolation Elastomers," SMiRT 11 Trans., K:163 (1991).
4. R. F. Kulak and C. Y. Wang, "Design and Analysis of Seismically Isolated Structures," J. Nucl. Eng. & Design, 127:419 (1991).

Safety (Contd.)

5. T. Kuroda, Y. W. Chang, and R. W. Seidensticker, "Joint US/Japanese Program on Full-Size Building Tests for Base Seismic Isolation," Proc. of the Intl. Fast Reactor Safety Mtg., III:379, Snowbird, UT (August 12-16, 1990).
6. R. W. Seidensticker, "R&D Activities at Argonne National Laboratory for the Application of Base Seismic Isolation in Nuclear Facilities," Presented at 2nd Intl. Seminar on Seismic Base Isolation for Nuclear and Non-Nuclear Structures, Nara, Japan (August 26-28, 1991).
7. R. W. Seidensticker and Y. W. Chang, "Applicability of Base Isolation R&D in Nonreactor Facilities to a Nuclear Reactor Plant," Proc. 52nd Am. Power Conf., 52:50, Chicago, IL (April 23-25, 1990).
8. C. P. Tzanos, "A Multigrid Method for the Solution of the Incompressible Flow Equations at High Re Numbers," Trans. Am. Nucl. Soc., 63:199, Nashville, TN (June 10-14, 1990).
9. C. P. Tzanos, "Evaluation of a Central-Difference-Like Method for the Solution of the Convection-Diffusion Equation," Trans. Am. Nucl. Soc., 62:293, Washington, DC (November 11-15, 1990).
10. C. P. Tzanos and D. R. Pedersen, "Analysis of DRACS and DRACS-RVACS Decay heat Removal Experiments," J. Nucl. Technol., 95:253 (1991).
11. C. P. Tzanos, J. H. Tessier, and D. R. Pedersen, "An Optimization Study for the Reactor Vessel Auxiliary Cooling System of a Pool Liquid-Metal Reactor," J. Nucl. Technol., 94:68 (1991).
12. T. S. Wu and T. J. Moran, "Seismic Requalification of a Safety Class Crane," 1991 Pressure Vessel and Piping Conf., PVP-220:331, San Diego, CA (June 22-27, 1991).

Neutronics and Core Design

1. Y. I. Chang, R. N. Hill, E. K. Fujita, D. C. Wade, Y. Kumaoka, M. Suzuki, M. Kawashima (Toshiba), H. Nakagawa (JAPC), "Core Concepts for "Zero-Sodium-Void-Worth Core" in Metal Fueled Fast Reactor," Proc. Intl. Conf. on Fast Reactors and Related Fuel Cycles, II:14.5, Kyoto, Japan (October 28-November 1, 1991).
2. T. J. Downar and H. S. Khalil, "Uncertainty in the Burnup Reactivity Swing of Liquid-Metal Fast Reactors," J. Nucl. Sci. Eng., 109:278 (1991).
3. P. J. Finck, R. N. Hill, and S. Sakamoto, "Improvements in EBR-II Core Depletion Calculations," Proc. Intl. Conf. on Fast Reactors and Related Fuel Cycles, III:P1-3, Kyoto, Japan (October 28-November 1, 1991).

Neutronics and Core Design (Contd.)

4. R. N. Hill, "LMR Design Concepts for Transuranic Management in Low Sodium Void Worth Cores," Proc. Intl. Conf. on Fast Reactors and Related Fuel Cycles, II:19.1, Kyoto, Japan (October 28-November 1, 1991).
5. H. S. Khalil and R. N. Hill, "Evaluation of Liquid-Metal Reactor Design Options for Reduction of Sodium Void Worth," J. Nucl. Sci. Eng., 109:221 (1991).
6. L. C. Leal, J. R. Liaw, T. A. Daly, and E. K. Fujita, "Neutron Source from Spontaneous Fission and (α ,n) Reactions in Mixtures," Trans. Am. Nucl. Soc., 64:555, San Francisco, CA (November 10-14, 1991).
7. W. H. Perry, R. M. Singer, R. W. King, and K. C. Gross, "Advanced Condition Monitoring Techniques and Plant Life Extension Studies at EBR-II," Proc. of the Intl. Conf. on Nuclear Plant Life Extension, Upgrading, Repair, Refurbishment, Upgrading, and Aging (PLEX-91), 251, Berlin, Germany (December 2-4, 1991).
8. J. Reifman, L. L. Briggs, and T. Y. C. Wei, "A First-Principles Generic Methodology for Representing the Knowledge Base of a Process Diagnostic Expert System," Proc. Fourth Intl. Conf. on Industrial and Engineering Applications of Artificial Intelligence and Expert Systems, 1:255, Kauai, HI (June 2-5, 1991).
9. R. M. Singer, K. C. Gross, and K. E. Humenik, "Pumping System Fault Detection and Diagnosis Utilizing Pattern Recognition and Fuzzy Inference Techniques," Proc. of the Fourth Intl. Conf. on Industrial and Engineering Applications of Artificial Intelligence and Expert Systems, 1:55, Kauai, HI (June 2-5, 1991).
10. B. J. Toppel, "REBUS-3, Fuel Cycle Analysis," Proc. Intl. Mtg. on Advances in Mathematics, Computations, and Reactor Physics, 5:30.5, Pittsburgh, PA (April 28-May 1, 1991).

Fuel Cycle Demonstration

1. R. W. Benedict, D. W. Condiff, and R. D. Phipps, "Interim Storage for the Integral Fast Reactor Cycle Demonstration," Proc. of the Second Annual Intl. Conf. on High-level Radioactive Waste Management, 2:1688, Las Vegas, NV (April 28-May 3, 1991).
2. J. C. Courtney, M. D. Carnes, C. C. Dwight, and R. J. Forrester, "A Description of the Demonstration Integral Fast Reactor Fuel Cycle Facility," Health Physics, 61:553 (October 1991).
3. J. C. Courtney and C. C. Dwight, "Radiation Shielding Design for a Hot Repair Facility," Health Physics, 61:565 (October 1991).
4. M. J. Lineberry, R. D. Phipps, R. H. Rigg, R. W. Benedict, M. D. Carnes, J. E. Herceg, and R. E. Holtz, "IFR Fuel Cycle Demonstration in the EBR-II Fuel Cycle Facility," Intl. Conf. on Fast Reactors and Related Fuel Cycles, 4:15-2, Kyoto, Japan (October 28-November 1, 1991).

END

**DATE
FILMED
9 / 17 / 92**