119
8-24-94 JS (2)

DOE/ID/12584-179
GJ/TMC-01 (Third Edition)
UC-902

June 1994

Field Calibration Facilities for Environmental Measurement of Radium, Thorium, and Potassium

Third Edition

R. Leino, D. C. George, B. N. Key, L. Knight, and W. D. Steele

Technical Measurements Center

Grand Junction Projects Office

RUST GEOTECH INC.

Approved for public release; distribution is unlimited.

REPRODUCTION OF THIS DOCUMENT IS UNLIMITED

Printed on recycled paper

Printed in the United States of America.

Available from:
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161

NTIS price codes
Printed copy: A05
Microfiche copy: A01

James Lampley, Manager,
Grand Junction Projects Office
Daniel Varhus, DOE Program Manager,
Grand Junction Projects Office
John R. Duray, Program Manager,
Technical Measurements Center
W. D. Steele, Project Manager
Technical Measurements Center

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed in this report, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Field Calibration Facilities for Environmental Measurement of Radium, Thorium, and Potassium

Third Edition

**R. Leino
D. C. George
B. N. Key
L. Knight
W. D. Steele**

Technical Measurements Center

June 1994

**Prepared by
RUST Geotech Inc.
P.O. Box 14000
Grand Junction, Colorado 81502**

**Work performed under DOE Contract No. DE-AC04-86ID12584 for the
U.S. Department of Energy
Grand Junction Projects Office**

MASTER

rp
A PORTION OF THIS DOCUMENT IS UNCLASSIFIED

Contents

	Page
Preface	v
Summary	vii
1.0 Introduction and Discussion	1
1.1 Description of the Calibration Facilities	1
1.2 Characterization of the Calibration Facilities	3
2.0 Bibliography	7
Appendix A Primary Field Calibration Facilities	A-1
Map to Grand Junction Calibration Site	A-4
Layout of Grand Junction Calibration and Test Site	A-5
Walker Field Large-Area Calibration Pads: Grand Junction	A-6
Grand Junction H Pads	A-7
Grand Junction P Pads	A-8
Grand Junction E Pads	A-9
Grand Junction L Pads	A-10
Grand Junction K, U, and T Models	A-11
Grand Junction KW Model	A-12
Grand Junction BL/BH, BT/BK, BU/BM, and BA/BB Models	A-13
Grand Junction N3, U1, U2, and U3 Models	A-15
Grand Junction WF Model	A-16
Grand Junction N1 Model	A-17
Grand Junction N2 Model	A-18
Grand Junction N4 Model	A-19
Grand Junction N5 Model	A-20
Grand Junction Thin Dipping Bed Models	A-22
Grand Junction A Models	A-23
Grand Junction D Model	A-25
Grand Junction SW Model	A-26
Grand Junction SS/SB Model	A-27
Grand Junction Granite Block Model	A-28
Grand Junction 300-Foot Test Hole	A-29
Appendix B Secondary Field Calibration Facilities	B-1
Map to Casper Calibration Site	B-4
Layout of Casper Calibration Site	B-5
Casper P Pads	B-6
Casper E Pads	B-7
Casper CBT/CBK, CBU/CBM, and CBA/CBB Models	B-8
Casper CH and CL Models	B-10
Map to Grants Calibration Site	B-11

Contents (continued)

	Page
Layout of Grants Calibration Site	B-12
Grants P Pads	B-13
Grants E Pads	B-14
Grants GBT/GBK, GBU/GBM, and GBA/GBB Models	B-15
Grants GH and GL Models	B-17
Map to George West Calibration Site	B-18
Layout of George West Calibration Site	B-19
George West P Pads	B-20
George West E Pads	B-21
George West TBT/TBK, TBU/TBM, and TBA/TBB Models	B-22
George West TH and TL Models	B-24
Appendix C Relocatable Field Calibration Pads	C-1
NP Pads	C-4
PP Pads	C-5
T Pads	C-6
Appendix D Conversion Factors	D-1
Appendix E Example Conversion Factor Derivation	E-1

Figure

Figure	1. Locations of U.S. Department of Energy Calibration Facilities	2
--------	--	---

Tables

Table	1. Summary of Surface Calibration Facilities for Radiometric Instruments	4
	2. Summary of Subsurface Calibration Facilities for Radiometric Instruments	5
	3. Summary of Calibration Facilities for Nonradiometric Instruments	6

Preface

The first edition of this report, prepared by D. C. George and L. Knight and released in October 1982, presented physical-characteristic information for the various U.S. Department of Energy radiologic-instrument calibration facilities located throughout the United States. The primary and secondary calibration facilities are maintained by the Technical Measurements Center. The second edition, prepared by W. D. Steele and D. C. George and released in August 1986, was an effort to provide the most current information available regarding the calibration facilities. This third edition is necessary to keep current with changes to the facilities. Three secondary field calibration facilities were decommissioned and several models were added to or removed from the primary calibration facility. Every attempt has been made to ensure that the information presented is accurate.

Summary

This report describes calibration facilities located at Grand Junction, Colorado, and at three secondary sites. These facilities are available to contractors for the calibration of radiometric field instrumentation for in situ measurements of radium, thorium, and potassium.

The U.S. Department of Energy and its predecessor agencies constructed all of the calibration facilities described herein for use in annual uranium-reserve determinations. The use of these facilities for the calibration of radiometric field instruments used in remedial action is made possible by the commonality of the radiometric measurement technique for uranium and for radium. The use of these facilities standardizes remedial action measurements in a cost-effective manner.

1.0 Introduction and Discussion

The U.S. Department of Energy (DOE) Office of Environmental Management has responsibility for four major remedial action programs: the Grand Junction Remedial Action Program (GJRAP), authorized by congressional legislation,* the Uranium Mill Tailings Remedial Action Project (UMTRAP), also authorized by congressional legislation, the Formerly Utilized Sites Remedial Action Program (FUSRAP),† and the Surplus Facilities Management Program (SFMP).‡

In support of these programs, the DOE Office of Environmental Management established the Technical Measurements Center (TMC) in 1982 at the DOE Grand Junction Projects Office in Grand Junction, Colorado. RUST Geotech Inc. is the current contractor responsible for operation of the TMC.

A key component of TMC support is the development, identification, standardization, and maintenance of calibration facilities for environmental radioelement measurements. The borehole facilities also can serve as standards to calibrate high-resolution passive gamma logging systems for analyses of cobalt-60, cesium-137, europium-152, europium-154, and other man-made nuclides (Koizumi et al. 1991; Brodeur et al. 1991; Koizumi et al. 1994). Logging systems calibrated for these anthropogenic gamma-ray emitters have been used to assess subsurface contaminants at the DOE Hanford nuclear weapons facility in Washington State.

Over the past 25 years, DOE and its predecessor agencies have been developing facilities for calibrating gamma-ray-measuring instruments used in uranium exploration. These facilities are also suitable for calibration of gamma-ray

instruments used for remedial action measurements, specifically, in situ assays for natural radionuclides. The calibration facilities are available for use free of charge at four sites located throughout the United States (see Figure 1). The primary calibration facilities are located at Grand Junction, Colorado, and secondary facilities are located at each of three sites: Casper, Wyoming, Grants, New Mexico, and George West, Texas.

In addition, calibration pads are currently located at Niagara Falls, New York, and Middlesex, New Jersey (referred to herein as the PP and NP calibration pads). These pads (and the T pads currently located at Grand Junction, Colorado) may be moved as requirements change, and information as to their current location is available from the TMC.

To use any of the facilities described in this report, contact TMC personnel at

RUST Geotech Inc.
P.O. Box 14000
Grand Junction, CO 81502
(303) 248-6702
Fax (303) 248-6040

1.1 Description of the Calibration Facilities

The calibration facilities provide distributed sources of radium, thorium, and/or potassium. In general, they were constructed by enriching a concrete mix with uranium ore, monazite sand, and/or orthoclase sand. The facilities consist of pads and borehole models with the following characteristics:

*Public Law 92-314, "Radiation Exposure Remedial Action," dated June 16, 1972. Also, "Amendments to Program Providing Remedial Action Regarding Uranium Mill Tailings," dated February 21, 1978.

U.S. Public Law, 1978. "Uranium Mill Tailings Radiation Control Act of 1978," Public Law 95-604, November 8, 1978.

†In 1974, the Atomic Energy Commission (AEC) initiated a survey program to identify all formerly utilized sites and determine their radiologic status. The survey program was continued by the Energy Research and Development Administration (ERDA) and the U.S. Department of Energy (DOE), successors to the AEC. In 1978, the Formerly Utilized Sites Remedial Action Program (FUSRAP) was established and a generic program plan was prepared by DOE. Legislative authority for 14 FUSRAP sites is implied in the Atomic Energy Act of 1954, as amended.

‡The Atomic Energy Act of 1954, as amended, is the DOE's charter that gives it responsibility for the many Federal sites and facilities involved in various nuclear programs. In 1978, a program plan, the Surplus Facilities Management Program (SFMP), was established by DOE for those sites and facilities classified as surplus and owned by the Federal Government. Beginning in FY 1982, Congress directed that surplus facility projects be budgeted according to their primary use during operation, that is, energy-related or defense-related.

Figure 1. Locations of U.S. Department of Energy Calibration Facilities

- Cylinders approximately 4 feet in diameter by 2 feet high, referred to as "scintillometer pads," "spectrometer pads," or simply "pads."
- Large-area slabs, 30 feet by 40 feet and 1.5 feet thick, referred to as "Walker Field pads" because they are located at Walker Field Airport in Grand Junction, Colorado.
- Cylinders and other equivalent configurations approximately 4 feet in diameter and up to 30 feet deep containing boreholes along their axes, referred to as "borehole models" or simply "models."

This report presents descriptions of the facilities and the accompanying physical-characteristic information contained in Appendices A, B, and C. The values for radioelement concentrations within the models and pads use information from studies conducted by George, Heistand, and Krabacher (1983), Heistand and Novak (1984), and George, Novak, and Price (1985). Information concerning dimensional descriptions of the models and pads, as well as maps to all of the calibration sites, have been updated as required to reflect the latest available information. Concepts and details of calibration procedures for specific instruments are beyond the scope of this report; however, many of these procedures are presented in other TMC reports (Marutzky and others, 1984; George and Price, 1982).

1.2 Characterization of the Calibration Facilities

Over the years, several studies have been performed to characterize the models and pads referred to in this document. The information provided in this third edition regarding the calibration facilities is as current as possible. Every effort has been made to ensure that the data are consistent with DOE remedial action contractor procedures.

Concentrations were not assigned for the barren zones of the models in any of the recent studies. Consequently, barren-zone data have not been included in this report. Because some parameters for the Grand Junction A and D Models were not reassigned, the original assignments have been included here in an effort to present the most complete data set possible. Footnotes presented with each data set are intended to clarify the origin of the assigned parameters.

Tables 1, 2, and 3 are summary descriptions of pads and models at the calibration facilities. The entries in the column labeled "Intended Use" are not necessarily intended to be restrictions on the use of the calibration facility, because some models and pads are useful for several instrument types. The entries in the column labeled "Approximate Concentration" are meant only for order-of-magnitude comparisons. More precise values for the models and pads can be found in Appendices A, B, and C. The entries in the column labeled "Notes" suggest appropriate uses for the pads and models.

Discussions of calibration procedures for specific instrument types can be found in TMC reports by Marutzky and others (1984) and George and Price (1982). It is recommended that personnel involved in remedial action programs who intend to utilize the calibration facilities contact TMC personnel to discuss specific procedures not covered in these documents.

Several units of measure have been used over the years to represent radionuclide concentrations. The accepted units for remedial action programs are picocuries per gram. All concentrations stated herein are reported in picocuries per gram. Useful conversion factors are presented in Appendix D. In addition, Appendix D contains the constants used to derive these conversion factors. The derivation of the conversion factors is discussed in Appendix E.

Table 1. Summary of Surface Calibration Facilities for Radiometric Instruments

Intended Use	Pad Designation	Approximate Concentration ^a			Location	Notes
		Potassium-40 (pCi/g)	Radium-226 ^b (pCi/g)	Thorium-232 ^b (pCi/g)		
Portable or Mobile Instrument Calibrations	W1	10	1	1	Grand Junction Airport	These large-area pads, 30 ft by 40 ft, are intended for calibration of spectral "surface-surveying" instruments.
	W2	50	2	1		
	W3	20	2	5		
	W4	20	10	1		
	W5	50	8	2		
Portable Spectrometer Calibrations	H1	10	1	1	GJPO ^c	These pads are intended for calibration of portable spectral instruments.
	H2	50	1	1		
	H3	10	160	1		
	H4	10	10	70		
	H5	50	100	20		
Portable Scintillometer and Spectrometer Calibrations	PK, XPK ^d	50	1	0	All Sites	These pads are intended for calibration of both scintillometers and spectral instruments.
	PL, XPL ^d	15	80	1		
	PH, XPH ^d	15	400	1		
	PT, XPT ^d	15	7	30		
	PB, XPB ^d	0	0	0		
	NPL, PPL	11	16	1	See Footnote e	
	NPH, PPH	50	11	1		
	TL1, TL2, TL3, TL4	2	1	10	GJPO ^c	
	TH1, TH3, TH3, TH4	5	1	40		
	E1, E2, E4, E5	10, 10, 10, 10	30, 80, 400, 900	1, 1, 1, 1	GJPO ^c C, G, T ^c	These pads are intended for calibration of portable total-count instruments.
	XE2 ^d , XE4 ^d	10, 10	80, 400	1, 1		
	L1, L2, L3		100, 200, 400		GJPO ^c	These pads were made from the same materials as models A1, A2, and A3. These pads have a 2-inch diameter vertical bore-hole through the center of the pad.

^aConcentrations shown are rounded to order of magnitude for purposes of comparison. Consult data sheets in Appendices A, B, and C for concentrations to be used for calibration.

^bValues tabulated are radiometric equivalent (e) concentrations; see Appendices D and E.

^cGJPO—Grand Junction Projects Office; C, G, T—secondary sites as explained in footnote d.

^dThe X designates any of the three secondary sites. C = Casper, Wyoming; G = Grants, New Mexico; T = George West, Texas. For example CH is at Casper.

^eAt the time of publication, pad NPL was located at Niagara Falls, New York, and pad NPH was located at Middlesex, New Jersey.

Table 2. Summary of Subsurface Calibration Facilities for Radiometric Instruments

Intended Use	Pad Designation	Approximate Concentration ^a			Location	Notes
		Potassium-40 (pCi/g)	Radium-226 ^b (pCi/g)	Thorium-232 ^b (pCi/g)		
Spectral Logging System Calibrations	K U T KW BK, XBK ^d BU, XBU ^d BT, XBT ^d BM, XBM ^d	50 10 10 40 50 10 10 40	1 160 10 120 1 200 10 130	2 6 500 200 2 8 600 500	GJPO ^c All Sites	The K, U, and T models are used to determine stripping factors for spectral logging systems. The U, BU, and XBU models are useful for Ra calibrations for total-count systems. The KW model has five different borehole diameters; the enriched middle zone is a mixture of Ra-Th-K.
Total-Count Logging System Calibrations	N3, U1, U2, U3 WF XL, XH ^d BL, BH, XBL, XBH ^d		700, 7000, 3000, 1500 800 800, 6000 300, 3000		GJPO ^c C, G, T ^c GJPO ^c	The high concentrations of models in this group make them unsuitable for some logging systems. Lower "radium-only" concentrations can be found in other models. The WF model is useful for water, casing, and hole size corrections; the D model has a lower Ra concentration and is similar to the WF model.
Total-Count Logging Systems Measurements	N1 N2 N4 N5		700 1200 700, 2600 300, 600, 700, 2700, 4900		GJPO ^c	The high concentrations of these models make them unsuitable for some logging systems. These models are for experimental use.
Total-Count and Spectral Logging System Measurements of Thin Dipping Enriched Zones	TDB-1, TDB-2	17	700	1	GJPO ^c	These models are intended for the total-count and spectral measurements of thin dipping enriched zones.
Fission-Neutron Logging System Calibrations	A1, A2, A3, A4, A5, A6 D BA, BB, XBA, XBB ^d		90, 200, 500, 600, 200, 200 200 60, 800, 900		GJPO ^c GJPO ^c All Sites	These models are intended for fission-neutron logging system calibrations. However, they are useful for gamma-ray system calibrations if they have not been recently used with a neutron source. The D model has seven different borehole diameters.

^aConcentrations shown are rounded to order of magnitude for purposes of comparison. Consult data sheets in Appendices A, B, and C for concentrations to be used for calibration.

^bValues tabulated are radiometric equivalent (e) concentrations, see Appendices D and E.

^cGJPO—Grand Junction Projects Office; C, G, T—secondary sites as explained in footnote d.

^dThe X designates any of the three secondary sites. C = Casper, Wyoming; G = Grants, New Mexico; T = George West, Texas. For example CH is at Casper.

Table 3. Summary of Calibration Facilities for Nonradiometric Instruments

Intended Use	Pad Designation			Location	Notes
Moisture/Porosity and Density	SW SS, SB	Porosity (vol %)	Dry Bulk Density (g/cm ³)	GJPO ^a	These models are intended for calibration of moisture/porosity and/or density measurement systems. Model SW is water and sand and also is suitable for tool background determination.
		40 20, 5	1.6 2.2, 2.6		
Magnetic Susceptibility Calibration	Granite Block	Magnetic Susceptibility (μCGS)	Dry Bulk Density (g/cm ³)	GJPO ^a	This model is intended for calibration of magnetic susceptibility measurement systems.
		385	2.63		
Depth Odometer Verification	300-Foot Test Hole	Depth (ft)		GJPO ^a	This model is intended for verification of depth odometers using measurements of radium sources placed at various depths.
		80.9 180.5			

^aGJPO—Grand Junction Projects Office

2.0 Bibliography

- Bristow, Q., J. Conaway, and P. Killeen, 1984. "Application of Inverse Filtering to Gamma-Ray Logs: A Case Study," *Geophysics*, Volume 49, Number 8, pp. 1369-1373.
- Brodeur, J.R., C.J. Koizumi, W.H. Ulbricht, and R.K. Price, 1991. *Calibration of a High-Resolution Passive Gamma-Ray Logging System for Nuclear Waste Assessment*, Proceedings of the Fourth International Symposium on Borehole Geophysics for Minerals, Geotechnical, and Groundwater Applications, Minerals and Geotechnical Logging Society, Toronto, Ontario (Canada).
- Emilia, D.A., J.W. Allen, R. B. Chessmore, and R. B. Wilson, 1981. *The DOE/Simplec Magnetic Susceptibility Logging System*, GJBX-75(81), Bendix Field Engineering Corporation, Grand Junction Office, U.S. Department of Energy, Grand Junction, Colorado, and Simplec Manufacturing Co., Inc. (Wilson), Dallas, Texas, March 1981.
- George, D.C., 1986. *Parameter Assignments for Sandstone Models*, Internal Memorandum, Bendix Field Engineering Corporation, Grand Junction, Colorado, July 17, 1986.
- George, D.C., and R.K. Price, 1982. *Abbreviated Total-Count Logging Procedures for Use in Remedial Action*, GJ/TMC-03(82), Technical Measurements Center, U.S. Department of Energy, Grand Junction Area Office., Grand Junction, Colorado.
- George, D.C., B.E. Heistand, and J.E. Krabacher, 1983. *Grade Assignments for Models Used for Calibration of Gross-Count Gamma-Ray Logging Systems*, GJBX-39(83), Bendix Field Engineering Corporation, Grand Junction, Colorado.
- George, D.C., E.F. Novak, and R.K. Price, 1985. *Calibration-Pad Parameter Assignments for In-Situ Gamma-Ray Measurements of Radium, Thorium, and Potassium*, GJ/TMC-17, Technical Measurements Center, U.S. Department of Energy, Grand Junction Projects Office, Grand Junction, Colorado.
- Heistand, B.E., and E.F. Novak, 1984. *Parameter Assignments for Spectral Gamma-Ray Borehole Calibration Models*, GJBX-2(84), Bendix Field Engineering Corporation, Grand Junction, Colorado.
- Koizumi, C.J., 1979. *Logging Calibration Models for Fission Neutron Sondes*, GJBX-267(81), Bendix Field Engineering Corporation, Grand Junction, Colorado.
- Koizumi, C.J., 1980. *Thin, Dipping Ore Zone Logging Models: Log Studies*, GJBX-54(80), Bendix Field Engineering Corporation, Grand Junction Operations, U.S. Department of Energy, Grand Junction, Colorado, March 1980.
- Koizumi, C. J., J.R. Brodeur, W.H. Ulbricht, and R.K. Price, 1991. *Calibration of the RLS HPGe Spectral Gamma Ray Logging System*, Westinghouse Hanford Company, publication WHC-EP-0464, Richland, Washington.
- Koizumi, C. J., J.R. Brodeur, R.K. Price, J.E. Meisner, and D.C. Stromswold, 1994. "High-Resolution Gamma-Ray Spectrometry Logging for Contamination Assessment," *Nuclear Geophysics*, Volume 8, Number 2.
- Lederer, C.M., and V.S. Shirley (eds.), 1978. *Table of Isotopes*, Seventh Edition, John Wiley and Sons, New York, New York.
- Marutzky, S.J., W.D. Steele, B.N. Key, and K. L. Kosanke, 1984. *Surface Gamma-Ray Measurement Protocol*, GJ/TMC-06, Technical Measurements Center, U.S. Department of Energy, Grand Junction Projects Office, Grand Junction, Colorado.
- Matthews, M., 1975. *Data Compendium for the Logging Test Pits at the ERDA Grand Junction Compound*, Bendix Field Engineering Corporation, Grand Junction, Colorado.
- Walker, F.W., G.J. Kirouac, and F.M. Rourke, 1977. *Chart of the Nuclides*, Twelfth Edition, General Electric Corporation, San Jose, California.

Appendix A

Primary Field Calibration Facilities

Primary Field Calibration Facilities

This appendix presents detailed information concerning location, layout, pad and model descriptions, and radioelement concentrations for the primary calibration facilities at Grand Junction, Colorado. These facilities are administered by the U.S. Department of Energy Grand Junction Projects Office and are maintained and operated by the Technical Measurements Center.

Questions concerning use of the facilities and/or calibration procedures should be addressed to the Technical Measurements Center.

Map to Grand Junction Calibration Site

Map not to scale.

Layout of Grand Junction Calibration and Test Site

Not to scale.

Walker Field Large-Area Calibration Pads: Grand Junction

Section (typical)

Table A-1. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
W1	0.82 ± 1.02	0.67 ± 0.10	12.67 ± 0.72	1.91	0.256
W2	1.92 ± 1.54	0.87 ± 0.12	45.58 ± 1.82	1.99	0.260
W3	1.70 ± 1.38	4.92 ± 0.26	17.07 ± 0.82	1.92	0.208
W4	12.07 ± 5.64	1.04 ± 0.12	17.56 ± 0.98	1.91	0.247
W5	8.36 ± 3.52	1.91 ± 0.16	34.68 ± 1.46	1.97	0.244

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

Grand Junction H Pads

Plan

Section

Table A-2. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
H1	0.84 ± 0.90	0.67 ± 0.10	10.95 ± 0.62	1.86	0.185
H2	0.67 ± 0.90	0.08 ± 0.06	54.00 ± 1.56	1.87	0.142
H3	161.83 ± 20.40	0.66 ± 0.08	11.31 ± 0.86	1.89	0.181
H4	11.03 ± 4.00	67.90 ± 1.24	10.76 ± 1.48	1.92	0.099
H5	102.59 ± 17.42	19.57 ± 0.54	37.75 ± 1.60	1.93	0.143

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

Grand Junction P Pads

Table A-3. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
PK	1.16 ± 0.78	0.04 ± 0.06	50.96 ± 1.50	1.94	0.145
PL	85.71 ± 14.16	0.64 ± 0.10	15.78 ± 1.02	1.90	0.180
PH	374.36 ± 47.06	0.60 ± 0.10	15.80 ± 1.58	1.92	0.180
PT	6.63 ± 3.06	31.28 ± 0.86	14.92 ± 1.08	1.90	0.162
PB ^c	0.0 ± 0.3	0.0 ± 0.3	0.0 ± 0.1	d	d

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

^cPad PB does not have a hole as shown above.

^dValue not assigned.

Grand Junction E Pads

Plan

Section

Table A-4. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
E1	25.21 ± 6.68	0.67 ± 0.10	13.30 ± 0.72	1.89	0.116
E2	80.34 ± 14.12	0.79 ± 0.10	13.83 ± 0.98	1.84	0.123
E4	395.84 ± 46.92	0.66 ± 0.12	11.43 ± 1.48	1.84	0.143
E5	871.45 ± 97.72	0.75 ± 0.12	14.27 ± 2.18	1.94	0.114

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

Grand Junction L Pads

Plan

Section

Table A-5. Assigned Parameters

Model Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
L1	86.3 ± 2.5 ^c	0.73 ± 0.15	15.0 ± 3.0	2.22	0.184 ^c
L2	224.7 ± 6.5 ^c	1.04 ± 0.35	18.2 ± 4.2	2.17	0.200 ^c
L3	455.8 ± 3.3 ^c	0.73 ± 0.33	15.5 ± 2.2	2.18	0.195 ^c

^aThese models were constructed from the same material as borehole models A1, A2, and A3 and are assumed to have the same parameters. Uncertainties are 95 percent confidence level. Assigned values taken from Koizumi (1979), except as noted.

^bUncertainties for these values have not been determined.

^cAssigned values taken from George and others (1983).

Grand Junction K, U, and T Models

Typical Section

Table A-6.1. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
K	Enriched	0.92 ± 0.09	0.28 ± 0.03	52.24 ± 1.67	1.86	0.269
U	Enriched	162.9 ± 5.34	0.73 ± 0.06	10.21 ± 0.84	1.89	0.274
T	Enriched	8.47 ± 0.47	53.03 ± 1.49	10.38 ± 1.17	1.88	0.275

^aUncertainties are 95 percent confidence level. Assigned values taken from Heistand and Novak (1984).

^bUncertainties for these values have not been determined.

Table A-6.2. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
U	Enriched	158 ± 6.0	4.98 ± 0.00	1.89	0.274

^aUncertainties are 95 percent confidence level. Assigned value taken from George and others (1983).

^bUncertainty reported as 0.00 is not zero, but is less than 0.01 ft.

^cUncertainties for these values have not been determined.

Grand Junction KW Model

Table A-7. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
KW	Enriched	120.55 ± 4.00	26.71 ± 0.79	38.43 ± 1.67	1.86	0.264

^aUncertainties are 95 percent confidence level. Assigned values taken from Heistand and Novak (1984).
^bUncertainties for these values have not been determined.

Grand Junction BL/BH, BT/BK, BU/BM, and BA/BB Models

D^*	
Model	Diameter (in.)
BL/BH	48
BT/BK	48
BU/BM	48
BA/BB	60

Table A-8.1. Assigned Parameters for Calibration of Total-Count Gamma-Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
BU	Upper	188 ± 6	4.01 ± 0.02	1.91	0.243
BL	Upper	334 ± 9	3.97 ± 0.00	2.23	0.188
BH	Lower	3136 ± 181	4.00 ± 0.02	2.22	0.196
BA	Upper	62.4 ± 1.8	3.99 ± 0.00	2.22	0.187
BB	Lower	913 ± 27	3.97 ± 0.00	2.21	0.188

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.01 ft.

^cUncertainties for these values have not been determined.

Table A-8.2. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
BT	Upper	10.46 ± 0.51	58.78 ± 1.53	10.13 ± 1.34	1.91	0.244
BK	Lower	1.03 ± 1.67	0.10 ± 0.02	54.00 ± 1.67	1.81	0.250
BU	Upper	194.59 ± 5.94	0.65 ± 0.06	10.63 ± 1.00	1.91	0.243
BM	Lower	131.16 ± 4.07	40.12 ± 1.09	42.86 ± 2.01	1.88	0.251

^aUncertainties are 95 percent confidence level. Assigned values taken from Heistand and Novak (1984).

^bUncertainties for these values have not been determined.

Table A-8.3. Assigned Parameters for Calibration of Fission-Neutron Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Partial Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
BA	Upper	62.4 ± 1.8	3.99 ± 0.00	2.22	0.187
BB	Lower	913 ± 27	3.97 ± 0.00	2.21	0.188

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.01 ft.

^cUncertainties for these values have not been determined.

Grand Junction N3, U1, U2, and U3 Models

**Section
N3 Model**

**Typical Section
U1, U2, and U3 Models**

Table A-9. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
N3	Enriched	654 ± 23	4.19 ± 0.00	1.83	0.281
U1	Enriched	7460 ± 465	4.06 ± 0.02	2.07	0.255
U2	Enriched	3478 ± 218	4.01 ± 0.00	1.70	0.295
U3	Enriched	1278 ± 51	4.01 ± 0.00	1.67	0.304

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Grand Junction WF Model

Table A-10. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
WF	Enriched	850 ± 30	4.02 ± 0.00	1.86	0.282

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Grand Junction N1 Model

Dimensions shown are for reference only; complete as-built dimensions are not available.

Grand Junction N2 Model

Dimensions shown are for reference only; complete as-built dimensions are not available.

Grand Junction N4 Model

Dimensions shown are for reference only; complete as-built dimensions are not available.

Grand Junction N5 Model

Dimensions shown are for reference only; complete as-built dimensions are not available.

Table A-11. Assigned Parameters^a

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^{b,c}	Uranium Concentration (U ppm) ^{b,c}	Thickness (in.) ^c
N1	Enriched	702	1,642	14.0
N2	Enriched	1,216	3,218	12.5
N3	Enriched	654	1,573	50.3
N4	Z1 Enriched	696	1,628	27.8
N4	Z2 Enriched	2,599	7,527	12.0
N5	Z1 Enriched	708	1,662	8.9 ^d
N5	Z2 Enriched	291	712	6.0 ^d
N5	Z3 Enriched	2,678	7,714	13.2
N5	Z4 Enriched	620	1,454	6.5
N5	Z5 Barren ^d	—	—	6.8
N5	Z6 Enriched ^d	4,852	13,830	5.6

^aValues for dry bulk density have not been determined.

^bAssigned values, except for N3 Ra-226 concentration and thickness taken from George and others (1983), are calculated using conversion factors in Appendix D and values taken from an internal report Matthews (1975). The values reported were determined by "gamma-only" and chemical analyses on samples taken from the model during its construction.

^cUncertainties of the values have not been determined.

^dData for four zones in N5 are based on analysis of logging data published by Bristow and others (1984), data which was subsequently substantiated by researchers at the GJPO.

Grand Junction Thin Dipping Bed Models

Model TDB-1

Model TDB-2

Table A-12.1. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (in.) ^b	Dry Bulk Density (g/cm ³)	Partial Density H ₂ O (g/cm ³) ^c
TDB	Enriched	710.6 ± 6.8	2.0	1.90 ± 0.05	—

^aUncertainties are 95 percent confidence level. Assigned values taken from Koizumi (1980). Value determined by NaI(Tl) based total gamma-ray method.

^bUncertainties for these values have not been determined.

^cValue has not been determined.

Table A-12.2. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³)	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
TDB	Enriched	694.7 ± 6.8	0.94 ± 0.54	17.64 ± 8.7	1.90 ± 0.05	—

^aUncertainties are 95 percent confidence level. Assigned values taken from Koizumi (1980). Values determined by Ge(Li) based spectral gamma-ray method.

^bValue has not been determined.

Grand Junction A Models

A5 and A6 Models

**A1, A2, A3,
and A4 Models**

Table A-13. Assigned Parameters for Calibration of Fission-Neutron Logging Systems^a

Model Designation	Zone	Zone Thickness (ft) ^b	Characteristic ^c	Concentration (pCi/g)			Dry Bulk Density (g/cm ³) ^d	Partial Density H ₂ O (g/cm ³) ^d	Grain Density (g/cm ³) ^d	Porosity (%) ^d	Magnetic Susceptibility (10 ⁻⁶ cgs) ^d
				Ra-226	Th-232	K-40					
A1	C	6.01 ± 0.00 ^e	—	86.3 ± 2.5 ^e	0.73 ± 0.15	15.0 ± 3.0	2.22	0.184 ^e	—	18 ^f	841
A2	C	5.94 ± 0.00 ^e	—	224.7 ± 6.5 ^e	1.04 ± 0.35	18.2 ± 4.2	2.17	0.200 ^e	—	18 ^f	804
A3	C	5.95 ± 0.00 ^e	—	455.8 ± 13.3 ^e	0.73 ± 0.33	15.5 ± 2.2	2.18	0.195 ^e	—	18 ^f	822
A4	C	6	—	600.5 ± 270.1	0.92 ± 0.37	17.8 ± 8.4	2.22	—	—	18 ^f	844
A5	T	4	High Σ	204.6 ± 20.8	1.16 ± 0.31	20.1 ± 8.4	2.17	—	2.64	17.8	741
A5	B	4	High ρ	208.6 ± 6.5	0.86 ± 0.22	19.6 ± 4.2	2.40	—	2.92	17.8	596
A6	T	4	High ø	206.6 ± 7.5	0.78 ± 0.13	13.9 ± 3.5	1.85	—	2.60	28.8	348
A6	C	4	Low ø	201.8 ± 60.0	0.98 ± 0.15	18.8 ± 3.7	2.21	—	2.64	16.3	1055

^aUncertainties are 95 percent confidence level. Assigned values taken from Koizumi (1979), except as noted.^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.^cΣ = macroscopic neutron cross section; ρ = density; ø = porosity.^dUncertainties for these values have not been determined.^eAssigned values taken from George and others (1983).^fEstimated.

Grand Junction D Model

Section A-A

Plan

Table A-14. Assigned Parameters for Calibration of Fission-Neutron Logging Systems^a

Model Designation	Zone	Zone Thickness (ft) ^b	Concentration (pCi/g)			Dry Bulk Density (g/cm ³)	Partial Density H ₂ O (g/cm ³) ^b	Grain Density (g/cm ³)	Porosity (%)	Magnetic Susceptibility (10 ⁻⁶ cgs)
			Ra-226 ^b	Th-232	K-40					
D	Enriched	5.80 ± 0.00 ^c	218 ± 7	0.84 ± 0.37	14.9 ± 4.4	2.12 ± 0.06	0.216	2.72 ± 0.14	22.1 ± 0.2	826 ± 94

^aUncertainties are 95 percent confidence level. Assigned values taken from Koizumi (1979), except as noted.

^bAssigned value taken from George and others (1983).

^cUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

Grand Junction SW Model

All run tubes are aluminum
with .060 in. wall thickness

Plan

Section

Table A-15. Assigned Parameters^a

Zone Designation	Zone Description	Porosity (vol %) ^b	Dry Bulk Density (g/cm ³) ^b	Wet Bulk Density (g/cm ³) ^b	Grain Density (g/cm ³) ^b	Moisture Fraction (wt %) ^b
W	Water	0	—	1.0	—	100
WS	Ottawa Sand	36.0	1.60	1.96	2.50	18.4

^aAssigned values taken from George (1986) and George (in preparation).

^bUncertainties for these values have not been determined.

Grand Junction SS/SB Model

Plan

Section

Table A-16. Assigned Parameters^a

Zone Designation	Zone Description	Porosity (vol %) ^b	Dry Bulk Density (g/cm ³) ^b	Wet Bulk Density (g/cm ³) ^b	Grain Density (g/cm ³) ^b	Moisture Fraction (wt %) ^{b, c}
SS	Scioto Sandstone	18.3	2.20	2.38	2.69	7.7
SB	Bluestone Sandstone	5.1	2.60	2.65	2.74	1.9

^aAssigned values taken from George (1986) and George (in preparation).

^bUncertainties for these values have not been determined.

^c100 percent saturation is assumed.

Grand Junction Granite Block Model

Borehole in the granite block is uncased.

Table A-17. Assigned Parameters

Model Designation	Magnetic Susceptibility (μCGS) ^a	Dry Bulk Density (g/cm^3) ^b	Partial Density H_2O (g/cm^3) ^c
Granite Block	385 ± 30	2.63	—

^aUncertainties are 95 percent confidence level. Assigned values taken from Emilia and others (1981).

^bUncertainties for these values have not been determined.

^cValue has not been determined.

Grand Junction 300-Foot Test Hole

Drawing not to scale.

Appendix B

Secondary Field Calibration Facilities

Secondary Field Calibration Facilities

This appendix presents detailed information concerning location, layout, pad and model descriptions, and radioelement concentrations for the secondary field calibration facilities. These facilities are administered by the U.S. Department of Energy Grand Junction Projects Office.

Questions concerning the use of the facilities should be addressed to the Technical Measurements Center.

Map to Casper Calibration Site

Map not to scale.

Layout of Casper Calibration Site

Map not to scale.

Casper P Pads

Table B-1. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
CPK	0.76 ± 0.90	0.04 ± 0.06	51.36 ± 1.46	1.94	0.130
CPL	91.77 ± 15.20	0.54 ± 0.10	15.44 ± 1.02	1.89	0.148
CPH	360.65 ± 43.82	0.55 ± 0.10	14.99 ± 1.58	1.91	0.153
CPT	6.07 ± 2.92	30.18 ± 0.78	14.13 ± 1.02	1.89	0.157
CPB ^c	0.0 ± 0.3	0.0 ± 0.3	0.0 ± 0.1	d	d

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

^cPad does not have a hole as shown above.

^dValue not assigned.

Casper E Pads

Plan

Section

Table B-2. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
CE2	81.45 ± 14.42	0.79 ± 0.12	13.63 ± 0.98	1.85	0.135
CE4	409.93 ± 50.90	0.66 ± 0.10	12.29 ± 1.58	1.84	0.162

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

Casper CBT/CBK, CBU/CBM, and CBA/CBB Models

D^*	
Model	Diameter (in.)
CBT/CBK	48
CBU/CBM	48
CBA/CBB	60

Table B-3.1. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
CBU	Upper	169 ± 6	3.99 ± 0.02	1.91	0.244
CBA	Upper	64.8 ± 1.9	4.00 ± 0.00	2.23	0.189
CBB	Lower	862 ± 26	4.02 ± 0.02	2.21	0.201

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Table B-3.2. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
CBT	Upper	11.43 ± 0.56	68.46 ± 1.81	10.55 ± 2.01	1.91	0.238
CBK	Lower	1.16 ± 0.10	0.11 ± 0.02	51.21 ± 1.67	1.81	0.255
CBU	Upper	175.94 ± 5.61	0.69 ± 0.06	11.55 ± 0.84	1.91	0.239
CBM	Lower	128.13 ± 4.07	47.73 ± 1.29	41.27 ± 1.84	1.88	0.252

^aUncertainties are 95 percent confidence level. Assigned values taken from Heistand and Novak (1984).

^bUncertainties for these values have not been determined.

Table B-3.3. Assigned Parameters for Calibration of Fission-Neutron Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
CBA	Upper	64.8 ± 1.9	4.00 ± 0.00	2.23	0.189
CBB	Lower	862 ± 26	4.02 ± 0.02	2.21	0.201

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Casper CH and CL Models

Typical Section
Each Model

Table B-4. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
CH	Enriched	6635 ± 388	2.89 ± 0.00	2.21	0.235
CL	Enriched	852 ± 26	2.97 ± 0.00	2.27	0.217

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Map to Grants Calibration Site

Layout of Grants Calibration Site

Grants P Pads

Plan

Section

Table B-5. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
GPK	0.58 ± 0.82	0.01 ± 0.06	51.53 ± 1.46	1.96	0.127
GPL	87.78 ± 14.32	0.50 ± 0.10	15.58 ± 1.02	1.90	0.165
GPH	375.74 ± 45.14	0.61 ± 0.10	15.93 ± 1.62	1.91	0.142
GPT	6.57 ± 3.14	30.23 ± 0.80	14.94 ± 1.02	1.89	0.146
GPB ^c	0.0 ± 0.3	0.0 ± 0.3	0.0 ± 0.1	d	d

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

^cPad does not have a hole as shown above.

^dValue not assigned.

Grants E Pads

Plan

Section

Table B-6. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
GE2	83.13 ± 15.42	0.70 ± 0.10	12.93 ± 1.02	1.85	0.237
GE4	396.66 ± 49.70	0.80 ± 0.12	12.20 ± 1.48	1.84	0.148

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

Grants GBT/GBK, GBU/GBM, and GBA/GBB Models

D^*	
Model	Diameter (in.)
GBT/GBK	48
GBU/GBM	48
GBA/GBB	60

Table B-7.1. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
GBU	Upper	167 ± 5	3.98 ± 0.00	1.88	0.247
GBA	Upper	64.8 ± 1.9	3.97 ± 0.02	2.21	0.189
GBB	Lower	881 ± 27	3.99 ± 0.00	2.22	0.199

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.01 ft.

^cUncertainties for these values have not been determined.

Table B-7.2. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
GBT	Upper	11.34 ± 0.58	68.06 ± 1.83	9.71 ± 1.51	1.93	0.248
GBK	Lower	1.08 ± 0.10	0.10 ± 0.02	52.16 ± 1.84	1.81	0.263
GBU	Upper	178.18 ± 5.47	0.71 ± 0.06	11.80 ± 0.84	1.88	0.244
GBM	Lower	129.09 ± 4.14	48.22 ± 1.35	41.84 ± 2.01	1.87	0.257

^aUncertainties are 95 percent confidence level. Assigned values taken from Heistand and Novak (1984).

^bUncertainties for these values have not been determined.

Table B-7.3. Assigned Parameters for Calibration of Fission-Neutron Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
GBA	Upper	64.8 ± 1.9	3.97 ± 0.02	2.21	0.189
GBB	Lower	881 ± 27	3.99 ± 0.00	2.22	0.199

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.01 ft.

^cUncertainties for these values have not been determined.

Grants GH and GL Models

Typical Section
Each Model

Table B-8. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
GH	Enriched	5645 ± 344	2.89 ± 0.02	2.22	0.247
GL	Enriched	777 ± 24	2.99 ± 0.00	2.22	0.236

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Map to George West Calibration Site

Vicinity Map

No Scale

Layout of George West Calibration Site

George West P Pads

Plan

Section

Table B-9. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
TPK	0.69 ± 0.86	0.00 ± 0.06	52.81 ± 1.46	1.95	0.131
TPL	87.02 ± 14.68	0.57 ± 0.10	15.49 ± 1.02	1.88	0.157
TPH	385.36 ± 47.52	0.45 ± 0.10	14.85 ± 1.42	1.90	0.158
TPT	5.96 ± 2.96	31.21 ± 0.82	15.03 ± 1.08	1.90	0.155
TPB ^c	0.0 ± 0.3	0.0 ± 0.3	0.0 ± 0.1	d	d

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

^cPad does not have a hole as shown above.

^dValue not assigned.

George West E Pads

Plan

Section

Table B-10. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
TE2	83.53 ± 15.10	0.66 ± 0.10	13.17 ± 0.98	1.83	0.177
TE4	398.74 ± 50.36	0.51 ± 0.10	11.44 ± 1.58	1.86	0.223

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

George West TBT/TBK, TBU/TBM, and TBA/TBB Models

D^*	
Model	Diameter (in.)
TBT/TBK	48
TBU/TBM	48
TBA/TBB	60

Table B-11.1. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
TBU	Upper	168 ± 6	3.98 ± 0.00	1.87	0.247
TBA	Upper	61.8 ± 1.7	3.95 ± 0.02	2.20	0.184
TBB	Lower	840 ± 25	3.96 ± 0.00	2.21	0.187

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.01 ft.

^cUncertainties for these values have not been determined.

Table B-11.2. Assigned Parameters for Calibration of Spectral Gamma-Ray Logging Systems

Model Designation	Zone	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
		Ra-226	Th-232	K-40		
TBT	Upper	11.30 ± 0.55	67.66 ± 1.88	9.71 ± 1.67	1.94	0.243
TBK	Lower	1.13 ± 0.10	0.09 ± 0.02	53.58 ± 1.84	1.81	0.264
TBU	Upper	177.01 ± 5.54	0.69 ± 0.06	11.39 ± 1.00	1.87	0.247
TBM	Lower	128.63 ± 4.14	48.62 ± 1.40	42.03 ± 2.01	1.85	0.257

^aUncertainties are 95 percent confidence level. Assigned values taken from Heistand and Novak (1984).

^bUncertainties for these values have not been determined.

Table B-11.3. Assigned Parameters for Calibration of Fission-Neutron Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
TBA	Upper	61.8 ± 1.7	3.95 ± 0.02	2.20	0.184
TBB	Lower	840 ± 25	3.96 ± 0.00	2.21	0.187

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.01 ft.

^cUncertainties for these values have not been determined.

George West TH and TL Models

Typical Section

Table B-12. Assigned Parameters for Calibration of Total-Count Gamma-Ray Logging Systems

Model Designation	Zone	Ra-226 Concentration (pCi/g) ^a	Thickness (ft) ^b	Dry Bulk Density (g/cm ³) ^c	Partial Density H ₂ O (g/cm ³) ^c
TH	Enriched	5770 ± 368	3.94 ± 0.00	1.86	0.302
TL	Enriched	680 ± 23	3.99 ± 0.00	2.07	0.272

^aUncertainties are 95 percent confidence level. Assigned values taken from George and others (1983).

^bUncertainties reported as 0.00 are not zero, but are less than 0.005 ft.

^cUncertainties for these values have not been determined.

Appendix C

Relocatable Field Calibration Pads

Relocatable Field Calibration Pads

This appendix presents detailed information concerning pad descriptions and radioelement concentrations for the relocatable field calibration pads. These pads are administered by the U.S. Department of Energy Grand Junction Projects Office.

Questions concerning present location, use, and/or calibration should be addressed to the Technical Measurements Center.

NP Pads

Plan

Section

Table C-1. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
NPL	15.83 ± 5.32	0.64 ± 0.10	10.92 ± 0.72	1.94	0.176
NPH	44.20 ± 9.72	0.73 ± 0.10	11.13 ± 0.82	1.95	0.191

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

NOTE: Contact the Technical Measurements Center for the present location of these pads.

PP Pads

Plan

Section

Table C-2. Assigned Parameters

Pad Designation	Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³) ^b	Partial Density H ₂ O (g/cm ³) ^b
	Ra-226	Th-232	K-40		
PPL	15.08 ± 5.54	0.62 ± 0.10	10.84 ± 0.66	1.95	0.176
PPH	49.34 ± 10.78	0.63 ± 0.10	10.97 ± 0.86	1.95	0.199

^aUncertainties are 95 percent confidence level. Assigned values taken from George, Novak, and Price (1985).

^bUncertainties for these values have not been determined.

NOTE: Contact the Technical Measurements Center for the present location of these pads.

T Pads

Plan

Section

Table C-3. Assigned Parameters

Pad	Diameter (in.)	Assigned Concentration (pCi/g) ^a			Dry Bulk Density (g/cm ³)	Partial Density H ₂ O (g/cm ³)
		Ra-226	Th-232	K-40		
TL1	56	<1	10.18 ± 0.43	2.07 ± 0.16	1.89	0.209
TL2	56	<1	10.56 ± 0.45	2.80 ± 0.16	1.92	0.225
TL3	57	<1	10.28 ± 0.43	2.28 ± 0.16	1.84	0.206
TL4	60	<1	11.36 ± 0.45	2.18 ± 0.16	1.85	0.191
TH1	56	<1	41.48 ± 1.30	<3	1.89	0.206
TH2	56	<1	42.00 ± 1.27	<3	1.94	0.192
TH3	60	<1	42.48 ± 1.33	<3	1.88	0.200
TH4	60	<1	45.31 ± 1.27	<3	1.90	0.168

^aUncertainties are two sigma (95 percent confidence interval).

Appendix D

Conversion Factors

Conversion Factors

This appendix presents conversion factors used to determine radioelement concentrations for the calibration facilities. An example of conversion-factor derivation is presented in Appendix E. The nuclear data referenced in this appendix are taken from the *Table of Isotopes* (Lederer and Shirley, 1978). Half-life (T), isotopic-abundance (P), and gram atomic weight (A) data agree (within quoted significant figures) with those listed in the *Chart of the Nuclides* (Walker and others, 1977).

Conversion factors for a sample containing uranium in secular equilibrium with its daughters are

$$\begin{aligned}1 \text{ g (eU-238)} &= 3.400 \times 10^{-7} \text{ g (Ra-226)} \\1 \text{ g (eU)} &= 3.376 \times 10^{-7} \text{ g (Ra-226)} \\1 \text{ wt-ppm (eU)} &= 0.3337 \text{ pCi (Ra-226)/g} \\1 \text{ pCi (Ra-226)/g} &= 3.534 \times 10^{-4} \text{ wt-}\%(\text{eU}_3\text{O}_8) \\1 \text{ pCi (Ra-226)/g} &= 2.997 \text{ wt-ppm (eU)} \\1 \text{ wt-}\% (\text{eU}_3\text{O}_8) &= 2830 \text{ pCi (Ra-226)/g}\end{aligned}$$

The conversion factor for radium is

$$\begin{aligned}n_{\text{Ra-226}} &= \text{specific activity of Ra-226} \\&= N_o \lambda_{\text{Ra-226}} / A_{\text{Ra-226}} \\&= 0.9885 \text{ Ci/g}\end{aligned}$$

Conversion factors computed for a sample containing thorium are

$$\begin{aligned}1 \text{ pCi (Th-232)/g} &= 9.159 \text{ wt-ppm (eTh)} \\1 \text{ wt-ppm (eTh)} &= 0.1092 \text{ pCi (Th-232)/g}\end{aligned}$$

Conversion factors computed for a sample containing naturally occurring potassium are

$$\begin{aligned}0.0117 \text{ atom-}\% (\text{K-40}) &= 0.01196 \text{ wt-}\% (\text{K-40}) \\1 \text{ pCi (K-40)/g} &= 0.1195 \text{ wt-}\% (\text{K}) \\1 \text{ wt-}\% (\text{K}) &= 8.372 \text{ pCi (K-40)/g} \\1 \text{ pCi (K-40)/g} &= 1.428 \times 10^{-5} \text{ wt-}\% (\text{K-40})\end{aligned}$$

Numerical values used for computing the conversion factors are

$$\begin{aligned}A_{\text{U-238}} &= 238.9597 \text{ g/mole} \\A_{\text{U-235}} &= 235.0439 \text{ g/mole} \\A_{\text{U-234}} &= 234.0409 \text{ g/mole} \\A_{\text{Ra-226}} &= 226.0254 \text{ g/mole} \\A_{\text{Th-232}} &= 232.0380 \text{ g/mole} \\A_{\text{K-41}} &= 40.9618 \text{ g/mole} \\A_{\text{K-40}} &= 39.9640 \text{ g/mole} \\A_{\text{K-39}} &= 38.9637 \text{ g/mole} \\P_{\text{U-238}} &= 99.275\% \\P_{\text{U-235}} &= 0.720\% \\P_{\text{U-234}} &= 0.0054\%\end{aligned}$$

$$P_{\text{Th-232}} = 100\%$$

$$P_{\text{K-41}} = 6.73\%$$

$$P_{\text{K-40}} = 0.0117\%$$

$$P_{\text{K-39}} = 93.26\%$$

$$T_{\text{U-238}} = 4.468 \times 10^9 \text{ years} = 1.410 \times 10^{17} \text{ sec}$$

$$T_{\text{Ra-226}} = 1600 \text{ years} = 5.049 \times 10^{10} \text{ sec}$$

$$T_{\text{Th-232}} = 1.411 \times 10^{10} \text{ years} = 4.453 \times 10^{17} \text{ sec}$$

$$T_{\text{K-40}} = 1.278 \times 10^9 \text{ years} = 4.033 \times 10^{16} \text{ sec}$$

$$N_0 = 6.022045 \times 10^{23} \text{ atoms/mole}$$

$$1 \text{ Ci} = 3.7 \times 10^{10} \text{ disintegrations/sec}$$

Appendix E

Example Conversion Factor Derivation

Example Conversion Factor Derivation

The calibration of gamma-ray counting instruments at Grand Junction has been traditionally performed using equivalent uranium (eU) as the reporting unit for spectral instruments and equivalent uranium oxide (eU₃O₈) as the reporting unit for gross-count or total-count instruments. The word equivalent (e) has been traditionally taken to mean radiometric equivalent or gamma-ray equivalent, because concentrations assigned to the calibration models are based on gamma-ray measurements. The purpose of this derivation is to establish the factors needed to convert from currently assigned uranium concentrations in parts per million on a weight basis for eU [wt-ppm(eU)] and in weight-percentage for eU₃O₈ [wt-% (eU₃O₈)] to radium concentrations [pCi (Ra-226)/g].

For the conversion derived, it is necessary to assume secular equilibrium between uranium and radium-226 in the uranium decay series. This assumption has always been made in the past when assigning equivalent-uranium concentrations to the models and pads. Because previous assignments are based on gamma-ray counting measurements, and because those measurements are responsive primarily to radium-226 daughters, the assumption is appropriate here.

For a given sample of mass M, containing uranium and its daughters in secular equilibrium, the decay rates of U-238 and Ra-226 are equal by definition. That is,

$$\text{Decay rate } (-dN/dt) = N_{\text{Ra-226}}\lambda_{\text{Ra-226}} = N_{\text{U-238}}\lambda_{\text{U-238}} \quad (1)$$

where N = number of atoms of the isotope indicated by the subscript,

λ = decay constant of the isotope indicated by the subscript,

= $\ln(2)/T$,

T = half-life of the isotope indicated by the subscript.

If both sides of Equation (1) are divided by the mass of the sample, M, and if mass-normalized decay rate is r,

$$r_{\text{Ra-226}} = r_{\text{U-238}} = \frac{N_{\text{Ra-226}}\lambda_{\text{Ra-226}}}{M} = \frac{N_{\text{U-238}}\lambda_{\text{U-238}}}{M} \quad (2)$$

Computing the number of atoms of U-238 from the mass of U-238 in the sample, $M_{\text{U-238}}$,

$$r_{\text{Ra-226}} = N_{\text{U-238}}\lambda_{\text{U-238}}/M = (M_{\text{U-238}}/M)(N_0/A_{\text{U-238}})\lambda_{\text{U-238}} \quad (3)$$

where N_0 = Avogadro's number, and

A = gram atomic weight of the isotope indicated by the subscript.

Noting that $M_{\text{U-238}}/M$ is the weight fraction of U-238 in the sample,

$$c_{\text{U-238}} = M_{\text{U-238}}/M \quad (4)$$

Equation (3) produces the result

$$r_{\text{Ra-226}} = c_{\text{U-238}}(N_0\lambda_{\text{U-238}}/A_{\text{U-238}}) \quad (5)$$

The desired units are picocuries of Ra-226 per gram of sample [pCi(Ra-226)/g], and parts per million on a weight basis for U-238 (wt-ppm). Performing the computation indicated in Equation (5) and converting units produces

$$r_{\text{Ra-226}} = c_{\text{U-238}}/2.975 \quad (6)$$

where $r_{\text{Ra-226}}$ is the mass-normalized decay rate of Ra-226 in picocuries per gram and $c_{\text{U-238}}$ is the weight concentration of U-238 in parts per million.

Numerical values and conversion factors used for the computations are presented in Appendix B.

The result in Equation (6) must be adjusted to account for the isotopic abundance of U-238 within naturally occurring uranium (U). The isotopic abundance of U-238 must first be computed on a weight basis because the isotopic abundance values in the *Table of Isotopes* (Lederer and Shirley, 1978) are given on an atom-percent basis.

$$P'_{U-238} = \frac{P_{U-238}A_{U-238}}{P_{U-238}A_{U-238} + P_{U-235}A_{U-235} + P_{U-234}A_{U-234}} \quad (7)$$

$$= 0.9928 \frac{g(U-238)}{g(U)}$$

where P' is the isotopic abundance on a weight basis for the isotope indicated by the subscript, and P is the isotopic abundance on an atom-percent basis for the isotope indicated by the subscript.

From this result, $c_{U-238} = 0.9928c_U$, which is then substituted into Equation (6) to produce the final and desired result

$$r_{Ra-226} = c_U/2.997 \quad (8)$$

where c_U is the weight concentration of naturally occurring uranium in parts per million (ppm) and r_{Ra-226} is the mass-normalized decay rate of Ra-226 in picocuries per gram.

Publications Issued by the
Technical Measurements Center

June 1994

Operated by
RUST Geotech Inc.

for
U.S. Department of Energy
Office of Environmental Management
Albuquerque Operations Office
Grand Junction Projects Office

Number	Title (Authors)
GJ/TMC-01* 3rd Edition	<i>Field Calibration Facilities for Environmental Measurement of Radium, Thorium, and Potassium.</i> (R. Leino, D. C. George, B. N. Key, L. Knight, and W. D. Steele)
GJ/TMC-02	<i>Review of Selected DOE Remedial Action Field Measurement Procedures for the Summer of 1982.</i> (TMC Staff)
GJ/TMC-03*	<i>Abbreviated Total-Count Logging Procedures for Use in Remedial Action.</i> (D. C. George and R. K. Price)
GJ/TMC-04*	<i>Evaluation of Methods for the Estimation of Indoor Radon Daughter Concentrations for Remedial Action Programs.</i> (G. H. Langner, Jr., J. C. Pacer, V. G. Johnson, and M. A. Gillings)
GJ/TMC-05*	<i>Feasibility Study of the Prompt Pb-214, Bi-214 Gamma Method for Determining Radon Migration Through Tailings.</i> (L. R. Stieff, The Stieff Research and Development Co., Inc., Kensington, Maryland)
GJ/TMC-06*	<i>Surface Gamma-Ray Measurement Protocol.</i> (S. J. Marutzky, W. D. Steele, and B. N. Key)
GJ/TMC-07*	<i>Procedures for Field Chemical Analyses of Water Samples.</i> (N. Korte and D. Ealey)
GJ/TMC-08* 2nd Edition	<i>Procedures for the Collection and Preservation of Groundwater and Surface Water Samples and for the Installation of Monitoring Wells.</i> (N. Korte and P. Kearn)
GJ/TMC-09* 2nd Edition	<i>Protocol for the Estimation of Average Indoor Radon-Daughter Concentrations.</i> (G. H. Langner, Jr. and J. C. Pacer)
GJ/TMC-10*	<i>Development of Solid Radium-226 Reference Materials.</i> (R. B. Chessmore and P. R. Engelder)
Letter Report (unnumbered)	<i>Supplemental Measurements for Polonium-210 and Lead-210 in TMC Radium Reference Material (insert to GJ/TMC-10).</i> (S. Donivan)
GJ/TMC-11*	<i>Procedure Manual for the Estimation of Average Indoor Radon-Daughter Concentrations Using the Radon Grab-Sampling Method.</i> (J. L. George)
GJ/TMC-12*	<i>Procedure Manual for the Estimation of Average Indoor Radon-Daughter Concentrations Using the Radon Progeny Integrating Sampling Unit (RPISU) Method.</i> (G. H. Langner, Jr.)
GJ/TMC-13*	<i>Procedures for Sampling Radium-Contaminated Soils.</i> (H. L. Fleischhauer)

*Available from National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161, (703) 487-4600.

Number	Title (Authors)
GJ/TMC-14*	<i>Procedures for Reconnaissance Stream-Sediment Sampling.</i> (H. L. Fleischhauer and P. R. Engelder)
GJ/TMC-15*	<i>A Feasibility Study of the Use of Nuclear-Emulsion Techniques in the Study of Drill Core and Water Samples from the Monticello Mill, Monticello, Utah.</i> (L. R. Stieff, The Stieff Research and Development Co., Inc., Kensington, Maryland)
GJ/TMC-16*	<i>Test and Evaluation of Selected Instruments for Surface Gamma-Ray Measurements.</i> (B. N. Key)
GJ/TMC-17*	<i>Calibration-Pad Parameter Assignments for In-Situ Gamma-Ray Measurements of Radium, Thorium, and Potassium.</i> (D. C. George, E. F. Novak, and R. K. Price)
GJ/TMC-18*	<i>Operating Manual for the Radon-Daughter Chamber.</i> (G. H. Langner, Jr., and T. Nelson)
GJ/TMC-19*	<i>Laboratory Intercomparison of Analytical Results on Samples Contaminated by Uranium Mill Tailings.</i> (N. Korte, M. Hollenbach, and S. Donovan)
GJ/TMC-20	<i>Radon-Daughter Chamber Instrumentation System Reference Manual.</i> (L. Johnson and R. Showalter)
GJ/TMC-22*	<i>Development of Solid Thorium-232 Reference Materials.</i> (P. R. Engelder, S. Donovan, and R. B. Chessmore)
Letter Report (unnumbered)	<i>Supplemental Measurements for Radium-226 and Potassium-40 in TMC Thorium Reference Material (insert to GJ/TMC-22).</i> (S. Donovan)
GJ/TMC-23	<i>Gamma-Ray Instrument Calibration Comparison Workshop.</i> (W. D. Steele, D. C. George, and J. L. Burnham)
GJ/TMC-24*	<i>Comparison of In-Situ and Laboratory Measurement Methods for Radium-226 in Soils.</i> (S. J. Marutsky, H. L. Fleischhauer, and P. R. Engelder)
GJ/TMC-25*	<i>Interlaboratory Radon-Daughter Measurement Comparison Workshop: 9-12 September 1985.</i> (M. Pearson)
GJ/TMC-26*	<i>Field Study of Indoor Average Radon-Daughter Estimation Methods.</i> (J. L. George and G. H. Langner, Jr.)
GJ/TMC-27*	<i>Assessment of Mobile Gamma-Scanning Van Activities in Edgemont, South Dakota.</i> (U.S. Department of Energy Task Force)

*Available from National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161, (703) 487-4600.

Number	Title (Authors)
GJ/TMC-28*	<i>Interim Results of the Prompt Alpha-Track Radon Detector Study.</i> (J. L. George and G. H. Langner, Jr.)
UNC/GJ-29(TMC)*	<i>Comparison of Radon and Radon-Daughter Grab Samples Obtained During the Winter and Summer.</i> (K. E. Karp)
UNC/GJ-31(TMC)*	<i>Investigation of the Hammer-Gamma Measurement Technique: A Feasibility Study.</i> (R. Showalter)
UNC/GJ-32(TMC)*	<i>Construction and Characterization of the TL/TH Thorium Calibration Pads.</i> (W. Douglass Steele)
UNC/GJ-33(TMC)*	<i>Validation of the Prompt Alpha-Track Method.</i> (J. L. George and G. H. Langner, Jr.)
UNC/GJ-34(TMC)*	<i>Validation of the Abbreviated Radon Progeny Integrating Sampling Unit (RPISU) Method for Mesa County, Colorado.</i> (G. H. Langner, Jr.)
UNC/GJ-35(TMC)*	<i>Construction and Testing of a Blower-Door Assembly for Regulation of Air Pressure Within Structures.</i> (W. Douglass Steele)
UNC/GJ-36 (TMC)*	<i>Uranium Reference Materials.</i> (S. Donivan and R. B. Chessmore)
UNC/GJ-TMC-1	<i>Determination of Radon Sources at Four Vicinity Properties in Edgemont, South Dakota.</i> (K. E. Karp)
UNC/GJ-TMC-2	<i>Radon-Daughter Grab-Sampling Technical Exchange Meeting 14-17 April 1986.</i> (M. D. Pearson)
UNC/GJ-37(TMC)*	<i>Soil-Based Uranium Disequilibrium and Mixed Uranium-Thorium Series Radionuclide Reference Materials.</i> (S. Donivan and R. B. Chessmore)
UNC/GJ-38 (TMC)*	<i>The Use of Atomic Absorption Spectroscopy to Measure Arsenic, Selenium, Molybdenum, and Vanadium in Water and Soil Samples From Uranium Mill Tailings Sites.</i> (M. H. Hollenbach)
UNC/GJ-39(TMC)*	<i>Procedure Manual for the Estimation of Average Indoor Radon-Daughter Concentrations Using the Electronic Radon Progeny Integrating Sampling Unit (ERPISU) Method.</i> (M. D. Pearson)
UNC/GJ-40(TMC)*	<i>Procedure Manual for the Estimation of Average Indoor Radon-Daughter Concentrations Using the Filtered Alpha-Track Method.</i> (J. L. George)
UNC/GJ-41(TMC)*	<i>Detecting Buried Radium Contamination Using Soil-Gas and Surface-Flux Radon Measurements.</i> (K. E. Karp)
UNC/GJ-42(TMC)*	<i>Exposure-Rate Calibration Using Large-Area Calibration Pads.</i> (E.F. Novak)

*Available from National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161, (703) 487-4600.

Number	Title (Authors)
UNC/GJ—43(TMC)*	<i>Year-Long Comparison of Two Techniques to Monitor Outdoor Radon Concentrations at Shiprock, New Mexico.</i> (E. F. Novak)
UNC/GJ-TMC-3*	<i>Procedures, Analysis, and Comparison of Groundwater Velocity Measurement Methods for Unconfined Aquifers.</i> (P. M. Kearl, J. J. Dexter, and J. E. Price)
UNC/GJ-TMC-4*	<i>Supplement to Procedures, Analysis, and Comparison of Groundwater Velocity Measurement Methods for Unconfined Aquifers.</i> (R. J. Zinkl and P. M. Kearl)
UNC/GJ—44(TMC)*	<i>Evaluation of the Performance Characteristics of Radon and Radon-Daughter Concentration Measurement Devices Under Controlled Environmental Conditions.</i> (M. D. Pearson)
UNC/GJ—45(TMC)*	<i>Construction and Characterization of the RH/RL Radium Calibration Pads.</i> (W. D. Steele, S. J. Marutzky, and J. W. Dickerson)
UNC/GJ—46(TMC)*	<i>Performance of Diffusion-Barrier Scintillation Cells Under a Variety of Controlled Environmental Conditions.</i> (R. R. Spangler and G. H. Langner, Jr.)
UNC/GJ—47(TMC)*	<i>Validation of the Diffusion-Barrier Charcoal Canister Method.</i> (D. E. Martz, J. L. George, S. T. Mamich, and G. H. Langner, Jr.)
UNC/GJ—48(TMC)*	<i>Field Method for Determining Thorium-230 in Soils.</i> (G. Dechant)
UNC/GJ-TMC-5*	<i>Development of Electret Technology to Measure Indoor Radon-Daughter Concentrations</i> (Stieff Research and Development Co., Inc., Kensington, Maryland)
UNC/GJ-TMC-6*	<i>Radon-Daughter Grab-Sampling Technical Exchange Meeting April 10-14, 1989.</i> (M. D. Pearson)
UNC/GJ-49(TMC)*	<i>Gamma and Beta Logging of Underground Sewer and Process Lines.</i> (M. J. Rangel, D. E. Martz, and G. H. Langner, Jr.)
UNC/GJ-50(TMC)*	<i>Variation in the Annual Average Radon Concentration Measured in Homes in Mesa County, Colorado.</i> (A. S. Rood, J. C. George, and G. H. Langner, Jr.)
UNC/GJ-51(TMC)*	<i>Calibration of the Alpha-Track Monitors for Measurement of Thoron.</i> (M. D. Pearson)
GJPO-53(TMC)*	<i>Evaluation of Thoron-Daughter Instruments.</i> (J. L. George)

*Available from National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161, (703) 487-4600.