AIM

Association for Information and Image Management

1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910
301/587-8202

Centimeter

Inches

MANUFACTURED TO AIM STANDARDS
BY APPLIED IMAGE, INC.

1 of 1

2
WSRC-OS-93-010

RECEIVED
JUL 25 1993
0011

**ATTACHMENT 4 RLCA CALCULATION NO. P191-1/7 REVIEW
OF 105K REACTOR TANK LOWER SUPPORTS (U)**

by

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

Robert L. Cloud Associates, Inc.

This report was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U.S. Department of Energy. By acceptance of this report, the publisher and/or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this report, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted report.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED 878

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

Attachment 4

RLCA Calculation No. P191-1/7
Review of 105K Reactor Tank Lower Supports
Revision 0

DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION

Reviewing
Officer: Carl W. West
Mr. [Signature]
Date: 8/27/91

RLCA

FINAL
ENGINEERING DOCUMENTATION PACKAGE

PROJECT NUMBER:

P191-1

RECORD NUMBER:

P191-1/7

DESCRIPTION:

REVIEW OF 105K REACTOR TANK
LOWER SUPPORTS

KEYWORDS:

REACTOR TANK, SUPPORTS

COMPUTER PROGRAMS USED, IF ANY:

NONE

REV. NUMBER	CHANGES (INCLUDE REVISION LOG IF NECESSARY)	TOTAL PAGES	ORIGINATING ENGINEER	DATE	CHECKER & DATE	TECH. REVIEW & DATE	PROJ. MGR. & DATE
ORIGINAL ISSUE	25 plus cover	H. Loew	5/23/90	G.P. Gee 5-23-90	5-23-90	5/23/90

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loey DATE 2/18/90
CHKD. BY G. P. Gee DATE 4/2/90

SAVANNAH RIVER SITE
Calc. No. P191-1/7

PAGE NO. 1 OF 25
PROJ. NO. P191-1

Table of Contents

	<u>Page No.</u>
1.0 Introduction	2
2.0 Methodology	5
3.0 Analysis	6
4.0 Summary and Conclusions	23
5.0 References	24

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. L. L. L. DATE 2/18/90
CHKD. BY G. P. G. DATE 4/2/90

SAVANNAH RIVER SITE
CALC. NO. PKI-1/7

PAGE NO. 2 OF 25
PROJ. NO. PI91-1

1.0 INTRODUCTION

Confirmatory analyses were performed to examine the adequacy of the 105-K Reactor Tank Bottom Supports. The supports were reviewed for updated loads from a separate confirmatory calculation for the reactor tank and bottom tubesheet.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. L. Lee DATE 2/18/90
CHKD. BY G. P. Lee DATE 4/2/90

SAVANNAH RIVER SITE
CALC. NO. P191-1/7

PAGE NO. 3 OF 25
PROJ. NO. P191-1

1.1 Support Pad Configuration

Based on Drawing W133481 (Reference 1), the Main Tank supports consist of 12 bearing plate assemblies evenly spaced (30° apart) around the circumference of the bottom tubesheet.

Each of the supports has individually fitted keys that allow 0.008 inches (at initial installation) of lateral clearance from either side of the bottom tubesheet support foot pad to the key. The key bears against the cutout on the upper bearing plate to transfer lateral load upon closure of the 0.008 in gap. The bearing contact is supplemented by a position retaining dowel pin.

The top bearing plate in turn transfers all loading to the bottom bearing plate by means of two 1 1/4" ϕ taper pins (supplemented by two capscrews).

Finally, the bottom plate is secured by two 1 inch ϕ vertical anchor bolts. (Reference Dwg. W133583 and W133584, Ref. 1). Four additional 1" ϕ anchor bolts tie into the bearing plate perpendicular to the line of action of the keys. These horizontal bolts are oriented

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Wey DATE 2/22/90
CHKD. BY GP DATE 4/2/90

SAVANNAH RIVER SITE
Calc. No. P191-1/7

PAGE NO. 4 OF 25
PROJ. NO. P191-1

primarily in the tank radial direction.

The configuration of the keys on the supports is such that the clearance is taken up first by the two supports 90° to the direction of motion (loading). This behavior is due to the effect of the angled supports and the resultant clearance when the support is not oriented 90° to the direction of motion.

To bring the 30° location supports into effect the total lateral motion required is:

$$.008 / \cos 30^\circ = 0.0092 \text{ in}$$

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loey DATE 2/18/90
CHKD. BY G. P. Gae DATE 4/2/90

SAVANNAH RIVER SITE
CALC. NO. P191-1/7

PAGE NO. 5 OF 25
PROJ. NO. P191-1

2.0 METHODOLOGY

Bottom tubesheet support loads have been determined in a previous RLCA calculation package (Reference 3). These loads were resolved into loads on each of the 12 bearing pad supports.

The individual pad load was used to determine the adequacy of the key support components as identified within the analysis.

The design condition calls for a clearance of 0.009 in. between the bottom tubesheet support pad and the key, with the key machined to fit after the bottom tubesheet was set in place on top of the support.

The gaps and load redistribution of load at gap closure will be considered in the analysis.

2.1 Criteria

Applicable criteria are the ASME Code, Ref. 11, and SRS Engineering Standard B1 M for Shear Type Anchor Bolts, Reference 2. Other applicable criteria are identified within the analysis.

ROBERT L. CLOUD & ASSOCIATES, INC.

BY H. Wey DATE 5/22/90
CHKD. BY GP Gees DATE 5-23-90

SAVANNAH RIVER SITE
CALC. NO. P191-1/7

PAGE NO. 6 OF 25
PROJ. NO. P191-1

3.0 ANALYSIS

3.1 Load Definition

The reactor tank lower supports are subjected to loads from the reactor tank, bottom tubesheet, and fuel/target assemblies (lateral only). The loads calculated in RLCA Calculation No. P191-1/11, Reference 2, will be used as the basis for developing the support loads for this analysis.

Due to the configuration of the keyed supports, each support primarily resists loading only in the direction orthogonal to the support orientation. Loading parallel to the support is not transmitted through the key (only by friction). As a result, the worst case support load is generated by the maximum load due to one of the two horizontal directions. Also, the geometry of the support layout is also axisymmetric.

For this analysis, use the maximum loading from a single horizontal input direction from RLCA Calc. P191-1/11.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Lee DATE 2/22/90
CHKD. BY G. P. Lee DATE 4/2/90

SAVANNAH RIVER SITE
CALC. No. PI91-1/7

PAGE NO. 7 OF 25
PROJ. NO. PI91-1

The axisymmetric geometry in this case particularly justifies this approach. Since the twelve support locations are all identical in configuration and spacing, and are at an equal radius from the center, they will be loaded in the same manner regardless of the load direction.

Due to the gap/key configuration, the two supports at 90° to the load direction will always see the maximum loading.

ROBERT L. CLOUD & ASSOCIATES, INC.

BY th wey DATE 5/24/90
CHKD. BY GPG DATE 5-23-90

SAVANNAH RIVER SITE
CALC. NO. PPII-1/7

PAGE NO. 8 OF 25
PROJ. NO. P191-1

From Reference 3, extract the lateral seismic loads for the worst case horizontal direction:

Tank Shell Reaction: 33030 lb. (Ref. 3, p. 14)

Bottom Tubesheet: 54260 lb. (Ref. 3, p. 20)

Fuel/Target Assembly:

42900 lb. + 10% = 47190 lb. (Ref. 3, p. 16)

Total Lateral Force At

Support In One Direction = 134500 lb.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loey DATE 2/22/90
CHKD. BY G.P. Greed DATE 5-23-90

SAVANNAH RIVER SITE
Calc. No. P191-1/7

PAGE NO. 9 OF 25
PROJ. NO. P191-1

Support Friction Load

Due to the support design, a substantial portion of the lateral load will be resisted by friction between the bottom tubesheet support pad and the bearing pads. The load not carried by friction to the bearing plates will be transferred to the plates through the lateral keys and their connecting pins.

Per the Ref. 1 drawings, the smoothest surface finish of the contacting surfaces is 32μ in.

Table 5.1 of Reference 7 was reviewed to determine an applicable coefficient of friction. For A36 material, semipolished, an average value of 0.28 was reported based on twelve tests with a standard deviation of 0.04.

Assume a coefficient of static/dynamic friction of 0.3. The value of 0.3 for machined mild carbon steel surfaces is commonly used in the commercial nuclear industry.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loey DATE 2/19/90
CHKD. BY G.P. Goe DATE 5-23-90

SAVANNAH RIVER SITE
CALC. NO. P191-1

PAGE NO. 10 OF 25
PROJ. NO. P191-1

Maximum vertical weight of the reactor tank, fluid, and bottom tubesheet was tabulated on page 19 of Reference 3.

$$\text{Maximum Deadweight} = 463800 \text{ lb.}$$

Using a seismic acceleration of 0.242g from Ref. 3, calculate vertical normal force considering uplift (0.242g represents envelope EPA for Elevs. -20 ft for longitudinal and transverse directions).

$$[463800][1 - (0.242)(2/3)] = 389000 \text{ lb}$$

Thus, the minimum friction resistance to the seismic inertial lateral load is:

$$F_f = (0.3)(389000) = \underline{116700 \text{ lbs.}}$$

ROBERT L. CLOUD & ASSOCIATES, INC.

BY LL DATE 2/24/90
CHKD. BY GPG DATE 5-23-90

SAVANNAH RIVER SITE
CALC. No. P191-1/7

PAGE NO. 11 OF 25
PROJ. NO. P191-1

If maximum vertical DW + seismic load is considered,

$$\text{Friction Capacity} = [0.3][463800][1 + (0.242)(2/3)] \\ = 161600 \text{ lb.}$$

$$\text{Maximum Friction Capacity} > \text{Calculated Lateral Load} \\ 161600 \text{ lb.} > 134500 \text{ lb.}$$

Maximum friction resistance exceeds the inertial force. If all lateral load is resisted by friction, the resulting analysis is less conservative for the most highly loaded supports (at 90° to load) since friction load is more evenly distributed. With less friction resistance, more load is picked up by the keys. Thus use the 116700 lb. friction load.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Wee DATE 2/23/90
CHKD. BY G.P. Gue DATE 4/2/90

SAVANNAH RIVER SITE
CALC. NO. P191-1/7

PAGE NO. 12 OF 25
PROJ. NO. P191-1

Calculate worst case individual support load
for use in analyzing the taper pins and
anchor bolts.

Define support
locations as
shown (for
an arbitrary
load orientation):

ROBERT L. CLOUD & ASSOCIATES, INC.

BY H. Heery DATE 5/22/90
CHKD. BY G. P. Goe DATE 5-23-90

SAVANNAH RIVER SITE
Calc. No. P191-1/7

PAGE NO. 13 OF 25
PROJ. NO. P191-1

Non-Friction Mechanical Load

The remaining lateral force is to be mechanically resisted by the key, pins, etc.
The magnitude of the remaining force is:

$$F = 134500 - 116700 \\ = 17800 \text{ lb.}$$

Per Support:

Due to the support arrangement (see W133481), only the two supports at the 0° and 180° locations are able to initially pick up the non-friction mechanical load through the keys (after gap closure).

For each support:

$$\text{Mech. Support Load} = \frac{17800}{2} = 8900 \text{ lb.}$$

$$\text{Friction Load Per Support} = \frac{116700}{12} = 9725 \text{ lb.}$$

$$\text{Total Load Per Support} = 8900 + 9725 = \underline{18630} \text{ lb.} \\ (0^\circ \text{ \& } 180^\circ \text{ locations})$$

ROBERT L. CLOUD & ASSOCIATES, INC.

BY H. Lee DATE 5/22/90
CHKD. BY G. P. Lee DATE 5-23-90

SAVANNAH RIVER SITE
CALC. No. P191-1 / 7

PAGE NO. 14 OF 25
PROJ. NO. P191-1

Taper Pin Stress

Load is transferred from the upper to lower bearing plates by two $1\frac{1}{4}" \phi$ taper pins and two $1\frac{1}{8}" \phi$ flat head cap screws.

Due to the tighter fit and direct load path to the taper pins, analyze assuming only the taper pins carry shear load. Use nominal diameter and maximum load.

$$\text{Maximum Shear Stress (per pin)} = \frac{(18630 / 2)}{\frac{\pi}{4} (1\frac{1}{4}")^2} = 7590 \text{ psi}$$

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Lee DATE 2/20/90
CHKD. BY GPGee DATE 5-23-90

SAVANNAH RIVER SITE
CALC. NO. P191-1/7

PAGE NO. 15 OF 25
PROJ. NO. P191-1

Pin Material Allowable Stress

Drawing W1334B1 calls out the dowel and pin material as "ASTM A108-49T, Grade B1112 OR BETTER". The current ASTM Standard A108 (-81) (Ref. 9) does not list a Grade B1112 material. However, the current standard includes Grades 1117, 1118, etc. Also, A108 (B1112) is not an ASME material.

Assume Grade B1112, as called out, is equivalent to a 1112 type steel. Based on this assumption, the Metals Handbook, Volume 1, pg. 240 (Ref. 10) includes information that will allow assuming a yield strength of 35 ksi for a 1112 type steel (conservative since lowest value and hot rolled condition is assumed).

Apply rules from ASME Section III, App. F (Ref. 11.)
Per F-1335.2, allowable bolt shear stress
 $F_v = \text{lesser of } (0.42 S_u \text{ or } 0.6 S_y).$

Adjust S_y for 200°F assuming A36 (mild steel) material behavior (use Ref. 11, App. I, Table I-13.1)

$$S_{y200^\circ\text{F}} = (32.8/36.0) (35.0) = 31.9 \text{ ksi}$$

$$F_v = \text{lesser of } (25.2, 19.1 \text{ ksi}) = \underline{\underline{19.1 \text{ ksi}}} \Rightarrow \text{Taper Pins } \underline{\underline{\text{ok}}}$$

ROBERT L. CLOUD & ASSOCIATES, INC.

BY H. Loey DATE 4/22/90
CHKD. BY G. P. Gue DATE 5-23-90

SAVANNAH RIVER SITE
Calc. No. P191-1/7

PAGE NO. 16 OF 25
PROJ. NO. P191-1

Anchor Bolts

As a conservative analysis simplification, neglect the contribution of the horizontal anchor bolts. If only the two vertical bolts are assumed active, the net shear load per bolt is:

$$\frac{18630}{2} = 9320 \text{ lb. /bolt}$$

To determine the seismic margin, calculate the seismic allowables that would apply to these anchor bolts.

Check both the bolting material and the concrete anchorage.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loey DATE 2/19/90
CHKD. BY G. P. Gee DATE 5-23-90

SAVANNAH RIVER SITE
CALC. NO. P191-1/7

PAGE NO. 17 OF 25
PROJ. NO. P191-1

Allowables for Vertical Bolts

Per Standard BIM (Ref. 2) for a 1 inch diameter bolt, the allowable shear load is 7.8 kip.

This allowable is the same as that specified in Reference 6, Part 4, Table 1-D for A36 stock. (Standard BIM specifies A36 as the anchor bolt material, and refers to AISC, 8th Ed.) Apply the $\frac{1}{3}$ increase as allowed for seismic (per Ref. 5 AISC 7th Ed., Section 5, # 1.5.6 and/or Reference 6 AISC 8th Ed. Section 5, # 1.5.6/1.6.3), the bolt shear seismic allowable is:

$$\begin{aligned}\text{Bolt Seismic Shear Allowable} &= (1\frac{1}{3})(7.8) \\ &= \underline{10.4 \text{ kip}} > 9.3 \text{ kip} \quad \underline{\text{OK}}\end{aligned}$$

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loay DATE 2/20/90
CHKD. BY G.P.C. DATE 4/2/90

SAVANNAH RIVER SITE
CALC. No. P191-1/7

PAGE NO. 18 OF 25
PROJ. NO. P191-1

Check the concrete anchorage for the "Transverse" direction:

Per Drawing W133504, the anchor bolt layout is:

Review concrete anchorage adequacy per Reference B, ACI-349, Appendix B, Section B.5.1.2 - Anchorage Requirements for Shear.

$$\text{Minimum Side Over Distance} = D \sqrt{\frac{f_{ut}}{7.5 f'_c}}$$

where: $D = 1 \text{ inch}$

$f_{ut} = 58,000 \text{ psi}$ (for A-36, per Ref. 6)

$f'_c = \text{Assume } 2000 \text{ psi (conservative)}$

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Lee DATE 2/20/90
CHKD. BY GPG DATE 4/2/90

SAVANNAH RIVER SITE
CALC. No. P191-1/7

PAGE NO. 19 OF 25
PROJ. NO. P191-1

$$m = (1) \sqrt{\frac{58,000}{7.5 (\sqrt{2000})}}$$

$$= 13.5 \text{ inches}$$

Shear Capacity in Direction of Free Edge:

Assume effective stress area based on 7 inch minimum edge distance (actual embedment depth $\cong$ 20 inches per BIM). Thus, effective stress area(s) is:

$$\text{Effective Stress Area} = \pi(7)^2 - \pi(1)^2$$

(per anchor)

$$= 151 \text{ in}^2$$

$$\text{Uniform Tensile Stress} = 4\phi \sqrt{f'_c} = 4(0.65) \sqrt{2000}$$

$$= 152 \text{ psi}$$

$$\text{Concrete Shear Capacity} = (152)(151) = \underline{22950 \text{ lb.}} \text{ per anchor location}$$

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Wey DATE 2/20/90
CHKD. BY G. P. Gee DATE 4/2/90

SAVANNAH RIVER SITE
CALC. NO. P91-1/7

PAGE NO. 20 OF 25
PROJ. NO. P91-1

Per Ref. B, Φ B.S.1.4:

$$m/3 = \frac{13.5}{3} = 4.5 \text{ inch (minimum side cover)}$$

$$\text{Existing} = 7 \text{ inches} > m/3 = 4.5 \text{ in} \Rightarrow \underline{\underline{OK}}$$

Existing 7 inches also greater than all minimum concrete cover distances in § 7.14 of Ref. B.
 $\Rightarrow$ OK.

Individual Concrete Anchorage adequate for the 10.4 kip/bolt limitation imposed by the bolt material.

$\Rightarrow$ Vertical 1 inch ϕ anchor bolts OK

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loay DATE 2/10/90
CHKD. BY G. P. Gede DATE 5-23-90

SANANNAA RIVER SITE
CALC. NO. D191/7

PAGE NO. 21 OF 25
PROJ. NO. D191-1

Vertical Loading

From Reference 3, the maximum vertical support reaction, conservatively calculated, was determined to be:

$$\text{Vertical Load} = 57550 \text{ lbs.} \quad (\text{Ref. 3, p. 22})$$

From Drawing W1334B1 the portion of the bearing pad beneath the tubesheet support pad is approximately 10 in. x 12 1/2 in. (minimum). Vertical loads pass through the bearing plates and grout to the building reinforced concrete. By inspection, the support is adequate for vertical loads.

ROBERT L. CLOUD & ASSOCIATES, INC.

BY H. Loey DATE 5/22/90
CHKD. BY G. P. Greed DATE 5-23-90

SAVANNAH RIVER SITE
CALC. No. P191-1/7

PAGE NO. 22 OF 25
PROJ. NO. P191-1

Results Summary

$$\text{Taper Pin Margin} = \frac{19.1}{7.59} = 2.52$$

$$\text{Anchor Bolt Margin} = \frac{10.4}{9.32} = 1.12$$

Based on design allowable,
and neglecting contribution
of horizontal bolts

$$\text{Anchor Bolt Margin} = \frac{36/\sqrt{3}}{9.32} = 2.23$$

Based on ultimate shear
capacity, and neglecting
contribution of horizontal
bolts

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Loey DATE 2/20/90
CHKD. BY GPG DATE 9/2/90

SAVANNAH RIVER SITE
CALC. No. P191-1/7

PAGE NO. 23 OF 25
PROJ. NO. P191-1

4.0 SUMMARY AND CONCLUSIONS

The reactor tank lower supports have been reviewed. The lower supports were found to be adequate for the current loading even with conservatisms applied to allow for analysis of the nonlinear friction/gapped support design.

ROBERT L. CLOUD ASSOCIATES, INC.

BY H. Lee DATE 2/10/90
CHKD. BY G. P. Gell DATE 5-23-90

SAVANNAH RIVER SITE
CALC. No. P191-1/7

PAGE NO. 24 OF 25
PROJ. NO. D191-1

5.0 REFERENCES

1. Drawings: W133481, Rev. 0
W133583, Rev. 52
W133584, Rev. 40
W134313, Rev. 12
W133389, Rev. 24
2. Concrete Engineering Standard, BIM,
Sleeved Anchor Bolts, Shear Type, Nov. 1981.
3. RLCA Calculation Package P191-1/11, Rev. 2.
4. Formulas for Stress and Strain, Roark, Young,
5th Ed., McGraw-Hill, 1975.
5. Manual of Steel Construction, AISC, 7th Edition.
6. Manual of Steel Construction, AISC, 8th Edition.
7. Guide to Design Criteria for Bolted and Riveted Joints,
Kulak, Fisher, & Struik, 2nd Edition, John Wiley
& Sons, Inc., 1987.

ROBERT L. CLOUD & ASSOCIATES, INC.

BY H. Lee DATE 2/22/90
CHKD. BY G. Gee DATE 5-23-90

SAVANNAH RIVER SITE
CALL NO. P191-1/7

PAGE NO. 25 OF 25
PROJ. NO. P191-1

5.0 References (cont'd)

8. ACI Standard 349-76, Code Requirements for Nuclear Safety Related Concrete Structures, including Appendices, American Concrete Institute.
9. ASTM Standard Specification A108-81 (Reapproved 1988), Standard Specification for Steel Bars, Carbon, Cold Finished, Standard Quality.
10. Metals Handbook, Volume 1, Properties and Selection: Irons and Steels, Ninth Edition, American Society For Metals, 1978.
11. ASME B2PV Code, Section III, 1974 Edition w/ Addenda, Supplemented as required by 1986 Edition.

**DATE
FILMED**

9 / 9 / 93

END