DOE/PC/88890--T2

DE92 016145

ACQ

JUN 26 1992

PROOF OF CONCEPT TESTING OF AN INTEGRATED
DRY INJECTION SYSTEM FOR SO_x/NO_x CONTROL

Quarterly Technical Progress Report

April - June, 1989

Prepared by

D. J. Helfritch and S. J. Bortz,
Research-Cottrell Environmental Services & Technology

and

R. Beittel, Riley Stoker Corp.

DOE Contract No. DE-AC22-88PC88890

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Q/20/89

INTRODUCTION

The proof of concept testing at the Riley Stoker Test Facility is designed to demonstrate the integrated dry injection technology on a relatively large scale and over a relatively long time period. The program was not designed to evaluate a number of potential sorbents. Indeed, such an evaluation would be difficult due to the large quantities of sorbents required. On the other hand, it is known that the sorbent properties strongly influence the SO_2 and NO_x removal capabilities, and the proper choice of sorbents for use in the proof of concept testing is clearly important if target SO_2 and NO_x removal efficiencies are to be achieved. The subscale testing was proposed as a quick and economic means to evaluate a wide range of sorbents, resulting in recommendations for the choice of sorbents for use in the proof of concept tests.

The subscale tests were developed to investigate three areas of concern. Calcium hydroxide sorbents can be obtained from a large number of sources and can be enhanced by means of milling or additives to the hydration water. One concern is how to choose the best sorbent from among such a large group.

It has been found that the effectiveness of sodium bicarbonate for SO_2 removal decreases as temperature falls below 300°F , because it does not decompose to the active sodium carbonate form as rapidly at lower temperatures. Some investigators have found that sodium sesquicarbonate is more effective at low temperatures due to its lower decomposition temperature. Since it is expected that the flue gas temperature will need to be reduced to about 200°F for precipitator enhancement, it is important to characterize the low temperature effectiveness of both sodium bicarbonate and sesquicarbonate, in order to make a selection for the proof of concept tests.

The chemistry of NO_x removal by sodium bicarbonate is given below.

Because the production of NO₂ in reaction 2 outpaces its removal via reaction 3, the result is a net generation of NO₂ with sodium bicarbonate injection. Several additives to the sodium bicarbonate that can reduce the amount of NO₂ have been identified. These are ammonia, urea and activated carbon. While it is known that these compounds can suppress NO₂ increases, the mechanism is not yet determined, although it is thought that urea decomposes to ammonia, which reacts directly with NO₂. For the projected rates of NO removal, it is expected that NO₂ can be generated in excess of 100 ppm. This level of NO₂ would result in a brown stack plume and would be unacceptable. As a result, it is important to identify an NO₂ suppressing additive, capable of maintaining NO₂ emissions at under 30 ppm, the visible threshold.

OBJECTIVES

The objectives of the subscale test program were designed to provide sorbent and additive selection guidance, and, in so doing, supply answers to the questions posed in the preceding section. The objectives are:

- Identify the best commercial hydrate sorbent and the best enhanced hydrate sorbent from a list of nine types, based upon SO_2 removal at $\text{Ca/S}=2$.
- Determine the relative effectiveness of sodium sesquicarbonate versus sodium bicarbonate for SO_2 and NO_x control over the temperature range of 200°F - 400°F .
- Identify the best NO_2 suppressing additive among the group of ammonia, urea, and activated carbon.

TEST PROCEDURES

Subscale sorbent tests were performed at the KVB lab during May, June, and July. These tests involved the injection of calcium hydroxide and sodium sorbents at various points of the flue gas system downstream of a $.25 \times 10^6$ Btu/hr coal fired combustor. The system is shown in Figure 1. Sorbents could be directly injected by means of a compressed air driven eductor or could be milled immediately preceding injection by means of an air mill.

The flue gases were measured at three positions, at the end of the convective section, at the baghouse inlet and the baghouse outlet. The SO_2 and NO_x reductions measured were based on the difference between the SO_2 , NO , NO_2 and NO_x levels at convective section exit without injection and the same gas species measured at the baghouse exit with calcium and sodium injection. The SO_2 reduction resulting from calcium alone was based on the readings at the convective section exit with and without calcium injection. All measurements shown in the data tables were normalized to 3% O_2 . Actual O_2 values were approximately 4% at the convective section exit, 4% at the baghouse inlet and 8% at the baghouse exit.

Water injection could be performed upstream or downstream of the heat exchanger. The water injection position upstream of the heat exchanger was the position used for lowering the temperature of the flue gas stream while the position downstream of the heat exchanger was used to inject a urea solution when this additive was tested.

The flue gas flow from the furnace is approximately 4.2 pound/min. and the residence time between the sodium injection point and the baghouse inlet is about 1.0 seconds during which time the temperature remains steady. The baghouse temperature was measured by inserting a thermocouple through the wall of the baghouse between bags and should accurately represent the temperature of the sorbent deposited on the bags. The gas residence times and cooling rates are comparable to those found for full scale boilers.

Figure 1

PILOT PLANT FACILITY

CALCIUM HYDROXIDE INJECTION RESULTS

The hydrates tested and their characteristics are given in Table 1. These hydrates were injected into the convective section of the pilot scale combustor as indicated in Figure 1. The injection points correspond to gas temperatures of 1100, 1000, and 900°F. The SO₂ inlet concentration for all hydrate injection tests was 2600 ppm, and the Ca/S mole ratio was 2 for all tests. The hydrates were injected as received by means of an eductor for some tests and were injected after being air milled in other tests.

The results are shown in Figure 2, which gives SO₂ removal as a function of injection temperature. The results of Figure 2 are unchanged by the use or non use of the air mill. This result is not in accord with prior experience, and efforts are underway to resolve this difference.

It is seen that peak effectiveness of all hydrates is achieved at about 1000°F, and the clear superiority of the alcohol hydrate is evident. On the other hand, the expected SO₂ enhancement by means of the lignosite additive did not occur. Upon examination of the hydrate characteristics, it is obvious that the single most important hydrate characteristic for good SO₂ removal is surface area, and Figure 3 shows hydrate utilization as a function of surface area. It is seen that utilization is almost directly proportional to surface area.

Table 1

TEST HYDRATES

Hydrate		Source	Surface Area m^2/g	MMD (μm)
1.	Mississippi Lime	St. Genevieve, MO	23.5	2.2
2.	Marblehead Lime	Chicago, IL	16.0	3.4
3.	Bellefonte Lime	Bellefonte, PA	20.5	2.8
4.	Tenn-Luttrell	Luttrell, TN	19.0	2.7
5.	Chemical Lime	Clifton, TX	19.1	3.4
6.	Colton Lime	Colton, CA	19.0	2.6
7.	Alcohol Hydrate	KVB Lab	38.0	1.7
8.	Lignosite Additive 1	B & W	15.1	2.6
9.	Lignosite Additive 2	KVB Lab	11.5	3.8

Figure 2

% SO₂ Removal for Various Hydrates

Hydrate Injection Temperature, °F

Ca/S = 2

Hydrate

1 □	5 X
2 ▽	6 ○
3 ◇	7 +
4 △	8 ●

Figure 3

Effect of Hydrate Surface Area on Utilization

SODIUM INJECTION RESULTS

The sodium compounds tested were sodium bicarbonate, NaHCO_3 , and sodium sesquicarbonate, $\text{Na}_2\text{CO}_3 \cdot \text{NaHCO}_3 \cdot 2\text{H}_2\text{O}$. The mass mean diameter particle sizes were 12.9 microns for the bicarbonate and 12.2 microns for the sesquicarbonate. The NO_2 suppressing additives tested were ammonia, NH_3 , urea, $(\text{NH}_2)_2\text{CO}$, and activated carbon. The injection point of these compounds is indicated in Figure 1. The heat exchanger was used to cool the flue gas to 350°F and a water spray to cool to lower temperatures. For all tests the inlet SO_2 concentration was 2600 ppm and the inlet NO concentration was 350°F. The alcohol hydrate was injected at 1000°F for all tests and the sodium compounds at temperatures between 250 and 500°F. The baghouse temperature was lower than the injection temperature, due to heat loss through the walls. Figure 4 shows the relationship between baghouse and injection point temperatures. The injected sodium compounds were entrained in flue gas at the injection temperature for about one second, after which they entered the baghouse, where they remained until removed from the bags. The reactions between the sodium compounds and SO_2 and NO_x therefore took place initially at the injection temperature (one second) and subsequently at the baghouse temperature (minutes). The tabulated results of the tests are given in the Appendix.

Figure 5 shows $\Delta\text{NO}/\Delta\text{SO}_2$ as a function of temperature. The decrease in NO from an initial 350 ppm (ΔNO) is normalized by the decrease in SO_2 (ΔSO_2) caused by reaction with sodium carbonate. This is done to eliminate the effects of differing Na_2/SO_2 mole ratios, from test to test, and is valid because NO can only be effected in conjunction with SO_2 , via reaction 2. We see that maximum NO removal occurs at an injection temperature of 350°F (baghouse temperature = 240°F), and it is seen that this result applies for both bicarbonate and sesquicarbonate injection, an unexpected finding. It is also seen that bicarbonate and sesquicarbonate are approximately equally effective for NO removal.

Figure 6 shows the net increase in NO_2 , normalized with respect to ΔSO_2 , as a result of sodium injection. 30 ppm of NO_2 corresponds to approximately $\Delta\text{NO}_2/\Delta\text{SO}_2 = .05$. It is seen that the additives only become effective at suppressing NO_2 at injection

Figure 4
Relationship Between Injection Point
and
Baghouse Temperatures

Figure 5

Effect of Temperature on NO Removal

Figure 6

Effect of Temperature on NO₂ Production

△ Sesquicarbonate
○ Bicarbonate

Ca/S = 1.8 - 2.5
Na₂/S = .8 - 1.6

▲ ● Urea Additive
● Ammonia Additive
▲ ● Carbon Additive

temperatures greater than 350°F, and at these temperatures the urea additive appears to be superior. It can also be seen that NO_2 levels decrease below a 350°F injection temperature, and NO_2 is less than 30 ppm at temperatures lower than 300°F. (200°F baghouse temperature). Similar NO_2 temperature dependence was observed by Markussen et. al. * in spray dryer testing utilizing lime slurry containing sodium hydroxide.

Figure 7 shows $\Delta\text{NO}_x/\Delta\text{SO}_2$ as a function of temperature. It is seen that there is no clear difference between bicarbonate and sesquicarbonate. NO_x removal does not drop off as rapidly as NO removal at low temperature because NO_2 production decreases in this temperature range. At high temperature NO_x reduction can be maintained through the use of additives. The net result is a relatively constant NO_x removal over the full range of temperatures.

Figure 8 shows percent SO_2 and NO_x removals as functions of temperature. The data is surprisingly independent of temperature and sorbent type, showing approximately 90% SO_2 removal and 20% NO_x removal over the full range of injection temperature.

* J. M. Markussen, J. T. Yeh and C. J. Drummond, "Enhanced Removal of Nitrogen Oxides in a Spray Dryer Using a Lime Slurry Containing Sodium Hydroxide," Proceedings of the 1986 AIChE Spring Meeting, April 1986.

Figure 7
Effect of Temperature on NO_x Removal

- △ Sesquicarbonate
- ▲ Sesqui with Additive
- Bicarbonate
- Bicarb with Additive

Ca/S = 1.8 - 2.5

Na₂/S = .8 - 1.6

Figure 8

SO₂ and NO_x Removal Vs. Na Injection Temperature

- △ Sesquicarbonate
- ▲ Sesqui with Additive
- Bicarbonate
- Bicarb with Additive

Ca/S = 1.8 - 2.5

Na₂/S = .8 - 1.6

SUBSCALE TESTING CONCLUSIONS

The conclusions that can be drawn from the results of the subscale test are:

- Utilization of the hydrate sorbents is almost directly proportional to surface area.
- The alcohol hydrates have the highest surface area and hence yield the highest SO_2 removal efficiency at 70%.
- Milling the hydrate sorbents prior to injection has no effect on SO_2 removal efficiency. This conclusion is still being investigated.
- There is no difference in the effectiveness of sodium sesquicarbonate and sodium bicarbonate for SO_2 or NO_x control over the range of temperatures considered.
- Approximately 90% SO_2 removal can be achieved when using an alcohol hydrate in combination with either sodium sesquicarbonate or sodium bicarbonate.
- Approximately 20% NO_x removal can be achieved by either sodium sesquicarbonate or sodium bicarbonate injection.
- Urea additive can limit NO_2 production to below 30 ppm when gas temperatures are higher than 300°F (baghouse temperature).
- NO_2 production does not exceed 30 ppm when gas temperature is lower than 200°F (baghouse temperature).

RECOMMENDATIONS FOR PROOF OF CONCEPT TESTS

Several recommendations can be made concerning the design and plans for the proof of concept tests at Riley Research Center. These recommendations are:

- Original planning called for an on-lime milled commercial hydrate to be used as the principal sorbent. It is recommended that this be changed to an unmilled alcohol hydrate.
- Due to its lower commercial cost and its demonstrated performance, it is recommended that sodium sesquicarbonate be the sodium sorbent for all tests.
- Urea should be used for NO_2 suppression when needed, although it is likely that no additive will be required for tests where the precipitator exit temperature is lower than 200°F.

APPENDIX - SODIUM INJECTION TABULAR RESULTS

SO₂ AND NO_x REMOVALS DURING NO₂
ADDITIVE TESTS WITH SESQUICARBONATE

Test Ratio	Ca/S Ratio	Na ₂ /S Ratio	Na Type	Additive Type/wt%	Na Inj. Temp. °F	% SO ₂ Reduction Ca Only	% SO ₂ Reduction Ca + Na	% NO _x Reduction Ca + Na
1	2.1	1.0	Ses.	—	320	61.4	92.3	19.6
2	—	1.2	Ses.	—	330	—	76.7	16.7
*3	2.2	1.0	Ses.	—	250	57.4	82.9	27.7
*4	2.4	0.9	Ses.	5% Urea	350	58.0	85.0	21.6
*5	2.2	1.6	Ses.	5% Urea	250	65.4	90.2	35.5
6	2.4	1.2	Ses.	—	350	65.0	89.0	21.6
7	2.4	1.3	Ses.	5% Carbon	350	68.0	86.0	22.1
8	2.3	1.0	Ses.	—	350	62.0	87.0	20.7
9	2.1	1.0	Ses.	—	270	66.1	83.9	14.9
10	2.1	1.0	Ses.	5% Urea	270	66.1	85.9	13.2

* NO_x results assumed to be incorrect due to erratic inlet NO concentration.

NORMALIZED NO_x REMOVALS AND NO₂ INCREASE DURING NO₂
ADDITIVE TESTS WITH SESQUICARBONATE

Test No.	Na ₂ /S Ratio	ΔSO ₂ ppm	Na ₂ U _t %	ΔNO ppm	ΔNO ₂ ppm	NO _x ppm	ΔNO/ ΔSO ₂	ΔNO _x / ΔSO ₂	ΔNO ₂ / ΔSO ₂	Na Injection Temp., °F	Baghouse Temp., °F
1	1.0	794	80.0	143	74	69	0.18	0.08	0.09	320	225
2	1.2	608	74.9	141	84	57	0.23	0.09	0.14	350	240
3	1.0	547	60.0	111	14	97	0.20	0.18	0.02	250	190
4	1.0	631	62.8	160	79	81	0.25	0.13	0.12	350	240
5	1.6	586	41.4	129	12	117	0.22	0.20	0.02	250	190
6	1.2	707	65.5	132	54	78	0.19	0.11	0.08	340	230
7	1.3	617	55.5	109	39	70	0.17	0.11	0.06	350	240
8	1.0	699	70.6	134	62	72	0.19	0.10	0.09	350	240
9	1.0	588	61.0	69	17	52	0.12	0.09	0.03	270	190
10	1.0	500	58.5	60	15	46	0.12	0.09	0.03	270	190

SO₂ AND NO_x REMOVALS DURING NO₂

ADDITIVE TESTS WITH BICARBONATE

Test No.	Ca/S Ratio	Na ₂ /S Ratio	Na Type	Additive Type/wt%	Na Inj. Temp. °F	% SO ₂ Reduction Ca Only	% SO ₂ Reduction Ca + Na	% NO _x Reduction Ca + Na
1	2.5	1.5	Bicarb.	—	350	70	88.3	21.2
2	2.5	1.5	Bicarb.	5% Urea	350	72.2	93.7	21.9
3	2.5	1.4	Bicarb.	—	250	69.0	98.6	18.2
4	2.5	1.5	Bicarb.	—	450	69.6	98.0	15.0
5	1.8	1.0	Bicarb.	—	474	65.0	88.5	7.5
6	1.8	0.8	Bicarb.	4/1 NH ₃ /NO	494	55.6	80.2	17.7
7	1.8	0.9	Bicarb.	5% Carbon	507	63.9	87.5	14.7
8	1.8	0.9	Bicarb.	5% Urea	481	59.0	90.0	36.9
9	1.8	1.2	Bicarb.	—	240	61.0	93.5	23.7

NORMALIZED NO_x REMOVALS AND NO₂ INCREASE DURING
NO₂ ADDITIVE TESTS WITH BICARBONATE

Test No.	Na ₂ /S Ratio	ΔSO ₂ ppm	Na ₂ Ut. %	ΔNO ppm	ΔNO ₂ ppm	NO _x ppm	ΔNO/ΔSO ₂	ΔNO _x /ΔSO ₂	ΔNO ₂ /ΔSO ₂	Na Injection Temp., °F	Baghouse Temp., °F
1	1.5	461	40.9	103	41	62	0.22	0.134	0.09	350	236
2	1.6	533	48.4	110	43	67	0.21	0.126	0.08	350	234
3	1.4	773	68.2	82	18	64	0.11	0.08	0.02	250	190
4	1.5	752	62.9	111	58	54	0.15	0.07	0.08	450	290
5	1.0	619	66.9	73	51	25	0.12	0.04	0.08	474	316
6	0.8	569	60.0	88	26	60	0.15	0.11	0.05	494	314
7	0.9	628	72.4	97	48	49	0.15	0.08	0.08	507	315
8	0.9	780	81.4	128	17	112	0.16	0.14	0.02	481	296
9	1.2	858	69.9	96	13	83	0.11	0.10	0.02	240	190

**DATE
FILMED
9/01/92**