AIM

Association for Information and Image Management

1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910
301/587-8202

Centimeter

Inches

MANUFACTURED TO AIM STANDARDS
BY APPLIED IMAGE, INC.

1 of 1

GRI-91/0158
LBL-30376
UC-000

**ANALYSIS OF THE IMPACTS OF ENERGY CONSERVATION CODES
IN NEW SINGLE-FAMILY HOMES**

TOPICAL REPORT

Prepared by

R.L. Ritschard, J.W. Hanford, and A.O. Sezgen

Lawrence Berkeley Laboratory
Applied Science Division
Berkeley, CA 94720

For

Gas Research Institute
GRI Contract No. 5086-800-1318
GRI Project Manager
James M. Fay
Residential/Commercial
Technology Analysis Program
Through U.S. Department of Energy
under Contract No. DE-AC03-76SF00098

December 1992

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED *yp*

GRI DISCLAIMER

LEGAL NOTICE: This report was prepared by Lawrence Berkeley Laboratory as an account of work sponsored by Gas Research Institute (GRI). Neither GRI, members of GRI, nor any persons acting on behalf of either:

1. Makes any warranty of representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any apparatus, method, or process disclosed in this report may not infringe on privately owned rights; or
2. Assumes any liability with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report.

This report is available from National Technical Information Service, U. S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161.

RESEARCH SUMMARY

TITLE	Analysis of the Impacts of Energy Conservation Codes in New Single-Family Homes
CONTRACTOR	Lawrence Berkeley Laboratory Applied Science Division 1 Cyclotron Road Berkeley, California 94720
PRINCIPAL INVESTIGATOR	R.L. Ritschard
REPORT	May 1990 - May 1991
OBJECTIVE	To analyze the energy implications of two thermal codes (ASHRAE 90.2P and 1990 Model Energy Code) and the National Appliance Energy Conservation Act (NAECA) of 1987 and Amendments of 1988 on energy use in prototypical new single-family buildings in the U.S.
TECHNICAL PERSPECTIVE	Within all 50 states, some form of code or standard for energy conservation in new building construction has been introduced. These codes or standards are of special importance to GRI because when fully implemented they will influence the heating and cooling requirements of single-family building types. The study provides estimates of the impacts of these standards on annual and peak energy usage for space heating and cooling and annual energy usage for water heating and non-HVAC end uses.
RESULTS	The two thermal standards, ASHRAE 90.2 and Model Energy Code, and appliance and equipment efficiency requirements (NAECA) can be effective in reducing annual energy use for both natural gas and electricity. In many U.S. climates this will result in significant reductions in annual energy costs. The thermal codes are not effective in lowering cooling energy use since they are mostly "envelope" codes and not equipment codes.

**TECHNICAL
APPROACH**

Single-family prototypical buildings with 1990s construction characteristics were simulated in 16 base cities representative of U.S. climates using a state-of-the-art hourly building energy code, DOE-2.1D. These simulations were performed with and without the requirements of the two thermal codes and provisions of the NAECA. Domestic hot water usage and non-HVAC electricity use were also calculated using standard engineering methods. The results include annual and peak energy consumption for natural gas and electricity end-uses for each prototype and base city. In addition, annual cost savings are calculated for a few selected cities with high natural gas or electricity usage.

**PROJECT
IMPLICATIONS**

The energy impacts of two building energy codes and the NAECA on 1990s prototypical single-family homes will provide useful information to GRI's R&D programs about natural gas requirements in new residences. These annual and peak energy requirements for space heating and cooling, water heating, and non-HVAC end uses will provide insights for further analysis into important issues related to the use of energy technologies in the single-family homes.

Project Manager

Mr. James M. Fay
Residential/Commercial
Technology Analysis

Table of Contents

1. INTRODUCTION	1
2. DESCRIPTION OF CODES	3
THERMAL CODES	3
ASHRAE 90.2P Standard	4
Model Energy Code	4
EQUIPMENT AND APPLIANCE CODES	6
3. METHODOLOGY	9
SELECTION OF BASE CITIES	10
STRUCTURAL ASSUMPTIONS	10
Building Prototypes	10
Building Geometry	15
Infiltration	16
Shading	16
Foundation Heat Loss	17
OPERATING ASSUMPTIONS	17
Thermostat Settings	17
Internal Loads	18
Non-HVAC Energy Consumption Methodology	20
Domestic Hot Water Methodology	20
HVAC Energy Use Calculation	24
METHODS FOR CALCULATING ENERGY COST SAVINGS	24
4. RESULTS AND DISCUSSION	27
STANDARDS IMPACTS ON NATURAL GAS CONSUMPTION	28
Effects on Gas Space Heating Consumption	28
Effects on Appliance Gas Use	35
STANDARDS IMPACTS ON ELECTRICITY CONSUMPTION	35
Effects on Cooling Energy Consumption	35

Effects on Non-HVAC Electricity Consumption	38
SUMMARY OF INTERNAL GAINS INTERACTIONS	39
TOTAL HOUSE ENERGY SAVINGS	39
ENERGY COST SAVINGS	41
5. CONCLUSIONS	45
6. REFERENCES	47
APPENDIX A: Heating and Cooling Loads Tables	51
APPENDIX B: Requirements of the Proposed ASHRAE 90.2 Standard	55
APPENDIX C: Requirements of the Model Energy Code	59

LIST OF TABLES

Table No.	Title	Page No.
1	ASHRAE 90.2P Code Thermal Integrity Requirements (R-values)	5
2	Model Energy Code Thermal Integrity Requirements (R-values)	6
3	Appliance Energy Use and Equipment Efficiency Improvements Under NAECA	7
4	Base Cities for Building Prototypes and Climates	11
5	General Specifications for Prototype Buildings	14
6	Building Envelope Parameters for Base Case and Code Compliance Buildings	15
7	1984 RECS Data Tape Results for Single-Family Detached Dwellings- Appliance Saturations and Types by Census Division	19
8	Annual Appliance and Lighting Energy Use	20
9	Estimated Non-HVAC Electric and Gas Consumption and Internal Loads	22
10	Average Air and Well Temperatures for Base Cities	23
11	HVAC Equipment Efficiency Assumptions	24
12a	Calculation of Natural Gas Energy Costs	26
12b	Calculation of Electric Energy Costs	26
13	Annual Hot Water Use and Water Heat Energy by Fuel and Location	28
14	End Use Energy Consumption Under Efficiency Standard Combinations	29-31
15	Change in Heating and Cooling Loads and Energy Use from Changes in Internal Gains	40
16	Base Case Energy Use and Total House Energy Savings from Standards Measures	41
17	Annual Energy Cost Savings for Natural Gas	44
18	Annual Energy Cost Savings for Electricity	44

LIST OF FIGURES

Figure No.	Title	Page No.
1	Average Floor Area for New Construction U.S. Single-Family Buildings, 1980-1989	13
2	Construction Type for New Construction U.S. Single-Family Buildings, 1980-1989	13
3	Internal Loads Profiles for Prototype Buildings	21
4	Space Heating Gas Use with Envelope Standards	33
5	Space Heating Gas Use with NAECA Standards	33
6	Space Heating Gas Use with Combination Standards	34
7	Appliance Gas Use with NAECA Standards	34
8	Cooling Electricity Use with Envelope Standards	36
9	Cooling Electricity Use with NAECA Standards	36
10	Cooling Electricity Use with Combination Standards	37
11	Appliance Electricity Use with NAECA Standards	37
12	Change in Heating and Cooling Loads with Change in Internal Gains	40
13	Annual Energy Cost Savings for Natural Gas	43
14	Annual Energy Cost Savings for Electricity	43

EXECUTIVE SUMMARY

Within the 50 states some form of federal code or standard for energy conservation in new building construction is typically incorporated into state and local codes. Two of these codes, the Model Energy Code (MEC) and the proposed ASHRAE standard 90.2P are of special importance to the residential data base developed by the Gas Research Institute (GRI) because they influence thermal requirements and have either been recently updated or will be revised in 1992.

In this study, we evaluate the impacts of these two thermal codes on the energy performance and energy consumption of prototypical new single-family buildings. Base case buildings, with characteristics typical of current building practices, are modified to meet the thermal envelope standards and are simulated with the DOE-2.1D building energy simulation program. In addition, we also model the effects of appliance and heating and cooling equipment efficiencies promulgated under the National Appliance Energy Conservation Act (NAECA) of 1987 (P.L. 100-12) and of the NAECA Amendments of 1988 (P.L. 100-357).

We compare heating and cooling loads and energy use for the prototypical house for several cases: the base case, with 1980s vintage thermal envelope and appliance and equipment efficiencies; with ASHRAE 90 thermal requirements; with Model Energy Code thermal requirements; with NAECA appliance and HVAC efficiencies; and with combinations of the ASHRAE 90 Standard or Model Energy Code and the NAECA appliance and equipment efficiency improvements. The results provide a glimpse of how these standards will affect future end-use energy consumption in new single-family buildings, both alone and in combination as they would occur in the "real" world.

The simulations and other calculations suggest that these new standards could lead to significant changes in energy consumption for particular end uses, with the following major conclusions.

- The greatest annual energy savings for both natural gas and electricity are from the combination of the ASHRAE Standard and full provisions of the NAECA. In the most extreme climates, the standards will potentially reduce space heat energy use by 31%, or 42 MMBtu for natural gas heat, and can reduce space cooling energy use by up to 20%, or 1032 kWh for electric air-conditioning.
- The requirements of the combined ASHRAE Standard and the appliance and equipment provisions in NAECA also provide large peak savings of natural gas and electricity. Gas peak savings for space heat reach 13.6 kBtu/hr and electricity peak savings for cooling reach 0.8 kW.

- The ASHRAE 90 Standard alone has the largest impact on space heating energy use, particularly in colder climates. The maximum annual gas space heat savings for ASHRAE are 37.9 MMBtu in Minneapolis, the coldest climate studied. Typical savings in colder climates are about 22 MMBtu/yr, or 27%. The ASHRAE standard typically has more stringent requirements than the MEC, and thus is more effective in reducing gas space heating energy usage than the Model Energy Code in all but one location (Fort Worth). In some locations, the MEC did not challenge current construction practices.
- In all locations, the appliance standards of the NAECA slightly increase annual space heating gas use by 2 to 4% and slightly decrease cooling electricity consumption by 4%. These changes arise from a decrease in internal heat gains from the more efficient appliances.
- Improvements in furnace efficiency under the NAECA standards save 9% in both annual and peak natural gas consumption for space heating in all climates.
- Improvements in air-conditioner efficiency (i.e., changes in SEER) in the NAECA equipment standards reduce space cooling energy consumption by 10-14%, or up to 750 kWh/yr, annually in the hotter climates.
- The thermal envelope standards have a varied effect on cooling. They reduce energy consumption in the south and west, and slightly increase cooling in the north and midwest. The increase in electricity use is a result of the new balance point temperature established by the insulation levels in the colder climates. In total, changes in cooling energy use from the envelope standards are small compared to the equipment standards.
- The non-HVAC electricity savings resulting from the NAECA are 10% to 15% of the base case appliance electricity consumption, or an annual average of about 1125 kWh. The appliance savings are greater than the space cooling savings in all climates.
- Rate schedules can influence the effectiveness of the thermal and appliance standards. That is, cost savings may be greater even though the annual energy savings are not.

These standards, if fully implemented, could significantly change end-use energy requirements in new single-family buildings. The overall conclusions are that new thermal standards and appliance and equipment efficiency requirements can be effective in reducing total annual energy use for both natural gas and electric heating, cooling, and appliance end uses, and in turn, can substantially reduce annual energy costs in many U.S. climates.

INTRODUCTION

Within the 50 states some form of federal code or standard for energy conservation in new building construction is typically incorporated into state and local codes. There are several existing energy codes that cover residential buildings, typically applying to the single-family and low-rise multifamily building types. Two of these codes are of special importance to the residential data base developed by the Gas Research Institute (GRI) because they influence thermal requirements and have either been recently updated or will be revised in 1992. The Model Energy Code (MEC), developed by the Council of American Building Officials (CABO) with assistance from the Building Officials and Code Administrators International, Inc. (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International, Inc. (SBCCI), and the National Conference of States on Building Codes and Standards, Inc (NCSBCS), was updated in 1989 to provide simplified nomographs for making thermal envelope "tradeoffs" between wall and roof/ceiling requirements for new residential buildings.¹ The technical requirements of the MEC were also updated from the previous 1983 version.

A second equally important building energy standard is ASHRAE 90-85 (Energy Efficient Design of New Low-rise Residential Buildings) developed by the American Society of Heating, Refrigerating and Air-conditioning Engineers, Inc. An updated version of the ASHRAE 90 Standard is currently being reviewed and may be adopted in 1992.² The revised ASHRAE 90 Standard (90.2P) will consider, for the first time, both heating and cooling requirements. In previous versions, only space heating, along with some minimum requirements for water heating and lighting, are considered. ASHRAE 90.2P will also be based on regional energy costs as well as climate variations. Only climate variations had been considered in previous versions. The ASHRAE standards continue to serve as technical bases for state building energy codes.

In this study, we evaluate the impacts of the requirements in the two thermal envelope standards on the energy performance of prototypical new single-family buildings. Base case construction and modified standards buildings are simulated with the DOE-2.1D building energy simulation program. The base case building characteristics and operating conditions are designed to emulate new buildings which will be built in the 1990s with no new standards in place and no increase in thermal envelope, appliance, or equipment efficiencies. Thus, the base case is an estimated 1990 vintage building in terms of building size, shape, etc., yet with insulation characteristics typical of buildings built in the 1980s, or between 1980 and 1989. In addition, we also model the effects of appliance and heating and cooling equipment efficiency standards promulgated under the National Appliance Energy Conservation Act (NAECA) of 1987 (P.L. 100-12) and of the NAECA Amendments of 1988 (P.L. 100-357).⁴ The impacts of

the NAECA are evaluated separately (i.e., improved appliance efficiency and improved efficiency of space conditioning equipment) and also in combination with either the Model Energy Code or the ASHRAE 90.2 Standard.

The overall focus of this work is to demonstrate what changes can be expected in new single-family building types with regard to end use (heating, cooling, water heating, and non-HVAC[‡] energy) and total building energy consumption and peak HVAC energy use. In analyzing the effects of the ASHRAE 90 Standard, 16 cities are studied that are part of the GRI single-family loads data base, while only a subset (7) of these cities were used for the study of the Model Energy Code. The cities for which the MEC impacts are analyzed are in states where the MEC has been adopted, either in full or in part, as part of the state building code.

In the report, we compare heating and cooling loads and energy use for the prototypical house for several cases: the base case, with 1980s vintage thermal and equipment efficiencies; with ASHRAE 90 thermal requirements; with Model Energy Code thermal requirements; with NAECA appliance and HVAC efficiencies; and with combinations of the ASHRAE 90 Standard or Model Energy Code and the NAECA appliance and equipment upgrades. These comparisons offer a way to evaluate the energy effects of the thermal and appliance standards alone as well as in combination as they exist in the "real" world.

The remainder of the report is organized into four additional sections. First, we present the nature of the various thermal envelope, appliance, and efficiency standards as they affect each prototypical building type in each location. This section provides a list of the assumed thermal conditions or appliance and equipment efficiencies for each standard. Second, we summarize the methods and technical approach, including discussions of the selection of weather tapes and base cities, structural assumptions, and building operating conditions. Next, we present the results for each energy standard or a combination of standards assumed in the overall analysis. The results are discussed in light of the impacts of the various building standards on annual heating and cooling energy use and peak heating and cooling loads and energy use. Finally, in the last section, we present the major conclusions of this study.

[‡] HVAC denotes heating, ventilation, and air-conditioning systems

2

DESCRIPTION OF CODES

To more fully characterize the end-use impacts of the standards considered in this project, we consider each standard separately, and even parts of each standard separately. This section defines the requirements in each standard that we consider. For example, we define the ASHRAE and MEC codes as "thermal" or "envelope" standards. That is because the primary component of these codes is minimum thermal requirements for the major building heat gain and loss components such as roofs, walls, floors, foundations, windows, and infiltration. As we discuss below, ASHRAE and MEC both contain standards for HVAC equipment and water heater efficiencies. However, we consider the furnace and air-conditioner requirements to be "equipment" standards and the water heater standards as an "appliance" standard. Standards enacted under NAECA include both minimum efficiency requirements for "equipment" -- furnaces, air-conditioners, and heat pumps -- as well as typical household appliances such as refrigerators, clothes washers, water heaters and television sets. We distinguish between the two because they affect end-use energy consumption in different ways.

THERMAL CODES

The thermal codes considered here are national standards; they are meant to serve as technical and programmatic bases for energy codes throughout the U.S. even though the requirements vary between regions. Thus, the requirements contained in either the ASHRAE standard or the MEC are likely to be later incorporated in state building energy standards.

ASHRAE 90.2P is a proposed update to the ASHRAE 90-1985 standard, which itself was an improved version of ASHRAE 90A-1980. This family of national energy conservation standards is the basis for almost all state and local government building energy codes. In some cases, the ASHRAE standard is adopted in full. In others, some of the ASHRAE standard provisions are modified to suit local conditions.⁵

The Model Energy Code is also updated every several years. The first standard, entitled "Model Code for Energy Conservation in New Building Construction 1977" (MCEC) was based on the technical provisions of ASHRAE 90-75. The next major version, "Model Energy Code 1983", was based on ASHRAE 90A-1980. The latest Model Energy Code, which the following work will analyze, is a version released in 1989 and still maintains ASHRAE 90A as its technical basis.⁵ Thus, the Model Energy Code revisions follow revisions to the ASHRAE standard, and lag it in time by two to three years. The Model Energy Code (MEC) is adopted by reference in the Uniform Building Code (UBC).

ASHRAE 90.2P Standard

The purpose of the ASHRAE 90.2P standard is "to provide design requirements for energy efficient new residential buildings." For the building stock, it covers residential buildings of three stories or less and manufactured housing. In terms of the systems covered in the standard, it includes specifications on the building envelope, space heating equipment, space cooling equipment and domestic water heating. Furthermore, it allows for two methods of compliance: a prescriptive approach and a systems analysis approach.²

In this analysis, we model the code as solely a prescriptive code. Because the systems analysis approach allows a combination of many varied conservation strategies, we chose to simplify the approach by applying the prescriptive code to the building prototypes on a component-by-component basis. Since the systems analysis approach allows for trading undercompliance on one building component with overcompliance on another, the final energy consumption should be roughly equivalent. Our assumption that individual components would each be upgraded independently to meet the standard, while the other components maintained at current levels, also introduces some error, although we found that where the base case currently meets or exceeds the minimum standard, it is only by a small amount. As previously noted, we consider only the building envelope provisions of the ASHRAE 90 standard. The standards which apply to space heating and cooling equipment and water heating appliances and systems are included as part of the equipment code analysis under NAECA.

Table 1 provides the essential thermal requirements of ASHRAE 90.2P for single-family detached buildings in each of the climate zones under investigation. Requirements for the full range of building envelope components are given in Appendix B. The R-values and U-values are taken from nomographs and reflect the heating degree days and cooling degree hours of the local climate. For each building component two nomographs are given; one for buildings with the ducts in the conditioned space, and one for ducts outside of the conditioned space. For this analysis we chose the latter since it is the more typical construction practice. Since the requirements are more stringent when the ducts are outside the conditioned space, we may be slightly overestimating the savings due to the envelope requirements.

The ASHRAE code also gives requirements for air leakage. However, these are based on test values for building components such as windows and doors and not on whole-building or component performance estimates in real-life conditions. The method used in estimating infiltration in the base case and standards case buildings will be discussed in the following chapter.

Model Energy Code

The intent and scope of the Model Energy Code are similar to that of ASHRAE 90.2. It covers the same building types, components, and systems. Furthermore, it also allows for multiple methods of compliance: a systems approach, a component performance approach, and

Table 1. ASHRAE 90.2P Code Thermal Integrity Requirements (R-Values)*

City	HDD65**	CDH74***				Bsmt	Window	(U-value)§
			Wall	Roof†	Floor††	Wall‡	Slab‡‡	
Boston MA	5596	5358	16	28	21	16F	8(2)	0.36
New York NY (JFK)	5171	7634	16	28	21	16F	5(2)	0.36
Chicago IL	6459	6606	16	28	21	16F	8(2)	0.36
Minneapolis MN	8010	6806	24	48	21	16F	8(2)	0.36
Kansas City MO	4814	20256	16	28	21	16F	5(2)	0.36
Washington DC (Dulles)	5005	7715	16	28	21	16F	5(2)	0.36
Atlanta GA	3025	16803	16	28	14	6F	4(2)	0.87
Miami FL	198	39401	16	28	14	0.6F	4(2)	1.31
Dallas-Ft Worth TX	2420	36294	16	28	14	5F	5(2)	0.87
New Orleans LA	1490	28605	16	28	14	5F	4(2)	0.87
Denver CO	6023	5908	16	28	21	16F	8(2)	0.36
Albuquerque NM	4415	11012	16	28	21	16F	5(2)	0.36
Phoenix AZ	1444	54404	16	28	14	5F	5(2)	0.87
Seattle WA (urban)	4684	897	16	28	21	16F	5(2)	0.36
San Francisco CA	3078	216	16	28	14	6F	4(2)	0.87
Los Angeles CA (LAX)	1595	4306	16	20	14	5F	-	0.87

* All values are for ducts outside the conditioned space. R-value in hr-ft²-°F/Btu.

** HDD65 is heating degree-day, base 65°F

*** CDH74 is cooling degree-hour, base 74°F

† Roof values are for ceilings with attics.

†† Floor values are for floors over unconditioned space.

‡ Basements with exterior insulation. F = full basement height.

‡‡ Number in parentheses is depth of insulation in feet.

§ Fenestration U-value including framing.

specified acceptable practice.¹ As with the ASHRAE analysis, we model the code as solely a prescriptive code. We also consider only the building envelope provisions of the MEC, neglecting the HVAC system and infiltration requirements of the code. The HVAC requirements are considered as NAECA equipment standards. The infiltration assumptions are considered in the next chapter.

Table 2 gives the important requirements of the Model Energy Code, while the full list is given in Appendix C. These requirements are also taken from nomographs. However, the Model Energy Code requirements are based only on the heating degree days of the climate. Note that the wall requirements are an overall average of wall and window conductance. This allows tradeoffs between wall insulation, window u-value, and window and wall area.

Table 2. Model Energy Code Thermal Integrity Requirements (R-Values)

City	HDD65*	Wall**	Roof	Floor†	Bsmt Wall††	Slab‡
Boston MA	5596	8	37	20	10F	5(2)
New York NY (JFK)	5171	8	34	20	11F	5(2)
Chicago IL	6459	9	40	20	11F	5(4)
Minneapolis MN	8010	9	40	20	11F	6(4)
Kansas City MO	4814	7	32	20	10F	4(2)
Washington DC (Dulles)	5005	8	33	20	10F	5(2)
Atlanta GA	3025	6	25	20	7F	4(2)
Miami FL	198	3	20	13	-	-
Dallas-Ft Worth TX	2420	6	23	14F	7	-
New Orleans LA	1490	5	21	14	6F	-
Denver CO	6023	8	40	20	11F	5(4)
Albuquerque NM	4415	7	30	20	10F	4(2)
Phoenix AZ	1444	5	21	14	-	-
Seattle WA	4684	7	31	20	10F	4(2)
San Francisco CA	3078	6	25	20	7F	4(2)
Los Angeles CA (LAX)	1595	5	22	14	6F	-

* HDD65 is heating degree-day, base 65°F

** Overall wall R-value, including window and opaque portions.

† Floor values are for floors over unconditioned spaces.

†† F = full basement height.

‡ Number in parentheses is depth of insulation in feet.

EQUIPMENT AND APPLIANCE CODES

The National Appliance Energy Conservation Act (NAECA) was enacted in 1987 and updated by the NAECA Amendments of 1988. These provisions mandate minimum energy-efficiency standards for most major household appliances and space conditioning equipment. The Act included standards for many household appliances and equipment, and established a procedure for updating the standards in future years. The first major efficiency requirements took effect in 1990, and covered furnaces, refrigerators, freezers, room air conditioners, and water heaters. In 1992 standards will be applied to central air conditioners and heat pumps, and in 1993 new refrigerator and freezer standards will become effective. NAECA allows for periodic updates, which will likely continue into the next century.⁶

For this study, we analyze the effect of the NAECA appliance and equipment standards separately and combined. The appliance standards will not only affect baseload energy use in the building but will also impact heating and cooling energy consumption by changing the internal gains inputs into the building. The appliances considered under NAECA which are included in this study are refrigerators, freezers, dishwashers, clothes washers and dryers, ranges and ovens, and water heaters. Also included in our calculation of appliance

consumption and internal gains are televisions and other small appliances, which are not yet affected by NAECA. We also calculate electricity use for lighting, but NAECA only regulates fluorescent light ballasts which should have little effect on residential lighting loads. We also model the effect of NAECA's furnace and air conditioner standards on heating and cooling energy use. For the purposes of this study, we consider the 1990s prototypical house will meet all standards under NAECA that will be in place by 1995, rather than staggering them as they are enacted.

Typically, the standards set for these appliances will be a function of capacity or appliance size. Thus, defining one typical energy use value for all appliance sizes and types is not possible. We used average energy use values for average 1980 stock and new 1995 appliances derived from the LBL Residential Energy Model.⁷ The values used in this study are provided below in Table 3.

Table 3. Appliance Energy Use and Equipment Efficiency Improvements Under NAECA

Appliance or Equipment	Units	1980s Average	1995 NAECA	Comments
Refrigerators	kWh	1125	705	
Electric Cooking	kWh	1200	1010	
Dishwasher	kWh	200	160	Does not include water heat
Clothes Washer	kWh	110	95	Does not include water heat
Electric Dryer	kWh	900	750	
Freezer	kWh	950	475	
Gas Cooking	MMBtu	8.99	4.89	
Gas Dryer	MMBtu	4.07	3.21	
Water Heater (Gas)	EF	51.2	56.1	
Water Heater (Electric)	EF	82.9	88.0	
Gas Furnace	AFUE	73	78	
Air Conditioning	SEER	8.5	10.0	

Sources: References 6 and 7.

3

METHODOLOGY

The objective of this analysis is to evaluate the impacts of two building energy standards, ASHRAE 90.2 and the 1989 Model Energy Code, and the standards promulgated under the 1987 National Appliance Energy Efficiency Act (NAECA), on building energy use in new single-family detached housing. The procedure was based on the following steps:

1. We chose 16 base cities for the analysis based on capturing the range of climate variation and population distribution in the U.S.
2. For each of the 16 base cities, we characterized an estimated 1990s average house (conditioned square footage, window area, foundation type, etc.) from available data.
3. We defined the base case condition as the prototype house with current, or 1980s vintage, levels of thermal integrity for the building components and with average 1980s vintage appliance and equipment efficiencies. In other words, the base case represents the average condition for a house built between 1980 and 1989.
4. For each city, we compiled the required wall, ceiling, and floor R-values, foundation insulation, and window glazing levels specified in ASHRAE 90.2P and the 1989 Model Energy Code.
5. We gathered data on 1980s appliance and space-conditioning equipment efficiency and evaluated the impact of the National Appliance Energy Efficiency Act (NAECA) on appliance electricity consumption in the 1990s.
6. We developed procedures for calculating water heating and non-HVAC electric and gas energy use in the prototype buildings. We used the same procedure to calculate the internal gains inputs for DOE-2 to maintain consistency between the estimates of appliance efficiency improvements and changes in internal gains. We use estimates of 1980s average and new 1995 appliance efficiencies as the base case and NAECA code inputs, respectively.
7. We translated the base case, the ASHRAE Standard and the Model Energy Code conservation packages into DOE-2.1D input files and conducted simulations of the base buildings, and the base buildings with combinations of standards packages and appliance and equipment efficiency packages. For the ASHRAE Standard, we simulated buildings in all 16 base cities, while for the Model Energy Code, we simulated only those cities located in states which have adopted the MEC or use it as the primary basis for the state energy code (7 total).
8. We summarized the results and developed procedures to calculate electricity and gas cost savings in a few selected climates.

SELECTION OF BASE CITIES

The base cities for the analysis were those used in previous GRI residential data base projects.³ The cities were chosen to represent the regional variation in the building stock, based on the regional division of the United States given in the Department of Energy's Residential Energy Conservation Survey (RECS) data and GRI regional models. In addition, the cities represent the significant climates types within each region, with the significance determined by population and uniqueness of climate.

To determine the climate centers to use for each region, we relied on earlier work at LBL and GLOM⁸, a computer-based interactive climate agglomeration program. GLOM is a tool for aggregating Standard Metropolitan Statistical Areas (SMSAs) into climate groups based on climate characteristics and populations. Similarities in heating degree days, cooling degree days, Kt (which measures solar potential), and latent enthalpy hours, allow the clustering of SMSAs to their "closest", or most similar, climate center.

The result was a grouping of sixteen climate zones with 2 in the Northeast, 3 in the North Central, 5 in the South, and 6 in the West. The population centers of these climate groups were used as the weather locations for the simulations. For this study, we used WYEC (Weather Year for Energy Conservation) weather tapes⁹ for all cities except Chicago, New Orleans, and San Francisco. We observed anomalies in the Chicago WYEC weather tape, and WYEC was not available for New Orleans or San Francisco. The base cities are listed in Table 4.

STRUCTURAL ASSUMPTIONS

We developed an estimated average 1990 vintage prototype building for each base city from published data on building construction trends. Using this basic building form and occupancy characteristics, we varied the thermal integrity values and appliance and equipment efficiencies to model the base case and the various code requirements.

In addition to the generic building characterizations, numerous other assumptions are needed to develop complete models of prototype buildings, and used as input to the DOE-2 simulations. For example, building geometry, average window shading and window operations, and shading from adjacent buildings are not part of any data sets. We relied on our previous study of single-family buildings to develop the necessary DOE-2 inputs for these parameters as well as several others described below.¹⁰

Building Prototypes

We used the 1987 NAHB Builder's Survey¹¹ and building construction data from U.S. Census Bureau Reports, 1980 to 1989,¹² as the primary data source in developing the building prototype in each location. We also consulted the 1984 RECS data tape¹³ and a previous GRI single-family data base report¹⁴ for characteristics not available in these other sources.

Table 4. Base Cities for Building Prototypes and Climates

Census Division	Base Cities	Weather Tape	Heating Degree Days (60°F)(65°F)		Cooling Degree Days (65°F)	Cool. Degree Hours/24 (75°F)	Latent Enthalpy Days † (75°F, 0.0116 HR)
NORTHEAST							
New England	Boston	WYEC	4396	5627	699	186	48
Mid Atlantic	New York	WYEC	3784	4882	1005	256	118
NORTH CENTRAL							
East North Central	Chicago	TMY	4946	6120	969	318	121
West North Central	Minneapolis	WYEC	6733	8004	727	238	72
	Kansas City	WYEC	3799	4799	1605	632	269
SOUTH							
South Atlantic	Washington	WYEC	3184	4180	1388	403	244
	Atlanta	WYEC	2050	2965	1543	405	284
	Miami	WYEC	91	222	3922	1193	1155
West South Central	Fort Worth	WYEC	1571	2329	2495	1044	490
	New Orleans	TMY	804	1374	2503	789	719
WEST							
Mountain	Denver	WYEC	4621	5879	611	329	0
	Albuquerque	WYEC	3147	4186	1256	540	9
	Phoenix	WYEC	675	1320	3609	2144	97
Pacific	Seattle	WYEC	3583	5136	90	39	0
	San Francisco	TMY	1682	3172	66	28	0
	Los Angeles	WYEC	635	1636	428	54	6

† Latent enthalpy days are in units of (Btu-day/pound of air) and is a measure of the cumulative amount of latent heat removal from the air necessary to reach a base comfort criteria, specified here as 75°F and a humidity ratio of 0.0116.

The survey results were processed statistically and cross-referenced to three major criteria: (1) location (census region, census division, or state) (2) number of stories in the building, and (3) thermal integrity of the building shell. Thus, one building in each of the 16 base cities, which was representative of typical construction types in that location and climate zone, was defined from this analysis. To estimate the characteristics of the average building to be built in the 1990s, we relied primarily on historical data describing 1980s construction practices, and modified certain characteristics to account for trends identified in the 1980s data. In general, the average building in the 1990s was assumed to be similar to those built in the 1980s, only slightly larger.

Building Size

The most complete set of data on building size and construction type for the decade of the 1980s came from U.S. Census Bureau reports.¹² The Census reports give mean and median square foot data for new construction as well as the total number of units completed annually in each census region. They also tabulate the percentage of new homes in each construction type category: one story, two story, and split-level. From the Census Bureau data we calculated the average square footage for new buildings built between 1980-89 and the proportion of each construction type in each census region. From the NAHB survey data, we calculated the average difference in building size between the different construction types in each census region. For example, the NAHB data showed that 2-story houses were typically larger than 1-story houses by 710 ft² in the Northeast, by 720 ft² in the Midwest, by 560 ft² in the South, and by 400 ft² in the West. Using these data, it was possible to develop a typical 1-story and 2-story building size for each census region. We determined the typical construction type for each state and base city from the NAHB survey data. Using these two data sets, we selected the appropriate building construction type and square footage for the 1980s prototype building in each base city.

In Figure 1, we show the average size of new single family dwellings from several data sources for the period 1980-89. Between 1985 and 1989, average conditioned building area for new single-family dwellings increased at rates between 35 and 70 square feet per year. In addition, Figure 2 shows how construction type also changed through the decade, with the proportion of two-story houses compared to one-story increasing in all parts of the country. Because the trend towards increasing house size seems to be strong and prevalent through all areas of the country, we assumed that house size would continue to increase at approximately the same rate per decade into the 1990s. The most straightforward method for estimating the size of 1990s vintage houses is to add the 1980-89 size increase to the 1980s house size, while accounting for the change in proportion of one and two story houses. Over the decade from 1980 to 1989, we calculated overall increases in heated floor area 100 to 200 square feet between 1980 and 1989 in each census region. We added these increases to average 1980s house size to get average 1990s house size. Based on this method, the prototype house types and sizes are as given in Table 5.

Window Areas

Data on the amount of window area in new buildings is not readily available. Until 1983, the NAHB Builder Survey compiled data on window area as a percentage of floor area. However, the 1987 Survey only includes "number of windows" without reference to window size. The 1984 RECS data also contains "number of windows" as a data base entry. However, these data sources contain no information about average size of windows. We used the most recent data we identified, from the 1981 NAHB Builder Survey, which provided estimates of windows area as a percentage of floor area. These numbers were developed for a previous GRI

**Figure 1. Average Floor Area for New Construction
U.S. Single-Family Buildings, 1980-1989**

**Figure 2. Construction Type for New Construction
U.S. Single-Family Buildings, 1980-1989**

Table 5. General Specifications for Prototype Buildings

Base City	Number of Stories	Heated Floor Area (ft ²)	Window Area (ft ²)	Wall Surface Type	Foundation Type
Boston	2	2280	285	Wood	Basement
New York	2	2280	265	Wood	Basement
Chicago	2	2420	300	Aluminum	Basement
Minneapolis	2	2420	264	Wood	Basement
Kansas City	2	2420	307	Wood	Basement
Washington	2	2390	316	Aluminum	Basement
Atlanta	2	2390	289	Wood	Basement
Miami	1	1830	242	Stucco	Slab
Fort Worth	1	1830	242	Wood	Slab
New Orleans	1	1830	242	Brick	Slab
Denver	2	2290	291	Wood	Basement
Phoenix	1	1880	203	Stucco	Slab
Albuquerque	1	1880	203	Stucco	Slab
Seattle	2	2290	424	Wood	Crawl
San Francisco	2	2290	360	Stucco	Slab
Los Angeles	2	2290	360	Stucco	Slab

single-family study.¹⁴ This same percentage was assumed to apply to houses built in the 1990s.

Wall and Foundation Type

We used the most predominant wall siding material and foundation type for each base city based on 1986 and 1987 data from the NAHB.¹⁵ These were assumed to be representative of the 1990s building population as well as the 1980s. They are presented in Table 5.

Building Thermal Integrity

For the base case thermal integrity, we used thermal characteristics typical of 1980s vintage buildings taken as averages from the 1987 NAHB Builder Survey. Because this survey included only one year of data, we checked these results for each base city with the data from the surrounding states, and also with published data summaries from NAHB representing the construction years of 1986 and 1987.¹⁵

For the upgraded code buildings, we compared the ASHRAE and MEC standards with the base case. In a sense, we "upgraded" the base case building to meet the ASHRAE or MEC standards on a component basis. In cases where the base case met or exceeded the standard, the component thermal integrity remained the same. The insulation specifications for the base case prototype, and the ASHRAE and MEC standards cases, are given in Table 6.

For prototypes with basement foundations, we made assumptions about whether the basement was heated or not, and thus determined the location of the insulation. The base case is

modeled with the predominant location, and "codes" buildings with floor insulation rather than basement wall insulation. We assume that the floor insulation or basement wall insulation requirements provide roughly the same energy performance.

Table 6. Building Envelope Parameters for Base Case and Code Compliance Buildings

Base City	Base Case					ASHRAE 90.2P					1989 MEC				
	Wall (R)	Ceil (R)	Floor (R)	Glzng Layers	Fndn Insul.	Wall (R)	Ceil (R)	Floor (R)	Glzng Layers	Fndn Insul.	Wall (R)	Ceil (R)	Floor (R)	Glzng Layers	Fndn Insul.
Boston	13	27	0	2	none	16	28	19	3	none	16	37	19	2	none
New York	13	27	19	2	none	16	28	19	3	none					
Chicago	13	32	0	2	none	16	32	19	3	none					
Minneapolis	19	32	0	2	R-5 4ft	24	48	19	3	none	19	40	19	2	none
Kansas City	11	29	0	2	none	16	29	19	3	none					
Washington	13	30	19	2	none	16	30	19	3	none					
Atlanta	11	27	19	2	none	16	28	19	2	none	11	27	19	2	none
Miami	11	25	0	1	none	16	28	0	1	R-5 2ft					
Fort Worth	11	27	0	1	R-5 2ft	16	28	0	1	R-5 2ft	11	27	0	2	R-5 2ft
New Orleans	11	19	0	1	none	16	28	0	1	R-5 2ft					
Denver	13	31	11	2	none	16	31	19	3	none	13	40	19	2	none
Albuquerque	13	29	0	2	R-5 2ft	16	29	0	3	R-5 2ft	13	30	0	2	R-5 2ft
Phoenix	13	27	0	2	none	16	28	0	2	R-5 2ft	13	27	0	2	R-5 2ft
Seattle	11	32	19	2	none	16	32	19	3	none					
San Francisco	11	25	0	2	none	16	28	0	2	R-5 2ft					
Los Angeles	11	25	0	2	none	16	25	0	2	none					

Note: Building components are upgraded independently to meet ASHRAE and MEC code provisions.

Building Geometry

The prototype descriptions specified the numbers of floors, foundation type, and conditioned floor area in each prototype building, but not the architectural layout of the buildings. To transform these general descriptions into DOE-2 input files, we made assumptions about the architecture of typical single-family buildings depending on their climate and building size. The intent was not to create a detailed hypothetical building, but to capture average thermal conditions common to single-family buildings.

In calculating the width and length of the building for foundation heat loss calculations, we used a standard width of 28 feet, which is a typical roof truss dimension. This gave some unusually long dimensions for the larger prototypes. While these long dimensions do not represent any actual building, thermally the building can be thought of as pieces arranged in L-shapes or courtyard shapes. The exposed foundation length and wall area are the same for the long building as the contorted building.

In each prototype, we also modeled an attached, uninsulated two-car garage with a slab floor. The attached wall area was 180 square feet for one story and 240 square feet for two story prototypes, with a garage floor area of 460 square feet.

Infiltration

The effects of infiltration on building heating and cooling loads were simulated using the Sherman-Grimsrud model.¹⁶ This is a simplified physical model developed at LBL for air infiltration in residential buildings. The only information needed for the model is the leakage of the building. The leakage quantities, expressed in terms of *effective areas*, are the total leakage areas of the wall, floor, and ceiling. Weather parameters used in the model include mean wind speed, terrain class, and average temperature difference. The model separates infiltration into two distinct parts: stack and wind-regimes. Each regime is treated separately, with a sharp transition between the two. The model has been tested with data from several sites that differ in climate and construction methods.¹⁶

We based the assumed effective-leakage-areas for the base case on measured single-family results published in the literature and previous studies of single family building simulation.¹⁷ We assumed the base case prototype would be slightly tighter than earlier-vintage houses, with a fractional leakage area (ELF) of 0.0005. For the ASHRAE and MEC prototypes, we used the climate-specific guidelines in ASHRAE Standard 119 for air leakage to upgrade the base case prototype numbers to meet the ASHRAE standard.¹⁸ This affected only Boston, New York, Chicago, and Denver (ELF= 0.00046) and Minneapolis (ELF= 0.00033). Since the net infiltration into a building depends not only on its physical characteristics, but also on the shielding effects of its surroundings, we simulated the surrounding areas as typical suburban residential neighborhoods for all prototypes and in all base cities.

Shading

The solar gain entering a building depends on the orientation of the windows and walls, the amount of shading due to adjacent buildings, and characteristics and operations of window shades, if available. In this study, we modeled *average*, rather than *typical*, building conditions. We created an average building orientation by apportioning the amounts of walls, windows, and doors equally in the four cardinal directions. Similarly, we considered average amounts of shading from two adjacent buildings by modeling semi-transparent shading surfaces with a transmittance of 0.50 with the same height as, and located on all sides of, the prototype building. These building shades were sited 20 feet away for the suburban areas. We accounted for average window shade operations by using a shading coefficient of 0.80 during the winter and 0.60 during the summer. We distinguished between the summer and winter operating modes by adding a special Fortran function into the DOE-2 input that counted the number of cooling degree-days over the previous four days.

Foundation Heat Loss

Since the existing DOE-2 program does not adequately model the building-to-ground interface, we used a Fortran function to incorporate into DOE-2 heat fluxes calculated by a two-dimensional finite difference program developed by the Underground Space Center at the University of Minnesota. We used this program to simulate, on a daily time-step basis, the dynamic behavior of a representative one-foot vertical cross-section of the foundation and surrounding soil extending 50 feet down and 30 feet out from the building.

The finite difference simulations yielded daily fluxes at each node of the finite difference grid for the representative section. We then integrated these fluxes over the "foot-print" of the prototype buildings to produce files of average hourly fluxes through their underground surfaces for each day of the year. During the DOE-2 simulation, these fluxes are read as a function in LOADS, replacing the standard DOE-2 underground flux calculation. A more complete description of this method is given elsewhere.¹⁹

OPERATING ASSUMPTIONS

Operating assumptions refer to those actions affecting building energy use that are under the control of the occupants. These include such factors as temperature settings, night thermostat setback, window operations (i.e., opening and closing), and internal loads due to occupants and appliances. For this study, we defined the most average, rather than the optimal, operating conditions in single-family buildings based on survey data and other studies.

Thermostat Settings

We modeled each of the prototype buildings with the same thermostat settings. The heating set point in the living spaces was held at 70°F during the day, with a 8-hour setback to 64°F between 11 p.m. and 7 a.m. These assumptions correspond to data from recent RECS surveys that report the mean household temperature in units with heating controls was 69.3°F; over 64 percent of the respondents turned down their thermostats at night by 3 to 10 degrees.¹³ They also agree with information on thermostat management from other sources.^{20,21,22}

To account for natural ventilation, we modeled average window operations by building occupants as follows. During the heating season, window venting (i.e., opening windows) was assumed when indoor temperatures rose above 78°F, while during the cooling season venting was assumed down to a level of 72°F if the following criteria were met: (1) the outdoor temperature was lower than indoor temperatures and not higher than 78°F, (2) the enthalpy of outdoor air was less than that of indoor air, and (3) the cooling load that hour could be met totally through window venting. Since occupants typically do not adjust windows after going to bed, window conditions were assumed to be fixed between 11 p.m. and 7 a.m. unless indoor temperatures dropped below the heating set point.

Internal Loads

Under normal occupancy, a building collects heat, which is termed the internal load, released by people, appliances, and lighting. This internal load reduces a building's heating loads during the winter, but adds to its cooling loads during the summer. After reviewing a previous LBL study of internal loads in single-family residences,¹⁰ we developed a method for deriving internal loads values for the prototype buildings. We combined assumptions of occupancy levels, schedules, and typical occupancy heat gains; appliance saturations, appliance heat gain schedules, and typical appliance energy use; and annual lighting energy and lighting schedules.

For average occupancy levels, we assumed 3 persons per household in each prototype based on previous LBL studies¹⁰ and an analysis of the 1984 RECS tape which showed an average of 3.1 occupants per household. We used occupant heat gain of 230 Btu/hr sensible and 190 Btu/hr latent per person from ASHRAE.²³ These values are equivalent to seated, very light work. When combined with the occupant load profile, the total occupant heat gain is 15,200 Btu/day for each prototype (8360 Btu/day sensible, 6840 Btu/day latent).

The 1984 RECS data was used to develop average appliance saturations for calculating internal gains. We stratified the RECS single-family data by the nine census divisions, and calculated average appliance saturations in single-family detached dwellings. The RECS data we used did not include clothes washers, so based on clothes dryer saturations between 0.7 and 0.9 we used a saturation of 1.0 for clothes washers. We also assumed a saturation of 1.0 for ovens/ranges. For cooking fuel, RECS data give the saturation of electric and gas cooking. Electric predominates in all census divisions except for the West South Central. RECS also gives separate saturations for electric and gas dryers. In calculating *internal gains*, we assumed that clothes dryers and cooking were electric. The results also show multiple refrigerators per household. We assumed the primary refrigerator was of new vintage while the fractional number of second refrigerators were assumed to be an older variety. The appliance saturations in each census division are given in Table 7.

We combined these appliance saturations with typical appliance energy use values taken from several sources, including previous LBL work, RECS summaries, the LBL Residential Energy Model, and for the code analysis, LBL-REM estimates of new appliance energy consumption under the requirements of the 1987 National Appliance Energy Conservation Act (NAECA).^{4,7,10,24} For the base case runs, we used energy use values representative of typical 1980s stock appliances. For the NAECA case, we used appliance energy consumption values modified to meet the NAECA code where applicable. All appliance energy use assumptions are provided in Table 8. We used annual lighting energy of 1 kWh/ft², which we have used for previous single-family and multifamily studies.

Not all heat generated by appliances is input to the conditioned space. Therefore, we made assumptions about the average location of appliances and venting of the generated heat.

**Table 7. 1984 RECS Data Tape Results for Single-Family Detached Dwellings
Appliance Saturations and Types by Census Division**

Appliance	New England	Mid Atlantic	E. North Central	W. North Central	South Atlantic	E. South Central	W. South Central	Mountain	Pacific
Refrigerator	1.23	1.27	1.23	1.19	1.14	1.10	1.12	1.13	1.18
Range/Oven*	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Dishwasher	.55	.51	.34	.42	.36	.41	.45	.59	.46
Clothes Washer*	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Electric Dryer	.67	.62	.49	.65	.56	.71	.56	.68	.54
Gas Dryer	.15	.24	.30	.21	.12	.02	.22	.12	.27
FF Freezer	.10	.15	.16	.15	.17	.21	.20	.19	.21
Manual Freezer	.27	.35	.39	.46	.27	.37	.37	.33	.24
B/W TV	.67	.61	.53	.54	.60	.55	.52	.49	.49
Color TV	1.37	1.56	1.35	1.30	1.29	1.25	1.42	1.36	1.45
Refr type 1	FFF	FFF	FFF	FFF	FFF	FFF	FFF	FFF	FFF
Refr type 2	Man	Man	Man	Man	Man	FFF	FFF	Man	Man
Cooking Fuel	Elec	Elec	Elec	Elec	Elec	Elec	Gas	Elec	Elec
DHW Fuel †	Elec	Elec	Gas	Gas	Elec	Elec	Elec	Gas	Elec/Gas ‡

FFF = Full Frost Free Freezer; Auto = Automatic Defrost Freezer; Man = Manual Defrost Freezer

* - Not from RECS data

† - 1987 RECS data

‡ - Electric in North Pacific, Gas in South Pacific

We assumed all of the heat generated by the dishwasher and clothes washer and most of the dryer heat and hot water use would be dissipated outside of the dwelling. We also assumed some of the refrigerators, freezers, and water heaters would, on average, be located in unconditioned spaces. For the DOE-2 simulations, we added this portion of the internal gains to the basement, if existing, or else to the garage. Although there is little data on lighting usage behavior and locations, 10% of the lighting energy was assigned to lighting outside the conditioned space. We also assigned latent portions to those end uses which generate moisture. These assumptions are included in Table 8. Calculated internal gains values are given in Table 9.

The internal gains profiles we use in the simulations were taken from a California Energy Commission (CEC) study, which provides a daily profile for occupants, appliances, and lighting with seasonal modifications for appliances and lighting.²⁵ In total, these profiles are roughly equivalent to those used in the ASHRAE standards methodology.² The average daily profiles are shown in Figure 3. Using the CEC lighting schedule, the peak lighting load is 0.43 Watts/ft². The peak appliance loads for the prototypes range from 1.03 kW for the large prototypes to 0.79 kW for the average size 1990s prototypes. The effect of the change in appliance energy consumption for NAECA case houses is to decrease internal gains from appliances by

Table 8. Annual Appliance and Lighting Energy Use

	Units	Base Case	NAECA Case	% to Cond.	% to Uncond.	% Latent
Refrigerators						
New	kWh	1125	705	100	0	0
Old	kWh	1600	1600	15	85	0
Range/Oven	kWh	1200	1010	100	0	35
Dishwasher	kWh	200	160	0	0	0
Clothes Washer	kWh	110	95	0	0	0
Clothes Dryer	kWh	900	750	10	0	0
Freezer	kWh	950	475	50	50	0
B/W Television	kWh	100	100	100	0	0
Color Television	kWh	320	320	100	0	0
Small Appliances	kWh	300	300	100	0	0
Water Heat						
Standby	kWh	1320	1320	50	50	0
Use	kWh	2800	2800	10	0	33
Lighting	kWh/Sqft	1	1	90	0	0

about 17%, with total internal gains decreasing by about 9%.

Non-HVAC Energy Consumption Methodology

We calculated average annual non-HVAC electricity consumption per building using the same method for calculating internal gains, by combining typical appliance and lighting energy usage with the appliance saturations for each census division derived from the 1984 RECS data tape. Water heating energy was calculated separately. Since electric dryers predominated in all census divisions, we assumed all dryers were electric. The RECS data also show that cooking in new single-family buildings was with electric ranges except for in the West South Central census division. The resulting values are shown in Table 9. The non-HVAC electric and gas values includes all energy used in the household, including that which would occur outside the conditioned space.

Domestic Hot Water Methodology

Energy use for heating water is a function of several variables such as water storage temperature, inlet and outlet temperatures, air temperatures, and the rate of usage of hot water. In addition, hot water consumption is highly dependent on behavior and is often influenced by cultural and social norms. Obviously, not all of these variables can be incorporated into the estimates of weekly energy consumption for heating water. To calculate the annual hot water load, we used the methodology developed for the California Residential Building Energy Efficiency Standards,²⁶ which is mathematically identical to the DOE calculations:²⁷

Figure 3. Internal Loads Profiles for Prototype Buildings

Table 9. Estimated Non-HVAC Electric and Gas Consumption and Internal Loads

Base City	Heated Area (ft ²)	Appliance Type	Non-HVAC		Appliance Gains		Total Internal Gains	
			Electric (kWh/yr)	Gas (MMBtu/yr)	Sensible (Btu/day)	Latent (Btu/day)	Sensible (Btu/day)	Latent (Btu/day)
Boston	2280	Base Case	7088	0.00	36119	4791	63669	11633
		NAECA Case	6142	0.00	30101	4169	57650	11011
New York	2280	Base Case	7358	0.00	37333	4791	64883	11633
		NAECA Case	6346	0.00	31019	4169	58569	11011
Chicago	2420	Base Case	7310	0.00	36703	4791	65431	11633
		NAECA Case	6291	0.00	30289	4169	59017	11011
Minneapolis	2420	Base Case	7366	0.00	36798	4791	65526	11633
		NAECA Case	6306	0.00	30241	4169	58969	11011
Kansas City	2420	Base Case	7366	0.00	36798	4791	65526	11633
		NAECA Case	6306	0.00	30241	4169	58969	11011
Washington	2390	Base Case	6924	0.00	35806	4791	64281	11633
		NAECA Case	5973	0.00	29651	4169	58127	11011
Atlanta	2390	Base Case	6924	0.00	35806	4791	64281	11633
		NAECA Case	5973	0.00	29651	4169	58127	11011
Miami	1830	Base Case	6364	0.00	35806	4791	59569	11633
		NAECA Case	5413	0.00	29651	4169	53414	11011
Fort Worth	1830	Base Case	5397	8.99	36737	4791	60499	11633
		NAECA Case	4556	4.89	30279	4169	54042	11011
New Orleans	1830	Base Case	5397	8.99	36737	4791	60499	11633
		NAECA Case	4556	4.89	30279	4169	54042	11011
Denver	2290	Base Case	7049	0.00	36346	4791	63980	11633
		NAECA Case	6034	0.00	29997	4169	57631	11011
Albuquerque	1880	Base Case	6639	0.00	36346	4791	60530	11633
		NAECA Case	5624	0.00	29997	4169	54181	11011
Phoenix	1880	Base Case	6639	0.00	36346	4791	60530	11633
		NAECA Case	5624	0.00	29997	4169	54181	11011
Seattle	2290	Base Case	7074	0.00	36425	4791	64059	11633
		NAECA Case	6096	0.00	30230	4169	57864	11011
San Francisco	2290	Base Case	7074	0.00	36425	4791	64059	11633
		NAECA Case	6096	0.00	30230	4169	57864	11011
Los Angeles	2290	Base Case	7074	0.00	36425	4791	64059	11633
		NAECA Case	6096	0.00	30230	4169	57864	11011

Note: Total Internal Gains = Appliance + Lighting + Occupants

Occupant Gains = 8360 Btu/day sensible and 6840 Btu/day latent

Lighting Gains = 8.42 Btu/day-ft² sensible * heated area (ft²)

Non-HVAC energy consumption in Table 9 does not include hot water energy consumption.

One of the most uncertain parameters in the estimation of hot water loads in any building type is the average per capita water usage. For example, average measured water consumption reported in the literature varies between types of dwellings (single-family, multifamily, etc.), geographic regions, and time of year. Standard values include the DOE standard assumption for single-family residences, which is about 21.4 gal/person-day (64.2 gal/household-day) and assumes the presence of a clothes washer in each residence, and the ASHRAE standard value

$$\text{Load} = W \times C_p \times (T_T - T_M) \times 365 \text{ days} \quad [1]$$

where W = average daily hot water consumption (62.4 gallons)²⁸
 (based on 3 occupants)
 C_p = energy required per gallon heated (8.25 Btu/gal/°F)
 T_T = tank set temperature (140°F)
 T_M = city water main temperature (estimated by well temperatures)

of 62.4 gal/household-day.²⁸ A recent survey for ASHRAE of available field-measured hot water usage data showed the ASHRAE standard assumption to be valid as an average national value.²⁹ This survey also showed substantial variation between climatic locations and between seasons in each location. Thus, we also added a seasonal variation in consumption levels as a function of outdoor temperatures based on methods described in a previous study for multifamily buildings.³⁰

The estimated domestic hot water load reflects only the amount of heat necessary to raise the temperature of the water from the main to the tank temperature of 140 F. The effects of burner efficiency and standby losses are not considered in the calculation of water heating loads, but standby losses are included in the internal loads assumptions (see Table 8).

Since the average well temperature in most cities corresponds to the average air temperature, we use data from the weather tapes to estimate city water main temperature (T_M). Table 10 shows the average air and well temperatures for the base cities in this analysis.

Table 10. Average Air and Well Temperature for Base Cities

City	Annual Average Air Temp. (F)	Well Temp. (F)	City	Annual Average Air Temp. (F)	Well Temp. (F)
Albuquerque	56.6	62.0	Los Angeles	61.0	62.0
Atlanta	60.6	64.0	Miami	75.2	77.0
Boston	51.0	48.0	Minneapolis	45.1	45.0
Chicago	50.7	51.0	New Orleans	68.0	70.0
Denver	50.1	47.0	Phoenix	71.5	66.0
Fort Worth	65.1	68.0	San Francisco	55.4	58.0
New York	54.2	52.0	Seattle	50.5	52.0
Kansas City	67.6	68.0	Washington	57.1	54.0

To determine annual water heating energy, we applied the energy factor (EF, which is the estimated seasonal efficiency) determined from the DOE test procedure to the annual hot water loads calculated as shown above, for the water heating fuel which predominated in the census division where the cities are located. The energy factor is derived from a simulated usage test

under laboratory conditions, and is a reliable estimate of seasonal efficiency as long as the operating conditions of the water heater are similar to those of the DOE test procedure. For the base case, we used an energy factor of 51.2 for gas water heaters and 82.9 for electric water heaters, which are typical of 1980s vintage water heaters. For new water heaters under the NAECA standards, we use energy factors of 56.1 for gas and 88.0 for electric, both of which were taken from the LBL Residential Energy Model forecasts.⁷

HVAC Energy Use Calculation

We simulated HVAC energy use with typical gas furnace and central electric air conditioning systems. For one story buildings, the systems included a 50,000 Btu/hr furnace, a 36,000 Btu/hr air-conditioner, with a system air flow rate of 1050 cfm. For two story buildings, the systems included a 100,000 Btu/hr furnace, a 48,000 Btu/hr air-conditioner, and a system air flow rate of 2100 cfm.

We simulated two HVAC equipment efficiencies, one for 1980s vintage equipment and one with equipment meeting the NAECA requirements. The assumed efficiencies are given in Table 11. 1980 stock efficiencies are weighted averages for 1981-89 shipments taken from the LBL-REM data base. NAECA requirements are those listed in the code. The NAECA furnace standard of AFUE=78% was increased to 80% following the assumption that 2% of the jacket loss would be input to the heated space (the new AFUE test calculation assumes the jacket loss goes to the unheated space). The increase in either AFUE or SEER for space-conditioning equipment is assumed to represent an equivalent proportional increase in the steady-state efficiency. We did not assume different part loads efficiency curves or other performance parameter curves between the base case and the standards-level equipment.

Table 11. HVAC Equipment Efficiency Assumptions

Equipment	Unit	1980s Average	NAECA Requirement
Furnace	AFUE	73.0	80.0*
Air Conditioner	SEER	8.5	10.0

* Code value is 78.0%. 2% jacket loss added to heated space.

METHODS FOR CALCULATING ENERGY COST SAVINGS

For illustrative purposes, utility costs were calculated for a few base cities to provide some estimate of the potential dollar savings resulting from the various thermal or appliance codes. Four cities that represent high heating or high cooling energy use were chosen for this

exercise. The cities include Chicago and Minneapolis for gas (heating), and Atlanta and Washington for electricity (cooling). The utility costs were taken from a 1990 study sponsored by the Gas Research Institute.³¹ The data in these volumes represent rates that were in effect on January 1, 1990.

Although the GRI data include a wide variety of innovative rate structures (time-of-use, load factors, block pricing, etc.), we used the basic residential rate schedule in all cases. For gas consumption (space heating and water heating), the winter rates were used if the winter and summer schedules were different. This method may have slightly overestimated the domestic hot water heating energy costs during the summer months. For electricity use (cooling and non-HVAC electricity such as lighting and appliances), the calculation methods were somewhat more complex. In estimating the electricity rates, costs for cooling energy use were calculated separately from those for non-HVAC consumption. The summer rates were used for the cooling costs, while an average of summer and winter rates were assumed in the calculation of the non-HVAC costs. This method may underestimate any air-conditioning costs which may occur in the non-summer months.

The annual general service rates were calculated in a similar manner for gas and electricity usage except for the caveats described above. An example of the calculation procedure used to estimate the costs of gas usage in Minneapolis and electricity usage in Atlanta is shown in Table 12. This procedure considers several factors in addition to the energy charge. For example, there is usually a monthly customer charge (used as annual totals in our calculation), an energy cost adjustment or fuel cost factor charged for energy usage, taxes, and a surcharge (i.e., charge levied by utilities to recover fees or other imposts other than taxes). In some cases, the energy charge is defined by energy blocks with differing rates and/or by seasonal rates.

Table 12a. Calculation of Natural Gas Energy Costs
Gas Heating in a Minneapolis House Meeting ASHRAE 90.2

<i>Annual Energy Usage - 103.8 MMBtu</i>		
1.	Annual Customer/Minimum Charge:	\$36.00
2.	Energy Charge:	\$500.32
	Block 1 - 0.3 MMBtu x 0.00 (free)	
	Block 2- 103.5 MMBtu x 4.8384	
3.	Energy Cost Adjustment:	\$10.85
	103.8 MMBtu x .1045	
4.	Tax Adjustment:	None
	Exempt November - April	
5.	Surcharge:	\$16.09
	3.0% x (1 + 2)	
6.	Total Annual Charge:	\$563.26

Table 12b. Calculation of Electric Energy Costs
Electricity Use in Atlanta House Meeting NAECA Code

<i>Annual Electricity Usage: 12,804 kWh</i>		
1.	Annual Customer/Minimum Charge:	\$90.00
2.	Energy Charge:	\$520.63
	Block 1 - 1,300 kWh x \$.04551	
	Block 2 - 350 kWh x \$.07556	
	Block 2 - 350 kWh x \$.03907 (summer)	
	Block 3 - 10,804 kWh x \$.03845	
3.	Energy Cost Adjustment:	\$36.53
	2277 kWh x \$.016045	
4.	Tax Adjustment:	\$34.95
	5% x (1 + 2)	
5.	Surcharge:	\$5.00
	.0071726 x (1 + 2)	
6.	Total Annual Charge:	\$687.11

4

RESULTS AND DISCUSSION

In this chapter, we discuss the effects of two building energy standards, ASHRAE 90.2P and the Model Energy Code, and the National Appliance Energy Conservation Act (NAECA) and Amendments on energy use in new single-family buildings. First, we present the results for space heating energy consumption and other non-HVAC uses of natural gas. For space heating, the thermal codes are found to be more effective in reducing energy use than the improved appliance and equipment efficiencies. In addition, the effects of the NAECA on water heating energy use and cooking energy consumption are compared between regions and prototypes. Second, we present the results for standards impacts on electricity consumption, including cooling and non-HVAC electricity end uses. The provisions of the NAECA -- both appliance and equipment efficiency improvements -- are found to be more effective in reducing total cooling energy use than either the proposed ASHRAE Standard or Model Energy Code. To gain a better understanding of the causative factors, we discuss the effects of space conditioning and non-space conditioning separately. We also consider the effects of the standards for typical household appliances and HVAC equipment both separately and in combination. We also present the impacts of the combined effects of the thermal codes and the full provisions of the NAECA on heating and cooling energy use.

Third, we look in some detail at the interactions between changes in internal gains due to the NAECA appliance standards and space conditioning loads and energy usage. These results show the magnitude of the potential gains or losses in heating and cooling from appliance standards in new buildings. Fourth, we present the total energy savings for each building prototype from selected standards combinations. The results here show the relative magnitudes of standards impacts on total natural gas and electricity usage for the prototype buildings.

For this analysis, we chose specific technologies to analyze in terms of energy savings; that is, all houses have heating with gas furnaces and central electric air-conditioning equipment. We also tabulate the results for appliance energy use based on data which shows the predominant fuel used for water heating and cooking. However, in Table 13, we show the water heating energy use for each base city for both gas and electric water heaters, both under the Base Case condition and under the NAECA standard for water heaters. We provide both gas and electric energy use for each city even though the most dominant water heater is selected for the analysis described below. The dominant type represents the most prevalent type in each Census Division reported in the 1987 RECS data tape and shown in Table 7.

In Table 14, we show the simulated energy consumption and peak HVAC energy use for each of the prototype buildings in the base case and under each of the standard combinations. The cities are listed by census division. The results show the impact on end use energy consumption from the NAECA appliance standards, the NAECA equipment standards, the entire

Table 13. Annual Hot Water Use and Water Heat Energy by Fuel and Location

City	Annual Average Hot Water Use (Gal/Day)	Annual Load (MMBtu/yr)	DHW Gas Use (MMBtu/yr)		DHW Electricity Use (kWh/yr)	
			Old	New	Old	New
Boston	64.3	17.81	34.78	31.73	6297	5929
New York	62.8	16.63	32.49	29.64	5882	5539
Chicago	64.4	17.27	33.72	30.76	6105	5749
Minneapolis	67.1	19.18	37.47	34.18	6783	6387
Kansas City	61.9	16.03	31.30	28.55	5666	5336
Washington	61.4	15.90	31.06	28.33	5623	5295
Atlanta	59.8	13.68	26.71	24.37	4836	4554
Miami	52.9	10.03	19.60	17.87	3547	3340
Fort Worth	57.6	12.50	24.41	22.27	4419	4161
New Orleans	56.3	11.86	23.17	21.13	4194	3950
Denver	64.7	18.12	35.39	32.28	6407	6033
Albuquerque	61.6	14.48	28.28	25.80	5119	4821
Phoenix	54.6	12.17	23.78	21.69	4304	4053
Seattle	64.5	17.10	33.39	30.46	6045	5692
San Francisco	62.2	15.36	30.00	27.37	5431	5115
Los Angeles	59.6	13.99	27.33	24.93	4947	4659

Gas: Old Energy Factor = 0.5120, New Energy Factor = 0.5613

Electric: Old Energy Factor = 0.8287, New Energy Factor = 0.88

NAECA standard set, each of the envelope standards, and the combined envelope and NAECA standards. The numbers in the table are discussed in the following sections. In Appendix A, we also present the heating and cooling *loads* for each of these standard conditions; that is, the heating and cooling requirements without considering the equipment efficiencies.

STANDARDS IMPACTS ON NATURAL GAS CONSUMPTION

In this section we describe the impact of the standards on annual natural gas consumption and peak natural gas usage for space heating. We consider two major end uses; space heating and non-HVAC gas, which includes water heating and cooking.

Effects on Gas Space Heating Consumption

For most locations, the space heating energy consumption in the the single-family prototypical houses is significantly reduced by the thermal envelope requirements found in MEC and ASHRAE. The level of energy savings is greater for the ASHRAE standard than for the MEC, and is generally greater in colder climates, both on an absolute and percentage basis. In Figure 4, the thermal code cases are compared to the base case condition for gas space heating. As shown in Table 14, the ASHRAE 90 Standard is more effective in reducing heating energy

Table 14. End Use Energy Consumption Under Efficiency Standard Combinations

City and Standards Case	Natural Gas Consumption (MMBtu/yr)			Electricity Consumption (kWh/yr)			Peak Heat	Peak Cool
	Heat	Appliance†	Total	Cool	Appliance†	Total	(kBtu/hr)	(kW)
Boston								
Base Case	95.9	0.0	95.9	1481	13385	14866	61.6	3.4
NAECA Appliance	97.8	0.0	97.8	1450	12071	13521	61.6	3.3
NAECA Equipment	87.5	0.0	87.5	1335	13385	14720	56.2	2.9
NAECA Combination	89.2	0.0	89.2	1310	12071	13381	56.2	2.8
ASHRAE	69.9	0.0	69.9	1558	13385	14943	55.7	3.3
ASHRAE + NAECA	65.3	0.0	65.3	1364	12071	13435	50.1	2.7
MEC	78.2	0.0	78.2	1624	13385	15009	59.4	3.4
MEC + NAECA	72.8	0.0	72.8	1416	12071	13487	53.5	2.9
New York								
Base Case	68.8	0.0	68.8	1724	13240	14964	49.8	2.6
NAECA Appliance	70.5	0.0	70.5	1668	11885	13553	49.1	2.5
NAECA Equipment	62.8	0.0	62.8	1533	13240	14773	45.5	2.2
NAECA Combination	64.3	0.0	64.3	1485	11885	13370	44.8	2.2
ASHRAE	57.5	0.0	57.5	1653	13240	14893	46.2	2.4
ASHRAE + NAECA	53.9	0.0	53.9	1413	11885	13298	40.8	2.0
Chicago								
Base Case	103.9	33.7	137.6	1999	7310	9309	67.2	3.4
NAECA Appliance	105.9	30.8	136.6	1949	6291	8240	67.9	3.4
NAECA Equipment	94.8	33.7	128.5	1776	7310	9086	61.3	2.9
NAECA Combination	96.6	30.8	127.4	1734	6291	8025	61.9	2.9
ASHRAE	76.5	33.7	110.2	2137	7310	9447	59.1	3.3
ASHRAE + NAECA	71.3	30.8	102.1	1842	6291	8133	53.9	2.8
Minneapolis								
Base Case	107.5	37.5	144.9	1473	7366	8839	56.4	2.7
NAECA Appliance	109.6	34.2	143.7	1425	6306	7731	56.4	2.6
NAECA Equipment	98.1	37.5	135.5	1331	7366	8697	51.5	2.3
NAECA Combination	100.0	34.2	134.1	1291	6306	7597	51.5	2.3
ASHRAE	69.6	37.5	107.0	1639	7366	9005	47.6	2.8
ASHRAE + NAECA	65.2	34.2	99.3	1409	6306	7715	42.8	2.4
MEC	89.1	37.5	126.6	1759	7366	9125	54.2	3.1
MEC + NAECA	83.1	34.2	117.3	1527	6306	7833	49.5	2.6
Kansas City								
Base Case	71.9	31.3	103.2	3131	7366	10497	57.3	3.4
NAECA Appliance	73.5	28.5	102.0	3041	6306	9347	56.6	3.3
NAECA Equipment	65.6	31.3	96.9	2730	7366	10096	52.3	2.9
NAECA Combination	67.1	28.5	95.6	2654	6306	8960	51.6	2.8
ASHRAE	49.0	31.3	80.3	3327	7366	10693	53.6	3.2
ASHRAE + NAECA	45.9	28.5	74.5	2799	6306	9105	47.6	2.7
Washington								
Base Case	62.6	0.0	62.6	2627	12547	15174	60.8	3.1
NAECA Appliance	64.0	0.0	64.0	2543	11268	13811	59.3	3.0
NAECA Equipment	57.1	0.0	57.1	2299	12547	14846	55.5	2.7
NAECA Combination	58.4	0.0	58.4	2228	11268	13496	54.2	2.6
ASHRAE	51.3	0.0	51.3	2508	12547	15055	56.4	2.9
ASHRAE + NAECA	48.1	0.0	48.1	2132	11268	13400	50.8	2.4

† Appliance energy includes domestic water heating and cooking of appropriate fuel for each location.

Table 14. End Use Energy Consumption Under Efficiency Standard Combinations

City and Standards Case	Natural Gas Consumption (MMBtu/yr)			Electricity Consumption (kWh/yr)			Peak Heat	Peak Cool
	Heat	Appliance†	Total	Cool	Appliance†	Total	(kBtu/hr)	(kW)
Atlanta								
Base Case	38.2	0.0	38.2	2716	11760	14476	52.2	2.7
NAECA Appliance	39.3	0.0	39.3	2613	10527	13140	51.4	2.7
NAECA Equipment	34.9	0.0	34.9	2366	11760	14126	47.6	2.3
NAECA Combination	35.8	0.0	35.8	2277	10527	12804	46.9	2.3
ASHRAE	33.5	0.0	33.5	2678	11760	14438	51.4	2.7
ASHRAE + NAECA	31.4	0.0	31.4	2240	10527	12767	45.6	2.2
MEC	38.2	0.0	38.2	2716	11760	14476	52.2	2.7
MEC + NAECA	35.8	0.0	35.8	2277	10527	12804	46.9	2.3
Miami								
Base Case	2.9	0.0	2.9	5203	9911	15114	31.2	2.4
NAECA Appliance	3.0	0.0	3.0	4971	8753	13724	31.3	2.3
NAECA Equipment	2.7	0.0	2.7	4450	9911	14361	28.4	2.0
NAECA Combination	2.8	0.0	2.8	4252	8753	13005	28.5	2.0
ASHRAE	2.4	0.0	2.4	5113	9911	15024	29.3	2.3
ASHRAE + NAECA	2.3	0.0	2.3	4171	8753	12924	26.8	1.9
Fort Worth								
Base Case	38.5	9.0	47.5	3589	9816	13405	44.8	3.2
NAECA Appliance	39.7	4.9	44.6	3463	8717	12180	44.9	3.2
NAECA Equipment	35.2	9.0	44.2	3104	9816	12920	40.9	2.8
NAECA Combination	36.2	4.9	41.1	2997	8717	11714	41.0	2.7
ASHRAE	36.0	9.0	45.0	3517	9816	13333	43.2	3.2
ASHRAE + NAECA	33.9	4.9	38.8	2932	8717	11649	39.5	2.7
MEC	26.5	9.0	35.4	3341	9816	13157	36.7	2.9
MEC + NAECA	25.1	4.9	30.0	2778	8717	11495	33.6	2.4
New Orleans								
Base Case	21.5	9.0	30.5	2976	9591	12567	40.3	2.5
NAECA Appliance	22.4	4.9	27.3	2840	8506	11346	39.6	2.5
NAECA Equipment	19.6	9.0	28.6	2571	9591	12162	36.8	2.1
NAECA Combination	20.4	4.9	25.3	2455	8506	10961	36.1	2.1
ASHRAE	18.8	9.0	27.8	2833	9591	12424	38.8	2.4
ASHRAE + NAECA	17.9	4.9	22.8	2332	8506	10838	34.8	2.0
Denver								
Base Case	62.7	35.4	98.0	1605	7049	8654	57.8	2.6
NAECA Appliance	64.2	32.3	96.5	1561	6034	7595	57.0	2.5
NAECA Equipment	57.2	35.4	92.6	1434	7049	8483	52.7	2.2
NAECA Combination	58.6	32.3	90.9	1397	6034	7431	52.0	2.2
ASHRAE	48.3	35.4	83.7	1507	7049	8556	54.1	2.4
ASHRAE + NAECA	45.4	32.3	77.7	1309	6034	7343	48.0	2.0
MEC	59.2	35.4	94.6	1596	7049	8645	57.0	2.6
MEC + NAECA	55.5	32.3	87.8	1388	6034	7422	51.4	2.2

† Appliance energy includes domestic water heating and cooking of appropriate fuel for each location.

Table 14. End Use Energy Consumption Under Efficiency Standard Combinations

City and Standards Case	Natural Gas Consumption (MMBtu/yr)			Electricity Consumption (kWh/yr)			Peak Heat	Peak Cool
	Heat	Appliance†	Total	Cool	Appliance†	Total	(kBtu/hr)	(kW)
Albuquerque								
Base Case	39.7	28.3	68.0	1366	6639	8005	39.9	1.9
NAECA Appliance	41.1	25.8	66.9	1307	5624	6931	39.8	1.8
NAECA Equipment	36.2	28.3	64.5	1217	6639	7856	36.4	1.6
NAECA Combination	37.5	25.8	63.3	1167	5624	6791	36.3	1.5
ASHRAE	33.4	28.3	61.7	1302	6639	7941	37.1	1.7
ASHRAE + NAECA	31.8	25.8	57.6	1108	5624	6732	33.8	1.5
MEC	39.4	28.3	67.7	1359	6639	7998	39.9	1.8
MEC + NAECA	37.2	25.8	63.0	1159	5624	6783	36.3	1.5
Phoenix								
Base Case	11.4	23.8	35.2	5530	6639	12169	33.2	4.1
NAECA Appliance	12.1	21.7	33.8	5378	5624	11002	33.4	4.1
NAECA Equipment	10.4	23.8	34.2	4748	6639	11387	30.3	3.5
NAECA Combination	11.0	21.7	32.7	4619	5624	10243	30.5	3.5
ASHRAE	10.7	23.8	34.5	5450	6639	12089	32.4	4.1
ASHRAE + NAECA	10.3	21.7	32.0	4548	5624	10172	29.8	3.5
MEC	11.4	23.8	35.2	5530	6639	12169	33.2	4.1
MEC + NAECA	11.0	21.7	32.7	4619	5624	10243	30.5	3.5
Seattle								
Base Case	85.6	0.0	85.6	1047	13119	14166	63.1	3.3
NAECA Appliance	87.4	0.0	87.4	1029	11788	12817	63.1	3.2
NAECA Equipment	78.1	0.0	78.1	972	13119	14091	57.6	2.8
NAECA Combination	79.8	0.0	79.8	957	11788	12745	57.6	2.7
ASHRAE	64.4	0.0	64.4	970	13119	14089	55.6	3.0
ASHRAE + NAECA	60.4	0.0	60.4	892	11788	12680	50.8	2.5
San Francisco								
Base Case	41.7	30.0	71.7	633	7074	7707	43.0	3.0
NAECA Appliance	43.0	27.4	70.4	629	6096	6725	43.1	3.0
NAECA Equipment	38.0	30.0	68.0	607	7074	7681	39.3	2.6
NAECA Combination	39.3	27.4	66.6	604	6096	6700	39.4	2.5
ASHRAE	33.0	30.0	63.0	612	7074	7686	40.3	2.9
ASHRAE + NAECA	31.2	27.4	58.6	583	6096	6679	36.9	2.4
Los Angeles								
Base Case	19.5	27.3	46.9	861	7074	7935	40.1	4.1
NAECA Appliance	20.4	24.9	45.3	836	6096	6932	40.3	4.1
NAECA Equipment	17.8	27.3	45.2	787	7074	7861	36.6	3.5
NAECA Combination	18.6	24.9	43.5	766	6096	6862	36.8	3.5
ASHRAE	15.1	27.3	42.5	838	7074	7912	37.1	3.9
ASHRAE + NAECA	14.5	24.9	39.4	729	6096	6825	34.1	3.3

† Appliance energy includes domestic water heating and cooking of appropriate fuel for each location.

use than is the Model Energy Code in all but Fort Worth. For the ASHRAE Standard, the greatest savings (35% or 37.9 MMBtu/yr) are found in Minneapolis. In the other colder climates, such as Boston, Chicago, Kansas City, Denver and Seattle, the thermal requirements of ASHRAE 90 reduce heating energy use by an average of 22 MMBtu/yr, or 27%. The ASHRAE Standard also reduces peak gas usage for space heating. The range of peak savings is 2-16%. The greatest peak savings are found in Minneapolis (8.8 kBtu/hr) and Chicago (8.1 kBtu/hr).

In Fort Worth, the Model Energy Code will save about 31% (12.0 MMBtu) of the annual gas space heating consumption. However, this appears to be a special condition. The typical percentage savings for locations where the MEC requirements challenge current building practices are 17 to 18% in Minneapolis and Boston, respectively. The savings in Fort Worth are related to the specific requirements of the Model Energy Code. The ASHRAE Standard requires an R-28 ceiling, R-16 wall, single glazed windows, and R-5(2 ft deep) slab-on-grade foundations, while the MEC requires an R-23 ceiling, an overall wall thermal value of R-6, and R-6 insulation on the slab. The tradeoff between window and wall insulation levels leads to greater requirements in the Fort Worth house, and in the Fort Worth climate will save an additional 9.5 MMBtu/yr above the ASHRAE standard.

The space heating effects of the NAECA are shown in Figure 5, as well as in Table 14. The NAECA appliance standards effect space heat consumption by reducing internal gains, and thus will increase the heating load during the months where heating is required. Over the range of climates analyzed here, the package of efficiency improvements in typical residential appliances under the NAECA standards will increase heating energy use between 0.1 and 2 MMBtu/yr, or between 2 and 6%. These changes are small compared to the overall total space heating consumption. On the other hand, improved furnace efficiency required under NAECA, or the NAECA equipment standards, shows an annual savings of 9% in all locations, and is the direct result of an increase in the minimum AFUE of natural gas furnaces. This 9% improvement results in annual savings of over 9 MMBtu in Minneapolis and Chicago, and 8 MMBtu in Boston. The average gas peak savings resulting from improved equipment efficiencies is also found to be 9%. The greatest peak space heat savings, 5.9 kBtu/hr, are found in Chicago.

The space heating savings of the equipment standards under NAECA more than offset the increased space heating from the appliance standards. The combined effect of NAECA is a savings in space heating consumption of 3% in warmer climates to 7% in the colder climates. Peak heating energy use is also reduced by the combined NAECA standards, ranging from 8 to 11%.

The combined effects of the thermal codes and the NAECA provide the greatest impact on annual heating energy use, as shown in Figure 6. The savings from the NAECA standards slightly reduce the potential savings from the envelope standards by a few percentage points. The estimated annual space heating reduction ranges from 10% (1.1 MMBtu/yr) in Phoenix to 39% (42.3 MMBtu/yr) in Minneapolis. Boston and Chicago also show significant savings in

Figure 4. Space Heating Gas Use with Envelope Standards

Figure 5. Space Heating Gas Use with NAECA Standards

Figure 6. Space Heating Gas Use with Combination Standards

Figure 7. Appliance Gas Use with NAECA Standards

gas space heating of 30.6 MMBtu/yr (32%) and 32.6 MMBtu/yr (31%), respectively. The peak space heating savings as given in Table 14 range from 10% (3.4 kBtu/hr) in Phoenix to 24% (13.6 kBtu/hr) in Minneapolis. Substantial peak savings are also found in Chicago (13.3 kBtu/hr), Seattle (12.3 kBtu/hr), and Boston (11.5 kBtu/hr) as a result of the combined requirements of ASHRAE and NAECA. While the savings are greater with ASHRAE and NAECA than with the MEC and NAECA from stronger thermal requirements, the gas savings with the MEC and NAECA combination are quite substantial in Minneapolis (24.4 MMBtu/yr) and Boston (23.1 MMBtu/yr). The greatest peak savings for the combined MEC and NAECA are found in Fort Worth (25% or 11.2 kBtu/hr).

Effects on Appliance Gas Use

The only end uses considered under the appliance end uses are water heating and cooking. We show these impacts in Figure 7. For Fort Worth and New Orleans, the savings are from improvements to the gas cooking end use under NAECA which eliminated the standing gas pilot on stoves and ovens. For the other cities where gas appliance data are shown, all of the energy use is for water heating. The water heater standards provide savings in water heating energy use of approximately 9% across all locations, which is a direct result of improvements in the water heating Energy Factor (EF) from 51.2 to 56.1 as required under NAECA.

STANDARDS IMPACTS ON ELECTRICITY CONSUMPTION

In this section we describe the effects of the codes on annual electricity consumption and peak electricity use for cooling. As in the case of natural gas usage, we consider two major end uses; cooling and non-HVAC electricity, which includes lighting, water heating, and other appliances.

Effects on Cooling Energy Consumption

The energy-related effects of the thermal and appliance standards on the cooling energy use are very different from those of the heating energy use summarized above (see Table 14 for energy impacts and Appendix A for the load impacts). The most important difference between standard impacts on cooling as compared to heating is that the provisions of the NAECA generally result in greater cooling savings than do the thermal requirements of the ASHRAE 90 Standard and Model Energy Code.

As shown in Figure 8, the envelope codes had small, yet varied, effects on space cooling. The savings are greatest in the south and west, and negative in the north and midwest. The range of annual space cooling energy savings for the ASHRAE Standard are 5% to -6% with a maximum savings of 143 kWh/yr in New Orleans. In some climates, namely Boston, Chicago, Kansas City, and Minneapolis, the ASHRAE Standard actually increases electricity used for cooling compared to the base case condition. This increase in space cooling ranges from +138 kWh/yr in Chicago to +196 kWh/yr in Kansas City. These energy penalties occur in climates

Figure 8. Cooling Electricity Use with Envelope Standards

Figure 9. Cooling Electricity Use with NAECA Standards

Figure 10. Cooling Electricity Use with Combination Standards

Figure 11. Appliance Electricity Use with NAECA Standards

with colder winters, but with some cooling energy demand during the summer. This increase in cooling energy use is due to the change in balance point temperature that the ASHRAE thermal standard creates. That is, as the building's envelope becomes tighter in these colder climates, which is a beneficial feature during the winter months, it can also result in greater demand for cooling energy during the summer periods. The effects of the thermal codes on peak cooling with electricity are also quite small. In the typical case, the envelope standards shave 0.1 to 0.2 kW from the peak.

As with the calculations of natural gas usage, the effects of appliance changes are distinguished from those for the air-conditioner's efficiency (SEER, or Seasonal Energy Efficiency Rating), and are shown in Figure 9. In all cases, the effect of improved efficiencies for space cooling equipment is to reduce annual cooling electricity usage by 15-18% in the warm climates, leading to significant energy savings in Phoenix (780 kWh), Miami (750 kWh), and Fort Worth (485 kWh). The cooling savings from appliance efficiency improvements, which result in decreased internal gains, are relatively small, and range from 1-4%. The greatest annual cooling savings from the decreased internal gains are in Miami (230 kWh), Phoenix (150 kWh), New Orleans (130 kWh), and Fort Worth (130 kWh). The combined appliance and equipment efficiency improvements have significant savings in annual space cooling energy use. The hot climates showed the highest potential annual savings: Phoenix (910 kWh), Miami (950 kWh), Fort Worth (590 kWh), New Orleans (520 kWh), and Kansas City (480 kWh).

Improvements in appliance efficiencies, or decreases in internal gains, have a negligible impact on electric cooling peaks, but improved cooling equipment efficiencies reduce peak electricity demand by 0.3-0.6 kW, with the greatest savings in Phoenix, Boston, and Kansas City. In each city, the full provision of the NAECA resulted in a peak savings of 0.6 kW (about 18%).

The combined electricity savings for cooling from thermal envelope and the NAECA standards are greater than those from the individual measures, and are shown in Figure 10. These savings range from 22% (644 kWh/yr) in New Orleans, to 20% (1030 kWh/yr) in Miami and 18% (980 kWh/yr) in Phoenix. Net cooling electricity savings are even possible in those climates that have increased cooling demands from the envelope standards because of the improved equipment efficiencies. The combined thermal standards and appliance and equipment standards are also effective in reducing peak energy use by 0.4 to 0.7 kW.

Effects on Non-HVAC Electricity Consumption

The effects of the standards on non-HVAC electricity use are determined by the type of domestic hot water system (natural gas or electric), the hot water loads, appliance saturations, and the type of cooking fuel. As shown in Figure 11, the savings from the improved appliance efficiency range from 980 kWh in Los Angeles, with gas water heat, to 1360 kWh in New York, with electric water heat. The warmer cities, such as Miami and Phoenix, do not have as

much savings in appliances because in Miami, the water heating load is smaller due to warmer incoming cold water temperature is greater, while in Phoenix, we assume gas water heating.

SUMMARY OF INTERNAL GAINS INTERACTIONS

By simulating the reduced internal gains from appliances under the NAECA standards, we are able to quantify the effects of improved appliance efficiency on heating and cooling loads in new single family buildings. A summary of the impacts are presented in Table 15. The impact of reduced gains on the heating or cooling load is related to the length of the heating or cooling season. Hence, these results apply only to new buildings with these levels of thermal integrity. Since these buildings are new, and relatively well-insulated, the heating and cooling seasons are typically shorter than older buildings. In older buildings, the impact of changes in internal gains would be greater than those shown here.

Figure 12 shows the fractional change in heating and cooling loads given a unit change in internal gains. The cities are ranked in order from left to right of decreasing base case heating energy consumption. In Minneapolis about 60% of the reduction in heat gain appears as increased heating load, while only 4% does so in Miami. Alternatively, 70% of the reduction in internal gains appears as reduced cooling load in Miami. Any appliance standards will thus have an obvious double benefit in cooling-dominated climates but the net energy savings are less than 100% of appliance savings in areas where heating is more important.

TOTAL HOUSE ENERGY SAVINGS

By looking at the potential energy savings across all end-uses we can understand the relative impacts the various standards may have on future energy use in the single family sector. The total potential savings for a variety of code combinations are presented in Table 16. Because the effects of the standards on household energy use are dominated by the type of domestic hot water system (natural gas or electric), appliance saturations, and the type of cooking fuel, the table is sorted by fuel type for those appliances.

Table 16 shows that in the best case, with the ASHRAE envelope measures and full provisions of NAECA, electricity savings are 1000 to 2000 kWh/year in the cities with gas water heat and 1400 to 2200 kWh/year in the cities with electric water heat, depending on the climate. The reductions in electricity consumption are dominated by the various appliance standards resulting from NAECA except in the extreme cooling climates where cooling electricity consumption becomes a significant portion of the overall electricity bill. Electricity savings can be approximated across locations as 1100 kWh/year from household appliances, 200 kWh/year from water heating where applicable, and between 0 and 700 kWh/year from cooling.

Overall, the potential savings in natural gas are dominated by space heating energy reductions (in gas heated buildings) from building envelope measures in the colder climates.

Table 15. Change in Heating and Cooling Loads and Energy Use from Changes in Internal Gains

City	Base Case		Δ Internal Gains (MMBtu/yr)	Δ Loads		Delta Energy	
	Heating (MMBtu/yr)	Cooling (kWh/yr)		Heating (MMBtu/yr)	Cooling (MMBtu/yr)	Heating (MMBtu/yr)	Cooling (kWh/yr)
Minneapolis	107.5	1473	-2.6	1.5	-0.4	2.1	-48
Chicago	103.9	1999	-2.6	1.3	-0.4	2.0	-50
Boston	95.9	1481	-2.4	1.2	-0.3	1.9	-31
Seattle	85.6	1047	-2.5	1.4	-0.2	1.8	-18
Kansas City	71.9	3131	-2.6	1.1	-0.7	1.6	-90
New York	68.8	1724	-2.5	1.2	-0.5	1.7	-56
Denver	62.7	1605	-2.5	1.1	-0.4	1.5	-44
Washington	62.6	2627	-2.5	1.1	-0.7	1.4	-84
San Francisco	41.7	633	-2.5	1.0	0.0	1.3	-4
Albuquerque	39.7	1366	-2.5	1.0	-0.5	1.4	-59
Fort Worth	38.5	3589	-2.6	0.8	-1.0	1.2	-126
Atlanta	38.2	2716	-2.5	0.7	-0.8	1.1	-103
New Orleans	21.5	2976	-2.6	0.6	-1.1	0.9	-136
Los Angeles	19.5	861	-2.5	0.5	-0.2	0.9	-25
Phoenix	11.4	5530	-2.5	0.4	-1.1	0.7	-152
Miami	2.9	5203	-2.5	0.1	-1.8	0.1	-232

Note: Cities sorted by base case heating load.

Figure 12. Change in Heating and Cooling Loads with Change in Internal Gains

ΔIG = change in internal gains; ΔHL = change in heating load; ΔCL = change in cooling load

**Table 16. Base Case Energy Use and Total House Energy Savings
from Standards Measures**

City	Base Case Energy Use		Annual Energy Savings							
	Gas (MMBtu)	Electric (kWh)	NAECA Appliance		NAECA Combined		ASHRAE+ NAECA		MEC+ NAECA	
			Gas (MMBtu)	Electric (kWh)	Gas (MMBtu)	Electric (kWh)	Gas (MMBtu)	Electric (kWh)	Gas (MMBtu)	Electric (kWh)
<i>Gas DHW/Electric Cooking</i>										
Minneapolis	144.9	8800	1.2	1100	10.8	1200	45.6	1100	27.6	1000
Chicago	137.6	9300	1.0	1100	10.2	1300	35.5	1200		
Kansas City	103.2	10500	1.2	1200	7.6	1500	28.7	1400		
Denver	98.0	8700	1.5	1100	7.1	1200	20.3	1300	10.2	1200
San Francisco	71.7	7700	1.3	1000	5.1	1000	13.1	1000		
Albuquerque	68.0	8000	1.1	1100	4.7	1200	10.4	1300	5.0	1200
Los Angeles	46.9	7900	1.6	1000	3.4	1100	7.5	1100		
Phoenix	35.2	12200	1.4	1200	2.5	1900	3.2	2000	2.5	1900
<i>Electric DHW/Electric Cooking</i>										
Boston	95.9	14900	-1.9	1300	6.7	1500	30.6	1400	23.1	1400
Seattle	85.6	14200	-1.8	1300	5.8	1400	25.2	1500		
New York	68.8	15000	-1.7	1400	4.5	1600	14.9	1700		
Washington	62.6	15200	-1.4	1400	4.2	1700	14.5	1800		
Atlanta	38.2	14500	-1.1	1300	2.4	1700	6.8	1700	2.4	1700
Miami	2.9	15100	-0.1	1400	0.1	2100	0.6	2200		
<i>Electric DHW/Gas Cooking</i>										
Fort Worth	47.5	13400	2.9	1200	6.4	1700	8.7	1800	17.5	1900
New Orleans	30.5	12600	3.2	1200	5.2	1600	7.7	1700		

Gas space heating and electric air conditioning assumed in all locations.

Combined equipment and appliance savings from NAECA are about 7% with and without gas water heating, whereas the combined NAECA and ASHRAE envelope measures give 20-30% savings. Savings from MEC standards, while less than for ASHRAE, are also significant in those cities where the MEC requires increased thermal integrity from current construction practices.

ENERGY COST SAVINGS

In an attempt to make the analysis more meaningful to the reader, we estimate the energy costs for a few cases. Four cities are selected to represent the monetary effects of the codes on heating and cooling energy use: Chicago and Minneapolis for heating (i.e., natural gas usage), and Atlanta and Washington D.C. for electricity consumption. The cities in our sample are chosen to have similar fuels for all appliances. In each case, the annual energy costs are

estimated for each standard condition presented in the previous section. The utility costs are taken from an earlier GRI report.³²

For several reasons these utility costs are considered broad estimates and are provided for illustrative purposes only. First, the energy use estimates from the simulations are based on "average" building characteristics and "average" building operating conditions and they may vary on a site-specific basis (i.e., between individual houses). Second, utility costs are variable, and may have changed since the publication of the GRI report. Finally, the rate schedule chosen for this analysis is only one choice out of several rate options that are available to any particular residential customer. In all cases, we selected the general rate schedule for residential customers.

As expected, the annual savings of energy costs follow the levels of avoided natural gas or electricity that results from the particular standard in question. In some cases, however, because of the utility rate structure, the implementation of a building code in one city may result in more dollar savings than would be expected from the level of energy saved. In other words, saving less energy in a city with a higher utility rate will make more impact. In every case, we compare the energy costs of a particular code to the annual costs for the base case house.

The annual cost savings for natural gas usage (space and water heating) are shown in Table 17 and Figure 13 for Minneapolis and Chicago. The estimated annual cost savings of the ASHRAE Standard are \$192 in Minneapolis and \$97 in Chicago. These results provide an example of the effects of utility costs. The natural gas savings resulting from the ASHRAE Standard are only 40% greater in Minneapolis than in Chicago (37.9 MMBtu vs. 27.4 MMBtu, respectively), yet the cost savings in Minneapolis are almost twice as great. The dollar savings for the combined effects of ASHRAE and the NAECA are \$231 in Minneapolis and \$126 in Chicago. As shown, the Model Energy Code savings in Minneapolis are comparable to the ASHRAE savings in Chicago.

The annual cost savings for electric usage are quite different from those for natural gas (see Figure 14 and Table 18). First, the dollar savings for appliances and for equipment are significantly higher than those for the thermal codes (ASHRAE or MEC). For example, the ASHRAE Standard saves about \$2-21/yr, the equipment standard saves \$20-34/yr, and the appliance standards save \$50-102/yr. In the case of electricity, the appliance measures, taken as a whole, are more effective in reducing annual electricity use (and therefore annual costs) than cooling savings from the improvements in SEER under NAECA.

The greatest annual cost savings are equated to the combination of the ASHRAE standard and the combined NAECA. The annual dollar savings in Atlanta are \$71, while the combination of ASHRAE and NAECA save \$140 in Washington, D.C. As in the case of natural gas usage, the effects of the difference in rate schedule is significant. As shown in Table 18, the annual electricity savings in Washington DC for the combined thermal and NAECA standards

Figure 13. Annual Energy Cost Savings for Natural Gas

Figure 14. Annual Energy Cost Savings for Electricity

Table 17. Annual Energy Cost Savings for Natural Gas

City and Standard Case	Space Heat (MMBtu)	Appliance Gas (MMBtu)	Total Gas (MMBtu)	Annual Costs (\$)	Annual Savings (\$)
<i>Minneapolis</i>					
Base Case	107.5	37.5	144.9	772	
NAECA Appliance	109.6	34.2	143.7	767	5
NAECA Equipment	98.1	37.5	135.5	725	46
NAECA Combined	100.0	34.2	134.1	718	54
ASHRAE	69.6	37.5	107.0	580	192
MEC	89.1	37.5	126.6	679	92
ASHRAE + NAECA	65.2	34.2	99.3	541	231
MEC + NAECA	83.1	34.2	117.3	632	140
<i>Chicago</i>					
Base Case	103.9	33.7	137.6	544	
NAECA Appliance	105.9	30.8	136.6	541	3
NAECA Equipment	94.8	33.7	128.5	512	32
NAECA Combined	96.6	30.8	127.4	508	36
ASHRAE	76.5	33.7	110.2	447	97
ASHRAE + NAECA	71.3	30.8	102.1	418	126

Table 18. Annual Energy Cost Savings for Electricity

City and Standard Case	Space Cool (kWh)	Appliance Electric (kWh)	Total Electric (kWh)	Annual Costs (\$)	Annual Savings (\$)
<i>Atlanta</i>					
Base Case	2716	11760	14476	756	
NAECA Appliance	2613	10527	13140	706	50
NAECA Equipment	2366	11760	14126	736	20
NAECA Combined	2277	10527	12804	687	69
ASHRAE	2678	11760	14438	754	2
MEC	2716	11760	14476	756	0
ASHRAE + NAECA	2240	10527	12767	685	71
MEC + NAECA	2277	10527	12804	687	69
<i>Washington</i>					
Base Case	2627	12547	15174	1165	
NAECA Appliance	2543	11268	13811	1063	102
NAECA Equipment	2299	12547	14846	1131	34
NAECA Combined	2228	11268	13496	1034	131
ASHRAE	2508	12547	15055	1154	11
ASHRAE + NAECA	2132	11268	13400	1025	140

is 6% higher than Atlanta, but the annual dollars savings are nearly twice as high.

5 CONCLUSIONS

The requirements of the two thermal standards, ASHRAE 90.2P and the Model Energy Code, and the provisions of the NAECA may affect the annual residential energy use in different ways, depending on the type of fuel and end use. In this study these effects were investigated both in isolation (i.e., ASHRAE vs. MEC; appliances vs. equipment), and in combination (ASHRAE or MEC plus appliances and equipment). Several conclusions can be drawn about the individual effectiveness of each energy code, as well as the total impact of all standards:

- The greatest annual energy savings for both natural gas and electricity are from the combination of the ASHRAE Standard and full provisions of the NAECA. In the most extreme climates, the standards can reduce space heat energy use by 31%, or 42 MMBtu for natural gas heat, and can reduce cooling energy use by up to 20%, or 1030 kWh for electric air-conditioning.
- The requirements of the combined ASHRAE Standard and the appliance and equipment provisions in NAECA also provide significant peak savings of natural gas and electricity. Gas peak savings for space heat reach 13.6 kBtu/hr (26%) and electricity peak savings for cooling reach 0.7 kW (23%).
- The ASHRAE 90 Standard has the potential to significantly decrease energy consumption for space heating, particularly in colder climates. The maximum annual gas space heat savings for ASHRAE are 37.9 MMBtu in Minneapolis, the coldest climate studied. Typical savings in colder climates are about 22 MMBtu/yr (27%). In addition, the ASHRAE standard is more effective in reducing gas space heating energy usage than the Model Energy Code in all but one location (Fort Worth), where the provisions of the Model Energy Code are slightly more stringent. In some locations, the MEC did not challenge current construction practices.
- In all locations, the appliance aspects of the NAECA minimally increase annual space heating gas use by 1-2 MMBtu (2 to 4%) because of the reduction in internal heat gains from more efficient appliances. However, these increases are more than offset by improvements in furnace efficiency under the NAECA standards, which reduce by 9% both annual and peak natural gas consumption for space heating in all climates.
- Annual gas water heating consumption is reduced by 9% (about 3 MMBtu/yr) in all locations as a result of the NAECA. Where gas cooking is assumed, the appliance code reduces annual usage by 4 MMBtu/yr.

- Appliance efficiency standards, by lowering internal heat gains, reduce cooling energy use by up to 4% in hotter climates (232 kWh in Miami).
- The equipment portion (i.e., changes in SEER) of the NAECA reduces cooling energy consumption by 10-14%, or up to 753 kWh/yr, annually in the hotter climates.
- The thermal envelope codes have a varied effect on cooling. They save up to 140 kWh/yr (5%) in the south and west, and slightly increase cooling in the north and midwest by 70 kWh to 200 kWh (up to 6%). The increase in electricity use is a result of the new balance point temperature established by the insulation levels in the colder climates.
- The non-HVAC electricity savings resulting from the NAECA are 10% to 15% of the base case appliance electricity consumption, or an annual average of about 1125 kWh. The appliance savings are greater than the cooling savings from air-conditioner equipment standards in all climates.
- Rate schedules can influence the effectiveness of the thermal and appliance standards. That is, cost savings may be greater even though the annual energy savings are not.

The overall conclusions are that new thermal envelope standards, and appliance and equipment efficiency standards can be effective in reducing annual energy use for both natural gas and electric heating, cooling, and appliance end uses, and in turn, can substantially reduce annual energy costs in many U.S. climates. The overall reductions caused by the thermal standards, the NAECA, and their combined effects will not only make the residential sector more energy efficient, but they will help the nation reduce its emissions of greenhouse gases such as carbon dioxide, which is a by-products of fossil fuel combustion and consumption.

6

REFERENCES

1. CABO 1989. *Model Energy Code (1989 edition)*. The Council of American Building Officials, Falls Church, VA.
2. ASHRAE 1990. "ASHRAE Standard: Energy Efficient Design of New Low-rise Residential Buildings. (BSR/ASHRAE 90.2p), Public Review Draft". American Society of Heating, Refrigerating, and Air-conditioning Engineers, Inc., Atlanta, GA.
3. Ritschard, R. L., J. W. Hanford, and A. O. Sezgen 1991. "Single-family Heating and Cooling Requirements: Assumptions, Methods, and Summary Report", Gas Research Institute. Report No. GRI-91/0236, Chicago, IL.
4. National Appliance Energy Conservation Act of 1987 (P.L. 100-12) and National Appliance Energy Conservation Amendments of 1988 (P.L. 100-357), Washington, DC.
5. National Conference of States on Building Codes and Standards (NCSBCS), 1988. *The Energy Directory*. NCSBCS, Herndon, VA.
6. Turiel, I., D. Berman, P. Chan, T. Chan, J. Koomey, B. Lebot, M. Levine, J. McMahon, G. Rosenquist, and S. Stoft. 1990. "U.S. Residential Appliance Energy Efficiency: Present Status and Future Directions", Proceedings of the American Council for an Energy Efficient Economy (ACEEE) 1990 Summer Study on Energy Efficiency in Buildings, Asilomar, CA.
7. McMahon, J.E. 1987. "LBL Residential Energy Model: An Improved Policy Analysis Tool", *Energy Systems and Policy*, Vol. 10, No. 1, pp. 41-71.
8. Andersson, B., W. L. Carroll, and M. R. Martin 1986. "Aggregation of U. S. Population Centers Using Climate Parameters Related to Building Energy Use". *Journal of Climate and Applied Meteorology*, Vol. 25, No. 5, May 1986.
9. Crow, L., 1984. "Weather Year for Energy Calculations". *ASHRAE Journal* 16 (6): 42-47.
10. Huang, Y.J., R. Ritschard, J. Bull, S. Byrne, I. Turiel, D. Wilson, C. Hsui and D. Foley, 1987. "Methodology and Assumptions for Evaluating Heating and Cooling Energy Requirements in New Single-family Residential Buildings. Technical Support Document for the PEAR Microcomputer Program", Lawrence Berkeley Laboratory Report 19128, Berkeley, CA.

11. NAHB National Research Center, 1989. "1987 Builder Practices Survey Data". prepared for Lawrence Berkeley Laboratory, P.O. no. 4556710, March 1, 1989.
12. U. S. Department of Commerce, Bureau of the Census, 1980-1989. "Characteristics of New Housing: 1980-1989". Current Construction Reports, series C25.
13. Energy Information Administration, 1984. *Residential Energy Consumption Survey (RECS)*. U.S. Department of Energy, Washington, D.C.
14. Bluestein, J. and H. DeLima, 1985. "Regional Characteristics and Heating/Cooling Requirements for Single-family Detached Houses." Topical Report GRI-85/164, Gas Research Institute, Chicago, IL.
15. NAHB Research Foundation, Inc. n.d. "Special NAHB Research Foundation Report". Upper Marlboro, MD.
16. Sherman, M.H. and D.T. Grimsrud, 1980. "Measurement of Infiltration Using Fan Pressurization and Weather Data", Lawrence Berkeley Laboratory Report 10892, Berkeley, CA.
17. Sherman, M.H., D.J. Wilson, and D.E. Kiel, 1984. "Variability in Residential Air Leakage". Lawrence Berkeley Laboratory Report 17587, Berkeley, CA.
18. American Society of Heating, Refrigeration and Air-conditioning Engineers (ASHRAE), 1988. "Air Leakage Performance for Detached Single-Family Residential Buildings," ANSI/ASHRAE 119-1988, Atlanta, GA.
19. Labs, K., J. Carmondy, R. Sterling, L. Shen, Y.J. Huang, and D. Parker, 1988. *Building Foundation Design Handbook*, Oak Ridge National Laboratory Report, ORNL/Sub/86-72143/1., Oak Ridge, TN.
20. Fels, M.F. and M.L. Goldberg, 1984. "With Just Billing and Weather Data, Can One Separate Lower Thermostat Settings from Extra Insulation?" In: *Families and Energy*, (Eds.) B. Morrison and W. Kempton, Institute for Family and Child Study, Michigan State University, East Lansing, MI.
21. Kempton, W. and S. Krabacher, 1987. "Thermostat Management: Intensive Interviewing Used to Interpret Instrumentation Data". In: *Energy Efficiency: Perspectives on Individual Behavior*, (Eds.) W. Kempton and M. Neiman, American Council for an Energy-Efficient Economy, Washington, DC.
22. Vine, E., 1986. "Saving Energy the Easy Way: An Analysis of Thermostat Management", *Energy* 11 (10): 977-984.

23. American Society of Heating, Refrigeration and Air-conditioning Engineers (ASHRAE), 1981. ASHRAE Handbook of Fundamentals, Atlanta, GA.
24. Energy Information Administration, 1989. *Household Energy Consumption and Expenditures 1987, Part 1: National Data*. U.S. Department of Energy, Washington, D.C.
25. California Energy Commission, 1980. "Assumptions Used with Energy Performance Computer Programs, Project Report No. 7", California Energy Commission, Sacramento, CA.
26. California Energy Commission, 1985. "Methodology for Calculating Water Heating Energy Pursuant to the Residential Building Standard (Staff Report)", California Energy Commission, Sacramento, CA.
27. U.S. Department of Energy 1985. "Code of Federal Regulations", 10: Part 430 (Energy Conservation Program for Consumer Products), pp. 58-65.
28. American Society of Heating, Refrigeration and Air-conditioning Engineers (ASHRAE), 1987. Chapter 54. Handbook of HVAC Systems and Applications, Atlanta, GA.
29. Thrasher, W.H., D.W. DeWerth, and B.R. Becker 1990. "Comparison of Collected and Compiled Existing Data on Service Hot Water Use Patterns in Residential and Commercial Establishments; Phase 1 Final Report". ASHRAE research project no. 600-RP, Atlanta, GA.
30. Ritschard, R. L. and Y.J. Huang 1989. "Multifamily Heating and Cooling Requirements: Assumptions, Methods, and Summary Results", Gas Research Institute. Report No. GRI-88/0239, Chicago, IL.
31. L.J. White, S.R. Cumbow and K.L. Sumner 1990. "Electric and Gas Rates for the Residential, Commercial, and Industrial Sectors". Gas Research Institute Report No. GRI-90/0123.1 and GRI-90-0123.2 (in two volumes), Chicago, IL.

APPENDIX A: HEATING AND COOLING LOADS TABLES

Annual and Peak Heating and Cooling Loads Under Efficiency Standards

City and Standards Case	Annual Loads				Peak Loads			
	(MMBtu/yr)		(kBtu/ft ² -yr)		(kBtu/hr)		(Btu/ft ² -hr)	
	Heating	Cooling	Heating	Cooling	Heating	Cooling	Heating	Cooling
Boston								
Base Case	63.1	7.0	27.7	3.1	44.9	26.8	19.7	11.8
NAECA Combination	64.3	6.7	28.2	2.9	44.9	26.4	19.7	11.6
ASHRAE	45.6	8.1	20.0	3.5	40.6	26.3	17.8	11.5
ASHRAE + NAECA	46.8	7.7	20.5	3.4	40.1	25.9	17.6	11.4
MEC	51.0	8.4	22.4	3.7	43.3	27.5	19.0	12.1
MEC + NAECA	52.2	8.0	22.9	3.5	42.8	27.2	18.8	11.9
New York								
Base Case	45.4	9.6	19.9	4.2	36.4	21.3	15.9	9.4
NAECA Combination	46.6	9.1	20.5	4.0	35.8	21.0	15.7	9.2
ASHRAE	37.8	9.3	16.6	4.1	33.7	20.0	14.8	8.8
ASHRAE + NAECA	39.0	8.7	17.1	3.8	32.6	19.4	14.3	8.5
Chicago								
Base Case	68.6	10.5	28.4	4.4	49.0	26.7	20.3	11.0
NAECA Combination	69.9	10.1	28.9	4.2	49.6	26.3	20.5	10.9
ASHRAE	50.2	12.3	20.7	5.1	43.2	27.0	17.8	11.1
ASHRAE + NAECA	51.4	11.8	21.2	4.9	43.2	26.5	17.8	11.0
Minneapolis								
Base Case	72.0	6.7	29.8	2.8	41.2	22.1	17.0	9.1
NAECA Combination	73.5	6.3	30.4	2.6	41.2	21.6	17.0	8.9
ASHRAE	46.1	8.4	19.1	3.5	34.8	23.7	14.4	9.8
ASHRAE + NAECA	47.5	7.9	19.6	3.3	34.2	23.2	14.1	9.6
MEC	59.3	9.0	24.5	3.7	39.6	25.3	16.3	10.4
MEC + NAECA	60.6	8.5	25.1	3.5	39.6	24.8	16.3	10.2
Kansas City								
Base Case	47.7	19.8	19.7	8.2	41.8	25.5	17.3	10.5
NAECA Combination	48.8	19.1	20.2	7.9	41.3	25.2	17.1	10.4
ASHRAE	32.1	21.8	13.2	9.0	39.2	24.5	16.2	10.1
ASHRAE + NAECA	33.0	20.9	13.7	8.6	38.1	24.2	15.7	10.0
Washington								
Base Case	40.6	17.1	17.0	7.2	44.4	26.1	18.6	10.9
NAECA Combination	41.7	16.4	17.4	6.9	43.3	25.5	18.1	10.7
ASHRAE	33.2	16.4	13.9	6.9	41.2	24.4	17.2	10.2
ASHRAE + NAECA	34.2	15.7	14.3	6.6	40.6	24.1	17.0	10.1

Effects of NAECA on building *loads* is only from changes in internal gains.

Annual and Peak Heating and Cooling Loads Under Efficiency Standards (cont.)

City and Standards Case	Annual Loads				Peak Loads			
	(MMBtu/yr)		(kBtu/ft ² -yr)		(kBtu/hr)		(Btu/ft ² -hr)	
	Heating	Cooling	Heating	Cooling	Heating	Cooling	Heating	Cooling
Atlanta								
Base Case	25.0	18.5	10.5	7.8	38.1	23.1	15.9	9.7
NAECA Combination	25.7	17.7	10.8	7.4	37.5	22.7	15.7	9.5
ASHRAE	21.8	18.2	9.1	7.6	37.5	22.4	15.7	9.4
ASHRAE + NAECA	22.5	17.4	9.4	7.3	36.5	22.0	15.3	9.2
MEC	25.0	18.5	10.5	7.8	38.1	23.1	15.9	9.7
MEC + NAECA	25.7	17.7	10.8	7.4	37.5	22.7	15.7	9.5
Miami								
Base Case	1.8	37.7	1.0	20.6	22.0	20.4	12.0	11.1
NAECA Combination	1.9	35.9	1.0	19.6	22.1	19.9	12.1	10.9
ASHRAE	1.5	37.0	0.8	20.2	20.6	19.6	11.2	10.7
ASHRAE + NAECA	1.6	35.2	0.9	19.2	20.7	19.2	11.3	10.5
Fort Worth								
Base Case	24.6	22.6	13.4	12.3	32.0	24.4	17.5	13.3
NAECA Combination	25.4	21.6	13.9	11.8	32.1	24.1	17.5	13.2
ASHRAE	22.9	22.1	12.5	12.1	30.8	23.8	16.8	13.0
ASHRAE + NAECA	23.7	21.1	13.0	11.5	31.0	23.5	16.9	12.8
MEC	16.8	21.2	9.2	11.6	26.0	22.0	14.2	12.0
MEC + NAECA	17.5	20.2	9.6	11.0	26.2	21.6	14.3	11.8
New Orleans								
Base Case	13.7	20.0	7.5	10.9	29.4	22.8	16.1	12.5
NAECA Combination	14.3	18.9	7.8	10.3	28.9	22.4	15.8	12.2
ASHRAE	11.9	18.9	6.5	10.3	28.3	22.1	15.5	12.1
ASHRAE + NAECA	12.5	17.7	6.8	9.7	27.8	21.6	15.2	11.8
Denver								
Base Case	40.9	8.7	17.9	3.8	42.2	20.9	18.4	9.1
NAECA Combination	42.0	8.3	18.3	3.6	41.6	20.5	18.2	9.0
ASHRAE	31.3	8.2	13.7	3.6	39.5	19.6	17.2	8.6
ASHRAE + NAECA	32.4	7.8	14.1	3.4	38.4	19.2	16.8	8.4
MEC	38.6	8.7	16.8	3.8	41.6	20.9	18.2	9.1
MEC + NAECA	39.7	8.3	17.3	3.6	41.1	20.5	17.9	9.0

Effects of NAECA on building *loads* is only from changes in internal gains.

Annual and Peak Heating and Cooling Loads Under Efficiency Standards (cont.)

City and Standards Case	Annual Loads				Peak Loads			
	(MMBtu/yr)		(kBtu/ft ² -yr)		(kBtu/hr)		(Btu/ft ² -hr)	
	Heating	Cooling	Heating	Cooling	Heating	Cooling	Heating	Cooling
Albuquerque								
Base Case	25.7	6.9	13.7	3.7	29.1	13.9	15.5	7.4
NAECA Combination	26.7	6.4	14.2	3.4	29.0	13.5	15.4	7.2
ASHRAE	21.5	6.5	11.5	3.5	26.9	13.1	14.3	6.9
ASHRAE + NAECA	22.5	6.1	12.0	3.2	27.0	12.7	14.4	6.8
MEC	25.5	6.8	13.6	3.6	29.0	13.8	15.4	7.3
MEC + NAECA	26.5	6.4	14.1	3.4	29.0	13.4	15.4	7.1
Phoenix								
Base Case	6.7	31.7	3.6	16.9	22.4	29.4	11.9	15.6
NAECA Combination	7.1	30.6	3.8	16.3	22.5	29.1	12.0	15.5
ASHRAE	6.2	31.1	3.3	16.6	21.8	29.1	11.6	15.5
ASHRAE + NAECA	6.6	30.0	3.5	16.0	22.0	28.8	11.7	15.3
MEC	6.7	31.7	3.6	16.9	22.4	29.4	11.9	15.6
MEC + NAECA	7.1	30.6	3.8	16.3	22.5	29.1	12.0	15.5
Seattle								
Base Case	54.6	4.3	23.9	1.9	45.4	27.1	19.8	11.8
NAECA Combination	56.0	4.1	24.4	1.8	45.6	26.5	19.9	11.6
ASHRAE	40.7	3.9	17.8	1.7	39.8	25.0	17.4	10.9
ASHRAE + NAECA	42.0	3.8	18.4	1.7	40.0	24.7	17.5	10.8
San Francisco								
Base Case	25.7	1.3	11.2	0.6	29.8	24.2	13.0	10.6
NAECA Combination	26.7	1.3	11.6	0.5	30.0	23.8	13.1	10.4
ASHRAE	20.3	1.2	8.9	0.5	27.9	23.0	12.2	10.0
ASHRAE + NAECA	21.1	1.2	9.2	0.5	28.0	22.6	12.2	9.9
Los Angeles								
Base Case	11.5	3.4	5.0	1.5	27.1	29.5	11.8	12.9
NAECA Combination	12.0	3.2	5.3	1.4	27.3	29.3	11.9	12.8
ASHRAE	8.9	3.3	3.9	1.5	25.0	28.2	10.9	12.3
ASHRAE + NAECA	9.3	3.0	4.1	1.3	25.2	27.9	11.0	12.2

Effects of NAECA on building *loads* is only from changes in internal gains.

APPENDIX B: ASHRAE 90.2P THERMAL REQUIREMENTS

ASHRAE 90.2P CODE THERMAL INTEGRITY REQUIREMENTS (R-Values)

CITY	HDD65	CDH74	1-DW	1-DO	2-DW	2-DO	3-DW	3-DO	4-DW	4-DO	5-DW	5-DO	6-DW	6-DO
Phoenix AZ	1444	54404	28	28	30	30	16	16	6	6	11	13	11	11
Los Angeles CA (LAX)	1595	4306	20	20	14	14	10	16	6	6	8	9	11	11
San Francisco CA	3078	216	20	28	22	22	16	16	6	6	11	13	11	11
Denver CO	6023	5908	28	28	30	30	16	16	13	13	13	15	11	11
Washington DC (Dulles)	5005	7715	28	28	30	30	16	16	10	13	13	15	11	11
Miami FL	198	39401	20	28	22	22	16	16	4	6	8	9	11	11
Atlanta GA	3025	16803	28	28	22	30	16	16	6	6	13	13	11	11
Chicago IL	6459	6606	28	28	30	30	16	16	13	13	13	15	11	17
New Orleans LA	1490	28605	28	28	22	22	16	16	6	6	9	11	11	11
Boston MA	5596	5358	28	28	30	30	16	16	10	13	13	15	11	11
Minneapolis MN	8010	6806	28	48	30	30	16	24	13	13	15	18	11	17
Kansas City MO	4814	20256	28	28	30	30	16	16	10	13	13	15	11	11
Albuquerque NM	4415	11012	28	28	22	30	16	16	6	13	13	13	11	11
New York NY (JFK)	5171	7634	28	28	30	30	16	16	10	13	13	15	11	11
Dallas-Ft Worth TX	2420	36294	28	28	22	30	16	16	6	6	13	13	11	11
Seattle WA (urban)	4684	897	28	28	22	30	16	16	6	13	13	13	11	11

Note: DW= ducts within the conditioned space, DO= ducts outside the conditioned space.

- 1 ceilings with attics
- 2 ceilings without attics
- 3 above-grade frame walls and band joists
- 4 above-grade concrete, masonry, or log walls w/ exterior or integral insulation
- 5 above-grade concrete, masonry, or log walls w/ interior insulation
- 6 wood frame walls adjacent to unconditioned space

Notes:

1. The wall R-values do no include thermal mass effects
2. When a city falls on the boundary between two R-value bands, the most stringent of the two values was used in this table

ASHRAE 90.2P CODE THERMAL INTEGRITY REQUIREMENTS (R-Values) [Continued]

CITY	7-DW	7-DO	8-DW	8-DO	9-DW	9-DO	10-DW†	10-DO†	11-DW	11-DO	12-DW**	12-DO*
Phoenix AZ	12	14	21	30	14	14	5F	5F	11	11	4(2)	5(2)
Los Angeles CA (LAX)	12	12	14	14	4	14	5F	5F	11	11	0	0
San Francisco CA	12	12	21	21	14	14	5F	6F	11	11	4(2)	4(2)
Denver CO	14	19	30	30	21	21	16F	16F	13	13	5(2)	8(2)
Washington DC (Dulles)	14	14	30	30	14	21	9F	16F	11	13	5(2)	5(2)
Miami FL	12	12	14	21	4	14	0.6F	0.6F	2	2	0	4(2)
Atlanta GA	12	14	21	30	14	14	5F	6F	11	11	4(2)	4(2)
Chicago IL	14	19	30	30	21	21	16F	16F	13	13	5(2)	8(2)
New Orleans LA	12	12	21	21	14	14	5F	5F	11	11	4(2)	4(2)
Boston MA	14	14	30	30	14	21	9F	16F	13	13	5(2)	8(2)
Minneapolis MN	19	19	30	30	21	21	16F	16F	13	18	8(2)	8(2)
Kansas City MO	14	14	30	30	14	21	9F	16F	11	13	5(2)	5(2)
Albuquerque NM	14	14	30	30	14	21	6F	16F	11	13	4(2)	5(2)
New York NY (JFK)	14	14	30	30	14	21	9F	16F	11	13	5(2)	5(2)
Dallas-Ft Worth TX	12	14	21	30	14	14	5F	5F	11	11	4(2)	5(2)
Seattle WA (urban)	14	14	30	30	14	21	9F	16F	11	13	4(2)	5(2)

Note: DW= ducts within the conditioned space, DO= ducts outside the conditioned space.

† F= full wall, H= half wall

* numbers in parentheses are ft

7 concrete or masonry walls adjacent to unconditioned spaces

8 wood frame floors over exterior ambient conditions

9 wood frame floors over unconditioned space (vented crawl space, basement, enclosed garage or porch)

10 below grade basement walls with exterior or integral insulation

11 below grade basement walls with interior insulation

12 slab-on-grade floor

ASHRAE 90.2P CODE THERMAL INTEGRITY REQUIREMENTS (R-Values) [Continued]

CITY	13-DW	13-DO	14-DW	14-DO	15-DW	15-DO	SC-DW	SC-DO
Phoenix AZ	8	11	5	5	1	1	0.5	0.5
Los Angeles CA (LAX)	0.6	8	3	3	1	1	0.7	0.7
San Francisco CA	8	11	5	5	1	1	0.7	0.7
Denver CO	18	18	5	5	3	3	0.7	0.7
Washington DC (Dulles)	11	18	5	5	1	3	0.7	0.7
Miami FL	0.6	8	3	5	0.8	0.8	0.5	0.5
Atlanta GA	11	11	5	5	1	1	0.7	0.7
Chicago IL	18	18	5	5	3	3	0.7	0.7
New Orleans LA	8	8	5	5	1	1	0.7	0.7
Boston MA	11	18	5	5	2	3	0.7	0.7
Minneapolis MN	18	18	5	5	3	3	0.7	0.7
Kansas City MO	11	18	5	5	1	3	0.7	0.7
Albuquerque NM	11	18	5	5	1	3	0.7	0.7
New York NY (JFK)	11	18	5	5	1	3	0.7	0.7
Dallas-Ft Worth TX	11	11	5	5	1	1	0.7	0.5
Seattle WA (urban)	11	18	5	5	1	3	0.7	0.7

Note: DW= ducts within the conditioned space, DO= ducts outside the conditioned space.

13 crawl space wall

14 non wood doors

15 fenestration including framing

SC fenestration shading coefficient

APPENDIX C: 1989 MODEL ENERGY CODE THERMAL REQUIREMENTS

MODEL ENERGY CODE THERMAL INTEGRITY REQUIREMENTS (R-Values)

CITY	HDD65	WALLS		ROOFS	HEATED SLAB	UNHEATED SLAB	FLOORS OVER UNHTD. SPACE		CRAWL WALL		BASEMENT WALL	
		A-1	A-2									
Phoenix AZ	1444	5	3	21	6	*	14		7		*	
Los Angeles CA (LAX)	1595	5	3	22	6	*	14		7		6	
San Francisco CA	3078	6	3	25	6	4	20		9		7	
Denver CO	6023	8	4	40	7	5	20		17		11	
Washington DC (Dulles)	5005	8	3	33	7	5	20		17		10	
Miami FL	198	3	3	20	*	*	13		*		*	
Atlanta GA	3025	6	3	25	6	4	20		9		7	
Chicago IL	6459	9	4	40	8	5	20		17		11	
New Orleans LA	1490	5	3	21	6	*	14		7		6	
Boston MA	5596	8	4	37	7	5	20		17		10	
Minneapolis MN	8010	9	4	40	9	6	20		17		11	
Kansas City MO	4814	7	3	32	6	4	20		16		10	
Albuquerque NM	4415	7	3	30	6	4	20		14		10	
New York NY (JFK)	5171	8	3	34	7	5	20		17		11	
Dallas-Ft Worth TX	2420	6	3	23	6	*	14		7		7	
Seattle WA (urban)	4684	7	3	31	6	4	20		14		10	

* No insulation requirements

Notes:

1. The wall R-values do not include thermal mass effects
2. A-1 buildings are detached, one- and two-family dwellings. A-2 buildings include all other residential buildings three stories or less in height.

**DATE
FILMED**

8 / 19 / 93

END