1 of 3

**Clean Coal Reference Plants:
Atmospheric CFB**

**Topical Report
Task 1**

**Lynn N. Rubow
Lawrence E. Harvey
Thomas L. Buchanan
Richard G. Carpenter
Matthew R. Hyre
Roman Zaharchuk**

Work Performed Under Contract No.: DE-AC21-89MC25177

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880**

**By
Gilbert/Commonwealth, Inc.
Engineers and Consultants
P.O. Box 1498
Reading, Pennsylvania 19603**

June 1992

**CLEAN COAL REFERENCE PLANTS
ATMOSPHERIC CIRCULATING FLUIDIZED BED COMBUSTION
REFERENCE PLANT
REPORT TABLE OF CONTENTS**

<u>Section</u>	<u>Page Number</u>
List of Figures	iv
List of Tables	vi
EXECUTIVE SUMMARY	E-1
1.0 INTRODUCTION	1-1
2.0 SUMMARY OF BASELINE PLANT AND SCALE-UP PHILOSOPHY	2-1
2.1 BASELINE PLANT DESIGN	2-1
2.1.1 Overall Plant Design	2-2
2.1.2 Description of Major Systems	2-2
2.1.3 Plant Environmental Performance	2-18
2.1.4 Problems Experienced/Overcome	2-21
2.2 SCALE-UP PHILOSOPHY	2-23
3.0 REFERENCE PLANT DESIGN DESCRIPTION	3-1
3.1 DESIGN BASIS	3-1
3.1.1 Plant Site and Ambient Design Conditions	3-1
3.1.2 Fuel and Sorbent	3-2
3.1.3 Capacity	3-2
3.1.4 Plant Life	3-2
3.1.5 Plant Availability	3-2
3.1.6 Maturity of Plant Technology	3-2
3.1.7 Steam Conditions	3-2
3.1.8 Insulation and Lagging	3-4
3.1.9 Preheating	3-4
3.1.10 Modes of Operation	3-5
3.1.11 Control Systems	3-5
3.1.12 Plant Services	3-5
3.1.13 Structures and Foundations	3-7
3.1.14 Heat Recovery	3-7
3.1.15 Codes and Standards	3-7
3.2 HEAT AND MASS BALANCE	3-8
3.3 ENVIRONMENTAL STANDARDS	3-13
3.3.1 Air Quality Standards	3-14
3.3.2 Water Quality Standards	3-14
3.3.3 Solid Waste Disposal	3-14
3.3.4 Noise	3-15

REPORT TABLE OF CONTENTS (CONT'D)

<u>Section</u>		<u>Page Number</u>
3.4	DESCRIPTION OF STEAM GENERATION SYSTEMS	3-16
3.4.1	Steam Generator and Ancillary Equipment	3-16
3.4.2	Coal Handling System	3-37
3.4.3	Limestone Handling System	3-41
3.4.4	Ash Handling System	3-43
3.5	BALANCE OF PLANT	3-47
3.5.1	Turbine Generator and Auxiliaries	3-47
3.5.2	Condensate and Feedwater Systems	3-51
3.5.3	Main, Reheat, and Extraction Steam Systems	3-57
3.5.4	Circulating Water System	3-59
3.5.5	Miscellaneous BOP Systems	3-61
3.5.6	Piping and Valves	3-65
3.6	PLANT CONTROL AND MONITORING SYSTEMS	3-67
3.6.1	Design Basis	3-67
3.6.2	Control Room	3-67
3.6.3	Automation and Operation	3-67
3.6.4	Data Gathering, Reduction and Retrieval	3-70
3.6.5	Start-Up Testing and Tuning	3-71
3.7	LAYOUT ARRANGEMENT	3-72
3.7.1	Assumptions	3-72
3.7.2	Overall Site Plan	3-72
3.7.3	Power Block - Plan	3-75
3.7.4	Power Island Cross Section	3-78
4.0	REFERENCE PLANT ECONOMIC ANALYSIS	4-1
4.1	METHODOLOGY	4-1
4.2	CAPITAL COSTS	4-3
4.2.1	Bare Erected Cost	4-3
4.2.2	Total Plant Cost (TPC)	4-7
4.2.3	Capital Cost Estimate Exclusions	4-11
4.3	OPERATING COSTS AND EXPENSES	4-12
4.3.1	Operating Labor	4-12
4.3.2	Consumables	4-13
4.3.3	Maintenance	4-15
4.4	COST OF ELECTRICITY (COE)	4-17
5.0	CONCLUSIONS AND RECOMMENDATIONS	5-1
6.0	REFERENCES	6-1

REPORT TABLE OF CONTENTS (CONT'D)

<u>Section</u>	<u>Page Number</u>
7.0 BIBLIOGRAPHY	7-1
APPENDIX A - Baseline Plant Major Equipment List	A-1
APPENDIX B - Reference Plant Major Equipment List	B-1
APPENDIX C - Reference Plant Detailed Cost Estimate	C-1

LIST OF FIGURES

<u>Figure</u>	<u>Page Number</u>
2-1 Nucla Overall Plant Flow Diagram	2-3
2-2 Nucla - Heat and Mass Balance	2-4
2-3 Pyropower Fluidized Bed Units	2-26
2-4 Typical Large Fluid Bed Units - Worldwide	2-27
3-1 Reference Plant-Heat and Mass Balance-100%	3-9
3-2 Reference Plant-Heat and Mass Balance-VWO, 5% O.P.	3-11
3-3 Pyropower Plan	3-17
3-4 Pyropower Cross Section	3-18
3-5 Air and Gas Flow Schematic	3-19
3-6 Split Loop Seal	3-25
3-7 Secondary Air System	3-27
3-8 High Pressure Air System	3-28
3-9 Steam/Water Flow	3-29
3-10 Reheat Design	3-31
3-11 Front Wall Fuel Feed System	3-33
3-12 Flyash Reinjection System	3-36
3-13 Coal Handling System Flow Diagram	3-38
3-14 Limestone Handling System Flow Diagram	3-42
3-15 Ash Handling System	3-44
3-16 Main, Reheat and Extraction Steam	3-48
3-17 Condensate, Feedwater and Circulating Water	3-49
3-18 Site Plan	3-73

3-19	Plant Layout	3-76
3-20	Plant Cross Section	3-79
4-1	Components of COE	4-20

LIST OF TABLES

<u>Table</u>	<u>Page Number</u>
2-1 Coal Fuel Analysis	2-5
2-2 Ash Mineral Analysis	2-6
2-3 Limestone Analysis	2-6
2-4 Circulating AFBC Boiler Performance Summary	2-7
2-5 Boiler Performance Test Results	2-19
3-1 Pittsburgh No. 8 Coal Analysis	3-3
3-2 Greer Limestone Analysis	3-4
3-3 Typical Design Codes and Standards	3-7
3-4 Plant Performance Summary - 100% Load	3-8
3-5 Plant Performance Summary - VWO, 5% O.P.	3-12
3-6 Applicable Environmental Regulations	3-13
3-7 Baghouse Design	3-37
4-1 Code of Direct Accounts Summary	4-4
4-2 Total Plant Cost	4-8
4-3 Circulating AFBC Cost Comparison	4-9
4-4 Operating Labor Requirements	4-14
4-5 Consumables, By-Products & Fuels Data	4-14
4-6 Maintenance Factors	4-16
4-7 Estimate Basis	4-18
4-8 Capital Investment & Revenue Requirements Summary	4-19
5-1 Economic Summary	5-1

EXECUTIVE SUMMARY

The Clean Coal Technology Demonstration Program is a government and industry cofunded technology development effort to demonstrate a new generation of innovative coal utilization processes in a series of full-scale facilities. The goal of the program is to provide the U.S. energy marketplace with a number of advanced, more efficient and environmentally responsive coal-using technologies.

The Morgantown Energy Technology Center (METC) has the responsibility for monitoring the CCT Projects within certain technology categories, which correspond to the center's areas of technology development, including atmospheric fluidized bed combustion, pressurized fluidized bed combustion, integrated gasification combined cycle, mild gasification, and industrial applications.

A measure of success in the CCT program will be the commercial acceptance of the new technologies being demonstrated. The dissemination of project information to potential users is being accomplished by producing a series of reference plant designs which will provide the users a basis for the selection of technologies applicable to their future energy requirements.

As a part of DOE's monitoring and evaluation of the CCT Projects, Gilbert/Commonwealth (G/C) has been contracted to assist in this effort by producing the design of a commercial size Reference Plant, utilizing technologies developed in the CCT Program. This report, the first in a series, describes the design of a 400 MW electric power plant, utilizing an atmospheric pressure, circulating fluidized bed combustor (ACFB) similar to the one which was demonstrated at Colorado-Ute's Nucla station, funded in Round 1 of the CCT Program. The Nucla plant was used as the basis for the 400 MWe Reference Plant design.

The Nucla project involved the installation of a 110 MWe Pyropower ACFB which was, at that time, the largest of its kind in the world. The boiler replaced three existing coal fired units which were retired. The size of the boiler was such that it provided the last critical link between small test facilities and a commercial size plant.

The plant operated for four years under Electric Power Research Institute (EPRI), Department of Energy (DOE) and Colorado-Ute sponsorship, providing operational and design data for scale-up purposes. Data showed that nearly all performance guarantees were met. Although typical startup and maintenance problems were experienced, they were not related to deficiencies in the ACFB technology and were not considered significant.

Combustion and boiler efficiencies were as expected and SO₂ and NO_x emissions were below permit levels. Databases were initiated for material-related problems and for reliability of equipment components. Three coals were tested. Section 2 provides a description of the Nucla facility, and a brief summary of operating experience.

The intent of the reference plant design effort was to portray a commercial power plant with attributes considered important to the utility industry. The logical choice for the ACFB combustor was Pyropower since they supplied the ACFB for the Nucla Project. The design used for the Reference Plant, however, is different in several significant areas such as the use of reheat, double

loop seals, internal wingwalls, pigtail nozzles, etc. The reasons for the changes are discussed in the portion of Section 3 describing the combustor.

The nominal size of the Reference Plant is 400 MWe, which is comprised of one 400 MWe turbine generator and two 200 MWe combustors. The 200 MWe combustor size was selected based on projections of future availabilities of commercial guarantees; satisfactory predicted operating availabilities; the current and projected need for units in the 400 MWe range; and the reasonableness of the size extension of similar units that are presently operating. Some ACFB plants currently in the planning process are larger (250 to 300 MWe) than the combustors proposed for this plant. However, for the purposes of this effort, it was felt that the Reference Plant should represent a commercial plant that would be built in the relatively near future with the expectation of high availability, based on significant operation of a similar size plant.

Section 3 provides a detailed description of the Reference Plant. Heat balances are shown as well as system diagrams for the major systems and plant layouts showing equipment arrangements. An equipment list is contained in the Appendix B.

To provide uniformity in comparisons of Clean Coal Technologies, a consistent design basis was applied, including the following factors:

- Plant Site and Ambient Design Conditions
- Fuel and Sorbent Characteristics
- Plant Capacity and Design Life
- Plant Availability, Approach to Redundancy
- Maturity of Plant Technology, nth Plant
- Design Steam Conditions
- Approach to Insulation and Lagging
- Preheating/Start-up Requirements
- Modes of Operation, Turndown, Minimum Load
- Control System Design Approach
- Plant Services Requirements
- Structures and Foundations, Soil Bearing Loads
- Heat Recovery Approach
- Applicable Codes and Standards

Reference Plant Design

The Reference Plant uses a 2400 psig/1000°F/1000°F single reheat steam power cycle. The high pressure turbine uses 2,867,038 lb/h steam at 2415 psia and 1000°F. The cold reheat flow is 2,603,391 lb/h of steam at 531 psia and 617°F, which is reheated to 1000°F before entering the intermediate pressure turbine section. The net plant output power, after plant auxiliary power requirements are deducted, is 400 MWe. The overall net plant (HHV) efficiency is 34.35 percent.

The Reference Plant is expected to meet all applicable Federal, State, and Local environmental standards relating to air, water, solid waste and noise. A calcium-in-the-limestone to sulfur-in-the-coal ratio of 2.5 to 1 ensures an SO₂ emission rate of less than 0.371 lb/10⁶ Btu (92% reduction). Air quality regulations concerning other compounds such as CO, CO₂ and air toxics now being considered may have an effect on the design of plants in the time frame being considered here. However, details of the end results of these considerations are not clear at the present time and are not included in this report.

Because of the increasing international concern about the greenhouse effect, the discharge of N₂O from combustion sources has gained recent attention. Fluidized beds are known to emit larger amounts of N₂O than PC boilers per unit size, primarily because of the lower combustion temperature. Reduction of N₂O can be accomplished in several ways, all of which have offsetting drawbacks or penalties. The control or reduction of N₂O has not been addressed in this design because N₂O levels are presently unregulated.

Each boiler is designed for a flow of 1,580,454 lbs. of steam per hour at 2660 psig and 1000°F at the superheater outlet. Flow at the reheat outlet is 1,430,404 lbs. of steam per hour at 543 psig and 1000°F.

The major components of the boiler system are the combustion chamber, the hot cyclone, the non-mechanical loopseal and the convection section. In the combustion chamber the bed material, with the fuel, is fluidized with primary air. Heat is transferred to the membrane water-wall tubing that forms the walls of the combustion chamber, evaporative wingwall surfaces and radiant superheat surfaces. The hot combustion gases with the entrained solids exit at the top of the combustion chamber into the hot cyclone. The cyclone separates the solids from the combustion gases and returns the solids, including any unburned solid fuel, through a non-mechanical loopseal to the combustion chamber where they mix with incoming fresh fuel. The long solids residence time at combustion temperature and the retention and continuous recirculation of the solids ensure high combustion efficiencies and sulfur capture. Coal is fed into the lower combustion chamber and the loopseals.

The lower section of the combustion chamber includes a water cooled air distribution grid and a bottom ash removal system. Primary air is supplied through the lower windbox to the distribution grid providing fluidization air flow. Secondary air entering above the bed ensures solids circulation, provides staged combustion for NO_x reduction and supplies air for continuous fines combustion in the upper part of the combustion chamber.

Flue gas and some particulate matter leave the hot cyclone collector and pass through the convection section which contains primary and final superheat, reheat and economizer banks, plus

a tubular air preheater. The flue gas then enters a reverse air baghouse where particulate matter is removed in compliance with environmental regulations. Clean flue gas is discharged to the stack via the induced-draft fan. The economizer is a bare tube, in line, horizontal serpentine type heat exchanger, arranged in multiple banks. The air heater is tubular, designed with gas over the tubes and air through the tubes.

Feedwater enters the economizer and counterflows against the flue gas, picking up heat before entering the drum. Water flows from the drum to the lower combustion chamber headers via downcomers and supply pipes. The combustion chamber is designed for complete natural circulation.

Dry, saturated steam from the drum is delivered to the convection cage walls, and then to the superheater. Heat from the flue gases is transferred to the superheated steam in multiple stages (primary and final) with attemperation between each stage. Main steam exits the outlet header of each boiler's final superheater, is headered, and delivered to the turbine generator.

Cold reheat steam from the high pressure turbine is split and directed to the reheat inlet header. Hot reheat steam flow from the reheater is also headered and sent to the intermediate pressure turbine.

The design used for the Reference Plant is improved from that used for Colorado Ute's Nucla Plant in several significant areas. The following partial list includes the more important changes and their basis. In general, changes have been made to improve reliability where operation has shown the need for modification, or to address performance in terms of carbon burnup efficiency, NO_x production, or limestone calcium utilization.

- Double loop seals will be used to allow recirculating solids to re-enter the combustor in two distinct flow streams for better distribution.
- 16 vs. 8 limestone feed points to improve contact with SO₂.
- An in-combustor omega superheat surface is designed to provide a flat surface parallel to the upward flowing gas in the combustor, thus minimizing erosion.
- A flyash reinjection system was added to optimize limestone utilization and carbon burnout.
- Refractory brick is used instead of castable or gunnite to minimize erosion.
- A cyclone configuration change to lessen reentrainment and maximize gas residence time in the cyclone has been made.
- A single piece vortex finder was added to the cyclone to prevent shortcutting and enhance particulate capture.
- The refractory interface design was changed to eliminate ash eddying and decrease erosion potential.

- Pigtail nozzles are used instead of bubblecaps to reduce backsifting of ash into the windbox.
- A change in the air supply source was made to allow initial variation in the primary/secondary air split to provide optimum heat transfer, performance, and emission characteristics for the combustor system.
- A single combustion chamber was designed instead of two.
- The rotary feed valve/pressurization of the feed system was eliminated.
- The "wrap-around" combustor superheat surface was eliminated and the backpass superheat hanger design was changed.

It is expected that the combustor design will continue to change as more operating experience is obtained, and that improved performance, reliability, and cost-competitiveness will be the result.

The balance of plant is similar to conventional PC based electric utility power plants. A seven stage regenerative feedwater heating design is used, with a deaerating feedwater heater as the 5th stage. Condenser circulating water is cooled by a mechanical draft cooling tower.

Economic Analysis

Following the design of the Reference Plant, an economic analysis was performed to provide capital and O&M costs. Section 4.0 contains this analysis and Appendix C has second level cost details. A brief summary of the costs is given below:

	<u>\$ x 1000</u>		<u>\$/kw</u>
Total Capital Requirement	552,703		1,380
Fixed O&M (1st year)		31.82 \$/kw-yr	
Variable O&M (1st year)		3.01 mills/kwh	
Total consumables (1st year)	6,583		2.89
Fuel cost (1st year)	36,217		15.88
Levelized Busbar Cost of Power		87.9 mills/kwh	

Conclusions

The Nucla Project has produced data which has confirmed the predicted performance and provided a basis for the design of future commercial ACFB based power plants. The Reference Plant illustrates one commercial design that could be built based on that experience.

It is apparent that CFB boilers are an established option for utilities considering the addition of capacity to their system, or in retrofitting existing capacity. Continued operation and improved reliability will serve to increase utility confidence in the technology.

It is recommended that the progress of CFB technology be monitored closely and that this Reference Plant design be updated as major advances occur. Parallel efforts of FBC development

are also ongoing with different versions of AFB technology. The applicability of the various designs with regard to load change, minimum load, emissions mitigation potential, combustor maximum size limitations, efficiency, and reliability should be evaluated, since each design has unique advantages. These developments should also be monitored, and comparisons made of commercial reference plant designs which are based on similar design criteria.

1.0 INTRODUCTION

The Clean Coal Technology Demonstration Program (CCT) is a government and industry cofunded technology development effort to demonstrate a new generation of innovative coal utilization processes in a series of full-scale facilities. The goal of the program is to provide the U.S. energy marketplace with a number of advanced, more efficient, and environmentally responsive coal-using technologies. To achieve this goal, a multiphased effort consisting of five separate solicitations is underway. At this time, four solicitations have been completed and the fifth solicitation is planned for 1992.

The Morgantown Energy Technology Center (METC) has the responsibility for monitoring the CCT Projects within certain technology categories, which, in general, correspond to the center's areas of technology development. Primarily the categories of METC CCT projects are: atmospheric fluid bed combustion, pressurized fluidized bed combustion, integrated gasification combined cycle, mild gasification, and industrial applications.

A measure of success in the CCT Program will be the commercial acceptance of the new technologies being demonstrated. In order to achieve this commercial acceptance it is necessary to provide the potential technology users with project information in a format which allows the technology users to translate the results from the demonstration project to their particular circumstances.

DOE is monitoring project performance and evaluating project operating results. Based on this data, technology vendor input, and in-house expertise, Gilbert/Commonwealth, Inc., was contracted by DOE/METC to assist in this effort, and has developed a 400 MWe ACFB Reference Plant design which will be comparable with other reference plants. One objective of this work is to produce a series of reference plant designs which will enable the end user to select the technologies to be applied to meet future energy requirements.

This report describes the results of the effort to design a mature, commercial power plant utilizing a technology demonstrated under the CCT program. This first report in this series is based on the atmospheric-pressure, circulating, fluidized-bed combustor (ACFB) which was demonstrated at Colorado Ute's Nucla Station. The plant design and cost estimate provided are of sufficient detail to allow potential technology users to adjust the results to their specific conditions.

2.0 SUMMARY OF BASELINE PLANT AND SCALE-UP PHILOSOPHY

The objective of the study is to produce a conceptual design of a commercial power plant utilizing the technology being developed as part of the Clean Coal Program. The basis, or Baseline Plant, of the commercial size Reference Plant described in this report is the Nucla Project, a circulating atmospheric pressure fluid bed plant funded in Round 1 of the DOE Clean Coal Technology Program. The plant described is the Nucla Plant as modified by the installation of the atmospheric fluidized bed boiler. A description of this project and the methods used to develop the basis for the Reference Plant are contained in this Section.

2.1 BASELINE PLANT DESIGN

In 1982 Colorado-Ute Electric Association (CUEA) evaluated options for upgrading the Nucla Station facility. The plant had three 12.6 MWe, stoker fired units burning local bituminous coal and was burdened with low efficiency and high operating costs.

After two years of study, a decision was made to retire the three existing boilers and install a 110 MWe circulating fluidized bed boiler. At the time of construction in 1985 this boiler was the largest of its type in the world. The Electric Power Research Institute (EPRI) assisted in preparing boiler specifications and agreed to participate in the project. In 1984 the National Rural Utilities Cooperative Finance Corporation approved a project loan of \$87 million and the Rural Electrification Administration approved the project.

In 1984, Pyropower was awarded the boiler contract. Subsequently, tests of Nucla coal and local limestone were conducted in a small scale AFBC plant to provide data for boiler design. In the spring of 1985 construction started and two years later the first coal firing began.

In October of 1987 the ongoing CUEA project was selected in the first round of the DOE Clean Coal Technology (CCT) Demonstration Program. Under the cooperative agreement between CUEA and the DOE, DOE participated in Phase 3: Operation. Over 4400 hours of operation were logged using low sulfur Colorado coals during acceptance tests which were completed in October, 1988. Performance testing began in March, 1989 and continued through March, 1991, during which high ash and high sulfur coals were tested.

The project completed the scheduled testing program in March, 1991, after operating 15,707 hours. The size of the unit is such that it provided the last critical link between small test facilities and commercial size plants.

Data from 72 tests performed on the unit showed that both SO₂ and NO_x emissions were below the permit level limits of 0.4 and 0.5 lb/10⁶ Btu respectively. Combustion efficiency ranged from 96.9% to 98.9% and boiler efficiency varied between 85.6% and 88.6%. Three coals were tested. No significant operating problems were experienced but a ten week outage occurred due to the structural damage to waterwalls when one combustion chamber overheated. Few materials-related problems were encountered during the four years of operation and a reliability monitoring database was initiated to provide data on frequency of failure for equipment components.

2.1.1 Overall Plant Design

Prior to installation of the circulating fluidized bed boiler, the Nucla plant consisted of three identical stoker boiler units, each rated at 12.6 MWe. Each boiler supplied a turbine generator at inlet conditions of 600 psig and 825°F. The existing units were all commissioned in 1959. The ACFB addition was designed to integrate the existing plant equipment into the new plant cycle. However, to improve heat rate it was decided to elevate the steam conditions. After analysis of several options, the plant was designed for throttle steam conditions of 1450 psig and 1000°F. The retrofit design incorporated the addition of a new 74 MWe steam turbine for a total plant output rating of 110 MWe. Exhaust steam from this turbine supplies steam to the three existing 12 MWe turbines. The existing stoker boilers were retired. A flow diagram for the overall plant is shown in Figure 2-1. An overall heat and mass balance is given in Figure 2-2.

2.1.2 Description of Major Systems

The following sections contain descriptions of the major systems in the plant, with most detail concentrated on the systems and equipment affected by the modifications made in the ACFB conversion.

2.1.2.1 Steam Generator and Ancillary Equipment

Pyropower Boiler

The circulating fluidized bed boiler is a coal fired, balanced draft boiler which is rated at 925,000 lb/h of superheated steam at 1510 psig and 1005°F. This fluidized bed operates in a region between that of a bubbling fluidized bed and that of a circulating fluidized bed during start-up, and then operates as a circulating bed during normal operation. Combustion and desulfurization both take place in the bed which is cooled by waterwalls. Boiler performance, design parameters, and fuel, ash, and limestone analyses are given in Tables 2-1 through 2-4.

Several features of the Pyropower boiler described herein have been modified/upgraded in more recent offerings as a result of experience operating this boiler and others like it. These changes are reflected in the conceptual commercial design report.

The boiler consists of two combustion chambers each 22 ft.-8.25 in. wide, 24 ft.-2.75 in. deep and 110 ft. high. Each combustor has three gravity coal feed ports and four pneumatic limestone feed ports. Spent bed ash is removed through two bottom ash drain ports which lead to ash coolers. The bed distributor grid floor is membrane water-cooled and slopes toward the ash drain ports. Heat transfer in the combustors is accomplished through a combination of conduction and convection from the fluidized bed to waterwall enclosures and superheaters.

Primary combustion air is introduced through bubble caps on the bottom distributor plate and through lower wall ports located on the four combustor walls. Flow is controlled to fluidize the bed and to provide a proper air-to-fuel ratio. Secondary air, which completes the combustion and reduces NO_x formation, is introduced above the primary air ports in the lower zone of the combustion chambers.

The fluidized bed is composed mostly of spent limestone, ash and calcium sulfate. Only 5 to 10 percent is unreacted limestone and unburned coal. Bed particles in the mid and upper

NUCLA - OVERALL PLANT FLOW DIAGRAM

TYPICAL OF THREE
TURBINE GENERATORS

Figure 2-1

216082.0 482001.CRA
216082.0 482001.LMOD

1/4" = 1'-0" 0' 5' 10' 15' 20'

Figure 2-2

NUCLA - HEAT AND MASS BALANCE

A COK N/A N/A

REV DATE DESG FOR BY

REVISIONS

STATUS OF DRAWING	DEFINITION
☐ APPROVED	REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.
☐ PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPTS. SUBJECT TO CHANGE.
☒ CONCEPTUAL	REPRESENTS GENERAL CONCEPTS BASED ON ASSUMPTIONS. CHANGES COULD ENSUE.

COAL FUEL REFERENCE PLANTS

MECHANICAL HEAT AND MASS BALANCE

CLEAN COAL REFERENCE PLANT STUDIES

COLORADO UTE NUCLA AFB - REFERENCE PLANT

GILBERT/COMMONWEALTH, INC.
ENGINEERING AND CONSULTANTS READ FING, PA

REVISIONS

DATE	BY	REVISION
08-27-90	COK	1
08-27-90	COK	2
08-27-90	COK	3
08-27-90	COK	4
08-27-90	COK	5
08-27-90	COK	6
08-27-90	COK	7
08-27-90	COK	8
08-27-90	COK	9
08-27-90	COK	10
08-27-90	COK	11
08-27-90	COK	12
08-27-90	COK	13
08-27-90	COK	14
08-27-90	COK	15
08-27-90	COK	16
08-27-90	COK	17
08-27-90	COK	18
08-27-90	COK	19
08-27-90	COK	20
08-27-90	COK	21
08-27-90	COK	22
08-27-90	COK	23
08-27-90	COK	24
08-27-90	COK	25
08-27-90	COK	26
08-27-90	COK	27
08-27-90	COK	28
08-27-90	COK	29
08-27-90	COK	30
08-27-90	COK	31
08-27-90	COK	32
08-27-90	COK	33
08-27-90	COK	34
08-27-90	COK	35
08-27-90	COK	36
08-27-90	COK	37
08-27-90	COK	38
08-27-90	COK	39
08-27-90	COK	40
08-27-90	COK	41
08-27-90	COK	42
08-27-90	COK	43
08-27-90	COK	44
08-27-90	COK	45
08-27-90	COK	46
08-27-90	COK	47
08-27-90	COK	48
08-27-90	COK	49
08-27-90	COK	50
08-27-90	COK	51
08-27-90	COK	52
08-27-90	COK	53
08-27-90	COK	54
08-27-90	COK	55
08-27-90	COK	56
08-27-90	COK	57
08-27-90	COK	58
08-27-90	COK	59
08-27-90	COK	60
08-27-90	COK	61
08-27-90	COK	62
08-27-90	COK	63
08-27-90	COK	64
08-27-90	COK	65
08-27-90	COK	66
08-27-90	COK	67
08-27-90	COK	68
08-27-90	COK	69
08-27-90	COK	70
08-27-90	COK	71
08-27-90	COK	72
08-27-90	COK	73
08-27-90	COK	74
08-27-90	COK	75
08-27-90	COK	76
08-27-90	COK	77
08-27-90	COK	78
08-27-90	COK	79
08-27-90	COK	80
08-27-90	COK	81
08-27-90	COK	82
08-27-90	COK	83
08-27-90	COK	84
08-27-90	COK	85
08-27-90	COK	86
08-27-90	COK	87
08-27-90	COK	88
08-27-90	COK	89
08-27-90	COK	90
08-27-90	COK	91
08-27-90	COK	92
08-27-90	COK	93
08-27-90	COK	94
08-27-90	COK	95
08-27-90	COK	96
08-27-90	COK	97
08-27-90	COK	98
08-27-90	COK	99
08-27-90	COK	100

8402 1 400 314 - 001

A

08 8402-201

08225.COL.UTE.CAD.PLOT.DATA
216002.8402001.CAA.8402001.A00

MR. HYPER
10-30-90

0.00

Table 2-1

COAL FUEL ANALYSIS

Coal	A* <u>Performance Coal</u>	B <u>Design Coal</u>
Source	Nucla, CO	Nucla, CO
Gradation	Uniform	Uniform
Proximate analysis, % of weight:		
Moisture	5.8	6.0
Volatile	26.9	21.0
Fixed Carbon	31.2	40.0
Ash	<u>26.1</u>	<u>33.0**</u>
Total	100.0	100.0
Ultimate analysis, % of weight:		
Carbon	55.17	46.41
Hydrogen	3.63	3.60
Sulfur	0.73	2.5**
Oxygen	7.51	7.5
Nitrogen	0.98	0.90
Chlorine	0.04	0.04
Moisture	5.86	6.00
Ash	<u>26.08</u>	<u>33.05</u>
Total	100.00	100.00
Gross heating value as fired: J/kg	10.26 x 10 ⁶	8.47 x 10 ⁶
(Btu/lb)	(9693)	(8000)
Surface moisture as fired: % by weight	3.74	4.0
Ash softening temperatures (reducing atmosphere), °C (°F)		
Initial deformation	1454 (2650)	1454 (2650)
Softening	1482 (2700)	1482 (2700)
Fluid	1482 (2700)	1432 (2700)

*Coal analysis as tabulated in Column A constitutes the basis for all guaranteed and predicted performance data. The circulating AFBC boiler unit is capable of developing specified capacity using coal analysis as tabulated in Column B. Also, the Column B coal ensures that the boiler will be capable of burning alternative fuels during EPRI's two-year test program.

**2.5% sulfur and 33.0% ash for coal "B" does not occur at the same time.

Table 2-2
ASH MINERAL ANALYSIS
(% by weight)

Phos. pentoxide, P_2O_5	0.1
Silica, SiO_2	56.1
Ferric oxide, Fe_2O_3	4.7
Alumina, Al_2O_3	29.1
Titania, TiO_2	1.2
Lime, CaO	4.2
Magnesia, MgO	0.8
Sulfur trioxide, SO_3	2.7
Potassium oxide, K_2O	0.8
Sodium oxide, Na_2O	<u>0.3</u>
Total	100.0

Table 2-3
LIMESTONE ANALYSIS
(% by weight)

The following analysis is typical of the limestone Colorado-Ute used:		
	<u>Range</u>	<u>Design Basis</u>
$CaCO_3$	80 - 98%	90
SiO_2	0.2 - 0.9%	1
$MgCO_3$	6 - 18%	9
Others	Trace	0
Bulk Density	85 lb/ft ³	0

Table 2-4

CIRCULATING AFBC BOILER PERFORMANCE SUMMARY

Superheater outlet:		
Steam flow	420,000 kg/h	(925,000 lbs/h)
Steam temperature	521 +/- 6°C	(1005 +/- 10°F)
Steam pressure	106 kg/cm ²	(1510 psig)
Boiler design pressure	124 kg/cm ²	(1760 psig)
Sootblowing steam:		
Flow	12,250 kg/h	(27,000 lbs/h)
Pressure	113 kg/cm ²	(1610 psig)
Temperature	427°C	(801°F)
Fuel input:		
Coal A	52,850 kg/h	(116,400 lbs/h)
Coal B	63,010 kg/h	(143,200 lbs/h)
Drum pressure	116 kg/cm ²	(1655 psig)
Economizer:		
Inlet pressure	119 kg/cm ²	(1689 psig)
Inlet temperature	227°C	(440°F)
Outlet temperature	280°C	(536°F)
Excess air	20%	
Primary air:		
Air temperature	190°C	(374°F)
Secondary air:		
Air temperature	184°C	(363°F)
Flue gas flow:	501,100 kg/h	(1,103,700 lbs/h)
Heat release:	1.19 x 10 ¹² J/h	(1,128 x 10 ⁶ Btu/hr)
Boiler efficiency:	88.27	
Flue gas temperatures:		
Leaving combustors (furnace)	871°C	(1600°F)
Leaving air heater	126°C	(258°F)
Boiler emission limits:		
Particulates	13 ng/J	(0.03 lb/ 10 ⁶ Btu)
NO _x	215 ng/J	(0.5 lb/ 10 ⁶ Btu)
So ₂	172 ng/J	(0.4 lb/ 10 ⁶ Btu)

portions of the combustion chamber are less dense and are elutriated particles exit each combustion chamber through a waterwall-cooled duct section connected to the top rear corner of each combustor. This section is connected to the hot cyclone with a refractory lined expansion joint. Non-mechanical gravity loop seals are used to recirculate particles from the cyclone to the lower zone of the combustor.

There are four secondary radiant superheaters in the upper zone of the combustors. Each is arranged horizontally, adjacent to the combustor front and sidewalls. Heat transfer is primarily by conduction and convection from the circulating bed material. Attenuator sprays are located at the inlet and outlet of the superheaters.

Boiler feedwater is heated in the economizer before delivery to the steam drum. From the steam drum, feedwater flows via downcomers to the combustor chamber waterwalls where, after heating, it is returned in risers as a steam/water mixture to the steam drum. Boiler water circulates naturally between the steam drum and the combustion chamber waterwall heat absorption surfaces.

Steam flows from the steam drum to a convection cage section at the outlet of the hot cyclone collectors. The saturated steam goes through the convection cage which forms a steam-cooled enclosure before going to the primary superheater. Primary and final superheaters are located in the convection cage. Steam flows from the primary superheater to the final superheater via radiant sections located in the upper zone of the combustion chambers.

Coal and Limestone Feed Systems

Crushed coal, 1/4 inch x 0, is stored in two 250 ton storage silos, one for each combustion chamber. Each silo bottom splits to three gravimetric coal feeders. An elongated silo outlet hopper design enhances flow out of the silo through 24 in. chain-wheel-operated, slide-gate isolation valves to the three feeders. Coal flows by gravity from the feeders, through a rotary valve which provides a seal from boiler pressure, into three locations in each combustor - two front wall ports and a rear-wall loop seal port. In addition there is a combustion chamber motor operated isolation valve. The coal feed system operates at atmospheric pressure.

Two of the six coal feed trains, the rear-wall feeders, also have horizontal and inclined en-masse conveyors to transport coal from the feeder discharge connection around the combustor to the rear feed port located on the loop seal leg.

Each combustion chamber feed system is capable of supplying full load coal flow. Each feeder feeds coal through an inclined chute. At each feed port a plenum box is provided through which secondary air acts as a purge.

The coal feed rate is adjusted automatically, as required by steam demand, and trimmed by boiler pressure. This is done by changing the gravimetric feeder speed on a predetermined proportionate basis over the boiler turndown range.

Limestone is delivered by truck, crushed and pulverized to 150 micron size and stored in two 135 ton silos, one for each combustor chamber. The limestone flows by gravity from the silo hopper through a slide gate valve to the limestone feeder. The feeders, one for each combustion chamber, are loss-in-weight gravimetric feeders, where the rate of feed from a measured feed

hopper weight is integrated over a period of time. Flow is automatically adjusted based on coal flow and is trimmed based on SO₂ content of the cyclone outlet flue gas.

Each limestone feed stream passes through rotary valves into the positive pressure pneumatic conveying system. There are four 50% capacity pneumatic trains per combustion chamber consisting of a blower, rotary valve, conveying line and injection gate. The trains are sized to feed the maximum expected limestone flow through any two of the four injection ports. There are two ports on the front wall, one on the side-wall and one on the rear wall.

Boiler Ancillary Equipment

Sootblowers

A total of 16 steam sootblowers are used to clean the economizer and tubular air heater surfaces. Twelve fixed position lance type sootblowers are installed in the economizer and four straight-line retractable blowers are on the air heater cold section inlet tube sheet. Soot blowing steam is provided from the primary superheater outlet steam header and reduced to 600 psig pressure. Soot blower wall boxes are located at the primary and final superheater sections of the connection zone for additional lances if required.

Boiler Insulation

All external surfaces of the boiler are insulated with mineral wool or calcium-silicate to prevent face surface temperatures from exceeding 140°F based on 80°F ambient air temperature and 50 fpm air velocity. The recycle components, including hot cyclones, loop seals and gas flues are internally lined with castable refractory.

The combustor and convection section enclosures have membrane walls with external mineral fiber insulation lagged with ribbed aluminum. The economizer has an uncooled casing, with only insulation for temperature reduction.

To withstand 40 in. W.G. boiler pressure fluctuations, the combustors and convection sections are reinforced with channel tie bars and buckstays. The buckstays are externally located outside the membrane wall insulation.

Boiler Vents and Drains

Vents are installed on all boiler pressure part high points including the steam drum, economizer, superheaters and the final superheater outlet to the main steam line. All vents are routed to the atmosphere. Boiler drains are located at all pressure part low points and are piped to the blowdown tank. Vents and drains meet ASME Boiler and Pressure Vessel code requirements.

Three safety valves are provided on the steam drum and one on the final superheater outlet header. In addition, the main steam system has an electromatic relief valve.

Boiler blowdown is piped through throttling valves to the flash tank. Flash steam is routed to the deaerator. Flash tank blowdown drains to either a new circulating water system for makeup or to a blow down tank. The blowdown tank also receives turbine drains. Makeup is supplied from service water. Blowdown tank drains go to a storm drain and holding pond.

Startup and duct burners

Vaporized propane is used for plant startup fuel gas. Six burners are used to raise the fluidized-bed temperature to 1400°F. Two propane duct burners located in each combustion chamber primary air inlet heat inlet air to 850°F during startup.

Startup and duct burners are provided with an ignitor, flame failure/supervisory system, instrumented valve rack, windbox and local burner control. A common boiler master gas trip, isolation and system supply pressure control valve are provided as part of the system. In addition, for each group of three startup burners there are rack mounted pressure reducing stations.

A burner management system provides remote burner control, purge control, indication, detection, safety shutdown and annunciation of burner system malfunctions.

Boiler instruments and controls

The boiler instrument and control equipment supplied by Pyropower includes primary elements for steam and water, air and flue gas, and fuel and ash; transmitters; flue gas analyzers; engineering of control and logic diagrams; and the boiler distributive control system.

2.1.2.2 Combustion Air and Flue Gas

Primary, Secondary and Induced Draft Fans

The primary and secondary air centrifugal fans provide air for combustion. Primary air (PA) enters below the distribution grid, through lower wall ports around the combustion chambers, through rear-wall coal ports and through the startup burners. Secondary air (SA) enters wall ports above the primary ports and through the front wall coal injection ports. Additional small amounts of combustion air enter through the loop seals, bottom ash coolers and the limestone pneumatic feed system. Both PA and SA intakes are from the boiler house upper building area except in colder periods when it enters directly from the outside. Both streams are heated in the tubular air heater.

The forced-draft PA and SA fans have variable frequency speed-controls. The PA fan has backwardly curved inclined air foil blades, an intake silencer and inlet vanes. The SA fan has airfoil blades, inlet silencer and inlet vanes. The SA inlet vanes control flow at low loads.

Proper air-to-fuel ratio is controlled by damper position, and primary air duct pressure by varying the fan speed. Secondary air duct pressure is maintained by changing fan speed and inlet vane position. Flow meters are used to measure flow upstream of the flow control dampers.

The induced draft (ID) fan is used to maintain a constant furnace pressure measured at each combustion outlet chamber. It has a variable frequency control drive and backwardly curved inclined airfoil blades.

In order to handle alternative test fuels, fan test block margins were increased from what would normally be specified.

Air Distributor and Windbox

The bottom of the combustion chamber consists of a water-cooled air distributor grid which is used to uniformly fluidize the bed.

Hot primary air at a relatively high pressure flows through a windbox up through capped nozzles. The caps prevent bed material from back flowing into the air nozzles and windbox. The distributors are supported from lower waterwall headers and have a water-cooled membrane. A high-density, abrasion-resistant refractory protects the distributors and lower section of the sidewalls.

Air Ducts and Gas Flues

In addition to a new baghouse, three existing baghouses are used to handle the total flue gas flow. As a result, the duct design is more complex than a typical conventional new plant arrangement; however, the final routing is designed to minimize pressure drop and dust buildup.

Ducts and flues are designed for maximum gas velocities of 3500 fpm. Baghouse collector branch flues are sized for lower velocities. Between the ID fan and stack there is a long straight section to accommodate stack gas analyzers.

Carbon steel plate is used for duct fabrication and reinforcement is provided to withstand design pressure fluctuations. All duct work is externally insulated with mineral wool and ribbed aluminum lagging to prevent surface temperatures from exceeding 140°F.

Dampers are provided in the primary air system to bypass the air heater and to control flows to the combustion chamber grid windbox, sidewall windbox and to the startup burners. Secondary air dampers are located in the fan inlets to maintain supply pressure and flow control dampers are installed in both secondary air ducts. Manual SA dampers are located at each combustor port and at each front-wall coal injection port. The only dampers in the flue gas section are for baghouse bypass, isolation and flow balancing. The ID fan controls flow and pressure.

Tubular Air Heater

A tubular air heater was specified because of the relatively high pressure differentials between the combustion air and the boiler flue gas stream. Also a vertical-tube with downward flowing flue gas was desired so that tube cleaning and maintenance would be easier. Separate tube sections (upper hot end and lower cold end) are incorporated to facilitate cleaning. Flue gas flows inside the tubes and heats both primary and secondary air.

The air heater has an uncooled casing with external mineral wool/ribbed aluminum insulation. There are two ash hoppers with a design capacity (half full) of 36 tons each. It is sized to result in a flue gas outlet temperature of 258°F at boiler MCR with 80°F ambient air inlet temperature. Because the boiler is started with propane gas and sulfur capture occurs within the combustors, the SO₃ dew point impact on the air heater is reduced.

Baghouse

The baghouse system is needed to meet particulate emission requirements. Three existing units and one new collector are connected in parallel.

The three existing units handle 48% of the CFBC flue gas flow. The units are of the shake-and-deflate type with a net operating air-to-cloth ratio of 2.7 to 1. Each baghouse has six individual compartments. They have no bypass or ventilation system. The ash hoppers are electrically heated and can hold a six hour accumulation of "B" coal flyash (including spent sorbent).

The new baghouse provides 52% of the required capacity and is also the shake-deflate type. There are twelve individual compartments erected in modules arranged so that any one or more of the compartments may be isolated for maintenance. An internal bypass duct with three bypass dampers functions automatically during excessive or low flue gas temperatures. These dampers can also be operated manually during startup. The bypass is sized to handle full boiler gas flow.

The new baghouse hoppers are also electrically heated and can store an eight hour accumulation of Type "B" coal flyash.

The bag cleaning cycle is automatically controlled to maintain a predetermined pressure drop. Compartments are cleaned in sequence and a deflation air fan is provided for a low-velocity purge. There is, in addition, a motor driven shaker drive mechanism in each compartment. Depending on how many compartments are bypassed, the air-to-cloth ratio ranges from 2.44 to 2.9.

Both existing and new baghouses are externally insulated with mineral wool covered with aluminum lagging to prevent surface temperature from exceeding 140°F based on 80°F ambient air and 50 ft/min air velocity.

Stack

A new 215 ft. high stack was installed for the CFBC. It has a single-wall all welded steel construction, is self supporting and has a base diameter of 18 ft. with a straight wall column diameter of 12 ft. Design temperature is 300°F, operating temperature is 258°F.

2.1.2.3 Coal Handling System

The function of the coal handling system is to provide for unloading, transporting, preparation and storing of the coal delivered to the plant. The scope of the system is from the receiving truck hoppers up to the in-plant coal silos. The fuel feed equipment from these silos to the boiler comprises the boiler fuel feed system and is discussed in Section 2.1.2.1.

Run-of-mine coal, in sizes up to 30 inches, is delivered to the plant in over-the-road coal trucks. The trucks are weighed on a truck scale at the plant. The trucks dump the coal into an unloading hopper. From the hopper, coal is fed to a primary crusher by two 50% vibrating feeders. The capacity of the feeders can be varied from 30-62.5 tons per hour (tph). The primary crusher, a single roll crusher, reduces the coal to 7 inch x 0 and discharges to a 125 tph, 24 inch belt conveyor, Conveyor 1A.

Conveyor 1A conveys the coal to the secondary crusher house and discharges to a single vibrating feeder. A magnetic detector is provided on Conveyor 1A to detect any ferrous tramp metal and trip the conveyor (and the upstream equipment) before the metal is fed to the secondary crusher. The vibrating feeder feeds the coal to the secondary ring granulator crusher, where material is crushed down to 3/4 inch x 0, and then discharged onto a 125 tph, 24 inch belt conveyor, Conveyor A.

Conveyor A conveys the sized coal to the transfer house. A belt scale is provided on Conveyor A to weigh the received coal. From the discharge of Conveyor A, coal is diverted by a two-way flop gate to either the yard storage pile via a 125 tph, 24 inch belt conveyor Conveyor B, or to the boiler building 1A on a 125 tph, 24 inch belt conveyor, Conveyor C. An "As-Received" sampling system is provided in the transfer house to provide a representative sample of the coal delivered to the plant. The primary sample cutter is located at the discharge of Conveyor A to continuously extract samples from the coal stream. This sample flow is fed to a crusher, then further reduced in size by a secondary sample cutter, which discharges to the final sample collecting can. The excess sample rejects from the secondary sample cutter are discharged to Conveyor C.

Coal sent to the yard storage via Conveyor B is discharged to the storage pile via a lowering well which minimizes coal dust emissions. Coal is reclaimed from yard storage through a hopper located at the base of the lowering well. Since the hopper is underneath the storage pile, a portion of the coal is reclaimed by gravity without the use of mobile yard equipment. The total storage capacity of the pile is 50,000 tons, equivalent to 30 days storage. From the yard reclaim hoppers coal is fed onto Conveyor C by a single vibrating feeder. Conveyor C runs from the underground yard reclaim hopper through the transfer house to the top of the boiler building.

Coal discharged from Conveyor C is sent via a diverter/splitter gate to either one or both of two 17 inch wide, 140 tph drag chain conveyors, 4A and 4B, which further elevate the material to a single 20 ton surge bin. The surge bin provides the ability to empty Conveyor C in the event of malfunction downstream.

An "As-Fired" sampling system is installed to extract a representative sample of coal discharged from Conveyor C and sent to the boilers. From the surge bin, coal is directed via a diverter/splitter gate to either one or both of two vibrating feeders. The vibrating feeders feed coal to two 75 tph, reversible impactor type crushers, where the coal is crushed down to 1/4 inch x 0 size suitable for combustion in the fluidized bed boiler. Each crusher discharges to a 13 inch wide, 100 tph drag chain conveyor, which discharge into either or both of the in-plant storage silos. Coal is discharged to each silo at three points through pneumatic operated slide gates. The two coal silos have a total storage capacity of 470 tons providing eight hours of storage.

If a crusher becomes unavailable, the remaining crusher can deliver 100 percent of the maximum coal feed rate to the boiler. However, this would require conveying coal to the plant continuously. Alternatively, the operating crusher can be adjusted to deliver 100 tph of 1/2 inch x 0 product which would only require conveying coal to the plant 16 hours per day. However, the larger coal size would decrease the boiler efficiency slightly.

Fugitive dust emissions are controlled by a wet spray type dust suppression system. This system utilizes a mixture of water and surfactant which is sprayed at coal transfer points from the truck hoppers to the transfer house. The solution tank and pump are located in the transfer house.

Dust control in the boiler building coal handling facilities is accomplished by a dust collection system which consists of a single dust collector and a fan. The dust collected is discharged through a rotary air lock valve to one coal silo.

2.1.2.4 Limestone Handling System

The function of the limestone handling system is to receive, convey, store, and prepare the limestone for use as sulfur dioxide sorbent in the circulating fluidized bed boilers. The limestone is delivered to the plant in the form of raw limestone rock. For efficient utilization, the limestone fed to the fluid bed boiler is crushed to an average size of 150 microns.

Limestone is delivered to the plant in over-the-road trucks direct from the quarry. The delivered product is run-of-mine quality with approximately 10 inch maximum lump size. Limestone is dumped into a receiving hopper which is partially enclosed by a wind guard structure to minimize fugitive dust emissions. From the hopper, the rock is fed to a reversible hammermill crusher by a vibrating feeder at a maximum rate of 75 tph, where it is reduced to 3/4 inch x 0 sized product. The crusher discharges onto a 24 inch wide, 75 tph belt conveyor which conveys limestone from the crusher to a bucket elevator. The conveyor is provided with a belt scale to weigh the received product, and a magnetic separator to remove any ferrous tramp metal. The bucket elevator discharges into a 850 ton capacity limestone storage silo, which serves as the reserve storage for the plant, sufficient for 70 hours of full load operation. Fugitive dust is collected at the truck unloading hopper and conveyor transfer points. The dust is collected in a pulse jet dust collector, which discharges the dust to the feed point of the bucket elevator.

From the silo, the limestone is fed to the pulverizing system which operates at a maximum capacity of 9 tph. The limestone discharges from the silo to a vibrating feeder which feeds an air swept, roller mill type pulverizer. Material flow from the silo is aided by a vibrating bin discharger at the silo outlet. A mill air fan circulates heated air in a closed circuit from the pulverizer, to a cyclone, through the fan, and back to the pulverizer. The air is heated in order to reduce surface moisture to 1 %, suitable for pneumatic conveying. In the pulverizer, limestone of small enough size is picked up and carried in the air stream. A motor driven spinner separator is included in the pulverizer to separate oversize particles picked up by the air stream and return them to the grinding zone for further grinding. Particles that pass the spinner separator are separated from the air stream in the cyclone separator. From the cyclone, the separated limestone is discharged to a pneumatic conveying system surge hopper through a rotary air lock valve.

The pulverizer circulating air system is maintained at sufficient temperature by providing heated fresh makeup air. This makeup air is fed into the mill by a makeup fan which discharges through a gas fired air heater. Simultaneously, a portion of the circulating air stream is bled off to a pulse jet duct collector and exhaust fan. The pressure in the mill circulating air circuit is maintained slightly negative by the dust collector exhaust fan to minimize fugitive dust emissions. Particulate in the dust collector is then discharged to the surge hopper through a rotary air-lock valve.

From the surge hopper, the pulverized limestone is fed, by a rotary feeder, to a dilute phase pressure pneumatic conveying system. Conveying air is provided by a rotary lobe, positive displacement blower at an approximate discharge pressure of 9 psig. From the surge hopper, the pulverized limestone is conveyed to one of the two limestone silos in the main boiler vented from the silo through a pulse jet bin vent filter (one per silo). Each limestone silo supplies the limestone

feed system for one of the combustion chambers. Each silo has a capacity of 135 tons, equivalent to twelve hours full load operation with the performance coal (0.73 percent sulfur.)

2.1.2.5 Ash Handling System

The ash handling system consists of two main sub-systems: the bottom ash system and the fly ash system. The function of the bottom ash system is the removal, classification, cooling, conveying, storage and disposal of the ash from the combustion chambers. The ash is handled and stored in a dry state. The material is conveyed pneumatically by a vacuum system. An ash reinjection system is provided to convey bottom ash from the silo back to the combustion chamber to provide the necessary initial inventory of fluid bed material for boiler startup. The fly ash system functions to remove, convey, store and dispose of the fly ash collected in the baghouse hoppers, boiler economizer hoppers and the air heater hoppers. This material is also conveyed by a vacuum pneumatic conveying system. The bottom ash and fly ash are stored in separate silos.

Bottom Ash System

The bottom ash system includes all equipment from the combustion chamber sidewall ports to the ash silo and truck loading facility. In addition, an ash reinjection system is included which conveys ash from the bottom ash storage silo back to a rear wall reinjection port on each combustion chamber to provide sufficient bed material for boiler startup.

Hot bottom ash, at approximately 1600°F, is removed through bottom ash ports located on the lower side of each combustion chamber. From these ports the plant bed ash is fed to four 100 percent capacity ash coolers (2 per combustion chamber) which cool and classify the ash. Fluidizing air aids material flow from the ports to the coolers. Each ash cooler is rated at 8100 lb/h. Heat in the ash is transferred to cool combustion air and cooling water. The cooling air for all four coolers is supplied by a single centrifugal cooling air fan which discharges directly into all four ash coolers without any pre-heating. The cooling air exits the top of the cooler with the classified bed material and enters the combustion chamber through pressure equalization ports.

Cooling water to the ash cooler is circulated through cooling coils in a closed loop and the heat from the ash is transferred to the low pressure feedwater system.

Each pair of ash coolers discharges through a rotary valve to a surge bin; there is one surge bin per combustor. The rotary valve has a variable speed drive which is controlled based on bed inventory in the combustor. The surge bin is mounted on load cells to provide indication of the bottom ash production rate. Each surge bin discharges to the vacuum pneumatic conveying system through an ash intake valve. A water-cooled screw cooler is also provided as an alternate to the vacuum discharge system. This cooling screw would be used in the event that 1) one of the ash coolers is out of service; 2) high ash and high sulfur fuel is being burned, causing the ash flow rate to increase; and 3) the discharge temperature of the ash to the surge bin exceeds 400°F. Upon detection of high temperature in the surge bin, the screw cooler is automatically placed in operation. Cooling water to the cooling screw is supplied from the same system as the cooling water for the ash coolers.

The vacuum pneumatic system conveys ash from the surge bins (or the cooling screws) to the bottom ash storage silo. Ash is separated from the conveying air by a primary cyclone separator

followed by a pulse jet type bag filter. Conveying air is handled by two 100 percent motor driven vacuum exhausters. Both the bottom ash silo and the exhausters are existing equipment. The capacity of the bottom ash silo is 200 tons. Three discharges from the bottom ash silo are included: one to a rotary dust conditioning unloader, one to a dry unloading spout and one to the ash reinjection system. The rotary unloader mixes water with the ash for duct control and discharges to an open top truck.

During boiler startup, an initial inventory of fluid bed material is required in the combustion chamber. This material is supplied by the ash reinjection system. The ash reinjection system is a pressure type pneumatic conveying system with a capacity of 20 tph. The system includes a pressure air lock feeder vessel to transfer ash from the silo into the pressurized conveying line. The ash is then discharged into either combustion chamber through a single reinjection port in the lower rear wall of each combustor.

Fly Ash Handling System

The fly ash handling system includes all equipment from the baghouse hoppers, economizer hoppers and air heater hoppers to the fly ash silo and truck loading facility. Two 27 tph systems are provided, one serving the new baghouse, economizer hoppers and air heater hoppers and one serving three existing baghouses.

Ash is withdrawn from each hopper through a fly ash intake valve. Two parallel trains of cyclone separators and bag filters separate the ash from the conveying air. A cross-tie with valve is provided upstream of this separating equipment for enhanced system reliability in the event one train is unavailable. Conveying power is supplied by three vacuum exhausters, one for each separating train, with a common spare.

The fly ash storage silo is a mass flow design with a capacity of 900 tons. Ash is discharged from the silo to a surge hopper by a screw feeder and operates in a batch mode. From the surge hopper, ash is discharged to trucks through either a dry unloading spout or a rotary dust conditioning unloader.

2.1.2.6 Turbine Generators and Main Cycle

A total of four turbine generators are included in the plant. Three of the turbines (Units 1, 2, & 3) are the existing machines originally installed with the stoker boilers. The fourth turbine (Unit 4) was installed with the CFB addition to the plant along with the necessary auxiliaries.

Units 1-3 are identical 3600 rpm, multistage, nonreheat condensing turbines rated at 12.65 MWe at 1.5 in. Hg backpressure. Throttle steam conditions for these turbines are 600 psig and 825°F. The original installation utilized four stages of uncontrolled extraction for feedwater heating. This extraction steam supplied two low pressure feedwater heaters, a deaerating heater and a high pressure feedwater heater. The highest extraction stage has been capped and the high pressure feedwater heaters removed from the cycle. Each of the existing turbine generators include their own auxiliaries, turning gear, lube oil system, DC generator exciter and turbine governor.

The new Unit 4 turbine generator is a 3600 rpm, multistage, single automatic extraction, non-reheat condensing machine rated at 73.4 MWe. Steam is supplied from the ACFB at inlet conditions of 1450 psig and 1000°F. The Unit 4 automatic extraction supplies steam to the Unit 1,

2 and 3 turbine generators. Five stages of uncontrolled extraction supply steam for feedwater heating to two low pressure feedwater heaters, one deaerating heater, and two high pressure feedwater heaters. The new turbine generator includes the following auxiliaries: stop-throttle valve and governing control valve, automatic extraction control valve, electro-hydraulic control system, lube oil system, gland sealing system, turning gear, hydrogen cooling system and seal oil system.

As previously indicated, each of the existing Units 1, 2, and 3 included their own complete cycle equipment such as feedwater heaters, condenser, condensate pump, etc. This equipment was retained in the modified plant cycle up to the deaerating feedwater heaters. From the Unit 1, 2 and 3 deaerating heaters, the feedwater is pumped to the new Unit 4 deaerating feedwater heater.

2.1.2.7 Additional Balance of Plant Equipment

Each of the 4 turbines discharge to a dedicated condenser. Heat from the exhaust steam is rejected to the circulating water which is then cooled in cooling towers. Units 1, 2 and 3 are served by an existing common cooling tower and Unit 4 is served by a new cooling tower.

Makeup water for boiler makeup, cooling tower makeup, fire protection and other miscellaneous plant services is supplied from the San Miguel River by the existing service water pumps and stored in an elevated storage tank. Water for boiler makeup is treated by a demineralizer system consisting of a cation exchanger, anion exchanger and mixed bed polisher train. The demineralized water is then sent to the Unit 4 condenser hotwell or the Unit 4 condensate storage tank.

Additional details of the balance of plant equipment are reflected in the equipment list in Appendix A.

2.1.2.8 Plant Control and Instrumentation

The new control system for the Nucla Station was designed to integrate the old and new systems. Obsolete pneumatics were replaced with a microprocessor based control system which could easily be changed after operating experience was gained, and system diagnostics were incorporated to monitor operation and collect data for the test program.

The plant is operated and controlled using a distributed, microprocessor based system referred to as the Distributed Control System (DCS). Operator interface is with CRT displays and keyboard terminals, segregated in a manner to provide control by unit number, system and function. Combustion, feed water, ash handling and the baghouse are controlled with this analog system and loops are capable of either manual or automatic operation via CRT/keyboard interface. Basic control mode, however, is automatic with operator override. Safety systems are hardwired to trip.

A digital control system, also part of the DCS, controls fans and pumps with a microprocessor based system providing sequential, digital interlock logic control. Information is displayed on the operator CRTs and also recorded on hard copy printout. Loop integrity is provided so that one loop failure will not affect others.

Alarms, grouped by systems, which require operator attention are displayed on CRTs and on hard copy printout. Design is such that operators are not affected by unimportant alarms. CRT

pictorial graphics show alarm points and local annunciators are provided showing any actuated local alarm.

The DCS gathers and displays the following basic information:

- Alarms
- Events recording for normal plant events
- Sequence of events recording and display of plant upsets
- Scanning of analog and digital inputs
- Logging of trends called for by the operator
- Logging of daily and hourly summaries of averages, totals, etc. of analog inputs
- Graphic display capabilities upon demand by the operator

The following systems are integrated with the DCS and controlled by the plant operator from the control room:

- Boiler
- Burner management system
- Main interlocks and purges
- Ash handling
- Baghouse

The pre-boiler water treatment system is controlled outside the control room locally by programmable controllers. Some pneumatic systems are used for drives, valves, etc. and these are local, single closed loop systems with electric/pneumatic positioners.

A new turbine control system was purchased with the Unit 4 turbine-generator. Startup is from the main control room.

Pyropower furnished the boiler furnace safety and fuel automation system to ensure that the ignition system and damper drive were correctly interfaced with the boiler. They also were responsible for control philosophy and logic. Basic control mode is "supervisor manual." Redundant instrumentation is employed where necessary to minimize nuisance trips.

The four CRT/keyboard control consoles were purchased with the main control system and are installed in the new plant control room. One CRT/keyboard engineer's console is in the new logic room, and the distributed control equipment is in a new remote logic room. The main logic room located beneath the new control room contains the protective relay, turbine-generator, and coal and limestone feeder cabinets.

2.1.3 Plant Environmental Performance

Even though the plant output was increased from 36 MWe to 110 MWe, preliminary reviews by both the U.S. EPA and the Colorado Department of Health disclosed that no significant environmental impacts would be associated with the Nucla project. This was substantiated in tests done with Nucla coal at a 1.5 MWe test facility and later during plant operation.

2.1.3.1 Flue Gas

Performance calculations were run for 72 steady state tests. Bed temperature was found to be the most influential operating parameter. Typical data, issued after two years operation, is shown in Table 2-5. This data was obtained when burning design coal (22% ash and 0.7% sulfur). Maximum allowable emission for NO_x is 359 ppmv, and for SO_2 it is 206 ppmv. As Table 2-5 shows, the Nucla emissions are well below these limits when burning 0.7% sulfur coal. Daily averages and 30-day rolling averages were plotted from 1988 through 1991 for SO_2 and NO_x emissions. Permit levels of 0.4 lbs/ 10^6 Btu and 0.5 lbs/ 10^6 Btu for SO_2 and NO_x respectively were consistently met except for a few violations of the SO_2 30-day rolling average. There were no permit restrictions for CO emissions which varied between 70 and 140 ppmv. All of the plant data is included in a final technical report prepared for the DOE by CUEA dated August, 1991 (1).

Table 2-5

BOILER PERFORMANCE TEST RESULTS

	Approximate Load (%)		
	100	75	50
MWe (gross)	105.3	82.3	55.2
Auxiliary power (%)	10.4	8.1	7.2
Boiler efficiency (%)	88.1	88.4	88.1
Combustion efficiency (%)*	98.1	98.6	99.7
NO_x (ppmv)	59	56	26
SO_2 (ppmv)	136	78	77
CO (ppmv)	99	92	119
O_2 (vol. % dry)	3.9	3.8	5.65
Calcium-sulfur molar ratio**	2.05	2.46	2.84
Average combustor temperature ($^{\circ}\text{F}$)	1563	1557	1493
* Boiler efficiency ranged from 85.6% to 88.6% depending on which coal was tested.			
** Calcium includes coal and sorbent			
Stack opacity has been reported as varying between 5 and 10% which satisfies restriction levels set by the state.			

Stack emissions monitoring instrumentation is mounted in the duct between the ID fan and the stack inlet. Both in-situ and extractive measurement techniques are used to measure SO_2 , NO_x , CO_2 and opacity. This information is sent to the plant operator via analog signals to the distributed control system.

The stack emissions monitor functions are:

- Scanning, conversion and linearization of measured emissions concentrations
- Computation of pollutant emissions
- Reduction of emission data
- Hourly determination of periods of excess emissions of SO₂ and NO_x
- Determination and logging of excess opacity emissions
- Hourly recording events
- Data logging; daily and monthly
- Analyzer interface to allow off-line calibration and standardization

Samples of bottom ash and fly ash are manually taken and analyzed in on-site laboratories.

The plant wastewater system has not been modified, and hence no new analysis equipment was needed.

2.1.3.2 Ash Solid Waste

Solid wastes consist of bed drain or bottom ash, and fly ash collected in the bag collectors.

A material balance done during acceptance tests shows the relative amounts of the wastes collected:

<u>Input</u> (lb/h)	<u>Coal</u> 108.75	<u>Limestone</u> 3.59	<u>Air</u> 1,140.51	<u>Total</u> 1,252.85
<u>Output</u> (lb/h)	<u>Flue Gas</u> 1,225.47	<u>Fly Ash</u> 23.59	<u>Bed Drain</u> 3.79	<u>Total</u> 1,252.85

The U.S. DOE collected field data on the engineering and environmental performance of disposed solid waste generated by the Nucla facility.

A test cell approximately 100 feet square and 8 feet deep was constructed adjacent to a landfill located 10 miles south of the Nucla station. The cell was filled with ash conditioned with water to prevent dusting resulting in an average moisture content of 30 percent.

The test cell is instrumented to provide data on the water balance at the site and to permit monitoring of water quality parameters. A meteorological station measures temperature, precipitation, humidity, insolation, wind speed and direction. A Parshall flume provides data on surface runoff, and access tubes allow measurement of soil moisture content using a neutron attenuation probe. Leachate quality is monitored by sampling porous-cup lysimeters installed at the site. The cell will be monitored for three years to determine physical and chemical changes in the ash.

Chemical analyses of the waste and soils have been completed and core samples were taken and analyzed. The results to date have demonstrated that landfill construction using FBC wastes is straight-forward with no problems encountered with rapid set-up of the conditioned waste or with excessive dusting at the site.

2.1.4 Problems Experienced/Overcome

In the acceptance tests using design coal (22% ash and 0.7% S), nearly all performance guarantees were met. Only fan performance and flue gas duct pressure losses did not meet guarantees. Problems experienced fell into three categories: typical startup/shutdown problems, problems related to construction errors and scale-up problems:

2.1.4.1 Start-up problems

Throughout the commissioning period the boiler experienced typical startup problems. These included coal feeder trips, steam leaks, valve linkage problems, valve packing leaks, generator trips and synchronization problems, propane feed difficulties, and steam line expansion interference. These problems were not specifically related to the type of technology being demonstrated.

2.1.4.2 Construction related problems

The two major construction problems incurred on this project involved boiler casing leaks and steam leaks on superheater field welds caused by weld contamination. These problems were discovered early in the program, repaired, and steps were taken to prevent their reoccurrence.

2.1.4.3 Scale-up problems

Problems related to design scale-up from previous smaller boilers were of more concern and some became chronic; however, none were so serious as to affect the ability to operate or to obtain good data except for the primary air fan which did not meet design specifications. The fan was modified in October, 1989 so that a key test variable, primary-secondary air ratio, could be controlled. Backsifting of bed material from the furnace into the windbox was a problem which was alleviated, but never eliminated, by increasing air flows. A reinjection line had to be installed to return material to the loopseal that had backsifted into the windbox. At various locations, the bubble cap design was modified to address backsifting, which was worse at low load operation but occurred at all conditions.

Although the limestone feed system improved with operating experience, weigh feeders, leaking rotary valves, erratic weigh signals and shaker motor failures persisted throughout the test program. By contrast, the coal feed system was reliable and required relatively low maintenance.

The bottom ash handling system experienced several problems, which involved sizing and material handling in general. Changes were made to correct these problems, including amendment of the ash cooler to classifier, modifications to the ash cooler discharge lines and modifications to increase ash handling capability. Controls changes were also made to facilitate operation with the physical system changes.

Problems persisted with drum level control, especially during startup and load change, despite changes in operating logic and increased operator attention. This placed a burden on the propane startup and make-up water systems. These drum level control problems were related primarily to the fact that a single drum was provided to serve two combustion chambers. Differences in heat

absorption in the two chambers under these operating conditions occasionally caused an imbalance in water flow into the drum, resulting in drum level control problems.

Instrumentation problems, other than drum level control, included faulty oxygen analyzers, errors in combustion air flow indication and bed pressure taps which plugged. New oxygen analyzers were installed which operated successfully.

Inadequately designed air dampers and actuators were a problem until the dampers were modified and larger actuators were installed.

Refractory durability, although it improved, remained a concern and was monitored throughout the test program. Sections of refractory were replaced on the rear wall of the combustor and in the conical portions of the cyclones and several areas of the loop seals. Surface spalling was also evident in the combustor.

In September of 1987, an incident occurred which resulted in a 10 week outage. One of the two combustion chambers overheated when unburned coal ignited during a fan cooldown following a waterwall tube leak. This caused structural damage due to downward differential expansion between the two chambers. No metallurgical damage was sustained by boiler pressure parts, and after repairs were made, no further problems associated with the deformation were experienced.

The limestone crusher was not able to vary the sorbent particle size and as a result, a finer-than-desired particle was produced. A modification to the crusher will be made to solve the problem.

2.2 SCALE-UP PHILOSOPHY

The intent of the Reference Plant design effort is to portray a commercial power plant with attributes considered important to the utility industry. The system designs and equipment selections are chosen using operating availability, overall cycle efficiency and cost effectiveness in the same manner as would be done in a commercial plant design. The pulverized coal (PC) fired power plant with flue gas desulfurization design is considered as the utility standard, from which commercial comparisons are made. Design assumptions are therefore based on criteria used for PC plant applications, except where the new technology portions require special consideration.

A series of assumptions concerning generic and geographical features has been made to define the Reference Plant as a guide for designs and cost estimates. Similar assumptions can also be made for future commercial versions of other Clean Coal plants which will permit valid comparisons to be made. These assumptions are documented in Section 3.1.1, and provide a common base for present and future comparisons. By documenting these assumptions, it also becomes possible for individual utilities to modify the assumptions for their own specific situations.

The plant is a single unit on a new, or grass roots, site. The facilities necessary to support the plant on the site are included, and are sized for one unit. The single unit plant may not be the reasonable choice in many actual situations, since many sites are multi-unit; however it provides a total plant cost picture, as well as a logical and understandable basis for evaluation purposes and comparison of different technology plants.

A site location has been chosen so that geographical assumptions can be made. Likewise, specific coal and limestone characteristics have been selected to define the equipment to be used in the plant. A description of the site, and the coal and limestone are included in the referenced Section 3.1.1.

To provide a sound basis for the ACFB combustor design, and for the plant which utilizes the combustor, a specific manufacturer was chosen. The logical choice was Pyropower, since they supplied the ACFB for the Nucla Project. There are significant design differences between ACFB manufacturers which affect the plant design and operation. However, a specific combustor design is required to complete a conceptual plant design, and the manufacturers are generally competitive in cost and performance, since CFB technology is now "market driven". As other Clean Coal projects are initiated, it will be of interest to make a direct comparison of different manufacturer's designs. It will also be interesting to determine how various approaches to combustor design affect upper limits of unit size, load change ability, minimum load capability, reheat configurations, and other design features.

The Pyropower boiler is classified as an atmospheric pressure, circulating fluidized bed boiler. Traditionally, fluidized bed boilers have been classified as either ACFB or bubbling bed (BB). The difference between the two types primarily relates to the fluidizing velocity used. Bubbling beds normally operate at 2 to 8 ft/s fluidizing velocity and the beds remained in a specific area of the bottom of the combustor, while circulating fluidized beds operate from 12 to 30 ft/s, thereby elutriating and recirculating most of the bed. However, this distinction is blurring (2). As outlined in the reference, there now appear to be at least four categories, namely bubbling bed units with solids recirculation, units with internal circulation, hybrid designs combining one or more fluidizing

regions and full fledged ACFBs. It is expected that distinctions will be further reduced as operating experience is gained by the manufacturers.

The type of AFB boiler chosen/offered for a particular application will be vendor specific as well as fuel and use specific. The requirement to:

- burn/incinerate certain waste fuels;
- operate for extended periods at low loads;
- change load quickly;
- provide a large furnace size;
- achieve high efficiency using high pressure/temperature steam with reheat, or;
- meet other user requirements,

may alter the competitive price range of vendors based on the configuration they offer. The current trend for large unit sizes (above 50 to 100,000 lb/h) has been toward the CFB, with some exceptions.

Placement of heat transfer surface clearly separates some vendors into categories with distinct differences. In small CFB units (less than 50 to 100,000 lb/h), this is less of a problem, i.e. surface can be accommodated in several ways because the wall surface to combustor volume ratio of the unit is large. As unit size increases, this ratio decreases, and vendors have elected to either employ external heat exchangers (EHE's), or surface which extends from the walls of the combustor. Wall surface is sometimes maximized through the use of cyclones constructed of waterwall heat transfer surface.

Pyropower and some other vendors have elected to proceed with the use of heat transfer surface internal to the combustor. Designs have evolved from conventional headered tube banks and wingwalls to OmegaTM (Pyropower) surface which provides superior erosion protection. Lurgi and ABB/CE started and have continued with the EHE and claim that this design approach is better for temperature control, turndown and accommodating reheat. Foster Wheeler has recently offered a version of the EHE called "INTREX" which is mechanically integral with the combustor. FW claims advantages of this design over the patented EHE design offered by others. ABB/CE offers a similar arrangement, where the walls of the EHE are integral with the combustor.(3) Pyropower claims that the "simpler" and lower cost wingwall (now improved OmegaTM surface) approach is better. The OmegaTM surface is described elsewhere in this report.

Foster Wheeler and Lurgi both offer steam/water cooled cyclones. Because only a thin layer of protective/sacrificial refractory is needed, start-up to full load times are reduced, and start-up time is limited by temperature gradients in thick walled pressure parts, similar to a conventional boiler. Integrating the cyclone into the boiler circuitry improves structural and thermal stability and reduces the number of required expansion joints and boiler radiation losses. Pyropower has retained their successful approach of using a full refractory-lined cyclone. The advantages of the EHE, cyclone design approach, and the approach placement of heat transfer surface with regard to

cost, operability and reliability will become apparent as more experience is gained with CFB plant operation.

The nominal size chosen for the ACFB Reference Plant is 400 MWe. This has been selected as being the most logical candidate size for this technology, considering factors such as technology scale-up and utility growth rate needs. The plant utilizes two boilers, each sized to produce one-half of the required steam flow, or 200 MWe equivalent. This selection was made for the following reasons:

- The 200 MWe size is presently available with commercial warranties, even though units of this size and technology do not presently have significant operating experience. The warranties offered may be different than those offered on mature technology equipment. Since there is a lack of operating experience at this size, there is a good chance that some if not all manufacturers will either offer warranties with escape clauses, or equipment that is designed very conservatively, with higher margins and/or additional assemblies, to give the manufacturer some protection if the equipment does not meet expectations. This results in more expensive installations than would be expected if the equipment design was mature. However, the added cost on a 200 MWe size boiler would be small compared to what would have to be added on a 300 MWe size boiler to mitigate risk at the size.
- The 200 MWe boiler size chosen is a reasonable extension of similar units that are presently operating, and hence should be available as a mature technology in a reasonable time period. A listing of fluid bed boilers installed by Pyropower and presently operating is shown in Figure 2-3, Pyropower FBC Units. If a curve depicting the average size of these units is drawn and extended into the future, the curve will reach the general size area of 1,500,000 lb/h, which is the size of the individual boilers proposed, well within the next decade. Figure 2-4, Fluid Bed Units, includes a fairly comprehensive list of free world FBC units, installed and operating, including the Pyropower units. The Pyropower units are generally in the conservative portion of the range of sizes, which reinforces the fact that when Pyropower units are designed, built and operated in the size considered, the technology should be well along the path to maturity.
- It is reasonable to conclude that a 200 MWe, or 1,500,000 lb/h ACFB boiler will be commissioned by 1997-1999. Within 2 to 3 years after this, an operating base for this size unit will have been established, and a utility could be confident that when an order is placed for one, the technological degree of risk associated with it has been minimized, and unit availability can be expected to be similar to other mature technologies. If, however, the size of the boiler were enlarged to 300 MWe or greater, there would be a higher degree of risk. With a higher risk, more time is required for mitigation. This difference could be anywhere from a few to many years depending on the demand for this type of equipment, and the perceived problems involved in the enlargement process. In the 1960's and early '70's, electric utilities were burned when PC boilers were enlarged beyond sizes that could be justified based on previous operating experience, and some large units were then rated at less than their intended capacity. The fluid bed boilers are a relatively new technology for electric utilities and it can be expected that progress to larger sizes will be done cautiously.

Pyropower Fluidized Bed Units

Figure 2-3

Typical Large Fluidized Bed Units – Worldwide

Figure 2-4

- This technology should be capable of achieving successful commercialization at this size; the problems encountered to date appear to be solvable within a scale-up of the technology of 2 to 1 or less, as it is in this case.
- It is expected that a large portion of the utility industry will prefer a unit capable of generating more than 200 MWe (the size of the recommended boiler) for the majority of the expansion envisioned in the 1990's and beyond. The economic trade-offs used to select the unit size will probably dictate a unit in the 300 to 600 MWe range. Extending the size of the circulating fluidized bed boiler beyond 200 MWe in the reasonably near future and considering it to be a mature unit is not as conservative as desired for this case. Hence, two 200 MWe boilers providing steam for a single 400 MWe turbine-generator is the most logical choice, given these parameters. Unit size (400 MWe) is in the predicted most desirable size range and each boiler is a reasonable extension of today's technology. In addition, it not only provides enhanced availability at part load by allowing one boiler to be taken out of service without shutting the plant down, it also results in higher efficiencies at low loads by taking one boiler out of service and operating the remaining boiler near it's most efficient operating point.
- Present day control systems can be designed to successfully control two boilers and one turbine with reheat, thus providing an efficient coal-fired plant.(4)

The choice of 2-200 MWe boilers does not imply that 200 MWe is the largest ACFB boiler that will be built. In the near term, 250 to 300 MWe modules may be designed and built. Rather, 200 MWe fits several criteria, including a size near the maximum size expected to be built in the near term.

The balance of the plant will be designed for operating availabilities comparable to a commercial PC unit of similar capacity.

Even though the size increase from presently operating to future mature commercial plants considered here is not large, there are still some areas of concern that will have to be addressed.

- On the newer, larger units, there are questions about part load operation. For instance, how rapidly can load changes take place, and what part load points can be sustained for extended operation. One study done for a large Pyropower plant(5) assumed a load change rate of 5% per minute, which would be acceptable, if correct. However, only experience will confirm this and the capability to shed load without plant trip under upset conditions. Also, the steam conditions at lower load points need to be determined. These questions become even more important because the unit under consideration will be a reheat unit, which will tend to make sustaining full load steam temperatures more difficult at lower loads.
- There are many techniques for controlling steam temperatures on a large, utility type boiler. These techniques are generally applicable to a ACFB plant, and can be successfully applied using experience from the units now in operation. This can also be assumed for the steam temperature control at part load as long as the load is not changing. However, during load changes, enough disruption may occur that the unit could be tripped. This will be especially true during rapid load changes, since the ACFB tends to respond to load change requirements more slowly than a PC unit. An additional problem that may occur on a plant

with two boilers and one steam turbine is one of mismatch of steam temperatures between boilers. During steady load operation, control will be relatively simple, but during load changes, the problems envisioned for ACFB units in general will be magnified by having two steam sources.

- One of the advantages in having two boilers on a power plant is that when one boiler is out of service, the other boiler can still produce steam so that the plant can operate at half load or slightly better. Also, if low load plant operation is desired, one boiler can be taken out of service and the plant efficiency will not suffer as much. However, the plant should be capable of transfer from two boiler to one boiler operation and vice versa. If the steam temperatures sag too much at 50% plant output, it may be a problem to make the transfer. At the least, care will have to be taken to design the control system such that this transfer can be made with minimal effect on plant life.

The design of the commercial plant will be done with assumptions made where an area of concern cannot be addressed with a final conclusion.

3.0 REFERENCE PLANT DESIGN DESCRIPTION

The Reference Plant Design is based on the technology demonstrated at the Nucla Plant and is described in this section.

3.1 DESIGN BASIS

The plant design basis has a significant influence on equipment selection, plant construction and operation, and resulting capital and operating costs. The following sections describe the basis which has been established for this plant.

3.1.1 Plant Site and Ambient Design Conditions

The plant site is assumed to be in the Ohio River Valley of western Pennsylvania/eastern Ohio/northern West Virginia. The site consists of approximately 300 usable acres (not including ash disposal) within 15 miles of a medium sized metropolitan area, with a well-established infrastructure capable of supporting the required construction work force. The area immediately surrounding the site has a mixture of agricultural and light industrial uses. The site is served by a river of adequate quantity for use as makeup cooling water with minimal pretreatment and for the receipt of cooling system blowdown discharges.

A railroad line suitable for unit coal trains passes within 2-1/2 miles of the site boundary. The site is served by a well-developed road network capable of carrying AASHTO H-20 S-16 loads and with overhead restriction of not less than 16 ft (Interstate Standard).

The site is on relatively flat land with a maximum difference in elevation within the site of about 30 ft. The topography of the area surrounding the site is rolling hills with elevations within 2000 yards not more than 300 feet above the site elevation.

The site is within Seismic Zone 1, as defined by the Uniform Building Code, and the ambient design conditions will be:

•	Pressure	14.4 psia
•	Dry bulb temperature	60 ^o F
•	Dry bulb temperature range	(-) 10 to (+) 110 ° F
•	Wet bulb temperature	52 ^o F

A sufficient number of well-trained construction laborers are available within a 50-mile radius of the site. Labor conditions are such that a "Project Work Agreement" can be obtained from labor organizations and contractors.

All commodities of bulk construction material are available locally and can be delivered within a reasonable period of time.

3.1.2 Fuel and Sorbent

Plant performance will be based on the Pittsburgh coal and Greer limestone compositions and data listed in Tables 3-1 and 3-2. No. 2 fuel oil will be used for unit start-up.

3.1.3 Capacity

The plant will consist of two circulating fluidized bed boiler modules that can operate individually to produce up to 50% plant load, or will operate in parallel to produce steam up to 100% plant load for one turbine generator that will produce approximately 400 MW net output. The boilers and other equipment in the steam producing systems have been sized based on flows, pressures and temperatures corresponding to the steam turbine valves-wide-open (VWO), 5% over pressure (OP) design point.

3.1.4 Plant Life

The plant will utilize components suitable for a 30-year life, with provision for periodic maintenance and replacement of critical parts. Major components requiring periodic maintenance during the plant life will be identified and the cost for the work included in the plant economic analysis.

3.1.5 Plant Availability

The plant will be capable of achieving a 65-percent levelized capacity factor while operating in a utility system.

Auxiliary systems that operate continuously and are essential for power generation shall be designed to have standby (backup) capability. Generally, the backup units are brought into service automatically. The backup capability may include fractional capacity equipment that can operate beyond the design point.

3.1.6 Maturity of Plant Technology

The plant design will be for a mature technology (i.e., the n^{th} plant). First-of-a-kind considerations such as high design margins, excessive test instrumentation, etc., will not be included in the design.

3.1.7 Steam Conditions

A single reheat steam turbine will be used, with the following nominal steam conditions:

- Main steam: 2400 psig/1000^o F
- Reheat steam: 464 psig/1000^o F

Table 3.1
PITTSBURGH NO. 8 COAL ANALYSIS

<u>Constituent</u>	<u>Air Dry, %</u>	<u>Dry, %</u>	<u>As Received, %</u>
Carbon	71.88	73.79	69.36
Hydrogen	4.97	4.81	5.18
Nitrogen	1.26	1.29	1.22
Sulfur	2.99	3.07	2.89
Ash	10.30	10.57	9.94
Oxygen	<u>8.60</u>	<u>6.47</u>	<u>11.41</u>
Total	100.00	100.00	100.00

	<u>Dry Basis, %</u>	<u>As Received, %</u>
Moisture	---	6.00
Ash	10.57	9.94
Volatile Matter	38.20	35.91
Fixed Carbon	<u>51.23</u>	<u>48.15</u>
Total	100.00	100.00
Sulfur	3.07	2.89
Btu Content	13,244	12,450
Moisture and Ash Free (MAF), Btu	14,810	

<u>Ash Analysis, %</u>	
Silica, SiO ₂	48.1
Aluminum Oxide, Al ₂ O ₃	22.3
Iron Oxide, Fe ₂ O ₃	24.2
Titanium Dioxide, TiO ₂	1.3
Calcium Oxide, MgO	1.3
Magnesium Oxide, MgO	0.6
Sodium Oxide, Na ₂ O	0.3
Potassium Oxide, K ₂ O	1.5
Sulfur Trioxide, SO ₃	0.8
Phosphorous Pentoxide, P ₂ O ₅	<u>0.1</u>
Total	100.5

<u>Ash Fusion Temperature, °F</u>		
	<u>Reducing Atmosphere</u>	<u>Oxidizing Atmosphere</u>
Initial Deformation	2015	2570
Spherical	2135	2614
Hemispherical	2225	2628
Fluid	2450	2685

Table 3.2
GREER LIMESTONE ANALYSIS

	<u>Dry Basis, %</u>
Calcium Carbonate, CaCO_3	80.4
Magnesium Carbonate, MgCO_3	3.5
Silica, SiO_2	10.32
Aluminum Oxide, Al_2O_3	3.16
Iron Oxide, Fe_2O_3	1.24
Sodium Oxide, Na_2O	0.23
Potassium Oxide, K_2O	0.72
Balance	0.43

Plant performance is based on the nominal 2400 psig throttle steam pressure conditions (i.e., pressures, temperatures, and flow rates) with an assumed 2.5-in. Hg condenser back pressure. Plant design is based on the VWO, 5% OP conditions.

Condensing steam cycle calculations will account for pressure drops in the equipment ducts and piping. The following pressure drops through the steam system piping will be assumed for the heat balance if more accurate estimates cannot be made:

- Main steam: 5 percent
- Cold and hot reheat steam: 5 percent (reheater excluded)
- Extraction steam to feedwater heaters:
 - Extractions below 100 psia 5 percent
 - Extractions above 100 psia 3 percent

3.1.8 Insulation and Lagging

Insulation and lagging will be provided on pressure vessels, piping, valves, and all other plant components that are potentially a significant heat-loss source to ambient and that require protection for personnel. The outside surface temperature will be limited to 145°F, with an ambient air temperature and velocity of 100°F and 160 ft/min respectively. If higher temperatures are used, appropriate personnel protection, such as a surrounding cage, will be specified and included.

3.1.9 Preheating

A No. 2 oil-fired start-up burner(s) is provided as the primary means for unit preheat and start-up. Where required, additional preheat sources such as electric/steam trace heaters or steam coil air heaters are provided to prevent cold-end acid corrosion, to preheat refractory, etc. If required, an auxiliary boiler firing No. 2 fuel oil will be provided to meet preheat requirements.

3.1.10 Modes of Operation

The plant is designed for base-load operation with occasional turndown to 25% plant load. The normal operating load range is from 25 to 100%. Below 25% load, the plant is in a start-up or shutdown mode. The high-pressure steam turbine operates at constant pressure over the operating load range.

Heat and material balances were prepared for the plant for the 100% load condition. Control/load following, start-up, and shutdown procedures are established.

3.1.11 Control Systems

An integrated plant wide control and monitoring system (DCS) is provided. The DCS is a redundant micro-processor based, functionally distributed system. The control room consists of multiple video monitor (CRT) and keyboard units. The CRT/keyboard units are the primary interface between the generating process and operations personnel. Minimal dedicated control and monitoring instrumentation is provided to safely shut-down (trip) the unit on a loss of the DCS. The DCS incorporates plant monitoring and control functions for all the major plant equipment. Control of minor plant equipment is included where economically practical.

The following control functions are implemented in the DCS: boiler and combustion controls, burner management, and plant logic. The following monitoring functions, as a minimum, are incorporated: alarming, trending, historical storage and retrieval, sequence of events, logging, and performance calculations.

The design of the DCS complies with the applicable standards of ASME, IEEE, ISA, NEMA and NFPA.

The DCS is designed to provide a unit operating availability of 99.5%. Geographic distribution of portions of the DCS is implemented where a cost/benefit analysis identifies an installed cost saving while maintaining the design criteria and availability required above.

The plant equipment and the DCS are designed for automatic response to load changes from minimum load to 100%. Start-up and shut-down routines are implemented as supervised manual with operator selection of modular automation routines available.

3.1.12 Plant Services

The following services/support systems are available at the plant as a part of the balance-of-plant systems. Any additional services required will be identified.

- **Auxiliary Power Systems**
 - 7200-v system for motors above 3000 hp.

- 4160-v system for motors from 250 to 3000 hp.
- 480-v system for motors 0 to 250 hp and miscellaneous loads.
- Emergency diesel generator (480 v) to supply loads required for safe and orderly plant shutdown. Instruments and controls and other loads requiring regulated (1 percent) 208/120 vac power are supplied from this source.
- 250 vdc system motors and, via static inverters, uninterruptible ac power for the integrated control and monitoring system, intercommunication.
- 125 vdc system for dc controls, emergency lighting, and critical tripping circuits including the plant shutdown system.
- Cooling Water
 - Cooling water (from the cooling towers) is available at between 30 and 50 psig, 90°F maximum temperature. The water is periodically chlorinated, and pH is maintained at 6.5 to 7.5. The cooling towers receive makeup water from the river.
 - Auxiliary cooling water, which uses demineralized water treated for corrosion control, at 60 to 80 psig and 105°F, is available for small heat loads (e.g., control oil coolers). The pH is maintained at about 8.5.
- Compressed Air
 - Instrument air filtered and dried to -40°F dewpoint at 80 to 100 psig and 110°F (maximum).
 - Service air at 80 to 100 psig and 110°F (maximum).
- Lube Oil

Lube oil from the conditioning system, with particulate matter removed to 10 μm or lower.
- Hydrogen and Carbon Dioxide

H₂ and CO₂ for generator cooling and purging from storage.
- Nitrogen

N₂ for equipment blanketing against corrosion during shutdown and layup.

- Raw Water

Filtered river water. Additional water treatment will be included for potable water, etc.

3.1.13 Structures and Foundations

A structure or structures are provided to support and permit access to all plant components requiring support to conform with the site criteria defined in Section 3.1.1. The structure(s) are enclosed if deemed necessary to conform with the environmental conditions.

Foundations are provided for the support structures, pumps, tanks, and other plant components. A soil-bearing load of 5000 lb/ft² is used for foundation design.

3.1.14 Heat Recovery

Sensible heat in solids streams discharged from the plant is recovered to the extent economically practical.

3.1.15 Codes and Standards

Recognized design codes and standards that are commonly used for the design of commercial fossil-fuel-fired power plants are applied to the extent of ensuring that their requirements are met. Where the existing codes and standards cannot be applied to the design and fabrication of a component, the components will be designed using accepted industry standards. Some of the more important applicable codes and standards are listed in Table 3-3.

**Table 3-3
TYPICAL DESIGN CODES AND STANDARDS**

• ASME Boiler and Pressure Vessel Code:
Section I, Power Boilers,
Section VIII, Divisions 1 and 2, Unfired Pressure Vessels • ASME/ANSI B31.1, Power Piping Codes and Addenda • National Fire Protection Association (NFPA) Code,
Volumes 1 through 16, 1979, including Supplements A and B • OSHA Regulations, 29CFR1910 • Uniform Building Code • ANSI A58.1, Building Code Requirements for Minimum
Design Loads in Buildings and other Structures, 1979 |
|--|

3.2 HEAT AND MASS BALANCE

The steam power cycle is shown schematically in the 100 percent Heat and Mass Balance diagram, Figure 3-1. The diagram shows state points at each of the major components for the conventional plant. Overall performance is summarized in Table 3-4 which includes auxiliary power requirements.

Table 3-4
PLANT PERFORMANCE SUMMARY - 100 PERCENT LOAD

STEAM CYCLE	
Throttle Pressure, psig	2,400
Throttle Temperature, °F	1,000
Reheat Outlet Temperature, °F	1,000
POWER SUMMARY, kWe	
3600 rpm Generator	
GROSS POWER, kWe	437,114
AUXILIARY SUMMARY, kWe	
Forced Draft Fans	8,232
Induced Draft Fans	4,132
Main Feed Pump	9,841
Steam Turbine Auxiliaries	900
Condensate Pumps	626
Circulating Water Pumps	3,411
Cooling Tower Fans	1,713
Cooling Tower Pumps	3,169
Coal Handling	187
Sorbent Handling	42
Soot Blowers	1,031
Baghouse	529
Ash Handling	1,997
Miscellaneous	803
TOTAL AUXILIARIES, kWe	36,613
Net Power, kWe	400,501
Net Efficiency, % HHV	34.38
Net Heat Rate, Btu/kWh (HHV)	9,926
CONDENSER COOLING DUTY, 10 ⁶ Btu/h	1,930
CONSUMABLES	
As-Received Coal Feed, lb/h	328,354
Sorbent, lb/h	72,990

REFERENCE PLANT - HEAT AND MASS BALANCE - 100%

LEGEND

DD

	CONDENSATE, FEEDWATER, AND STEAM
	COAL, ASH, AND SLUDGE
	AIR
	FLUE GAS
P	PRESSURE, PSIA
F	TEMPERATURE, °F
H	ENTHALPY, BTU/LBW
W	MASS FLOW, LBM/HR
E	EXPANSION LINE END POINT, BTU/LBW
U	USED ENERGY END POINT, BTU/LBW

SYSTEM PERFORMANCE SUMMARY

GROSS POWER :	436.88 MW
AUXILIARY POWER :	36.75 MW
NET POWER :	400.05 MW
NET PLANT EFFICIENCY :	34.35 %
NET HEAT RATE (HHV) :	9,937 Btu/kwh

Figure 3-1

A	CHK	N/A	N/A						
REV	DATE	CHK	DATE	CHK	DATE	CHK	DATE	CHK	DATE

REVISIONS

STATUS OF DRAWING	DEFINITION
☐ APPROVED	REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.
☐ PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPTS. SUBJECT TO CHANGE.
☒ CONCEPTUAL	REPRESENTS GENERAL CONCEPTS BASED ON ASSUMPTIONS. CHANGES COULD ENSUE.
COAL FUEL REFERENCE PLANTS	
MECHANICAL HEAT AND MASS BALANCE	
CLEAN COAL REFERENCE PLANT STUDIES	
REFERENCE 2400/1000/1000 AFBC PLANT	
GILBERT/COMMONWEALTH, INC.	
ENR ENGINEERS AND CONSULTANTS DEARBORN, PA	
PROJECT NO. 8402-201	
SCALE NONE	
8402 1 400 314 - 002	
A	

REV	DATE	CHK	DATE	CHK	DATE	CHK	DATE	CHK	DATE
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									

The plant uses a 2400 psig/1000°F/1000°F single reheat steam power cycle. The high pressure turbine uses 2,867,038 lb/h steam at 2415 psia and 1000°F. The cold reheat flow is 2,603,391 lb/h of steam at 531 psia and 617°F, which is reheated to 1000°F before entering the intermediate pressure turbine section.

Tandem high, intermediate, and low pressure turbines drive one 3600 rpm hydrogen-cooled generator. The low pressure turbines consist of two condensing turbine sections. They employ a single-pressure condenser operating at 2.5 HgA. For the low pressure turbines, the last stage bucket length is 30.0 inches, the pitch diameter is 85.0, and the annulus area per end is 55.6 square feet.

The feedwater train consists of six closed feedwater heaters (four low pressure and two high pressure), and one open feedwater heater (deaerator). Extractions for feedwater heating, deaerating, and the boiler feed pump, are taken from all of the turbine cylinders.

The net plant output power, after plant auxiliary power requirements are deducted, is 400 MWe. The overall net plant (HHV) efficiency is 34.35 percent.

The major features of this plant include the following:

- boiler feed pumps are steam turbine driven
- turbine configuration is a 3600 rpm tandem compound
- plant has six stages of closed feedwater heaters plus a deaerator

A 5% O.P., VWO Heat and Mass Balance (Figure 3-2) was prepared, on which the design at the plant is based. The net power output increased by 8.8 percent with the efficiency increasing from 34.385 to 34.42 percent. Overall performance is summarized in Table 3-5 which includes auxiliary power requirements.

LEGEND

—————	CONDENSATE, FEEDWATER, AND STEAM
—●—●—	COAL, ASH, AND SLUDGE
- - - - -	AIR
- - - - -	FLUE GAS
P	PRESSURE, PSIA
F	TEMPERATURE, °F
H	ENTHALPY, BTU/LBM
W	MASS FLOW, LBM/HR
E	EXPANSION LINE END POINT, BTU/LBM
U	USED ENERGY END POINT, BTU/LBM

SYSTEM PERFORMANCE SUMMARY

GROSS POWER :	476.45 MWo
AUXILIARY POWER :	48.66 MWo
NET POWER :	435.79 MWo
NET PLANT EFFICIENCY :	34.42 %
NET HEAT RATE (HHV) :	9,916 Btu/kwh

Figure 3-2

A	COK	N/A	N/A				
REV	DATE	CHK	PS	PC	TS	DATE	

REVISIONS

STATUS OF DRAWING	DEFINITION
☐ APPROVED	REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.
☐ PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPTS. SUBJECT TO CHANGE.
☒ CONCEPTUAL	REPRESENTS GENERAL CONCEPTS BASED ON ASSUMPTIONS. CHANGES COULD ENSUE.

COAL FUEL REFERENCE PLANTS

MECHANICAL HEAT AND MASS BALANCE

CLEAN COAL REFERENCE PLANT STUDIES

REFERENCE 2400/1000/1000 AFBC PLANT 5% O.P.

GILBERT/COMMONWEALTH, INC.
ENGINEERS AND CONSULTANTS READING, PA

DATE

CHG

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

Table 3-5

PLANT PERFORMANCE SUMMARY - VWO, 5% O.P.

STEAM CYCLE	
Throttle Pressure, psig	2,521
Throttle Temperature, °F	1,000
Reheat Outlet Temperature, °F	1,000
POWER SUMMARY, kWe	
3600 rpm Generator	
GROSS POWER, kWe	476,448
AUXILIARY SUMMARY, kWe	
Forced Draft Fans	8,760
Induced Draft Fans	4,832
Main Feed Pump	11,356
Steam Turbine Auxiliaries	992
Condensate Pumps	686
Circulating Water Pumps	3,696
Cooling Tower Fans	1,878
Cooling Tower Pumps	3,474
Coal Handling	203
Sorbent Handling	45
Soot Blowers	1,120
Baghouse	575
Ash Handling	2,171
Miscellaneous	873
TOTAL AUXILIARIES, kWe	40,661
Net Power, kWe	435,787
Net Efficiency, % HHV	34.42
Net Heat Rate, Btu/kWh (HHV)	9,916
CONDENSER COOLING DUTY, 10⁶ Btu/h	2,091
CONSUMABLES	
As-Received Coal Feed, lb/h	347,098
Sorbent, lb/h	79,344

3.3 ENVIRONMENTAL STANDARDS

Environmental standards applicable to the design of an electric utility power plant relate primarily to air, water, solid waste, and noise (Table 3-6). Both State and Federal regulations control emissions, effluents, and solid waste discharged from the plant. Additional environmental regulations may apply on a site-specific basis (National Environmental Policy Act, Endangered Species Act, National Historic Preservation Act, etc.) but will not be considered for this project.

Table 3-6
APPLICABLE ENVIRONMENTAL REGULATIONS

Clean Air act as amended in 1990, including:

- New Source Performance Standards
- National Ambient Air Quality Standards
- Best Available Control Technology
- Lowest Achievable Emission Rate

Federal Water Pollution Control Act (as amended by the Clean Water Act of 1977), including:

- Section 404 Dredge and Fill
- National Pollution Discharge Elimination System
- Best Available Technology Economically Achievable
- Effluent Guidelines and Standards 40CFR423

Resource Conservation and Recovery Act (RCRA)

OSHA Regulations 29CFR1910

State Regulations

- Air Quality Standards
- Water Quality Discharge Standards
- Solid Waste Disposal Standards

3.3.1 Air Quality Standards

The plant pollution emission requirements under New Source Performance Standards (NSPS) are:

- SO_x : 90-percent removal
- Particulates: $0.03 \text{ lb}/10^6 \text{ Btu}$
- NO_x : $0.6 \text{ lb}/10^6 \text{ Btu}$
- Visibility: 20-percent opacity

However, in most cases, Prevention of Significant Deterioration (PSD) Regulations will apply, requiring that Best Available Control Technology (BACT) be used. BACT is applied separately for each site, and results in different values for different sites. In general, the emission limits set by BACT will be significantly lower than NSPS limits. The following ranges will generally cover most cases:

- SO_x : 92 to 95%
- NO_x : 0.2 to $0.45 \text{ lb}/10^6 \text{ Btu}$
- Particulate: 0.015 to $0.03 \text{ lb}/10^6 \text{ Btu}$
- Visibility: 10-20%

Air quality regulations concerning other compounds such as CO, CO₂ and air toxics are being considered by federal authorities at the present time, and may have an effect on the design of plants in the time frame being considered here. However, details of the end results of these considerations are not clear at the present time and are not included in this report.

3.3.2 Water Quality Standards

Waste water, principally cooling tower blowdown, boiler blowdown, ash transport water, and process condensate or purge water, will be discharged following treatment to comply with the Environmental Protection Agency Effluent Guidelines and Standards (Title 40CFR).

3.3.3 Solid Waste Disposal

Spent sorbent, ash, air-pollutant emission control waste, and sludge produced from water treatment will be disposed of according to the nonhazardous waste disposal guidelines of Sections 1008 and 4004 of the Resource Conservation and Recovery Act (RCRA), and applicable state standards, appropriate for the actual plants' location.

Several programs are presently underway to characterize and classify solid wastes from CFB plants, to determine if the wastes can be utilized profitably in some manner. If these prove

attractive, solid waste disposal requirements could be reduced substantially, increasing the attractiveness of the CFB option.

3.3.4 Noise

In-plant equipment will be designed to meet the noise exposure regulations of the Occupational Safety and Health Administration (OSHA). Noise levels from major noise sources (e.g., fans, motors, gas turbines, valves, pumps, and piping) will not exceed 95 dBA at 3 ft. Outdoor noise criteria for on-site sources of noise will be an integrated equivalent level (Leq) of 55 dBA at the property boundary. The minimum distance to the property line will be assumed to be 1000 ft.

3.4 DESCRIPTION OF STEAM GENERATION SYSTEMS

The following sections contain descriptions of the steam generation systems in the plant. The boiler description was obtained from the vendor, Pyropower. The balance of the steam generation systems are conventional for this size plant.

3.4.1 Steam Generator and Ancillary Equipment

The 400 MWe circulating fluidized bed reference plant consists of two 200 MWe Pyropower combustors, coal and limestone feed systems, boiler ancillary equipment and one GE turbine generator. This section includes descriptions of:

- Pyropower boilers
- Coal and limestone feed systems
- Boiler ancillary equipment
- Ash discharge system

A description of the equipment is included in Appendix A, Major Equipment List. Figures 3-3 and 3-4 illustrate a plan view and cross section of the boiler, respectively.

3.4.1.1 Operation Description

Pyropower Boiler

The Pyropower boilers are designed for a flow of 1,580,454 lbs. of steam per hour at 2660 psig and 1000°F at the superheater outlet. Conditions at the reheat outlet are a flow of 1,430,404 lbs. of steam per hour at 543 psig and 1000°F.

The major components of Pyropower's patented CFB boiler system are the combustion chamber, the hot cyclone, the non-mechanical loopseal and the convection section as shown in Figure 3-5, Air and Gas Flow Schematic. In the combustion chamber the bed material, with the fuel, is fluidized with primary air which turbulently transports the solids up the full height of the combustion chamber. Combustion of the fuel takes place as it rises and heat is transferred to the membrane water-wall tubing that forms the walls of the combustion chamber, evaporative wingwall surfaces and radiant superheat surfaces. The hot combustion gases with the entrained solids exit at the top of the combustion chamber into the hot cyclone. The cyclone separates the solids from the combustion gases and returns the solids, including any unburned solid fuel, through a non-mechanical loopseal to the combustion chamber where they mix with incoming fresh fuel. The long solids residence time at combustion temperature and the retention and continuous recirculation of the solids ensure high combustion efficiencies and provide an ideal system for the mixture of fine limestone with the fuel for efficient SO₂ retention as a solid. Coal is fed into the lower combustion chamber and the loopseals.

D = 140'-0" W = 120'-0"

FOR ELEVATION VIEW SEE DWG B90-88-ED1

PYROPOWER PLAN

3-17

THIS IS A CAD DRAWING
DO NOT REVISE MANUALLY

TAG NO	ITEM	DRAWING NUMBER	ITEM	DESCRIPTION
MATERIAL LIST				
				PYROFLOW REFEREN
SCALE				NONE
DO NOT SCALE				

PLEASE NOTICE

DR	CHK	APPR	APPR	APPR
EM				

H

G

F

E

D

C

B

Figure 3-3

PTION	QTY	MATL SPEC	SIZE	SPEC NO	P.O NO
IST			QTY'S SHOWN FOR 10 UNIT NO. UNITS IN CONTRACT		
FLOW • 1,580,454 LBS/HR - 2660 PSIG - 1000°F					
ENCE PLANT MORGANTOWN / DOE					
PLAN			PYROPOWER SAN DIEGO, CALIFORNIA DRAWING NO. B90-88-E02 KEY A		

REV	DATE	DESCRIPTION
A		PROPOSAL

H = 155'-0"

PYROPOWER CROSS SECTION

3-18

THIS IS A CAD DRAWING.
DO NOT REVISE MANUALLY.

- LEGEND**
- + SOOTBLOWER
 - ACCESS DOOR
 - ① DESIGNATES TERMINAL WHE PYROPOWER CORP WORKS
- NOTE**
1. INTERCONNECTING PIPING & REPRESENTATION FINAL RE QUANTITY TO BE DETERM

ITEM NO.	ITEM	QUANTITY	ITEM	DESCRIPTION
MATERIAL LIST				
				PYROFLOW
				REFERENC
				EL

1						
LEASE NOTICE						
	DR	CHK	APPO	APPO	APPO	
	EM					
						H
HERE 5 STOPS G B90-88-E01 IS A ROUTING & WED AT CONTRACT						G
						F
						E
						D
						C
						B
						A

IN	QTY	MAT'S SPEC	SIZE	SPEC NO	P.O NO	
T			QTY'S SHOWN FOR 10 UNIT NO UNITS IN CONTRACT			
•1,580,454 LBS/HR - 2660 PSIG - 1000°F CE PLANT MORGANTOWN / DOE						
ELEVATION			PYROPOWER SAN DIEGO, CALIFORNIA			
			DRAWING NO			REV
			B90-88-E01			A

Figure 3-4

AIR AND GAS FLOW SCHEMATIC

Figure 3-5

As sulfur in the form of SO_2 is released from the combusted coal, it reacts with calcined limestone to produce CaSO_4 . The sulfation reaction requires that there is always an excess amount of limestone present. Limestone is fed directly to the bed in order to maintain a pre-determined ratio of calcium-in-the-limestone to sulfur-in-the-coal which for this boiler is 2.5 to 1. This ratio ensures an SO_2 emission rate of less than $0.371 \text{ lb}/10^6 \text{ Btu}$ (92% reduction).

The lower section of the combustion chamber includes a water cooled air distribution grid and a bottom ash removal system. Primary air is supplied through the lower windbox to the distribution grid providing fluidization air flow. Secondary air entering above the bed ensures solids circulation, provides staged combustion for NO_x reduction and supplies air for continuous fines combustion in the upper part of the combustion chamber.

Flue gas and some particulate matter leave the hot cyclone collector and pass through the convection section which contains primary and final superheat, reheat and economizer banks, plus a tubular air preheater. The flue gas then enters a reverse air baghouse where particulate matter is removed in compliance with environmental regulations. Clean flue gas is discharged to the stack via the induced-draft fan.

Feedwater enters the economizer and flows counter to the flue gas, picking up heat before entering the drum. Water flows from the drum to the lower combustion chamber headers via downcomers and supply pipes. The combustion chamber is arranged for complete natural circulation. As the steam/water mixture in the waterwalls absorbs heat from the combustion flue gases it rises up the water wall tubes, is collected in the upper combustor headers and is transferred to the drum via riser tubes. The density difference between the water and the steam/water mixture creates a natural pumping action. The steam/water mixture is separated in the drum.

Dry saturated steam leaves the top of the drum and is delivered to the convection cage walls, then to the superheater inlet header. Heat from the flue gases is transferred to the steam in the superheater tube bundles. The superheater bundles are arranged in multiple stages (primary, intermediate and final) with attemperation between each stage. The superheated steam exits the outlet header of the final superheater and enters the main steam header for delivery to the turbine generator.

Exhaust steam from the high pressure turbine enters the reheat inlet header, passes through the reheat tube bundles absorbing heat from the flue gas and flows to the reheat outlet headers for transmission to the intermediate pressure turbine.

The design used for the Reference Plant is different than that used for Colorado Ute's Nucla Plant in several significant areas. The following is a list of the more important changes and some of the reasons for the changes. In general, changes have been made to improve reliability where operation has shown the need for modification, or to address performance in terms of carbon burnup efficiency, NO_x production, or limestone Ca utilization.

1. Double loop seals will be used to allow recirculating solids to re-enter the combustor in two distinct flow streams for better distribution.
2. 16 vs. 8 limestone feed points to improve distribution of calcined limestone and contact with SO_2 .
3. In-combustor wingwalls have been added to provide additional evaporative and superheat duty.
4. An in-combustor omega superheat surface is designed to provide a flat surface parallel to the upward flowing gas in the combustor, thus minimizing erosion.
5. A bottom drain classifier is used instead of a side drain for ash removal because it is more economical.
6. A flyash reinjection system was added to optimize limestone utilization and carbon burnout.
7. Refractory brick is used in the cyclone instead of castable or gunnite to minimize erosion, improving refractory life.
8. The cyclone configuration was changed to lessen reentrainment and maximize gas residence time in the cyclone.
9. A single piece vortex finder was added to the cyclone to prevent shortcutting and enhance particulate capture.
10. The refractory/waterwall interface design was changed to eliminate ash eddying and decrease erosion potential.
11. Pigtail nozzles are used instead of bubblecaps to reduce backsifting of ash into the windbox, to improve maintainability of the nozzle system by allowing a simplified method of cleaning the nozzles from the windbox area, to eliminate the potential of erosion of the nozzles, and to enhance the migration of the coarser materials to the ash removal ports.
12. A change in the air supply source was made to allow initial variation in the primary/secondary air split to provide optimum heat transfer, performance, and emission characteristics for the combustor system.
13. Belt conveyors for fuel are generally being used instead of drag chains based upon superior performance relative to maintenance requirements.
14. Splitter screws are used in the fuel feed system to improve flow of fuel to feed ports.
15. Additional instrumentation was added to the control systems to provide more time/function graphs and emission data.
16. An ammonia or urea DeNO_x system could be used for NO_x control, if required, but was not included in the Reference Plant design.

17. A single combustion chamber was designed instead of two to alleviate flow distribution problems.
18. Duct burners were eliminated; all start-up burners are now located in the lower combustor area.
19. The steam driven auxiliary feed pump was changed to a motor drive for economic reasons.
20. The rotary feed valve/pressurization of the feed system was eliminated to improve reliability.
21. The "wrap-around" combustor superheat surface was eliminated and the backpass superheat hanger design was changed.

Because of the increasing international concern about the greenhouse effect, the discharge of N_2O from combustion sources has gained recent attention. Fluidized beds are known to emit larger amounts of N_2O than PC boilers per unit size, primarily because of the lower combustion temperature. Reduction of N_2O might be accomplished in three ways, all of which have offsetting drawbacks or penalties:

- Increase temperature in the combustion chamber. This will lead to higher NO_x emissions and an increase in limestone requirements.
- Decrease excess air. This will normally lead to decreased combustion efficiency.
- Add a gas-fired post-combustion system following the cyclone. Two stage combustion requires a more expensive fuel for the second stage, or a more expensive fuel delivery system. Two stage combustion is also difficult to accomplish in a CFB type boiler.

The control or reduction of N_2O has not been addressed in this design because N_2O levels are presently unregulated.

3.4.1.2 Combustor Design

The combustor is designed as a totally water-cooled chamber using only natural circulation. The tubes are designed of carbon steel using 2-1/2 inch tubes on 3 inch centers. The lower portion of the combustor waterwalls from the grate to a level just above the secondary air ports are refractory-lined with a high alumina refractory to protect the waterwalls from abrasion and the reducing atmosphere present in this area. The refractory is applied as a rammed refractory at a thickness of about 2 inches.

The interface where the refractory ends and the bare waterwalls begin is designed using a proprietary feature that eliminates direct impingement of the bed material cascading down the walls on the refractory interface. Previous experience has shown that any type of discontinuity at this point (feathering, shelves, etc.) results in gradual erosion of the waterwalls at this point caused by turbulent eddies that are formed. Hardfacing of the waterwalls above this interface point has

been reasonably effective in minimizing this erosion, but the new proprietary design eliminates this erosion potential due to ash eddying.

A second proprietary feature is included near the bottom of the combustor chamber just above the fluidizing grid. This feature prevents direct impingement of the ash cascading down the refractory-covered walls onto the fluidizing grid, and assists in redistributing the ash more evenly across the floor of the combustor.

The windbox is designed as a carbon steel attachment to the bottom of the combustor. The windbox is generally not refractory lined except in instances where windbox startup burners are required for startup. It is not anticipated that windbox burners will be required for this application.

Due to the size of this application, all of the required evaporative duty cannot be provided by the combustor waterwalls alone. The remaining evaporative duty is provided by wingwall panels located on the front wall of the combustor. (Note that some of the wingwall panels are evaporative panels, while the remainder are superheat panels; the design is essentially the same. The superheat panels are discussed below.) Each wing wall panel consists of a series of parallel watertubes that enter horizontally into the combustor chamber through the front wall approximately half way up the combustor wall, and then turn upward, leaving the combustor chamber through the roof. The horizontal portion of the tubes are, therefore, stacked in a vertical direction, while the vertical portion of the tubes run parallel to the upward gas flow.

The horizontal portion of each panel, and several feet of the panel in the vertical direction, are refractory lined to protect against erosion from the solids cascading down the walls, and, to a lesser extent, against erosion from solids travelling upward with the gas stream. This style of wingwall panel has been operating successfully in several CFB applications for up to 6 years.

Special provisions are included in the design to seal the wingwalls at both penetration points in the combustor (side wall and roof), and to provide for expansion differentials that may be present.

The upper portion of the combustor chamber is provided with openings which allow the flue gas and entrained particles to enter the cyclones.

A proprietary primary air fluidizing grid is provided at the floor of the combustor. The grid is sloped approximately 2 degrees to facilitate ash removal. The bottom of the grid system (portion facing the windbox) is a water-cooled membrane which is an extension of the waterwalls. The proprietary nozzles are welded to the webs of this membrane surface, and terminate several inches above the membrane surface in a single air outlet for each nozzle. Refractory is then placed over the membrane surface such that nozzle termination orifice is flush with the top of the refractory, thus providing a flat floor in the combustor to facilitate internal maintenance in the combustor to enhance the migration of coarser material to the bed drain system (since there are no nozzle projections to impede this movement) and to provide erosion protection for the nozzles. The nozzles are also designed to minimize ash backsifting into the windbox.

The combustor normally operates with a differential pressure drop from the top of the grid to the top of the combustor of about 25 to 30 inches of water depending on the fuel characteristics. Typical slumped bed height is 2 to 4 feet.

3.4.1.3 Cyclone Design

This 200 MWe unit is provided with 3 cyclones arranged on the rear wall of the combustor (between the combustor and backpass). Each cyclone is approximately 24 feet in diameter, and incorporates the use of metal vortex finders projecting downward from the cyclone outlet into the scroll area. The vortex finders enhance the capture of particulate by avoiding short-circuiting of the incoming dust directly to the outlet. At a capture efficiency of over 99%, and a particulate cut size of approximately 80 microns, sufficient ash is normally retained in the circulating loop to avoid the addition of supplemental sand or limestone to maintain adequate solids in the system. Supplemental solids addition would only be anticipated for extremely low ash, low sulfur fuels.

The cyclones are designed to minimize reentrainment from the cone of the cyclone, and to maximize residence time of the gases in the cyclone. Areas in the cyclone that are subject to high potential abrasion are provided with either hardfaced brick or castable refractory containing high alumina content and designed to resist alkali attack. The barrel of the cyclone is primarily brick and the cone is designed entirely using brick. Other portions of the cyclone, loop seal, and inlet/outlet ductwork are provided with refractory appropriate to the environment; brick, castable, rammed, and gunned refractory are provided as the environment requires.

The above refractory is the portion in direct contact with the flue gas and/or ash. Between this refractory and the metal shell of the cyclone, insulating refractory is applied such that the outside metal temperature of the cyclone is between 160 and 180 degrees F. Protection for personnel in areas where maintenance or access is required are provided with screening to prevent accidental skin contact with the shell.

Bed material separated in the cyclones is directed through the loop seals back to the combustor. For applications of this size it is common to provide a split loop seal such that the recirculating solids flow is split in the loop seal and reenters the combustor in two distinct flow streams. The design of a typical split loop seal is shown in Figure 3-6. Fuel feed to the loop seals is provided to each returning solids flow stream; therefore, for this 200 MWe design, a total of six fuel feed points are provided on this rear face of the combustor. Additional front wall fuel feed (discussed later) is also provided.

3.4.1.4 Air Distribution

Air for combustion is provided in two different regions of the combustor. Approximately 50-65% of the combustion air is provided through the windbox/fluidizing grate as primary air. This air is normally provided by a centrifugal fan complete with inlet silencer and inlet vanes/dampers for flow control. The number of primary air fans is determined by the size of the application and the need for fan redundancy. For this application two primary air fans with outlet shutoff dampers are supplied to allow isolation of one of the fans for maintenance.

PYROFLOW CIRCULATING FLUIDIZED BED BOILER

SPLIT LOOP SEAL

Figure 3-6

The remainder of the combustion air is supplied by two secondary air fans, which are also centrifugal fans complete with silencers and flow control inlet vanes/dampers. The number of these fans is similar in principle to the primary air fans. Secondary air is introduced into the combustor above the grate. The system is designed to allow variation in the primary/secondary air split to provide optimum heat transfer, performance, and emission characteristics for the combustor system.

The secondary air fan system also provides air for other fluidization and sealing air functions. The complete secondary air system design is shown schematically in Figure 3-7.

A small amount of air is also introduced to the combustor through the loop seal as fluidizing air. The loop seal air is supplied by blowers, and is introduced into the loop seal at proprietary locations in the loop seal and inlet/outlet ducts of the loop seal to assure complete fluidization of the returning solids flow. It is typical to provide one fluidization blower for each loop seal for an application of this size. As with the secondary air system, the high pressure blowers provide fluidizing air to other areas of the CFB system. Figure 3-8 shows schematically the high pressure air system design.

Fan margins are based upon the maximum air flow requirements consistent with the worst case fuel. To this calculated flow, an additional 20% is added in establishing the test block condition of the fans. From a pressure standpoint, the test block design is typically 30% higher than the calculated pressure drop of the system from the fan inlet to the top of the combustor (note that the balanced draft point of the CFB is at the inlet to the cyclones).

The ID fans will be of the backward curved design, with fan margins similar to the combustion air fans. Variable speed drives will be used to control fan capacity, i.e., to maintain the balanced draft point in the combustor. The particular fan control method selected for this application will allow better control during part load operation. A base loaded plant could use inlet vane control.

3.4.1.5 Superheat System

The superheat surface is located in the backpass and in the combustor proper. The flow path of the steam is shown schematically in Figure 3-9, and is described in more detail below:

- From the drum, the steam is directed to the backpass walls and roof.
- From the backpass walls and roof, the steam is directed to the primary superheat section located in the combustor. This primary superheater is provided using Pyropower's patented OmegaTM surface, which is designed to provide a flat surface parallel to the upward flowing gas in the combustor. The OmegaTM surface spans the width (front wall to rear wall) of the combustor chamber. In addition, the leading tube (lowest tube in the bundle) is specially designed to provide minimum metal temperatures for further protection against erosion that might accelerate due to high metal temperatures. The OmegaTM type of surface has been in operation at several facilities for up to 5 years.

SECONDARY AIR SYSTEM

Figure 3-7

HIGH PRESSURE AIR SYSTEM

Figure 3-8

Figure 3-9

- From the primary OmegaTM superheat section to the intermediate wingwall superheat section located in the upper portion of the combustor chamber.
- From the intermediate superheat section in the combustor, the steam flows to the final superheat section located as the first heat absorption section in the backpass. From here the steam flows to the turbine.

Steam attemperation is provided by a desuperheat station located between the primary and intermediate superheat sections, and between the intermediate and final superheat sections. The desuperheaters are of the venturi/spray type.

3.4.1.6 Reheat System

Both the primary and final reheat sections are located in the backpass of the CFB following the final superheat surface. The design of the reheat control system is shown in Figure 3-10. A specially designed patented reheat temperature control system using conventional bypass valves, selected to provide optimum control characteristics, is used to divert the flow based on reheat steam outlet temperature requirements.

This reheater design minimizes pressure drop by locating both of the reheat surfaces in one location (rather than splitting the surface in two different locations in the CFB), and allows startup of the CFB up to 30% of MCR without the need for reheat flow through the reheater, since backpass temperatures are below acceptable metal temperatures. It also avoids the need for backpass gas flow biasing dampers common in other designs. Reheat metal selection is based on standard industry design criteria.

3.4.1.7 Economizer

The economizer is a bare tube, in line, horizontal serpentine type heat exchanger, arranged in multiple banks. Extended surface economizers may be provided when appropriate.

3.4.1.8 Air Heater

The air heater is a tubular air heater designed with gas over the tubes and air through the tubes. For the low outlet gas temperatures required for this application, the airheater would be provided in a multiple pass design, and both the primary and secondary air would be directed through the airheater. The various banks of the airheater would be provided with ample rotary sootblowers to maintain surface cleanliness.

Because a high differential pressure must be maintained for the circulating fluidized bed, regeneration air heaters are not a good choice for this service, since seal leakage would be excessive. In certain applications, where space constraints in particular are of concern, a heat pipe air heater may be employed. These are relatively new to the industry, and although there are some specific advantages to using them, the Reference Plant employs the more conventional tubular air heater. The selection of either the tubular or heat pipe configuration is site and

PYROFLOW CIRCULATING FLUIDIZED BED BOILER REHEAT DESIGN

REHEATER ARRANGEMENT

Figure 3-10

configuration dependent.

3.4.1.9 Bottom Ash Removal/Cooling System

It is anticipated that, for this application based on the 9.94 percent ash in the fuel, approximately 30% of the ash will be withdrawn as bottom ash, with the remainder leaving as flyash. The bottom ash system is designed to accommodate 100 percent of the total ash production.

The bottom ash may be removed in one of two designs, either using side ash coolers, or bottom ash coolers. Since there are no space constraints in the conceptual design, bottom ash withdrawal was chosen.

For this design, the ash is withdrawn downward through ports located in the floor of the combustor. The ash passes down through pipes which are located in the windbox. From there the ash enters conventional water-cooled screws, which cool the ash from 1600 degrees F to 450-500 degrees F. A total of six withdrawal points would be anticipated for this application.

The water-cooled screws are designed to use either cooling water (of boiler quality) or condensate. Two separate cooling streams are provided in each screw; one stream cools the internal screw mechanism and the other cools the trough.

3.4.1.10 Fuel Feed System

Fuel is introduced into the combustor through both the loop seals and through the front wall. Based on three cyclones, each cyclone being designed with a split loop seal, the loop seal feed system provides a total of six individual feed points to the rear wall of the combustor. Fuel is directed from the fuel transfer system to six vertical feed systems, one located above each loop seal return leg. Each vertical feed system consists of an isolation valve, expansion joint, vertical feed leg, and appropriate fluidizing system to maintain constant fuel feed.

The transfer system to provide fuel to the loop seals consists of a series of gravimetric feeders and belt conveyors. The design of the belt conveyors is proprietary, but it should be noted that belt conveyors have been selected in lieu of drag chain conveyors based upon superior performance of the belt conveyors relative to maintenance requirements.

The front wall feed consists of a gravity feed system operating under pressure. The design of a typical front wall feed system is shown in Figure 3-11. Fuel is directed from the silos through a vertical drop leg (for pressure isolation) complete with isolation valve and into two pressurized gravimetric feeders. From each gravimetric feeder, the fuel is split into two streams, each stream then entering the combustor by gravity. Thus, a total of four front wall feed points is provided. The design of the front wall feed ports to provide smooth flow of fuel into the combustor is a proprietary design.

FRONT WALL FUEL FEED SYSTEM

Figure 3-11

Coal sizing and surface moisture content are critical to successful operation of the fuel feed system. Required coal sizing is dependent on the characteristics of the fuel. Top size may vary from 1/4 to 1/2 inch. Allowable coal moisture content is also fuel dependent; the smaller the required coal particle size, the lower the allowable moisture content of the fuel to provide good flowability of the fuel. Typically, surface moisture contents below 10% are desirable.

3.4.1.11 Limestone Feed System

The limestone is fed into the combustor pneumatically. Limestone sizing is critical to achieving optimum calcium-to-sulfur molar ratios. Ideal limestone sizing would be 100% less than 1000 microns, and a mean limestone size of 150 microns. Moisture content must be maintained less than 1% to provide for acceptable flowability and transport.

Limestone from the day silos is metered using either a gravimetric or volumetric belt feeder. From the metering system, the limestone is directed through rotary valves to the pressurizing blower exit pipe. A total of four limestone blowers are provided, each blower providing limestone to four individual injection points on the combustor. Thus, the limestone flow from each blower would be split twice to provide the four injection point flows, resulting in a total of sixteen combustor injection points.

The limestone is pneumatically transported and injected into the combustor chamber through secondary air ports. The limestone injection pipe is located concentrically within the secondary air injection pipe at the point of injection. Six injection points are provided on both the front and rear walls, and two injection points are provided on each of the side walls.

3.4.1.12 Startup Burner System

A startup burner system using No. 2 oil is provided to heat the bed material to the required ignition temperature of the coal. The burners are located several feet above the grid plate, and are typically designed to provide a total heat input of approximately 30 percent MCR. For this application, a total of 10 to 12 burners is required to provide the total heat input and to distribute the heat properly within the combustion chamber.

Natural gas, if it is available, can also be used for startup fuel. Economics, based on geographical location should be used to make the choice.

Although #6 fuel oil has been used as a start-up fuel in many plants, there has been a reluctance to use it where baghouses are used for flue gas particulate clean-up, because of actual or perceived problems involving the blinding of the bags with oil soot. Pyropower claims that #6 fuel oil is now acceptable in their units, since they have found no problems with the use of #6 oil in their start-up burners, and do not require a baghouse bypass with the use of this oil.

3.4.1.13 Flyash Reinjection

To optimize limestone utilization and carbon burnout, a flyash reinjection system is provided.

Ash reinjection is accomplished by direct reinjection of the flyash from the ash silo discharge. The design of a typical reinjection system is shown schematically in Figure 3-12. Ash from the silo is discharged into a lock hopper system, from which it is reinjected back into the CFB combustion chamber through the use of a dense phase pneumatic system. the quantity of ash reinjected will vary with the type of fuel being burned, but generally ranges from 50% to 100% of the quantity of ash that would leave the air heater if reinjection were not being employed.

3.4.1.14 Sootblower System

Rotary and/or retractable sootblowers are provided for all convection pass superheat, reheat, economizer, and airheater surfaces. The sootblowers are located between tube banks, and are designed to provide complete cleaning coverage of all surfaces. Experience with CFB's has confirmed that surface cleaning is generally required at most once per shift due to the nonadhesive characteristics of CFB dust.

3.4.1.15 Particulate Collection

For this larger application, the decision regarding the use of pulsejet baghouse versus reverse air is primarily one of economics. Either system will meet the particulate emission levels specified. The use of electrostatic precipitators is not recommended due to the lack of operating experience on a wide range of fuels. The excellent CFB experience with baghouses to date makes the baghouse the system of choice at the present time.

At the 200 MWe CFB size either a pulse jet baghouse or reverse air baghouse could be used. Because the pulse jet would be designed at an air-to-cloth ratio of 4/1 and the reverse air would have a ratio of 2/1, the pulse jet would be more economical. Typically the capital cost of the reverse air bag collector would be approximately 20% greater. However, the use of pulse jets in utility applications is not yet widely accepted so a reverse air baghouse has been selected for this conceptual design. The 2/1 ratio is designed with two compartments out of service.

Flue gases from the boiler are conveyed through an inlet duct to the integral inlet plenum. The gases enter each hopper through a connecting elbow. Heavy particles drop directly into the hoppers and fine particles are conveyed upwards and are deposited on the inside of the filter bags. The bags are 12 inch diameter and 35 ft. long, and are constructed of fiberglass with a special acid resistant polymer finish which helps resist abrasion and lubricates the fabric for flexing purposes.

The clean gas passes through the fabric and exits the collector into the distribution plenum. The I.D. fan draws the clean gas from the outlet plenum and discharges it to the stack.

Figure 3-12

FLYASH REINJECTION SYSTEM

The particles collected on the inside of the bags are dislodged by a reverse air cleaning system. The reverse air fan pulls clean gas from the outlet plenum and redistributes it into a selected compartment. When this clean gas enters the compartment, the filter bags collapse, dislodging the particles into the hoppers. The dirty reverse gases flow into the inlet plenum to be redistributed for filtering to the remaining on-line compartments. The cleaning sequence is controlled by differential pressure transmitter override. Each reverse air fan has an outlet louver control damper and a butterfly isolation damper.

The baghouse has inlet butterfly flow control dampers and outlet poppet dampers. There is also one bypass poppet damper per baghouse which will open during a power failure or high temperature situation. Specific baghouse criteria are given in Table 3-7.

**Table 3-7
BAGHOUSE DESIGN**

• Inlet loading	7.50 gr/acf
• Outlet loading	0.014 gr/acf
• Pressure drop	10 in of water
• No. of compartments	10
• Quantity of bags per compartment	486
• Total No. of bags	4860
• Overall A/C ratio	1:6
• A/C ratio net (one module off-line)	1:95
• A/C ratio act. (two modules off-line)	2:2
• Hopper capacity	97,000 ft ³
• Overall dimensions	83 x 80 x 138 feet
• Reverse air power consumption	311 kW

3.4.2 Coal Handling System

The function of the coal handling system is to provide the equipment required for unloading, conveying, preparing, and storing the coal delivered to the plant. The scope of the system is from the coal receiving hoppers up to the boiler fuel inlet. A schematic diagram of the system is shown on the Coal Handling Flow Diagram, Figure 3-13.

3.4.2.1 Operation Description

The 6 x 0 inch bituminous coal will be delivered to the site by unit trains of 100-ton rail cars. The choice of delivery system is site-dependent and may involve other means, such as trucks or barges. For this study, unit trains were selected as the most appropriate. Each unit train consists of 100, 100-ton rail cars. The unloading will be done by a rotary car dumper with a hydraulic car positioner. The rotary car dumper will unload the coal to four receiving hoppers. Coal from each hopper is fed by a vibratory feeder onto a belt conveyor. The 6 x 0 inch coal is conveyed into a transfer building where a sample of coal is taken from each consignment by a coal sampling system. The main stream of coal feeds onto the coal stacker conveyor.

COAL HANDLING SYSTEM FLOW DIAGRAM
UNIT TRAIN UNLOADING

STATUS OF DRAWING		DEFINITION	
☒	APPROVED	REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.	
☐	PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPT. SUBJECT TO CHANGE.	
☐	CONCEPTUAL	REPRESENTS GENERAL CONCEPTS BASED ON ASSUMPTIONS. CHANGES COULD ENSUE.	
DRAFTING		ENGINEERING INTERFACES	
MADE	CHECKED	1	2
NDF		5/16/91	
PROJ DFG SUPR		ORIGINATOR	
		RE APPROVAL	DATE
		2/21	1/2/91
SCALE		NONE	
		808402-201

Figure 3-13

COAL FUEL REFERENCE PLANT
CONCEPTUAL DESIGN

DOE\METC DE-AC21-89MC25177

MECHANICAL

FLOW DIAGRAM

COAL HANDLING

GILBERT/COMMONWEALTH, INC.
ENGINEERS AND CONSULTANTS READING, PA

8402 1 241 302-001

0

DRAWING NUMBER

REV

The coal is fed into a traversing, double-wing stacker. The coal can be diverted to either the active pile boom conveyor or the dead pile boom conveyor. Each fixed boom conveyor has luffing capabilities for discharging the coal into a longitudinal pile. The double-wing stacker traverses on a track between the active and dead coal storage piles. Each coal storage pile is lined and provided with a runoff treatment system.

The dead pile boom conveyor discharges the coal onto the dead coal storage pile where a bulldozer moves and compacts the coal. The dead storage area will have an emergency reclaim hopper with a vibratory feeder feeding a belt conveyor. The conveyor discharges the reclaimed coal into the crusher building's, surge bin.

The active pile boom conveyor discharges the coal onto the active coal storage pile and is reclaimed via three reclaim hoppers. The coal is then discharged onto a belt conveyor.

The coal is conveyed from the reclaim hoppers to the crusher building and is fed into a two-compartment surge bin, provided with a vent filter to reduce dust emissions. Each compartment of the surge bin supplies coal to a full size vibratory feeder. At the inlet of each primary crusher, a bypass flop gate allows coal to be fed to either the primary crusher, or to a crusher by-pass when presized coal is being used. The primary crusher is a ring granulator type crusher while the secondary reduction of the coal is performed by an impactor type crusher.

Coal taken from the crusher discharge, is sampled by a two-strand, swing-hammer type sampling system before entering the boiler building.

Conveyors then feed the sized and sampled coal to either of the tripper conveyors. Each tripper discharges coal into a coal bunker for storage. The coal bunkers have two separate compartments, each with 16-hour total storage capacity. Conveyors are sized to fill the 16 hour bunkers in less than 6 hours while the plant is operating at full load. The fuel is discharged into the boiler via gravimetric feeders.

3.4.2.2 Technical Requirements and Design Basis

1. Coal Burn Rate

- Maximum Coal Burn Rate = 347,098 lb/h = 174 tph
(based on two boilers operating at 5 percent OP, VWO continuously)
- Average Coal Burn Rate = 250,000 lb/h = 125 tph
(based on Maximum Coal Burn Rate multiplied by an assumed capacity factor)

The coal is fed into a traversing, double-wing stacker. The coal can be diverted to either the active pile boom conveyor or the dead pile boom conveyor. Each fixed boom conveyor has luffing capabilities for discharging the coal into a longitudinal pile. The double-wing stacker traverses on a track between the active and dead coal storage piles. Each coal storage pile is lined and provided with a runoff treatment system.

The dead pile boom conveyor discharges the coal onto the dead coal storage pile where a bulldozer moves and compacts the coal. The dead storage area will have an emergency reclaim hopper with a vibratory feeder feeding a belt conveyor. The conveyor discharges the reclaimed coal into the crusher building's, surge bin.

The active pile boom conveyor discharges the coal onto the active coal storage pile and is reclaimed via three reclaim hoppers. The coal is then discharged onto a belt conveyor.

The coal is conveyed from the reclaim hoppers to the crusher building and is fed into a two-compartment surge bin, provided with a vent filter to reduce dust emissions. Each compartment of the surge bin supplies coal to a full size vibratory feeder. At the inlet of each primary crusher, a bypass flop gate allows coal to be fed to either the primary crusher, or to a crusher by-pass when presized coal is being used. The primary crusher is a ring granulator type crusher while the secondary reduction of the coal is performed by an impactor type crusher.

Coal taken from the crusher discharge, is sampled by a two-strand, swing-hammer type sampling system before entering the boiler building.

Conveyors then feed the sized and sampled coal to either of the tripper conveyors. Each tripper discharges coal into a coal bunker for storage. The coal bunkers have two separate compartments, each with 16-hour total storage capacity. Conveyors are sized to fill the 16 hour bunkers in less than 6 hours while the plant is operating at full load. The fuel is discharged into the boiler via gravimetric feeders.

3.4.2.2 Technical Requirements and Design Basis

1. Coal Burn Rate

- Maximum Coal Burn Rate = 347,098 lb/h = 174 tph
(based on two boilers operating at 5 percent OP, VWO continuously)
- Average Coal Burn Rate = 250,000 lb/h = 125 tph
(based on Maximum Coal Burn Rate multiplied by an assumed capacity factor)

2. Coal Delivered to the Plant by Unit Trains

- Three Unit Trains Per Week at Maximum Burn Rate
Two Unit trains Per Week at Average Burn Rate
- Each Unit Train Shall Have 10,000 Tons (100-Ton Cars) Capacity
- Unloading Rate = 900 tph
- Total Unloading Time Per Unit Train = 13 hours
- Conveying Rate to Storage Piles = 900 tph
- Reclaim Rate = 643 tph

3. Storage Piles with Liners, Run-off Collection, and Treatment Systems:

- Active Storage = 9,000 tons (72 hours)
- Dead Storage = 270,000 tons (90 days)

System design reflects the concern for maintenance of the coal handling equipment in that redundant equipment is recommended in critical areas. Reclaiming and conveying belts, crushers, and bunker loading equipment fall into this category.

Access platforms and catwalks are provided to permit the periodic greasing, lubrication, and observation of all rotating or moving equipment.

Conveyors have a main access aisle either on one side or, in the case of two conveyors, between them with grease fittings directed toward this aisle.

On conveyor bridges or in tunnels, small access platforms or aisles on the outboard side give access to idlers for replacement. Monorails serve the conveyor head shafts and their accompanying drive assembly (gear and motor), permitting the removal of heavy pieces to grade.

The crusher building has monorails serving each crusher for rotor, motor, and drive assembly maintenance. For installations with a rotary car dumper, monorails serve the hydraulic pumps that operate the car positioner. A maintenance aisle adjacent to the pumps and their monorail system supports forklift truck traffic.

A hatch, strategically located in the car dumper, allows access to the lowest level in that structure. Equipment below the hoppers is winched or skidded into the hatch area, then hoisted to the surface with a "cherry picker" or truck crane.

3.4.3 Limestone Handling System

The function of the limestone handling system is to provide the equipment required for conveying, preparing, and storing the limestone delivered to the plant. The scope of the system is from the receiving hopper up to the boiler limestone inlet. A schematic diagram of the limestone flow is shown on the Limestone Handling Flow Diagram, Figure 3-14.

3.4.3.1 Operation Description

Limestone will be delivered to the plant by 25-ton trucks.

The limestone is unloaded into a receiving hopper. The limestone in the receiving hopper is then fed onto a belt conveyor via a vibrating feeder and then fed onto a tripper conveyor. The tripper conveyor feeds the material to a tripper, which distributes the limestone within the "A"-frame storage building. The limestone is reclaimed within the "A"-frame building by a portal scraper reclaimer. The portal scraper reclaimer transfers limestone onto a belt conveyor which feeds limestone onto a tripper conveyor located in the limestone preparation building. The tripper discharges limestone into a four-section, 200-ton surge bin, equipped with a vent filter system, which supplies four, full size rod mill (BMR) units. The BMR units are fed via vibratory feeders.

The BMR units pulverize the limestone to 1,000 microns and discharge the reduced material onto two belt conveyors. To prevent fugitive dust, a discharge dust collection system is provided for each set of BMR units. The dust collected is then discharged onto each belt conveyor.

The conveyors transfer the pulverized limestone to limestone storage silos, each equipped with a vent filter. Each limestone silo supplies limestone to a separate pneumatic, dense-phase boiler feeding system.

Each dense-phase transporter conveys the pulverized limestone to limestone day bins. Each limestone day bin discharges limestone into a gravimetric feeder which, in turn, meters the proper amount of limestone into the boiler. Rotary valves, coupled with properly designed venting systems to relieve any rotary valve leakage back to the limestone silo, will allow for material transfer without blow-back due to boiler pressure.

3.4.3.2 Technical Requirements and Design Basis

1. Limestone Usage Rate:
 - Maximum Limestone Usage Rate = 79,344 lb/h = 40 tph
(based on two boilers operating at 5% OP, VWO continuously)
 - Average Limestone Usage Rate = 57,000 lb/h = 28.5 tph
(based on Maximum Limestone Usage Rate multiplied by assumed capacity factor)
2. Limestone Delivered to the Plant by 25-Ton Dump Trucks

CC

ENSE
HASE
RANSPORTER
(YP.)

Figure 3-14

L FUEL REFERENCE PLANT
CONCEPTUAL DESIGN
METC DE-AC21-89MC25177

ANICAL FLOW DIAGRAM
LIMESTONE HANDLING

GILBERT/COMMONWEALTH, INC.
ENGINEERS AND CONSULTANTS READING, PA

02 1 462 302-001

0

DRAWING NUMBER

REV

3. Total Number of Trucks Per Day = 39
4. Total Unloading Time Per Day = 6.5 hours
5. Frequency of Trucks Per Day = 10 min./truck
6. Receiving Hopper Capacity = 35 tons
7. Limestone Received = 2" x 0"
8. Limestone Storage Capacity = 25,920 tons (30 days supply @ maximum burn rate)
9. Storage Building Size = 363 ft. x 90 ft. x 40 ft. high.
10. Day Bin Storage = 320 Tons (8 hr supply @ maximum burn rate)
11. Silo Storage Capacity = 2880 Tons (72 hr supply @ maximum burn rate)
12. Conveying Rate to Storage = 225 tph

Access platforms and catwalks are provided to permit the periodic greasing, lubrication, and observation of all rotating or moving equipment.

Conveyors have a main access aisle on one side with grease fittings directed toward this aisle.

On conveyor bridges or in tunnels, small access platforms or aisles on the outboard side give access to idlers for replacement. Monorails serve the conveyor head shafts and their accompanying drive assembly (gear and motor), permitting the removal of heavy pieces to grade.

A hatch, strategically located adjacent to the truck receiving hopper, allows access to the lowest level in that structure. Equipment below the hoppers is winched or skidded into the hatch area, then hoisted to the surface with a "cherry picker" or truck crane.

3.4.4 Ash Handling System

The function of the ash handling system is to provide the equipment required for conveying, preparing, storing, and disposing the flyash and bottom ash produced on a daily basis by the boiler. The scope of the system is from the boiler baghouses, air heater hopper collectors, and ash coolers up to the storage silos and truck filling stations for removal. A schematic diagram of the flyash and bottom ash flow is shown on the Ash Handling Flow Diagram, Figure 3-15.

2 of 3

STATUS OF DRAWING		DEFINITION		COA
☒	APPROVED	REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.		DOE\MECHA
☐	PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPT. SUBJECT TO CHANGE.		
☐	CONCEPTUAL	REPRESENTS GENERAL CONCEPTS BASED ON ASSUMPTIONS. CHANGES COULD ENSUE.		
DRAFTING		ENGINEERING INTERFACES		
MADE	CHECKED	1	2	3
NDF		10/21/77		
PROJ DFG	SUPR			
ORIGINATOR		RE APPROVAL	DEPT	DATE
SCALE		W.O.	088492-281	840

CC

Figure 3-15

FUEL REFERENCE PLANT CONCEPTUAL DESIGN ETC DE-AC21-89MC25177	
ICAL	FLOW DIAGRAM
ASH HANDLING	

GILBERT/COMMONWEALTH, INC.	
ENGINEERS AND CONSULTANTS	READING, PA

2 1 450 302-001

0

DRAWING NUMBER

REV

3.4.4.1 Operation Description

To determine the flyash and bottom ash handling system conveying rates, a 50% split of the total ash generated by the boiler has been assumed. The conveying rate is then assumed to be twice the generation rate for each, thereby sizing each system to be capable of handling 100% of the ash generated. Separate vacuum conveying systems are provided for flyash and bottom ash conveying.

The flyash collected in the baghouse is conveyed to the flyash storage silo where the separation equipment discharges the flyash into the silo. The separation equipment includes both a primary and a secondary collector. Both collectors are supported by the silo roof and connected to a vacuum pump. A spare vacuum pump is provided for redundancy.

The primary collector extracts all large flyash particles and discharges them through a secondary collector into a flyash silo, equipped with a vacuum breaker and vent filter system.

Flyash is discharged through a wet unloader, which conditions the flyash and conveys it through a telescopic unloading chute into a truck for disposal.

The bottom ash from each boiler is cooled by an ash cooler and fed into a clinker grinder. The clinker grinder is provided to break up any clinkers that may form in the system due to air leaks. From the clinker grinders the bottom ash is discharged onto a chain conveyor and fed to a surge bin. The surge bin is equipped with a vent filter for dust collection. A separate vacuum conveying system transports the bottom ash from the surge bin into a primary separator.

The primary separator extracts all large bottom ash particles, which are discharged through a secondary collector into a flyash silo, equipped with a vacuum breaker and vent filter system. Both separators are supported by the silo roof and connected to a vacuum pump.

The bottom ash is discharged through a wet unloader which conditions the bottom ash and conveys it through a telescopic unloading chute into a truck for disposal.

Either silo can be used for ash removal. The control loop is designed to bypass silo conveying lines in the case of a line failure or silo equipment damage. Redundant vacuum pumps can be accessed for either conveying loop.

A minimum 5 foot clearance between the discharge flange of the ash cooler and the floor must be provided.

3.4.4.2 Technical Requirements and Design Basis

A. Bottom Ash:

1. Bottom Ash And Flyash Rates:
 - Bottom Ash Generation Rate = 26 tph
(two boilers)
 - Flyash Generation Rate = 26 tph
(two boilers)
2. Ash Cooler Capacity = 52 tph
3. Clinker Grinder Capacity = 52 tph
4. Chain Conveying Rate To Storage Bin = 52 tph
5. Surge Bin Capacity = 25 tons (half hour storage)
6. Surge Bin Fill Up Time = 1/2 hour
7. Conveying Rate To Primary and Secondary Collectors = 52 tph
8. Bottom Ash Silo Capacity = 1,860 tons (72 hour storage)
9. Bottom Ash Silo Fill Up Time = 37.2 hours
10. Wet Unloader Capacity = 150 tph (ten minutes per truck)

B. Flyash:

1. Baghouse Collection Rate (2-Boilers) = 26 tph
2. Conveying Rate From Baghouse to Primary And Secondary Separators =
52 tph.(Maximum Removal Rate = 2 Times Ash Rate)
3. Flyash Silo Capacity = 1,860 Tons (72 Hour Storage)
4. Flyash Silo Fill Up Time = 37.2 hours
5. Wet Unloader Capacity = 150 tph

3.5 BALANCE OF PLANT

The following section provides a description of the plant outside the FBC boiler system and its auxiliaries. Flow diagrams for the balance of plant are provided in Figure 3-16, Main, Reheat and Extraction Steam, and Figure 3-17, Condensate, Feedwater and Circulating Water.

3.5.1 Turbine-Generator and Auxiliaries

The turbine consists of an high pressure (HP) section, intermediate pressure (IP) section and two double flow low pressure (LP) sections all connected to the generator by a common shaft. Main steam from the boilers passes through the stop valves, control valves and enters the HP turbine at 2400 psig/1000°F. The steam initially enters the turbine near the middle of the high pressure span, flows through the turbine and returns to the boilers for reheating. The reheat steam flows through the reheat stop valves, intercept valves and enters the IP section at 464 psig/1000°F. After passing through the IP section, the steam enters a cross-over pipe which transports the steam to the two LP sections. The steam divides into four paths and flows through the LP sections exhausting downward into the condenser.

Turbine bearings are lubricated by a closed loop water cooled pressurized oil system. The oil is contained in a reservoir located below the turbine floor. During startup or unit trip the oil is pumped by an emergency oil pump mounted on the reservoir. When the turbine reaches 95 percent of synchronous speed, oil is pumped by the main pump mounted on the turbine shaft. The oil flows through water cooled heat exchangers prior to entering the bearings. The oil then flows through the bearings and returns by gravity to the lube oil reservoir.

Turbine shafts are sealed against air in-leakage or steam blow out using a labyrinth gland arrangement connected to a low pressure steam seal system. During startup seal steam is provided from the main steam line. As the unit increases load HP turbine gland leakage provides the seal steam. Pressure regulating valves control the gland leader pressure and dump any excess steam to the condenser. A steam packing exhauster maintains a vacuum at the outer gland valves to prevent leakage of steam into the turbine room. Any steam collected is condensed in the packing exhauster and returned to the condensate system.

The generator stator is cooled with a closed loop water system consisting of circulating pumps, shell and tube heat exchangers, filters and deionizers, all skid mounted. Water temperature is controlled by regulating heat exchanger bypass water flow. Stator cooling water flow is controlled by regulating stator inlet pressure.

The generator rotor is cooled with a hydrogen gas recirculation system using fans mounted on the generator rotor shaft. The heat absorbed by the gas is removed as it passes over finned tube gas coolers mounted in the stator frame. Stator cooling water flows through these coils. Gas is prevented from escaping at the rotor shafts using a closed loop oil seal system. The oil seal system consists of a storage tank, pumps, filters and pressure controls, all skid mounted.

4

2

o

1

1

0

4

1

Figure 3-16

<table border="1"> <tr> <td>A</td> <td>CR</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		A	CR														
A	CR																
REVISIONS																	
DATE OF DRAWING	SECTION																
☒ APPROVED	REVIEWED AND APPROVED DESIGN ON PAPER UNDER "HOLD" REVIEW PRELIMINARY DRAW																
☐ PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPT SUBJECT TO CHANGE																
☐ CONCEPT	REPRESENTS GENERAL CONCEPT BASED ON ASSUMPTIONS CHANGES COULD BE MADE																
COAL FUEL REFERENCE PLANT CONCEPTUAL DESIGN DOE/METC DE-AC21-89MC-29177																	
MECHANICAL P & ID																	
MAIN, REHEAT & EXTRACTION STEAM
GLENN/CONSONHEAL, INC. ENGINEERS AND ARCHITECTS																	
8402 1 540 302-002 0

CONDENSATE, FEEDWATER & CIRCULATING WATER

A

B

C

D

E

F

G

H

J

K

RECIRC. TO
CONDENSER
HOTWELL

Figure 3-17

REV	DATE	BY	CHKD	APPD
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

REVISIONS

STATUS OF DRAWING	DEFINITION
☒ APPROVED	REVIEWED AND APPROVED DESIGN FOR PROCEEDING TO THE NEXT PHASE OF DESIGN
☐ PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPTS SUBJECT TO CHANGE
☐ CONCEPTUAL	REPRESENTS GENERAL CONCEPTS BASED ON ASSUMPTIONS, SUBJECT TO CHANGE
COAL FUEL REFERENCE PLANT CONCEPTUAL DESIGN DOE/METC DE-AC21-89MC-28177	
MECHANICAL P & ID	
CONDENSATE, FEEDWATER & CIRCULATING WATER
GILBERT/CONDON/HEALY, INC. <small>DESIGNERS AND ENGINEERS</small>	
DATE	10/10/89
BY	J. L. L. L.
CHKD	
APPD	
NO	8402 1 540 302-001 0
DATE	10/10/89

3.5.1.1 Operation Description

The turbine stop valves, control valves, reheat stop valves and intercept valves are controlled by an electro-hydraulic control system.

The turbine is designed to operate at constant inlet steam pressure over the entire load range and is capable of being converted in the future to sliding pressure operation for economic unit cycling.

3.5.1.2 Technical Requirements and Design Basis

Design Basis

1. Full Load Heat Balance - 8402-1-400-314-002
2. 5% Overpressure, VWO Heat Balance - 8402-1-400-314-003

Components

1. Turbine Generator

- Quantity 1
- Type Tandem compound, four flow exhaust, single reheat, 26 inch test stage bucket with direct connected hydrogen cooled generator

Design Data

- Guarantee Rating 455,000 kw
- Max. Expected Rating (5% O.P. VWO) 476,000 kw
- Speed 3600 rpm
- Throttle Pressure
 - Guarantee 2400 psig
 - 5% O.P. 2520 psig
- Main Steam Temp. 1000° F
- Reheat Steam Temp. 1000° F
- Throttle flow
 - Guarantee 2,867,000 lb/h
 - 5% O.P. 3,161,000 lb/h
- Exhaust Pressure 2.5 inch Hg
- Number of Extractions 7

2. Auxiliary Equipment

- Bearing Lube Oil System
- Gland Steam Seal System

- Generator Cooling Water System
- Generator Hydrogen Cooling System
- Hydrogen Seal Oil System
- Electro-Hydraulic Control System
- Exciter

3.5.2 Condensate and Feedwater Systems

Condensate

The function of the condensate system is to pump condensate from the condenser hotwell through the steam packing exhauster and four stages of low pressure (LP) feedwater heaters to the deaerator.

The system consists of one main condenser; three 50 percent capacity, motor driven vertical condensate pumps with eddy-current variable speed electric drives; one gland steam exhauster; four stages of feedwater heaters with the first two stages located in the condenser neck; one deaerator with storage tank; three 50 percent capacity vacuum pumps; and two 250,000 gallon condensate storage tanks.

The first two stages of feedwater heating are two 50 percent, parallel flow, duplex, U-tube exchangers installed in the condenser necks. Heaters Nos. 3 and 4 are 100% capacity, shell and U-tube heat exchangers. The fifth stage is the deaerator.

Condensate is delivered to a common discharge header through three separate pump discharge lines, each with a check valve and a gate valve. A common minimum flow recirculation line discharging to the condenser is provided to maintain minimum flow requirements for the gland steam exhauster and the condensate pumps.

Each LP feedwater heater is provided with inlet/outlet isolation valves and a full capacity bypass. LP feedwater heater drains cascade down to the next lowest extraction pressure heater and finally discharge into the condenser. Normal drain level in the heaters are controlled by pneumatic level control valves. High heater level dump lines discharging to the condenser are provided for each heater for turbine water induction protection. Dump line flow is controlled by pneumatic level control valves.

Feedwater

The function of the feedwater system is to pump feedwater from the deaerator storage tank through two stages of high pressure (HP) feedwater heaters to the economizer inlet on the boilers.

The system consists of three 50 percent capacity motor driven boiler feed booster pumps; two 60 percent capacity turbine driven boiler feed pumps; one 20 percent capacity motor driven startup boiler feed pump and two stages of high pressure feedwater heaters.

Each pump is provided with inlet and outlet isolation valves, outlet check valves and individual minimum flow recirculation lines discharging back to the deaerator storage tank. The recirculation flow is controlled by pneumatic flow control valves. In addition, the suctions of the boiler feed booster pumps are equipped with simplex strainers.

The booster pump discharges are manifolded so that any booster pump can feed the boiler feed pumps.

Each HP feedwater heater is provided with inlet/outlet isolation valves and a full capacity bypass. HP feedwater heater drains cascade down to the next lowest extraction pressure heater and finally discharge into the deaerator. Normal drain level in the heaters are controlled by pneumatic level control valves. High heater level dump lines discharging to the condenser are provided for each heater for turbine water induction protection. Dump line flow is controlled by pneumatic level control valves.

Downstream of the heaters the boiler feed line splits to feed each boiler's economizer.

3.5.2.1 Operation Description

Condensate

Condenser vacuum pump operation is initiated by the operator at local panels. After initiation, vacuum pump operation is automatic throughout the design range of the vacuum pumps. The local panels include alarms for monitoring the performance of the vacuum pumps, with common annunciation in the main control room.

After the initial vacuum is established, and condensate system valves are aligned for normal operation, the system is monitored from the main control board for startup, shutdown, and all load swings.

The condensate pumps and heater bypass valves are controlled from the main control room.

The condensate transfer pump is arranged for local starting and stopping only, with automatic minimum flow recirculation.

Feedwater

The boiler feed booster pumps and boiler feed pumps are controlled by the DCS. All critical system malfunctions are alarmed.

In the event of heater failure, automatic controls are actuated to prevent turbine water induction damage. An individual heater can be isolated and bypassed from the main control room.

During a startup, the motor driven startup boiler feed pump is used to allow a boiler to be fired. When main steam becomes available, a turbine driven feed pump can be operated to bring the turbine-generator on line. As the turbine exceeds 60 percent load, the steam source automatically switches over to IP turbine extraction. If one of the turbine driven feed pumps fails, the motor driven startup feed pump can be used to supply approximately 20 percent plant load

3.5.2.2 Technical Requirements and Design Basis

Design Basis

1. The systems are sized to pass the flow rates occurring at 5 percent overpressure, valves wide open condition.
2. All piping is designed in accordance with ANSI B31.1. All valves are designed in accordance with ANSI B16.34.
3. All heaters, the deaerator/storage tank, and the condenser are designed in accordance with ASME BPVC Section VIII Div. 1 and/or HEI Standards.
4. The condensate storage tank is designed in accordance with AWWA D100.

Components

Condenser

• Quantity	1
• Type	Two shell, transverse with divided waterbox for each shell
• Steam Condensate at	2,050,000 lb/h
• 1029.9 Btu/lb	
• Net Heat Transfer	$2,100 \times 10^6$ Btu/h
• Circulating Water Flow	280,000 gpm
• Circulating Water Inlet Temp.	75° F
• Circulating Water Temp. Rise	15° F
• Terminal Temp Diff (max)	18.7° F
• Condenser Shell Pressure	2.5 inch Hg. abs.
• Tube Material	90-10 CuNi (main section) 70-30 CuNi (air removal section)

Condensate Pumps

• Quantity	3
• Type	Vertical canned centrifugal with eddy current variable speed drive

• Capacity	2000 gpm
• Total Head	850 ft.
• Horsepower	600 hp
• Speed (max)	1750 rpm
• Impeller Material	Bronze

L. P. Feedwater Heaters

• Quantity	4
• Type	Horizontal, 2 pass, U-tube
• Feedwater Flow	2,672,000 lb/hr
• Terminal Temp Diff	+ 5° F
• Tube Material	Welded type 304 S.S. with .03% max carbon

Heater No. 1A/1B (Combined Flows)

• Feedwater Inlet Temp.	110.2° F
• Steam Enthalpy	1106.9 Btu/lb
• Shell Sat. Temp/Pressure	165.3° F/5.4 psia
• Drains Cooler Approach	+ 5° F
• Drains Inlet Flow	381,000 lb/h
• Drains Inlet Enthalpy	143.3 Btu/lb
• Shell Design Condition	50 psig/300° F
• Tube Design Condition	500 psig/300° F

Heater No. 2A/2B (Combined Flows)

• Feedwater Inlet Temp	160.3° F
• Steam Enthalpy	1202.3 Btu/lb
• Shell Sat. Temp/Pressure	233.9° F/22.3 psia
• Drain Cooler Approach	+ 15° F
• Drain Inlet Flow	222,000 lb/h
• Drains Inlet Enthalpy	212.4 Btu/lb
• Shell Design Conditions	100 psig/400° F
• Tube Design Conditions	500 psig/250° F

Heater No. 3

• Feedwater Inlet Temp	228.9° F
• Steam Enthalpy	1243.5 Btu/lb
• Shell Sat. Temp/Pressure	262.9° F/37.2 psia
• Drains Cooler Approach	+ 15° F
• Drains Inlet Flow	150,000 lb/h
• Drains Inlet Enthalpy	334.4 Btu/lb
• Shell Design Conditions	100 psig/500° F

- Tube Design Conditions 500 psig/350° F

Heater No. 4

- Feedwater Inlet Temp 257.9° F
- Steam Enthalpy 1328.2 Btu/lb
- Shell Sat. Temp/Pressure 322.4° F/92.7 psia
- Shell Design Conditions 150 psig/650° F
- Tube Design Conditions 500 psig/400° F

Deaerator and Storage Tank

- Quantity 1
- Type Horizontal, spray tray type with internal direct contact stainless steel vent condenser and storage tank
- Design Condition 200 psig/400° F
- Outlet Feedwater Flow 3,160,000 lb/h
- Saturation Temp/Pressure 362° F/156.9 psia
- Steam Enthalpy 1380.5 Btu/lb
- Steam Flow 110,000 lb/h
- Condensate Inlet Flow 2,672,000 lb/h
- Condensate Inlet Enthalpy 287.9 Btu/lb
- Drains Inlet Flow 378,000 lb/h
- Drains Inlet Enthalpy 358.3 Btu/lb
- Storage Tank Live Volume 40,000 gal.

Vacuum Pumps

- Quantity 2
- Type Rotary-Water sealed
- Holding Capacity at 1 inch Hg abs 20 scfm
- Hogging Capacity at 15 inch Hg abs 2000 scfm
- Speed 470 rpm
- Horsepower 100 hp
- Construction iron

Condensate Storage Tanks

- Quantity 2
- Type Field fabricated dome top
- Capacity 250,000 gallons
- Diameter 40 ft.
- Height 30 ft.

- Internal Coatings

Epoxy-phenolic-Plastic 7155 or equal

Boiler Feed Booster Pumps

- Quantity 3
- Type Horizontal split case
- Capacity 3000 gpm
- Total Head 400 ft.
- Horsepower 350 hp
- Speed 1750 rpm

Boiler Feed Pumps - Turbine Driven

- Quantity 2
- Type Staged high pressure centrifugal
- Capacity 4,000 gpm
- Total Head 7,300 ft.
- Horsepower 10,000 hp
- Speed 5,500 rpm

Startup Boiler Feed Pumps - Motor Driven

- Quantity 1
- Type Staged high pressure centrifugal
- Capacity 1,500 gpm
- Total Head 7,300 ft.
- Horsepower 4,000 hp
- Speed 3,600 rpm

HP Feedwater Heaters

- Quantity 2
- Type Horizontal 2 pass U-tube
- Feedwater Flow 3,161,000 lb/h (total)
- Terminal Temp Diff + 0° F
- Drains Cooler Approach + 15° F
- Tube Material Welded type 304 S.S. with .03% max carbon

Heater No. 6

- Feedwater Inlet Temp 369.3° F
- Steam Enthalpy 1450.4 Btu/lb
- Shell Sat. Temp./Pressure 410° F/276.6 psia
- Drains Inlet Flow 266,000 lb/h

- Drains Inlet Enthalpy 402.6 Btu/lb
- Shell Design Condition 300 psig/(900° F skirt/650° F shell)
- Tube Design Condition 3600 psig/450° F

Heater No. 7

- Feedwater Inlet Temp 410° F
- Steam Enthalpy 1307.3 Btu/lb
- Shell Sat. Temp./Press 480° F/566.4 psia
- Shell Design Condition 650 psig/650° F
- Tube Design Condition 3600 psig/550° F

3.5.3 Main, Reheat and Extraction Steam Systems

Main and Reheat Steam

The function of the main steam system is to convey main steam from both boiler superheater outlets to the high pressure turbine stop valves.

The function of the reheat system is to convey steam from the HP turbine exhaust to both boiler reheaters and from the boiler reheater outlets to the IP turbine stop valves.

Main steam at approximately 2620 psig/1000°F exits each boiler superheater through a motor operated stop/check valve and a motor operated gate valve, and combines into a single line feeding the HP turbine.

Cold reheat steam at approximately 517 psig/625°F exits the HP turbine, splits into two paths, one for each boiler, flows through a motor operated isolation gate valve, a flow control valve and enters each boiler reheater.

Hot reheat at approximately 488 psig/1000°F exits each boiler reheater through a motor operated gate valve and combines into a single line feeding the IP turbine.

A branch line off the main steam line feeds the two boiler feed pump turbines during unit operation up to 60 percent load.

A two stage turbine bypass system is provided for each boiler. Each system permits bypassing steam around the HP turbine and for bypassing steam around the IP/LP turbine. The system is utilized to start up one boiler while matching temperatures with the other boiler and the turbine, and for restarting when plant has tripped.

A branch connection from the cold reheat piping supplies steam to feedwater heater No. 7.

Extraction Steam

The function of the extraction steam system is to convey steam from turbine extraction points through the following routes:

- from HP turbine to Heater 7
- from IP turbine to Heater 6
- from IP turbine to Deaerator
- from LP turbine to Heaters 1, 2, 3 and 4

The turbine is protected from overspeed on turbine trip, from flash steam reverse flow from the heaters through the extraction piping to the turbine. This protection is provided by positive closing, balanced disc non-return valves located in all extraction lines except the lines to the low pressure feedwater heaters in the condenser neck. The extraction non-return valves are located only in horizontal runs of piping and as close to the turbine as possible.

Water is prevented from entering the turbine through the use of motor-operated gate valves in each branch of the extraction piping. The header to the deaerator and boiler feed pump turbines has two extraction non-return valves, and the lines to the boiler feed pump turbines each have a manually operated gate valve and a swing check valve. The motor-operated gate valves close automatically on an emergency high-level signal from a level switch located on the heater being supplied with steam or the respective line drain pot. The emergency high water level switch will also energize the solenoid of the air cylinder to close the non-return valve, and actuate an alarm in the control room. The motor-operated gate valve position limit switch opens the drain valves on the corresponding extraction steam drain manifold, which drains to the condenser. The valves cannot be returned to their normal positions until the emergency high water level switch indicates that the water level has fallen below the emergency level.

The turbine trip signal automatically trips the non-return valves through relay dumps. The remote manual control for each heater level control system is used to release the non-return valves to normal check valve service when required to restart the system.

3.5.3.1 Operation Description

All motor operated isolation valves can be operated locally or from the main control room. In the event of high water level in the respective steam line, the valve closes automatically.

All extraction non-return valves close automatically either on a unit trip or when high water level in the respective steam line is detected.

All pneumatic drain pot valves operate automatically during unit startup or on high level.

3.5.3.2 Technical Requirements and Design Basis

Design Basis

1. The systems are sized to pass the flow rates occurring at 5 percent overpressure, valves wide open condition (VWO).
2. All piping is designed in accordance with ANSI B31.1. All valves are designed in accordance with ANSI B16.34.
3. The main steam line is designed for a total pressure drop of 100 psi at VWO. while limiting velocities to 20,000 fpm.
4. The cold reheat line is designed for a total pressure drop of 10 psi at VWO. while limiting velocities to 15,000 fpm.
5. The hot reheat line is designed for a total pressure drop of 20 psi at VWO. while limiting velocities to 20,000 fpm.
6. The extraction steam lines are designed for a total pressure drop of 5 percent of the extraction nozzle pressure while limiting velocities to 1,000 fpm per inch of pipe I.D.

3.5.4 Circulating Water System

The function of the circulating water system is to supply cooling water to condense the main turbine exhaust steam.

The system consists of one rectangular counterflow, concrete mechanical draft cooling tower; two 50% capacity vertical circulating water pumps; and carbon steel cement lined interconnecting piping.

The condenser is a twin shell type with divided water boxes arranged for series flow of the circulating water. There are two separate circulating water circuits in each box. The water enters condenser A, then reverses flow into condenser B, where the discharge returns to the cooling tower. There are two separate cooling circuits through the condensers. One half of each condenser can be removed from service for cleaning or plugging tubes. This can be done during normal operation at reduced load.

The warm water leaving the condenser is passed through the cooling tower to transfer heat to the atmosphere by evaporation. The air flow is induced by the fans. Drift eliminators are used to remove entrained water droplets. Makeup water, to replace evaporated water, blowdown and drift, enters the cooling tower basin through a motor operated, automatic, level control valve. The tower is equipped with a fill bypass system to prevent freeze-up during cold weather.

The cooling tower discharge water flows to the circulating water pumps. A double set of removable screens, which remove large objects such as leaves, sticks, logs and ice to protect the circulating water pumps and condenser tubes, is installed upstream of the pump suction. These may be pulled out one at a time for cleaning as required. A bubbler type pressure differential switch monitors high pressure drop as an indication of plugging.

Each pump has a motor operated discharge butterfly valve. The pump discharge valve is interlocked with the pump motor starting circuit so that the valve is first opened approximately 15°. The motor starts automatically when the valve reaches that position. After the pump is up to speed, the system is full and stable flow is established, the valve is opened to 90°. On shutdown, the valve closes fully and as it passes the 15° position, trips the pump automatically. The valve closes automatically on loss of power to avoid hydraulic surges.

3.5.4.1 Operation Description

Prior to operation, the circulating water lines and tower basin are filled using the tower makeup system. During filling the piping and condenser water boxes are manually vented.

Normal operation is with two circulating water pumps in service. One pump can be used during startup, during periods of reduced load or when half of each condenser shell is out of service for inspection or tube plugging.

3.5.4.2 Technical Requirements and Design Basis

Design Basis

1. The system is sized to pass the flow rates occurring at 5 percent overpressure, VWO condition.
2. The circulating water piping is sized for a maximum velocity between 9 to 10 fps.
3. The cooling tower is designed in accordance with CTI standards.

Components

Cooling Tower

• Quantity	1
• Type	Rectangular, counter flow, concrete, mechanical draft
• Water Flow	280,000 gpm
• Inlet Temp.	90° F
• Outlet Temp.	75° F
• Wet Bulb Temp.	52° F

Circulating Water Pumps

• Quantity	2
• Type	Vertical wet pit
• Capacity	140,000 gpm
• Total Head	100 ft.
• Horsepower	4,200 hp
• Speed	450 rpm
• Impeller Material	316 S.S.

3.5.5 Miscellaneous BOP Systems

Many ancillary systems and subsystems support the operation of a power plant such as presented in this report. Descriptions of some of the more prominent systems are described within this section, including liquid waste treatment, auxiliary boiler, fuel oil, service and instrument air, and service water.

3.5.5.1 Liquid Waste Treatment

Industrial wastewater from station operations will be collected, treated in an on-site treatment system, and discharged to an adjacent stream. The industrial waste treatment system will treat wastewater from the following sources:

- Coal pile leachate and runoff
- Limestone storage runoff
- Contaminated yard drains
- Maintenance cleaning wastes
- Cooling tower blowdown
- Demineralizer regenerants
- Filter backwash
- Miscellaneous low volume wastes

The treated effluent will meet U.S. Environmental Protection Agency standards for total suspended solids, oil and grease, pH, and miscellaneous metals.

The industrial waste treatment system employs the following unit processes and operations:

Flow equalization

Contaminated rainfall runoff from the 10 yr - 24 hr. storm is collected in a synthetic-membrane lined 700,000 gallon earthen basin (approximate 167 ft x 80 ft x 7 ft deep) and is pumped to the treatment system at a controlled rate. This basin also equalizes flow from maintenance cleaning wastes. In addition, the 4500 gallon raw waste sump has sufficient surge capacity to equalize

short-term peak flows such as filter backwashes. Three raw waste pumps are provided, each 280 gpm.

Neutralization

Acidic wastewater is neutralized with hydrated lime in a two-stage system. Each neutralization tank is a 6000 gallon fiberglass tank providing a 7.5 minute reaction time at design flow. Each tank is equipped with a pH probe and controller which automatically feeds lime slurry to the respective tank to control pH. Each tank is equipped with a fixed-mount mixer to completely mix lime slurry with the wastewater. An integral lime storage silo/lime slurry makeup system with 50 ton lime silo, a 0-1000 lb/h dry lime feeder, a 5,000 gallon lime slurry tank, slurry tank mixer, and 25 gpm lime slurry feed pumps is provided.

Oxidation

Air is fed to the second stage neutralization tank through a sparge pipe to oxidize any remaining ferrous iron to the ferric state. The air is supplied by a 50 scfm compressor which also furnished air for operation of sludge pumps and the filter press.

Flocculation

Flocculation to promote particle size growth is provided in a 7,600 gallon fiberglass tank with a 10 minute retention time at design flow. The tank is equipped with a low rpm, variable speed agitator. Polymer emulsion is drawn directly from a 55-gallon drum and is diluted and fed to the flocculation tank by a 100 gallon/h polymer feed unit.

Clarification/Thickening

Overflow from the flocculation tank enters a plate-type clarifier/thickener for suspended solids separation. Solids settle between the inclined plates to the thickener zone while the clarified supernatant rises from the plates to discharge through flow-distribution orifices. The integral thickener section includes a picket-fence type scraper mechanism which further concentrates the sludge.

Sludge Dewatering

Thickener sludge is pumped to an 8,000 gallon holding tank which allows one-shift operation of the dewatering equipment and provides some further thickening. From the holding tank, the sludge is pumped to a plate-and-frame filter press for dewatering. The filter press produces a sludge cake of 35 percent by weight dry solids or higher. Filter press cake is dropped from the press into a sludge dump truck or dumpster. Filtrate is returned to the raw waste sump.

The coal pile runoff basin, the raw waste sump, and the lime storage and feed system are located outdoors. The remaining treatment system components are located in a heated building.

3.5.5.2 Auxiliary Boiler Steam System

The auxiliary boiler supplies steam to all plant components normally requiring steam during periods of unit or station shutdown, startup, or in certain cases, normal plant operation. The major interfacing components and systems with the auxiliary boiler are the feedpumps, deaerator, fuel oil storage and supply, forced-draft fan(s), and stack.

The sizing and selection of steam conditions for the auxiliary boiler were based on a review of potential system demands, including such components as fuel oil atomizers, fuel oil tank heating, turbine seals, building heating, etc. An auxiliary watertube boiler sized to produce 100,000 lb/h of 400 psig/650°F superheated steam was selected for this installation.

3.5.5.3 Fuel Oil Supply System

A fuel oil storage and supply system sized to accommodate the boiler startup burners and auxiliary boiler was included in the estimate. Number 2 grade fuel oil was selected for use due to anticipated usage and cost considerations, as well as providing future fuel flexibility benefits.

A storage tank capacity of 300,000 gallons was selected, providing an on-site supply of approximately 15 days when firing the auxiliary boiler at maximum rating. Delivery of fuel oil to the station site is designed for receipt by truck. the tank storage area is diked for spill containment, and is located away from buildings, hazardous equipment and materials, and power lines, for reasons of safety.

Unloading pumps, transfer pumps, strainers, regulators, controls, instrumentation, valves, piping, and fittings are included in the design of this system.

3.5.5.4 Station Air Service

Service and Instrument Air System

Service air is provided by any of three, 100 percent capacity single-stage, jacketed, double-acting compressors sized to deliver 800 ft³/min. of air at a discharge pressure of 100 psig. The service air system is also equipped with a common air receiver tank, automatic start pressure control, controls, instrumentation, valving, piping, and fittings. Instrumentation air is provided by the service air system, and is conditional using duplex regenerative air dryers sized to deliver 400 ft³/min.

Sootblower Air System

A separate compressed air system consisting of two, 100 percent capacity, three-stage intercooled air compressors, sized to provide 1,500 ft³/min. (each) of 350-500 psig soot blowing air is provided. This system delivers compressed air for soot blowing the superheater, reheater, economizer, and air heater surfaces.

3.5.5.5 Station Service Water

The pumps provided for the various station water services generally take water from either of two suction headers connected directly to the circulating water pump basin.

Service Water

Three service water pumps provide the general water requirements for the station. These pumps are single stage, double suction centrifugal pumps, with each pump designated to deliver 700 gpm of water against an estimated head of 200 feet. The service water system consists of a loop header around the plant, fitted with segregating valves so that portions of the loop may be closed off while the remainder stays in service.

Cooling water is supplied from this system to equipment such as FD fans, compressors, mills, boiler feed pumps, etc. Service Water is also used to cool the closed cycle cooling water system loop. A separate header takes water to the ash and dust unloading systems, and car dumper house. A service water tank of 15,000 gallons capacity is connected to the system for capacity control, and is operated using both level and pressure control.

Closed Cycle Cooling Water

A closed cycle cooling water system is used to cool smaller cooling loads and those that require a higher pressure, such as coolers located higher in the plant. Condensate quality water is used as the cooling fluid.

Fire Service Water

The fire service water piping supplies the various hose reels throughout the plant, fire hydrants and the transformer fire fog system. The system is normally under house service water pressure. For fire fighting it receives water from the fire service booster pump and/or the engine driven fire pump.

The fire service booster pump is a two stage centrifugal pump, capable of delivering 700 gpm at 250 feet total head. The engine driven fire pump takes suction directly from the circulating pump suction chamber. The pump is a vertical turbine type, gasoline engine drive, and delivers 1,000 gpm of water at a total head of 350 feet.

Makeup Pumps

Three pumps are installed to supply water for makeup to the circulating water system, filtered water, service water and condensate. They are centrifugal pumps equipped with single suction, cast iron vertically split casings. Each pump delivers 11,500 gpm of water against a total head of 100 feet.

Filtered Water Pumps

Two filtered water pumps take water from the clearwell and supply the filtered water tank and the demineralizers. The pumps are centrifugal pumps constructed with single suction, cast iron vertically split casings. Each pump will deliver 220 gpm against a total head of 200 feet.

A filtered and sterile water storage tank is provided, and has a capacity of 15,000 gallons.

All water except that flowing directly to the demineralizers is taken directly to the storage tank to provide a constant head on the system and to prevent stagnation of water in the tank.

3.5.6 Piping and Valves

Generally, piping and valves will conform to the requirements of ANSI B31.1, Power Piping. Carbon steel piping material will be A106, Gr. B and Chrome Moly piping will be A335, Gr. P22.

In addition to the general requirements, the following are specifics concerning the more critical piping in the plant

- Condensate Pump Suction - (Design-50 psig/100° F)
Class - 150; carbon steel - A 106 Gr B, all std. wall.
- Condensate Pump Discharge Before Heaters (Design-500 psig/150° F)
Class 150; carbon steel - A106 Gr B, 2 inch and under-sch 80, 2 1/2 to 6 inch - std. wall, 8 to 14 inch - xs, 16-24 inch-sch 60.
- Boiler Feed Booster Pump Suction (200 psig/400° F)
Class 150; carbon steel A106 Gr B, std. wall
- Boiler Feed Booster Pump Discharge (300 psig/400° F)
Class 300, carbon steel A106 Gr B, 1/2 to 16 inch std. wall, 18 to 24 inch - extra strong wall.
- Boiler Feed Pump Discharge Before Heaters (3600 psig/400° F)
Class 2500, carbon steel A106 Gr B, 1/2 to 2 inch - sch 160, 2 1/2 to 6 inch - double extra strong wall, 18 inch - 2.20 inch min. wall.
- Boiler Feed Pump Discharge After Heater (3600 psig/550° F)
Class 2500, carbon steel A106 Gr B, 1/2 to 2 inch - sch 160, 2 1/2 to 6 inch - double extra strong wall, 18 inch - 2.20 inch min. wall
- Main Steam Pipe and Valves (Design 2750 psig/1000° F)
Chrome-Moly A335 Gr P22 pipe, 20 inch O.D.-3.12 inch min. wall; Class 4500 chrome-moly A217 Gr WC9 valves.

- Hot Reheat Pipe and Valves (Design 650 psig/1000^o F)
Chrome-moly A335 Gr P22 pipe, 30 inch O.D.-1.375 inch min. wall; Class 900 chrome-moly A217 Gr WC9 valves.
- Cold Reheat Pipe and Valves (Design 725 psig/700^o F)
Carbon steel A106 Gr B, 30 inch O.D.-.875 inch min. wall; Class 600 carbon steel A216 Gr WCB valves
- Extraction Steam Pipe from Heater No. 6 (Design 350 psig/900^o F)
Chrome-moly A375 P22 pipe, sch 40; Class 300 chrome moly A217 Gr WC6 valves
- Extraction Steam Pipe from Cross Over (Design 165 psig/750^o F)
Carbon steel A106 Gr B pipe, standard wall;
Class 300 carbon steel A216 Gr WCB Valves.
- Extraction Steam Pipe from LP Turbine (100 psig/650^o F)
Carbon steel A106 Gr B pipe, standard wall; Class 150 carbon steel A 216 WCB valves
- Circulating Water Pipe - (Design 60 psig/100^o F) Carbon Steel, API5L, 108 inch O.D., extra strong (1/2" nominal wall) with 1/2 inch thick cement lining.

3.6 PLANT CONTROL AND MONITORING SYSTEMS (6, 7)

3.6.1 Design Basis

Control and monitoring functions will be implemented in an integrated multi-function distributed control system (DCS). This system will utilize multiple redundant micro-processors to execute closed loop control strategies, alarm monitoring and reporting, data presentation, data recording, data storage and data retrieval. Conventional panel instrumentation will be held to a minimum, to be used solely for plant shutdown in the case of a major multi-element DCS failure. Geographical distribution of both micro-processor modules and I/O units will be implemented wherever practical to reduce plant wiring and cabling costs. Control valves, transmitters and control drives (actuators) will be standardized and purchased in lots from a single manufacturer to the greatest extent possible.

Proprietary control strategies will be safeguarded via confidentiality agreements to allow implementation in the DCS. Use of specialty control or monitoring systems will be minimized (eliminated if possible). If the required function cannot be technically implemented in the DCS due to processing (execution speed) shortcomings on the part of the DCS, or if the control strategy is programmed in a language where the cost of the conversion to the DCS control language is prohibitive, exceptions may be made. In this case the specialty system will be held responsible to provide either a hardwired interface to the DCS or a communication link compatible with the DCS.

3.6.2 Control Room

The Control Room will utilize cathode ray tube (CRT) and keyboard units for operator interface. Touchscreen will be utilized to improve operator access to data and control functions. The final number of CRT's and keyboards will be determined from an analysis of the plant's operating modes (baseload, on-off, cycling, on-line load following). Between six and twelve CRT's are envisioned. Color printers will be utilized for logging data, alarm hardcopy, CRT screen copies, data trending hardcopy, and reports. Minimal hardwired panel instrumentation will be utilized to safely shutdown the plant due to a major multi-element DCS failure.

3.6.3 Automation and Operation

The DCS will be configured to operate all plant equipment in an automated closed loop mode. Plant operators will initiate start-up and shut-down sequences. Operation of individual pieces of equipment will be automated to the greatest extent possible. Operator initiation of the starting and/or stopping of individual equipment will be automated to require as few operator actions as necessary. This will minimize the variations in start-up and shutdown procedures which impact equipment operating life and availability.

The design of the combustion control systems will be a joint, integrated process involving the boiler supplier, the plant designer, the operator/user and the DCS supplier.

The DCS shall be configured to provide closed loop automatic control of the following loops:

- Throttle Pressure
- Coordinated Load Control
- Unit (turbine) Load
- HP Turbine Bypass
- IP/LP Turbine Bypass
- Boiler Steam Blending (Separating)
- Secondary Air Pressure/Flow
- Primary Air Pressure/Flow
- Loop Seal Fluidizing Air Pressure
- Fuel (Coal) Feed/Limestone Feed
- Superheat Steam Temperature
- Reheat Steam Temperature
- Furnace Pressure
- Feedwater Flow and Drum Level
- Deaerator Level
- Feedwater Heater Level
- Supplemental Oil Firing
- Bed Height
- Bed Differential
- Bed Temperature
- Coal/Limestone Ratio (SO₂ Control)
- Excess Air/Oxygen
- Condensate Pump Recirculation Flow
- BFP and BF Booster Pump Recirculation
- Hotwell Level
- Condensate Storage Tank Level
- Generator Hydrogen Temperature
- Turbine Lube Oil Temperature
- Baghouse Cleaning

Conventional logic and control strategies will be utilized for the majority of the control loops.

The steam turbine will be brought on line by starting on Fluid Bed Module.

Initially the Fluid Bed Module is fluidized via the start-up oil burners. This operation provides the steam conditions necessary to warm-up and roll the turbine, bring up to speed and synchronize it. As the transition from start-up burners to coal combustion is made the steam bypass systems will be utilized to smoothly initiate and stabilize fluidized bed combustion.

In addition, the turbine bypass system operates automatically to balance respective superheater/reheater flows and to match the other boiler's steam conditions to those of the operating module or turbine metal temperature during startup. The bypass systems are monitored and controlled directly from the DCS.

This module will initially load the steam turbine and provide approximately 50-60% load capability. The second module will be brought on line when required to achieve loadings from 40-100%. The second module start-up sequence will enable the second module to match the operating module's steam pressure and temperature. The two modules will then be loaded equally and respond to requested load changes in a parallel manner. The reverse procedure would be followed when reducing load. A designated module would be decoupled from the steam cycle and shut-down. The remaining module would then be able to reduce load to a stable condition and still be able to respond to requested load changes within the load range of single module operation.

Coal and limestone feed would be varied to meet the control objectives. Bed inventory including inert material overflow and make-up must be adjusted to provide a suitable combustion environment. SO₂ removal is controlled as a function of coal/limestone ratio and bed temperature. Bed temperature must be maintained within an operating range of 150°F for optimum SO₂ removal efficiency.

Deaerator storage tank level is controlled by a control valve in conjunction with pump speed modulation to minimize energy consumption. Condenser hotwell level is controlled by either discharging condensate back to the storage tank through a spillover line connected to the discharge of the condensate pumps or by admitting condensate by gravity from the storage tank. Control is accomplished using pneumatic control valves.

Each boiler's feedwater flow and drum level is controlled by independent pneumatic control valves in conjunction with pump speed modulation to minimize energy consumption. Hot reheat temperature is controlled by spraying intermediate stage boiler feed pump discharge water into the reheater desuperheaters using pneumatic temperature control valves.

The turbine control system provides the following basic turbine control functions:

- Automatic control of turbine speed and acceleration through the entire speed range, with several discrete speed and acceleration rate settings.
- Automatic control of load and loading rate from no load to full load, with continuous load adjustment and discrete loading rates.
- Standby manual control of speed and load when it becomes necessary to take the primary automatic control out of service while continuing to supply power to the network via the turbine-generator.
- Detection of dangerous or undesirable operating conditions, annunciation of the detected condition, and initiation of proper control response to the condition.
- Monitoring of the status of the control system, including the power supplies and redundant control circuits.

- Testing of valves and controls.
- Prewarming of valve chest and turbine rotor using main or auxiliary steam supply.

The DCS shall be configured to provide on/off control of the following equipment. This control shall be both automatic (process logic) and manual (operator).

- Condensate Pumps
- Boiler Feed Booster Pumps
- Boiler Feed Pump Turbines
- Motor Driven BFP
- Secondary Air Fans
- Primary Air Fans
- Fluidizing Air Fans
- ID Fan
- Circulating Water Pumps
- All Motor Operated Valves
- All Motor Operated Dampers
- All Pneumatically Operated Dampers
- Turbine Water Induction Prevention Valves
- Coal Feeders
- Oil Pumps
- Oil Burners
- Cooling Tower Fans

3.6.4 Data Gathering, Reduction and Retrieval

Operating data will be stored for future retrieval and analysis by utilizing the latest, most reliable technology from among magtape, optical disk and other available technologies. Redundant storage devices and mediums may be provided to insure complete one-hundred percent availability of operating data for retrieval and analysis. The types of data to be stored will include the following:

- Turbine Start-Up Log
- Turbine Shut-Down Log
- Fluid Bed Module Start Up Log
- Fluid Bed Module Shutdown Log
- Post Trip Logs
- Sequence of Event Logs
- Periodic (Hourly and Daily) Logs
- All Trend Data
- Process Data by Exception Reporting

Means shall be provided to allow plant personnel to modify the collection and storage of data both from a quantity (points to be stored) and a quality (data collection frequency) perspective.

Retrieval of data for analysis shall make allowance for both retrieval at the plant site and at remote locations. Plant site retrieval shall utilize personal computers for access to and analysis of historical data from the DCS. Personal computer software will be provided to enable spreadsheet analyses and statistical correlation analysis. Remote site data retrieval shall be based on utilizing a mini-computer environment such as DEC Micro-Vax or Hewlett Packard.

3.6.5 Start-Up Testing and Tuning

Sufficient time will be allotted in the start-up schedule for the complete tuning of the control system in order to meet the operational requirements. Modifications to control strategies will probably be required. These will be generated by the equipment supplier and reviewed with the DCS equipment personnel and plant operating personnel. Modification of software based control strategies shall be made and documented by personnel from the DCS supplier and further tested as to their improved capabilities. The objective of this testing and tuning is to provide complete automatic control of the process by the DCS control system.

3.7 LAYOUT ARRANGEMENT

The arrangement of equipment systems, and structures on site are shown in this section, and the basis for this arrangement is described.

3.7.1 Assumptions

The following assumptions were taken into consideration when developing the site layout arrangement.

- Initially a single unit facility is to be constructed which includes two CFB's connected to a single turbine generator.
- Make provisions in the initial unit site layout arrangement to provide for the addition of a future second unit and the necessary support facilities.
- The circulating water heat sink is a mechanical draft cooling tower.
- Make up and potable water for plant use is filtered and treated on site.
- Plant and sanitary wastes are held and treated on site.

3.7.2 Overall Site Plan

The site layout arrangement is shown in Figure 3-18, and is arranged to include the following considerations.

General

The location of structures, facilities, equipment and systems is arranged with consideration given to process flows, costs construction requirements, rail access, roadways and future unit requirements. The site is approximately 320 acres.

Facilities required for the operation of the first unit which are located in a manner to allow for the addition of a future unit include the following.

- Coal unloading, storage, and conveying system
- Limestone unloading, storage, and conveying system
- Permanent warehouse
- Waste treatment system
- Water supply system and primary treatment equipment
- Administration/service building
- Oil unloading and storage facilities

DD

- 42 Limestone Reclaim Hopper
- 43 Coal Crusher Building
- 44 Coal Conveyors
- 45 Limestone Conveyors
- 46 Coal Pile Runoff Pond
- 47 Limestone Pile Runoff Pond
- 48 Runoff Water Pump House
- 49 Industrial Waste Treatment Building
- 50 Waste Treatment Ponds
- 51 Guard House

RAGE

30 DAYS

Figure 3-18

SITE PLAN

A

B

C

D

E

F

G

H

- PUBLIC ROAD

ISSUED FOR REPORT				INTERFACE	
0	NIA	-	-	5/14/82	
REV	DATE	END	FILE	APP	DATE

REVISIONS

STATUS OF DRAWING	DEFINITION
☐ APPROVED	
☐ PRELIMINARY	
☒ CONCEPTUAL	
COAL FUEL REFERENCE PLANTS CONCEPTUAL DESIGN DOE / METC DE-AC21-89MC25177	
PLANT LAYOUT GENERAL ARRANGEMENT	
400 MW CFB REFERENCE PLANT	
SITE PLAN
GILBERT COMMONWEALTH, INC. ENGINEERS AND CONSULTANTS READING, PA	
SHEET NO. 0 DATE 5/14/82 DRAWN BY [Signature] CHECKED BY [Signature] PROJECT NO. 8402-201	
SCALE 1"=200'-0" 8402 1 201 010 - 003 0	

REV	DATE	DESCRIPTION
1	5/14/82	ISSUED FOR REPORT

600

L A N I

- Auxiliary boilers
- Diesel generators

The on-site railroad system completely loops around the station. The location of the railroad main line turnout is determined by the length of a unit train of 100 cars, with each car having a capacity of 100 tons. The length of track must be sufficient to store a fully loaded unit train in front of the dumping facility and an empty unit train beyond the dumping facility, with both completely clearing the first station turnout.

Plant Waste

The spatial requirements of the plant waste system are site-related. The size of this system is largely determined by the quality of the makeup water and, to a lesser extent, the amount of rainfall. This system will be arranged to handle coal pile runoff along with other plant discharges.

Coal Handling

Coal unloading and handling occupy a large percentage of the plant's total land area requirements. An automatic unloading system was selected for illustration on the Plot Plans, using unit trains with swivel-coupled cars, a rotary car dumper, a car positioner, and a thaw shed. The coal is dumped and conveyed to a transfer tower where it is placed on the belt of a double wing travelling stacked. The two coal piles which are created are for active and dead storage. Coal is reclaimed from the active and dead storage piles by dozing into the reclaim hopper at the active pile or the emergency reclaim hopper located at the dead storage pile. The area of the dead storage pile is determined by the 90-day minimum requirement and the active pile is determined by the 72 hour active coal requirement. The coal is conveyed to the crusher building where crushers reduce the coal to the maximum size accepted by the CFB's. After crushing the coal is transferred to the power block using two conveying systems, with each utilizing a tripper conveyor which discharges the coal to the bunkers for in-plant storage.

Limestone Handling

Limestone is delivered to the site by truck and is dumped into the limestone truck unloading hopper. From the unloading hopper the limestone is conveyed using a belt conveyor to the limestone storage A-frame storage structure which is sized for 30 days storage. Limestone is distributed within the A-frame structure by a tripper conveyor. The stored limestone is reclaimed by using a portal scraper reclaimer. Limestone is transferred from the A-frame to the limestone preparation building using an inclined belt conveyor. The pulverized limestone is conveyed from the preparation building with two belt conveyors which supply two limestone storage silos located adjacent to the boiler house. From the silos the limestone is fed to separate boiler feeding systems.

Power Block

The power block contains the following major areas.

- Steam Turbine Building (one steam turbine)
- Boiler Building (two CFB's)
- Control Complex
- Machine Shop
- Auxiliary Boiler and Diesel Generator Building
- Administration and Service Building
- Fly Ash Baghouse (one per CFB)
- Stack
- Transformer Area

Yard Area

The following are additional facilities located in the yard.

- Substation
- Cooling Tower
- Cooling Tower Pump House
- Makeup Water and Pretreatment Building
- Industrial Waste Treatment Building
- Coal Pile Runoff Pond and Pump House
- Limestone Pile Runoff Pond and Pump House
- Warehouse
- Coal Yard Vehicle Maintenance Garage
- River Water Intake Structure
- Guard House

3.7.3 Power Block - Plan

General

The layout of the power block is shown on Figure 3-19. The building housing the turbine generator is 315 ft. long and 115 ft. wide. The turbine building is sized to provide sufficient clear area to completely disassemble the turbine-generator and provide adequate laydown space for all parts.

The turbine room width is set taking into consideration the width of the turbine foundation, the physical requirements of the turbine-driven boiler feed pumps located at the operating floor along with sufficient space to locate additional equipment and route systems. Additionally, maintenance provisions and spatial requirements were considered. An equipment access hatch located at the southeast corner of the turbine room provides for truck and railcar access. The turbine room bridge crane which spans the width and travels the length of the turbine room is sized to handle

EE

A

20

B

19

18

C

17

16

D

14

12

E

11

9

F

7

5

G

4

H

ISSUED FOR
REPORT

REVISIONS

DEFINITION

REVIEWED AND APPROVED DESIGN AND PORTION
 NAMED "HOLD" RETAINS PRELIMINARY STATUS.

REPRESENTS ACCEPTABLE DESIGN CONCEPT.
 SUBJECT TO CHANGE.

REPRESENTS GENERAL CONCEPTS BASED ON
 ASSUMPTIONS. CHANGES COULD BE MADE.

1. FUEL REFERENCE PLANTS
 CONCEPTUAL DESIGN

/ MEPC DE-AC21-SPACER/77

GENERAL ARRANGEMENT

FOR CFB REFERENCE PLANT

POWER BLOCK

SILBERT/COMMONWEALTH, INC.

DESIGNED AND ENGINEERED BY

REVISIONS

DATE

BY

3402 1 580 010 001

A

the weight of the turbine generator rotor.

The left or boiler side of the turbine generator has been designated for the steam seal feed system and the right side for the steam seal drains and turbine lube oil system. The boiler feed pump turbines exhaust directly into the main condenser on the left side of the machine and the low pressure heater extraction points exit from the low pressure turbine cylinders on the right. The low pressure heaters No. 3 and No. 4 are located on the right side of the machine at the generating floor level.

Isolated phase bus ducts are routed directly from the generator end of the machine to the transformer area which is located outside and adjacent to the turbine room.

Heater Bay

The heater bay is 30 ft wide and extends the full length of the turbine room. The purpose of the heater bay is to house components of the feedwater cycle such as the high pressure heaters and deaerator. This location within the station provides the most economical piping and equipment arrangement.

Additionally, the heater bay will provide dedicated space for routing horizontal and vertical runs of pipe and cable trays. At the grade floor level, space is reserved to provide a maintenance corridor which interconnects vital equipment areas with the machine shop, repair facilities and to provide for equipment removal capability from the plant.

The heater bay height is established to meet the requirements of the feedwater system requirements including NPSH considerations of the boiler feed pumps.

Boiler Area

The boilers are located that the combustor chamber faces the heater bay and turbine generator and the gas exits to the rear. The boiler area also includes the in-plant coal storage system.

Sizing

The length (or depth) of the boiler area is determined by the vendor and is that distance required to encompass the steam drum, combustion chamber, hot cyclone and convection section and air heater. A 30 ft wide bay was added between the area adjacent to the area housing the boiler steam drum and the heater bay. This area contains the coal bunkers, limestone bins, belt conveyors with trippers and coal and limestone feed systems.

Additionally, a twenty foot wide bay is provided on the outboard sides of each boiler. These bays house the primary and secondary air fans, associated duct work and in addition, also provide space for routing of systems. A thirty ft wide bay, which is common to both boilers, is provided between the two boilers. A twenty ft wide bay is provided at the rear of the boilers. The building enclosing the boilers, coal bunkers and limestone day bins is 326 ft wide and 190 ft deep in plan.

The boiler building is arranged that the number one and number two boilers are duplicate design arrangements, therefore improving construction, operations and maintenance considerations. Directly in back of and adjacent to the back of the boiler the dust collectors, I.D. fans, stacks and interconnecting duct work are located for each boiler. The intent of the arrangement is to keep these facilities as close to the gas outlet ducts of the boilers as possible, but also provide reasonable space for operations and maintenance.

Control Complex

The control complex is located at the future expansion end of the plant to place it adjacent to the future plant facilities in the event the plant is expanded. The control complex is located directly adjacent to both the boiler building and the turbine building. The location provides for convenient routing of control systems from all areas of the power block to the control complex.

The control complex building will most likely contain the machine shop facility at the grade floor elevation. The upper floors of the complex will contain cable spreading areas, termination areas, control room, office and lavatories, instrument shop and mechanical equipment room containing HVAC for the control complex. The size and arrangement and the exact types of areas required will be dependent upon the type of control system selected.

3.7.4 Power Island Cross Section

The cross section shown in Figure 3-20 illustrates the elevation differences through the major areas of the plant. The cross section indicates the elevational relationships between the turbine building and heater bay. Also the heater bay to the area containing the coal bunkers and limestone day bins. Finally, the elevational relationship of the boiler area to the adjacent areas. Also, the relationships of the major boiler areas including the convection section, hot cyclones and boiler combustion chamber are illustrated. The arrangement of the boiler is the responsibility of the boiler vendors.

EE

A

B

C

D

E

F

G

H

J

K

Figure 3-20

TABLE FOR REPORT	
A	MA
REVISIONS	

STATUS OF DESIGN	DEFINITION
☐ APPROVED	REVIEWED AND APPROVED DESIGN AND POSITION MARKED "HOLD" REMAINS PRELIMINARY STATUS.
☐ PRELIMINARY	REPRESENTS ACCEPTABLE DESIGN CONCEPT, SUBJECT TO CHANGE.
☒ CONCEPTUAL	REPRESENTS GENERAL CONCEPT BASED ON ASSUMPTIONS. CHANGES COULD OCCUR.
CON. FUEL REFERENCE PLANTS CONCEPTUAL DESIGN DUE / HENC BE-AC21-0002977	
PLANT LAYOUT	GENERAL ARRANGEMENT
400 MW CPB REFERENCE PLANT	
CROSS SECTION
GILBERT & COMMONWEALTH, INC. ENGINEERING AND CONSULTING FIRM WASHINGTON, DC
DATE	PROJECT NUMBER
8-88	8402 1 580 010 002
REV. 1	A

4.0 REFERENCE PLANT ECONOMIC ANALYSIS

The economics of the Atmospheric Circulating Fluidized Bed Combustion Reference Power Plant were developed on the basis of consistently evaluating the capital and operating costs and then performing an economic analysis based on the levelized cost of electricity (COE) as the figure of merit. The conceptual cost estimate was determined on the basis of several major data sources including the detail estimate data from a major PC fossil plant currently in final design and starting construction, a detailed AFB boiler vendor quote, plus inhouse cost data and conceptual estimating of scope not compatible with the PC plant scope.

The emphasis of this effort was placed on obtaining good cost results at the TPC level. The capital costs at the Total Plant Cost (TPC) level include equipment, materials, labor, indirect construction costs, engineering and contingencies.

Operation and maintenance (O&M) cost values were determined on a first year basis and subsequently levelized over the 30 year plant life to form a part of the economic analysis. Consumables were evaluated on the basis of the quantity required, operation cost was determined on the basis of the number of operators, and maintenance was evaluated on the basis of maintenance costs required for each major plant section. These operating costs were then converted to unit values of \$/kW-yr or mills/kWh.

In addition, the following economic assumptions were made:

- Plant book life is 30 years
- Capacity factor is 65 percent
- Plant inservice date is January 1992
- COE determined on a levelized, current dollar basis
- COE methodology was based on EPRI TAG methodology

The capital and operating costs of the plant are combined with plant performance in the comprehensive evaluation of cost of electricity (COE).

4.1 METHODOLOGY

This section describes the approach, basis, and methods that were used to perform capital and operating cost evaluations of the circulating AFBC power plant. Included in this section are descriptions of:

- Capital Costs (Section 4.2)
 - Bare Erected Cost (Section 4.2.1)
 - Total Plant Cost including TPI and TCR (Section 4.2.2)
 - Capital Cost Estimate Exclusions (Section 4.2.3)
- Operating Costs and Expenses (Section 4.3)
 - Operating Labor (Section 4.3.1)

- Consumables, including fuel costs (Section 4.3.2)
- Maintenance (Section 4.3.3)
- Economic Evaluation (Section 4.4)

The capital costs, operating costs, and expenses were established consistent with EPRI Technical Assessment Guide (TAG) methodology and the plant scope identified in Section 3. The cost of each component was quantitatively developed to enhance credibility and establish a basis for subsequent comparisons and modification as the technology is further developed.

- Total plant cost values are expressed in December 1991 dollars.
- The estimates represent mature technology plant, or "nth plant" (i.e., it does not include costs associated with a first-of-a-kind plant).
- The estimate represents a complete power plant facility with the exception of the exclusions listed in Section 4.2.3.
- The estimate boundary limit is defined as the total plant facility within the "fence line," including coal receiving and water supply system but terminating at the high side of the main power transformers.
- Site is located within the Ohio River Valley, southwestern Pennsylvania/eastern Ohio, but not specifically sited within the region except that it is considered to be located on a major navigable water way.
- Terms used in connection with the estimate are consistent with the EPRI TAG.
- Costs are grouped according to a process/system-oriented code of accounts; all reasonably allocable components of a system or process are included in the specific system account in contrast to a facility, area, or commodity account structure.
- The basis for equipment, materials, and labor costing is described in Section 4.2.
- Design engineering services, including construction management and contingencies basis, are examined in Section 4.2.2.
- The operating and maintenance expenses and consumables costs were developed on a quantitative basis.
 - The operating labor cost was determined on the basis of the number of operators required and an operating labor hourly wage rate.
 - The maintenance cost was evaluated on the basis of separate relationships of maintenance cost to initial capital cost for each cost account.

- The cost of consumables, including fuel, was determined on the basis of individual rates of consumption, the unit cost of each consumable, and the plant annual operating hours.

Each of these expenses and costs were determined on a first-year basis and subsequently leveled over the life of the plant through application of a leveling factor to determine the value that forms a part of the economic evaluation. This amount when combined with annual fuel cost and capital charges results in the figure of merit, COE.

4.2 CAPITAL COSTS

The capital cost, specifically referred to as Total Plant Cost (TPC) for the mature circulating AFBC power plant, was estimated using the EPRI structure. The major components of TPC consist of bare erected cost, engineering and home office overheads and fee plus contingencies.

The capital cost was determined through the process of estimating the cost of every significant piece of equipment, component, and bulk quantity. A Code of Accounts was developed to provide the required structure for the estimate. The Code facilitates the consistent allocation of individual costs that were developed and will serve as the basis for future evaluation of other clean coal sponsored technologies and permit future cost comparisons if desired. The Code also facilitates recognition of estimated battery limits and the scope included in each account. This Code is presented as Table 4-1 along with a listing of scope included in each account.

4.2.1 Bare Erected Cost

The bare erected cost level of the estimate, also referred to as the sum of process capital and general facilities capital, consists of the cost of: factory equipment, field materials and supplies, direct labor, indirect field labor, and indirect construction costs

Major equipment prices were based on vendor furnished budget cost information. They include the following:

- Circulating Fluidized Bed Boilers and Baghouse.
- Coal/Limestone Handling Equipment.
- Flyash and Limestone Storage Silos.
- Steam Turbine-Generator.
- Condenser.
- Feedwater Heater.
- Deaerator.
- Concrete Cooling Tower.
- Ash Handling System

Table 4-1
Code of Direct Accounts Summary

<u>Account Number</u>	<u>Account Title</u>
1	COAL and SORBENT HANDLING Coal Receiving and Unloading Equipment Coal Stackout and Reclaim Equipment Coal Storage Bin and Yard Crushers Other Coal-Handling Equipment Sorbent Receiving and Unloading Equipment Sorbent Stackout and Reclaim Equipment Sorbent Storage Bin and Yard Crusher Other Sorbent Handling Equipment Coal and Sorbent Handling Foundations and Structures
2	COAL and SORBENT PREP and FEEDING Coal Crushing and Drying Equipment Prepared Coal Storage and Feed Equipment Coal Injection System Miscellaneous Coal Preparation and Feed Sorbent Preparation Prepared Sorbent Storage and Feed Equipment Sorbent Injection System Booster Air Supply System Foundations and Structures
3	FEEDWATER and MISCELLANEOUS SYSTEMS and EQUIPMENT Feedwater System Makeup Treatment, Pretreating, and Storage Other Feedwater and Condensate Subsystems Service Water Systems Other Boiler Plant Systems Fuel Oil Supply System Waste Treatment Equipment Miscellaneous Power Plant Equipment
4	CIRCULATING AFB BOILER, and ACCESSORIES
5	FLUE GAS CLEAN-UP Baghouse and Accessories Foundations and Supports
6	COMBUSTION TURBINE and ACCESSORIES
7	WASTE HEAT BOILER, DUCTING and STACK Ductwork Stack Foundations
8	STEAM TURBINE GENERATOR, and AUXILIARIES Steam Turbine Generator and Accessories Turbine Plant Auxiliaries Condenser and Auxiliaries Steam Piping Foundations

Table 4-1 (cont)

9	COOLING WATER SYSTEM Cooling Towers Circulating Water Pumps Circulating Water System Auxiliaries Circulating Water Piping Make-Up Water System Component Cooling Water System Circulating Water Foundations and Structures
10	ASH/SPENT SORBENT RECOVERY and HANDLING Ash Coolers Other Ash Recovery Equipment Ash Storage Silos Ash Transport and Feed Equipment Miscellaneous Ash Handling Equipment Foundations and Structures
11	ACCESSORY ELECTRIC PLANT Generator Equipment Station Service Equipment Switchgear and Control Equipment Conduit and Gable Tray Wire and Cable Protective Equipment Standby Equipment Main Power Transformer Foundations
12	INSTRUMENTATION and CONTROL AFBC Control Equipment Combustion Turbine Control Equipment Steam Turbine Control Equipment Other Major Component Control Equipment Signal Processing Equipment Control Boards, Panels, and Racks Computer and Auxiliaries Instrument Wiring and Tubing Other Instrumentation and Controls Equipment
13	IMPROVEMENTS TO SITE Site Preparation Site Improvements Site Facilities
14	BUILDINGS and STRUCTURES AFBC Structure Boiler Building Steam Turbine Building Administration Building Circulating Water Pumphouse Water Treatment Buildings Machine Shop Warehouse Other Buildings and Structures Waste Treatment Buildings and Structures

- Process Pumps
- Turbine Bridge Crane.
- Stacks

Other process equipment, minor secondary systems, and materials were estimated by G/C on the basis of the PC plant data and in-house data consisting of other project cost data and relationships, catalog data, and standard utility unit cost data.

Piping system costs for the circulating AFB power plant were estimated on the basis of the corresponding PC plant data. The pipe and fitting quantities were adjusted to reflect the differences generic to the AFB plant. This was especially true for the steam piping quantities that were impacted by use of two boilers in contrast to the PC plant with one boiler. This approach was supplemented in some minor systems to evaluate piping not sufficiently common to justify adjusting the reference data. In these instances, quantities were conceptually developed and costed on the basis of in-house standard utility piping unit costs and unit manhours.

The electrical and I&C portion of the AFB estimate was developed using material and equipment types and sizes typically used to construct a domestic utility owned and operated power plant. In most cases the costs for bulk materials and major electrical equipment for this estimate were derived from recent vendor or manufacturer's quotes for similar items on other projects.

Development of electrical quantities was done using the listing of electrical loads by kW. Where actual or specific information regarding equipment specifications was available, that information was used to size and quantify material and equipment requirements. Where information was not furnished or was not adequate, requirements were assumed and estimated based on information available from project estimates of similar type and size. Cable and raceway quantities were estimated using the provided kW information by system and area along with previous project experience. Areas such as lighting, paging, heat tracing, and unit heating were done based on project experience for a plant of comparable size with enclosed boiler and turbine buildings in a climate range similar to that of the proposed general location of this plant. Grounding for the project is included in the estimate assuming that a design for a loop type system attached to ground pads on structural steel and installed in slabs will be the accepted method. The section of the estimate for the Distributed Control System was developed from a system specified and designed for a plant of 600 MWe capacity which is larger than the AFB plant, but will provide an acceptable value for this system. The cabling for this system is included in the bulk cable portion of the estimate.

The labor cost to install the equipment and materials was estimated on the basis of labor manhours. Labor costing was determined on a multiple contract labor basis with the labor cost including direct and indirect labor costs plus fringe benefits and allocations for contractor expenses and markup. This was supplemented in limited cases, as required, with equipment labor relationship data to determine the labor cost. The relationships used were based on the in-house historical data and reference PC plant data.

The indirect labor cost was estimated at 7 percent of direct labor to recognize the cost of construction services and facilities not provided by the individual contractors. The latter cost

represents the estimate for miscellaneous temporary facilities such as construction road and parking area construction and maintenance; installation of construction power; installation of construction water supply and general sanitary facilities; and general and miscellaneous labor services such as jobsite cleanup and construction of general safety and access items.

Assuming of the capital cost is included in Subsection 4.2.2.

4.2.2 Total Plant Cost (TPC)

The TPC level of the estimate consists of the bare erected cost plus engineering and contingencies.

The engineering costs represent the cost of architect/engineer (A/E) services for design, drafting, and project construction management services. The cost was determined to be 12 percent of the bare erected cost on an individual account basis. The cost for engineering services provided by the equipment manufacturers and vendors is included directly in the equipment costs.

Allowances for project contingencies are also considered as part of the TPC. Since none of the various systems are still in the development stage and the boiler would be offered at commercial terms, no process contingency was added to the estimated cost of systems.

Consistent with conventional power plant practices, the general project contingency was added to the total plant cost to cover project uncertainty and the cost of any additional equipment that could result from a detailed design. Based on EPRI criteria, the cost estimate contains elements of Classes I, II, and III level estimates. As a result, on the basis of the EPRI guidelines, a nominal value of 15 percent was used to arrive at the plant nominal cost value. This project contingency is intended to cover the uncertainty in the cost estimate itself. The contingencies represent costs that are expected to occur.

Table 4-2 provides summary cost results at the level of the code of accounts for each component of TPC. Appendix C contains a detail estimate listing in the same format as Table 4-2.

The original approach for this cost evaluation was to include use of the Nucla circulatory AFBC boiler repowering cost information. While it was not possible to implement this approach on costing the CFBC reference plant, a comparison of the overall Nucla AFBC repowering actual costs and the reference grass roots circulating AFBC plant is included in Table 4-3. Although these values have been formatted in a common table and the Nucla based costs have been escalated so that costs are on the same year dollar basis, there are a number of considerations that reduce the significance of comparison:

- Nucla costs represent a repowering project, the reference AFBC represents a grass roots plant.
- The Nucla boiler provides steam for the full 100 MW output while the new steam turbine generator and related systems has a nominal 75 MW rating and is supplemented by three 12 MW existing steam turbine generators.
- The reference AFBC plant represents the plant or mature technology.

Table 4-2

Client: DOE-METC										Report Date: 23-Oct-91	
Project: AFBC-REFERENCE PLANT										Cost Year 1991, \$x1000	
Case: Base Case										Estimate Type: Conceptual	
Plant Size: 400.5 MW _{net}										TOTAL PLANT COST - SUMMARY	
Acct No.	Item/Description	Equipment Cost	Material Cost	Installation		Sales Tax	Bare Erected Cost \$	Eng'g, CM H.O. & Fee	Contingencies		TOTAL PLANT COST \$
				Cost	Indirects				Process	Project	\$/kW
1	COAL & SORBENT HANDLING	12,868	4,391	9,666	677		\$27,601	3,312		4,637	\$35,551
2	COAL & SORBENT PREP. & FEED	19,851		6,452	452		\$26,754	3,210		4,495	\$34,459
3	FW, COND. & MISC. SYS.	17,119		7,134	499		\$24,753	2,970		4,158	\$31,881
4	AFBC BOILER & ACCESSORIES	87,950		24,748	1,732		\$114,431	13,732		19,224	\$147,387
4	AFBC Boiler										
4	Open										
4	Open										
4	Other Acc't 4 Costs										
5	FLUE GAS CLEANUP	14,650	636	4,203	294		\$19,783	2,374		3,323	\$25,480
6	COMBUSTION TURBINE/ACCESSORIES	N/A		N/A							
6	Combustion Turbine Generator										
6	Other Acc't 6 Costs										
7	HRSG, DUCTING & STACK	N/A		N/A							
7	Heat Recovery Steam Generator										
7	Other Acc't 7 Costs										
8	STEAM TURBINE GENERATOR	1,844	75	1,257	88		\$3,264	392		548	\$4,205
8	Steam TG & Accessories	40,492		3,598	252		\$44,342	5,321		7,449	\$57,112
8	Other Acc't 8 Costs	7,456	313	4,350	304		\$12,423	1,491		2,087	\$16,001
9	COOLING WATER SYSTEM	8,730	2,742	6,174	432		\$18,077	2,169		3,037	\$23,284
10	ASH/SPENT SORBENT HANDLING SYS	5,946	77	3,190	223		\$9,436	1,132		1,585	\$12,153
11	ACCESSORY ELECTRIC PLANT	7,259	3,204	7,204	504		\$18,171	2,181		3,053	\$23,404
12	INSTRUMENTATION & CONTROL	6,294		4,160	291		\$10,745	1,289		1,805	\$13,839
13	IMPROVEMENTS TO SITE	1,823	1,017	3,740	262		\$6,842	821		1,149	\$8,813
14	BUILDINGS & STRUCTURES		23,825	22,429	1,570		\$47,824	5,739		8,034	\$61,598
TOTAL COST		\$232,281	\$36,279	\$108,305	\$7,581		\$384,446	\$46,133		\$64,587	\$495,166
											1236

Table 4-3

CIRCULATING AFBC PLANT COST COMPARISON				
REFERENCE PLANT VS NUCLA REPOWERING DEMONSTRATION				
All Costs in 1991 Dollars				
DESCRIPTION	TOTAL PLANT COST		UNIT COST - \$/KW	
	REF. PLANT	NUCLA	REF. PLANT	NUCLA
	AFBC	AFBC	AFBC	AFBC
UNIT SIZE - kW net	400,500	100,000		
BOILER	114,431,000	38,525,000	286	385
STEAM TG & ACCESSORIES	44,342,000	8,376,300	111	84
MECHANICAL/PIPING	142,091,000	14,868,800	355	149
ELECTRICAL/I&C	28,916,000	10,063,700	72	101
STRUCTURAL/ARCHITECTURAL	54,666,000	5,575,200	136	56
DEMOLITION, RELOCATION & MOD'S	N/A	868,200		9
SUBTOTAL	\$384,446,000	\$78,277,200	960	783
FIELD DISTRIBUTLES AND CONTRACTOR H.O.	N/A	13,222,600		132
ARCHITECT/ENGINEER (Ref. AFBC incl. Const.Mgmt.)	46,133,000	8,941,300	115	89
CONTINGENCY	64,587,000	N/A	161	
TOTAL	\$495,166,000	\$100,441,100	1236	1004

- The Nucla costs include some plant life extension costs.
- The equivalent of field distributables and contractor home office costs are included in the direct costs for the reference AFB plant.
- Due to the above consideration the \$/kW values on the table are included for general reference and are not directly comparable.
- The reference AFB plant is four times the capacity of Nucla.

When the boiler only is compared on the basis of the scaling exponent relationship between the two plants, the result is reasonable.

In addition to the TPC cost level, the Total Plant Investment (TPI) and Total Capital Requirement (TCR) were determined.

TPI at date of start-up includes escalation of construction costs and allowance for funds used during construction (AFDC), formerly called interest during construction, over the construction period. TPI is computed from the TPC which is expressed on an "overnight" or instantaneous construction basis. For the construction cash flow, a uniform expenditure rate was assumed, with all expenditures taking place at the end of the year. The construction period is estimated to be 3 years. Given TPC, cash flow assumptions, nominal interest, and escalation rates, TPI was calculated using:

$$TPI = TPC \times A[(R^3 - 1)/(R - 1)]$$

where:

- A = % cost expended per year = 33.33%
- R = Compound adjustment factor = $(1 + i)/(1 + e_a)$
- i = Weighted cost of capital, 11.5%
- e_a = Inflation rate, 5%

In addition, the results introduced in Section 4.4 include recognition of separate mixed year dollars and AFDC.

The apparent escalation rate and the weighted cost of capital (discount rate) indicated above, are the standard values currently proposed by EPRI.

The TCR includes all capital necessary to complete the entire project. TCR consists of TPI, prepaid royalties, preproduction (or start-up) costs, inventory capital, initial chemical and catalyst charge, and land cost:

- Royalties costs are assumed inapplicable to the mature AFB plant and thus are not included.

- Preproduction U.S. costs are intended to cover operator training, equipment checkout, major changes in plant equipment, extra maintenance, and inefficient use of fuel and other materials during plant start-up. They are estimated as follows:
 - 1 month fixed operating costs - operating and maintenance labor, administrative and support labor, and maintenance materials.
 - 1 month of variable operating costs as full capacity (excluding fuel) - includes chemicals, water, and other consumables and waste disposal charges.
 - 25% of full capacity fuel cost for 1 month - covers inefficient operation that occurs during the start-up period.
 - 2% of TPI - covers expected changes and modifications to equipment that will be needed to bring the plant up to full capacity.
- Inventory capital is the value of inventories of fuel, other consumables, and by-products, which are capitalized and included in the inventory capital account. The inventory capital is estimated as follows: Fuel inventory is based on full-capacity operation for 60 days. Inventory of other consumables (excluding water) is based on full-capacity operation at the same number of days as specified for the fuel. In addition, an allowance of 1/2% of the TPC equipment cost is included for spare parts.
- Initial catalyst and chemical charge covers the initial cost of any catalyst or chemicals that are contained in the process equipment (but not on storage, which is covered in inventory capital). No value was included because costs are minimal and included with the component equipment capital cost.
- Land cost is based on 320 acres of land at \$1,300 per acre.

Each of the TCR cost components, as well as the summary TPC components and the TPI, is shown separately in the Section 4.4 expressed in \$x1000 and \$/kW (net).

4.2.3 Capital Cost Estimate Exclusions

Although the estimate is intended to represent a complete power plant, there remain several qualifications/exclusions as follows:

- Sales tax is not included (considered to be exempt).
- On-site fuel transportation equipment (such as barge tug, barges, yard locomotive, bulldozers) is not included.
- Allowances for unusual site conditions (such as piling, extensive site access, excessive dewatering, extensive inclement weather) are not included.
- Switchyard (transmission plant) is not included. The evaluated scope terminates at the high side of the main power transformer.

- Ash disposal facility is excluded, other than the 3-day storage in the ash-storage silos. (The ash disposal cost is accounted for in the ash disposal charge as part of consumables costs)
- Royalties are not included.

4.3 OPERATING COSTS AND EXPENSES

The operating costs and related maintenance expenses (O&M) described in this section pertain to those charges associated with operating and maintaining the AFB power plant over its expected life.

The costs and expenses associated with operating and maintaining the plant include:

- Operating labor
- Maintenance
 - Material
 - Labor
- Administrative and support labor
- Consumables
- Fuel cost

The values for these items were determined consistent with EPRI TAG methodology. These costs and expenses are estimated on a first-year basis, in December 1991 dollars. The first-year costs assume normal operation and do not include the initial start-up costs.

The operating labor, maintenance material and labor, and other labor-related costs are combined and then divided into two components; fixed O&M, which is independent of power generation, and variable O&M, which is proportional to power generation. The first-year operating and maintenance cost estimate allocation is based on the plant capacity factor.

The other operating costs, consumables and fuel, are determined on a daily 100-percent operating capacity basis and adjusted to an annual plant operation basis.

The development of the actual values was performed on a G/C model that is consistent with TAG. The inputs for each category of operating costs and expenses are identified in the succeeding subsections along with more specific discussion of the evaluation processes.

4.3.1 Operating Labor

The cost of operating labor was estimated on the basis of the number of operating jobs (OJ) required to operate the plant (on an average-per-shift basis). The operating labor charge (OLC) expressed in first year \$/kW was then computed using the average labor rates:

$$OLC = \frac{(OJ) \times (\text{labor rate} \times \text{labor burden}) \times (8760 \text{ h/yr})}{(\text{net capacity of plant at full load in kW})}$$

The operating labor requirements were determined on the basis of in-house representative data for the major plant sections (such as coal handling and steam turbine plant). These data were combined to arrive at total plant operating requirements as indicated in Table 4-4.

4.3.2 Consumables

The feedstock and disposal costs are those consumable expenses associated with power plant operation. Consumable operating costs are developed on a first-year basis and subsequently levelized over the 30-year life of the plant. The consumables category consists of water, chemicals, other consumables, and waste disposal, as shown on Table 4-5.

The "water" component pertains to the water acquisition charge for water required for the plant steam cycle, and for miscellaneous services.

The "chemicals" component consists of:

- A composite water makeup and treating chemicals requirement in which unit cost and the ratio of chemicals to water were based on data from comparable plants
- The liquid effluent chemical category, representing the composite chemical requirement for wastewater treating, in which unit cost and quality were developed similar to the water makeup and treating chemicals
- The limestone category represents the sorbent required for sulfur control. The unit cost is the EPRI standard limestone cost.

The "other consumables" component consists of startup fuel, gases, primarily nitrogen required for transport and blanketing and steam but does not contain any significant quantity.

The "waste disposal" component pertains to the cost allowance for off-site disposal of plant solid wastes. The unit cost for disposal is based on an adjusted EPRI value.

The fuel (coal) cost (FC) was developed on the basis of delivered coal of \$1.60/10⁶ Btu, the plant net heat rate Btu/kWh (HR) and the coal higher heating value (HHV) of 12,450 Btu/lb. For the coal as well as for all feedstock and disposal costs, the quantity per day represents the 100% capacity requirement, while the annual cost values are adjusted for the designated 65% plant capacity factor. The calculation of first year fuel cost occurred as follows:

- Fuel (ton/day) =
$$\frac{\text{HR} \times \text{kW (plant new capacity)} \times 24 \text{ hours}}{\text{HHV} \times 2000 \text{ lb/ton}}$$
- Fuel Unit (per ton) Cost =
$$\frac{\text{HHV} \times 2000 \text{ lb/ton} \times \text{FC}}{1 \times 10^6 \text{ Btu}}$$
- Fuel Cost (1st year) = Fuel (t/d) x Fuel Unit Cost (\$/t) x 365 days x 0.65 (cap. factor)

Table 4-4

OPERATING LABOR REQUIREMENTS			
Case Title: Base Case			
Operating Labor Rate(base):	22.50	\$/hour	
Operating Labor Burden:	35.00	% of base	
Labor O-H Charge Rate:	30.00	% of labor	
<u>Operating Labor Requirements(O.J.)per Shift:</u>			Total
Category	1 unit/mod.		Plant
-----	-----		-----
Skilled Operator	2.0		2.0
Operator	20.0		20.0
Foreman	1.0		1.0
Lab Tech's, etc.	3.0		3.0
TOTAL-O.J.'s	26.0		26.0

Table 4-5

CONSUMABLES, BY-PRODUCTS & FUELS DATA			
Case Title: Base Case			
Item/Description	Consumption Initial	/Day	Unit Cost
-----	-----	-----	-----
Water(/1000 gallons)		11540	0.66
Chemicals			
MU & WT Chem.(lbs)	744000	12400	0.16
Liquid Eff.Chem.(lbs)	1384800	23080	0.12
Limestone(ton)	52552.8	875.88	16.5
Other			
Natural Gas(MM Btu)			
Gases,N2 etc./100scf)			
L.P. Steam(/1000 pounds)			
Waste Disposal			
Sludge(ton)			
Bottom Ash(ton)		105.6	8.75
By-products			
Sulfuric Acid(pounds)			
Sulfur(pounds)			
Fuel(ton)		3831.7	39.84

Table 4-5 summarizes the quantities and unit costs used to determine the consumable costs including fuel.

4.3.3 Maintenance

Since the development of the maintenance labor and material costs are so interrelated in this methodology, their cost bases are discussed together. Annual maintenance costs are estimated as a percentage of the installed capital cost. The percentage varies widely, depending on the nature of the processing conditions and the type of design.

On the basis of G/C in-house data and EPRI guidelines for determining maintenance costs, representative values expressed as a percentage of system cost were specified for each major system. The rates were applied against individual estimate values. Using the corresponding TPC values, a total annual (first-year) maintenance cost was calculated, including both material and labor components. The rates for calculation of maintenance are indicated in Table 4-6.

Since the maintenance costs are expressed as maintenance labor and maintenance materials, a maintenance labor/materials ratio of 40/60 was used for this breakdown. The operating costs, excluding consumable operating costs, are further divided into fixed and variable components. Fixed costs are essentially independent of capacity factor and are expressed in \$/kW-yr. Variable costs are incremental, directly proportional to the amount of power produced, and expressed in mills/kWh (\$/MWh). The equations for these calculations are:

- Fixed O&M = Capacity Factor (CF) x Total O&M (\$/kW-yr)
- Variable O&M =
$$\frac{(1 - CF) \times \text{Total O\&M (\$/kW-yr)} \times 1000 \text{ mills/\$}}{(CF \times 8760 \text{ h/yr})}$$

The results of the evaluation of the individual categories of O&M expenses are shown on the table included in Section 5.4 (Capital Investment and Revenue Requirement Summary) along with summary TPC, TPI and TCR values.

Table 4-6

MAINTENANCE FACTORS	
Case Title: Base Case	
Item/Description	Maintenance %
COAL & SORBENT HANDLING	2.0
COAL & SORBENT PREP.& FEED	3.5
FW,COND.& MISC.SYS.	2.2
AFBC BOILER & ACCESSORIES	
AFBC Boiler	3.5
Open	NA
Open	NA
Interconnecting Pipe	NA
FLUE GAS CLEANUP	4.2
COMBUSTION TURBINE/ACCESSORIES	
Combustion Turbine Generator	NA
Combustion Turbine Accessories	NA
HRSG, DUCTING & STACK	
Heat Recovery Steam Generator	NA
Stack	1.4
STEAM TURBINE GENERATOR	
Steam TG & Accessories	1.5
Turbine Plant Auxiliaries	1.7
COOLING WATER SYSTEM	1.2
ASH/SPENT SORBENT HANDLING SYS	3.3
ACCESSORY ELECTRIC PLANT	1.2
INSTRUMENTATION & CONTROL	0.5
IMPROVEMENTS TO SITE	1.2
BUILDINGS & STRUCTURES	1.5

4.4 COST OF ELECTRICITY (COE)

The revenue requirement method of performing an economic analysis of a prospective power plant is widely used in the electric utility industry. This method permits the incorporation of the various dissimilar components for a potential new plant into a single value that can be compared to various alternatives. The revenue requirement figure-of-merit is COE, that is the levelized (over plant life) coal pile-to-busbar cost of power expressed in mills/kWh. The value, based on EPRI definitions and methodology, includes the TCR, which is represented in the levelized carrying charge (sometimes referred to as the fixed charges), levelized fixed variable operating and maintenance costs, levelized consumable operating costs, and the levelized fuel cost.

The levelized carrying charge, applied to TCR, establishes the required revenues to cover return on equity, interest on debt, depreciation, income tax, property tax, and insurance. Levelizing factors are applied to the first year fuel, O&M costs, and consumable costs to yield levelized costs over the life of the project. A long-term inflation rate of 5%/yr. was assumed in estimating the cost of capital and in estimating the life cycle revenue requirements for other expenses (except that fuel was escalated at 5.4%/yr.). To represent these varying revenue requirements for fixed and variable costs, a "levelized" value was computed using the "present worth" concept of money based on the assumptions shown in the basis table resulting in a levelized carrying charge of 16.5% and levelization factor of 1.612 for all other-than-coal and 1.677 for coal.

By combining costs, carrying charges, and levelizing factors, a levelized COE for the 65% design capacity factor was calculated along with the levelized constituent values. The format for this cost calculation is:

$$\text{Power Cost (COE)} = \frac{(\text{LCC} + \text{LFOM}) \times 1000 \text{ mills/\$}}{\text{CF} \times 8760 \text{ h/y}} + \text{LVOM} + \text{LCM} - \text{LB} + \text{LFC}$$

where:

LCC	=	Levelized carrying charge, \$/kW-y
LFOM	=	Levelized fixed O&M, \$/kW-y
LVOM	=	Levelized variable O&M, mills/kWh
LCM	=	Levelized consumable, mills/kWh
LB	=	Levelized by-products (if any), mills/kWh
LFC	=	Levelized fueled costs, mills/kWh
CF	=	Plant capacity factor, %

The consolidated basis for calculating capital investment and revenue requirements is given in the succeeding Table 4-7 titled Estimate Basis/Financial Criteria for Revenue Requirement Calculations. The principle cost and economics output for this study, Table 4-8, the Capital Investment and Revenue Requirement Summary, presents key TPC values and other significant capital costs operating costs, maintenance costs, consumables, fuel cost and the levelized busbar COE. Figure 4-1 provides a graphic illustration of the COE breakdown.

Table 4-7

ESTIMATE BASIS/FINANCIAL CRITERIA for REVENUE REQUIREMENT CALCULATIONS			
GENERAL DATA/CHARACTERISTICS			
Case Title:	Base Case		
Unit Size:/Plant Size:	400.5 MW,net	400.5 MWe	
Location:	Ohio River Valley		
Fuel:	Pitts.#8		
Plant Heat Rate–Full Load:/Avg.:	9,926 Btu/kWh	9,926 Btu/kWh	
Levelized Capacity Factor:	65 %		
Capital Cost Year Dollars:	1991 (December)		
Delivered Cost of Coal:	1.60 \$/x10^6 Btu(at startup)		
Design/Construction Period:	3 years		
Plant Startup Date(year):	1992 (January)		
Land Area/Unit Cost	260 acre	\$1,300 /acre	
FINANCIAL CRITERIA			
Project Book Life:	30 years		
Book Salvage Value:	0.0 %		
Project Tax Life:	15 years		
Tax Depreciation Method:	Reform		
Property Tax Rate:	1.0 % per year		
Insurance Tax Rate:	1.0 % per year		
Federal Income Tax Rate:	38.0 %		
State Income Tax Rate:	6.0 %		
Investment Tax Credit/% Eligible	0.0 %	0 %	
Capital Structure	% of Total	Cost(%)	
Common Equity	45	13.4	
Preferred Stock	10	10.0	
Debt	45	10.0	
Weighted Cost of Capital:		11.5 %	
Escalation Rates(Apparent)			
General Escalation:	5.0 % per year		
Fuel Price Escalation:	5.4 % per year		

Table 4-8

CAPITAL INVESTMENT & REVENUE REQUIREMENT SUMMARY			
TITLE/DEFINITION			
Case:	Base Case		
Plant Size:	400.5 (MW,net)	HeatRate:	9,926 (Btu/kWh)
Fuel(type):	Pitts.#8	Cost:	1.60 (\$/MMBtu)
Design/Construction:	3 (years)	BookLife:	30 (years)
TPC(Plant Cost) Year:	1991 (Dec.)	TPI Year:	1992 (Jan.)
Capacity Factor:	65 (%)		
CAPITAL INVESTMENT		\$x1000	\$/kW
Process Capital & Facilities		384,446	959.9
Engineering(incl.C.M.,H.O.& Fee)		46,133	115.2
Process Contingency			
Project Contingency		64,587	161.3
		-----	-----
TOTAL PLANT COST(TPC)		\$495,166	1236.4
TOTAL CASH EXPENDED	\$471,961		
AFDC	\$54,638		
TOTAL PLANT INVESTMENT(TPI)		\$526,598	1314.8
Royalty Allowance			
Preproduction Costs		14,166	35.4
Inventory Capital		11,600	29.0
Initial Catalyst & Chemicals(w/equip.)			
Land Cost		338	0.8
		-----	-----
TOTAL CAPITAL REQUIREMENT(TCR)		\$552,703	1380.0
OPERATING & MAINTENANCE COSTS(First Year)		\$x1000	\$/kW-yr
Operating Labor		6,917	17.3
Maintenance Labor		3,773	9.4
Maintenance Material		5,659	14.1
Administrative & Support Labor		3,207	8.0
		-----	-----
TOTAL OPERATION & MAINTENANCE(1st yr.)		\$19,557	48.8
FIXED O & M (1st yr.)			31.74 \$/kW-yr
VARIABLE O & M (1st yr.)			3.00 mills/kWh
CONSUMABLE OPERATING COSTS(less Fuel)		\$x1000	mills/kWh
Water		1,807	0.79
Chemicals		4,557	2.00
Other Consumables			
Waste Disposal		219	0.10
		-----	-----
TOTAL CONSUMABLES(1st yr.,-fuel)		\$6,583	2.89
BY-PRODUCT CREDITS(First Year)			
FUEL COST(First Year)		\$36,217	15.88
LEVELIZED OPERATION & MAINTENANCE COSTS			
Fixed O & M			51.2 \$/kW-yr
Variable O & M			4.8 mills/kWh
Consumables			4.7 mills/kWh
By-product Credit			mills/kWh
Fuel			26.6 mills/kWh
LEVELIZED CARRYING CHARGES(Capital)			227.7 \$/kW-yr
LEVELIZED BUSBAR COST OF POWER			85.1 mills/kWh
30 Year at a Capacity Factor of:	65%		

Figure 4-1

CIRCULATING AFBC REFERENCE PLANT COMPONENTS OF COE

COMPONENTS OF COE CAPITAL COST(Carrying Charges) Component Fractions (%)

Fractions of capital cost based on 1991 TPC \$
 TPC = \$495 million (1236 \$/kW)
 % fractions include engineering & contingency

COE based on 30 year, levelized current dollars
 COE = 85.1 \$/MWH (mills/kWH)

5.0 CONCLUSION AND RECOMMENDATIONS

The Nucla Clean Coal Project has operated for over 15,700 hours, and has achieved better than 90% sulfur removal, NO_x emissions less than 0.18 lb/10⁶ Btu and 99.9% removal of particulates, thus meeting all NSPS requirements. Tests to establish the effects of plant load, excess air, primary-to-secondary air ratio, unit operating temperature, coal and limestone feed configuration, and coal type and size distributions on emissions performance and combustion and boiler efficiencies have been successfully completed.

These successes have contributed to the fact that large numbers of orders for this type of equipment have been placed with Pyropower and other manufacturers in recent years. The test program has also been instrumental in effecting the changes that have taken place in equipment design and materials use for circulating AFB boilers in recent years. Examples of this are presented in Section 3. It is apparent that CFB boilers are an established option for utilities considering the addition of capacity to their system, or in retrofitting existing capacity. Continued operation and improved reliability will serve to increase utility confidence in the technology.

CFB technology has achieved a large unit size in a relatively short time of development. Because of the recent commercial success of this type of equipment and the physical sizes that are currently being offered with commercial warranties, the CFB Reference Plant size chosen to represent a well established commercial product in the near future for this study is conservative.

Table 5-1
ECONOMIC SUMMARY

	<u>\$ x 1000</u>	<u>\$/kW</u>
Total Capital Requirement	552,703	1,380
Fixed O&M (1st year)		31.82 \$/kW-yr
Variable O&M (1st year)		3.01 mills/kWh
Total Consumables (1st year)	6,583	2.89
Fuel Cost (1st year)	36,217	15.88
Levelized Busbar Cost of Power		87.9 mills/kWh

As can be seen in Table 5-1, the Reference Plant described herein is expected to require a capital expenditure of 1,380 \$/kW, and to produce electricity for a levelized cost of 87.9 mills/kwh. Since this is the first in a series of clean coal plants to be evaluated as a part of this program, comparisons will be made in subsequent reports. In general, these costs seem to compare favorably with costs of other plants with the same vintage and characteristics.

It is recommended that the progress of CFB technology be monitored closely and that this Reference Plant design be updated as major advances occur. Parallel efforts of FBC development are also ongoing with different versions of AFB technology. The applicability of the various designs with regard to load change, minimum load, emissions mitigation potential, combustor maximum size limitations, efficiency, and reliability should be evaluated, since each design has unique advantages. These developments should also be monitored, and comparisons made of commercial reference plant designs which are based on similar design criteria.

6.0 REFERENCES

1. Nucla Circulating Atmospheric Fluidized Bed Demonstration Project Final Technical Report, Colorado-Ute Electric Assoc., Inc., DOE DE-FC21-89MC25137, August, 1991.
2. Article, "Fluidized Bed Boilers", Power Magazine, March, 1991.
3. Technical Paper, "The NISCO Cogeneration Project 100 MWe Circulating Fluidized Bed Reheat Steam Generator", S. J. Goidich, et. al., 11th Int'l. FBC Conference, Montreal, Canada, April 21-24, 1991.
4. Technical Paper, "Two Boilers-One Turbine: Multiple Steam Blending System", M. H. Binstock, Westinghouse Electric Corp. and R. L. Criswell, Foster Wheeler Energy Corp., ISA 1982.
5. Technical Paper, "Conceptual Design of a 350 MWe Circulating Fluidized-Bed Power Generating Plant", H. Isaka, Electric Power Development Company, Ltd., Tokyo and K. H. Hyvarinen, A Morita, K Yano, and M. Ooide, Shinko Pyropower, Ltd., Tokyo; 1989 International Conference on Fluidized Bed Combustion.
6. Technical Paper, "The Unique Control Problems of Circulating Fluidized Combustion Systems", Bordon L. Johnson, Bechtel Power Corporation, ISA, 1989.
7. Technical Paper, "Startup and Preliminary Operation of the Largest Circulating Fluid Bed Combustion Boiler in a Utility Environment -- NUCLA CFB Demonstration Project", Robert H. Melvin, Colorado-Ute Electric Association, Inc., and Reid E. Bichnell, United Engineers and Constructors.

7.0 BIBLIOGRAPHY

- De Laval Engineering Handbook, H. Gartman, Ed., McGraw-Hill, New York, 1970
- DOE/FE-0195P, March, 1990, Clean Coal Demonstration Program, Annual Report to Congress.
- EPRI Technical Brief RP2683 TB.GS.86.11.89, Colorado-Ute 110 MW AFBC Plant: Test Program.
- EPRI CS-5831 Final Report, Colorado-Ute's Nucla Circulating AFBC Demonstration Project, United Engineers and Constructors, Inc.
- Friedman, M. A., et. al., "The First Year of Operation at Colorado Ute Electric Association's 110 MWe Circulating Fluidized Bed Boiler", Proceedings: 1988 Seminar on Fluidized Bed Combustion Technology for Utility Applications, EPRI.
- Friedman, M. A., et. al., "The First One and One-Half Years of Operation at Colorado-Ute Electric Association's 110-MWe Circulating Fluidized Bed Boiler", 1989 International Conference on Fluidized Bed Combustion.
- Friedman, M. A. and Boyd, T. J., "Test Program Status at Colorado-Ute Electric Association's 110 MWe Circulating Fluidized Bed Boiler", Proceedings: 1989 International Conference on Fluidized Bed Combustion.
- Shang, J. Y., "Research and Development Needs for Fluidized Bed Combustion", 1989 International Conference on Fluidized Bed Combustion.
- Tang, J., et. al., "Combustion of Colorado-Ute Coal in a 1.5 MWt Ahlstrom Pyroflow Pilot Plant", Proceedings: 1986 Seminar on Atmospheric Fluidized Bed Combustion Technology for Utility Applications, EPRI.
- Weinberg, A., Holcombe, L., & Butler, R., Radian Corp., "Field Study of Water from Fluidized Bed Combustion Technologies", Draft Report.

APPENDIX A

BASELINE PLANT

MAJOR EQUIPMENT LIST

**APPENDIX A
NUCLA PLANT
MAJOR EQUIPMENT LIST**

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
BOILER AND AUXILIARIES			
Boiler	925,000 lb/hr, 1510 psig, 1005°F	1	See Below
Combustion Chambers 4A & 4B	N/A	2	N/A
Economizer 4A	N/A	1	N/A
Steam Drum 4A - 63" o.d. x 40' - 2.5" S/S	1760 psig, 650 °F	1	N/A
Coal Silo Isolation Valves 4A-4F	N/A	6	N/A
Coal Gravimetric Feeders 4A-4F 30" belt	71,800 lbs/hr	6	2HP, 1-1/2 HP
Coal Feed Inclined Conveyers 4E & 4F, Drag Chain Conveyor, 11" wide	71,800 lbs/hr	2	20 HP
Coal Feed Horizontal Conveyors 4E & 4F, 8" wide	71,800 lbs/hr	2	10 HP
Coal Rotary Airlock Feeders 4A - 4F, 18"	71,800 lbs/hr	6	3 HP
Boiler Isolation Gate Valves 4A - 4F, 18" x 18"	N/A	6	0.4 HP
Boiler Limestone Silo Gyrated Bin Dischargers 4A & 4B	N/A	2 (one per silo)	3 HP
Limestone Pneumatic Feed Systems 4A-4H	3125 lb/hr	8	See Below
Limestone Silo Isolation Gates 4A & 4B, 14" knife gates, pneumatic	N/A	2	N/A
Limestone Feeders 4A & 4B Loss-in-weight, 24"	12,500 lbs/hr	2	1-1/2 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Limestone Rotary Airlock Valves 4A - 4H, 6"	4,550 lbs/hr	8	N/A
Limestone Blowers 4A - 4H Rotary	262 CFM @ 5.9 psig	8	15 HP
Primary Air Fan 4A (includes coupling and variable frequency drive system) Centrifugal with backward inclined airfoil blades	265,300 cfm @ 70.2" w.c. & 120°F (test block)	1	3500 HP
Secondary Air Fan 4A (including coupling and variable frequency drive system) Centrifugal with airfoil blades	82,100 cfm @ 41.4" w.c. & 120°F (test block)	1	700 HP
Induced Draft Fan 4A (including coupling and variable frequency drive system) Centrifugal with airfoil blades	525,730 cfm @ 31.9" w.c. & 300°F	1	3250
Air Heater 4A Tubular, 2-3/8" dia. carbon steel tubes	See Sect. 4.4.2	1	N/A
Baghouses 1,2 & 3 (existing) Shake and deflate, 6 compartment, continuous, automatic collector, 30,000 sq. ft. eff. cleaning area	N/A	3	See Below
Pressure Fan	550 acfm @ 12" w.c.	1 per baghouse	30 HP motor
Bagshakers	N/A	1 per baghouse	1.5 HP
Baghouse 4A Shake and deflate, 12 compartment, 95,712 sq. ft. eff. cleaning area	N/A	1	N/A
Deflate Fan	9250 acfm @ 16" w.c.	1	50 HP/7.5 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Shakers	N/A	12	2 HP
Startup Burners 4A-4F Retractable center fired	51.2 million Btu/hr	6 (3) per combust.	N/A
Duct Burners 4A & 4B In-line mounted, nozzle mixing, manifold inside 10'-2" x 53" PA duct	44.0 million Btu/hr	2 (1 per combust)	N/A
Stack 4A 12 ft. diameter, 215 ft. high	1,109,000 lbs/hr @ 243°F	1	N/A
Hot Cyclones 4A & 4B 23' diameter approx.	N/A	1	N/A
Loop Seals 4A & 4B	N/A	1	N/A
High-Pressure Blowers 4A & 4B centrifugal, 8 stages, 3550 rpm	2720 cfm @ 19.95 psia	2	150 HP
Economizer Sootblowers rotating lance, steam	N/A	12	3/4 HP each
Air Heater Sootblowers Retractable, steam	N/A	4 (2 hot section, 2 cold section)	3/4 HP each
Boiler Blowdown Flash Tank 4A 30" i.d., 4'-0" SS.	9,250 lbs/hr @ 150 psig, 650°F	1	N/A
Boiler Blowdown Tank 4A 4'-6" i.d., 7'-6" S.S.	150 psig/650°F	1	N/A

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
COAL HANDLING SYSTEM			
Coal Truck Dump Hopper (existing two compartment	59.4 tons active each compartment	1	N/A
Primary Coal Crusher Vibratory Feeders (existing)	30-62.5 tons per hour	2	5 HP
Primary Coal Crusher (existing) Single roll granulator	300 tons/hr 30" cube feed, 7" x 0 discharge	1	50 HP (belt drive)
Coal Transfer Conveyor 1A (existing)	N/A	1	15 HP
Coal Transfer Conveyor 1A Magnetic Detector (existing)	N/A	1	N/A
Secondary Coal Crusher Vibratory Feeder (existing) Vibratory	125 tons/hr	1	5 HP
Secondary Coal Crusher (existing) ring granulator type	125 tons/hr, 7"x10" feed, 3/4"x0 discharge	1	75 HP
Coal Conveyor A (existing) 24" wide belt	125 tons/hr	1	15 HP
Coal Conveyor A Belt Scale (new) Load cell with belt speed sensor	N/A	1	N/A
As Received Coal Sample System Equipment (existing) Primary Sample Cutter Sample Hopper Primary Belt Feeder Sample Crusher Secondary Screw Conveyor Secondary Sample Cutter Rejects Bucket Elevator Sample Containers	N/A	1	N/A
Coal Conveyor B - Stackout Conveyor (existing) 24" wide belt	125 tons/hr	1	15 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Coal Conveyor C 24" wide belt (existing)	125 tons/hr	1	20 HP
As-Fired Coal Sample System (new)	N/A	1	N/A
Coal Crusher Feed Conveyors 4A & 4B 17" drag chain conveyors	140 tons/hr each	2	40 HP
Coal Surge Bin 4A	400 cubic ft.	1	N/A
Coal Crusher Vibratory Feeders 4A & 4B	30 to 100 ton/hr	2	N/A
Coal Crushers 4A & 4B reversible impactor type	75 ton/hr each 1-1/2"x0 feed, 1/4" x 0 discharge	2	125 HP
Coal Silo Feed Conveyors 4A & 4B 13" drag chain conveyors	100 tons/hr	2	10 HP
Coal Silos 4A & 4B 28'-0" i.d., 30'-0" high	234 tons	2	N/A
Coal Dust Collection System 4A Equipment Dust Collector Bag Filter Pulsed Jet, 2390 sq. ft.	N/A	1	N/A
Rotary Air Lock Valve	N/A	1	1 HP
Exhauster Fan	14,000 cfm, 15" w.g. static	1	50 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
LIMESTONE HANDLING SYSTEM			
Limestone Truck Hopper 4A Approx. 12' x 14' x 10' deep	640 cubic ft., 25 tons	1	N/A
Limestone Primary Crusher Vibrating Feeder 4A 48" wide x 9'-0" long	75 tons/hr	1	2 HP
Limestone Primary Crusher 4A Reversible hammermill	75 tons/hr	1	125 HP
Limestone Crushed Rock Belt Conveyor 4A	75 tons/hr	1	7.5 HP
Limestone Belt Scale 4A	N/A	1	N/A
Limestone Magnetic Separator 4A	N/A	1	2 HP
Limestone Bucket Elevator 4A	75 tons/hr	1	3 kW magnet 20 HP
Limestone Storage Silo 4A 25'-3" i.d., 77'-10" high	19,000 cu. ft. volume, effective capacity 850 tons	1	N/A
Limestone Vibrating Bin Discharger 4A 7'-0" dia.	N/A	1	1.5 HP
Limestone Pulverizer Mill Vibrating Feeder 4A 18" wide x 14'-0" long	9 tons/hr	1	3/4 HP
Limestone Pulverizer Mill 4A Roller mill	9 tons/hr	1	200 HP
Limestone Pulverizer Mill Air Heater 4A, natural gas fired	3 million Btu/hr	1	1 HP
Limestone Pulverizer Mill Fan 4A	15,500 cfm @ 40" w.c.	1	200 HP
Limestone Pulverizer Cyclone 4A 11 ft. dia.	97-98% based on 1000 micron	1	N/A
Limestone Pulverizer Dust Collector 4A			

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Pulsed jet bag filter, 1788 sq. ft.	N/A	1	N/A
Screw Feeder	N/A	1	3 HP motor
Rotary Feeder	N/A	1	1-1/2
Limestone Pulverizer Dust Collector Exhaust Fan 4A	N/A	1	30 HP
Limestone Surge Hopper 4A 36" dia. x 4'-9" high	14 cu. ft.	1	N/A
Limestone Transport Feeder 4A	9 tons/hr	1	1
Limestone Transport Blower 4A	1658 acfm @ 9 psig	1	100 HP
Limestone Silos 4A & 4B 16'-8" i.d., 26'-4" high	3600 cu. ft., 135 tons	2	N/A
Limestone Silo Bin Vent Filters 4A & 4B Pulse jet	N/A	2 (one per silo)	N/A
Limestone Dust Collection System 4A	N/A	1	N/A
Limestone Dust Collector 4A	18,900 cfm	1	N/A
Rotary Valve (10 x 10)	N/A	1	1 HP
Limestone Dust Collector Fan 4A	18,900 cfm, 12" w.g.	1	75 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
ASH HANDLING SYSTEMS			
Baghouses 1-3 Fly Ash Conveying System	30 tons/hr	1	See Below
Baghouse 4A and Boiler 4A Fly Ash Conveying System	30 tons/hr	1	See Below
Fly Ash Conveying Vacuum Blowers 4A - 4C	2,950 acfm @ 15.4 in. Hg vacuum	3	125 HP
Fly Ash Silo 4A 40' dia. x 73' high, mass flow	60,000 cu. ft., 720 tons	1	N/A
Fly Ash Silo Primary Separators 4A & 4B Cyclone type	N/A	2	N/A
Fly Ash Silo Secondary Separators 4A & 4B Bag Filter, pulsed jet cleaned	N/A	2	N/A
Fly Ash Silo Bin Vent Filter 4A Bag Filter, pulsed jet cleaned	N/A	1	N/A
Fly Ash Silo Unloading Feeder 4A Two-speed screw conveyor	N/A	1	N/A
Fly Ash Silo Unloader 4A Rotary drum	7,000 cu. ft/hr	1	30 HP
Fly Ash Silo Unloading Spout 4A	N/A	1	1-1/2 HP hoist 3 HP fan
Pulse Jet Cleaning Air Compressors 4A & 4B	85 cfm, 100 psig discharge	2	25 HP
Pulse Jet Air Dryers 4A & 4B	N/A	2	N/A
Ash Water Storage Tank (existing) 12' high x 12'-6" diameter	N/A	1	N/A
Ash Conditioning Water Pumps (one existing, one new)	225 gpm @ 250 ft.	2	40 HP
Bottom Ash Cooling Fan 4A Centrifugal type	14,100 cfm @ 72" w.g.	1	250 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Bottom Ash Fluidized Cooler/Classifiers 4A - 4D	8,100 lbs/hr	4, 2 per combust.	N/A
Bottom Ash Rotary Airlock Feeders 4A - 4D Rotary automatically reversing feeders	N/A	4	1-1/2 HP DC
Bottom Ash Hoppers 4A & 4B 8 ft. diameter	2 hours storage	2 (1 per combust)	N/A
Bottom Ash Screw Coolers 4A & 4B	11 tons/hr	2, (1 per combust)	10 HP
Bottom Ash Screw Cooler Outlet Hoppers 4A & 4B 24" i.d.	N/A	1	N/A
Bottom Ash Conveying System 4A	20 tons/hr	1	See Below
Bottom Ash Conveying Vacuum Blowers 4A & 4B	2810 cfm @ 15.2" Hg	2	150 HP
Bottom Ash Silo 4A (existing ash silo) Flat bottom, tile const., fluidized	200 tons	1	N/A
Bottom Ash Silo Bin Vent Filter 4A Bag filter with Nomex bags, pulsed jet cleaned	N/A	1	N/A
Bottom Ash Silo Primary Separator 4A Cyclone	N/A	1	N/A
Bottom Ash Silo Secondary Separator 4A Bag Filter, pulsed jet cleaned	N/A	1	N/A
Bottom Ash Silo Rotary Unloader 4A (existing) Drum dust mixer with integral feeder	65 tons/hr	1	N/A
Screw	N/A	1	7.5 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Drum	N/A	1	15 HP
Reinjection Ash Conveying System 4A 6" line with two 6" combustion chamber selector gates	20 tons/hr	1	See Below
Ash Reinjection Conveying Pressure Blower 4A	1035 cfm @ 8 psig	1	50 HP
Bottom Ash Silo Ash Reinjection Isolation Gate 4A Air operated knife gate	N/A	1	N/A
Ash Reinjection Airlock Feeder 4A	12 cu. ft.	1	N/A
Airlock Feeder Isolation Gate 4A Air operated knife gate	N/A	1	N/A

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
TURBINE GENERATORS AND BALANCED OF PLANT			
Turbine-Generators Units 1, 2 & 3 (existing)	12,650 kW	3	N/A
Turbine-Generator Unit 4A Turbine Single flow, condensing, extraction	73,285 kW	1	N/A
Condensers 1, 2 & 3 (existing) Surface condenser, 12,000 sq. ft.	84,000 lbs/hr	3	N/A
Air Ejectors 1, 2 & 3 (existing) Dual stage steam jet	N/A	3	N/A
Hogging Jet Ejectors 1, 2 & 3 (existing) Single stage steam jet	N/A	1	N/A
Condenser 4A Two pass surface condenser, 47,707 sq. ft.	354,135 lbs/hr	1	N/A
Steam Jet Air Ejector 4A 2 stage steam jet	N/A	1	N/A
Priming Ejector 4A Steam jet	N/A	1	N/A
Auxiliary Boiler 4A Firetube	20,000 lbs/hr	1	30-ton 3/4-oil pump 5-compressor
Condensate Pumps 1A, 1B, 2A, 2B, 3A & 3B (existing)	270 gpm, 325 ft.	6	40 HP
Low-Pressure Feedwater Heaters 1A, 2A & 3A (existing)	105,203 lbs/hr	3	N/A
Low-Pressure Feedwater Heaters 1B, 2B & 3B (existing) EU shell and tube	105,203 lbs/hr	3	N/A

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Deaerator Feedwater Heaters & Storage Tanks 1C, 2C & 3C (existing)	140,000 lbs/hr	3	N/A
Unit Condensate Transfer Pumps 1A, 2A, & 3A (new) Horizontal centrifugal, end suction	315 gpm @ 375 ft.	3	50 HP
Condensate Pumps 4A & 4B Vertical can, 6 stages	1000 gpm, 560 ft.	2	200 HP
Low-Pressure Feedwater Heater 4A	455,140 lb/hr condensate	1	N/A
Low-Pressure Feedwater Heater 4B	455, 140 lb/hr condensate	1	N/A
Deaerating Feedwater Heater and Storage Tank 4C	755,576 lb/hr condensate	1	N/A
Boiler Feed Pumps 4A & 4B	1312 gpm @ 4368 ft.	2, 60% capacity	1750 HP
High-Pressure Feedwater Heater 4D	925,000 lb/hr	1	N/A
High-Pressure Feedwater Heater 4E	925,000 lb/hr	1	N/A
River Intake Screens Slotted pipes located below the river bed	N/A	4	N/A
Service Water Pumps (existing) Vertical	1500 gpm @ 240 ft. TDH	2	125 HP
Water Storage Tank (existing) 15 ft. dia. x 24 ft. high	31,000 gallons	1	N/A
Pressure Filters (existing) Anthracite pressure filter	N/A	2	N/A
Treated Water Pumps (one existing, one replaced) Vertical	180 gpm @ 80 ft.	2	7.5 HP
Backwash Pump (existing)	N/A	1	7.5 HP
Clearwell (existing) 14'-6" x 10'-0" x 8'-0" deep	N/A	1	N/A

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Demineralizer Caustic Tank 4A 8' i.d. x 14' S-S long	5,000 gallons	1	N/A
Demineralizer Acid Day Tank 4A	276 gallons	1	N/A
Cation Exchanger 4A & 4B 3 ft. dia. x 15 ft. high	50 gpm	2	N/A
Anion Exchanger 4A & 4B 3 ft. dia. x 12.5 ft. high	50 gpm	2	N/A
Mixed Bed Polisher 4A 2.5 ft. dia. x 11 ft. high	50 gpm	1	N/A
Demineralizer Caustic Water Heater 4A Shell an tube	10 gpm	1	N/A
Water Treatment Filter 4A & 4B dual media	50 gpm	2	N/A
Demineralizer Acid Transfer Pump 4A	600 GPD @ 50 psig	1	N/A
Demineralizer Caustic Regeneration Pump 4A & 4B	57 GPD @ 100 psig	2	1/2 HP
Closed Cooling Water Head Tank 4A 12" std. pipe x 10'-6" high	58 gallons	1	N/A
Closed Cooling Water Chemical Pot Feeder 4A	N/A	1	N/A
Closed Cooling Water Pumps 4A & 4B	400 gpm, 140 ft. TDH	2, 100% capacity	20 HP
Closed Cooling Water Heat Exchangers 4A & 4B Shell and tube	400 gpm	2, each 100% capacity	N/A
Ash Equipment Cooling Water Pumps 4A & 4B	460 gpm, 165 ft. TDH	2, 100% capacity	30 HP
Ash Equipment Cooling Water Heat Exchanger 4A Shell and tube	436 gpm	1	N/A
Oil/Water Separator 4A	50 gpm	1	N/A

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Septic Tanks 1, 4A & 4B (one replaced and two new)	1250 gallons - replaced 3000 gallons - new septic tanks	3	N/A
Condensate Storage Tanks 1, 2 & 3 (existing) Atmospheric	18,000 gallons	3	N/A
Condensate Storage Tank 4A 20 ft. dia. x 24 ft. high, conical	50,000 gallons	1	N/A
Deaerator Feed Pumps 1A, 1B, 2A, 2B, 3A & 3B (existing)	125 gpm, 280 ft. TDH	6, each 100% capacity	15 HP
Condensate Transfer Pump 4A 2 x 1-1/2 x 9 HC	150 gpm, 230 ft. TDH	1	20 HP
Circulating Water Pumps 1, 2 & 3 (existing) Vertical wet pit	15,000 gpm, 47 ft. TDH	3, 50% capacity	200 HP
Cooling Water Pumps 1A, 1B & 1C (replaced)	750 gpm, 49 ft. TDH	3	15 HP
Cooling Tower (existing) Evaporative, mechanical draft, cross flow	N/A	1 (3 cells)	100 HP
Circulating Water Pumps 4A & 4B Horizontally split, centrifugal, single stage, double suction, single volute	16,500 gpm, @ 45 ft.	2, 50% capacity	250 HP
Cooling Tower 4A Counterflow, induced draft	N/A	1	N/A
Feedwater Chemical Feed Systems			
Hydrazine Solution Tank w/Agitator 4A	100 gallons	1	1/4 HP
Hydrazine Feed Pump 4A (existing pump used)	3.2 gph, 1350 psig	1	1/3 HP
Amine Solution Tank w/Agitator 4A	100 gallons	1	1/4 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Amine Feed Pump 4A (existing pump used)	3.2 gph, 1350 psig	1	1/3 HP
Amine/Hydrazine Spare Feed Pump 4A (existing pump used)	3.2 gph, 1350 psig	1	1/3 HP
Boiler Chemical Feed System			
Phosphate Solution Tank w/Agitator 4A	100 gallons	1	1/4 HP
Phosphate Feed Pumps 4A & 4B	6.25 gph @ 2000 psig	1	2 HP
Cooling Tower Chemical Feed System			
Gas Chlorinator (existing)	500 lbs/day	1	N/A
Gas Chlorinators 4A (new)	2000 lb/day	1	N/A
Cooling Tower Acid Tank (existing tank relocated)	6000 gallons	1	N/A
Cooling Tower Acid Feed Pumps	0-13.5 gph, 100 psig	3, each 100% for one cooling tower	1/4 HP
Cooling Tower Chemical Solution Tank 4A w/Agitator	100 gallons	1	1/4 HP
Cooling Tower Chemical Feed Pumps (two existing and one new)	6.25 gph @ 75 psig	3, each 100% for one cooling tower	1/4 HP
Water Sampling and Monitoring System Water Sample Panel 4A	N/A	1	N/A
Circulating Water Sample System 4A	N/A	1	N/A
Logic & Control Room Air Handling Units AHU-4A & 4B	11,470 acfm	2 full capacity	15 HP each
Logic & Control Room Air Cooled Condensing Units CU-4A & 4B	30 tons	2 full capacity	34 kW

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Control Room Duct Heater DH-1 & Logic Room Duct Heater DH-2	70 kW	1 of each	70 kW
Maintenance Shop Office Packaged Air Conditioner AC-1	2.65 kW	1	2.65 kW
Stack Monitoring Equipment Building Packaged Heat Pump AC-2	4.1 kW	1	N/A
Heating System Deaerator 4A	45,000 lbs/hr	1	N/A
Heating System Condensate Pumps 4A & 4B (provided with deaerator)	58 gpm, 377 ft. TDH	2 full capacity	20 HP
Boiler and Turbine Room Steam Unit Heaters UH-1 thru 20	N/A	20	1-1/2 HP
Electrical & Maintenance Shop Steam Unit Heaters UH-21 thru 24	N/A	4	1/2 HP
Ash Blower Building Electric Unit Heaters EUH-1 & 2	20 kW	2, 50% capacity each	20 kW
Cooling Tower Chemical Building Electric Unit Heaters EUH-3 & 4	7 kW	2, 50% capacity each	7 kW
Stack Monitoring Equipment Building Electric Unit Heater EUH-5	3 kW	1	3 kW
Ash Blower Bldg. Elect. Equip. Room Electric Unit Heater EHU-6	7 kW	1	7 kW
Electrical Room Supply Fan F-4	N/A	1	3 HP
Maintenance Shop Supply Fan F-2	N/A	1	1/2 HP
Maintenance Shop Toilet Exhaust Fan F-6	N/A	1	1/12 HP
Electrical Shop Supply Fan F-1	N/A	1	1/4 HP
Boiler Room Roof Supply & Exhaust Fans F-7 thru 9	N/A	3, 33% capacity	25 HP each
Battery Room Exhaust Fan F-3	N/A	1	1/12 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Control Room Toiler Exhaust Fan F-5	N/A	1	1/12 HP
Elevator Machine Room Supply and Shaft Supply Fans F-15 & 16	N/A	2, 50% capacity each	1-1/2 HP each
Cooling Tower Chemical Building Supply Fan F-11	N/A	1	1/4 HP
Ash Blower Building Electrical Equipment Room Supply Fan F-12	N/A	1	1/2 HP
Ash Blower Building Supply Fan F-13	N/A	1	3 HP
Cooling Tower Electrical Building Supply Fan F-14	N/A	1	1-1/2 HP
Standby Service Air Compressor (existing), rotary type	370 cfm @ 110 psig	1	75 HP
Emergency Service Air Compressor (existing), reciprocating type	300 cfm @ 100 psig	1	75 HP
Air Dryer (existing)	235 scfm	1	N/A
Service Air Receiver (existing)	125 psig, 650#F 87 cu. ft.	1	N/A
Instrument Air Receiver (existing)	125 psig 40 cu. ft.	1	N/A
Service Air Compressors 4A & 4B	610 acfm @ 110 psig	2, 100% capacity each	125 HP
Service Air Receiver 4A	125 psig, 110#F 88.2 cu. ft.	1	N/A
Instrument Air Compressor 4A Rotary Screw	1022 acfm @ 110 psig, 112#F	1	250 HP
Instrument Air Receiver 4A	125 psig, 112#F 140 cu. ft.	1	N/A
Instrument Air Dryer 4A desiccant type	1000 scfm	1	263 kW

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Turbine Room Crane (existing) CIP electric operated	25-ton/5 ton	1	20 HP-hoist 5 HP-bridge (2) 10 HP-trolley
Turbine Bay Crane 4A	60 ton/15 ton	1	30 HP-main hoist 6 HP-aux. hoist 4 HP-trolley 5 HP-bridge (2)
Plant Elevator 4A	2000 lbs	1	N/A
Centrifuge 1/2 (existing for units 1 & 2 alternately)	1,500 liters/hr	1	N/A
Centrifuge 3 (existing for unit 3)	45 gallons/hr	1	N/A
Lube Oil Storage Tanks 4A & 4B 10 ft. i.d. x 16 ft. high, conical roof	7,500 gallons each	1	N/A
Turbine Lube Oil Transfer Pump 4A	20 gpm, 50 psig	1	3 HP
Turbine Lube Oil Reservoir Transfer Pump 4A	20 gpm, 50 psig	1	3 HP
Turbine Lube Oil Conditioner 4A bag filter type w/polishing filter	1200 gallons/hr	1	N/A
Filter Pump	1200 gals/hr	1	1.5 HP
Vapor Extractor	N/A	1	1/6 HP
Waste Oil Sump Pump 4A	100 gpm, 25 ft. head	1	1 HP
Waste Oil Tank 4A 10 ft. i.d. x 16 ft. high, conical roof	7,500 gallons	1	N/A
Fire Booster Pump 4A Horizontal Centrifugal	1000 gpm, 170 ft. TDH	1	75 HP

<u>Description</u>	<u>Rating (each)</u>	<u>Quantity</u>	<u>MHP each</u>
Pressure Maintenance Fire Pump 4A Horizontal Centrifugal	10 gpm, 170 ft. TDH	1	1 HP
Propane Storage Tank 4A	30,000 gallons	1	N/A
Propane Vaporizers 4A & 4B Water bath direct-fired	(1) 2,500 gallons/hr, (1) 2,000 gallons/hr	2	N/A
Propane Backup Supply Pump 4A	N/A	1	N/A
Main Step-up Transformers 1, 2 & 3 (existing)	12,000 kVA	3	N/A
Isolated Phase Buses, 1, 2 & 3	N/A	1	N/A
Main Generator Step-up Transformer 4A	88,200 kVA	1	N/A
Isolated Phase Bus 4A	N/A	2, 100% capacity	N/A
Unit Auxiliary Transformer 4A	N/A	1	N/A
Unit Auxiliary Non-Segregated Phase Bus 4A	N/A	1	N/A
4160 Volt Switchgear Bus 4A	N/A	1 lineup	N/A
Load Centers 4A & 4B	N/A	2 lineups	N/A
480 Volt Motor Control Centers 4A thru 4G	N/A	7	N/A
Relay Cabinets and Control Panels	N/A	1	N/A
Rotary UPS System 4A Rotary motor-generator set	N/A	1	N/A
Distributed Control System 4A	N/A	1	N/A
Stack Monitoring System 4A	N/A	1	N/A
Hard Wired Control Panel 4A	N/A	1	N/A

APPENDIX B

REFERENCE PLANT

MAJOR EQUIPMENT LIST

CONDENSATE AND FEEDWATER SYSTEM

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Surface Condenser	Two Shell, Transverse	2.05 x 10 ⁶ lb/hr 2.5 in Hg	1
2	Condensate Pumps	Vert. Canned	2,000 gpm @ 850'	3
3	L.P. F.W. Htr. 1A/1B	Horiz. U tube	2,672,000 lb/hr 110°F to 160°F	1
4	L.P. F.W. Htr. 2A/2B	Horiz. U tube	2,672,000 lb/hr 160°F to 229°F	1
5	L.P. F.W. Htr. 3	Horiz. U tube	2,672, 000 lb/hr 229°F to 258°F	1
6	L.P. F.W. Htr. 4	Horiz. U tube	2,672,000 lb/hr 258°F to 317°F	1
7	Deaerator and Storage Tank	Horiz. Spray Type	2,672,000 lb/hr 317°F to 362°F	1
8	Cond. Vacuum Pumps	Rotary Waster Sealed	2,000/20 scfm	2
9	Cond. Storage Tank	Field Fab.	250,000 gal.	2
10	B.F. Booster Pumps	Horiz. Split	3,000 gpm @ 400'	3
11	B.F. Pumps/ Turbines	Staged HP Centr.	4,000 gpm @ 7,300'	2
12	Startup B.F. Pump	Staged HP Centr.	1,500 gpm @ 7,300'	1
13	H.P. F.W. Htr. 6	Horiz. U tube	1,580,500 lb/hr 369°F to 410°F	2
14	H.P. F.W. Htr 7	Horiz. U tube	1,580,500 lb/hr 410°F to 480°F	2

CIRCULATING WATER SYSTEM

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Cooling Tower	Mech Draft	280,000 gpm 90#F to 75#F	1
2	Circ. W. Pumps	Vert. Wet Pit	140,000 gpm @ 100'	2

COAL RECEIVING AND HANDLING

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Car Dumper Receiving Hopper	N/A	100 Ton	4
2	Feeder	Vibratory	235 TPH	4
3	Conveyor #1	54" Belt	900 TPH	1
4	As-Received Coal Sampling System	Two Stage	N/A	1
5	Conveyor #2	54" Belt	900 TPH	1
6	Coal Stacker	Double Wing	900 TPH	1
7	Active Pile Reclaim Hopper	N/A	30 Ton	3
8	Feeder	Vibratory	643 TPH	3
9	Emergency Coal Hopper	N/A	30 Ton	1
10	Feeder	Vibratory	643 TPH	1
11	Conveyor #3A	48" Belt	643 TPH	1
12	Conveyor #3B	48' Belt	643 TPH	1
13	Coal Surge Bin W/ Vent Filter	Compartment	300 Ton	1
14	Feeder	Vibratory	643 TPH	2
15	Flop Gate	N/A	643 TPH	2
16	Crusher	Granulator Reduction	6"x0"-3"x0"	2
17	Crusher	Impactor Reduction	3"x0"-1/4"x0"	2
18	Conveyor #4A	48" Belt	643 TPH	1
19	Conveyor #4B	48" Belt	643 TPH	1
20	As-Fired Coal Sampling System	Swing Hammer	643 TPH	2
21	Conveyor #5A	48" Belt	643 TPH	1
22	Conveyor #5B	48" Belt	643 TPH	1
23	Tripper #2	N/A	643 TPH	1

24	Coal Bunker W/ Vent Filter And Slide Gates	Compartment	1,389 Ton	2
25	Feeder	Gravimetric	44 TPH	4
26	Feeder	Rotary	44 TPH	8

LIMESTONE RECEIVING AND HANDLING

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Truck Unloading Hopper	N/A	35 Ton	1
2	Feeder	Vibratory	225 TPH	1
3	Conveyor #1	36" Belt	225 TPH	1
4	Conveyor #2	36" Belt	225 TPH	1
5	Tripper #1	N/A	225 TPH	1
6	Storage Building	"A"-Frame	25,920 TONS	1
7	Portal Scraper Reclaimer	N/A	200 TPH	1
8	Conveyor #3	36" Belt	200 TPH	1
9	Conveyor #4	36" Belt	200 TPH	1
10	Tripper #2	N/A	200 TPH	1
11	Surge Bin W/ Vent Filter	N/A	200 Ton	1
12	Feeder	Vibratory	50 TPH	4
13	Rod Mill (BMR)	N/A	50 TPH	4
14	Dust Collection Separator W/ Rotary Feeder	Dilute Phase	N/A	2
15	Conveyor #5A	36" Belt	100 TPH	1
16	Conveyor #5B	36" Belt	100 TPH	1
17	Limestone Silo W/ Vent Filter	N/A	1,440 Ton	2
18	Transporter W/ Air Compressor	Dense Phase	20 TPH	4
19	Limestone Day Bin W/ Vent Filter And Slide Gate	N/A	160 Ton	4
20	Feeder	Gravimetric	10 TPH	4
21	Feeder	Rotary	10 TPH	8

ASH HANDLING

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Baghouse Collecting Hoppers	Vacuum System	52 TPH	32
2	Primary Separator	Vacuum	52 TPH	2
3	Secondary Separator W/ Wafer Valve	Vacuum	52 TPH	2
4	Flyash Silo W/ Vent Filter And Slide Gate	Concrete Silo	1,860 Ton	1
5	Bottom Ash Silo W/ Vent Filter And Slide Gate	Concrete Silo	1,860 Ton	1
6	Feeder W/ Slide Gate	Wet Unloader (Pug Mill)	150 TPH	2
7	Unloading Chute	Telescopic	150 TPH	2
8	Vacuum Pump	Rotary	10 In-Hg	3
9	Bottom Ash Surge Bin W/ Ash Valves	Compartment	25 Ton	1
10	Conveyor	Chain	52 TPH	1
11	Clinker Grinder	Roll	52 TPH	1
12	Ash Cooler W/ Slide Gate	Screw	52 TPH	1

STEAM GENERATOR AND ANCILLARY EQUIPMENT

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Boiler with cyclones, connection section, loop seal	CFB	200 MWe, 1,580,454 PPH steam at 2660 PSIG/ 1000°F	2
2	Primary Air Fan	Cent.	624,000 PPH, 141,000 ACFM, 74" WG, 3500 HP	4
3	Secondary Air Fan	Cent.	634,000 PPH, 144,000 ACFM, 36" WG, 2000 HP	2
4	High Pressure Fluidizing Fan	Multi-Stage Cent.	18,000 PPH, 200" WG, 250 HP	4
5	I.D. Fan	Cent.	1,133,000 PPH, 372,000 ACFM, 22" WG 3000 HP	4
6	Fabric Filter + Baghouse	Reverse air	2/1 A/C Ratio, 10" WG DP, 10 COMP., BAGS 12" DIA X 35', Inlet Dust 4.74gr/ACF	2
7	Stack	285' High x 29' Dia.	1" Draft, 30fps,	2

TURBINE GENERATOR AND AUXILIARY EQUIPMENT

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	400 MW Turbine Generator	TC4F26	2400#, 1000/ 1000#F	1
2	Bearing Lube Oil Coolers	Shell & Tube	-	2
3	Bearing Lube Oil Conditioner	Pressure Filter Closed Loop	-	1
4	Control System	Electro Hydraulic	1600 psig	1
5	Generator Coolers	Shell & Tube	-	2
6	Hydrogen Seal Oil System	Closed loop	-	1
7	Generator Exciter	Solid State brushless	-	1

MISCELLANEOUS EQUIPMENT

<u>Equipment #</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Auxiliary Boiler	Shop Fab. Water Tube	400#, 650#F	1
2	Fuel Oil Storage Tank	vertical, cylindrical	300,000 gal	1
3	Fuel Oil Unloading Pump	Gear	150', 800 gpm	1
4	Fuel Oil Supply	Gear	400', 80 gpm	2
5	Service Air Compressors	S.S., Double Acting	100#, 800 CFM	3
6	Inst. Air Dryers	Duplex, Regeneration	400 CFM	1
7	Soot Blowing Air Compressors	3 Stage	500#, 1500 CFM	2
8	Service Water Pumps	S.S., Double Suction	200 ft, 700 gpm	3
9	Closed Cycle Cooling Heat Exch.	Shell & Tube	50% Cap. each	2
10	Closed Cycle Cooling Water Pumps		100', 5700 gpm	2
10a	Closed Cycle Cooling Water Jackey Pump		100', 1700 gpm	1
11	Fire Service Booster Pump	2 stage cent.	250', 700 gpm	1
12	Engin. Driven Fire Pump	Verd. Turbine, gasoline engine	350', 1000 gpm	1
13	Riverwater Makeup Pumps	S.S., Single Suction	100', 11,500 gpm	3
14	Filtered Water Pumps	S.S., Single Suction	200', 220 gpm	2
15	Filtered Water Tank	vertical, cylindrical	15,000 gal	1
16	Condensate Tank	vertical, cylindrical	250,000 gal	2
17	Makeup Demineralizer	Anion, Cation, & Mixed Bed	150 gpm	2 trains

3 of 3

18	Liquid Waste Treatment System	-	10 yrs. 24 hr. storm	1
19	Condensate Demineralizer	mixed bed	1500 gpm	1

APPENDIX C

REFERENCE PLANT

DETAILED COST ESTIMATE

Client: DOE-METC										Report Date: 23-Oct-91		
Project: AFBC-REFERENCE PLANT												
Case: Base Case										Cost Year 1991 , \$x1000		
Plant Size: 400.5 MW _{net}										Estimate Type: Conceptual		
TOTAL PLANT COST - DETAIL												
Acct No.	Item/Description	Equipment Cost	Material Cost	Installation		Sales Tax	Bare Erected Cost \$	Eng'g,CM H.O. & Fee	Contingencies		TOTAL PLANT COST	
				Cost	Indirects				Process	Project	\$	\$/kW
1	COAL & SORBENT HANDLING											
1.1	Coal Receive & Unload	2,823		1,637	115		\$4,574	549		768	\$5,892	14.7
1.2	Coal Stockout & Reclaim	3,700		1,064	74		\$4,838	581		813	\$6,232	15.6
1.3	Coal Conveyors & Yd. Crnab.	3,440		1,053	74		\$4,566	548		767	\$5,882	14.7
1.4	Other Coal Handling	900		244	17		\$1,161	139		195	\$1,495	3.7
1.5	Sorbent Receive & Unload	75		29	2		\$106	13		18	\$136	0.3
1.6	Sorbent Stockout & Reclaim	1,280		421	29		\$1,730	208		291	\$2,228	5.6
1.7	Sorbent Conveyors	650		202	14		\$866	104		146	\$1,116	2.8
1.8	Other Sorbent Handling											
1.9	Coal & Sorbent Hnd. Foundations		4,391	5,017	351		\$9,759	1,171		1,640	\$12,570	31.4
	SUBTOTAL 1.	\$12,868	\$4,391	\$9,666	\$677		\$27,601	\$3,312		\$4,637	\$35,551	88.8
2	COAL & SORBENT PREP. & FEED											
2.1	Coal Crushing & Drying	1,800		445	31		\$2,276	273		382	\$2,932	7.3
2.2	Prepared Coal Storage & Feed	8,520		2,360	165		\$11,046	1,325		1,856	\$14,227	35.5
2.3	Coal Injection System											
2.4	Misc. Coal Prep & Feed											
2.5	Sorbent Prep Equipment	6,560		1,652	116		\$8,328	999		1,399	\$10,726	26.8
2.6	Prepared Sorbent Storage & Feed	460		1,100	77		\$1,637	196		275	\$2,108	5.3
2.7	Sorbent Injection System	2,511		894	63		\$3,468	416		583	\$4,466	11.2
2.8	Booster Air Supply System											
2.9	Coal & Sorbent Feed Foundation											
	SUBTOTAL 2.	\$19,851		\$6,452	\$452		\$26,754	\$3,210		\$4,495	\$34,459	86.0
3	FW, COND. & MISC. SYS.											
3.1	Feedwater System	6,360		1,117	78		\$7,555	907		1,269	\$9,731	24.3
3.2	Water Makeup & Pretreating	2,494		929	65		\$3,488	419		586	\$4,492	11.2
3.3	Other Feedwater Subsystems	2,686		644	45		\$3,375	405		567	\$4,347	10.9
3.4	Service Water Systems	353		521	36		\$910	109		153	\$1,172	2.9
3.5	Other Boiler Plant Systems	1,587		1,911	134		\$3,632	436		610	\$4,678	11.7
3.6	Fuel Oil Supply System	170		260	18		\$449	54		75	\$578	1.4
3.7	Waste Treatment Equipment	1,847		1,115	78		\$3,040	365		511	\$3,916	9.8
3.8	Misc. Power Plant Equipment	1,623		636	45		\$2,303	276		387	\$2,967	7.4
	SUBTOTAL 3.	\$17,119		\$7,134	\$499		\$24,753	\$2,970		\$4,158	\$31,881	79.6

Client: DOE-METC										Report Date: 23-Oct-91		
Project: AFBC-REFERENCE PLANT												
Case: Base Case										Cost Year 1991 , \$x1000		
Plant Size: 400.5 MW,net												
Estimate Type: Conceptual												
TOTAL PLANT COST - DETAIL												
Acct No.	Item/Description	Equipment Cost	Material Cost	Installation		Sales Tax	Bare Erected Cost \$	Eng'g,CM H.O.& Fee	Contingencies		TOTAL PLANT COST	
				Cost	Indirects				Process	Project	\$	\$/kW
4	AFBC BOILER & ACCESSORIES											
4.1	AFBC Boiler	87,950		24,748	1,732		\$114,431	13,732		19,224	\$147,387	368.0
4.2	Open											
4.3	Open											
4.4	Interconnecting Pipe											
4.5	Primary Air System											
4.6	Secondary Air System											
4.8	Major Component Rigging											
4.9	AFBC Foundations											
	SUBTOTAL 4.	\$87,950		\$24,748	\$1,732		\$114,431	\$13,732		\$19,224	\$147,387	368.0
5	FLUE GAS CLEANUP											
5.1	Slagging Cyclone											
5.2	Hot Gas Filters											
5.3	F.A. Baghouse											
5.4	Hot Gas Piping											
5.9	Baghouse Foundations											
	SUBTOTAL 5.	14,650		3,507	245		\$18,402	2,208		3,092	\$23,702	59.2
6	COMBUSTION TURBINE/ACCESSORIES											
6.1	Combustion Turbine Generator											
6.2	Combustion Turbine Accessories											
6.3	Compressed Air Piping											
6.9	Combustion Turbine Foundations											
	SUBTOTAL 6.	\$14,650	636	696	49		\$1,380	166		232	\$1,778	4.4
			\$636	\$4,203	\$294		\$19,783	\$2,374		\$3,323	\$25,480	63.6
7	HRSG, DUCTING & STACK											
7.1	Heat Recovery Steam Generator											
7.2	HRSG Accessories											
7.3	Ductwork											
7.4	Stack											
7.9	HRSG,Duct & Stack Foundations											
	SUBTOTAL 7.	\$1,844	75	\$1,257	\$88		\$3,264	\$392		\$548	\$4,205	10.5
8	STEAM TURBINE GENERATOR											
8.1	Steam TG & Accessories											
8.2	Turbine Plant Auxiliaries											
8.3	Condenser & Auxiliaries											
8.4	Steam Piping											
8.9	TG Foundations											
	SUBTOTAL 8.	\$47,948	313	\$7,948	\$556		\$56,765	\$6,812		\$9,536	\$73,113	182.6

Client: DOE-METC										Report Date: 23-Oct-91		
Project: AFBC-REFERENCE PLANT												
Case: Base Case										Cost Year 1991 , \$x1000		
Plant Size: 400.5 MW _{net}												
Estimate Type: Conceptual										TOTAL PLANT COST - DETAIL		
Acct No.	Item/Description	Equipment Cost	Material Cost	Installation		Sales Tax	Bare Erected Cost \$	Eng'g, CM H.O. & Fee	Contingencies		TOTAL PLANT COST	
				Cost	Indirects				Process	Project	\$	\$/kW
9	COOLING WATER SYSTEM											
9.1	Cooling Towers	6,484		1,516	106		\$8,106	973		1,362	\$10,441	26.1
9.2	Circulating Water Pumps	1,770		55	4		\$1,829	219		307	\$2,355	5.9
9.3	Circ. Water System Auxiliaries	50		10	1		\$61	7		10	\$78	0.2
9.4	Circ. Water Piping		1,124	1,143	80		\$2,347	282		394	\$3,023	7.5
9.5	Make-up Water System	258		407	29		\$694	83		117	\$894	2.2
9.6	Component Cooling Water Sys	168		105	7		\$280	34		47	\$361	0.9
9.9	Circ. Water System Foundations		1,618	2,938	206		\$4,761	571		800	\$6,132	15.3
	SUBTOTAL 9.	\$8,730	\$2,742	\$6,174	\$432		\$18,077	\$2,169		\$3,037	\$23,284	58.1
10	ASH/SPENT SORBENT HANDLING SYS											
10.1	Ash Coolers	3,564		133	9		\$3,706	445		623	\$4,774	11.9
10.2	Cyclone Ash Leltdown	N/A		N/A								
10.3	HGCU Ash Leltdown	N/A		N/A								
10.4	High Temperature Ash Piping	N/A		N/A								
10.5	Other Ash Recovery Equipment	N/A										
10.6	Ash Storage Silos	463		1,624	114		\$2,200	264		370	\$2,834	7.1
10.7	Ash Transport & Feed Equipment	1,919		1,330	93		\$3,342	401		561	\$4,304	10.7
10.8	Misc. Ash Handling Equipment											
10.9	Ash/Spent Sorbent Foundation											
	SUBTOTAL 10.	\$5,946	\$77	\$3,190	\$223		\$9,436	\$1,132		\$1,585	\$12,153	30.3
11	ACCESSORY ELECTRIC PLANT											
11.1	Generator Equipment	229		221	15		\$465	56		78	\$599	1.5
11.2	Station Service Equipment	1,555		193	14		\$1,762	211		296	\$2,269	5.7
11.3	Switchgear & Motor Control	1,736		128	9		\$1,873	225		315	\$2,412	6.0
11.4	Conduit & Cable Tray		1,254	3,320	232		\$4,807	577		807	\$6,191	15.5
11.5	Wire & Cable		1,939	2,466	173		\$4,577	549		769	\$5,895	14.7
11.6	Protective Equipment	209		655	46		\$910	109		153	\$1,173	2.9
11.7	Standby Equipment	330		32	2		\$364	44		61	\$469	1.2
11.8	Main Power Transformers	3,200		159	11		\$3,370	404		566	\$4,341	10.8
11.9	Electrical Foundations		11	30	2		\$43	5		7	\$55	0.1
	SUBTOTAL 11.	\$7,259	\$3,204	\$7,204	\$504		\$18,171	\$2,181		\$3,053	\$23,404	58.4

Client: DOE-METC										Report Date: 23-Oct-91	
Project: AFBC-REFERENCE PLANT											
Case: Base Case										Cost Year 1991, \$x1000	
Plant Size: 400.5 MW.net											
Estimate Type: Conceptual											
TOTAL PLANT COST - DETAIL											
Acct No.	Item/Description	Equipment Cost	Material Cost	Installation Cost	Sales Tax	Bare Erected Cost \$	Eng'g, CM H.C. & Fee	Contingencies Process	Project	\$	\$/kW
12	INSTRUMENTATION & CONTROL										
12.1	AFBC Control Equipment	1,510		650	46	\$2,206	265		371	\$2,841	7.1
12.2	Combustion Turbine Control	N/A		N/A							
12.3	Steam Turbine Control	w/8.1		w/8.1							
12.4	Other Major Component Control										
12.5	Signal Processing Equipment	20		89	6	\$116	14		19	\$149	0.4
12.6	Control Boards, Panels & Racks	3,000		100	7	\$3,106	373		522	\$4,001	10.0
12.7	Computer & Accessories	1,154		2,853	200	\$4,207	505		707	\$5,418	13.5
12.8	Instrument Wiring & Tubing	609		469	33	\$1,110	133		187	\$1,430	3.6
12.9	Other I & C Equipment	\$6,294		\$4,160	\$291	\$10,745	\$1,289		\$1,805	\$13,839	34.6
	SUBTOTAL 12.										
13	IMPROVEMENTS TO SITE										
13.1	Site Preparation			624	44	\$667	80		112	\$860	2.1
13.2	Site Improvements		1,017	1,286	90	\$2,394	287		402	\$3,083	7.7
13.3	Site Facilities	1,823		1,830	128	\$3,781	454		635	\$4,870	12.2
	SUBTOTAL 13.	\$1,823	\$1,017	\$3,740	\$262	\$6,842	\$821		\$1,149	\$8,813	22.0
14	BUILDINGS & STRUCTURES										
14.1	Boiler Building		15,697	13,215	925	\$29,837	3,580		5,013	\$38,431	96.0
14.2	Turbine Building		6,608	6,969	488	\$14,065	1,688		2,363	\$18,116	45.2
14.3	Administration Building		506	652	46	\$1,204	144		202	\$1,550	3.9
14.4	Circulation Water Pumphouse		22	21	1	\$44	5		7	\$57	0.1
14.5	Water Treatment Buildings		211	212	15	\$438	53		74	\$564	1.4
14.6	Machine Shop & Warehouse		271	222	16	\$508	61		85	\$654	1.6
14.7	Control Complex		183	224	16	\$423	51		71	\$545	1.4
14.8	Other Buildings & Structures		112	117	8	\$237	28		40	\$305	0.8
14.9	Waste Treating Building & Str.		215	797	56	\$1,067	128		179	\$1,375	3.4
	SUBTOTAL 14.		\$23,825	\$22,429	\$1,570	\$47,824	\$5,739		\$8,034	\$61,598	153.8
	TOTAL COST	\$232,281	\$36,279	\$108,305	\$7,581	\$384,446	\$46,133		\$64,587	\$495,166	1236.4

**DATE
FILMED**

12 / 6 / 93

END