DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PERFORMANCE OF THE MAGCOOL-SUBCOOLER CRYOGENIC SYSTEM AFTER SSC QUADRUPOLE QUENCHES*

K. C. Wu

RHIC Project
Brookhaven National Laboratory
Upton, New York 11973-5000

INTRODUCTION

The subcooler assembly installed in the MAGCOOL magnet test area at Brookhaven National Laboratory has been used for testing SSC dipoles, quadrupoles and a spool piece since 1989. A detailed description of the system, its steady state capacity and the performance after quenches of a 50 mm SSC dipole were given^{1,2}. Subsequent studies on low current quenches of the SSC dipoles³ and quenches of the RHIC dipoles⁴ were also carried out. In this paper, the performance of the subcooler after quenches of the SSC quadrupole QCC404 is presented. Pressures, temperatures and flow rates in the magnet cooling loop after magnet quenches are given as a function of time. The cooling rates and total energy removed by cooling during quench recovery have been calculated for quench currents between 2000 and 7952 amperes. Because the inductance of the quadrupole is about one tenth that of a SSC dipole, the stored energy released is small and the impact on the system is mild. The cooling loop pressure never exceeds 12 atmospheres and the cryogenic system recovers in less than 15 minutes. As in all past studies, the peak pressure and temperature in the magnet cooling loop are linearly proportional to the energy released during a quench and excellent agreement between the total cooling provided and the magnetic stored energy is found.

SYSTEM DESCRIPTION

The MAGCOOL subcooler assembly is designed to provide supercritical cooling to the superconducting magnet. Figure 1 shows the flow schematic for the subcooler and the cooling loop. A circulating compressor is used for closed loop circulation of single phase helium which delivers cooling from the subcooler helium pot to the magnet. When the magnet quenches, the magnetic stored energy is deposited as heat in the magnet cooling loop. The pressure and temperature in the loop first increase and then return to their original values after the magnet is cooled again to the test temperature prior to a quench. Typical operating conditions prior to a magnet quench are also given in Figure 1 in which temperatures are shown without units and are in Kelvin. The volume of the circulating loop piping is about 200 liters and there is a warm line of 10 liters volume connecting the loop to the warm relief valve. It is believed the 10 liters warm volume reduces the peak pressure by some amount compared to a system without a warm volume, but has little effect on other properties.

*Work performed under contract with the U.S. Department of Energy

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNL

EB

Figure 4. Return temperatures after quenches

Figure 5. Mass flow rates after quenches

The peak temperatures recorded are proportional to the magnetic stored energy as shown in Figure 3. The time at which the peak temperatures were recorded depends primarily on the circulation of helium and was approximately 2 minutes after each quench. The recovery time for temperatures in the circulating loop is less than 10 minutes.

The helium flow through the magnet as a function of time is given in Figure 5. As can be seen, the mass flow rate only varies slightly because the energy released into the helium loop is not large. However a large energy release does cause a larger perturbation in flow rate.

COOLING RATE AND TOTAL COOLING

The apparent cooling rate applied to the magnet is defined as the difference in the enthalpy flux between the helium in the supply and the return lines. The net cooling rate for quench recovery equals the apparent cooling rate minus the background heat load. Because the system which started at a test condition is cooled to the original condition after a quench, the integration of the net cooling rate represents the total amount of cooling provided for quench recovery and should be equal to the stored energy released by the magnet. The apparent cooling rates during quench recovery are given in Figure 6. The total net cooling provided during quench recovery for each of the four quenches is given in Figure 7. The cooling provided increases with time and reaches a plateau when the loop is cooled to conditions existing prior to the quench.

Figure 6. Apparent cooling rates

Figure 7. Total net cooling provided

SUMMARY

Key parameters and the corresponding stored energies for the ten quenches studied including the four quenches given above are summarized in Table 1. As can be seen, the total net cooling provided agrees with the magnetic stored energy very well for quench currents above 4000 amperes. For the 2000 ampere quenches, accuracy of the measurements is not good because the energy released is simply too small.

Table 1. Results from quench of QCC-404 quadrupole*

Quench Current	Peak Pres.	Time to Peak Pres.	Peak Return Temp.	Time to Peak Return Temp.	Max. Cooling Rate	Total Net Cooling Provided	Magnetic Stored Energy $1/2 L I^2$	Ratio of Cooling to $1/2 L I^2$
ampere	atm	sec	K	sec	kw	kj	kj	
2000	5.14	N.A.	4.52	N.A.	0.18	8.4	15.0	0.56
4000	5.74	N.A.	4.91	N.A.	0.42	52.4	60.0	0.87
5000	6.61	52	5.24	110	0.65	92.3	93.8	0.98
7265	9.64	92	6.16	132	1.18	201.3	197.9	1.02
7396	9.92	90	6.27	115	1.26	210.7	205.1	1.03
7715	10.07	90	6.51	131	1.38	222.2	223.2	1.00
7749	10.20	91	6.54	122	1.39	242.1	225.2	1.08
7773	10.18	93	6.53	133	1.39	244.1	226.6	1.08
7953	10.81	92	6.59	133	1.40	239.6	237.2	1.01
7952	10.78	90	6.57	120	1.42	239.4	237.1	1.01

*0.0075 Henries is used for the inductance of the quadrupole.

CONCLUSION

These results from testing a SSC quadrupole and those from earlier tests of SSC and RHIC dipoles provide useful information and a method for analyzing other superconducting magnet systems. The thermal characteristics of the MAGCOOL system after a magnet quench is primarily determined by the magnetic stored energy released into the helium cooling loop. As in all past tests, the peak loop pressure and peak return temperature are found to be linearly proportional to the magnetic stored energy. The agreement between the total net cooling provided and the magnetic stored energy has been confirmed. The energy releases for a quadrupole quench are less than 250 kilo-joules. The peak loop pressure observed is less than 12 atms and no helium was vented from the cooling loop. The system recovers in less than 15 minutes.

ACKNOWLEDGEMENT

The author would like to thank D. Zantopp for developing the data acquisition software, P. Radusewicz for providing information on the quadrupole, A. Prodell for providing helpful comments and S. Agnetti for preparing this paper.

REFERENCES

1. K. C. Wu, D. P. Brown, J. H. Sondericker, Y. Farah, D. Zantopp and A. Nicolletti, Subcooler assembly for SSC single magnet test program, in "Advances in Cryogenic Engineering", 37A:763, Plenum Press, New York (1991)
2. K. C. Wu, Performance of the MAGCOOL-subcooler cryogenic system after 50 mm SSC dipole quenches, in "Supercollider 4", p.483, Plenum Press, New York (1992)
3. K. C. Wu, Peak loop pressure and temperature and comparison of total cooling provided to the energy released after low current quenches of SSC dipoles in MAGCOOL cryogenic system, to be presented in the CEC-ICMC conference, July 12-16, 1993, Albuquerque, N.M.
4. K. C. Wu, Thermal characteristics of the MAGCOOL cryogenic system after quenches of RHIC dipoles, to be presented in the CEC-ICMC conference, July 12-16, 1993, Albuquerque, N.M.

PERFORMANCE OF THE MAGCOOL-SUBCOOLER CRYOGENIC SYSTEM AFTER SSC QUADRUPOLE QUENCHES*

K. C. Wu

RHIC Project
Brookhaven National Laboratory
Upton, New York 11973-5000

INTRODUCTION

The subcooler assembly installed in the MAGCOOL magnet test area at Brookhaven National Laboratory has been used for testing SSC dipoles, quadrupoles and a spool piece since 1989. A detailed description of the system, its steady state capacity and the performance after quenches of a 50 mm SSC dipole were given^{1,2}. Subsequent studies on low current quenches of the SSC dipoles³ and quenches of the RHIC dipoles⁴ were also carried out. In this paper, the performance of the subcooler after quenches of the SSC quadrupole QCC404 is presented. Pressures, temperatures and flow rates in the magnet cooling loop after magnet quenches are given as a function of time. The cooling rates and total energy removed by cooling during quench recovery have been calculated for quench currents between 2000 and 7952 amperes. Because the inductance of the quadrupole is about one tenth that of a SSC dipole, the stored energy released is small and the impact on the system is mild. The cooling loop pressure never exceeds 12 atmospheres and the cryogenic system recovers in less than 15 minutes. As in all past studies, the peak pressure and temperature in the magnet cooling loop are linearly proportional to the energy released during a quench and excellent agreement between the total cooling provided and the magnetic stored energy is found.

SYSTEM DESCRIPTION

The MAGCOOL subcooler assembly is designed to provide supercritical cooling to the superconducting magnet. Figure 1 shows the flow schematic for the subcooler and the cooling loop. A circulating compressor is used for closed loop circulation of single phase helium which delivers cooling from the subcooler helium pot to the magnet. When the magnet quenches, the magnetic stored energy is deposited as heat in the magnet cooling loop. The pressure and temperature in the loop first increase and then return to their original values after the magnet is cooled again to the test temperature prior to a quench. Typical operating conditions prior to a magnet quench are also given in Figure 1 in which temperatures are shown without units and are in Kelvin. The volume of the circulating loop piping is about 200 liters and there is a warm line of 10 liters volume connecting the loop to the warm relief valve. It is believed the 10 liters warm volume reduces the peak pressure by some amount compared to a system without a warm volume, but has little effect on other properties.

*Work supported by the U.S. Department of Energy

Figure 1. Flow schematic and operating conditions prior to a magnet quench

PRESSURE, TEMPERATURE AND FLOW RATE AFTER QUENCH

The following results were obtained from quenches of the SSC QCC404 quadrupole in MAGCOOL Test Stand B. The magnet was maintained at 4.3 K prior to a quench. A total of ten quenches with quench currents between 2000 and 7953 amperes were investigated. The 2000, 4000 and 5000 ampere quenches were initiated by a strip heater located on the magnet coil. The other quenches were natural quenches occurring between 7265 and 7953 amperes. The corresponding magnetic stored energies varied from 15 to 240 kilo-joules. The results for the 4000, 5000, 7396 and 7952 ampere quenches are presented graphically below.

The loop pressures as a function of time after a quench are given in Figure 2. As seen, the loop pressure first increases after a quench due to the heat released from the magnet to the cooling loop. As the system is cooled to the condition prior to the quench, the pressure decreases. The peak loop pressure increases linearly with the amount of energy released as shown in Figure 3. The time at which these peak pressures occur also increases with the energy released. In all cases, the loop pressure returned to the original pressure before the quench in less than 4 minutes.

Temperatures recorded at the return line in the subcooler assembly after quenches are given in Figure 4. The return temperature increases initially as heat is carried to the subcooler. The temperature reaches a peak value before returning to test condition. The return temperature is higher for higher current quenches whereas the supply temperatures is essentially the same for all cases.

Figure 2. Loop pressures after quenches

Figure 3. Peak loop pressure and temperature versus stored energy

Figure 4. Return temperatures after quenches

Figure 5. Mass flow rates after quenches

The peak temperatures recorded are proportional to the magnetic stored energy as shown in Figure 3. The time at which the peak temperatures were recorded depends primarily on the circulation of helium and was approximately 2 minutes after each quench. The recovery time for temperatures in the circulating loop is less than 10 minutes.

The helium flow through the magnet as a function of time is given in Figure 5. As can be seen, the mass flow rate only varies slightly because the energy released into the helium loop is not large. However a large energy release does cause a larger perturbation in flow rate.

COOLING RATE AND TOTAL COOLING

The apparent cooling rate applied to the magnet is defined as the difference in the enthalpy flux between the helium in the supply and the return lines. The net cooling rate for quench recovery equals the apparent cooling rate minus the background heat load. Because the system which started at a test condition is cooled to the original condition after a quench, the integration of the net cooling rate represents the total amount of cooling provided for quench recovery and should be equal to the stored energy released by the magnet. The apparent cooling rates during quench recovery are given in Figure 6. The total net cooling provided during quench recovery for each of the four quenches is given in Figure 7. The cooling provided increases with time and reaches a plateau when the loop is cooled to conditions existing prior to the quench.

Figure 6. Apparent cooling rates

Figure 7. Total net cooling provided

SUMMARY

Key parameters and the corresponding stored energies for the ten quenches studied including the four quenches given above are summarized in Table 1. As can be seen, the total net cooling provided agrees with the magnetic stored energy very well for quench currents above 4000 amperes. For the 2000 ampere quenches, accuracy of the measurements is not good because the energy released is simply too small.

Table 1. Results from quench of QCC-404 quadrupole*

Quench Current	Peak Pres.	Time to Peak Pres.	Peak Return Temp.	Time to Peak Return Temp.	Max. Cooling Rate	Total Net Cooling Provided	Magnetic Stored Energy $1/2 L I^2$	Ratio of Cooling to $1/2 L I^2$
ampere	atm	sec	K	sec	kw	kj	kj	
2000	5.14	N.A.	4.52	N.A.	0.18	8.4	15.0	0.56
4000	5.74	N.A.	4.91	N.A.	0.42	52.4	60.0	0.87
5000	6.61	52	5.24	110	0.65	92.3	93.8	0.98
7265	9.64	92	6.16	132	1.18	201.3	197.9	1.02
7396	9.92	90	6.27	115	1.26	210.7	205.1	1.03
7715	10.07	90	6.51	131	1.38	222.2	223.2	1.00
7749	10.20	91	6.54	122	1.39	242.1	225.2	1.08
7773	10.18	93	6.53	133	1.39	244.1	226.6	1.08
7953	10.81	92	6.59	133	1.40	239.6	237.2	1.01
7952	10.78	90	6.57	120	1.42	239.4	237.1	1.01

*0.0075 Henries is used for the inductance of the quadrupole.

CONCLUSION

These results from testing a SSC quadrupole and those from earlier tests of SSC and RHIC dipoles provide useful information and a method for analyzing other superconducting magnet systems. The thermal characteristics of the MAGCOOL system after a magnet quench is primarily determined by the magnetic stored energy released into the helium cooling loop. As in all past tests, the peak loop pressure and peak return temperature are found to be linearly proportional to the magnetic stored energy. The agreement between the total net cooling provided and the magnetic stored energy has been confirmed. The energy releases for a quadrupole quench are less than 250 kilo-joules. The peak loop pressure observed is less than 12 atms and no helium was vented from the cooling loop. The system recovers in less than 15 minutes.

ACKNOWLEDGEMENT

The author would like to thank D. Zantopp for developing the data acquisition software, P. Radusewicz for providing information on the quadrupole, A. Prodell for providing helpful comments and S. Agnetti for preparing this paper.

REFERENCES

1. K. C. Wu, D. P. Brown, J. H. Sondericker, Y. Farah, D. Zantopp and A. Nicolletti, Subcooler assembly for SSC single magnet test program, in "Advances in Cryogenic Engineering", 37A:763, Plenum Press, New York (1991)
2. K. C. Wu, Performance of the MAGCOOL-subcooler cryogenic system after 50 mm SSC dipole quenches, in "Supercollider 4", p.483, Plenum Press, New York (1992)
3. K. C. Wu, Peak loop pressure and temperature and comparison of total cooling provided to the energy released after low current quenches of SSC dipoles in MAGCOOL cryogenic system, to be presented in the CEC-ICMC conference, July 12-16, 1993, Albuquerque, N.M.
4. K. C. Wu, Thermal characteristics of the MAGCOOL cryogenic system after quenches of RHIC dipoles, to be presented in the CEC-ICMC conference, July 12-16, 1993, Albuquerque, N.M.

END

DATE
FILMED
8/20/93