AIM

Association for Information and Image Management

1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910
301/587-8202

Centimeter

Inches

MANUFACTURED TO AIM STANDARDS
BY APPLIED IMAGE, INC.

1 of 1

RECORD CENTER FILE

HW-69390
Undocumented

SERIES AND COPY NO.

DATE _____

April 26, 1961

HANDED ATOMIC PRODUCTS OPERATION - RAYMOND, WASHINGTON

[X] RESTRICTED AREA
 THIS DOCUMENT CONTAINS RESTRICTED INFORMATION AS
 TRAINED IN THE ATOMIC ENERGY ACT OF 1946.
 ITS TRANSMISSION OR DISCLOSURE OF ITS
 CONTENTS TO ANY MAN OR AN UNAUTHORIZED
 PERSON IS PROHIBITED.

TITLE

PCCF FLOW ANALYSIS - DR REACTOR

OTHER OFFICIAL CLASSIFIED INFORMATION

THIS MATERIAL CONTAINS INFORMATION AFFECTING THE NATIONAL DEFENSE OF THE UNITED STATES WITHIN THE MEANING OF THE ESPIONAGE LAWS, TITLE 18, U. S. C. , SECS. 793 AND 794, THE TRANSMISSION OR REVELATION OF WHICH IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PROHIBITED BY LAW.

AUTHOR

J. F. Calkin

CIRCULATING COPY
RECEIVED 100D AREA

JUN 1 1951

RETURN TO

THIS DOCUMENT MUST BE LEFT UNCLASSIFIED OR WHERE AUTHORIZED BY OR MAY HAVE ACCESS TO IT WHEN NOT IN THE IT MUST BE KEPT IN AN APPROVED LOCKED REPOSITORY WITHIN THE APPROVED GUARD AREA. WHEN IT IS YOUR SESSION AND YOU HAVE OBTAINED A SIGNATURE RECEIPT OF CLASSIFIED FILE IT IS YOUR RESPONSIBILITY TO KEEP IT AND ITS CONTENTS WITHIN THE LIMITS OF THE PROJECT FROM ANY UNAUTHORIZED PERSON ITS TRANSMISSION TO, AND STORAGE AT YOUR PLACE OF RESIDENCE IS PROHIBITED. IT IS NOT TO BE DUPLICATED. ADDITIONAL COPIES ARE REQUIRED TO OBTAIN THEM FROM THE OFFICE ISSUING THEM. ALL PERSONS READING THIS DOCUMENT ARE REQUESTED TO SIGN THE SPACE PROVIDED BELOW.

[illegible]

DECLASSIFIED

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DECLASSIFIED

-1-

HW-69390
Undocumented

DISTRIBUTION

1. JD Agar
2. JM Batch
3. JF Calkin
4. PA Carlson
5. BR Cremer
6. RM Fryar
7. NE Fuller
8. SM Graves
9. CM Heeb
10. LC Lessor
11. WH Radtke
12. CE Reed
13. DL Renberger
14. A. Russell
15. WR Smit
16. FW VanWormer
17. EC Wood
22. Extra
23. 300 Files
24. Record Center

This document classified by

J M Batch
J M Batch

Classification Cancelled and Changed To

DECLASSIFIED

By Authority of CG-PR-2,

RM Itin, 2-28-94.

By Jerri Maly, 4-20-94.

Verified By MT Hanson, 4-20-94

PCCF FLOW ANALYSIS - DR REACTOR

J. F. Calkin

April 26, 1961

INTRODUCTION

In 1957 R. D. Waters of the Thermal Hydraulics Operation recommended an orifice to be used in the PCCF (Poison Column Control Facility) in DR Reactor. (Reference 2 in Bibliography) This orifice was selected with the object of giving at least 20 gpm flow to the tube to permit flush discharging and yet limit it to about 25 gpm to prevent vibration and chattering of the poison column pieces with a front header pressure of about 470 psig. A single primary orifice (0.236" I.D. with taper downstream) mounted in a pre-CG-558 nozzle accomplished this and operated in critical flow to limit the flow to about 25 gpm regardless of the length of poison column charge. Other reactors have since adopted this method of PCCF flow control and use similar fittings.

The following questions have been raised by reactor personnel concerning PCCF tubes: (1) What would be the flow increase through these PCCF tubes at higher front header pressures (up to 600 psig), and (2) What could be the maximum charge length without causing a decrease in flow. (This latter situation would be possible if the greater charge length would increase the back pressure on the orifice enough so that the orifice would not be operating in critical flow.)

DECLASSIFIED

DECLASSIFIED

-2-

HW-69390
Undocumented

SUMMARY

This report contains an analysis of PCCF tube flow and Panellit pressure relations at DR reactor. Supply curves are presented at front header pressures from 480 to 600 psig using cold water and the standard 0.236" orifice with taper down stream and the pigtail valve (plug or ball) open. Demand curves are presented for slug column lengths of 200" to 400" using 1.44" O.D. solid poison pieces (either Al or Pb-Cd) and cold water with a rear header pressure of 50 psig. Figure 1 is a graph of Panellit pressure vs. flow with the above supply and demand curves and clearly shows the effect of front header pressure and charge length on flow.

DISCUSSION

Data for the demand curves were taken from laboratory data gathered in connection with references 3 and 4. Based on data taken with cold water for 37 slugs 6.5" long and 1.44" O.D. and upon the assumption that the pressure drop from the front nozzle barrel to the end of active section is approximately proportional to the length of the charge, pressure drops for the various charge lengths were calculated for various flows from 20 to 28 gpm. It was found from the data that the pressure drop from the Panellit tap to the front nozzle was nil. Pressure drops from the rear nozzle to the rear header were taken from the same data used for reference 1 and 2.

The supply curves were also calculated from data taken for references 1 and 2. Based on the fact that at a front header pressure of 530 psig a critical flow of 24.5 gpm exists and that a critical pressure drop is approximately proportional to the square of the critical flow, critical flows were calculated for various front header pressures. Supply curves were calculated using the same front header pressures and a calibration for the 0.236" I.D. orifice with taper downstream and with the pigtail ball or plug valve in the open or high flow position.

Use of Figure 1

To find the flow at which any particular tube will operate, find the supply curve and vertical critical flow line corresponding to the front header pressure of interest. Compute the length of charge in inches and find the corresponding demand curve. The intersection of the demand curve with any portion (sloping or vertical) of the supply curve determines the operating Panellit pressure and the operating flow. If a vertical portion of the supply curve is intersected by the demand curve then the tube will be operating in critical flow.

If front header pressures other than those plotted are desired it should be noted that the vertical spacing of the supply curves is 20 psi for every 20 psig front header pressure change. In like manner, if higher rear header pressures than 50 psig are used, the demand curves must be moved up a corresponding amount (10 psi for every 10 psig increase of rear

DECLASSIFIED

UNCLASSIFIED

-3-

FW-69390
Undocumented

header pressure). Lower rear header pressures would similarly require lower demand curves.

If orifices other than 0.236" with taper downstream are used, new supply curves must be drawn as well as new critical flow (vertical) lines.

Figure 1 has been drawn from values calculated from a small amount of laboratory data and are consequently extrapolations and interpolations and should be treated as such. They do, however, show the approximate relationship of supply and demand curves and may be used to further the understanding of these peculiar PCCF tubes.

John Calkin
Engineer
Thermal Hydraulics Operation
LANFORD LABORATORIES OPERATION

JFC:leb

DECLASSIFIED

-4-

HW-69390
Undocumented

Figure 1. Supply and Demand Analysis for PCCP Ball Valve Tubes - DR Reactor

Rear Header pressure = 50 psig; cold water; 1.44" OD
solid slugs; 0.236" ID orifice, taper downstream; pigtail
plug valve open.

DECLASSIFIED

HW-69390
Undocumented

REFERENCES

- (1) Letter from K. W. Hess to J. M. Batch, "Poison Column Orificing," May 15, 1957. (Unclassified)
- (2) Letter from E. D. Waters to J. M. Batch, "Cavitating Orifice for Poison Columns," May 20, 1957. (Confidential Undocumented)
- (3) Letter from F. J. VanWormer to J. M. Batch, "PCCF Tests," July 2, 1958. (Unclassified)
- (4) Waters, E. D. Front Ball Valve Nozzle Pressures for a PCCF Tube (BDF), HW-56854. July 22, 1958. (Confidential Undocumented)

**DATE
FILMED**

9/16/94

END