WESTINGHOUSE SAVANNAH RIVER COMPANY
ENGINEERING AND PROJECTS DIVISION
SYSTEMS ENGINEERING
EWR NO. 866422

WSRC-TR--91-473

DE92 015123

KEY WORDS: Response Spectra
SASSI
K-Reactor
Seismic

RETENTION PERIOD: LIFETIME

IMPACT OF NEW K AREA GEOTECHNICAL PARAMETERS ON K REACTOR RESTART RESPONSE SPECTRA (U)

AUGUST 1991

SEISMIC STRUCTURAL ENGINEERING

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Seismic Engineering
Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

SAVANNAH RIVER SITE

PREPARED FOR THE U.S. DEPARTMENT OF ENERGY UNDER CONTRACT NO. DE-88SR18035

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

WESTINGHOUSE SAVANNAH RIVER COMPANY
ENGINEERING AND PROJECTS DIVISION
SYSTEMS ENGINEERING
EWR NO. 866422

WSRC-TR-91-473

IMPACT OF NEW K-AREA GEOTECHNICAL PARAMETERS ON K-REACTOR RESTART RESPONSE SPECTRA (U)

AUGUST 1991

PREPARED

J. A. Amin
Seismic Structural Engineering

PREPARED

R. C. Chen
Seismic Structural Engineering

PREPARED

J. S. Mulliken
Seismic Structural Engineering

APPROVED

M. E. Maryak, Manager
Seismic Structural Engineering

APPROVED

M. W. Barlow, Manager
Seismic Engineering

TABLE OF CONTENTS

ITEM	PAGE
1.0 Introduction	2
2.0 Study Procedure	2
2.1 Review of Existing Reactor Analysis	2
2.2 Model Modification	3
2.3 Live Loads	4
2.4 Proposed Soil Profiles	4
2.5 Strain Dependent Curves	5
2.6 Time History	5
2.7 Seismic Evaluation	5
2.8 Stack Building Impact	6
3.0 Conclusion	7
References	8
Tables	T1 to T4
Figures	F1 to F31

1.0 INTRODUCTION

This report provides a description of a study performed to evaluate the impact of recently obtained soils parameters on the 105-K Reactor using Soil-Structure Interaction (SSI) analysis. New soils data provided for K-Area resulted from an extensive geotechnical investigation and was reported in Reference 1.

This study includes:

- The frequency check of the reactor building based on the fixed base analysis.
- The modification of the computer model to reflect actual building properties and building frequencies.
- The live load impact on seismic analysis.
- The comparison of soil spectrum at elev. -50 ft with 60% of RG1.60 curve.
- Comparison of spectral results to the previous FRED A and SASSI results
- Implications to the stack building analysis.

2.0 STUDY PROCEDURE

2.1 REVIEW OF EXISTING K REACTOR ANALYSIS

The K-Reactor Building seismic analysis was performed by URS/Blume (2) in August, 1989. Using then available soil data, Blume generated floor acceleration response spectra(FRS) for use in qualifying equipment for the Interim Seismic Program. URS/Blume's proprietary computer code FRED A(3) was used to compute the soil-structure-interaction (SSI) response of the building. FRED A performs a frequency domain analysis to compute the SSI response.

A parametric study using the SASSI(4) computer code was also performed by URS/Blume to examine conservatism provided in the FRED A computations. The URS/Blume SASSI model was developed specifically to provide best estimate results and represent the FRED A model as closely as possible. This structural model consists of rigid, massless eight node brick elements to represent the embedded outer walls and the foundation. The base of the structural model represents a doubly symmetric structure embedded in the soil down to elevation -50 ft. The reactor building superstructure is the lumped-mass stick model utilized in the FRED A analysis and was attached to the wall-foundation elements by rigid beams at the -20' elevation which transfer soil motion to the stick. FRS was generated with SASSI for the North-South direction at 5% damping and compared with the FRS generated by FRED A. The structural frequencies and modal participation factors are also generated.

2.2 MODEL MODIFICATION

To incorporate building properties at elevation -50 ft, the Seismic Engineering Group modified the URS/Blume model to add a vertical beam element which extends from elevation -20 ft to -50 ft with verified building properties. The revised stick model representing the reactor building is connected to the below grade structural shell by two horizontal beams running in the direction of input motion, one at elevation -20 ft, another at elevation 0 ft. Both horizontal beams are provided to simulate actual structural diaphragm action below grade. The masses in the modified model are lumped to the respective nodes at appropriate elevations to more accurately represent the structure. The structural frequencies of the modified model approximately match the frequencies shown in the URS/Blume Report.(Table 1)

2.3 LIVE LOADS

To appropriately adjust the mass lumped at elevation -20 feet from the FRED A model, the actual weight of the structure at elevation -20 feet and at elevation -40 feet was calculated. The weight of twelve heat exchangers (250 KIP each) were added to the mass lumped at elevation -20 feet. The resulting weight at elevation -20 feet is 67,116 KIPs and the weight at elevation -50 feet is 105,074 KIPs. For comparative purposes, the participating live load at -20 was calculated to determine the relative magnitude and impact. A live load of 20 pounds per square foot, which makes up a total $(20 \text{ psf} \times 220' \times 200') = 880 \text{ KIPs}$ at elevation -20 feet, will represent 1.3 % of the lumped mass at that level. Based on this comparison, the live load will have a negligible effect on seismic analysis utilizing a lumped mass concentric stick model.

2.4 PROPOSED SOIL PROFILES

The proposed best estimate soil profile is based on the weighted average of GEI soil data from crossholes K-1008 and K-1012. In general, the factor for lower bound shear modulus is 0.5 times the best estimate and the factor for upper bound shear modulus is 2.0 times the best estimate. The lower bound was expanded at three points to cover data that was lying outside of the conservative lower bounding of 0.5 (Fig. 1). The SHAKE (4) computer code was used to generate best estimate, lower bound and upper bound soil spectra at elevation -50 feet, which is the basemat level of the structure. The enveloped free field soil response at -50 feet (Fig. 2) envelopes the 60 % Regulatory Guide 1.60 target spectrum at all frequencies in accordance with the Standard Review Plan. An acceleration profile with depth for free field analysis was also generated for each soil condition. (Fig. 3) A curve of the effective strains with depth for free field analysis is also generated. (Fig. 7)

The SHAKE input has the same layering as that of SASSI. The iterated values of shear moduli from SHAKE were converted to shear wave velocities and P wave velocities and then entered into SASSI input files. (Tables 3&4)

2.5 STRAIN DEPENDENT CURVES

The proposed site specific shear modulus and damping vs shear strain curves (Fig. 4) by GEI, were utilized for this analysis. The original URS/Blume analysis utilized the standard Seed and Idriss curves for sandy soils.

2.6 TIME HISTORY

The same time history which was used in URS/Blume SASSI analysis was used for both north-south and east-west directions.(Ref. 2)

2.7 SEISMIC EVALUATION

The Seismic Engineering Group evaluated three soil conditions (lower bound, best estimate and upper bound) for both east-west and north-south directions to determine the effects on seismic analysis due to the proposed soil profiles. Two soil models are generated for the six SASSI runs. The first model which was used for the best estimate and upper bound conditions utilizes the same layering as that by URS/Blume. The second model, for the lower bound condition, has a modified layering arrangement to allow passage of higher frequencies. The top 50 ft soil for the lower bound model (Fig. 5) is divided into five 10 ft layers compared to two 10 ft layers and two 15 ft layers as used in the URS/Blume model and this study's best estimate and upper bound model. This change is to better capture the frequency of the analysis for the lower bound soil condition.

Floor response spectra (FRS) for each soil condition and each node with lumped mass were generated and compared to the enveloped FREDA spectrum. (Fig 8 to Fig 31) The FRS at every elevation below 91 feet for all six conditions are lower than the respective FREDA spectra from SEP-11. Some excursions of broadened spectra occurred at higher elevations in the north-south direction only. For elevations at or above 91 feet, every point of the enveloped raw SASSI spectra is lower than FREDA spectra, but one point of the broadened spectra from SASSI is outside of FREDA spectra into the lower frequency range. These minor excursions are also shown in the URS/Blume SASSI parametric study. There is no impact to any restart analysis due this small excursion.

2.8 STACK BUILDING IMPACT

To assess the impact of the new soils profile on the stack building, a comparison of ZPA's for the old best estimate and new best estimate soil condition using the reactor stick model was made (see Table 2). It can be seen that little difference occurs in the lower elevations but the ZPA's increase in the upper elevations. An attempt was made to evaluate this change in response, but the review proved inconclusive, due to the many variables involved in the comparison. Those variables included damping differences, strain independent functions, building to building interactions, structural frequencies, etc.

In attempting correlation, it became evident that the final results would be inconclusive, but not necessarily cause concerns for overall structural integrity. Based on this, a reevaluation would not be urgently needed considering the newly strengthened structure. This reevaluation is to be structured as a SEP. An SEP approach is appropriate based on the structures importance to shutdown in a post seismic event (ie. contains no safe shutdown equipment). The only significant piece of equipment contained in this structure is the confinement filter, an accident mitigation system, not required for restart. These filters are presently being redesigned to a very conservative spectra. (See Figures 6-1, 6-2 & 6-3) Based on the above, this new analysis will be aggressively pursued as a post restart activity.

3.0 CONCLUSION

The conclusions of Seismic Engineering Group's study based on new proposed soil profile are:

- 1) The FRS at every elevation below 91 feet for all six conditions are lower than the respective FREDA spectra used for restart analysis. Therefore, there is no impact on any K- reactor restart analysis.
- 2) The zero period accelerations (ZPA) at all elevations are lower than the FREDA ZPA's, thus the structural evaluation based on the FREDA is still valid and provides a conservative loading.
- 3) The impact of new soils on the stack building is inconclusive, but based on recent upgrades and importance to safe shut down, it will be reevaluated in a post restart SEP program.

Based on the reviews, the complexity of the reactor and stack building is apparent and continued assessment is warranted for the long term seismic improvement program.

REFERENCE

- 1) K-Reactor Area Geotechnical investigation for seismic issues, Savannah River Site (U), March 1991, WSRC Seismic Structural Engineering.
- 2) Floor Acceleration Response Spectra for Updated DBE & Reg. Guide 1.60 Seismic Input: Building 105-K, Savannah River Plant, Aug 1989, URS/John A. Blume & Associates, engineering.
- 3) FRED A: FREquency Domain Aalysis, URS/John A. Blume & Associates, Engineering.
- 4) SASSI: A System for Aalysis of Soil Structure Interaction, July 1988 Bechtel Power Corporation.

WESTINGHOUSE SAVANNAH RIVER COMPANY
E&PD SYSTEMS ENGINEERING
SEISMIC STRUCTURAL ENGINEERING
K-REACTOR SOIL PROFILE STUDY

WSRC-TR-91-473
REVISION 0
AUGUST, 1991

TABLES

NORTH-SOUTH DIRECTION

MODE NO.	FREQUENCY (HZ)	
	FIXED @ -20	SASSI
1	6.93	7.05
2	12.47	12.84
3	19.71	20.98
4	24.57	25.55
5	31.76	33.97

EAST-WEST DIRECTION

MODE NO.	FREQUENCY (HZ)	
	FIXED @ -20	SASSI
1	9.53	9.89
2	13.85	14.79
3	22.16	23.07
4	28.04	31.95
5	36.75	38.43

**TABLE 1: STRUCTURAL FREQUENCIES OF THE FREDA MODEL
AND THE MODIFIED SASSI MODEL**

**NORTH-SOUTH DIRECTION
BEST ESTIMATE SOILS**

ELEV. (FEET)	ACCELERATION (G)	
	GEI	BLUME
148.67	0.61	0.48
130	0.51	0.44
125	0.48	0.41
120	0.45	0.38
110	0.40	0.34
91.25	0.29	0.25
66	0.22	0.20
48	0.21	0.19
34	0.19	0.18
15	0.18	0.17
0	0.17	0.17
-20	0.17	0.16

**TABLE 2: SEISMIC PEAK ACCELERATIONS AT DIFFERENT ELEVATIONS
FROM SASSI ANALYSES WITH BLUME SOIL PROFILE
AND NEW PROPOSED SOIL PROFILE FROM GEI DATA**

ELEV	dens	Vs(be)	Vs(ub)	Vs(lb)	Gbe	Gub	Glb
-10	0.120	1183	1673.01	836.51	5215.49	10430.97	2607.74
-20	0.120	1227	1735.24	867.62	5610.67	11221.33	2895.33
-35	0.120	1227	1735.24	867.62	5610.67	11221.33	2805.33
-50	0.118	1155	1633.42	816.71	4888.66	9777.33	2444.33
-60	0.120	1106	1564.12	782.06	4558.64	9117.29	2279.32
-73	0.125	1106	1564.12	782.06	4748.59	9497.17	2374.29
-85	0.125	1070	1513.21	756.60	4444.49	8888.98	2222.24
-90	0.120	1070	1513.21	756.60	4266.71	8533.42	2133.35
-100	0.125	1070	1513.21	756.60	4444.49	8888.98	2222.24
-105	0.125	1053	1489.17	744.58	4304.38	8608.77	2152.19
-115	0.115	1053	1489.17	744.58	3960.03	7920.06	1980.02
-125	0.115	1053	1489.17	744.58	3960.03	7920.06	1980.02
-135	0.115	1410	1994.04	997.02	7100.36	14200.71	3550.18
-145	0.115	990	1400.07	700.04	3500.36	7000.71	1750.18
-160	0.125	1300	1838.48	919.24	6560.56	13121.12	3280.28
-175	0.125	1300	1838.48	919.24	6560.56	13121.12	3280.28
-200	0.125	1300	1838.48	919.24	6560.56	13121.12	3280.28

TABLE 3: SOIL PROFILES BASED ON CROSSHOLES K-1008 & K-1012

ELEV	dens	Vs(be)	Vs(sub)	Vs(lb)	Gbe	Gub	Glb
-10	0.120	1168.45	1663.61	815.43	5088.00	10314.00	2478.00
-20	0.120	1182.94	1705.82	801.49	5215.00	10844.00	2394.00
-35	0.120	1141.27	1680.86	758.49	4854.00	10529.00	2144.00
-50	0.118	1022.32	1533.26	653.92	3830.00	8615.00	1567.00
-60	0.120	945.99	1438.16	595.37	3335.00	7708.00	1321.00
-73	0.125	927.43	1414.94	596.23	3339.00	7772.00	1380.00
-85	0.125	874.83	1340.91	582.68	2971.00	6980.00	1318.00
-90	0.120	865.56	1325.33	588.12	2792.00	6546.00	1289.00
-100	0.125	873.80	1324.29	586.87	2964.00	6808.00	1337.00
-105	0.125	859.53	1291.89	564.04	2868.00	6479.00	1235.00
-115	0.115	853.23	1269.30	539.37	2600.00	5754.00	1039.00
-125	0.115	867.23	1266.43	519.81	2686.00	5728.00	965.00
-135	0.115	1260.89	1814.14	800.40	5678.00	11754.00	2288.00
-145	0.115	788.42	1167.37	431.18	2220.00	4867.00	664.00
-160	0.125	1140.45	1667.96	676.96	5049.00	10800.00	1779.00
-175	0.125	1121.08	1678.12	661.95	4879.00	10932.00	1701.00
-200	0.125	1097.28	1680.11	637.57	4674.00	10958.00	1578.00

TABLE 4: ITERATED SOIL PROFILES FROM "SHAKE"

WESTINGHOUSE SAVANNAH RIVER COMPANY
E&PD SYSTEMS ENGINEERING
SEISMIC STRUCTURAL ENGINEERING
K-REACTOR SOIL PROFILE STUDY

WSRC-TR-91-473
REVISION 0
AUGUST, 1991

FIGURES

FIGURE 1: CROSSHOLES K1008 & K1012
AND ANALYTICAL SOIL PROFILES

FIGURE 2: ENVELOPED -50' FREE FIELD RESPONSE
COMPARED TO REG. GUIDE 1.60 SPECTRA

FIGURE-3 VARIATION OF MAX. ACCELERATION WITH
DEPTH FOR FREE FIELD ANALYSIS

FIGURE-4 SHEAR MODULUS REDUCTION AND DAMPING CURVES

FIGURE 6-1 105-K STACK BLDG ELEV. 55 FT N-S SMOOTHED FRS AND THE SPECTRUM FOR FILTER COMPARTMENT ANALYSIS

FIGURE 6-2 105-K STACK BLDG ELEV. 55 FT E-W SMOOTHED FRs AND THE SPECTRUM FOR FILTER COMPARTMENT ANALYSIS

FIGURE 6-3 105-K STACK BLDG ELEV. 55 FT VERTICAL SMOOTHED FRS AND THE SPECTRUM FOR FILTER COMPARTMENT ANALYSIS

FIGURE 7 VARIATION OF EFFECTIVE STRAIN
WITH DEPTH FOR FREE FIELD
FREE FIELD ANALYSIS

FIGURE 8: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION -20 FT.

FIGURE 9: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION 0 FT.

FIGURE 10: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +15 FT.

FIGURE 11: COMPARISON OF FREDA FRF, AND SASSI FRF WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +34 FT.

FIGURE 12: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +48 FT.

FIGURE 13: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +66 FT.

FIGURE 14: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +91.25 FT.

FIGURE 15: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +110 FT.

FIGURE 16: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +120 FT.

FIGURE 17: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +125 FT.

FIGURE 18: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +130 FT.

FIGURE 19: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +148.67 FT.

FIGURE 20: COMPARISON OF FREDa FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION -20 FT.

FIGURE 21: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION 0 FT.

FIGURE 22: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +15 FT.

FIGURE 23: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +34 FT.

FIGURE 24: COMPARISON OF FREDAS FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +48 FT.

FIGURE 25: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +66 FT.

FIGURE 26: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +91.25 FT.

FIGURE 27: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +110 FT.

FIGURE 28: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +120 FT.

FIGURE 29: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +125 FT.

FIGURE 30: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +130 FT.

FIGURE 31: COMPARISON OF FREDA FRS, AND SASSI FRS WITH NEW SOIL PROPERTIES FOR THE K-REACTOR, ELEVATION +148.67 FT.

**DATE
FILMED
8/12/92**