THE MEASURED ENERGY IMPACT OF AIR LEAKAGE ON FRAME WALL SYSTEMS

DOE/CE/21038--T1

Final Report
U.S. DOE Grant #DE-FG01-89-CE21038
June, 1991

DE92 017374

David E. Claridge, Ph.D., P.E.
Principal Investigator

Souvik Bhattacharyya
Research Assistant

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Foreword

This report presents the work performed under U.S. DOE Grant #DE-FG01-89-CE21038. A portion of the support for this work was provided by a grant from the Texas A&M Center for Energy and Mineral Resources and the Texas Higher Education Coordinating Board. This report was initially presented as the Ph.D. thesis of Souvik Bhattacharyya.

ABSTRACT

The Measured Energy Impact of Air Leakage on Frame Wall Systems. (May 1991)

Souvik Bhattacharyya, B.M.E., Jadavpur University;

M.S., University of Cincinnati

Chair of Advisory Committee: Dr. David E. Claridge

Infiltration is customarily assumed to increase the heating and cooling load of a building by an amount equal to the mass flow rate of the infiltration times the enthalpy difference between the inside and outside air – with the latent portion of the enthalpy difference sometimes neglected. An experimental and analytical investigation has been conducted on the actual energy impact of air leakage on frame wall systems. Calorimetric measurements conducted on a small test cell and on a well characterized stud-cavity wall specimen with measured amounts of air leakage introduced under a variety of controlled conditions and configurations show convincingly that infiltration can lead to a much smaller change in the energy load than is customarily calculated. The data also suggest that the phenomenon occurs in full-sized houses as well.

Infiltration Heat Exchange Effectiveness (IHEE), ϵ , is introduced as a measure of the effectiveness of a building in 'recovering' heat otherwise lost (or gained) because of infiltration. Measurements show that ϵ increases as:

- a) flow rate decreases;
- b) flow path length increases;
- c) hole/crack size decreases.

ϵ also generally increases as the pressurization exponent, n , increases; so fan

pressurization results may be useful in predicting ϵ for buildings. An analytical model based on fundamental heat and mass transfer principles has been developed and all the predicted values of ϵ as a function of air flow rates and effective path length for the different stud-cavity wall specimen test configurations were remarkably consistent with the experimental results.

Significant experimental results include:

- a) ϵ values as high as 0.9 and as low as 0.05 for the test cell configurations tested indicate an energy impact of the air leakage as low as 10% of customary values;
- b) ϵ values in the 0.16–0.7 range in the stud-cavity (vs. theoretical maximum of 0.5); and
- c) ϵ values of 0.16 to 0.34 for air exiting the stud-cavity directly across from the entry.

Pages v, vi, and vii are intentionally omitted.

TABLE OF CONTENTS

CHAPTER		Page
I	INTRODUCTION	1
II	LITERATURE REVIEW	9
	DYNAMIC INSULATION	9
	ENERGY CONSUMPTION DUE TO INFILTRATION	14
III	EXPERIMENTAL FACILITY	24
	INFILTRATION TEST CELL	24
	CALIBRATED HOT BOX	27
	DATA ACQUISITION SYSTEM	38
IV	THEORETICAL MODEL DEVELOPMENT	42
	THEORETICAL BACKGROUND	42
	APPLICATIONS	48
	MODEL DEVELOPMENT	50
V	EXPERIMENTAL METHODOLOGY	56
	EXPERIMENTAL PROCEDURE FOR THE TEST CELL	56
	EXPERIMENTAL PROCEDURE FOR THE STUD-CAVITY	59

TABLE OF CONTENTS (Continued)

CHAPTER		Page
VI	RESULTS: TEST CELL	64
	INFILTRATION HEAT	
	EXCHANGE EFFECTIVENESS	65
	EFFECT OF INFILTRATION	
	PATH ON IHEE	81
	HOLE-SIZE EXPERIMENT	
	ON TEST CELL	88
VII	RESULTS: STUD-CAVITY WALL SECTION	97
	TEMPERATURE DISTRIBUTION	
	INSIDE THE STUD-CAVITY	105
	COMPARISON OF EXPERIMENTAL	
	RESULTS WITH MODEL	115
VIII	CONCLUSIONS AND RECOMMENDATIONS	126
	CONCLUSIONS	126
	BENEFITS	129
	RECOMMENDATIONS	129
	REFERENCES	131
	APPENDIX A	136
	APPENDIX B	139
	APPENDIX C	156
	VITA	164

LIST OF TABLES

Table	Page
1. Description of Data Acquisition Sensor Channels	40
2. Pressurization Test Results (Air Entry Through Hole P)	65
3. Linearized Dependence of ϵ on α for Different Flow Configurations	67

LIST OF FIGURES

Figure	Page
1. Typical Wind Pressure Profile on a Building	4
2. Different Types of Dynamic Insulation	12
3. A Hypothetical Example to Demonstrate IHEE (Classical Loss)	18
4. Infiltration Example with Modified Calculation Procedure	19
5. Test Cell Schematic Showing Thermocouple Locations	26
6. Test Cell Set-up Showing Different Hole Openings	28
7. Schematic of the Stud-Cavity Wall Section	30
8. Layout of the Thermocouples Inside the Stud-Cavity Wall Section	31
9. Sectional Plan View of the Calibrated Hot Box	33
10. Sectional Elevation of the Calibrated Hot Box	34
11. Radiant Cooling Panel Schematic	36
12. Schematic Line Diagram of the Chilled Water System	39
13. Heat and Mass Transfer Across a Wall	44
14. Schematic of a House with Diffuse Infiltration	47
15. Wall Section Model with Intrusive Air Flow	51
16. Various Test Configurations for the Stud-Cavity	63
17. IHEE vs. a for Diffuse (B4) Inlet and Diffuse (A) Outlet	68
18. IHEE vs. a for Diffuse (B0) Inlet and No Outlet	69
19. IHEE vs. a for Diffuse (B1) Inlet and No Outlet	70
20. IHEE vs. a for Diffuse (B2) Inlet and No Outlet	71
21. IHEE vs. a for Diffuse (B3) Inlet and No Outlet	72
22. IHEE vs. a for Diffuse (B4) Inlet and No Outlet	73
23. IHEE vs. a for Diffuse (B4) Inlet and Concentrated (E) Outlet	74

LIST OF FIGURES (Continued)

Figure	Page
24. IHEE vs. a for Diffuse (B4) Inlet and Mixed (E & A) Outlet	75
25. IHEE vs. a for Concentrated (P) Inlet and No Outlet	76
26. IHEE vs. a for Concentrated (P) Inlet and Diffuse (A & B4) Outlet	77
27. IHEE vs. a for Concentrated (P) Inlet and Concentrated (E) Outlet	78
28. IHEE vs. a for Concentrated (P) Inlet and Mixed (A, B4 & E) Outlet	79
29. IHEE vs. n at Small Flow Rate for Diffuse Inlet	82
30. IHEE vs. n at Small Flow Rate for Concentrated Inlet	83
31. IHEE vs. n at Moderate Flow Rate for Diffuse Inlet	84
32. IHEE vs. n at Moderate Flow Rate for Concentrated Inlet	85
33. m vs. n for Diffuse Inlet	86
34. m vs. n for Concentrated Inlet	87
35. IHEE vs. Leakage Path Length for Diffuse Configuration	89
36. IHEE vs. a for 11/64 inch Diffuse Inlet and Diffuse Outlet	91
37. IHEE vs. a for 1/4 inch Diffuse Inlet and Diffuse Outlet	92
38. IHEE vs. a for 3/8 inch Diffuse Inlet and Diffuse Outlet	93
39. IHEE vs. a for 1/2 inch Diffuse Inlet and Diffuse Outlet	94
40. IHEE vs. Inlet Size for Diffuse Air Entry	95
41. Measured IHEE Values for Inlet at 1 and Outlet at 2	99
42. Measured IHEE Values for Inlet at 1 and Outlet at 3	100
43. Measured IHEE Values for Inlet at 1 and Outlet at 4	101
44. Measured IHEE Values for Inlet at 1 and Outlet at 2, 3 and 4	103
45. Measured IHEE Values for Inlet at 1 and Outlet at 5	104

LIST OF FIGURES (Continued)

Figure	Page
46. Uncertainty Bars for Measured IHEE Values	106
47. Temperature Difference Plot for Configuration A at 11 SLPM	109
48. Temperature Difference Plot for Configuration A at 13 SLPM	110
49. Temperature Difference Plot for Configuration B at 12 SLPM	111
50. Temperature Difference Plot for Configuration B at 14 SLPM	112
51. Temperature Difference Plot for Configuration C at 11 SLPM	113
52. Temperature Difference Plot for Configuration C at 13 SLPM	114
53. Temperature Difference Plot for Configuration D at 15 SLPM	116
54. Temperature Difference Plot for Configuration D at 17.5 SLPM	117
55. Temperature Difference Plot for Configuration E at 10.5 SLPM	118
56. Temperature Difference Plot for Configuration E at 13 SLPM	119
57. IHEE for Configuration A: Comparison Between Model and Experiment	121
58. IHEE for Configuration B: Comparison Between Model and Experiment	122
59. IHEE for Configuration C: Comparison Between Model and Experiment	123
60. IHEE for Configuration D: Comparison Between Model and Experiment	124
61. IHEE for Configuration E: Comparison Between Model and Experiment	125

NOMENCLATURE

a	non-dimensional flow parameter
A	surface area, ft^2
d	wall thickness, ft
C_p	specific heat, $Btu/lb - F$
H	wall specimen height, ft
k	pressurization test flow constant
L	path length, ft
$\dot{m}$	mass flow rate, $lb/hr - ft^2$
n	pressurization test flow exponent
Nu	Nusselt number
p	pressure difference, Pa
Δp	pressure difference, Pa
Q	power consumption, Btu/hr
q	volume flow rate, ft^3/s
S	surface area, ft^2
T	temperature, F
ΔT	temperature difference, F
U	thermal transmittance, $Btu/hr - ft^2 - F$
X	diffuse fraction of infiltration
ϵ	infiltration heat exchange effectiveness
λ	thermal conductivity, $Btu/hr - ft - F$
ρ	air density, lb/ft^3

SUBSCRIPTS

0	zero infiltration rate
a	ambient or room
c	cold space
f	fluid
h	hot space
i	indoor
inf	infiltration
o	outdoor
t	total
w	wall

CHAPTER I

INTRODUCTION

The rate of air infiltration into buildings affects both energy consumption and indoor air quality. When space conditioning is necessary, the energy required to maintain comfortable conditions increases with the rate of air infiltration. Infiltration is one of the major contributors to heating and cooling costs of buildings - especially houses. Therefore the relationship between energy use and air infiltration is of considerable concern in energy conservation.

Infiltration air flows are caused by pressure differences across openings in the building envelope. These driving pressures are caused by the wind, thermal buoyancy (stack effect) from temperature differences between indoor and outdoor air, and the operation of appliances such as combustion devices and mechanical ventilation systems. The pressure difference at any given location depends on the magnitude of these driving mechanisms in addition to the characteristics of the openings (cracks) in the building envelope i.e., their locations and the relationship between pressure difference and airflow for each opening. Pressure difference (Δp) across the building envelope is based on the mass conservation principle, i.e. the mass flow of air into the building equals the mass flow out. The wind striking a building causes a distribution of static pressures (p_w) on the building's exterior envelope which depends on the wind direction and the location on the building exterior. This pressure distribution is independent of the pressure inside the building ($p_{i,r}$). The indoor-outdoor temperature difference also imposes a gradient in the pressure difference. This pressure difference Δp ,

Journal model is *ASME Journal of Heat Transfer*.

is a function of height and temperature difference. The total pressure difference, Δp is expressed as:

$$\Delta p = p_o + p_w - p_{i,r} + \Delta p_s \quad (1.1)$$

where

$p_{i,r}$ = interior static pressure at some reference height

p_o = static pressure at the reference height in the disturbed flow

p_w = wind pressure at the location

Δp_s = pressure difference due to stack effect

The relationship between the airflow through an opening in the building envelope and the pressure difference across it is called the leakage function of the opening. The form of the leakage function depends on the geometry of the opening. The fundamental equation for the airflow rate through an opening is :

$$q = C_D A \frac{(2\Delta p)^{1/2}}{\rho} \quad (1.2)$$

where

q = airflow rate

C_D = discharge coefficient for the opening

A = cross-sectional area of the opening

ρ = air density

The discharge coefficient C_D is a dimensionless number and depends on the

opening geometry and the Reynolds number of the flow.

The openings in a building envelope are not uniform in geometry. They usually have many bends and varying cross-sectional area; the flow never becomes fully developed, thereby preventing the applicability of the simple relations between Q and Δp . The following expression is often used in such situations to describe the aggregate leakage characteristics of a building:

$$q = C (\Delta p)^n \quad (1.3)$$

where

C = flow coefficient

n = flow exponent

Equation (1.3) only approximates the relationship between q and Δp . In fact, the values of C and n depend on the range of Δp over which equation (1.3) is applied. The cracks with larger flow resistance, i.e., greater depths or narrower widths, tend to have an exponent n closer to 1 than that for gaps with less resistance. For openings in the shell of a building, the value of n depends on the opening geometry, as well as on the entrance and exit effects.

Figure 1 shows a typical wind pressure profile on a building. The positive pressure side will experience infiltration whereas exfiltration will occur on the leeward side or the negative pressure side.

Knowledge of infiltration and models for predicting the amount of infiltration were very limited until the late 1970s. Earlier air leakage models used what

Fig. 1. Typical Wind Pressure Profile on a Building

is conventionally known as the *crack method*. The air leakage temperature depends on the following parameters: temperature of the incoming air, flow rate, heat transfer in the crack, and crack form. The crack form primarily depends on the type of building component and workmanship. Crack deformation depends on the change of temperature, moisture content, and time. The crack air flow is mostly a mixed flow regime consisting of laminar, turbulent and transition flows. The proportion of each regime depends on the physical form of the crack and the pressure difference. The power law form (equation 1.3) is widely used for its simplicity. However, as Etheridge [1] points out, equations of this type lack generality because they are not dimensionally homogeneous, that is they do not obey *Reynolds law of similitude*. It is suggested that instead of equation 1.3, the following equation might be used:

$$\Delta p = A q + B q^2 \quad (1.4)$$

From the appearance, it seems this equation represents both turbulent and laminar flow. The coefficients remain independent of the rate of flow.

One of the earliest studies which quantified air leakage in a large number of houses was the work of Caffey [2]. Based on the measurements on 50 houses in the Dallas area, he concluded that up to 40% of the heating and cooling cost was due to air infiltration. The contribution of infiltration to heating and cooling requirements varies from house-to-house, but in one comprehensive study of infiltration, Persily [3] ascribed an average of one-third of these requirements to infiltration. Thus, infiltration constitutes a significant part of the total space conditioning load.

Extensive work has been done on the prediction and measurement of infil-

tration for building systems and comprehensive reviews of various methods and models are available [4–6]. But a very scant amount of research has been devoted to the actual energy consumption due to air infiltration. Recently a twelve-month workshop titled 'COMIS' (Conjunction of Multizone Infiltration Specialists) was concluded at the Lawrence Berkeley Laboratory, where a multi-national team of infiltration experts developed a reliable, versatile multizone infiltration model on a modular base. An extensive list of areas were identified for further investigation, but unfortunately the energy consumption aspect of air infiltration was again ignored. Moreover, the understanding of processes, factors and relationships have been largely qualitative. An improved quantitative understanding will enable the utilities, the consumer and the agencies to make sound decisions that are attractive from both an indoor air quality and an energy consumption point of view. Substantially more precise information than is now available is needed to characterize the physical processes involved. With this background, an experimental and analytical investigation was initiated to develop an understanding of the relationship between energy consumption and air leakage in frame walls.

It has been universally assumed that the amount of energy required to heat (or cool) infiltrating air is the same as that required to heat (or cool) outdoor air to the indoor conditions; this is the product of specific enthalpy difference between outdoor and indoor conditions and the mass flow rate of the infiltrating air. Measurements conducted for this dissertation [7] have convincingly shown that infiltration can lead to a much smaller change in the energy load on a test cell than is customarily calculated. The data obtained also suggest that the phenomenon occurs in full-sized houses and that infiltration in a typical house contributes 28 to 79% as much as is now calculated.

This investigation was initiated to gain a better understanding of the heat exchange which occurs in building components when coupled heat and mass transfer is present, as is the case when air leaks through the stud-cavity in a building wall structure. Design models for building heat transfer calculations universally assume no interaction between this heat and mass transfer. Failure to account for this interaction results in over-estimation of heat transfer by significant fractions of the heat loss or gain normally attributed to infiltration in houses. The objective of this investigation is to determine the actual energy transfer occurring while air infiltrates/exfiltrates through porous insulation in wall structures. A procedure is hypothesized which would use data from a normal pressurization test to estimate the actual energy impact due to infiltration in houses. A simple theoretical model is also developed to predict the actual energy impact of air infiltration.

This dissertation includes a review of the available and relevant literature, design and description of the experimental facility, an analysis of the theory behind this work and also the development of an analytical model, discussion of the experimental results and the concluding remarks. Chapter II summarizes the literature reviewed for this study. The review was undertaken to ascertain the current state of knowledge in the area of infiltration and energy consumption and to justify the need for additional research. Chapter III provides the design and construction details of the experimental test facility – the infiltration test cell and the calibrated environmental chamber; these were built exclusively for this investigation and the construction of the apparatus including the elaborate instrumentation is considered to be a part of this dissertation. The theoretical background and analytical modeling of the phenomenon and the prediction procedure of the *Infiltration Heat Exchange Effectiveness* is carried out in Chapter IV.

The experimental methodology developed for measuring the energy consumption due to air infiltration in the test cell as well as in the calibrated environmental chamber is discussed in Chapter V. Chapter VI reviews the experimental results for the *test cell* and Chapter VII describes the test results for the *calibrated hot box*. Conclusions and recommendations for future research are presented in Chapter VIII.

CHAPTER II

LITERATURE REVIEW

The International Energy Agency (IEA) Executive Committee for building and community systems in the late 1970s highlighted areas in building science where the level of knowledge was unsatisfactory and there was unanimous agreement that infiltration was the area about which least was known. Historically, with that perspective, the Air Infiltration Group was formed and consequently the Air Infiltration and Ventilation Center, England was started with participation by thirteen countries from Europe and North America. Many studies and investigations of air infiltration have been carried out during the last decade and presently there is a large volume of information available on the general subject of air infiltration. Most of this information is related to the measurement techniques and mathematical models for prediction of infiltration. The available literature on the energy impact of infiltration is quite limited and has been focused on two major areas:

- (i) dynamic insulation and (ii) energy consumption due to infiltration.

DYNAMIC INSULATION

Before any studies were carried out on the actual energy impact of infiltration, dynamic insulation systems were in existence. This type of system is referred to as *dynamic* as compared to *static*, corresponding to a classic configuration with no air flow. Since the same thermal phenomenon is involved in both cases, a review of the available information on dynamic insulation is

useful. Research on dynamic insulation goes back to 1978, when the first prototype experimental building [8] was completed in France. This was followed by a second prototype – with improved design and more extensive instrumentation – built in 1981 and commissioned late in 1982. Several definitions of dynamic insulation can be found in the literature; simply stated, it is a means of reducing building heat loss significantly without the use of massive thermal insulation. It is achieved by recycling the heat conducted through the fabric or reducing the temperature gradient across the wall section by means of a suitable heat transport fluid – usually air. Most of the structures that have been built and tested are in Sweden, France, Finland and Canada, and significant improvements over *classic* insulation methods have been reported. The physical phenomenon which occurs when an airflow circulates in the wall of a building can be described as heat exchange which takes place between the material of the wall and the air. The conductive flow through the wall is modified, and the airflow leaves the wall at a generally higher temperature (in a winter configuration when it is cold outside and warm inside).

A formal classification of generic dynamic insulation system has been reported in the literature [9] and the three types which can be associated with building applications are enumerated below.

Parietodynamic Insulation

In this case, ventilation air needed for the building circulates along the wall; this air can be either fresh or used air. In the first case, fresh air from the outside is preheated before it enters inside (Figure 2a). In the second case, used air warms up the wall, and consequently, conduction heat losses are

decreased (Figure 2b). This circulation requires the creation of one or two air gaps (Figure 2c). It is applicable to double or triple glazed windows [10].

Permeodynamic Insulation

Ventilation air needed for the building circulates through the walls; more precisely the air flows through a permeable porous medium, generally mineral fiber (Figures 2d and 2e), which acts as a heat exchanger. As in parietodynamic, the circulation air can be either used or fresh air; the last case (Figure 2d), where air flows in a direction opposite to the conduction heat flow, is sometimes referred to as *counterflow* or *contraflux insulation*.

In both cases, the air flow changes the local temperature within the porous medium. In counterflow, temperature will decrease compared to a situation with no air flow. The slope of the temperature profile at the cold side is lower and consequently heat losses are reduced. Similarly, the slope at the hot side is higher but a certain amount of prewarmed air is brought inside.

Thermodynamic Insulation

Parietodynamic and permeodynamic systems are involved only if ventilation air is needed. This is generally the situation, and in addition the ventilation requirements correspond to an air velocity compatible with good working conditions of the system.

However the present trend to reduce the ventilation flow rates has led to a third kind of dynamic insulation, named *thermodynamic*. It is in principle similar

Fig. 2. Different Types of Dynamic Insulation

to permeodynamic (counterflow configuration) but the air circulates in a closed circuit independent of the ventilation system. A heat exchanger is required to recover what is gained by the air as it flows through the porous medium. In practice, for appreciable gains, this heat exchanger is the evaporator of a heat pump (Figure 2f).

Arquis and Langlais [9] reported a theoretical model and an efficiency parameter for evaluation of dynamic insulation systems as compared to 'conventional' insulation. Limitations of such systems, where ventilation air circulated through a permeable porous medium which acts as a heat exchanger, and their most feasible applications were also discussed. It was concluded that the conventional insulation techniques were still competitive for houses, but dynamic insulation systems offered greater possibilities for industrial buildings.

In a study to demonstrate the concept and operation of a building ventilated by dynamic insulation in cold weather and strong winds, Timusk [11] reported that there would be energy savings for such an operation. Discussions were presented on related problems, e.g., the effect of dynamic insulation on indoor air quality, whether the slow infiltration of air into the building increases the moisture levels in walls.

Bailly [12] presented a comprehensive and informative review of dynamic insulation in general, where such systems were compared to the operation of an air-to-air heat exchanger. Transient models and experiments were used to evaluate the performance of dynamic insulation systems during the heating season and energy savings of the order of 7 to 14% were reported.

Dubois [13] reported some data on energy efficient building walls which

incorporated dynamic insulation. This formed part of a retrofitting project which produced significant energy savings. The beneficial effect of dynamic insulation increased with increase in specific airflow rate and a nominal 10% reduction in energy use was achieved when fresh air flowed through the wall and into the apartment.

None of the authors made an attempt either to derive a general expression to calculate the actual amount of heat transferred by the fluid flowing through the porous insulation or to investigate the heat transfer experimentally.

ENERGY CONSUMPTION DUE TO INFILTRATION

All computer models used for calculating energy consumption of buildings assume that infiltration increases the heating/cooling load on a building by an amount equal to the mass flow rate of the infiltration times the enthalpy difference between the inside and outside air - with the latent portion of the enthalpy difference sometimes neglected. The energy consumption due to infiltration is usually calculated using the simplified equation:

$$Q_{inf} = \dot{m}C_p(T_i - T_o) \quad (2.1)$$

where:

Q_{inf} = energy consumption due to infiltration (Btu/hr)

$\dot{m}$ = infiltration rate (lbm/hr)

C_p = specific heat of air ($Btu/lbm - F$)

T_i = indoor temperature (F)

T_o = outdoor temperature (F)

This practice is followed in simple models such as the Modified Degree-Day Method and the Variable-Base Degree-Day Method [14] as well as the most complex hourly simulation programs used for research and difficult design problems, including DOE-2.1 [15] and SERI-RES [16].

Observations have shown that attic temperatures are often higher than predicted by resistive models of attic insulation. This was first reported by Beyea et al. [17] followed by Harrje et al. [18], who conducted careful experiments on a group of townhouses in Twin Rivers, New Jersey. Claridge et al. [19] found that attic temperatures in nine of a group of 25 houses examined in the Denver area had less than half the temperature drop expected across attic insulation. These higher attic temperatures are due to air flow into the attic which bypasses the insulation. The overall loss coefficient calculated for 20 of these houses was 27 to 54 percent higher than values regressed from gas consumption data [20].

Consideration of the combined problem of conduction through insulation and air flow into the attic shows that total heat loss through an attic under these conditions is less than the conductive loss plus the normal exfiltration loss. The attic serves as a heat exchanger and the exfiltrating air reduces the "conductive" loss by increasing the attic temperature. Anderlind [21,22] has shown that this phenomenon is more general and that energy loss due to infiltration can have a maximum value given by the inside/outside enthalpy difference for the infiltrating/exfiltrating air. He suggests the use of a multiplier

R ($0 \leq R \leq 1$) in combination with the coefficient, $(UA)_{inf}$, customarily used. The energy lost by infiltration is then given by:

$$Q_{inf} = R\dot{m}C_p(T_i - T_o) \quad (2.2)$$

When air leakage enters a wall at one point and travels several feet through the wall before entering the house, it is termed "diffuse" leakage; that which directly enters the building such as through cracks around a door is termed "concentrated". Air infiltrating into a building affects the temperature distribution inside the walls of the building, especially when the air leakage is diffuse.

A new non-dimensional factor *Infiltration Heat Exchange Effectiveness*, IHEE, (ϵ) is introduced here. IHEE is the degree of effectiveness of the heat exchange process occurring while the infiltrating/exfiltrating air diffuses through the wall system. IHEE is directly related to the reduction factor, as defined by Anderlind [21], and is given by:

$$\epsilon = (1 - R) \quad (2.3)$$

The total heat lost through the walls due to transmission is reduced by diffuse air leakage. This reduction is properly described if the air leakage heat losses are multiplied by a factor, $(1 - \epsilon)$ ($0 \leq \epsilon \leq 1$) and the transmission losses are calculated in a normal way (i.e. assuming a linear temperature distribution across the walls). Accordingly, the energy lost by infiltration is given by:

$$Q_{inf} = (1 - \epsilon)\dot{m}C_p(T_i - T_o) \quad (2.4)$$

The value of the factor ϵ depends primarily on the relative amounts of diffuse and concentrated air leakage which enter and leave the building envelope.

To explain the concept of the IHEE, a simplified and hypothetical example of a two-dimensional house with specified insulation values is illustrated here (Figure 3). The building has an infiltration rate of 55.6 cfm and the ambient temperature is 40 F whereas the indoor temperature is maintained at 70 F. In the conventional estimates using a simple resistive model, the attic and crawl space will be at 46 F and 55 F respectively. The energy loss due to infiltration is 1800 Btu/hr and the total energy loss due to conduction and infiltration is 4500 Btu/hr, using customary calculation procedures. But if it is assumed that the cold air first enters the crawl space which acts as a heat exchanger and subsequently performing energy balances (Figure 4), the crawl space temperature decreases to 51.5 F; similarly, the modified attic temperature is 50.7 F. With these modified temperatures, the total energy loss for the house is now reduced to 3922 Btu/hr. Hence the effective infiltration loss is:

$$Q_{inf'} = [1800 - (4500 - 3922)] = 1222 \text{ Btu/hr}$$

where $Q_{inf'} = (1 - \epsilon)\dot{m}C_p\Delta T$. Thus in the current example ϵ has a value of 0.32.

In design heating load calculations, the infiltrating air is assumed to enter the room at the outside temperature. Kohonen [23-26] has reported that the infiltrating air warms up due to the heat transfer between infiltrating air and the wall structure along the air leakage path. Defining a Nusselt Number (Nu) as the ratio of the heat transfer on the control surface (a wall section) with and without

CLASSICAL HEAT LOSS

Fig. 3. A Hypothetical Example to Demonstrate IHEE (Classical Loss)

INFILTRATION EXAMPLE

Fig. 4. Infiltration Example with Modified Calculation Procedure

convection or leakage flows, it was shown that for typical leakage routes, Nu is about 0.6 – 0.8; which means that the combined heating load of infiltration air and transmission is commonly overestimated in the design heat loss calculations. Both simulation and experiments were carried out to investigate the thermal effects of air flow on the thermal performance of wall structures. An equation to take into account the interaction of air flows and conductive heat transfer in structures was suggested (assuming the exterior envelope of the building as the control surface boundary), and is given below in a schematic form :

$$\dot{Q} = (-\sum_i \dot{m}_i T_o + \sum_e \dot{m}_e T_e + (\sum_i \dot{m}_i - \sum_e \dot{m}_e) T_r) C_p + \sum_k Nu_k \bar{K}_k A_k (T_r - T_o) \quad (2.5)$$

where:

Nu_k = Nusselt number which takes into account the thermal effect of leakage flows as well as internal convection flows of structures

$\dot{Q}$ = heat transfer rate across the building envelope

T = temperature

$\bar{K}_k$ = overall average thermal transmittance of the structure

$\dot{m}$ = air flow rate

and subscripts :

i = infiltration

e = exfiltration

o = outdoor

r = indoor

k = conduction

It can be observed that several factors present in equation (2.5) are hard to determine, and accordingly, the heating load estimation becomes a complicated and empirical procedure. But if it is possible to predict the Nusselt number for a particular structure, the value of the transmission heat flow without infiltration should be multiplied by Nu in order to have the correct (valid with infiltration) transmission heat flow, i.e., in order not to overestimate the heat load of transmission and infiltration.

Theoretical and experimental analyses of heat transfer rates for permeable insulation systems which sustain infiltrative-exfiltrative air intrusion effects have been reported by Berlad et al. [27,28,29] who made an attempt to estimate the effective 'R' (thermal resistance) value for such systems. It was concluded that the intrusive airflow can serve to degrade the insulating value of various permeable insulator systems; but here the analyses included part of the convective heat transfer in the conductive fraction and thus failed to note that the combined loss due to convection and conduction is less than the customarily calculated value.

De Gids [30] studied the effects of building tightness, wind velocity, temperature, wind direction, surroundings and degree of exposure on infiltration loss and concluded that the relationship between airtightness and the heat loss due to infiltration was not linear. Investigations of the energy consumption due to infiltration have been reported [31,32,33], but they fail to bring out information as to how the actual energy consumption can be estimated or why the current estimates are not accurate for certain configurations. Michell et al. [31] conducted studies on houses in Melbourne, Australia (single story timber framed houses with an external wall of single brick, tiled roof and lined internally with

plasterboard) and quantified savings that occurred when the buildings were tightened to specified conditions. Heldt et al. [32] in a similar study conducted in the Federal Republic of Germany estimated energy-saving potential of houses through air-tightening and pre-heating of ventilation air applying waste-heat recovery. Nantka [33] carried out investigations on energy consumption in the Polish building sector. The work, carried out from 1980 to 1985, aimed at developing methods for measuring air flows and their influence on heat consumption in typical Polish dwellings. The basic criteria for the correct design of dwellings were formulated and ventilation heat loss reduction was estimated to be as high as 45% to 70%. Generally these studies, indicate that about one-third of the total energy consumption is due to air infiltration.

Persily [34] tested a residential air-to-air heat exchanger for effectiveness of heat recovery. Some of the data obtained during experiments to account for the heat loss due to air infiltration indicated that the actual infiltrative loss was less than that estimated by the conventional procedure of using the enthalpy difference between the indoor and outdoor air.

To demonstrate retrofit effects and to develop mathematical models of the physical processes, Nagda et al. [35] carried out a highly controlled experimental and analytical investigation on the relationship among air exchange, energy consumption and key indoor pollutants in residential buildings. Reduction in air infiltration rate and energy use in the retrofitted buildings was quantified ; but no effort was devoted to the investigation of the energy impact of infiltration, and their energy modeling employed the customary procedure (equation 2.1).

Although a number of researchers have recognized the importance of air infiltration and its energy impact in building systems, mostly general discussions

and theoretical modeling of the heat transfer phenomenon in porous vertical cavities exist in the available literature [36–40]; a practical application oriented modeling approach for the energy consumption due to air infiltration in buildings has not been reported. Since accurate measurements of the actual energy impact of air leakage has not been undertaken, this study was initiated as an attempt to fill in that void from the experimental point of view. But this dissertation still does not offer a complete modeling work for this phenomenon. Furthermore, this work embodies measurements taken for building components under laboratory conditions only; outdoor test house data and real building data will not be reported here.

CHAPTER III

EXPERIMENTAL FACILITY

A series of experiments were devised to characterize the dependence of *Infiltration Heat Exchange Effectiveness* on the four key parameters: 1) leakage type; 2) flow rate; 3) leakage path length; and 4) pressurization exponent. The experimental investigations were carried out in two phases. Initially a small test cell was designed, built and used for preliminary testing and confirmation of the hypothesis. Then a more sophisticated apparatus was used for testing a single stud-cavity. A modified calibrated hot-box with the associated instrumentation was designed and constructed for the stud-cavity tests. Both test facilities were assembled and operated in room 405 (T) of the Engineering Physics Building. The design and construction details of each facility are described below:

INFILTRATION TEST CELL

A set of experiments was designed to measure the energy impact of controlled amounts of infiltration air in a small test cell. The test cell was constructed using standard frame construction for the six wall, ceiling and floor surfaces. This construction was:

- 3/8 inch plywood sheathing
- 2x4 (1.5 in x 3.5 in) studs
- R-11 fiberglass batt insulation between the studs
- 3/8 inch plywood sheathing

The external measurements of the test cell are 56.5 inches wide by 48 inches high by 96 inches long. Each surface was constructed separately, and then, all

six surfaces were bolted together and caulked; this form of assembly permits replacement or rebuilding of individual surfaces as needed. One of the 56.5 inch by 48 inch end-walls contained a removable 24 inch square window glazed with 3/8 inch plexiglass. This aperture also served as the door to the test cell between experiments. All joints between the walls and all visible cracks in the wood were tightly caulked to minimize uncontrolled air leakage. The test cell was supported by six large casters to provide portability.

Type T (copper-constantan) thermocouples were used to measure the test cell temperature (including the air inlet and exit temperatures) at nine points as shown in Figure 5. The interior locations were located close to the center point of each wall surface. Another sensor was used to measure the temperature outside the test cell. All temperatures were recorded by a programmable datalogger (Omega OM205).

The pressure difference between the interior and exterior of the test cell was measured using a pressure gage (Retrotec RDF-700 blower door instrumentation). A regulated DC power supply (Adtech Power, Brute III; 5-50 V and 2-25 A, 1200 Watts) and wire-wound resistors (six resistors of 5 Ohms each, equivalent resistance 3.33 Ohms) were used for heating the test cell; an AC fan was employed to reduce temperature stratification. The power input for the heater and the fan was determined by measuring the voltage, current and power factor using an AC/DC multimeter. A pressurization test was performed whenever the test cell had been opened to ensure that cell tightness was maintained.

The various holes provided in the test cell for air inlet and outlet are illustrated in Figure 6. Air was introduced through a 1/2 inch hole (hole P) for all the pressurization tests. This hole and a *diffuse* hole (hole B on the exterior)

Fig. 5. Test Cell Schematic Showing Thermocouple Locations

were used as the air inlets in the heating tests to calculate ϵ . The 1.5 inch hole 'E' and another *diffuse* hole (hole A) were used as air outlets. The vertical position of holes B0 and B1 were 26 and 16 inches respectively from the floor of the cell; holes B2, B3 and B4 were close to the floor. The horizontal position of hole B0 was close to the back wall and holes B1, B2, B3 and B4 were 3, 14, 46 and 74 inches respectively from the back wall. The air flow rate was measured by a rotameter (Dwyer RMC series) before it entered the test cell.

CALIBRATED HOT BOX

The calibrated hot box method provides for the laboratory measurement of heat transfer through a specimen under controlled temperatures established in a metering chamber on one side and in a climatic chamber on the other side. It is primarily intended for measurements under steady-state conditions and at temperatures typical of normal building applications. The apparatus is generally operated in a conditioned laboratory space free from localized hot and cold sources; thus, in principle, the laboratory space acts as a guard. Accuracy of this procedure is obtained through careful analysis of the metering chamber wall heat transfer mechanism. This is achieved through the use of a calibration standard section, having known thermal characteristics; hence the name calibrated hot box. The apparatus usually consists of two large, five-sided, boxes with highly insulated sides plus an equally well-insulated frame which supports a test wall clamped between the open sides of the two boxes. One of the boxes is equipped with conditioning and control equipment suitable for maintaining a range of indoor temperature conditions and the other box is provided with similar equipment suitable for maintaining a range of outdoor

Fig. 6. Test Cell Set-up Showing Different Hole Openings

conditions. Instrumentation is provided to measure the heat input on the indoor side.

The standard calibrated hot box test [41] does not provide for mass transfer of air through the specimen during measurements of heat transfer. The present work modified the standard method to include air flow through the specimen. The design of such an apparatus requires that the range of test conditions be compatible with those naturally occurring.

Test Specimen

A single stud-cavity wall section (Figure 7) of external dimension 17.625 inches by 4.5 inches by 8 feet was constructed to serve as the test specimen. The stud-cavity was made up of 1/2 inch plywood facing and 2x4 studs. The 3.5 inch thick cavity was filled with four pieces of lightweight blanket type insulation (Microlite Insulation, Manville, 1 lbm/cft density) made of fine flame attenuated glass fibers bonded with a thermosetting resin. The thermal resistance (R) of the insulation arrangement was $15.385 \text{ hr ft}^2 \text{ F/Btu}$ according to the manufacturer's specifications. Five layers of thermocouples were mounted between the insulation blankets with each layer consisting of a grid of fifteen thermocouples. The layout of these 75 thermocouples is illustrated in Figure 8. The plywood and the studs were coated with polyurethane clear paint to seal off the pores and thereby minimize undesirable airflow through the test specimen. Highly dried furniture grade studs and cabinet grade plywood were used to build the standard stud-cavity.

All thermocouples were constructed using arc welded wire and small bead diameters. Finished thermocouples were spot checked with a precision Hg

Fig. 7. Schematic of the Stud-Cavity Wall Section

Fig. 8. Layout of the Thermocouples Inside the Stud-Cavity Wall Section

thermometer to see that they were all within the standard error limits of $\pm 0.75^{\circ}$ F. Type T thermocouples made of 30 gage wire (Omega) were used, the smaller wire size offering greater accuracy and compactness. Thus the exit hole from the stud-cavity and the hot box for the thermocouple bunch was kept to a minimum thereby maintaining the stringent tightness criterion needed for the experiment. The pressure difference between the wall specimen and ambient was monitored by a differential pressure transducer (Setra Systems, 239 series, -0.5 inch WC to +0.5 inch WC) connected to the datalogging system.

The design of the enclosure (Figure 9) around the stud-cavity incorporated 20 inch thick extruded polystyrene foam insulation, (Therma Foam, R-76) for the vertical surfaces and in order to restrict the overall height of the structure, 7 inch thick poly-isocyanate board insulation (Thermacore, R-50) was used for the horizontal surfaces. All insulation was covered internally with 1/2 inch thick plywood and enclosed externally in a 3/4 inch plywood casing. The external size of the box was 69.5 by 60.5 by 112.5 inches. Customarily, the hot box, the cold box and the specimen are all built and supported separately on casters and the three pieces are brought together during tests. This design philosophy presented a problem for the current set-up. Since this was an infiltration test facility, stringent airtightness requirements were adopted; hence a composite design with swing-out door, for access to the stud-cavity and the hot and cold space on either side of it, was incorporated. This kept the air leakage rate to a minimum. The elevation of the calibrated hot box is illustrated in Figure 10. Better quality lumber was used to reduce deformation, warpage etc. Metal reinforcements were avoided to reduce heat transmission. The entire enclosure along with the door was mounted on metal casters (with provision for level adjustment) for maneuverability.

Fig. 9. Sectional Plan View of the Calibrated Hot Box

Fig. 10. Sectional Elevation of the Calibrated Hot Box

Heating System

A flexible rollout resistance heating element (Aztec Flexel, 84 Ohms and 175 Watts), 16 inches wide by 8 feet long, was affixed to a 1/8 inch thick aluminum plate to serve as the radiant heating panel. The heating element consists of fiberglass cloth impregnated with a conducting carbon graphite dispersion. Copper buss bars were stitched along each edge and a plastic film was laminated to each face. This assembly was backed by styrofoam insulation. A microprocessor controlled precision DC power supply (Lambda model LLS6120, 0-120 V and 0-1.4 A) provided constant power to the heating panel assembly. This power supply was capable of operating as a constant current or constant voltage power source with front panel display of the voltage and current supplied.

Cooling System

The radiant cooling panel (Airtex Corporation) (Figure 11) was made of extruded aluminum; 5-inch wide individual extrusions were cut to 8 feet in length, painted white and assembled to span the width of the stud-cavity. One-half inch diameter copper tubing was then pressed into the oval saddle of the extrusions. This mechanical process conforms the copper tubing (carrying the chilled water) to the configuration of the saddle, maximizing the contact area and securing the tube so that separation from the panel cannot occur during normal operation.

An elaborately designed chilled water system with a sophisticated proportional control loop was used for the radiant cooling panel. A 55 gallon container stored a 50% glycol solution which in turn was cooled by a cooling unit through

Fig. 11. Radiant Cooling Panel Schematic

a heat exchanger; the cooling unit was built from components for this system only. A three way mixing valve-motor assembly in conjunction with a very accurate temperature controller formed the control loop for the cooling panel. The mixing valve assembly was formed from four components:

1. Double inlet and single outlet 3-way mixing valve (Honeywell V5013);
2. Modulating spring-return motor for controlling the valve (Honeywell M945D);
3. Valve linkage (Honeywell Q618A) used to connect the modutrol motor to the 3-way valve assembly;
4. Transformer for the motor.

This assembly provides a proportional control system for the chilled water supply to the radiant cooling panel. An RTD measured the temperature in the cold space and formed the control input to a microprocessor based temperature controller (Omega CN 6071A) which in turn sent an output signal to the modutrol motor for the necessary proportional opening/closing of the bypass line of the 3-way valve. This output signal (4–20 mA) is a function of the temperature difference between the set point for the space being controlled and the space temperature being measured by the RTD. The temperature controller was programmed from the front panel and displayed the process temperature being controlled. A magnetic drive centrifugal pump circulated the chilled water from the reservoir to the cooling panel. The 55 gallon glycol solution container was surrounded by a cold air-space and then finally enclosed by a two-inch thick poly-isocyanate board envelope. The air space was kept to a temperature very close to that of the chilled water by an auxiliary cooling unit and hence the

heat gain by the chilled water from the surroundings was kept to a minimum. A schematic line diagram of this system is depicted in Figure 12.

Air Flow Control System

The air supply to the stud-cavity wall specimen was metered and controlled by a mass flow controller (Sierra Instruments Series 840 Side-Trak) which employed a large diameter thermal mass flow sensor and a proportional control valve. Enthalpy transfer across the thermal sensor was the control parameter which attenuates the mass flow of the fluid flowing through the controller. A built-in electromagnetic servo-control valve modulates the flow, set previously by the user, within $\pm 1\%$ accuracy. The air coming in to the stud-cavity was brought close to the temperature of the cold space temperature by allowing sufficient (about 20 feet) flow length in the space inside the calibrated hot box (CHB). Temperatures of the air at the inlet and exit to the wall specimen were also measured.

DATA ACQUISITION SYSTEM

Sensor signals from the points listed in Table 1 were collected and converted to engineering units by an Acurex (model Netpac) distributed data acquisition and control system, which conditioned milli-volt, volt and milli-amp signals generated at various process locations. During each scan of the data, information collected and processed by the datalogger was transferred to an IBM/AT compatible personal computer where it was programmed to be stored on a hard disk on the proper directory and in a pre-configured file. The scanning rate was adjustable and user-specified and could be varied from as small as

Fig. 12. Schematic Line Diagram of the Chilled Water System

TABLE 1. Description of Data Acquisition Sensor Channels

Channel	Sensor Type	Location
01-15	Thermocouple	Stud-cavity Series 1
16-30	Thermocouple	Stud-cavity Series 2
31-45	Thermocouple	Stud-cavity Series 3
46-60	Thermocouple	Stud-cavity Series 4
61-75	Thermocouple	Stud-cavity Series 5
76-83	Thermocouple Grid	Cold-space Temperature
84-91	Thermocouple Grid	Hot-space Temperature
92	Pressure Transducer	Probe in Hot/Cold Space
93	Thermocouple	Air Exit from CHB
94	Thermocouple	Air Inlet to CHB
95	Thermocouple	Glycol Solution in Drum
96	Thermocouple	Ambient Temperature
97	DC Volts	Hot Side Fan Power
98	DC Amps	Hot Side Fan Power
99	DC-Watts	Hot Side Fan Power

a continuous scan (each scan spanning 7.5 seconds) to several hours between scans. For this study and for all the steady-state experiments the scanning period for the 100 channel datalogger was 30 minutes. A data acquisition program (Netcom) was employed to acquire and store the data and also to form the interface between the datalogger and the computer. Real time on-screen display with tabular and graphical trends of selected variables facilitated better control and visual monitoring of the process during tests. After the completion of a test (normal duration of about 12–20 hours) all the data stored in the hard disk were analyzed and reduced; subsequent graphical and statistical analyses were carried out as described in Chapter VII.

CHAPTER IV

THEORETICAL MODEL DEVELOPMENT

Existing literature, as reported in Chapter II, shows that only a few researchers have modeled the actual energy consumption due to air infiltration. One of them, Kohonen [26], adopted a modeling approach which focused on the modification of the conductive heat transfer term and hence is quite different from the approach used in this dissertation. Anderlind [21] used a modeling scheme which modifies the infiltration loss term and attempted to correct for the problem. But the model uses parameters which are hard, if not impossible, to measure in practical situations. Thus a simplified model which helps predict the energy impact of air infiltration using measurable parameters would provide a useful extension to the previous work.

This Chapter briefly provides a theoretical background of the phenomenon where a generalization of the existing theory is presented; details of the analytical modeling and the prediction procedure of the *Infiltration Heat Exchange Effectiveness* is also reported here.

THEORETICAL BACKGROUND

To generalize Anderlind's [21] approach, a permeable insulating material section (Figure 13) is considered having a cold boundary temperature T_1 at $x = 0$ and a hot boundary temperature T_2 at $x = d$. This permeable slab or wall sustains a steady infiltrative (cold) flow from the cold boundary to the hot boundary at a mass flow rate of $\dot{m}$ per unit surface area. The conductive part

of the energy flow is:

$$Q_h = -\lambda \frac{dT}{dx} \quad (4.1)$$

The energy flow due to mass transport (air flow) is:

$$Q_c = \dot{m}C_p(T - T_r) \quad (4.2)$$

where:

C_p = specific heat of air

λ = thermal conductivity of the insulation material

T = temperature of the wall section at x

T_r = arbitrary reference temperature for the fluid

Performing energy balance, energy stored = convected energy + conducted energy. Hence, $Q_t = Q_c - Q_h$

Since Q_t is constant as a function of x and $\frac{dT_r}{dx} = 0$, differentiating with respect to x results in:

$$\dot{m}C_p \frac{dT}{dx} - \lambda \frac{d^2T}{dx^2} = 0$$

or,

$$\frac{d^2T}{dx^2} - \frac{\dot{m}C_p}{\lambda} \frac{dT}{dx} = 0 \quad (4.3)$$

Let us define a non-dimensional parameter, a , which is comprised of the same variables as the Peclet Number except that the conductivity used here is

Fig. 13. Heat and Mass Transfer Across a Wall

that of the solid which is the insulation material:

$$a = \frac{\dot{m}C_p}{(\lambda/d)} \quad (4.4)$$

Hence,

$$\frac{d^2T}{dx^2} - \frac{a}{d} \frac{dT}{dx} = 0$$

The solution of this differential equation is given by:

$$T = Ae^{ax/d} + B$$

Ignoring the surface thermal resistance, the simplified boundary conditions are:

$$T = T_1 \text{ at } x = 0$$

$$T = T_2 \text{ at } x = d$$

This simplification overestimates the energy losses to a relatively small extent [21]. Solving for A and B, finally the temperature at any position, x, is given by:

$$T = T_2 + \frac{T_2 - T_1}{e^a - 1} (e^{ax/d} - e^a) \quad (4.5)$$

The temperature gradient is given by:

$$\frac{dT}{dx} = \frac{T_2 - T_1}{e^a - 1} (a/d)(e^{ax/d}) \quad (4.6)$$

or,

$$Q_t = \dot{m}C_p \left[T_2 + \frac{T_2 - T_1}{e^a - 1} (e^{ax/d} - e^a) \right] - \lambda \frac{T_2 - T_1}{e^a - 1} \left(\frac{a}{d} \right) (e^{ax/d})$$

hence, at $x = d$, the heat flux is given by:

$$Q_t = \frac{\lambda a (T_1 e^a - T_2)}{d(e^a - 1)} \quad (4.7)$$

If it is assumed that air is penetrating through a wall (A) of surface area (S/2) and is escaping through another wall (B) of the same surface area as illustrated in Figure 14. If X_A is the diffuse fraction of the air infiltrating through wall A, then $(1 - X_A)$ is the concentrated fraction flowing through. Similarly for wall B, it is assumed that X_B and $(1 - X_B)$ are the diffuse and concentrated fractions of the air exfiltrating through wall B. Let U_W be the heat loss coefficient for each of the walls. Thus the total heat loss from the building is :

$$Q_{tot} = \frac{S}{2} (Q_{tB} - Q_{tA})$$

where

$$Q_{tA} = X_A U_W a \frac{(T_2 - T_1 e^{X_A a})}{e^{X_A a} - 1} - (1 - X_A) a U_W T_1$$

$$Q_{tB} = X_B U_W a \frac{(T_1 - T_2 e^{X_B a})}{e^{X_B a} - 1} - (1 - X_B) a U_W T_2$$

The net heat loss due to air leakage is:

Fig. 14. Schematic of a House with Diffuse Infiltration

$$Q_{infil} = Q_{tot} - SU_W(T_1 - T_2)$$

Substituting for Q_{tA} and Q_{tB} and simplifying it can be shown that:

$$Q_{infil} = (S/2)(\dot{m}C_p)(T_1 - T_2)\left[\frac{X_A}{e^{X_A a} - 1} + \frac{X_B}{e^{X_B a} - 1} + 1 - \frac{2}{a}\right] \quad (4.8)$$

where $(S/2)\dot{m}$ is the mass flow rate of air through each wall. Comparing this with the IHEE equation:

$$Q_{infil} = (1 - \epsilon)\dot{m}C_p\Delta T$$

Hence IHEE can be expressed as:

$$\epsilon = \left[\frac{2}{a} - \frac{X_A}{e^{X_A a} - 1} - \frac{X_B}{e^{X_B a} - 1}\right] \quad (4.9)$$

APPLICATIONS

1. For equal infiltrating and exfiltrating fractions $X_A = X_B = X$:

$$\epsilon = \frac{2}{a} - \frac{2X}{e^{Xa} - 1}$$

The limiting cases of this expression are discussed below:

1A. For totally concentrated leakage, i.e. $X = 0$, expansion of the denominator of the second term of case 1 in the form of a power series can be used

to show that $\epsilon \rightarrow 0$ when $X \rightarrow 0$.

1B. For totally diffuse leakage, i.e. $X \rightarrow 1$:

$$\epsilon = \left[\frac{2}{a} - \frac{2X}{e^{Xa} - 1} \right] = \left(\frac{2}{a} - \frac{2}{(e^a - 1)} \right)$$

or,

$$\epsilon = \frac{2(e^a - 1 - a)}{a(e^a - 1)} \quad (4.10)$$

which is the same as equation (15) in reference [21].

1C. For extremely small flow rates, i.e. $a \rightarrow 0$ and totally diffuse leakage, i.e. $X \rightarrow 1$:

$$\epsilon = \left[\frac{2}{a} - \frac{2}{e^a - 1} \right]$$

the ratio becomes 0/0 and thus applying L'Hospital's rule it can be shown that $\epsilon \rightarrow 1$ for $a \rightarrow 0$ and for $X \rightarrow 1$.

2. For very large flow rates, i.e. $a \rightarrow \infty$, it is obvious from equation (4.10) that $\epsilon \rightarrow 0$; from a physical perspective this is expected, since at large flow rates the heat exchange process barely takes place before the fluid leaves the insulation and it gives rise to extremely small IHEE values.

3. For fully concentrated exfiltration, i.e. in the limit as $X_B \rightarrow 0$ and $X_A = X$, it can be shown that:

$$\epsilon = \frac{1}{a} - \frac{X}{e^{Xa} - 1}$$

In a real building system, estimation of the diffuse and concentrated fractions

of the air leakage is extremely difficult and the success of the modeling approach as described above depends primarily on those estimates. To overcome these limitations, an alternative modeling approach is adopted whereby measurable quantities are used as prediction parameters for IHEE; the model developed is described below.

MODEL DEVELOPMENT

It is assumed that a simple one-dimensional mathematical formulation can be used to simulate the flow phenomenon with measurable quantities as key model parameters. A wall section (Figure 15), simulating the single stud-cavity test specimen, is considered here; it sustains intrusive air flow, at a mass flow rate $\dot{m}$ through a crack. The air path traverses a vertical configuration through the mid-thickness of the wall specimen with end effects ignored. The air inlet side temperature is T_c (typically the cold temperature) and the exit side temperature is T_h (typically the warm temperature). The width of the specimen (perpendicular to the plane of the paper) is assumed to be w . The heat flow by conduction is assumed to be one-dimensional, along the thickness of the specimen. H is the height of the wall specimen and hence is also the maximum path length for the air flow. The air can exit the wall at any vertical height and accordingly the path length (L) can vary from $x = 0$ to $x = H$. The heat transfer coefficient of the insulation on either side of the air path (including the surface coefficients) is assumed to be U . U_0 is the conductive heat transfer coefficient (i.e. at zero air flow) of the wall specimen including surface coefficients. T_f is the air temperature which varies along x .

Different configurations of the air path were tested before choosing the

Fig. 15. Wall Section Model with Intrusive Air Flow

configuration described above for further investigation. Performing an energy balance on a differential air element for a steady state condition:

$$\text{Energy Lost} = \text{Energy Gained}$$

$$\dot{m}C_p dT_f + (wdx)U(T_f - T_c) = (wdx)U(T_h - T_f) \quad (4.11)$$

or,

$$\frac{dT_f}{dx} = \frac{wU}{\dot{m}C_p}(T_h + T_c - 2T_f) \quad (4.12)$$

Substituting for the constant terms, let $A = \frac{2wU}{\dot{m}C_p}$ and $B = \frac{(T_h + T_c)wU}{\dot{m}C_p}$; hence equation (4.12) can be written as:

$$\frac{dT_f}{dx} + AT_f = B \quad (4.13)$$

Equation (4.13) is a non-homogeneous differential equation with constant coefficients. This equation can be solved using an integrating factor given by:

$$e^{(\int A dx)} = e^{(Ax)}$$

Equation (4.13) when multiplied by e^{Ax} yields:

$$e^{Ax} \frac{dT_f}{dx} + e^{Ax} AT_f = e^{Ax} B \quad (4.14)$$

or,

$$\frac{d}{dx}(T_f e^{Ax}) = e^{Ax} B$$

Integrating,

$$T_f e^{Ax} = \frac{B}{A} e^{Ax} + C$$

where C is the constant of integration. Thus the air temperature is given by:

$$T_f = \frac{B}{A} + C e^{-Ax} \quad (4.15)$$

Using the boundary condition, at $x = 0$, $T_f = T_c$, thus $C = (T_c - \frac{B}{A})$. Hence the solution to equation (4.13) is given by:

$$T_f = \frac{B}{A} + (T_c - \frac{B}{A}) e^{-Ax} \quad (4.16)$$

Substituting for A and B the temperature of the air at any x is given by:

$$T_f = \frac{T_h + T_c}{2} - \frac{(T_h - T_c)}{2} e^{-(2wUx)/(\dot{m}C_p)} \quad (4.17)$$

To calculate *Infiltration Heat Exchange Effectiveness*, ϵ , an energy balance on the whole building must be performed. Diffuse infiltration through wall A and concentrated exfiltration through wall B is assumed. Heat transfer in the vertical direction is neglected; i.e., no heat transfer takes place through the floor and through the ceiling. Indoor temperature is T_h and outdoor temperature is T_c .

$$\text{Total heat loss} = Q_A + Q_B$$

where subscripts refer to the walls. The wall heat losses will have two components each, conductive and convective. If the actual conductive loss at wall A is designated by $Q_{c,A}$, then the total heat loss Q_{loss} is given by:

$$Q_{loss} = Q_{c,A} - \dot{m}C_p(T_f(L) - T_{ref}) + U_0S(T_h - T_c) + \dot{m}C_p(T_h - T_{ref})$$

where S is the surface area of the entire wall. Also from the definition of IHEE, the total loss is given by:

$$Q_{loss} = U_0S(T_h - T_c) + U_0S(T_h - T_c) + (1 - \epsilon)\dot{m}C_p(T_h - T_c)$$

where the first two terms are the customary conductive loss terms for walls A and B, and the third term is the modified infiltration loss term. Hence, equating these two heat loss expressions:

$$(1 - \epsilon)\dot{m}C_p(T_h - T_c) = Q_{c,A} + \dot{m}C_p(T_h - T_f(L)) - U_0S(T_h - T_c)$$

the IHEE is given by:

$$\epsilon = \frac{T_f(L) - T_c}{T_h - T_c} - \frac{Q_{c,A}}{\dot{m}C_p(T_h - T_c)} - \frac{(U_0S)}{(\dot{m}C_p)} \quad (4.18)$$

Now the actual conductive heat loss from wall A, $Q_{c,A}$ has to be found:

$$Q_{c,A} = U_0(H - L)w(T_h - T_c) + \int_0^L wU(T_h - T_f(x))dx \quad (4.19)$$

On simplification,

$$Q_{c,A} = U_0(H - L)w(T_h - T_c) + wUL\frac{(T_h - T_c)}{2} + \frac{\dot{m}C_p}{4}(T_h - T_c)[1 - e^{-(2wUL)/(\dot{m}C_p)}] \quad (4.20)$$

Hence, from equation (4.18) and (4.20), ϵ is given by:

$$\epsilon = \frac{T_f(L) - T_c}{T_h - T_c} + \frac{wL}{\dot{m}C_p} \left(U_0 - \frac{U}{2} \right) - \frac{1}{4} [1 - e^{-(2wUx)/(\dot{m}C_p)}] \quad (4.21)$$

Thus knowing the path length of the air crack, dimensions and thermal resistance values of the wall section, the air flow rate and the temperatures, the *Infiltration Heat Exchange Effectiveness*, ϵ , can be predicted. The air exit temperature, $T_f(L)$, in the above expression is given by equation (4.17).

CHAPTER V

EXPERIMENTAL METHODOLOGY

There are a number of variables which presumably affect the *infiltration heat exchange effectiveness* with the most significant parameters being: (i) flow rate, (ii) crack length, (iii) crack diameter, and (iv) the pressurization exponent of the cell or specimen (which represents the crack characteristics also).

A procedure for measuring these variables along with IHEE was established to ensure the repeatability and reliability of the test data. The procedure followed for these tests and the tests performed are described below.

EXPERIMENTAL PROCEDURE FOR THE TEST CELL

The test cell was heated by a measured electrical input which powered the heater and the fan which was used to reduce stratification in the test cell. Prior to the experiment, the cell pressurization characteristics were determined by pressurizing the unheated cell and measuring the air flow required to maintain pressure levels ranging from 10–60 Pa [42, 43]. This data was then used to determine the flow constant, k , and the flow exponent, n , of the cell according to the equation:

$$q = k(\Delta P)^n \quad (5.1)$$

where q is the air flow rate in m^3/s and ΔP is the pressure difference in Pa. This equation has been shown by many investigators [44] to describe the relationship between infiltration flow, q , and pressure difference, ΔP . On physical grounds, it is expected (and has been observed) that the flow exponent,

n , should be between 0.5 (for orifice flow) and 1.0 (for fully developed, long pipe laminar flow). It has been observed [44] that some tight buildings exhibit values of n closer to 1.0 than to 0.5.

The test cell was then heated until steady state conditions were obtained for various inlet flow rates. The temperatures T_i were values measured at different positions within the test cell as indicated in Figure 5. The temperature T_a was the temperature measured in the room near the test cell. The average temperature, $\bar{T}_i$, within the test cell was taken as the average of all T_i values. The value of the overall UA for the test cell and air flow was calculated as

$$UA = \frac{Q}{(\bar{T}_i - T_a)} \quad (5.2)$$

where Q is the heating power which is the sum of the heater input and the fan power, U is the overall heat transfer coefficient of the test cell and A is the total surface area of the test cell.

The experimental procedure has been used to test several configurations of the test cell, i.e., different sizes and positions of inlet and outlet holes. The initial experiment was the base case for which infiltration was negligible. In this configuration, the gate valve at exit E was kept closed, and no air was injected into the test cell. For the tests to determine ' ϵ ', the following configurations (Figure 6) comprising different air entry and exit arrangements were used :

1. Entry : through hole 'B4', exit : through hole 'A'.
2. Entry : through hole 'B0', exit : none.
3. Entry : through hole 'B1', exit : none.

4. Entry : through hole 'B2', exit : none.
5. Entry : through hole 'B3', exit : none.
6. Entry : through hole 'B4', exit : none.
7. Entry : through hole 'B4', exit : through hole 'E'.
8. Entry : through hole 'B', exit : through holes 'E' and 'A'.
9. Entry : through hole 'P', exit : none.
10. Entry : through hole 'P', exit : through holes 'A' and 'B'.
11. Entry : through hole 'P', exit : through hole 'E'.
12. Entry : through hole 'P', exit : through holes 'A', 'B' and 'E'.

Air flow through holes 'A' or 'B' is termed *diffuse*, and flow through hole 'E' or 'P' is considered *concentrated*. When the exit listed is 'none', there will be a small amount of diffuse leakage through the walls of the test cell. This will also be present in parallel with the other openings used. The explicit diffuse leakage site (hole A or B) consists of two 0.75 inch diameter holes created in the same wall; the first hole was drilled in the exterior plywood, while the second hole was drilled in the interior plywood near the opposite corner of the wall. Thus when air was forced through the exterior hole, it flows inside the wall and enters the test cell through the interior hole. Hole 'E' consists of a 2 inch length of 1.5 inch ID tubing.

The base case UA represents the steady-state conductive heat loss coefficient of the test cell. Using measured temperatures and heating power in

equation (5.2), for the base case, $UA = 22.44$ Btu/hr-deg F. This value is consistent with the calculated value $UA = 20.93$ Btu/hr-deg F. Corner and edge effects were ignored in the calculated value. Throughout this dissertation it is assumed that in absence of any infiltration, $UA = 22.44$ Btu/hr-deg F and that $\epsilon = 0$. For all other cases, the value of ϵ is calculated from the measured UA value and the injected flow rate $\dot{m}$ as:

$$\epsilon = 1 - \frac{UA - (UA)_0}{(UA)_{inf}} \quad (5.3)$$

The difference $[(UA) - (UA)_0]$ represents the measured infiltration UA value, while the term $(UA)_{inf} = (\dot{m}C_p)$ is the infiltration loss coefficient as is usually calculated.

EXPERIMENTAL PROCEDURE FOR THE STUD-CAVITY

The methodology for testing the single stud-cavity specimen in the modified calibrated hot box is fairly similar to the procedure described above for the test cell. The temperature difference in this case is defined by the cold and hot space temperatures on each side of the stud-cavity. The calibration of the hot box was done in a very elaborate pattern. Initially a 8-piece composite specimen was built out of 1/2 inch thick polystyrene boards and this was used to investigate heat conduction by the thermocouple leads across the stud-cavity. The outcome of this test was instrumental in a major change of thermocouple layout inside the stud-cavity. At every thickness location in the stud cavity, the thermocouples were laid along the width instead of running them parallel to the thickness. This was followed by the actual calibration procedure where a

4 inch thick extruded polystyrene insulation of known thermal resistance (R-20) was subjected to a set of steady state tests with various temperature differences across the calibration specimen attained by modulating the power input to the heater panel. Hence, to generate a dataset, measurements were made to record the hot space temperature, the cold space temperature, the ambient temperature and the power input to the heater panel. Since the thermal resistance of the calibration specimen was known, the energy flow through the specimen could be estimated accurately; thus the rest of the energy input to the heater panel would constitute the heat loss from the hot side to the ambient and also from the hot side to the cold side through surfaces other than the specimen. Multiple linear regression conducted on this dataset generated a heat loss model which sufficiently describes the energy flow from the hot enclosure to the ambient and to the cold space (flanking loss). This loss quantity does not include the heat flow through the test specimen, i.e. the stud-cavity wall specimen. Additionally, the hot and the cold enclosures in the hot box were continuously monitored for air tightness by carrying out pressurization tests to estimate the infiltration loss from the hot space during these calibration tests. When the stud-cavity wall section was used for actual experiments, these energy loss quantities were used to calculate the $(UA)_0$ or the base (UA) value of the stud-cavity with no airflow through it (A being the surface area).

The energy loss model, regressed from the calibration test data and which adequately describes the heat transfer from the hot-space to outside and to the cold space, is given by:

$$Q_{loss} = 1.0249(T_h - T_c) + 2.3075(T_h - T_a) \quad (5.4)$$

where Q_{loss} is in Btu/hr and T_h and T_c are the hot and cold space temperatures in deg C. The base $(UA)_0$ value of the stud-cavity wall specimen is then given by:

$$(UA)_0 = \frac{(Q_{in} - Q_{loss})}{(T_h - T_c)} \quad (5.5)$$

where Q_{in} is the total power input, which is the sum of the heater power and the fan power. The *Infiltration Heat Exchange Effectiveness* is calculated as given by equation (5.3) for the test cell case. The direct-current power quantities delivered to the electrical heater and the fan were determined by computing the product of voltage and current supplied to each electrical device. The fan current was determined by measuring the voltage across a $3\Omega \pm 1\%$ precision shunt resistor (Dale, 3 watts, metal film resistor) and computing the current from Ohm's law. These voltages were measured by the Netpac data acquisition system.

The base case UA represents the steady-state conductive heat loss coefficient of the stud-cavity. Using measured temperatures and heating power in equation (5.5), for the base case, $(UA)_0 = 0.87$ Btu/hr-deg F. Whenever the test specimen was removed or changes occurred in the experimental set-up these measurements were repeated to check for any modification in the value of $(UA)_0$. Only in the case of configuration 5 (described later) was a change observed and a modified $(UA)_0$ of 0.79 Btu/hr-deg F was used in data analysis. The value of ϵ was calculated from the measured base case $(UA)_0$ value and the injected flow rate $\dot{m}$ as:

$$\epsilon = 1 - \frac{Q_{in} - Q_{loss} - (T_h - T_c)(UA)_0}{(T_h - T_i)(UA)_{inf}} \quad (5.6)$$

The numerator of the fraction represents the measured infiltration UA value, while the term $(UA)_{inf} = (\dot{m}C_p)$ is the infiltration loss coefficient as usually calculated and T_i is the air inlet temperature in deg C.

Prior to the experiment, the test specimen pressurization characteristics were determined by pressurizing the unheated stud-cavity and measuring the air flow required to maintain pressure levels ranging from 10–60 Pa. This data was then used to determine the flow constant, k , and the flow exponent, n , of the cell according to equation 5.1. The stud-cavity was then subjected to hot and cold temperatures on either side simultaneously until steady state conditions were obtained for various air flow rates. The experimental procedure has been used to test several configurations of the wall specimen, i.e., different positions of inlet and outlet holes. For the tests to determine ' ϵ ', the following configurations (Figure 16) with different air exit arrangements were used :

- A. Entry : through hole '1', exit : through hole '2'.
- B. Entry : through hole '1', exit : through hole '3'.
- C. Entry : through hole '1', exit : through hole '4'.
- D. Entry : through hole '1', exit : through hole '2', '3' and '4'.
- E. Entry : through hole '1', exit : through hole '5'.

As can be seen from the arrangements, all the inlet-exit configurations that have been used were *diffuse* in nature, except for configuration E which exhibited a more concentrated flow regime.

Fig. 16. Various Test Configurations for the Stud-Cavity

CHAPTER VI

RESULTS: TEST CELL

Steady state tests were run on the test cell and the results are presented here in this chapter. Pressurization tests accompanied each experiment for every configuration to provide a quantitative measure of the degree of diffuse leakage for each configuration.

Table 2 shows the results of pressurization measurements for the test cell in various configurations ranging from extremely tight to the leakiest configuration tested. It also shows the leakage coefficient, k , and the air changes per hour for the cell if pressurized to 4 Pa. The units of k provide air flow in m^3/s when pressure difference is measured in Pa. Each pair of n , k values corresponds to the average resulting from two to six pressurization measurements of the configuration shown. The standard deviation of n is typically 0.03 while that of k is 0.02. The 4 Pa results shown are frequently used to approximate the rate at which natural infiltration might occur.

It can be observed that when the test cell is sealed and the only leakage occurs through naturally occurring cracks and holes (hole opening = none), n is large, indicating primarily diffuse leakage as expected. The air change rate at 4 Pa is about 0.25 ACH, indicating tight construction. Addition of the *diffuse* holes (hole opening = B0, B1, B2, B3, B4 or A,B) increases the leakage appreciably and also lowers the flow exponent, since the flow through these holes is apparently less diffuse. Addition of the large hole (E or combinations of E and A,B) increases the leakage by an order of magnitude and drops the flow exponent to 0.50–0.53. The air change rate is somewhat larger than that of

TABLE 2. Pressurization Test Results (Air Entry Through Hole P)

Exit Hole Opening	n (average)	k (average)	ACPH (4 PA)
None	0.7520	8.90×10^{-5}	0.250
B0	0.6982	9.64×10^{-5}	0.252
B1	0.7165	9.52×10^{-5}	0.255
B2	0.7300	9.71×10^{-5}	0.265
B3	0.7400	9.38×10^{-5}	0.260
B4	0.7500	8.90×10^{-5}	0.250
A and B4	0.7144	1.23×10^{-4}	0.329
E	0.5120	1.31×10^{-3}	2.640
B4 and E	0.5030	1.42×10^{-3}	2.830
A, B4 and E	0.5288	1.34×10^{-3}	2.780

typical houses, although it should be observed that the surface to volume ratio of the test cell is approximately three times that of a typical house, so direct comparisons can be misleading.

INFILTRATION HEAT EXCHANGE EFFECTIVENESS

The measurements show that the *Infiltration Heat Exchange Effectiveness* (IHEE) depends on the flow rate for any configuration. It is useful to define a normalized flow parameter

$$a = \frac{\dot{m}C_p}{(UA)_0} \quad (6.1)$$

where $(UA)_0$ is the total loss coefficient of the cell in the absence of air flow into/out of the cell. Hence a is zero for no air flow and is unity when the air flow rate gives an "infiltration loss coefficient," $\dot{m}C_p$, as large as the "conductive" loss coefficient, $(UA)_0$.

ϵ is shown as a function of the normalized flow rate a for different flow configurations in Figures 17-28. For the range of flow rates examined, ϵ appears to be an essentially linear function of a within measurement error. Consequently, for purposes of this discussion, ϵ is approximated by

$$\epsilon = \epsilon(0) + ma \quad (6.2)$$

where m is an empirical slope coefficient determined by linear regression. The values $\epsilon(0)$, m and the range of a used to determine $\epsilon(0)$ and m are summarized in Table 3.

It can be observed that in all cases except one the slope m is negative and $0 < \epsilon(0) < 1$ as expected; the measured positive slope is very small and may be due to measurement error. Examination of Figures 17-28 also shows that $0 < \epsilon < 1$ for all values of a for which measurements were conducted. This appears to be the most significant result of these measurements. The values of IHEE are greater than zero for every case measured, indicating that the standard procedure for calculating infiltration loads systematically overestimates infiltration loads. Furthermore, the measurements verify that significant *Infiltration Heat Exchange Effectiveness* can be measured in frame construction.

The data shown in Table 3 and Figures 17-28 can also be used to construct other hypotheses which should be investigated. These include the following:

1. For cases where the flow into or out of the test cell is highly diffuse, the

TABLE 3. Linearized Dependence of ϵ on a for Different Flow Configurations

Inlet	Outlet	$\epsilon(0)$	m	Range of a Measured
B4	A	0.87	-1.00	0.05 - 0.25
B0	None	0.75	-0.51	0.08 - 0.20
B1	None	0.75	-0.59	0.08 - 0.18
B2	None	0.81	-0.58	0.05 - 0.18
B3	None	0.76	-0.66	0.06 - 0.20
B4	None	0.82	-1.54	0.05 - 0.16
B4	E	0.76	-1.61	0.08 - 0.25
B4	E & A	0.60	-0.56	0.06 - 0.25
P	None	0.63	-2.53	0.04 - 0.17
P	A & B4	0.59	-1.10	0.05 - 0.26
P	E	0.08	0.111	0.07 - 0.28
P	A, B4 & E	0.21	-0.09	0.05 - 0.28

Fig. 17. IHEE vs. a for Diffuse (B4) Inlet and Diffuse (A) Outlet

Fig. 18. IHEE vs. a for Diffuse (B0) Inlet and No Outlet

Fig. 19. IHEE vs. a for Diffuse (B1) Inlet and No Outlet

Fig. 20. IHEE vs. α for Diffuse (B2) Inlet and No Outlet

Fig. 21. IHEE vs. a for Diffuse (B3) Inlet and No Outlet

Fig. 22. IHEE vs. a for Diffuse (B4) Inlet and No Outlet

Fig. 23. IHEE vs. a for Diffuse (B4) Inlet and Concentrated (E) Outlet

Fig. 24. IHEE vs. a for Diffuse (B4) Inlet and Mixed (E & A) Outlet

Fig. 25. IHEE vs. a for Concentrated (P) Inlet and No Outlet

Fig. 26. IHEE vs. a for Concentrated (P) Inlet and Diffuse (A & B4) Outlet

Fig. 27. IHEE vs. a for Concentrated (P) Inlet and Concentrated (E) Outlet

Fig. 28. IHEE vs. a for Concentrated (P) Inlet and Mixed (A, B4 & E) Outlet

slope is much larger than for concentrated flow; however, the range of a measured was small for these cases since the cell was tight and larger values of flow would have required pressures above 60 Pa, the upper limit used in the tests.

2. In about half the cases, the slope m is less than the value of $\epsilon(0)$. On physical grounds, it is expected that m will be less than ϵ for large values of flow and hence expect that the dependence of ϵ on a would become non-linear at larger flow rates.

Dependency of ϵ on Flow Exponent

The values of ϵ at a particular value of a , as obtained from the best fit linear regression, were correlated to the average values of n obtained from the pressurization tests. Each pair of ϵ and n corresponds to a particular air flow pattern which is characterized by a configuration identification and hole opening.

Figures 29 and 30 present the results of these correlations for the diffuse and concentrated entry configurations, respectively, in the low flow limit ($a = 0.05$). Figures 31 and 32 likewise show the pattern of variation of ϵ with n at moderate flow rates ($a = 0.2$). The important observation is that ϵ increases as n increases. Kiel et al. [44] measured n for a sample of 711 houses in Canada and the United States, and the flow exponent, n , appeared to have a normal distribution with a mean of 0.67, confirming the common perception that the average flow exponent is between 0.65 and 0.68. However, from a regression analysis of the IHEE data in Figures 29 through 32, ϵ assumes values ranging from 0.21 to 0.72 at $n = 0.67$. Hence, comparison of this trend with the pressurization test data reported by Kiel et al. [44] indicates that for

about half of all houses, a measured infiltration rate in a typical house probably changes the energy load to only 28 - 79 percent of the calculated value of the infiltration energy load.

To obtain greater insight into the correlation between the effectiveness, ϵ , and the flow exponent, n , the slope, m , of the ϵ - a correlation is plotted as a function of n in Figures 33 and 34 for diffuse and concentrated air entry configurations, respectively. Each pair (m, n) corresponds to a particular air flow pattern characterized by a configuration identification and a particular gate valve opening. A fairly strong correlation exists for 'concentrated' entry, but is less obvious for 'diffuse' entry. For hole configurations where air enters the cell through hole B2 or B4, the scatter in the data may have occurred due to the change in leakage characteristics of the test cell over the course of time and also may be due to measurement errors. The results suggest that the effectiveness, ϵ , is probably correlated to the flow rate, $\dot{m}$, as expected from physical considerations. It remains to be seen whether these correlations will be observed in normal houses.

EFFECT OF INFILTRATION PATH ON IHEE

It may be observed that the heat exchange effectiveness, ϵ , depends on the physical construction of the building and specially on the path along which air infiltrates into or exfiltrates out of the building. Five different configurations of the test cell (configurations 2 through 6 as mentioned before) were chosen to investigate the effect of leakage path length on ϵ . For each configuration, a series of experiments were conducted to determine the ϵ - a variation. The values of ϵ measured range from 0.55 to 0.80 with the parameter a varying

Fig. 29. IHEE vs. n at Small Flow Rate for Diffuse Inlet

Fig. 30. IHEE vs. n at Small Flow Rate for Concentrated Inlet

Fig. 31. IHEE vs. n at Moderate Flow Rate for Diffuse Inlet

Fig. 32. IHEE vs. n at Moderate Flow Rate for Concentrated Inlet

Fig. 33. m vs. n for Diffuse Inlet

Fig. 34. m vs. n for Concentrated Inlet

from 0.05 to 0.2. As noted earlier, effectiveness decreases with increasing α . But most importantly, ϵ increases with the leakage path length. This result is expected since the air flowing through the crack will have more contact with the warm surfaces (i.e. the leakage path) and increased heat transfer will occur for longer path lengths. Figure 35 shows this trend clearly where ϵ is plotted against a non-dimensional path length L_i/L_4 characterizing each configuration and for a constant value of $\alpha = 0$. The path length L_i is defined as the minimum distance between the exterior opening and the interior opening on the wall for a particular leakage path 'i'; the normalizing parameter L_4 is the leakage path length for configuration B4. However, it is not obvious, at this stage, that this distance represents the actual length that air traveled before entering the test cell. It is simply assumed to be a parameter to quantify the length of the leakage path.

HOLE-SIZE EXPERIMENT ON TEST CELL

To evaluate the effect of crack size (i.e. diameter of the hole in the current context) on the IHEE, a series of steady-state tests were carried out on the test cell. Air was introduced through three wall surfaces and air escaped out through the holes provided in the other three wall surfaces. All the six flows through the six wall, roof and wall surfaces were diffuse in nature, in the sense that air entered the wall insulation through the plywood, then it traveled along the surface dimensions and finally it left the wall through the other end of the wall. Four different hole sizes were attempted; diameter of the holes being 11/64 inch, 1/4 inch, 3/8 inch and 1/2 inch on all the six surfaces and the leakage path length remained the same in all the four configurations. The *Infiltration Heat Exchange Effectiveness* for the four hole sizes is presented in Figures 36–

Fig. 35. IHEE vs. Leakage Path Length for Diffuse Configuration

39. As is evident from the plots, the flow becomes less diffuse as the hole size increases and hence the effectiveness decreases. ϵ at $\alpha = 0.25$ is shown against hole diameter in Figure 40 and the trend is clearly illustrated there. Also with the hole diameter increasing, the $\epsilon - \alpha$ plots become flatter indicating the decreasingly diffuse nature of the leakage path.

The results presented in this chapter clearly show that air flow through frame construction can exhibit significant heat exchange, substantially reducing the energy requirements on the test cell due to infiltration. Infiltration heat exchange effectiveness increases as :

- a) flow rate decreases;
- b) flow path length increases;
- c) hole/crack size decreases.

Infiltration Heat Exchange Effectiveness values as large as 0.8 have been measured, which indicate that for very tight construction, it is possible that conventional estimates of the infiltration load based on air exchange estimates could be in error by as much as a factor of 5. For the range of values of the pressurization exponent, n , typically measured in houses, values of IHEE measured in the test cell were smaller but still suggest that estimates of infiltration load based on air exchange rates are likely to systematically overestimate infiltration loads by an average of 20 percent or more.

Examination of the dependence of IHEE on flow rate and flow exponent suggests that for typical flow rates, the flow exponent may provide useful predictive information regarding the size of IHEE and can be incorporated into a procedure for modifying infiltration load calculation procedures for houses after

Fig. 36. IHEE vs. a for 11/64 Inch Diffuse Inlet and Diffuse Outlet

Fig. 37. IHEE vs. a for 1/4 inch Diffuse Inlet and Diffuse Outlet

Fig. 38. IHEE vs. α for 3/8 inch Diffuse Inlet and Diffuse Outlet

Fig. 39. IHEE vs. a for 1/2 inch Diffuse Inlet and Diffuse Outlet

Fig. 40. IHEE vs. Inlet Size for Diffuse Air Entry

further experimental and theoretical research.

CHAPTER VII

RESULTS: STUD-CAVITY WALL SECTION

This chapter discusses the results obtained from the stud-cavity wall section. A parametric comparison of the simplified model and the data is also presented in this chapter. Steady state tests were run on a stud-cavity wall section which served as the test specimen; pressurization tests accompanied each experiment for every configuration. The objective was to quantitatively investigate the degree of diffuse behavior of the stud-cavity for several configurations. Five different configurations, each having a unique air inlet and exit combination, were tested at various air flow rates and a base case experiment was performed with no air flow. Details of this experimental methodology have been presented in Chapter V.

A sensitivity and uncertainty analysis was carried out for the measured values of the Infiltration Heat Exchange Effectiveness and the details are outlined in Appendix A. It was found that the measurement of ϵ is quite sensitive to cold space temperature, hot space temperature, ambient temperature and the power input since the model of the calibrated hot box was developed for a particular set of parameters. Accordingly, all these variables were kept within an extremely narrow band to minimize the bias caused by changes in these variables. A typical operating condition would be a hot space temperature of 25.5 C, a cold space temperature of 1 C and an ambient temperature of about 23 C. The heater power input and the temperature controller for the cooling system were manipulated to achieve such operating conditions. Air flow rate was varied within a range, typically 4 SLPM (standard liters per minute) to 15 SLPM, where the

pressure difference between the interior of the stud-cavity and the cold/hot space was maintained below 60 Pa. IHEE, ϵ , is shown as a function of the air flow rate in Figure 41 for configuration A, where the air leaves the stud-cavity at a point diagonally across from the inlet location (hole 2 in Figure 16) and thus should utilize the whole vertical height of the test specimen for heat exchange. It may be observed that ϵ decreases with increase in air flow rate, as anticipated. At small flow rates, the measurement uncertainty increases dramatically coincident with a sudden increase in the ϵ value at 4 SLPM. The maximum theoretical value of ϵ is 0.5 for this configuration, so the large value obtained at 4 SLPM is apparently due to experimental error. Repeatability is quite good as evidenced by the two cases where measurements were repeated at the same flow rates.

In configuration B, exit hole 2 was plugged and a new exit hole 3, vertically above the air inlet, was used for the experiments. Since the test specimen wall section has a height which is much greater than its width, this configuration has about the same air path length as compared to configuration A. The measured ϵ values (Figure 42) are comparable to those from configuration A and the dependence on flow rate is similar also; IHEE decreases with increasing air flow rate.

In configuration C, exit holes 2 and 3 were plugged and a new hole 4 was opened up at the center of the wall section. This provides about half the air path length that was used before and hence a lower ϵ value is anticipated. Figure 43 shows the variation of ϵ with air flow rate and a significant drop in IHEE values is noted. The figure also shows a sharper gradient in the variation for flow rates above 6 SLPM.

In the next configuration (D) all the exit holes used so far, i.e., exit hole 2,

Fig. 41. Measured IHEE Values for Inlet at 1 and Outlet at 2

Fig. 42. Measured IHEE Values for Inlet at 1 and Outlet at 3

Fig. 43. Measured IHEE Values for Inlet at 1 and Outlet at 4

3 and 4 were opened and thus a 3-hole exit pattern was employed. Naturally, a higher air flow rate could be used within the stipulated 60 Pa pressure difference limit. A longer path length and/or more heat exchange area can be envisaged for this configuration which would cause a rise in IHEE values. Figure 44 illustrates the variation of ϵ with air flow rate for configuration D and the general trend noted for configurations A and B is present, but ϵ values are not appreciably different. The high measured value of ϵ at 4 SLPM again may be assumed due to measurement error.

Configuration E represents a very short path length with the air outlet located just across the thickness of the wall section from the air inlet. The measured values of ϵ with respect to air flow rate are illustrated in Figure 45. A sharp drop in IHEE values is observed relative to the previous configurations. This is anticipated as the flowing air gets much less opportunity to exchange heat with the porous insulation inside the stud-cavity giving rise to small ϵ values. However, the results for this configuration are counter-intuitive; for a flow situation with a straight-across outlet, a lower range of ϵ values might be expected since there appears to be little opportunity for the moving air to exchange heat. But the measured data exhibits values of IHEE near 0.2; a sharper gradient in the plot is also observed.

The results presented clearly show that air flow through a stud-cavity specimen can exhibit significant heat exchange, substantially reducing the energy requirements on the specimen due to infiltration.

Four of the 39 measurements made show values of $\epsilon > 0.5$, the theoretical maximum value, and all occur for flow rates near or below 5 SLPM. An uncertainty analysis was performed for the test data domain as outlined in Appendix

Fig. 44. Measured IHEE Values for Inlet at 1 and Outlet at 2, 3 and 4

Fig. 45. Measured IHEE Values for Inlet at 1 and Outlet at 5

A. The uncertainty for each measured ϵ is illustrated for each configuration and air flow rate in Figure 46. The uncertainty is based on the maximum error specified for each measurement made in the experiment. The repeatability of individual data points and the consistent trend of ϵ values show that experimental error is generally less than the uncertainty values shown in Figure 46.

It may be observed from Figure 46 that at low flow rates (e.g. 4 SLPM), the uncertainty increases rapidly. The ϵ values at low flow rates have been consistently at or above the expected values. This deviation is within the inherent large uncertainty present in the experimental measurement procedure at extremely low flow rates; however, it may reflect a systematic error at low flow rates.

TEMPERATURE DISTRIBUTION INSIDE THE STUD-CAVITY

The stud-cavity design incorporated 75 thermocouples embedded in the fiberglass insulation inside the stud-cavity to measure temperature at selected points forming a grid, in a $3 \times 5 \times 5$ matrix across the inside volume. A normalized 3-dimensional temperature distribution analysis was carried out to better understand the air path length for each inlet-exit configuration. For each air flow rate and each configuration, the measured temperature was subtracted from the temperature measured at the same thermocouple location, with zero air flow rate. This temperature difference is assumed to represent the effect of the intrusive air flow at that particular location inside the wall specimen. After studying the data for all nodes inside the stud-cavity, it was decided that the temperature differences measured at the five locations across the thickness of the stud-cavity can be averaged to give 15 temperature differences representing

Fig. 46. Uncertainty Bars for Measured IHEE Values

the influence of the air flow and its variation along the width and along the height of the stud-cavity. A selection of these 3-D temperature distribution plots has been included in this chapter and the rest of them appear as Appendix B.

Figures 47 and 48 show the temperature difference distributions for 11 SLPM and 13 SLPM respectively for configuration A. The height of the bars in these plots depicts the influence of the air flow through the stud-cavity. In this configuration the air inlet is near location 1C and the outlet is near location 5A. Those locations register strong changes due to the air flow; otherwise locations 1A, 1B, 2A and 2C, near the inlet, clearly show air flow around them. Around the exit, nodes 4A, 5B and 5C show noticeable temperature differences. Node 3A, at the middle elevation, shows a small change due to air flow. A clear path is not completely apparent from the plot and a possible bypass around the thermocouple stations at 2B, 3B and 3C is suggested. The temperature differences increase with an increase in flow rate, as can be observed from the plots. The locations where no change is observed may have experienced natural convection flows around them in the zero air flow rate configuration and these plots simply superimpose the air flow experiments onto the base case; this is a possible explanation for those locations which show no temperature change.

These graphs have been plotted to reveal the distribution of temperature changes due to air flow in the stud-cavity when subjected to an intrusive cold air flow and to obtain a length parameter to serve as the effective air path length to be used in the simplified model, described in Chapter IV. An effective path length, L_{eff} , can be defined as:

$$L_{eff} = (\text{area affected} / \text{total area}) \times (\text{cavity length})$$

Thus, for example, if 5 of the 15 temperature differences are significant, then the effective air path length for that particular configuration is one-third ($5/15$) the total height of the test section. This definition was adopted after careful intuitive and quantitative examination of the measured data and the simplified 1-dimensional model being employed. Following this procedure, 11 of the 15 temperature bars in Figures 47 and 48 seem to be influenced by the air flow, and hence, the effective path length $0.733 \times 8 \text{ ft} = 5.87 \text{ ft}$.

Figures 49 and 50 show the temperature difference plots for configuration B at air flow rates of 12 and 14 SLPM respectively. This pair of plots is very similar to those described above for configuration A. But the change in location of the air outlet to node 5C is evident. Some of the nodes again seem to be unaffected by the fluid flow. On inspection, this configuration also yields an effective air path length of 5.87 ft. Appendix B clearly shows that the perturbation is much smaller at lower flow rates.

Configuration C uses a mid-elevation air outlet which is clearly evident in Figures 51 and 52 which show the temperature differences inside the stud-cavity for flow rates of 11 and 13 SLPM respectively. The upper half of the wall section does not seem to have participated in the heat exchange process as the traveling air escapes through the mid-exit without moving further up. The temperature bars are most prominent around the inlet and outlet and 8 locations out of 15 appear to be influenced by the cold air flow. Accordingly, the effective path length is calculated to be 4.3 ft. A notable omission among the unaffected cells is 2B which, though surrounded by affected cells, does not register any temperature change from the zero flow situation.

Marginally higher flow rates were used in Configuration D as noted earlier.

Configuration A
11 SLPM

Fig. 47. Temperature Difference Plot for Configuration A at 11 SLPM

Configuration A
13 SLPM

Fig. 48. Temperature Difference Plot for Configuration A at 13 SLPM

Configuration B

12 SLPM

Fig. 49. Temperature Difference Plot for Configuration B at 12 SLPM

Configuration B

14 SLPM

Fig. 50. Temperature Difference Plot for Configuration B at 14 SLPM

Configuration C

11 SLPM

Fig. 51. Temperature Difference Plot for Configuration C at 11 SLPM

Figures 53 and 54 show the temperature difference plots for this arrangement and the three different outlet locations can be identified in the plot. The entire stud-cavity seems to be influenced by the flow and hence the total height of the stud-cavity (8 ft.) is used as the effective path length for this configuration.

Finally, in configuration E, a short path length is encountered by the traveling air before it flows out through hole 5 located directly across the cavity from the inlet. Figures 55 and 56 show the temperature influence of the fluid flow at flow rates of 10.5 and 13 SLPM respectively. It may be noted that all three nodes 1A, 1B and 1C are significantly influenced and hence the effective path length is assumed to be equal to the inside width (the insulation filled width) which is 1.22 ft.

COMPARISON OF EXPERIMENTAL RESULTS WITH MODEL

In this section the experimental results are compared to those predicted by the analytical model. For this comparison, the hot-space and the cold-space temperature is assumed to be 78 F and 33.8 F respectively to match the test conditions. The measured U-value of the stud-cavity was used and the surface area of the wall specimen is taken as (8×1.5) or 12 square feet. Surface heat transfer coefficients have been used at the air-insulation interface and also at the external surfaces of the stud-cavity. The surface heat transfer coefficients are determined from forced convection correlations using the proper air velocity on the corresponding surface; for the interior surface coefficient, a value of $h_i = 2.5$ Btu/hr-sq.ft.-F has been used whereas for the external surface coefficient a value of $h_o = 4.0$ Btu/hr-sq.ft.-F has been used.

Configuration D

15 SLPM

Fig. 53. Temperature Difference Plot for Configuration D at 15 SLPM

Configuration E
10.5 SLPM

Fig. 55. Temperature Difference Plot for Configuration E at 10.5 SLPM

Configuration E

13 SLPM

Fig. 56. Temperature Difference Plot for Configuration E at 13 SLPM

Figures 57 through 61 show the model predictions compared with the measured values of *Infiltration Heat Exchange Effectiveness*, ϵ , for configurations A through E respectively. The model shows the tendency of ϵ to decrease in value with an increase in flow rate. For configuration A and configuration B the model underpredicts ϵ appreciably. The model shows excellent agreement with the measurements for the other three configurations, namely C, D and E. In configuration E, where small values of IHEE were intuitively expected, model predictions using the effective path length are very close to the measured values.

It may be noted that the IHEE prediction by the model is controlled by two primary parameters: the air flow rate, which is measured directly in the experiment; and the effective air path length, which is estimated from the temperature difference data. Although this heat and mass transfer problem is clearly 3-dimensional in nature, the simple 1-dimensional analytical model has performed remarkably well.

Fig. 57. IHEE for Configuration A: Comparison Between Model and Experiment

Fig. 58. IHEE for Configuration B: Comparison Between Model and Experiment

Fig. 59. IHEE for Configuration C: Comparison Between Model and Experiment

Fig. 60. IHEE for Configuration D: Comparison Between Model and Experiment

Fig. 61. IHEE for Configuration E: Comparison Between Model and Experiment

CHAPTER VIII

CONCLUSIONS AND RECOMMENDATIONS

The actual energy consumption due to air infiltration in a test cell and in a well-characterized stud-cavity wall specimen has been studied experimentally and analytically. The conclusions drawn from this investigation are presented and discussed in this chapter. The benefits and limitations of this study as well as recommendations for future work are presented.

CONCLUSIONS

Infiltration is customarily assumed to increase the heating and cooling load of a building by an amount equal to the mass flow rate of the infiltration times the enthalpy difference between the inside and outside air – with the latent portion of the enthalpy difference sometimes neglected. Calorimetric measurements conducted on a small test cell and a single stud-cavity wall test specimen with measured amounts of infiltration introduced under a variety of conditions show convincingly that infiltration can lead to a much smaller change in the energy load than is customarily calculated. The data also suggest that the phenomenon occurs in full-sized houses as well.

Infiltration Heat Exchange Effectiveness (IHEE), ϵ , is introduced as a measure of the effectiveness of a building envelope in *recovering* heat otherwise lost (or gained) due to infiltration. Measurements clearly show that air flow through frame construction can exhibit significant heat exchange, substantially reducing the energy requirements on a test cell due to infiltration. *Infiltration Heat Exchange*

Effectiveness increases as :

- a) flow rate decreases;
- b) flow path length increases;
- c) hole/crack size decreases.

There is a clear correlation between large values of ϵ and large values of the exponent, n , so fan pressurization results may be useful in predicting ϵ for buildings.

Infiltration Heat Exchange Effectiveness values as large as 0.8 have been measured, which indicate that for very tight construction, it is possible that conventional estimates of the infiltration load based on air exchange estimates could be in error by as much as a factor of 5. For the range of values of the pressurization exponent n typically measured in houses, values of IHEE measured in the test cell were smaller but still suggest that estimates of infiltration load based on air exchange rates are likely to systematically overestimate infiltration loads by an average of 20 percent or more. Examination of the dependence of IHEE on flow rate and flow exponent suggests that for typical flow rates, the flow exponent may provide useful predictive information regarding the size of IHEE and can be incorporated into a procedure for modifying infiltration load calculation procedures for houses after further experimental and theoretical research.

Measurements for various air flow rates, and incorporating a variety of inlet and outlet configurations on the stud-cavity test specimen, indicate similar generalized trends for ϵ . *Infiltration Heat Exchange Effectiveness* increases as:

- a) flow rate decreases;
- b) flow path length increases.

A careful study of the experimental data indicated a clear correlation between ϵ and the air flow rate along with the effective path length for the flow. A procedure has been developed for defining the effective path length for typical air flow configurations in terms of the changes in the interior temperature distribution within the insulation filled wall section.

A simplified model which incorporates macroscopically observable and a characterizable feature of wall structures, viz., effective path length etc., was investigated to complement the experimental study. The objective was to improve the ability to predict the energy penalty associated with air infiltration in a building envelope. A simplified model based on fundamental heat and mass transfer principles has been developed; 1-dimensional flow with idealized conditions was assumed. The model predicts the IHEE values as a function of air flow rate and effective path length. The predicted dependence of ϵ on air flow rate and effective path length for the configurations tested was consistent with the experimental results, although the model under-predicted the IHEE values for two of the configurations. For shorter path lengths the agreement between the model and the test data was much closer. At small flow rates disagreement between the model and the experimental data increased; however, the experimental uncertainty increased rapidly at extremely small flow rates. For a flow arrangement with a very short path length, the IHEE values measured were larger than expected (intuitively), but were in agreement with the model predictions. This counter-intuitive phenomenon occurred for configuration E where a straight-across flow outlet was incorporated.

BENEFITS

The benefits and impact of the outcome of such an investigation are expected to be quite significant in building science and in the HVAC area. They include:

- (a) better prediction of heating and cooling loads of building systems;
- (b) more accurate equipment sizing;
- (c) improved building tightening criteria;
- (d) more insight into the fundamental understanding of
 - (i) attic behavior (and radiant barriers);
 - (ii) insulation behavior;
- (e) economics of ventilation air heat exchangers vs. exhaust fans;
- (f) potential indoor air quality issues;
- (g) better accuracy in calibrated hot box measurements due to modified infiltration load.

RECOMMENDATIONS

The experiments on the well-characterized stud-cavity were quite sensitive to the space temperatures; closer control over these temperatures is desirable in future tests. More accurate measurement of the temperature of the air exiting

the stud-cavity should be undertaken. The current method introduced a significant bias toward the hot space temperature. For convenience:

- i) the space around the wall section needs to be increased so that access to several areas, viz. the inlet and outlet locations, cold side thermocouples, circulating fans, etc., becomes easier,
- ii) the sealing arrangement at the front of the calibrated hot box using polyethylene sheet, caulk and plywood planks bolted into the edges needs to incorporate a different design so opening and closing of the test apparatus become easier, quicker and more airtight.

There are several limitations of the model that can be noted; the physical flow pattern inside the stud-cavity wall specimen is 3-dimensional in nature and future simulation work should incorporate a more elaborate multi-dimensional approach. The mathematical model in its present form assumes no heat exchange during the horizontal travel of air inside the wall section. This needs to be modified to a more realistic assumption. The effect of the crack size does not appear in the current model; this needs to be introduced.

Studies on different building components have to be continued followed by measurements on real houses and test houses in the open to confirm the findings of this dissertation and also to extend the knowledge on the effect of other parameters on ϵ . The effects of seasonal variation and also of the simultaneous presence of infiltration and exfiltration at varying temperature differences across the walls are some of the parametric studies that can be undertaken in the future. Future studies should also include extensive dynamic testing starting from simple components and then moving on to more complex assemblies.

REFERENCES

- [1] Etheridge, D.W., "Crack Flow Equations and Scale Effect," *Building and Environment*, vol. 12, no. 3, 1977, pp. 181-189.
- [2] Caffey, G.E., "Residential Air Infiltration," *ASHRAE Transactions*, vol. 85, part 1, 1979, pp. 41-57.
- [3] Persily, A., "Understanding Air Infiltration in Homes," Report PU/CEES #129, *Princeton University Center for Energy and Environmental Studies*, NJ, February, 1982, 335 pp.
- [4] Baker, P.H., Sharples, S. and Ward, I.C., "Air Flow Through Cracks," *Building and Environment*, vol. 22, no.4, 1987, pp. 293-204.
- [5] Feustel, H.E. and Kendon, V.M., "Infiltration Models for Multicellular Structures - A Literature Review," *Energy and Buildings*, vol. 8, 1988, pp. 123-136.
- [6] Liddament, M. and Allen, C., "The Validation and Comparison of Mathematical Models of Air Infiltration," Technical Note AIC 11, *Air Infiltration Centre*, Berkshire, England, 1983.
- [7] Claridge, D.E. and Bhattacharyya, S., "The Measured Energy Impact of Infiltration in a Test Cell," *Journal of Solar Energy Engineering*, vol. 112, 1990, pp. 132-139.
- [8] Anon., "Dynamic Insulation : the Next Step?", *Australian Refrigeration, Air Conditioning and Heating*, November, 1984, pp.47.
- [9] Arquís, E. and Langlais, C., "What Scope for 'Dynamic Insulation'?", *Batiment International Building Research and Practice*, vol. 19, 1986, pp. 84-93.
- [10] Guo, J. and Liu, M.S., "The Energy Saving Effect of Double Frame Windows," *Proceedings of the CLIMA 2000 World Congress on Heating*,

Ventilating and Air-Conditioning, vol. 2, Copenhagen, Denmark, 1985, pp. 84-97.

- [11] Timusk, J., Seskus, A.L., and Lio, M., "Performance Evaluation of the Dynamic Wall House," Project Report prepared by *Centre for Building Science*, University of Toronto, Toronto, Canada, 1987, 51 pp.
- [12] Bailly, N.R., "Dynamic Insulation Systems and Energy Conservation in Buildings," *ASHRAE Transactions*, vol. 93, part 1, 1987, pp. 447-466.
- [13] Dubois, P., "Energy Efficient Building Walls," *Proceedings of the First E.C. Conference on Solar Collectors in Architecture*, Venice, Italy, 1983, pp. 144-158.
- [14] "ASHRAE Handbook: 1985 Fundamentals," *American Society of Heating, Refrigerating and Air-Conditioning Engineers*, Atlanta, GA, 1985, Chap. 28.
- [15] "DOE-2 Reference Manual," *Los Alamos Scientific Laboratory*, Los Alamos, NM, 1980.
- [16] "SERI-RES : Solar Energy Research Institute Residential Energy Simulator," version 1.0, *Solar Energy Research Institute*, Golden, CO, 1982.
- [17] Beyea, J., Dutt, G. and Wotecki, T., "Critical Significance of Attics and Basements in the Energy Balance of Twin Rivers Townhouses," *Energy and Buildings*, vol. 1, 1977, pp. 261-269.
- [18] Harrje, D.T., Dutt, G. and Beyea, J., "Locating and Eliminating Obscure but Major Energy Losses in Residential Housing," *ASHRAE Transactions*, vol. 85, part 2, 1979, pp. 521-59.
- [19] Claridge, D.E., Jeon H. and Bida, M., "Performance Analysis of the Colorado 50/50 Retrofit Program," vol. I, Submitted to the *Solar Energy Research Institute* by the University of Colorado, Dept. of Civil, Env. & Arch. Engineering, February, 1984, 82 pp.

- [20] Claridge, D.E., Jeon H. and Bida, M., "A Comparison of Traditional Degree-Day and Variable-Base Degree-Day Predictions with Measured Consumption of 20 Houses in the Denver Area," *ASHRAE Transactions*, vol. 91, part 2, 1985, pp. 865-874.
- [21] Anderlind, G., "Energy Consumption Due to Air Infiltration," *Proceedings of the 3rd ASHRAE/DOE/BTECC Conference on Thermal Performance of the Exterior Envelopes of Buildings*, Clearwater Beach, FL, 1985, pp. 201-208.
- [22] Anderlind, G. and Johansson, B., "Dynamic Insulation : A Theoretical Analysis of Thermal Insulation through which a Gas or Fluid Flows," Document D8:1983, *Swedish Council for Building Research*, Stockholm, Sweden, 1983, 69 pp.
- [23] Kohonen, R., "Thermal Effects of Airflows and Moisture on Exterior Wall Structures," *Proceedings of the 3rd ASHRAE/DOE/BTECC Conference on Thermal Performance of the Exterior Envelopes of Buildings*, Clearwater Beach, FL, 1985, pp. 583-605.
- [24] Kohonen, R. and Virtanen, M., "Thermal Effects of Air Leakages on the Thermal Performance of Building Structures," *Technical Research Center of Finland, Laboratory of Heating and Ventilating*, Espoo, Finland, 1985, 21 pp.
- [25] Kohonen, R., Ojanen, T. and Virtanen, M., "Thermal Coupling of Leakage Flows and Heating Load of Buildings," *8th AIVC Conference on Ventilation Technology - Research and Application*, Uberlingen, West Germany, 1987, pp. 10.1-10.22.
- [26] Kohonen, R. and Virtanen, M., "Thermal Coupling of Leakage Flows and Heating Load of Buildings," *ASHRAE Transactions*, vol. 93, part 2, 1987, pp. 2303-2318.
- [27] Berlad, A.L., Tutu, N., Yeh, Y-J., Jaung, R., Krajewski, R., Hoppe, R. and Salzano, F.J., "Air Intrusion Effects on the Performance of Permeable Insulation Systems," *Thermal Insulation Performance*, ASTM STP 718,

American Society for Testing and Materials, Philadelphia, PA, 1980, pp. 181-194.

- [28] Berlad, A.L., Tutu, N., Jaung, R. and Yeh, Y-J., "Interim Progress Report on an Investigation of Energy Transport in Porous Insulator Systems," Department of Mechanical Engineering, SUNY, Stony Brook, NY, October, 1979, 37 pp.
- [29] Berlad, A.L., Jaung, R., Joshi, N. and Westerinen, J., "Energy Transport in Porous-Insulator Systems - Performance of Vertical Enclosures," Oak Ridge National Lab., TN, August, 1982, 39pp.
- [30] De Gids, W.F., "Influence of Different Parameters in Infiltration Heat Loss," *Proceedings of the 2nd AIC Conference on Building Design for Minimum Air Infiltration*, Stockholm, Sweden, 1981, pp. 73-96.
- [31] Michell, D. and Biggs, K.L., "Energy Savings Through Reduced Air Infiltration in Houses," *Architectural Science Review*, vol. 27, no. 1, 1984.
- [32] Heidt, F.D., Haberda, F. and Trepte, L., "Impact of Air Infiltration and Ventilation on Energy Losses of Buildings," *Proceedings of International Congress on Building Energy Management*, Povo de Varzim, Italy, 1980, pp. 201-214.
- [33] Nantka, M.B., "Air Infiltration and Ventilation in Relation to the Thermal Performance of Dwelling Houses in Poland," *Building Service Engineering Research Technology*, vol. 7, no. 1, 1986, pp. 11-18.
- [34] Persily, A., "Evaluation of an Air-to-Air Heat Exchanger," *Environment International*, vol. 8, 1982, pp. 453-459.
- [35] Nagda, N.L., Koontz, M.D. and Rector, H.E., "Energy Use, Infiltration, and Indoor Air Quality in Tight, Well-Insulated Residences," EPRI Report EA/EM-4117, Electric Power Research Institute, Palo Alto, CA, June, 1985.
- [36] Lecompte, Jan G.N., "The Influence of Natural Convection in an Insulated Cavity on the Thermal Performance of a Wall," *Insulation Materials*,

Testing, and Applications, ASTM STP 1030, American Society for Testing and Materials, Philadelphia, PA, 1990, pp. 397-420.

- [37] Wolf, S., "A Theory for the Effects of Convective Air Flow through Fibrous Thermal Insulation," *ASHRAE Transactions*, vol. 72, part 2, 1966, pp. III 2.1-III 2.9.
- [38] Wolf, S., Solvason, K.R. and Wilson, A.G. "Convective Air Flow Effects with Mineral Wool Insulation in Wood-Frame Walls," *ASHRAE Transactions*, vol. 72, part 2, 1966, pp. III 3.1-III 3.8.
- [39] Bankvall, C., "Heat Transfer in Fibrous Materials," *Journal of Testing and Evaluation*, vol. 1, no. 3, 1973, pp. 235-243.
- [40] Burns, P.J., Chow, L.C. and Tien, C.L., "Convection in a Vertical Slot Filled with Porous Insulation," *International Journal of Heat and Mass Transfer*, vol. 20, 1977, pp. 919-926.
- [41] "Standard Test Method for Thermal Performance of Building Assemblies by means of a Calibrated Hot Box," ASTM C976-82, *American Society for Testing and Materials*, Philadelphia, PA, 1982, 15 pp.
- [42] "Standard Test Method for Determining Air Leakage Rate by Fan Pressurization," ASTM E779-87, *American Society for Testing and Materials*, Philadelphia, PA, 1987, 6 pp.
- [43] Charlesworth, P.S., "Air Exchange Rate and Air Tightness Measurement Techniques - an Application Guide," *Air Infiltration and Ventilation Centre*, Berkshire, England, 1988.
- [44] Kiel, D.E., Wilson, D.J. and Sherman, M.H., "Air Leakage Flow Correlations for Varying House Construction Types," *ASHRAE Transactions*, vol. 91, part 2, 1985, pp. 560-575.
- [45] Kline, S.J. and McClintock, F.A., "Describing Uncertainties in Single-sample Experiments," *Mechanical Engineering*, January 1953, pp. 3-7.

APPENDIX A

A precise method of estimating uncertainty in experimental results is available in the literature [45]. The procedure is based on a careful specification of the uncertainties in the various primary variables that have been measured during the tests. Our dependent variable is the Infiltration Heat Exchange Effectiveness, ϵ , and the primary variables are the various temperatures, the flow rate and the heating power input.

The energy loss model which adequately describes the heat transfer from the hot-space to the ambient and to the cold space by paths outside the experimental sample (stud-cavity) is given by:

$$Q_{loss} = 1.0249(T_h - T_c) + 2.3075(T_h - T_a) \quad (A.1)$$

where Q_{loss} is in Btu/hr and T_h and T_c are the hot and cold space temperatures in deg C. The base (UA) value (i.e. at zero flow rate) of the stud-cavity wall specimen is then given by:

$$(UA)_0 = \frac{(Q_{in} - Q_{loss})}{(T_h - T_c)} \quad (A.2)$$

where Q_{in} is the total power input, which is the sum of the heater power and the fan power. The base case UA represents the steady-state conductive heat loss coefficient of the stud-cavity. For the base case, $UA = 0.8698$ Btu/hr-sq.ft.-deg F. The value of ϵ is calculated from the measured base case UA value and the injected flow rate $\dot{m}$ as:

TABLE A-1. Measurement Accuracy of Different Variables

Variable	Unit	Absolute Uncertainty	Relative Uncertainty
T_h	deg C	± 0.5	± 0.2
T_c	deg C	± 0.5	± 0.2
T_i	deg C	± 0.5	± 0.2
T_a	deg C	± 0.5	± 0.2
Q_{in}	Watt	± 0.203	± 0.203
$\dot{m}$	SLPM	± 0.3	± 0.3
ϵ (@ 4 SLPM)		± 0.232	± 0.0302
ϵ (@ 10 SLPM)		± 0.093	± 0.0122

$$\epsilon = 1 - \frac{Q_{in} - Q_{loss} - (T_h - T_c)(UA)_0}{(T_h - T_i)(UA)_{inf}} \quad (A.3)$$

The numerator of the fraction represents the measured infiltration UA value, while the term $(UA)_{inf} = \dot{m}C_p$ is the infiltration loss coefficient as usually calculated and T_i is the air inlet temperature in deg C.

Let w_ϵ be the uncertainty in the result and w_T , w_Q and $w_{\dot{m}}$ be the uncertainties in the temperatures, heating power input and air flow rate respectively. Then the uncertainty in ϵ is given by :

$$w_\epsilon = \left[\left(\frac{\partial \epsilon}{\partial T_h} w_T \right)^2 + \left(\frac{\partial \epsilon}{\partial T_c} w_T \right)^2 + \left(\frac{\partial \epsilon}{\partial T_i} w_T \right)^2 + \left(\frac{\partial \epsilon}{\partial T_a} w_T \right)^2 + \left(\frac{\partial \epsilon}{\partial Q_{in}} w_Q \right)^2 + \left(\frac{\partial \epsilon}{\partial \dot{m}} w_{\dot{m}} \right)^2 \right]^{1/2} \quad (A.4)$$

The individual measurement accuracy of the different parameters is tabu-

TABLE A-2. Sensitivity of Different Variables

Sensitivity Derivative	(@4 SLPM)	(@10 SLPM)
$\frac{\partial \epsilon}{\partial T_a}$	0.1315	0.031
$\frac{\partial \epsilon}{\partial T_c}$	0.2406	0.096
$\frac{\partial \epsilon}{\partial T_i}$	0.0096	0.026
$\frac{\partial \epsilon}{\partial T_o}$	0.3684	0.147
$\frac{\partial \epsilon}{\partial Q_{in}}$	0.1485	0.060
$\frac{\partial \epsilon}{\partial m}$	0.0590	0.063

lated in Table A-1 and it can be observed that the uncertainty of IHEE increases quite drastically at low flow rates. Absolute uncertainty is the maximum error specified in the manufacturers' specifications for the various measuring devices. For the thermocouples, calibration tests indicated a lower relative uncertainty and thus a relative uncertainty of 0.2 for all the thermocouples was assumed. For power and flow rate measuring devices, the relative uncertainty was assumed to be the same as the absolute uncertainty. The sensitivity of different variables is listed in Table A-2 and ambient temperature seems to have the most influence on IHEE.

APPENDIX B

Some of the 3-dimensional temperature distribution plots were presented in Chapter VII; the rest of them are shown in this Appendix.

Configuration A 4 SLPM

Configuration A 8 SLPM

Configuration A 10 SLPM

Configuration B 4.5 SLPM

Configuration B 8 SLPM

Configuration B 10 SLPM

Configuration C 5 SLPM

Configuration C 7 SLPM

Configuration C 9 SLPM

Configuration D 4.5 SLPM

Configuration D 7 SLPM

Configuration D 10 SLPM

Configuration D 12.5 SLPM

Configuration E 4.5 SLPM

Configuration E 6.5 SLPM

Configuration E 8.5 SLPM

APPENDIX C

Raw data measured in the steady-state stud-cavity experiments is presented in this appendix. Each block of data is presented for a particular test corresponding to a specific configuration and a specific flow rate, as mentioned at the top of the block. Each block of data is shown as a matrix consisting of 5 rows (A through E) and 20 columns. All temperatures are given in degree Celsius.

A1 through D15 are the temperatures measured by the thermocouples located inside the stud-cavity. A1 through A5, A6 through A10 and A11 through A15 correspond to the temperatures measured by thermocouples at locations A1, B1 and C1 in Figure 8. Similarly A16 through A20, B1 through B5 and B6 through B10 correspond to the temperatures measured by the thermocouples at locations A2, B2 and C2 in Figure 8. The rest of the temperatures are similarly shown.

D16 through E3 represent the temperatures measured at 8 locations in the cold space and E4 through E11 represent the temperatures measured at 8 locations in the hot space. E12 represents the pressure difference between the stud-cavity interior and the hot/cold space in Pascal. E13, E14, E15 and E16 correspond to the ambient temperature, air inlet temperature, chilled water temperature and air exit temperature respectively. E18, E19 and E20 represent the hot space fan voltage (in Volts), fan current (in Amperes) and fan power (in Watts) respectively.

Zero Flow																				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
A	20.8	18.5	11.5	7.8	4.9	20.8	18.1	10.8	6.5	4.4	20.8	17.9	10.9	6.6	4.5	20.9	17.5	11.4	8.3	4.1
B	22	19.6	12.9	9	3.5	21.9	19.7	13.9	9.1	3.4	21.8	19.6	13.6	6.5	3.5	22.7	17.3	12.4	7.6	3.5
C	22.2	19.4	13	7.3	4.5	20.9	18.9	11.8	8.3	3.6	21.3	18.7	11.5	6.4	3.4	20.8	18.5	11.8	7.5	3.6
D	21	18.5	13.2	9.1	6	20.9	18.5	12.2	7.6	4.8	20.9	17.7	12.6	8.5	5.4	1.1	0.9	0.9	0.7	1.4
E	1.4	1.5	1.4	25.4	25.5	25.5	25.5	25.4	25.5	25.5	25.5	9.188	24.9	1	-3.8	23.2	10.5	0.483	5.077	

13.1 SLPN CONFIG A																				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
A	18.8	16.3	9.8	6.6	3.8	16.3	12.7	5.1	2.9	2.1	12.5	6.5	1.5	1.2	1.3	18.5	15.3	12.1	9.3	4.7
B	22.6	20.3	13.3	9.3	3.6	20.3	17.8	11.6	7.7	3.1	22	19.5	12.8	6.1	3.3	23.2	17.9	12.9	7.9	3.7
C	22.5	19.9	13.7	8	4.8	19.6	17.3	10.5	7.4	3.3	21.2	18.5	11.2	6.2	3.2	20.4	18.1	11.6	7.8	4
D	19.4	15.9	10.3	7.5	5.1	19.5	16.3	9.7	6	4	20.4	16.3	11.2	7.6	4.8	1.2	0.9	0.9	0.8	1.5
E	1.4	1.6	1.3	25.5	25.7	25.6	25.6	25.6	25.6	25.7	25.8	59.39	25.2	1	-3.9	23.3	10.47	0.482	5.052	

11 SLPN CONFIG A																				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
A	19	16.6	10	6.7	3.9	16.9	13.3	5.8	3.1	2.2	13.2	7.2	1.6	1.2	1.2	18.6	15.4	11.9	9	4.6
B	22.4	20.1	13.2	9.2	3.6	20.7	18.3	12.2	8.1	3.2	21.9	19.5	12.9	6.1	3.4	22.9	17.8	12.7	7.9	3.6
C	22.4	19.7	13.5	7.9	4.8	19.7	17.4	10.6	7.5	3.3	21.2	18.4	11.2	6.1	3.1	20.4	18.1	11.6	7.8	3.8
D	19.5	16.3	10.8	7.6	5.2	19.6	16.6	10.1	6.2	4.1	20.3	16.4	11.3	7.6	4.9	1.1	0.8	0.9	0.7	1.4
E	1.4	1.4	1.3	25.4	25.5	25.4	25.4	25.4	25.4	25.5	25.5	47.93	25	1	-3.9	23.2	10.51	0.479	5.032	

10 SLPN CONFIG A																				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
A	19.4	16.9	10.2	6.8	4	17.4	13.8	6.2	3.5	2.4	13.7	7.8	1.8	1.4	1.3	18.8	15.5	11.9	8.9	4.5
B	22.3	19.9	13.2	9.2	3.5	20.8	18.5	12.4	8.2	3.2	21.9	19.5	12.9	6.1	3.3	22.8	17.5	12.6	7.7	3.7
C	22.3	19.7	13.5	7.8	4.7	19.9	17.6	10.6	7.4	3.3	21.1	18.4	11.2	6.1	3.2	20.5	18.1	11.6	7.7	3.8
D	19.6	16.6	10.9	7.8	5.2	19.8	16.7	10.2	6.3	4.1	20.4	16.5	11.3	7.6	4.8	1.1	0.8	0.9	0.7	1.3
E	1.2	1.3	1.2	25.2	25.4	25.3	25.4	25.3	25.4	25.4	25.4	41.79	24.8	0.9	-3.9	23.1	10.49	0.483	5.071	

8 SLPM CONEFG B																				
	19.9	17.3	10.4	6.9	4	18.3	14.9	7.2	3.9	2.5	14.9	9.2	2.4	1.7	1.4	19.3	15.8	11.5	8.6	4.3
A	19.9	17.3	10.4	6.9	4	18.3	14.9	7.2	3.9	2.5	14.9	9.2	2.4	1.7	1.4	19.3	15.8	11.5	8.6	4.3
B	22.3	19.9	13	9.2	3.5	21.3	19	12.9	8.4	3.2	21.8	19.5	13	6.1	3.4	22.9	17.6	12.6	7.6	4
C	22.4	19.8	13.4	7.6	4.7	20.2	18.2	11.1	7.9	3.5	21.3	18.6	11.4	6.3	3.3	20.6	18.2	11.4	7.4	3.6
D	20.9	18.6	13.1	9.1	6	20.9	18.2	11.5	7.2	4.6	20	15.4	10.2	6.9	4.6	1.1	0.8	0.9	0.7	1.4
E	1.4	1.4	1.3	25.3	25.5	25.4	25.6	25.5	25.5	25.6	25.6	31.9	25.1	0.9	-4.7	23.1	10.43	0.692	5.132	

10 SLPM COMFIC B																				
A	19.5	16.8	9.9	6.4	3.6	17.4	13.8	6.1	3.2	2.1	13.6	7.7	1.7	1.3	1.1	18.7	15.4	11.6	8.7	4.3
B	22.2	19.8	12.9	9	3.2	20.5	18.2	12.1	7.9	2.8	21.7	19.3	12.6	5.8	3	22.7	17.4	12.4	7.5	4
C	22.3	19.6	13.3	7.6	4.5	19.9	17.8	10.8	7.6	3.1	21	18.3	11.1	6	2.9	20.3	17.9	11.1	7.1	3.4
D	20.7	18.3	12.7	8.8	5.7	20.6	17.8	11.1	6.8	4.2	19.7	14.6	9.4	6.2	4	0.8	0.5	0.6	0.5	1.2
E	1.2	1.3	1.2	25.3	25.5	25.5	25.6	25.4	25.5	25.6	25.6	42.43	25	0.8	-4.6	23.4	10.65	0.489	5.107	

12 SLPM CONFIG B																			
A	19	16.5	9.8	6.4	3.6	16.7	13.2	5.5	2.9	2	12.7	6.8	1.5	1.3	18.5	15.2	11.9	9	4.6
B	22.3	20	13.1	9.2	3.5	20.3	17.9	11.7	7.7	3	21.9	19.4	12.7	5.9	3.2	23	17.7	12.7	7.8
C	22.5	19.8	13.7	7.9	4.8	19.8	17.7	10.9	7.7	3.4	21.2	18.4	11.3	6.2	3.2	20.4	18	11.2	7.4
D	20.7	18.3	12.8	8.9	5.9	20.6	17.8	10.9	6.7	4.3	19.5	14.1	9	6.1	4.1	1	0.8	0.9	0.6
E	1.4	1.3	1.3	25.3	25.5	25.5	25.5	25.4	25.4	25.5	25.6	53.16	25	0.9	-4.4	23.1	10.46	0.498	5.1

13 SLPM CONFIG C																				
A	19.1	16.5	9.8	6.4	3.6	16.5	12.8	5.2	2.8	2	12.6	6.6	1.4	1.2	1.3	18.4	15.3	12	9.2	4.7
B	22.6	20.2	13.3	9.2	3.6	20.2	17.8	11.5	7.7	3.1	21	18.7	13.8	7	3.7	21.6	13.6	9	5.1	4.8
C	23	21.1	15.1	9.4	5.8	21.6	19.9	12.9	9.1	3.9	21.7	19.1	12	6.7	3.5	21.1	18.7	11.7	7.4	3.6
D	21.9	19.6	14.1	9.8	6.4	21.8	19.5	13	8.2	5.1	21.8	18.5	13.2	8.9	5.4	1.2	0.8	0.9	0.7	1.4
E	1.4	1.4	1.4	25.5	25.6	25.5	25.7	25.5	25.6	25.6	25.8	64.43	24.8	1	-4.4	23.6	10.47	0.483	5.05	

11 SUPM CONFIG C																				
A	19.5	16.9	10	6.6	3.8	17.2	13.6	5.8	3.1	2.1	13.3	7.3	1.6	1.2	1.1	18.7	15.4	11.9	9	4.5
B	22.5	20.1	13.1	9.2	3.5	20.7	18.2	12.1	7.9	3.1	21.1	18.8	13.8	6.8	3.6	21.5	13.6	9.1	5.1	4.6
C	22.8	20.8	14.8	8.9	5.4	21.4	19.7	12.6	8.9	3.7	21.5	19	11.7	6.6	3.3	20.9	18.5	11.5	7.2	3.4
D	21.8	19.5	14	9.7	6.3	21.6	19.4	12.9	7.9	4.9	21.7	18.4	13	8.7	5.3	1	9.7	0.8	0.5	1.2
E	1.2	1.2	1.2	25.3	25.4	25.4	25.5	25.3	25.5	25.6	25.6	53.47	24.9	0.9	-4.5	23	10.47	0.482	5.847	

9 SUPM CONFIG C																				
A	20	17.4	10.4	7	4	18.1	14.1	6.7	3.6	2.4	14.3	8.5	2.1	1.6	1.3	19	15.7	11.7	9.8	4.4
B	22.3	19.9	13.1	9.2	3.5	21.1	18.8	12.7	8.3	3.2	21.2	19	13.8	6.8	3.6	21.6	13.7	9.2	5.3	4.3
C	23	20.9	14.6	8.8	5.3	21.5	19.7	12.7	9	3.8	21.3	19	11.8	6.6	3.4	20.9	18.6	11.6	7.2	3.5
D	21.8	19.5	13.9	9.7	6.3	21.6	19.4	12.9	8	5.1	21.6	18.3	13	8.7	5.3	1.1	0.7	0.8	0.7	1.2
E	1.3	1.2	1.2	25.3	25.4	25.3	25.5	25.4	25.5	25.5	25.5	42.23	24.9	0.8	-4.6	23.3	10.47	0.481	5.036	

7 SUPM CONFIG C																				
A	20.4	17.8	10.8	7.1	4.2	18.9	15.55	7.8	4.1	2.8	15.6	10	2.7	1.8	1.4	19.6	16	11.5	8.5	4.3
B	22.4	19.9	13.1	9.1	3.5	21.5	19.3	13.3	8.6	3.2	21.5	19.2	13.9	6.8	3.6	21.7	14.1	9.4	5.4	4.3
C	22.9	20.6	14.3	8.3	5	21.3	19.6	12.5	8.8	3.7	21.5	18.9	11.7	6.4	3.3	20.9	18.5	11.5	7.2	3.3
D	21.7	19.4	13.9	9.7	6.2	21.6	19.3	12.8	7.9	4.9	21.5	18.3	13	8.6	5.3	0.9	0.7	0.8	0.5	1.3
E	1.2	1.2	1.2	25.4	25.6	25.5	25.6	25.5	25.5	25.6	25.6	31.68	25.1	0.8	-4.4	23.3	10.49	0.484	5.077	

5 SUPM CONFIG C																				
A	20.8	18.1	11.1	7.4	4.5	19.7	16.3	8.9	4.9	3.3	16.8	11.6	3.8	2.5	1.7	20	16.4	11.4	8.5	4.2
B	22.2	19.8	13	9.1	3.4	21.8	19.6	13.6	8.9	3.3	21.5	19.3	13.9	6.7	3.6	21.8	14.3	9.6	5.6	4.2
C	22.8	20.5	14.1	8.2	4.9	21.3	19.6	12.6	8.9	3.8	21.4	18.9	11.7	6.5	3.4	20.8	18.5	11.6	7.2	3.4
D	21.8	19.5	14	9.7	6.3	21.6	19.3	12.9	8	5	21.6	18.3	13	8.6	5.4	1	0.7	0.8	0.7	1.3
E	1.2	1.2	1.2	25.3	25.5	25.4	25.5	25.5	25.5	25.6	25.6	23.83	25.1	0.9	-4.5	23.1	10.47	0.479	5.017	

17.5 SLPM CONFIG D																				
A	17.3	14.7	8.6	5.7	3.2	14.3	10.75	3.7	2	1.6	10.7	4.9	1.1	1	1.1	17.5	14.6	11.9	9.2	4.8
B	22.4	20	12.8	8.9	3.3	19	16.2	10.2	6.8	2.9	21.4	19	12.3	5.8	3.1	22.4	15.9	11.1	6.7	4.2
C	22.4	20.1	14.1	8.4	5	19.5	17.4	10.6	7.5	3.3	21.1	18.4	11.2	6.1	3	20.1	17.7	11.2	7.5	3.8
D	19.7	16.9	11.3	8	5.4	19.2	16.2	9.6	6	3.9	18.9	14.1	9.3	6.2	4.1	1	0.7	0.8	0.7	1.3
E	1.2	1.3	1.2	25.2	25.4	25.3	25.5	25.4	25.4	25.5	25.6	66.3	24.7	0.9	-4.6	23.3	10.47	0.482	5.045	

15 SLPM CONFIG D																				
A	18.1	15.5	9.1	6	3.3	15.2	11.7	4.3	2.3	1.7	11.6	5.7	1.3	1.1	1.1	18	14.9	12	9.2	4.7
B	22.4	20	13	9	3.4	19.6	17	10.9	7.3	3	21.6	19	12.5	5.8	3.2	22.4	16	11.2	6.7	4.2
C	22.5	20.2	14	8.3	5	19.9	17.6	10.7	7.6	3.3	21.1	18.4	11.2	6.1	3	20.3	17.9	11.3	7.5	3.7
D	20.1	17.2	11.6	8.3	5.6	19.5	16.6	10	6.2	4	19.4	14.7	9.6	6.4	4.2	0.9	0.7	0.8	0.6	1.3
E	1.2	1.3	1.2	25.3	25.5	25.4	25.6	25.4	25.6	25.5	25.6	52.92	24.8	0.9	-4.5	23.5	10.49	0.486	5.094	

12.5 SLPM CONFIG D																				
A	18.7	16	9.4	6.1	3.4	16	12.5	4.9	2.5	1.7	12.4	6.4	1.3	1	1	18.3	15.1	11.8	9	4.5
B	22.5	20.1	13.1	9.1	3.4	20.2	17.7	11.5	7.6	3.1	21.7	19.2	12.7	6	3.2	22.5	16.1	11.2	6.6	3.9
C	22.6	20.1	13.9	8.1	4.8	20	17.8	10.8	7.6	3.1	21.2	18.5	11.1	6	3	20.4	18.1	11.4	7.5	3.7
D	20.3	17.6	12	8.5	5.7	20	17.2	10.5	6.5	4.2	19.8	15.4	10.2	6.8	4.4	0.9	0.8	0.8	0.7	1.2
E	1.2	1.2	1.1	25.4	25.5	25.5	25.6	25.4	25.6	25.6	25.6	42.46	24.9	0.9	-4.3	23	10.49	0.486	5.099	

7 SLPM CONFIG D																				
A	20.1	17.5	10.5	7	4	18.5	13.2	7.5	4	2.6	15.3	9.8	2.7	1.9	1.5	19.6	16.1	11.6	8.6	4.2
B	22.4	20	13	9.2	3.4	21.6	19.3	13.1	8.6	3.2	21.7	19.4	13.1	6.2	3.2	22.4	16.1	11.3	6.7	4.1
C	22.6	20	13.6	7.7	4.6	20.5	18.4	11.3	7.9	3.4	21.3	18.7	11.4	6.2	3.1	20.7	18.4	11.6	7.5	3.7
D	20.9	18.5	12.9	9	6	20.7	18.1	11.5	7.1	4.5	20.5	16.5	11.3	7.5	4.7	0.9	0.7	0.7	0.7	1.3
E	1.2	1.3	1.1	25.3	25.6	25.5	25.6	25.5	25.6	25.7	25.7	20.64	25.1	0.8	-4.4	23.4	10.46	0.485	5.074	

	10 SLEPM CONFIG D																				
A	19.3	16.7	10	6.5	3.7	17.1	13.6	6	3.1	2.1	13.5	7.7	1.7	1.3	1.3	18.8	15.5	11.9	8.8	4.4	
B	22.3	20	13.1	9.1	3.4	20.7	18.3	12.2	8	3.2	21.6	19.2	12.9	6	3.2	22.4	16	11.2	6.7	4	
C	22.8	20.2	13.8	8.1	4.9	20.3	18.1	11.1	7.9	3.5	21.3	18.6	11.4	6.3	3.2	20.6	18.3	11.6	7.6	3.8	
D	20.6	18.1	12.4	8.7	5.9	20.3	17.6	10.9	6.8	4.4	20.1	15.9	10.7	7.1	4.6	0.9	0.8	0.8	0.7	1.2	
E	1.2	1.2	1.2	25.3	25.5	25.4	25.5	25.4	25.5	25.6	25.6	31.57	24.9	0.9	-4.2	23.4	10.46	0.485	5.077		

	4.5 SLPM										CONFIG D									
A	20.5	17.9	10.9	7.3	4.4	19.5	16.3	8.8	4.8	3.1	16.9	11.9	4	2.6	1.8	20.1	16.6	11.3	8.4	4.2
B	22.2	19.8	13	9.1	3.4	21.8	19.6	13.7	8.9	3.4	21.8	19.5	13.4	6.3	3.4	22.5	16.4	11.5	6.9	4
C	22.5	19.8	13.4	7.5	4.6	20.7	18.8	11.6	8.2	3.5	21.4	18.7	11.5	6.3	3.2	20.8	18.5	11.7	7.5	3.7
D	21.1	18.8	13.2	9.4	6.2	20.9	18.5	12	7.5	4.8	20.8	17.1	11.9	7.9	5	0.9	0.8	0.8	0.6	1.3
E	1.3	1.3	1.2	25.3	25.5	25.4	25.5	25.4	25.5	25.5	25.6	13.76	25.1	0.9	-4.2	22.9	10.47	0.481	5.036	

13 SEPIM COMET E																				
A	20.2	17.1	9.5	6.4	3.8	17.4	13.5	5.2	2.6	1.7	14.3	7.7	1.3	1	0.9	22.1	19	12.3	8.7	4.1
B	22.1	19.7	13.1	9.2	3.4	21.9	19.8	13.9	9.1	3.2	21.8	19.8	13.9	6.8	3.5	22.8	17.4	12.4	7.4	3.9
C	22.2	19.4	12.9	7.1	4.2	21.2	19.4	12.3	8.7	3.5	21.5	18.9	11.7	6.5	3.2	20.9	18.6	11.6	7.3	3.5
D	21.6	19.4	13.8	9.5	6.1	21.6	19.5	13	8.1	5	21.8	18.5	13.1	8.8	5.4	0.9	0.7	0.9	0.6	1.3
E	1.2	1.3	1.1	25.5	25.5	25.6	25.5	25.5	25.5	25.6	25.6	66.98	24.9	0.6	-4.4	22.8	10.47	0.488	5.106	

	10.5 SLPH				COMETIG E															
A	20.4	17.4	9.9	6.6	4	17.9	14.2	6	3	2	14.8	8.5	1.5	1.2	1	21.9	18.9	12.3	8.6	4
B	22.1	19.6	13	9.2	3.5	21.9	19.8	13.9	9	3.2	21.7	19.7	13.9	6.7	3.4	22.8	17.4	12.3	7.4	3.8
C	22.3	19.4	12.9	7.1	4.2	21.2	19.5	12.4	8.8	3.5	21.5	18.9	11.7	6.6	3.2	20.8	18.7	11.7	7.4	3.4
D	21.5	19.2	13.7	9.5	6	21.5	19.3	12.8	8	4.9	21.6	18.4	13.1	8.7	5.2	0.8	0.6	0.7	0.6	1.3
E	1.2	1.3	1.2	25.5	25.6	25.6	25.5	25.5	25.5	25.6	25.5	51.64	25	0.7	-4.4	22.7	10.48	0.485	5.079	

6.5 SLPM CONFIG E																				
A	20.7	17.9	10.6	7.1	4.3	19.2	15.6	7.5	4	2.5	16	10.2	2.4	1.6	1.2	22	18.9	12.2	8.6	4
B	22.1	19.7	13	9.2	3.5	22	19.9	14.1	9.1	3.2	21.9	19.7	13.9	6.7	3.5	22.8	17.4	12.4	7.5	4
C	22.2	19.4	12.9	7.1	4.2	21.3	19.4	12.3	8.8	3.5	21.5	18.9	11.6	6.4	3.3	21	18.7	11.7	7.2	3.4
D	21.6	19.3	13.8	9.5	6	21.7	19.4	12.9	8.1	4.9	21.7	18.5	13.1	8.8	5.3	0.9	0.7	0.8	0.5	1.2
E	1.1	1.2	1.1	25.4	25.5	25.5	25.5	25.4	25.5	25.5	25.5	29.15	25	0.5	-4.5	22.8	10.47	0.484	5.068	

4.5 SLPM CONFIG E																				
A	20.8	18.1	10.7	7.3	4.5	19.6	16.3	8.3	4.4	2.8	16.7	11.3	3.1	2	1.3	21.9	18.8	12.2	8.5	4
B	22	19.5	13	9.2	3.4	21.9	19.8	14	9.1	3.2	21.7	19.6	13.8	6.6	3.4	22.7	17.3	12.2	7.3	3.9
C	22.1	19.3	12.8	7.1	4.2	21.1	19.4	12.3	8.7	3.5	21.4	18.8	11.6	6.4	3.2	20.8	18.5	11.5	7.1	3.3
D	21.5	19.2	13.7	9.4	6	21.5	19.3	12.8	8	4.9	21.5	18.3	13	8.7	5.3	0.9	0.6	0.8	0.5	1.2
E	1.1	1.1	1.1	25.4	25.5	25.4	25.5	25.4	25.5	25.5	25.5	20.21	25	0.6	-4.5	22.4	10.46	0.484	5.067	

8.5 SLPM CONFIG E																				
A	20.5	17.5	10	6.8	4.1	18.4	14.8	6.7	3.3	2.1	15.1	9.2	1.7	1.2	1	21.8	18.7	12.1	8.4	4.1
B	22	19.6	13	9.2	3.4	21.9	19.7	13.9	9.1	3.2	21.8	19.7	13.8	6.7	3.4	22.8	17.4	12.3	7.4	3.8
C	22.1	19.3	12.6	7	4.1	21.1	19.3	12.2	8.6	3.4	21.4	18.8	11.6	6.3	3.1	20.8	18.6	11.5	7.3	3.4
D	21.6	19.4	13.9	9.6	6.1	21.6	19.4	12.8	8	4.9	21.7	18.3	13	8.7	5.3	1	0.6	0.9	0.6	1.2
E	1.1	1.2	1.1	25.4	25.5	25.4	25.4	25.4	25.5	25.5	25.5	39.27	24.9	0.6	-4.3	23.4	10.49	0.487	5.109	

VITA

Souvik Bhattacharyya was born and brought up in Calcutta, India. His parents are the late Sallendranath Bhattacharyya and Mrs. Pratima Bhattacharyya. He attended Hare School, Calcutta, India from 1970 to 1976 and was awarded Government of India National Merit Scholarships on graduation. He graduated with honors from Jadavpur University, Calcutta, India with a Bachelor of Mechanical Engineering degree in August, 1981. For the next two years he worked as a design engineer with a premier consulting engineering firm in the power and process industry. He obtained a Master of Science in Mechanical Engineering from the University of Cincinnati, Cincinnati, Ohio in December, 1985. The area of specialization was thermal sciences. At Texas A&M University, in the Mechanical Engineering Department, he worked with Professor David E. Claridge as part of the Energy Systems Laboratory and obtained a Doctor of Philosophy in Mechanical Engineering in May, 1991.

His permanent mailing address is:

Souvik Bhattacharyya
12, Chaul Patty Road
Calcutta 700010, India.

END

**DATE
FILMED**

9 / 4 / 92