PNL--8330

DE93 000841

PACIFIC NORTHWEST LABORATORY FY 1993 SITE MAINTENANCE PLAN

For Maintenance of DOE Nonnuclear Facilities

September 28, 1992

Approved for Use and Application by:

**T.D. Chikalla, Director
Facilities and Operations**

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

for

TABLE OF CONTENTS

1.0	Executive Summary	1
2.0	Background	2
2.1	Significant Accomplishments During FY 1992	2
2.2	Initiatives Planned During FY 1993	4
2.3	Facility Deficiencies	5
2.4	Identification of Structures, Systems and Components included within the Maintenance Program	6
3.0	Graded Approach Strategy	6
3.1	Overall Strategy and Basis	6
3.2	Strategy for Safety-Related Items	6
4.0	DOE Order 4330.4A Chapter I Requirements	7
4.1	Organization, Administration, and Training	7
4.1.1	Organization/Staffing	7
4.1.2	Administration	12
4.1.3	Policies, Goals, and Objectives.....	16
4.1.4	Training and Qualification	18
4.2	Condition of Facilities and Equipment	23
4.2.1	Facility Condition Inspections	23
4.2.2	Condition Assessment Surveys	26
4.3	Maintenance Documentation	29
4.3.1	Site Maintenance Plan	29
4.4	Work Control System	31
4.4.1	Work Request System	31
4.4.2	Formal Job Planning and Estimating	34
4.4.3	Work Performance (Time) Standards	37

4.4.4	Priority System	38
4.4.5	Maintenance Procedures and Other Work-Related Documents	39
4.4.6	Scheduling System	43
4.4.7	Post-Maintenance Testing	45
4.4.8	Backlog Work Control	48
4.4.9	Equipment Repair History and Vendor Information	50
4.5	Maintenance Facilities, Equipment and Materials Control System	51
4.5.1	Maintenance Facilities, Equipment, and Tools	51
4.5.2	Requisitioning/Procurement	53
4.5.3	Materials Control	56
4.5.4	Control and Calibration of Measuring and Test Equipment	60
4.5.5	Maintenance Tools and Equipment Control	63
4.6	Implementation of Maintenance Activities	64
4.6.1	Surveillance and Preventive Maintenance	64
4.6.2	Predictive Maintenance	68
4.6.3	Corrective (Repair) Maintenance	69
4.6.4	Modification Work (Non-Davis-Bacon)	70
4.7	Maintenance Evaluation and Analysis	72
4.7.1	Analysis of Root Causes of Problems	72
4.7.2	Periodic Review and Analysis	73
4.7.3	Performance Measurement and Improvement	75
4.7.4	Management Involvement	76
4.7.5	Work Sampling	79
4.7.6	Cost Identification and Control	79
4.7.7	Audits and Lessons Learned	80

4.8	Additional Maintenance Management Requirements	81
4.8.1	Self-Assessments	81
4.8.2	Seasonal Facility Preservation Requirements	82
4.8.3	Maintenance Standards and Workmanship Standards	83
4.8.4	Warranty/Guarantee Information	83
5.0	Deviations Requested with Supporting Rationale	84
6.0	Projected Budget and Backlog of Maintenance	85
6.1	Operating Expenses for Maintenance and Repair of Real Property	85
6.2	Types of Maintenance and Repair of Real Property	85
6.3	Maintenance and Repair for Asset Type Codes 670 and 680	85
6.4	Operating Expense Funded Maintenance of Equipment Other Than Real Property	86
6.5	Consolidated Summary of Estimates	86
6.6	Backlog of Maintenance and Repair	87
7.0	Implementation Schedule	92
PNL	Maintenance Program Risk Criteria	Exhibit 1
PNL	Maintenance Management Program Graded Approach	Exhibit 2

1.0 EXECUTIVE SUMMARY

This Site Maintenance Plan has been developed for Pacific Northwest Laboratory's (PNL) Nonnuclear Facilities. It is based on requirements specified by U.S. Department of Energy (DOE) Order 4330.4A, Chapter I, Change #4.

The objective of this maintenance plan is to provide baseline information for compliance to the DOE Order 4330.4A, to identify needed improvements, and to document the planned maintenance budget for Fiscal Year (FY) 1993 and to estimate maintenance budgets for FY 1994 and FY 1995 for all PNL facilities.

Using the results of the self-assessment, PNL has selected 12 of the 36 elements of the Maintenance Program defined by DOE Order 4330.4A, Chapter I, for improvement. The elements selected for improvement are: Facility Condition Inspections; Work Request (Order) System; Formal Job Planning and Estimating; Work Performance (Time) Standards; Priority System; Maintenance Procedures and Other Work-Related Documents; Scheduling System; Post Maintenance Testing; Backlog Work Control; Equipment Repair History and Vendor Information; Work Sampling; and Identification and Control.

Based upon a graded approach and current funding, those elements considered most important have been selected as goals for earliest compliance. Commitment dates for these elements have been established for compliance. The remaining elements of noncompliance will be targeted for implementation during later budget periods.

Section 2 of this plan provides a brief status of PNL facilities, lists FY 1992 significant accomplishments, lists initiatives planned during FY 1993, gives a summary of facility deficiencies and identifies the structures, systems and components included within the maintenance program.

Section 3 explains the graded approach strategy. This includes the overall strategy basis and the strategy for safety-related items.

Section 4 lists the maintenance program elements required by Chapter I of DOE Order 4330.4A. The objective and listed program element is taken directly from the Order. The discussion explains PNL's current practice and identifies all known areas that do not meet the intent of the Order. The improvements section under each maintenance program element lists only those items, using the graded approach, currently planned for improvement.

Section 6 is the FY 1993 maintenance budget and backlog of maintenance for all PNL facilities, including nuclear facilities. The section also contains the estimated maintenance budgets for FY 1994 and FY 1995.

Section 7 is the implementation schedule for those items, identified using the graded approach, currently planned for improvement. Action items reference the maintenance program elements contained in Section 4.

2.0 BACKGROUND

The average age of the significant DOE-owned facilities operated and maintained by PNL is 34 years. Two of these significant facilities are less than 25 years old. They are the Life Sciences Building (331), which is 22 years old and the Technical Management Center (337), which is 19 years old. Due to the age of the majority of DOE's facilities, there is a continuing need to replace and/or refurbish all or portions of their systems. At the present time there are pending needs for almost all facilities. To date, significant repair/replacement efforts for these systems have been overhead funded from annual Building and Utility (B&U) budgets.

The maintenance effort at PNL is performed by the Technical Services Department and the Facilities Management Department. In addition to performing facility maintenance and operations for PNL, these organizations provide technical support and maintenance services for Research and Development (R&D) equipment and provide various shop and field support services for the research staff. Utilities are provided to PNL's DOE facilities by Westinghouse Hanford Company (WHC), as are central fire protection services, security patrol services, vehicle maintenance services, most grounds services, heavy transportation services, general stores services, road and railroad maintenance, Standards Laboratory services, and other minor services.

2.1 Significant Accomplishments During FY 1992

- PNL has worked closely with both Kaiser Engineers Hanford (KEH) and WHC to develop and issue a common "Hanford Hoisting and Rigging Manual" and "Hanford Site Lock and Tag Standard." PNL also contributes as a member of the DOE HQ Hoisting and Rigging Manual Committee and the DOE HQ Electrical Committee and National Maintenance Forum.
- Developed and implemented a comprehensive Maintenance Self-Assessment Program.
- Painted exterior of the 326 Building.
- Ahead of schedule on Ground Fault Circuit Interrupters (GFCI) program and electrical panel labeling program.
- Tiger Team commitment to write Fire System Preventive Maintenance Standards completed one year ahead of schedule.
- Successfully completed two A-frame filter changes in the 324 Building without any spread of radioactive contamination and with minimum exposure to personnel.

- Implemented a comprehensive Freeze Protection Program.
- Replaced the 747A Building water line.
- Installed the 331 Building fan bypass circuit.
- Installed the 329 Building vacuum system HEPA.
- Completed the 331 Building process sewer modification.
- Replaced the 331 Building heat exchanger.
- Installed the 324 Building vacuum pump alarm.
- Completed the 325 Building sump discharge Modification.
- Completed the 325 Building hazardous waste catch tank modification.
- Completed the 329 Building C section modification.
- Completed the 318 Building process sewer modification.
- Completed the 325 Building room 400 modification.
- Met 300 Area Process Sewer (PS) flow reduction requirements.
- Completed the 324 Building trailer site preparation.
- Installed 327 Building sump pump controls.
- Completed the 3745B Building process sewer modification.
- Completed the 329 Building process sewer modification.
- Evaluated the 3720 Building damper operation.
- Relocated the 325 Building safety showers.
- Upgraded the 325 Building roof electrical circuits.
- Installed the 331G Building HEPA filter system.
- Completed the 326 Building HVAC electrical modification.
- Installed the 3745B Building emergency lighting.
- Installed the 326 Building room 12A HEPA filter.
- Installed the 325 Building P-10 gas system.
- Installed the 325 Building operator room fire sprinkler system.

- Implemented the 323 Building emergency power procedure.
- Installed the 331H Building eyewash station.
- Completed Phase I of D-380.

2.2 Initiatives Planned During FY 1993

PNL will continue implementing trend analysis, and a computerized maintenance management system during fiscal year 1993. PNL will continue to enhance the preventive maintenance program by expanding the integration of predictive maintenance. Initial results indicate there will be substantial cost savings associated with these efforts. PNL will continue to remove and replace asbestos insulation where there is danger of the fibers being released into the air. PNL has implemented a program of replacing electrical outlets within 5 feet of a sink with Ground Fault Circuit Interrupters (GFCI). This program is projected to take approximately 3 years to complete. PNL has also implemented a program of labeling electrical equipment and piping systems. Electrical labeling is a 6 year program expected to be completed at the end of FY 1996. The piping system labeling is a 5 year program expected to be completed at the end of FY 1994. PNL has conducted an in-depth inspection of PNL-assigned permanent buildings that are presently occupied, based on the National Fire Protection Association Electrical Code and the Hanford Electrical Standards. PNL plans to correct the deficiencies identified with existing budgets and by requesting funding from DOE through Activity Data Sheets (ADS).

Environment, safety and health corrective actions have a very high priority. PNL has documented these needs in a number of plans, including the PNL Institutional Plan the Environmental Restoration and Waste Management Five-Year Plan. These combined facilities improvement plans constitute a comprehensive facilities improvement plan which has been implemented to ensure proper prioritization of need and the proper evaluation and acceptance of risk which complement overall maintenance activities and are integrated with PNL's research mission and strategic facilities plans. It is consistent with (1) changing DOE guidance contained in Admiral Watkins' SEN-11-89 10-point initiative emphasizing commitment to compliance with operational, environmental, safety, health, and security standards in the accomplishment of production and research objectives, and (2) the significant role the Laboratory has in achieving research mission accomplishments for the Department of Energy and the nation.

Specifically, PNL facility improvement planning objectives are to:

- Ensure PNL facilities are operated and maintained in full compliance with all applicable laws and regulations.

- Plan for and provide safe and operable facilities to accommodate and support ongoing and new research activities.
- Operate and maintain facilities economically to provide for the safety and health of plant personnel, protect the public and environs, protect property, and support research needs.
- Concentrate scarce financial resources on strategically important facilities that support overall Laboratory initiatives.
- Link, integrate, and unify PNL's strategic/program plans with facility/site development plans and with specific design/construction projects.
- Improve the usage of existing space.
- Consolidate similar technical functions wherever appropriate.

The program and funding profile has been developed establishing a balance between high priority work and the realities of the current federal budget climate. The increased visibility of self-assessments, audits and surveillances and the resulting action plans to correct deficiencies, most notably the Tri-Party Agreement and the Tiger Team Reports, have been a key factor in developing facility improvement plans.

The Multiprogram Energy Laboratories--Facility Support Program will initiate an \$8.4 million project at the 326 Building in FY 1992. Most of the construction is scheduled during FY 1993. This project will improve the life safety egress provisions throughout the 326 Building to meet Life Safety Code requirements. Construction of the \$9.1 million 329 Building Compliance project which is in progress is scheduled for completion in FY 1994.

The total resources being expended on facility maintenance initiatives at PNL concentrate maintenance resources on strategically important facilities. PNL will continue efforts to reduce expenditures on marginal facilities as opportunities arise.

2.3 Facility Deficiencies

The current operating budgets are able to generally maintain the various building systems and components in their current condition of usable repair. However, surveys are revealing numerous deficiencies associated with environmental compliance and safety codes. Current operating budgets are not sufficient to correct these problems. Supplemental funding will be required to correct them. Also, current operating budgets do not provide funding of long range plans for system and component replacement. Until recently PNL's capital construction budget has been limited, therefore aged system

replacement, improvements for new program needs, and upgrades to meet current regulations were extremely hampered.

The established levels of operating budgets are not adequate to correct all the identified compliance violations and to maintain the various building systems and components in a state of usable repair. Supplemental budget resources are being pursued. There has been a consistent lack of funding for system and component replacement; most systems are kept in a state of usable repair far beyond their expected life. Problems that are not, generally, being met by the current operating budgets include items such as upgrades and modifications to meet current health, safety, and environment requirements, as well as federal and state laws, codes and regulations. Examples of other items that are not being met by the current operating budgets are mechanical piping systems including steam piping, condensate piping, compressed air, breathing air, water and drain piping; electrical system upgrades to overcome the effects of age and changes in facility use; and the upgrade of heating, ventilating and air conditioning systems including the replacement of evaporative cooling systems with mechanical refrigeration systems to satisfy the current usage.

2.4 Identification of Structures, Systems and Components included within the Maintenance Program

The Maintenance Program for the PNL Nonnuclear Facilities includes all facilities, systems, and equipment that are not defined as a nuclear facility. A graded approach, per DOE Order 4330.4A (see discussion below) will be used to implement those elements of the DOE Order 4330.4A with which PNL is not currently in full compliance.

3.0 Graded Approach Strategy

3.1 Overall Strategy and Basis

The PNL Maintenance "Graded Approach" is defined as the depth of detail required and the magnitude of resources expended for a particular maintenance management element. This is to be commensurate with the element's importance for safe and reliable operations, environmental compliance, safeguards and security, programmatic mission, facility preservation, and/or other facility-specific requirements.

3.2 Strategy for Safety-Related Items

PNL has initiated a graded approach based on a three tier, risk-based maintenance program as defined in the PNL Maintenance Program Risk Criteria (see Exhibit 1). PNL will develop a more integrated and uniform graded approach, taking into consideration the requirements of other DOE Orders such as 5700.6C "Quality Assurance," 5480.19 "Conduct of Operations," 5480.20 "Personnel Selection, Qualification, Training, and Staffing" and 4320.2 "Capital Asset

Management Process." Equipment on the master equipment list has been evaluated against the risk category criteria to determine its risk classification. The classification is either High Risk, Medium Risk or Low Risk. These classifications will determine the depth of detail required and the magnitude of resources expended for a particular maintenance management element necessary for safe and reliable operations, environmental compliance, safeguards and security, programmatic mission, facility preservation, and/or other facility-specific requirements (see Exhibit 2).

The elements of DOE Order 4330.4A will also be implemented using a graded approach. This graded approach will be based on impact to safe and reliable operations, environmental compliance, safeguards and security, programmatic mission, facility preservation, and/or other facility-specific requirements. Work will be accomplished by effectively using the available resources and budgets to correct deficiencies prioritized by the graded approach.

Initially the aspects of the existing maintenance program will be enhanced in those areas identified by self-assessment as not adequate to the intent of the Order. Once the program administrative controls and procedures are in place, attention will be directed to maintenance activities at the facility, system, and equipment level. Procedures delineating the guidance and responsibilities of the maintenance program that need to be revised have been identified. Emphasis will be placed on the completion of these revisions in order to ensure compliance with this plan.

4.0 DOE ORDER 4330.4A CHAPTER 1 REQUIREMENTS

4.1 Organization, Administration, and Training

4.1.1 Organization/Staffing

Objective: *A clearly defined maintenance organization with specific lines of authority, responsibility and accountability should be established. Requirements for communication and interface with other facility organizations should be determined. A sufficient number of properly trained management, supervision, and craft personnel should be utilized to perform the required maintenance activities.*

- a. *The maintenance organizational functions and responsibilities are defined thoroughly and an appropriate staff assigned to ensure effective and timely accomplishment of the required work and to prevent the potential for waste, fraud, and error.*

Discussion: Craft Services' maintenance organizational functions and responsibilities are defined in the "Craft Services Policies and Procedures" (P&P) manual. This manual is now being evaluated for compliance to DOE Order

4330.4A. The results of this Management Assessment will determine if any adjustment in the manual's contents will be necessary. Appropriate staff are currently assigned to maintain status quo of the maintenance program. However, additional staff may be needed to correct deficiencies and adjust for additional requirements contained in this Order.

- b. Engineering and technical support functions have direct and continuous interface with the maintenance organization in order to provide support in determining the cause of repetitive equipment failures and to investigate the root cause of unplanned events.*

Discussion: Engineers are assigned to Craft Services (the maintenance organization) on an as-needed basis. In addition, there are a number of maintenance specialists assigned to the Preventive/Predictive Maintenance Group and the Compliance and Training Group. These engineers and specialists work jointly to support maintenance functions within Craft Services. Also, Craft Services receives additional support and assistance from the entire Facilities Engineering Section, when requested.

- c. Engineering and technical support functions incorporate the following into all maintenance activities: manufacturers' recommendations, specifications for operability, action levels, acceptance criteria, procurement specifications, installation and test requirements, and test equipment and procedures.*

Discussion: When directly applicable, engineering and technical support functions incorporate the following into maintenance activities: manufacturers' recommendations, specifications for operability, action levels, acceptance criteria, procurement specifications, installation and test requirements, and test equipment and procedures.

- d. Engineering and technical support functions identify and evaluate potential degradation mechanisms caused by environment and service over time and provide direction for timely mitigation of their effects.*

Discussion: Craft Services stresses the importance of predictive maintenance and avoidance of costly breakdown repairs on offshift, weekends, and holidays. PNL's Preventive Maintenance (PM) Checklist Standards are written to measure and predict degradation caused by the environment and time.

- e. Contracted maintenance services are controlled and overseen to ensure that contracted work is performed to*

the same standard established for the maintenance organization.

Discussion: Facilities Engineering oversees contracted maintenance work to ensure it is performed to the same standard established for the maintenance organization.

- f. Contracted personnel are qualified for the work they are to perform.*

Discussion: Facilities Engineering ensures contracted personnel are qualified for the work they perform.

- g. The Quality Assurance (QA) and Quality Control (QC) Programs are applied to maintenance activities commensurate with their safety and security significance.*

Discussion: Craft Services interfaces with the PNL Quality Programs Directorate and applies QA to the Maintenance Program per PNL-MA-70, "Quality Assurance," manual and the QA Plan, CSD-1, Revision 2. Craft Services is in full compliance with the QA compliance criteria as detailed in CSD-1.

- h. Working relationships are developed among all interfacing organizations supporting the maintenance function.*

Discussion: Craft Services has developed a good working relationship with all organizations interfacing with the Maintenance Program.

- i. Authority, responsibility, and accountability for support organizations is defined by identifying personnel interfaces, periodic self-assessments, procedural interfaces, overall maintenance performance indicators, and indicators related to the support of maintenance tracked by each support group.*

Discussion: Authority, responsibility, and accountability for support organizations is defined in a series of PNL manuals which provide for all the criteria in i., above. These manuals are defined and listed in PNL's *Management Guide*, MG 1.0, "Policies and Procedures System."

- j. The organization achieves a high level of performance in maintenance by effective implementation and control of maintenance activities.*

Discussion: Craft Services feels that a high level of performance in maintenance activities has been achieved. This opinion is derived from low failure rates of equipment and the computerized tracking, scheduling, and

performance measurement programs made of the maintenance system on a monthly basis.

- k. *The organization provides time for and emphasizes long range planning.*

Discussion: Long range planning is emphasized and time is provided to perform the identified task.

- l. *Maintenance personnel are held accountable for their performance through supervisory counseling, performance appraisals and, when necessary, disciplinary measures.*

Discussion: Maintenance personnel are held accountable for their performance through supervisory counseling as outlined in Craft Services P&P 6.1.2, "Appraisals--Bargaining Unit." Disciplinary actions are taken within the guidelines of the *Management Guide* that address disciplinary action. Assigned tasks are being accomplished.

- m. *Maintenance staffing and resources are sufficient to accomplish assigned tasks, including time for training.*

Discussion: Assigned tasks are being accomplished. Training requirements are increasing, and time for required training classes has priority over work assignments.

- n. *Entry-level criteria is established to ensure that maintenance personnel have the requisite background and experience to be trainable for work in facilities.*

Discussion: Craft Services employs fully qualified journeyman craftsman who have completed a certified apprenticeship, or equivalent, program. Apprentices are trained and developed within the guidelines of the joint apprenticeship committee agreement with the state of Washington. These criteria are used in conjunction with the PNL Human Resources Department's policy for hiring practices.

- o. *Position incumbents meet the prescribed job qualification requirements.*

Discussion: Craft Services personnel meet position requirements as outlined in criteria n., above.

- p. *Appropriate job qualification requirements are established for all facility maintenance positions affecting the safe and reliable operation of facilities.*

Discussion: In addition to the maintenance personnel outlined in criteria n., above, exempt staff must meet the criteria set in Craft Services P&Ps, Section 4, "Position Descriptions."

- q. *Maintenance job qualification requirements are periodically reviewed, evaluated, and revised, as necessary.*

Discussion: Craft Services P&P, Section 4, "Position Descriptions," and Section 17, "Craft Services Procedure Control," are reviewed every two years for adequacy and revised whenever the need arises, along with the entire P&P manual.

- r. *Adequate engineering and technical support personnel are readily available.*

Discussion: Engineers are assigned to Craft Services (the maintenance organization) on an as-needed basis. In addition, there are a number of maintenance specialists assigned to the Preventive/Predictive Maintenance Group and the Compliance and Training Group. These engineers and specialists work jointly to support maintenance functions within Craft Services. Also, Craft Services receives additional support and assistance from the entire Facilities Engineering Section, when requested.

- s. *High quality personnel are recruited for temporary increases in staff to support planned outages or other activities.*

Discussion: Temporary increases in staffing requirements are met through the use of the on-site construction forces (Kaiser Engineers Hanford).

- t. *Timely action is taken to anticipate and fill maintenance vacancies, and long-range maintenance staffing plans are developed.*

Discussion: Vacancies are filled with qualified individuals in a reasonable time frame. Long-range staffing plans are developed and submitted to senior management in annual work plans, business plans and the institutional plan.

- u. *Appropriate career progression plans are used to develop the management, supervisory, and technical expertise of personnel, and thus help to ensure that future maintenance staff vacancies are filled with qualified personnel.*

Discussion: Career progression plans are documented and

tracked within the guidelines of Craft Services P&Ps 6.1.0, "Staff Development Reviews--Exempt;" 6.1.1, "Staff Development Reviews--Nonexempt, Nonunit;" and 6.1.2, "Appraisals--Bargaining Unit."

Improvements: No improvements are planned at this time.

4.1.2 Administration

Objective: *The administration of the maintenance function should ensure that a high level of performance is achieved through effective implementation and control of maintenance activities by establishing written performance standards, periodically observing and assessing the performance of maintenance personnel and systems, and holding personnel accountable for their performance.*

- a. *The conduct of maintenance activities in a facility is documented, as necessary, to provide for systematic, coordinated, and accurate implementation consistent with maintenance policies, goals, and objectives.*

Discussion: Maintenance activities are documented in the "Craft Services Policies and Procedures" manual.

- b. *Sufficient staff, equipment, and funding is requested, justified, and available so that the maintenance organization can effectively perform its function and adequately train maintenance personnel.*

Discussion: Annual Work Plans and Crosscut Budgets are developed and implemented. Staff, equipment, and funding are made available when there is adequate justification. The maintenance organization effectively performs its function and provides adequate training for maintenance personnel as described in Craft Services P&P 19.1.1, "Orientation and Safety Training Program," and 14.1.0, "Methods and Training."

- c. *Administrative work control functions are documented in policies, procedures, and checklists.*

Discussion: PNL's work control process is documented in Craft Services P&P 9.2.0, "Facilities Work Control Procedure." This procedure covers reference documents to work control and describes the work control process from start to finish. The procedure also covers repairs, and emergency maintenance requirements in association with maintenance functions.

- d. *Maintenance procedures establish the responsibility for maintenance, accountability for work, authority, lines of*

communication, documentation requirements, required references, and means of review, approval and updating.

Discussion: PNL's work control process is documented in Craft Services P&P 9.2.0, "Facilities Work Control Procedure." This procedure covers reference documents to work control and describes the work control process from start to finish. The procedure also covers repairs, and emergency maintenance requirements in association with maintenance functions.

- e. *Maintenance procedures define the maintenance program and standards for maintenance activities.*

Discussion: The Maintenance Program is defined and standards for maintenance activities are covered in Craft Services P&P 11.1.0, "PM Program," and 9.2.0, "Facility Work Control Procedure."

- f. *The maintenance program and maintenance standards are communicated to the working level by training workers in good work practices and by supervisors who observe and guide work activities.*

Discussion: Supervisors oversee maintenance work, and must sign to verify successful completion of maintenance work on Safety Classification 1 and 2 facility systems. Formal annual training to Craft Services P&P 11.1.0, "PM Program," and 9.2.0, "Facility Work Control Procedure," with Craft Services staff who conduct maintenance work.

- g. *An effective maintenance program need not require extensive documentation, but it should be understood and effectively implemented by all involved personnel in a consistent manner.*

Discussion: Craft Services Maintenance Program is effectively implemented and consistently applied and conducted. Craft Services Management ensures compliance to procedures on a consistent basis. The Maintenance Program is considered adequately documented in procedure format.

- h. *Administrative controls are employed in the conduct of facility maintenance activities. Examples of such activities include scheduling of preventive maintenance, use of special tools and lifting equipment, and use of measuring and test equipment.*

Discussion: Administrative controls for planning and scheduling are documented in P&P 10.1.0, "Planning and Scheduling." Standard Maintenance Procedures (SMP) are

developed for the use of any special tools. PNL-MA-43, "Industrial Hygiene, Occupational Safety, and Fire Protection Programs," and WHC-CM-6-4, Hanford Hoisting and Rigging Manual, cover lifting equipment. Craft Services Calibration (CAL) Manual covers the use of measuring and testing equipment.

- i. Oral and written communications are effective within the maintenance organization and between the maintenance organization and such supporting groups as operations, safety, and engineering.*

Discussion: Both oral and written communications are considered effective and cooperation demonstrated for communications among Craft Services and Facilities Engineering, Facilities Operations, Laboratory Safety, and Quality Programs organizations.

- j. The communication necessary to develop working relationships and keep personnel at all levels cognizant of the information needed in order to perform their functions is defined in the maintenance program documents.*

Discussion: Necessary communications, interfaces, and assigned levels of cognizance are documented in Craft Services P&P Manual; Craft Services SMP Manual; Craft Services CAL Manual; Craft Services Welding Manual; PNL-MA-43, "Industrial Hygiene, Occupational Safety, and Fire Protection Programs;" PNL-MA-90, "Design: Preparation, Control, and Implementation;" and PNL-MA-70, "Quality Assurance" manual.

- k. Technical issues associated with maintenance are identified and resolved with involved organizations.*

Discussion: Any technical issue identified in the field by the craftsman performing the maintenance is documented on the PM Checklist for that piece of equipment. The PM Specialist is then obligated to obtain a documented answer, or resolution, to the issue and get back to the craftsman. The PM Specialist must also document this on the PM Checklist. Assigned Facilities Engineers will be utilized depending on the expertise needed and/or nature of the issue. If the issue is safety related, Laboratory Safety will be contacted.

- l. Rewards and other forms of recognition are given to maintenance personnel for superior performance.*

Discussion: Superior performance by maintenance personnel is recognized by a memo to the individual, their supervisor and/or section manager expressing an

appreciation for a job well done. These memos are filed in the individual's personnel file and used during Staff Development Review (SDR) preparation. The memos are also reflected in the annual personnel performance appraisals.

- m. Maintenance personnel involved in significant or frequent violations of requirements are encouraged to improve through counseling, by remedial training, or by disciplinary measures, as appropriate.*

Discussion: The *Management Guide*, MG 7.17, "Disciplinary Action," is to be used in dealing with maintenance personnel involved in significant or frequent violations of requirements.

- n. Performance appraisals and routine personnel feedback with supervisors or managers are utilized to enhance individual employee performance.*

Discussion: Craft Services uses performance appraisals, and uses personnel feedback from individuals to enhance employee performance. The appraisal process is covered by Craft Services P&P 6.1.0, "Staff Development Reviews--Exempt;" 6.1.1, "Staff Development Review--Nonexempt, Nonunit;" and 6.1.2, "Appraisals--Bargaining Unit."

- o. Personnel are encouraged to develop methods to improve safety, reliability, quality, and productivity through such activities as employee participation programs.*

Discussion: PNL management has an open door policy which welcomes any recommendations and criticisms in relation to all aspects of any individual's job. A formal employee participation program is the Craft Services Safety Forum, where craftsmen routinely meet with management to work together to establish a safer working environment.

- p. Commitments are routinely met. Open commitment status is tracked and up-to-date.*

Discussion: Commitments are routinely met. Craft Services maintains an Audit Log used to track and measure progress on any commitment made to other organizations.

- q. Performance indicators are reviewed and used to improve maintenance performance.*

Discussion: Performance indicators are incorporated into the PM Program and are reported on a monthly basis. These reports are reviewed by the Craft Services Manager who will request adjustments in the program to correct any negative trends. Examples of these reports are: PM

Waiver Report--number of PMs on waiver status and why; PMs returned to the field for corrections to data, legibility of data, or completion signatures; late returning PMs; number of PMs in the revision mode and why; Statistics Report--monthly number of PMs issued, completed on time, etc.; work request over 90 days old; and percent overrun of work packages.

- r. *Long-range planning of major maintenance activities and facility outages establish a scope for funding and staff resources to meet the needs of the maintenance program.*

Discussion: Long-range planning of major maintenance activities establishes a scope for funding and staff resources to meet the needs of the maintenance program.

Improvements: No improvements are planned at this time.

4.1.3 Policies, Goals, and Objectives

Objective: *Written maintenance policies, goals, and objectives should be documented in appropriate manuals and communicated to all maintenance personnel. Maintenance should be conducted based on these goals and objectives.*

- a. *Policies define the maintenance organization, establish administrative objectives and levels of responsibility, and generally serve to consistently regulate and guide the conduct of maintenance activities.*

Discussion: Craft Services P&P manual documents PNL's policies on maintenance activities. The topics covered in the Craft Services P&P Manual are: Organization, Position Descriptions, Mission and Goals, Personnel Practices, Continuity of Operation, Budgets and Cost Control, Materials Control, Work Package System, Planning and Scheduling, Preventive Maintenance, QA, Work Contracting, Methods and Training, Apprenticeship Program, Certified Vendor Information, Craft Services Procedure Control, Facilities Maintenance Upgrading, Housekeeping and Safety, Craft Services Welding, Calibration Program, Hazardous Waste, and Electrical and Piping Inspection Program.

- b. *Maintenance personnel are assigned responsibility for achievement of specific objectives and understand the actions necessary, within the scope of their duties and responsibilities, to achieve these objectives.*

Discussion: Each exempt staff member of Craft Services has a specific position description which assigns responsibilities for achieving their job objectives. These position descriptions are detailed in Craft Services

P&P, Section 4, "Position Descriptions." Craftsmen are assigned responsibility according to their journeyman specialty and their assigned work.

- c. *Maintenance goals are developed and used to improve maintenance performance and for measuring maintenance effectiveness.*

Discussion: Every year Craft Services establishes goals in preparation for the next fiscal year. These goals are developed within the framework of Craft Services P&P, Section 5, "Mission and Goals."

- d. *Maintenance objectives are challenging, stated in measurable terms, and address areas where improvement is needed.*

Discussion: Craft Services' maintenance goals use the information in criteria d. above, to grade the effectiveness of any selected goal. Goals are challenging, measurable, and cover areas of needed improvement.

- e. *Maintenance goals such as the following are established to:*

- *Minimize the impact on planned outages by planning and completing maintenance activities in a timely manner;*
- *Minimize the number of forced outages;*
- *Minimize unplanned challenges to critical systems;*
- *Minimize the lost-time accident rate;*
- *Minimize facility and equipment downtime;*
- *Minimize personnel errors;*
- *Reduce repeat maintenance work requests (rework);*
- *Complete scheduled surveillances and preventive maintenance activities in a timely manner;*
- *Manage the corrective maintenance backlog to minimize the backlog and completion time of outstanding deficiencies;*
- *Control overtime;*
- *Staff and train the maintenance organization; and*
- *Complete outage and nonoutage work on schedule.*

Discussion: Craft Services' goals have addressed each and every one of the above listed items. Each year's goals are selected to correct negative trends or improve a particular portion of the Maintenance Program.

- f. *Goals are substantive in nature, challenging the capability and ingenuity of the maintenance manager.*

Discussion: Goals are substantive and are purposely challenging to the maintenance manager in order to gain maximum effectiveness and improvements.

- g. Goals and objectives are attainable and are not to be considered "sacred." Initial objectives are revised if proven unfeasible, irrelevant, or impossible.*

Discussion: When goals are correctly written with obtainable objectives, the need to revise the goals because they are unfeasible, irrelevant or impossible is minimized. Craft Services revises goals when necessary.

- h. Effective safety programs are implemented with clearly defined policies, procedures, and responsibilities to protect maintenance personnel (see references h,i, and k).*

Discussion: Craft Services maintains knowledgeable compliance to PNL-MA-43, "Industrial Hygiene, Occupational Safety, and Fire Protection Programs," and Craft Services P&P, Section 19, "Housekeeping and Safety."

- i. Policies, procedures, and responsibilities clearly define both the quality assurance and quality control program interface with maintenance.*

Discussion: Craft Services P&P, Section 12, "QA," along with the Craft Services QA Plan, CSD-1, provides the QA/QC interface with the Maintenance Program. Craft Services also complies with applicable portions of PNL-MA-70, "Quality Assurance Manual."

Improvements: No improvements are planned at this time.

4.1.4 Training and Qualification

Objective: *Training and qualification programs should develop and maintain the knowledge and skills required by maintenance personnel to effectively perform maintenance activities.*

- a. The responsibility for establishing, maintaining, and implementing the maintenance training programs is defined, understood, and coordinated between the maintenance and training organizations.*

Discussion: Craft Services' training program is currently documented under Craft Services P&P, Section 14, "Compliance and Training," and 19.1.1, "Orientation and Safety Training Program." The procedure was recently rewritten to reflect current practice.

- b. Maintenance training programs are defined and encompass*

managerial, supervisory, planner/scheduler, engineering, and craft personnel.

Discussion: Craft Services training program encompasses exempt staff, including management, and craft personnel. The training program is well understood and documented. Craft Services P&P, Section 19.1.1, "Orientation and Safety Training Program" was recently rewritten to reflect current practice.

c. Initial training, consisting of classroom and on-the-job training, develops necessary job-related knowledge and skills and includes areas such as the following:

- 1. Basic technical and applied science subjects;*
- 2. Maintenance fundamentals and troubleshooting and repair techniques;*
- 3. Facility systems and components;*
- 4. Special maintenance craft skills;*
- 5. Practical factor demonstration;*
- 6. Work control procedures;*
- 7. Industrial safety, including hazards associated with work on specific equipment/systems and emergency response;*
- 8. Quality assurance and quality control;*
- 9. Maintenance procedures and job-specific work practices, including surveillance procedures;*
- 10. In-house and DOE-wide operating experience, including actual events; and*
- 11. Emergency response.*

Discussion: Initial training conducted by Craft Services covers portions of the above criteria, along with PNL's Orientation and Safety Training Program and Apprenticeship Program.

d. Continuing training maintains and improves job-related knowledge and skills in areas such as the following:

- 1. Facility system and component changes;*
- 2. Procedure changes;*
- 3. DOE-wide and in-house operating experiences, including facility operations;*
- 4. Seldom-used knowledge and skills that affect safe and reliable facility operations; and*
- 5. Selected topics from c. above to correct identified weaknesses.*

Discussion: Craft Services provides continuing training to maintain and improve job-related knowledge and skills to Craft Services personnel. This training is specifically designed within the guidelines of each

individual's job assignment(s). Each craftsman receives an average of 75 hours of annual training. Each exempt staff member receives training in line with their job assignments.

- e. *Maintenance organization support and guidance for maintenance training programs normally includes all or portions of the following tasks:*

1. *Defining the jobs, tasks, skill levels, and responsibilities and identifying individuals to fill these positions;*

Discussion: Each exempt position has a position description described in Craft Services P&P, Section 4, "Position Descriptions," which identifies the jobs tasks, skill levels and responsibilities. Craftsman position descriptions are described in the HAMTC Agreement.

2. *Defining training programs for each position;*

Discussion: Training programs for each position are documented in the Training Questionnaire for Craft Services, Facilities Services, and Power Operations staff members. The questionnaire is filled out and maintained for each individual in Craft Services.

3. *Determining the content and emphasis of the training needed;*

Discussion: The content and emphasis of the training is established in approved formal lesson plans for each required training class offered by PNL's Training Center.

4. *Determining and supporting training schedules;*

Discussion: Training schedules are offered and controlled by PNL's Training Center for classes offered. Craft Services puts a priority on attendance of required classes over work schedules and other high priorities.

5. *Determining the training needs of and tailoring the training program for each individual based on their previous education, training, experience, and skill level;*

Discussion: Training programs for each position are documented in the Training Questionnaire for Craft Services, Facilities Services, and Power Operations

staff members. The questionnaire is filled out and maintained for each individual in Craft Services.

6. *Providing instructors and trainers;*

Discussion: Instructors/trainers are provided by the various training organizations within PNL. Craft Services will provide its own instructors/trainers when necessary. Instructors have received appropriate training.

7. *Establishing qualification criteria, with emphasis on successful performance in the field;*

Discussion: Craft Services employs fully qualified journeyman craftsmen who have completed a certified apprenticeship, or equivalent, program. Apprentices are trained and developed within the guidelines of the joint apprenticeship committee agreement with the state of Washington. Initial training conducted by Craft Services, along with PNL's Orientation and Safety Training Program, satisfies qualification criteria for this item.

8. *Coordinating the conduct of and instruction during on-the-job training; and*

Discussion: Apprentice on-the-job training (OJT) is coordinated and scheduled to have an experienced journeyman work with each apprentice until the individual is qualified to perform a specific job.

9. *Providing effectiveness feedback to the training organizations to enhance and, where necessary, adjust course teaching methods, content, and emphasis.*

Discussion: Training classes coordinated by PNL's Training Center offer each student the opportunity to fill out class evaluation sheets. These cover the instructor's knowledge and presentation of the class content, and any recommendations for improvements.

f. *Training implementation is coordinated between the maintenance and training organizations to prepare training schedules, determine who should attend, and ensure qualified instructors are available to teach the courses.*

Discussion: PNL's Training Center offers multiple schedules of all listed classes. Craft Services works with the Training Center to schedule individuals needing a particular class.

- g. *A formal part of the maintenance training program is on-the-job training (OJT), in which facility personnel achieve learning objectives through practical hands-on training conducted within the job environment.*

Discussion: The formal OJT Program offered by Craft Services is the Apprenticeship Program. This program offers the opportunity for hands-on training conducted within the job environment.

- h. *OJT is conducted in accordance with formally defined training programs that specifically identify items the trainee must accomplish.*

Discussion: Craft Services' OJT Program is conducted within the stringent guidelines set down by the Joint Apprenticeship Committee as approved by the Washington State Department of Labor and Industries and Craft Services P&P 15.1.0, "Apprenticeship Program."

- i. *OJT is conducted by personnel who have successfully qualified as OJT Trainers.*

Discussion: OJT is overseen by journeymen craftsmen, who are selected for their expertise in their particular craft and the ability to instruct apprentices in developing their skills.

- j. *When trainees perform maintenance on installed equipment, a qualified OJT instructor observes the work. This allows the trainee to properly accomplish the activity and understand how to avoid errors that could affect personnel safety or adversely impact the facility.*

Discussion: Apprentices work alone only when qualified to perform a specific job. Otherwise, they function under the supervision of an experienced journeyman craftsman.

- k. *The number of trainees to simultaneously participate in any OJT is limited in order to ensure that each trainee receives effective and adequate instruction.*

Discussion: The number of trainees is strictly controlled by PNL and HAMTC. There are currently ten apprentices in the OJT Program in ratio to approximately 167 journeymen craftsmen.

- l. *Trainees independently perform maintenance only on facility equipment for which they are qualified.*

Discussion: Apprentices never independently perform maintenance until they are considered qualified.

- m. *Qualification standards and evaluation methods are adequate to verify trainee competence for formal qualification approval and documentation.*

Discussion: Qualification standards and evaluation methods are set by the Joint Apprenticeship Committee as approved by the Washington State Department of Labor and Industries.

- n. *Maintenance Managers are directly involved in approving and periodically reviewing the maintenance training program.*

Discussion: The Maintenance Training Program is approved and periodically reviewed by the Craft Services Manager. Each maintenance section manager also has input in the program's content and any proposed revisions. The programs are covered in Craft Services P&P 15.1.0, "Apprenticeship Program," and Section 14, "Methods and Training."

- o. *Training programs are systematically improved to ensure that trainees develop the required skills and knowledge. Feedback from job performance is used to help evaluate and refine maintenance skills.*

Discussion: Training programs are continually being improved to provide the best training available. Many improvements and changes are compliance-driven by frequently changing compliance criteria.

- p. *Management and supervisory training includes generic areas such as managerial and supervisory skills, accountability, assessment and observation of routine activities, communication skills, teamwork, and company management philosophies. Position-specific training is provided to first-line supervisors.*

Discussion: All of these elements are available in managerial and supervisory training programs.

Improvements: No improvements are planned at this time.

4.2 Condition of Facilities and Equipment

4.2.1 Facility Condition Inspections

Objective: *To establish and conduct periodic inspections of equipment and facilities, assuring that proper condition, cleanliness, and housekeeping are maintained to support safe and reliable facility operations.*

- a. *To display clearly the standard for facility condition, facility managers and supervisors are personally conducting periodic walkdowns and inspections to identify deficiencies and housekeeping discrepancies.*

Discussion: Craft Services P&P 19.1.0, "Housekeeping and Safety," covers Craft Services' policy of facility conditions and required scheduled inspections for areas under Craft Services responsibilities (shop areas). Discrepancies are noted and tracked to completion. Craft Services needs to revise P&P 19.1.0 to add detail for instruction on how the program functions.

- b. *Equipment and facility condition, cleanliness, and housekeeping standards are established and communicated to all maintenance personnel.*

Discussion: Equipment and facility conditions, and cleanliness and housekeeping standards are covered in Craft Services P&P 19.1.0, Housekeeping and Safety.

- c. *Adherence to these standards are assessed through the conduct of routine periodic inspections by managers and supervisors.*

Discussion: Supervisors are required to inspect their assigned areas for housekeeping and safe practices at least monthly. Section managers are required to inspect work areas under their responsibility at least quarterly. This is covered in Craft Services P&P 19.1.0, "Housekeeping and Safety." Supervisors are also responsible for over-checking crafts to ensure that maintenance work locations are left in a clean and orderly state.

- d. *Temporary environmental protection (e.g., from dust, humidity, freeze, and shock) is provided for facility equipment when needed to support construction, outage, or maintenance activities.*

Discussion: Various permits, such as welding, burning, outage, and modification permits, are required to perform maintenance which protects equipment and facilities.

- e. *Appropriate facility maintenance personnel are aware of facility condition standards and are trained in the techniques required to perform condition inspections.*

Discussion: Supervisors, specialists, and managers are trained in OSHA criteria inspections. Each participates in facility inspections.

- f. Condition inspection procedures define expected standards, provide for documentation of deficiencies, provide for follow-up on deficiency corrective actions, assign responsibilities for program implementation, and establish means to measure program effectiveness.*

Discussion: Safety inspection reports are sent to the Laboratory Safety Department to document conditions and assign corrective actions. Follow-up reports document completion of corrective actions. Shop inspections are covered by Craft Services P&P 19.1.0, "Housekeeping and Safety."

- g. Inspection areas are assigned so that the entire facility is inspected, including radiation and locked areas with difficult access.*

Discussion: Craft Services inspects assigned shops and work areas. Building managers are assigned to inspect the rest of the facility.

- h. Checklists of the equipment to be inspected and types of problems to look for are available as guides for the inspectors.*

Discussion: Craft Services needs to develop inspection checklists specific to each shop area/equipment.

- i. Schedules for the performance of routine periodic inspections are established and identify the area(s) to be inspected as well as periodic rotation for inspectors.*

Discussion: Craft Services schedules periodic inspections and identifies areas to be inspected. Different individuals are routinely assigned to inspect the various shops.

- j. The results of each inspection is transmitted to the facility manager and maintenance manager.*

Discussion: The results of Craft Services shop and work area inspections are transmitted to Laboratory Safety, and the Maintenance Manager. The Facility Manager conducts inspections of his/her facilities and reports the results to Laboratory Safety.

- k. Significant conditions or safety deficiencies are immediately reported to the appropriate supervisor for near-term attention.*

Discussion: Significant conditions or safety deficiencies are cause to immediately stop any work or activity until

conditions are returned to an acceptable condition. These conditions must also be reported within the guidance of PNL's *Management Guide*, ACT NOW Directive 90-7, "Off-Normal Events."

- l. *Facility deficiencies found are entered into the work control system for correction.*

Discussion: Deficiencies found are entered into the Craft Services Work Control System for correction.

- m. *Identified deficiencies are corrected in a timely manner so that facility personnel can see the positive results of the inspection program.*

Discussion: Craft Services deficiencies are given required completion dates and are tracked to verify completion.

- n. *Personnel are assigned corrective action and deficiencies are tracked to completion.*

Discussion: Individuals are assigned direct responsibility for corrective actions and the deficiencies are tracked for completion by the Craft Services' Cross Connection/Safety Specialist.

- o. *Reported deficiencies are monitored to identify recurring, generic, and long-term problems.*

Discussion: Craft Services housekeeping deficiencies are not trended. This should be a function of the Inspection Program.

Improvements: Craft Services P&P 19.1.0, Housekeeping and Safety, will be revised to reflect current practice by September 30, 1992.

Inspection checklists designed for each specific shop area/equipment will be implemented by September 30, 1992.

A method for trending housekeeping deficiencies and facility assessment deficiencies will be implemented by June 30, 1993.

4.2.2 Condition Assessment Surveys

Objective: *All real property and installed equipment should be inspected at predetermined frequencies to ensure that these facilities are maintained in a condition consistent with assigned missions or long-range planning.*

- a. *Condition Assessment Surveys (facility inspections) range*

from simple, visual walk-through-type assessments to in-depth studies using a variety of technical diagnostic techniques.

Discussion: Craft Services conducts condition assessment surveys through a comprehensive inspection program incorporated within the formal Predictive Maintenance (PM) Program. In addition, condition assessment surveys are performed through the use of: Facility Upgrade Inspection Program, Roof Inspection Program, interior and exterior Paint Program, Energy Management, Cross Connection Program, and Facility Electrical Inspection Program.

- b. The primary objective of the condition assessment survey program is the early detection of potential facility problems in order to prevent deterioration, possible damage to adjacent materials or systems, and failure of components.*

Discussion: This is the objective of Craft Services PM/Predictive Maintenance Program, documented in Craft Services P&P 11.1.0, PM Program.

- c. The standards and procedures that are the basis for condition assessments are reflected in checklists that prompt and assist the inspection team in the deficiency identification process.*

Discussion: Condition assessment inspections are documented in PM Standard Checklists which are governed by Craft Services P&P 11.1.0, "PM Program." Checklists are also used in the Facilities Maintenance Upgrade Program governed by Craft Services P&P 18.1.0, "Facility Maintenance Upgrading."

- d. The condition assessment process is standardized and performed on a predetermined basis, ranging from quarterly to every 3 years, by individuals trained to recognize and identify symptoms of facility problems.*

Discussion: PM Standard Checklists are standardized per Craft Services P&P 11.1.0, "PM Program," and are performed on a predetermined schedule. The individuals performing the PM Standard Checklist in the field are journeymen craftsmen who are trained in their craft specialty to identify equipment and facility problems. Facilities Upgrade Inspections are performed annually by a technical specialist and facility manager.

- e. Particular attention is given to potential problem areas such as interfaces between components, especially with respect to different systems or components by different*

manufacturers or suppliers.

Discussion: Potential problem areas are automatically addressed during the development and approval process for PM Standard Checklists.

- f. After the identification of symptoms of problems or deficiencies, a diagnostic analysis is performed to determine whether there is, in fact, a problem, the nature and extent of the problem, and options for corrective action.*

Discussion: Diagnostic analysis will be performed to determine the scope of potential problems, if applicable, or to determine if a method of analysis is available for the particular application. Results of applied diagnostic analysis are used to determine options for corrective action.

- g. Personnel performing diagnostic analysis have technical knowledge of the systems, equipment, or components involved, and frequently of the materials used in construction and maintenance.*

Discussion: Personnel performing diagnostic analysis are journeymen craftsmen, technical specialists and Facilities Engineers who have technical knowledge of the facility systems, equipment, and components. They also have knowledge of materials used in construction and maintenance. Craftsmen are also supported by technical specialists to aid in technical concerns, problems, and to answer technical questions.

- h. The diagnostic analysis is based on logical, standardized, professionally developed procedures, ensuring that identified deficiencies are efficiently and correctly evaluated.*

Discussion: Any diagnostic analysis used is based on the diagnostic analysis equipment's manufacturer's recommendations and procedures. Other methods can either be documented in the PM Standard Checklist itself, or a Craft Services SMP.

- i. For efficiency, the condition assessment survey team should be given target estimates for levels of anticipated problems, time required for inspection, number of buildings and amount of contained equipment to be inspected, symptom checklists, and standards to be applied in identifying symptoms.*

Discussion: When applicable, (e.g., vibration analysis

routes) there is a time frame for inspections, number of buildings to be covered, and amount of equipment to be inspected. For this program there is a computerized symptom checklist and standards to be applied in identifying symptoms.

- j. *Condition assessment surveys are conducted by dedicated teams that may include architects, engineers, inspectors, consultants, or others trained for the job.*

Discussion: Craft Services routinely uses craftsmen (who are aided by PM specialists) to perform condition assessment surveys. During the investigation to resolve an identified problem area, consultants, engineers, or architects may be called in. The annual Facility Upgrade Inspection is conducted by a technical specialist (field engineer) and a facility manager.

Improvements: No improvements are planned at this time.

4.3 Maintenance Documentation

4.3.1 Site Maintenance Plan

Objective: *Individual operating contractors should develop a maintenance plan that provides a clear understanding of the total maintenance needs and planned significant projects for the year and, at a summary level, the maintenance activities that support the long-range life cycle facility maintenance requirements.*

- a. *A maintenance plan describing the required maintenance activities by functional unit of site infrastructure is developed and annually updated by each site contractor performing maintenance to integrate maintenance activities for which they are responsible. The maintenance plan is also a narrative description of the contractor's maintenance management program and addresses all elements of a successful maintenance program.*

Discussion: Craft Services' Annual Business Plan addresses the criteria in a., above. Craft Services P&P 7.1.8, "Annual Work Plan (DOE)," needs to be revised to reflect current practice. This is not a priority and will be done at a later date.

- b. *Maintenance items to be included in the maintenance plan are those classical maintenance and repair activities funded by operating expense accounts. In general, those costs include labor and associated supervision and materials as well as other indirect and overhead-funded activities. Also included are preventive, corrective,*

predictive, and emergency maintenance and support functions as inspections, administration, engineering, and training.

Nonmaintenance work activities (such as janitorial services, snow removal, and asbestos abatement) may also be included in the maintenance plan if such nonmaintenance information helps to describe the "total" responsibilities of the maintenance organization. Such nonmaintenance activities should not be funded as maintenance work.

Discussion: These items are covered by the various procedures in Craft Services P&P, Section 7, "Budgets and Cost Control."

- c. The maintenance plan describes the strategy to monitor and control the maintenance backlog to ensure that facilities are adequately maintained.*

Discussion: The annual work plan addresses the backlog of maintenance. The backlog is prioritized and worked based upon importance in relation to other work.

- d. After the scope of major maintenance activities are established as required, funding and staff resources are estimated to meet the needs of the maintenance program.*

Discussion: Annual Work Plans and Crosscut Budgets are developed and implemented. Staff, equipment, and funding are made available when there is adequate justification.

- e. Long-range planning encompasses items such as the following:*

- 1. Recurring major maintenance items such as turbine overhaul, steam generator inspections, and major pump rebuilds;*
- 2. Timing of planned maintenance and downtime;*
- 3. Significant projects and modifications;*
- 4. Future organizational structure and staffing changes aimed at continuing improvements in the maintenance program and the facility as a whole;*
- 5. Planning for equipment replacement as components reach the end of their service life;*
- 6. Timing of outages for the other facilities in the system when reliance on them for resources is part of the maintenance plan;*
- 7. Regulatory issues and events that will change or impact the maintenance program; and*
- 8. Budget changes or projects that may divert major dollars from maintenance activities.*

Discussion: Long-range plans meet the criteria listed above. Facilities Engineering, Facilities Administration and Craft Services all contribute to these plans.

Improvements: No improvements are planned at this time.

4.4 Work Control System

4.4.1 Work Request (Order) System

Objective: *A formal, well-defined, work request (order) system should be in place to cover work performed, regardless of whether the jobs are repetitive or one-time tasks. The work request system should ensure that jobs are identified, logged, planned and scheduled, performed, tested, formally accepted, and documented in a "user-friendly" manner.*

- a. *A work request (order) system is established that clearly identifies the work needed and provides instructions to perform the work.*

Discussion: Craft Services Work Request System is detailed in Craft Services P&P 10.1.1, "Planning and Scheduling Procedure." This procedure details the processing of a work request, but needs to be expanded for more detail on the work request form itself and clarification of instruction on its use.

- b. *The work request forms (work package) for facilities provide procedures and guidance for performing the work and allow documentation for the following:*

- (1) *Number sequencing;*

Discussion: Each work request is sequentially numbered.

- (2) *Equipment and component identification;*

Discussion: The work request has a block for equipment identification.

- (3) *Description of symptom, problem, or work requested and the responsible person identifying them;*

Discussion: This information should be placed in the "Work To Be Performed" block on the work request. The responsible person signs in the "Requested By" block.

- (4) *Identification of crafts required;*

Discussion: Crafts required should be listed in the "Craft Type" block on the work request.

(5) *Dating of document package;*

Discussion: Date goes in the "Date Submitted" block on the work request.

(6) *Job priority;*

Discussion: Job priority goes in the "Priority" block on the work request.

(7) *Personnel safety;*

Discussion: Any special personnel safety requirements should be placed in the "Work To Be Performed" block on the work request.

(8) *Identification of the safety class of equipment or components or qualification requirements (such as environmental and seismic qualifications);*

Discussion: This information goes into the "Impact Level/Safety Classification (IL/SC)" block of the work request.

(9) *Applicable Technical Specification/Operational Safety Requirements, time restraints, and associated limiting conditions for operation;*

Discussion: If space allows on the work request, this information can be placed in the "Work To Be Performed" block. If there is not enough room, this documentation can be added to the work package for the job.

(10) *Identification of special process requirements (such as special work permits, special work instructions, special training, and personnel qualification requirements);*

Discussion: If space allows on the work request, this information can be placed in the "Work To Be Performed" block. If there is not enough room, this documentation can be added to the work package for the job.

(11) *Work instructions, hold points to allow inspections, special requirements, use of special materials or tools, test instrument ranges, accuracy, and clean-up requirements;*

Discussion: This type of information is recorded on the Quality Control Requirements (QCR) form. The form is attached to the work request, and becomes a part of the work package.

- (12) Required post-maintenance testing, inspections, and acceptance criteria;*

Discussion: This type of information is recorded on the QCR form. The form is attached to the work request, and becomes a part of the work package.

- (13) Work supervisor or appropriate person in charge;*

Discussion: This goes in the "Supervisor" block on the work request.

- (14) Applicable operating and maintenance procedures;*

Discussion: These can be noted in the "Work To Be Performed" block on the work request, or added to the work package.

- (15) Description of work performed, as-found conditions, repairs made, cause-of-failure evaluations, identification of special tools and parts, calibration data, set points, adjustments made, and as-left conditions;*

Discussion: For maintenance work, this is documented on the PM Standards Checklist, which is associated with a specific work request.

- (16) Cost code to which work performed is to be charged; and*

Discussion: This goes in the "Work Package" block on the work request.

- (17) Final reviews and sign-offs by maintenance, quality control, and other groups in the review process.*

Discussion: Final review of work completion is documented in the "Completed By" block on the work request.

- c. The work request system provides a method for tracking work in process.*

Discussion: Work requests are computer tracked from start to finish of work. This process is covered in Craft Services P&P 10.1.1, "Planning and Scheduling Procedure."

This procedure should be revised to take into account the new Craft Services Planning and Scheduling Computer Program.

- d. *A procedure is established for performing and documenting emergency maintenance.*

Discussion: Emergency maintenance is covered in Craft Services P&P 9.2.0, "Facility Work Control Procedure."

- e. *The work request (order) system provides for control of modifications, in-service tests, preventive maintenance (PM), and surveillances.*

Discussion: The work request covers in-service tests, preventive maintenance, surveillances, fabrications, and repairs. It does not cover facility modifications which are covered in PNL-MA-90, "Design: Preparation, Control, and Implementation."

Improvements: Craft Services P&P 10.1.1, Planning and Scheduling Procedure, will be revised to reflect current practice and DOE Order 4330.4A by May 31, 1993.

4.4.2 Formal Job Planning and Estimating

Objective: *A system of formal job planning estimating should be used to identify the required support, permits, hold points, work procedures, and material requests that determine the total scope of work and address task sequencing and steps to completion. Outage planning should promote optimum outage performance by providing integration and coordination of all work elements.*

- a. *Planning maintenance activities is accomplished by a dedicated planning staff or by maintenance supervisors at facilities with small staffs. If done by a supervisor, the workload allows time to supervise work in progress.*

Discussion: Currently Craft Services elects to have supervisors plan maintenance activities and allocate manpower. The estimating activity has never been formalized.

- b. *Adequate procedural controls are established and implemented to assure adequate job planning.*

Discussion: Craft Services controls planning and scheduling functions through Craft Services P&P 10.1.0, "Planning and Scheduling Policy," and 10.1.1, "Planning and Scheduling Procedure." P&P 10.1.1 needs to be

upgraded to take into account the new Craft Services Planning and Scheduling Computer Program which has been installed.

- c. *In-depth work planning is utilized to identify the required support and detailed scoping necessary to accurately schedule daily maintenance.*

Discussion: Daily maintenance activities are scheduled within the guidelines of Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," and 9.2.0, "Facility Work Control Procedure."

- d. *Involvement of such required support groups as operations (see reference 1), engineering, and quality control are coordinated to effectively support the maintenance effort.*

Discussion: Craft Services P&P 9.2.0, "Facility Work Control Procedure," describes the required work flow and required interfaces with all maintenance support organizations that are needed to complete maintenance activities.

- e. *Preplanning obtains such necessary support items as special tools, other equipment, repair parts, and materials required to accomplish the work when needed.*

Discussion: Preplanning is the first step in accomplishing any work. Work is preplanned by the supervisors in order to obtain needed materials, parts, equipment, etc., prior to starting work.

- f. *The planning process normally includes such items as the following:*

1. *Definition of the problem and identification of the workscope;*
2. *Identification and review of necessary procedures, drawings, vendor manuals, and maintenance history;*
3. *Identification of needed and available data for use in analysis of maintenance problems;*
4. *Procurement of necessary repair parts, materials, tools, and equipment;*
5. *Assessment of manpower and skill requirements;*
6. *Identification and review of resources, including other tasks scheduled to occur in the immediate area during the same time period;*
7. *Identification of initial facility conditions and prerequisites required for work to be accomplished;*
8. *Identification of quality control and technical inspection requirements;*
9. *Establishment of equipment restoration and*

- post-maintenance inspection or testing requirements;*
10. *Review of work instructions of work packages for completion; and*
 11. *Identification of applicable maintenance and operation procedures.*

Discussion: All aspects of criteria f., above, are utilized during Craft Services planning activities depending on the work to be accomplished and the applicability of the criteria.

- g. Pre- and post-job briefings are performed, as appropriate, to brief personnel on work to be performed and identify lessons learned.*

Discussion: Pre- and post-job briefings are held for specific types of work such as confined space entry and radiation zone work. These briefings are required by PNL-MA-43, "Industrial Hygiene, Occupational Safety, and Fire Protection Programs."

- h. Advance planning is performed and routinely updated for scheduled and unscheduled outages. Considerations such as work priority, work procedures and instructions, facility/system conditions, length of outage required, staging of documents and material, and coordination of support activities are included.*

Discussion: Organizations involved in outages are given adequate time to make necessary arrangements and preparations for the work. Outages are controlled by the *Management Guide*, MG 9.5, "Modification of Facilities and Utilities."

- i. Management of outages and planning for outages is performed to minimize the duration of these conditions and to use the available time effectively.*

Discussion: Outages are controlled by the *Management Guide*, MG 9.5, "Modification of Facilities and Utilities." Outages are coordinated with the various organizations who may need to perform work during an outage. Outages are coordinated to obtain the maximum amount of work by all involved organizations in the available amount of time during the outage.

- j. Preoutage milestones are established, and timely corrective actions are taken when milestones are not being met.*

Discussion: Pre-planning is conducted for outages.

Timely corrective action is taken when milestones are not being met.

- k. *Outage planning includes the identification of necessary manpower to support the outage and consideration of contingencies that may occur.*

Discussion: Planning for outages considers necessary manpower to support the outage, and contingency plans are developed, when necessary.

- l. *Elements of outage work are defined into manageable segments that can be accomplished by a typical work unit on a definite schedule and are entered into a tracking system to allow completion status to be monitored.*

Discussion: Outages are planned and monitored for completion in the same manner as other Craft Services work.

Improvements: Craft Services P&P 10.1.1, Planning and Scheduling Procedure, will be revised to reflect current practice by May 31 1993.

4.4.3 Work Performance (Time) Standards

Objective: *Work-hours required to perform a planned job through the utilization of estimating, the application of engineered standards, the use of job slotting techniques, or other industry-recognized methods should be established to allow the determination of cost estimates, establishment of reasonable schedules, and measurement of productivity.*

- a. *Planners are trained in the use or application of work performance (time) standards.*
- b. *Work performance (time) standards are used, where possible, as one basis for job-cost estimates.*
- c. *Work performance (time) standards are used as time estimates to ensure that schedules for each job in the daily and weekly schedules are accurate. The standards are reviewed and periodically updated based on actual times taken to perform the work.*
- d. *Job-slotting techniques or other industry-recognized simplified methods are used for applying time standards.*
- e. *Travel or delay times utilized for planning are derived from records or work sampling, where possible, or developed by the planner for the specific circumstances.*
- f. *Productivity measurements are obtained from the use of work performance (time) standards and reported as performance indicators.*
- g. *Work utilization measurements are obtained through the work-sampling process, reported as a performance*

indicator, and employed in conjunction with the maintenance backlog indicator to manage staffing levels with respect to the work backlog.

Discussion: Craft Services does not have developed programs to address any of the compliance criteria listed in Section 4.4.3.

Improvements: A work standards program will be evaluated for application to Craft Services. The results of this evaluation, along with the implemented program will be documented by August 31, 1993.

4.4.4 Priority System

Objective: *A systematic method of determining job priority or the importance of the work item to be performed should be established and is based on safety, environmental, and facility concerns.*

a. *The following items are considered when assigning priorities:*

- (1) Personnel safety;*
- (2) Equipment repair urgency/limiting conditions of operations;*
- (3) Operability of redundant equipment;*
- (4) Critical path equipment;*
- (5) Facility conditions required for equipment repair;*
- (6) Repair or replacement parts status; and*
- (7) Manpower availability.*

Discussion: The above items in criteria a. are addressed and used when applicable to specific work. Work priorities are established and controlled by Craft Services P&P 10.1.1, "Planning and Scheduling Procedure." This procedure needs to be revised to improve its description and use of Craft Services new computerized Planning and Scheduling Program.

b. *Preventive maintenance and surveillance priorities are established commensurate with personnel and facility safety, environmental protection, programmatic consideration, and value.*

Discussion: Currently, maintenance and surveillance priorities are set by PNL-MA-595, "QA Management Plan MP-FO-1, Rev.2" for Facility Systems Designated Impact Levels I, II and IIIR. Impact Levels are the priority levels. This is currently being changed to Safety Classifications and is being controlled by the Laboratory Safety Department's Interim Procedure for Implementation of

the Safety Classification System. Safety Classifications address personnel and facility safety, environmental protection, programmatic consideration and value.

- c. *Corrective maintenance priorities are established based on facility objectives and the relative importance of the equipment.*

Discussion: Corrective maintenance priorities are set in Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," and the Interim Procedure for Implementation of the Safety Classification System.

Improvements: Revise Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," to reflect current practice and DOE Order 4330.4A by May 31, 1993.

4.4.5 Maintenance Procedures and Other Work-Related Documents

Objective: *Maintenance procedures and other work-related documents (e.g., drawings and instructions) should be used to provide appropriate work direction and to ensure that maintenance is performed safely and efficiently.*

- a. *Compliance requirements for a given procedure are clearly stated in the procedure or in other overall guidance and thoroughly communicated to each craftsman. The normal two levels of compliance are:*

- (1) Step-by-step compliance without deviation; or*

- (2) General intent compliance.*

Discussion: Craft Services has both types of procedures. Policies and Procedures are general intent procedures, and are compiled in Craft Services P&P Manual. The step-by-step procedures are Craft Services SMPs, CALs, and Welding Procedures. Each procedure bears a heading statement reading: STRICT COMPLIANCE TO POLICIES, PROCEDURES AND REQUIREMENTS IS MANDATORY. It is believed that compliance requirements are clearly stated in the procedures and thoroughly communicated to each craftsman through reading assignments and training classes. Other PNL compliance manuals are listed in the *Management Guide*, MG 1.0, "Exhibit A: Administrative (A) Manuals."

- b. *Preparation, review, approval, and revision of procedures and other work-related documents are properly controlled.*

Discussion: Craft Services preparation, review, approval, and revision of procedures is covered in Craft Services P&P 17.1.0, Craft Services Procedures. This procedure

covers all procedures except PM Standard Checklists which are covered by Craft Services P&P 11.1.0, PM Program.

- c. *Documents used in lieu of procedures (such as excerpts from vendor manuals) receive the same level of review and approval as required for procedures.*

Discussion: Craft Services does not use documents in lieu of procedures, i.e., vendor manuals. Excerpts from vendor documents are commonly used in Craft Services SMPs, which do receive review and approval per Craft Services P&P 17.1.0, Craft Services Procedures.

- d. *Procedures and other work-related documents (such as vendor manuals, drawings, reference materials, and posted job performance aids) are used in support of maintenance and are technically accurate and up to date.*

Discussion: Procedures and other work-related documents used in maintenance performance are considered technically accurate and maintained in a current state of accuracy. However, some facility as-built drawings are not current.

- e. *Procedures are readily available and clearly identified.*

Discussion: Each supervisor has a complete set of controlled procedure manuals in the work place and these are available to the craftsmen at all times.

- f. *Maintenance procedures are established and utilized as necessary for the conduct of maintenance activities commensurate with the activity's importance to safety and security.*

Discussion: The need for new procedures is determined by the maintenance work's impact and effect on safety and security items, plus the attention to detail required and degree of complication of the job.

- g. *New and revised procedures are reviewed or verified for technical accuracy prior to use and checked or validated to ensure usability and correctness prior to or during initial use. Validation is done in a shop or training environment on a mockup or simulator or by the craftsman and supervisor during the first use of the procedure.*

Discussion: Craft Services SMPs are not routinely validated; however, PM Standard Checklists are routinely validated during the checklist's first use. This is covered in Craft Services P&P 11.1.0, PM Program.

- h. *Procedures are clear, concise, and contain adequate*

information for users to understand and perform their activities effectively. Items to be considered are:

- (1) Portions or steps of other documents that are used or referred to when performing a procedure are specifically identified in the procedure.*
- (2) Technical details such as setpoints, control logic, and equipment numbers are consistent among procedures, drawings, and system descriptions.*
- (3) Human factor considerations are incorporated into procedures to promote error-free performance.*

Discussion: Craft Services procedures are considered to be clear, concise, and contain adequate information to accomplish their intended function.

- i. Cautions, warnings, and hold points (such as quality checks) are included in the procedures, as needed.*

Discussion: Cautions, warnings, and hold points are included in procedures when appropriate.

- j. A policy governing the use of procedures and a procedure writer's guide should be implemented. The guidance includes the following:*

- (1) Procedures with purpose and scope;*
- (2) Consistent formats for organization, instruction step format, caution and note format, and page format;*
- (3) Methods to generate clearly understood text and assure consistent use of illustrations;*
- (4) Actions to be taken when procedures conflict, are inadequate for the intended tasks, or when unexpected results occur;*
- (5) Allowances for identification and verification of steps that can be performed out of the written sequence; and*
- (6) Requirements for use of procedures in hazardous situations, such as in friable asbestos locations.*

Discussion: Craft Services P&P 11.1.0, "PM Program," and 17.1.0, "Craft Services Procedures," both serve as policy guidance documents and as a writer's guide for procedures. However, these procedures need to be revised to clarify and update Craft Services procedure writing practices.

- k. Temporary changes to procedures, if used, are controlled through appropriate review and authorization prior to use and ensure user awareness of applicable temporary changes.*

Discussion: Temporary changes to PM procedures are

controlled in accordance with P&P 11.1.0, Preventive Maintenance Program.

- l. *Formal program exists to review procedures periodically for technical accuracy, human-factors considerations, and the inclusion of in-house and industry operating experience.*

Discussion: Procedures identified in Craft Services P&P 17.1.0, Craft Services Procedures, are reviewed on set time periods depending on the type of procedure.

- m. *A feedback mechanism is provided for the maintenance personnel to change and/or improve the usability of the procedure(s).*

Discussion: Each PM Standard Checklist has a remarks section set aside for field comments which are invited in order to improve the Checklists and PM Programs. A staff member can request, at any time, that a Craft Services procedure be reviewed for revision. This process is described in Craft Services P&P 17.1.0, Craft Services Procedures.

- n. *The maintenance procedures provide systematic guidance to craftsmen; are technically correct, complete, and up to date; and are presented utilizing sound human factor principles.*

Discussion: Craft Services believes that current procedures meet this criteria.

- o. *The maintenance procedures program documents how procedures are to be prepared, verified, validated, reviewed, approved, controlled, updated, revised, and used and specifies where these procedures are to be located.*

Discussion: This is contained in Craft Services P&P 17.1.0, "Craft Services Procedures," and 11.1.0, "PM Program."

Improvements: Work with Design and Drafting Services Section and Facilities Management Department to develop a plan to improve status of as-built drawings by August 31, 1993.

Both Craft Services P&P 11.1.0, "PM Program," and 17.1.0, "Craft Services Procedures" will be revised. A procedure writer's guide will be developed and placed in the appropriate Craft Services P&P manual section. P&P 11.1.0 will be expanded to include procedure verification and validation. These actions will be completed by March 30, 1993.

4.4.6 Scheduling System

Objective: *Scheduling and coordinating of corrective and preventive maintenance and modifications should be performed in such a way that maintenance activities are conducted in the proper sequence, efficiently, and within prescribed time limits. An outage scheduled should provide for work element completion and testing and should provide management with information necessary to control outage activities.*

- a. *Maintenance activities are scheduled and coordinated for the purpose of avoiding unnecessary removal of equipment and systems from service and providing better manpower utilization.*

Discussion: Maintenance activities are scheduled to conduct the work in the most efficient manner with the best utilization of manpower available.

- b. *The maintenance work-scheduling process incorporates a tracking system for identifying maintenance work requests being performed and post-maintenance testing.*

Discussion: Craft Services Planning and Scheduling Program is governed by Craft Services P&P 10.1.1, "Planning and Scheduling," which tracks work requests from issue to the field through final completion. This procedure needs to be revised to reflect current practices. Post-Maintenance is conducted in accordance with Craft Services P&P 9.2.0, Facilities Work Control Procedure.

- c. *Scheduling of daily activities is based on accurate planning estimates to improve the use of craftsmen's time on the job.*

Discussion: The supervisor schedules daily maintenance activities based on experience and knowledge gained from past maintenance activities, and work request history file.

- d. *A priority system is utilized to schedule work.*

Discussion: A work priority system is in place, utilized, and documented in Craft Services P&P 10.1.1, "Planning and Scheduling Procedure."

- e. *Weekly and/or daily job-scheduling meetings are conducted and the resulting work schedules are published.*

Discussion: Supervisors hold weekly maintenance job-scheduling meetings with facility managers in order to

complete work as scheduled and to coordinate work with other facility functions. The work schedules are documented.

- f. *Maintenance activities are scheduled to assure appropriate supervision and support is available.*

Discussion: Maintenance activities are scheduled to ensure appropriate supervision and support is available.

- g. *Facility personnel, especially facility managers, are apprised of scheduled maintenance activities that affect them, thus ensuring proper activity coordination.*

Discussion: Supervisors conduct weekly scheduling meetings with the facility managers in order to properly coordinate activities.

- h. *Scheduling considers only those planned activities with complete work packages and with all materials and equipment for the job.*

Discussion: The planning function covers items that do have all necessary material and equipment on hand.

- i. *Within the total available work hours, time is allotted for small call-in jobs, urgent jobs, or other unforeseen events.*

Discussion: Craft Services has a work classification called "Do It Now" (DIN) work. Work in this category is called in to the DIN Clerk who then dispatchs craftsmen to perform the requested function. This function is for call-in jobs, urgent jobs, and/or other unforeseen events only.

- j. *Timely feedback of work progress to schedulers, supervisors, and management is utilized to modify weekly and/or daily schedules, as necessary.*

Discussion: Timely feedback to the supervisor is made immediately, and the supervisor oversees the work in order to modify work schedules on an hourly basis, if needed.

- k. *Planned and forced outages are scheduled in a manner ensuring that required maintenance is performed within the time limits available and that opportunities for performing other needed maintenance are maximized.*

Discussion: The length of the outage is determined by the job to be performed. Other scheduled work for the

facility is reviewed to determine if it would best be conducted during the same outage.

- l. *An outage schedule provides for the completion of work elements and testing and provides management with a clear, concise, and understandable method of tracking completion of outage milestones. Supporting schedules are developed where necessary.*

Discussion: Outages, outage schedules and coordination are maintained and scheduled by Facilities Services. There has never been a problem with completing work elements and testing within the length of time designated for outages. Facilities Services tracks completion of outage milestones.

- m. *Outage schedules are updated on a timely basis to reflect changing conditions. When necessary, deviations from the outage plan and schedule are communicated to the proper level of management for action.*

Discussion: Outage schedule changes are immediately passed on to affected parties who are designated to receive outage information.

Improvements: Craft Services P&P 10.1.1, Planning and Scheduling, will be revised to reflect current practice and DOE Order 4330.4A by May 31, 1993.

4.4.7 Post-Maintenance Testing

Objective: *Post-maintenance testing should be performed to verify that equipment, systems, and components fulfill their design function when returned to service following maintenance. The tests performed are commensurate with the maintenance work performed and the importance of the equipment to facility safety and reliability.*

- a. *Post-maintenance testing is performed, as appropriate, after corrective and preventive maintenance activities.*

Discussion: Craft Services conducts post-maintenance testing on selected pieces of equipment. The results are documented in the PM Standard Checklist for each specific piece of equipment. This program should be evaluated by the PM Program's administrator. A section should be added to Craft Services P&P 11.1.0, "PM Program," to explain how post-maintenance testing is conducted. Post-maintenance testing on corrective maintenance items is covered in Craft Services P&P 9.2.0, "Facilities Work Control Procedure." This procedure should also be reviewed for adequacy of post-maintenance testing.

- b. *The rigor of the testing performed is based on the work on and the importance of the component or equipment to safe and reliable facility operation.*

Discussion: The rigor of the testing depends on the equipment's Safety Classification Level and the significance of the facilities Operations Safety Report requirements. Facility equipment has been reviewed for safety impact and classified with Safety Classification Levels.

- c. *The post-maintenance testing program is clearly defined and includes the following elements:*

- (1) Test requirements are identified by the appropriate technical authority. Responsibility for determining post-maintenance test requirements are assigned to functional groups such as operations, maintenance, and technical support.*
- (2) The scope of the post-maintenance testing program is determined to help ensure that appropriate levels of testing are applied to facility equipment and that redundant or unnecessary testing is minimized.*
- (3) The status of equipment that has undergone maintenance is tracked to ensure that all testing is completed prior to work closeout.*
- (4) Proper post-maintenance tests are conducted, the results documented, and the resulting data verified to have met acceptance criteria and obtained appropriate sign-offs.*

Discussion: Craft Services P&P 11.1.0, "PM Program," and 9.2.0, "Facilities Work Control Procedure," should both have a section added specifically dedicated to post-maintenance testing. Test requirements are identified by the Craft Services PM Specialist, with the test criteria being approved by all applicable organizations approving the specific PM Standard Checklist. The status of PM Standard Checklists in the field for completion are computer tracked to ensure all items, including post-maintenance testing, are completed. Post-maintenance test results are reviewed by the PM Specialist who reviews test data for acceptance to criteria and confirms that appropriate sign-offs are on the documentation.

- d. *Equipment that is important to reliable facility operation is tested in accordance with approved procedures.*

Discussion: Post-maintenance tests are documented in an approved PM Standard Checklist. The PM Standard Checklist gives instructions for maintenance and post-maintenance

testing, and contains documented data that is requested to be obtained.

- e. *Post-maintenance test results are documented and reviewed to ensure proper system/equipment performance prior to returning the system to service.*

Discussion: Test results are documented and reviewed by the craftsman and the responsible supervisor prior to returning the system/equipment back into service. Depending on the Safety Classification Level on the equipment/system, the facility manager must also confirm and sign acceptance for the system to be returned to operation.

- f. *For tests involving the participation of more than one support group, one individual should be responsible for coordinating appropriate personnel (e.g., operations, engineering, and maintenance) to perform post-maintenance testing, review results, and take corrective action, as necessary.*

Discussion: For tests which require participation of more than one organization, the assigned Craft Services supervisor is responsible for coordination of appropriate personnel and actions to complete the test.

- g. *Maintenance rework is identified and documented. Corrective actions, including periodic reviews for generic implications, are taken to minimize rework.*

Discussion: Craft Services needs to define rework and develop a procedure to document, track, and trend rework items.

- h. *Newly installed or modified systems/equipment are verified to be in good working order by maintenance staff prior to operational acceptance by the facility staff.*

Discussion: Currently, maintenance staff are not involved in the Acceptance Test Plans of newly installed or modified systems/equipment. This is currently the function of Facilities Engineering, with Acceptance Test Plans which are controlled by PNL-MA-90, "Design: Preparation, Control, and Implementation."

Improvements: Evaluate PM Program for effectiveness and adequacy of Post-Maintenance Testing Program to DOE Order 4330.4A requirements. Evaluation results will be incorporated into a revision of Craft Services P&P 11.1.0, "PM Program," which must also be revised to reflect current practice. Craft Services P&P 9.2.0, "Facility Work Control Procedure," will

also be evaluated for adequacy and adjusted to meet compliance criteria. The actions will be completed by August 31, 1993.

The term "rework" will be defined for Craft Services application and a procedure developed for implementation and use by May 31, 1993.

Arrangements will be made for Maintenance staff to be involved in ATP with Facilities Engineering by December 31, 1992.

4.4.8 Backlog Work Control

Objective: *Maintenance backlog (all outstanding corrective maintenance) should be monitored to ensure that the condition of the facility is maintained consistent with the facility's mission.*

- a. The maintenance backlog of work is measured in estimated man-hours and the number of work requests. This is used to adjust manning, as required.*

Discussion: Craft Services backlog of work is measured in estimated man-hours and number of work requests. This is used to adjust manpower, as required.

- b. The maintenance backlog is monitored to ensure that proper priority is given to facility conditions important to safety, environment, and facility mission.*

Discussion: Backlog is monitored through the planning and scheduling process as outlined in Craft Services P&P 10.1.1, "Planning and Scheduling Procedure." This procedure should be revised to reflect current practices.

- c. Deferred critical facility maintenance work is documented and justified in writing by management.*

Discussion: This is documented in the monthly maintenance backlog (PM Waiver Report).

- d. A maintenance work request is considered part of the backlog from the time the work is identified until all actions are complete, including post-maintenance testing and administrative reviews. Control is maintained by identifying and verifying the status of all valid work requests.*

Discussion: Maintenance work requests are considered part of the backlog from the time the work is identified until all actions are addressed. This includes Post-Maintenance testing, as required, as outlined in Craft Services P&P 9.2.0, "Work Control Procedure." Control is maintained as

outlined in Craft Services P&P 10.1.1, "Planning and Scheduling Procedure."

- e. *Backlog is reduced on the basis of prioritization and work significance.*

Discussion: The backlog is reduced on the basis of prioritization and facility safety significance. All Craft Services work is prioritized.

- f. *An analysis of maintenance backlog is performed and considers items such as the following:*

- (1) *Ratio of preventive to total maintenance;*
- (2) *Ratio of emergency-to-nonemergency maintenance; and*
- (3) *Number of man-hours required to reduce backlog to zero.*

Discussion: Craft Services performs an analysis of the backlog based on priority and number of work requests over 90 days old. Craft Services considers this a more effective measure of backlog than criteria in item f., because PNL has no emergency maintenance in backlog.

- g. *Budget and manpower levels are evaluated against both the planned maintenance and the amount of work in the backlog.*

Discussion: Both budget and manpower levels are evaluated for planned maintenance needs, which include the backlog.

- h. *The total amount of backlog is documented each fiscal year in the Site Maintenance Plan.*

Discussion: The backlog of maintenance will be addressed in the Site Maintenance Plan.

- i. *Performance measures are established to monitor the overall condition of the facility against the amount of work in the backlog.*

Discussion: Craft Services conducts an annual facility assessment to determine overall facility condition. This assessment is conducted with documented checklists. Documented deficiencies are used to justify budget requests.

Improvements: Revise Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," to reflect current practice and DOE Order 4330.4A by May 31, 1993.

Maintenance backlog will be documented in the Site Maintenance Plan by September 30, 1992.

4.4.9 Equipment Repair History and Vendor Information

Objective: *An equipment repair history and vendor information program should be established and maintained to provide historical information for maintenance planning and to support the maintenance and performance trending analysis of facility systems and components.*

- a. Equipment repair history is used to support maintenance activities, upgrade maintenance programs, optimize equipment performance, and improve equipment reliability.*
- b. The maintenance history program defines what data are to be collected, how the data are to be recorded, and how the data are to be used.*
- c. Maintenance history records are maintained for systems, equipment, and components that affect safe and reliable facility operations or could improve productivity and result in cost savings.*
- d. A cost-effective equipment history program is in place, including only the equipment that warrants special evaluation based on its initial cost, cost to maintain, and impact on facility safety or operations.*
- e. Maintenance records are closely correlated with the current issue of the facility master equipment list.*
- f. The facility master equipment list should be a compilation of system and equipment and provide an engineering data base.*
- g. Maintenance history records are considered in planning for corrective maintenance, modifications, and preventive maintenance, and development of facility life-cycle plans.*
- h. Maintenance history records are readily available for use by supervisors, work planners, and maintenance or plant engineers.*
- i. Maintenance history is periodically and systematically reviewed to identify equipment trends and persistent maintenance problems and to assess their impact on facility reliability.*
- j. Equipment maintenance and repair history files contain items such as the following: equipment and component identification, maintenance records, diagnostic monitoring data, vendor information (or a reference to this information), corrective and preventive maintenance or modification information, and spare parts information.*

- k. *The maintenance record is a chronological list of all maintenance repair work and materials expended on a piece of equipment or component.*
- l. *Equipment repair history data is used for such activities as failure analysis, conduct of maintenance assessments, preventive maintenance, outage planning, budget preparation, reviews of DOE-wide experience, and plant life extension.*
- m. *Vendor information obtained from suppliers is controlled and indexed for ready retrieval.*
- n. *Personnel using vendor manuals are provided with technically adequate documents that can be relied upon to provide best available information.*
- o. *A controlled vendor manual or information issuance program should consist of a controlled master set and verified satellite copies available for checkout.*

Discussion: Craft Services collects maintenance history only on critical equipment which is contained in the PM Program. However, this program is not formalized or well documented. A new procedure will be established to cover equipment history and all criteria in section 3.4.9 of DOE Order 4330.4A.

Craft Services P&P 16.1.0, "Certified Vendor Information (CVI) Files," addresses policy on this topic, but the procedure should be expanded to provide better detail of how Craft Services uses the filing system and what it can provide.

Improvements: A new procedure will be established to cover equipment history to comply with DOE Order 4330.4A by August 30, 1993.

Craft Services P&P 16.1.0, "CVI Files," will be revised to reflect DOE Order 4330.4A criteria by August 30, 1993.

4.5 Maintenance Facilities, Equipment and Materials Control System

4.5.1 Maintenance Facilities, Equipment, and Tools

Objective: *Maintenance facilities, equipment, and tools should be periodically reviewed for adequacy in supporting facility maintenance and maintenance training.*

- a. *Maintenance facilities, including storage facilities and*

laydown and staging areas, are sized and arranged to promote the safe and effective completion of work.

Discussion: Craft Services maintenance facilities, storage facilities, and laydown and staging areas are sized and arranged to promote safe and effective work completion. Additional shop and office space to the Central Maintenance Facility is currently being designed. Construction is planned for FY 1993.

- b. Maintenance training facilities, shops, satellite work areas, laydown and staging areas, storage facilities, mockups, temporary facilities, shower and toilet facilities, lunch areas, conference areas, and offices are evaluated for adequacy.*

Discussion: These items are under continual evaluation for adequacy. If performance starts to lag, or complaints are received, Craft Services facilities are evaluated as part of the root cause process for determining corrective actions.

- c. Work area lighting and other environmental conditions should promote safe and effective working conditions.*

Discussion: All parameters of Craft Services facilities meet OSHA compliance criteria to promote a safe and effective work environment.

- d. Work areas are uncluttered and in an orderly condition.*

Discussion: Work areas are uncluttered and in an orderly condition.

- e. Facility equipment is accessible for maintenance activities. Fixed local area hoists, ladders, and work platforms are provided, as needed.*

Discussion: Appropriate equipment/tools requested by maintenance craftsmen are promptly purchased. An adequate supply of tools and equipment is maintained.

- f. Storage facilities for parts and materials being gathered for or issued for a job are adequate and provide environmental controls to protect the parts and materials.*

Discussion: Storage facilities are currently considered adequate.

- g. Tool and equipment storage facilities are located near shops and normal work areas to improve maintenance efficiency.*

Discussion: Tools and equipment are stored in the shops where space allows and/or in storage warehouses within the maintenance facilities compound.

- h. Adequate office equipment is provided for efficient and effective work.*

Discussion: Adequate office equipment is provided.

- i. Communication equipment is reliable and provides necessary facility coverage.*

Discussion: Communication equipment is reliable and does provide necessary coverage.

- j. Facility equipment and associated components are properly labeled with sufficient information so that they can be easily identified by personnel.*

Discussion: Facility equipment in the Craft Services PM Program is labeled to provide sufficient information. Equipment labeling is an ongoing process.

- k. A plan for identifying and using maintenance laydown and staging areas is developed and kept current.*

Discussion: There is no plan for identifying and using maintenance laydown and staging areas. These areas are already identified and in continual use.

- l. Communications systems are available and arranged such that maintenance activities can be conducted without interfering with facility operations and controls. Areas that should be considered in particular are testing and troubleshooting of electrical and electronic equipment.*

Discussion: These systems are in place where deemed acceptable for use and do not interfere with facility operations and controls.

Improvements: No improvements are planned at this time.

4.5.2 Requisitioning/Procurement

Objective: *Parts, materials, and services required to perform maintenance activities should be available when needed.*

- a. An effective procurement process is provided to ensure that parts, materials, and services are available for work activities when they are scheduled.*

Discussion: Procurement activities at PNL are documented

and controlled by PNL-MA-67, "Procurement/Subcontracts User's Guide," and PNL-MA-70, "Quality Assurance Manual," Section PAP-70-401, Purchase Requisitions.

- b. *Procurement documents provide clear and adequate technical and quality assurance requirements consistent with design specifications.*

Discussion: Procurement documents are reviewed for clarity, and adequate technical and quality assurance requirements by Craft Services' QA Specialist, Material Coordinator and the PNL Purchasing Department. Any documents not meeting these minimum requirements are not processed and are returned to the originator.

- c. *Topics such as storage, in-storage preventive maintenance, and shelf-life requirements are addressed.*

Discussion: Applicable topics for each item purchased are addressed in the purchase order.

- d. *Proper engineering control and approval are obtained on any deviation from design specifications for parts or materials.*

Discussion: Documented guidance is given for various items/equipment when engineering approvals are required for deviations from original design specifications. For facility equipment/parts, Facilities Engineering must approve replacements or modifications from original specifications.

- e. *Mechanisms are in place to provide for the expeditious procurement of parts and material on a high priority basis when needed.*

Discussion: PNL-MA-67, "Procurement/Subcontracts User's Guide," contains provisions in the procurement procedures for emergency orders and emergency cash purchases, if the parts/materials can be located locally for quick purchase.

- f. *Methods are established to acquire replacement parts not available through the original supplier.*

Discussion: Approximately 95% of all parts are ordered out of catalogs from parts supply houses. The only requirement is that the parts ordered are a direct replacement part, or engineering approved substitute.

- g. *Lessons learned from experience, such as lead times, parts usage, and supplier reliability, are factored into materials management.*

Discussion: These topics are factored into materials management. Craft Services complies with PNL-MA-69, "Property Management," which gives direction for materials management.

- h. Material and parts activity are reviewed to determine possible new additions to be included in spare parts or site stores catalog.*

Discussion: Parts and material activities are reviewed annually. Any adjustments in spare parts or material storage levels are made as a result of the annual 90 day inventories required by PNL-MA-69.

- i. Off-site services are used when justified by specifications and/or economic reasons.*

Discussion: Off-site services are utilized when the work is beyond the capabilities of plant forces in regard to time frame, skills, or equipment, in accordance with the Battelle HAMTC Bargaining Unit Agreement.

- j. Purchased major electrical systems and equipment include provisions for isolation to permit disconnect for maintainability.*

Discussion: Electrical code systems must meet National Electrical Code requirements. This code requires disconnects.

- k. Long lead-time maintenance items services, and their procurement sources, are identified in order to expedite their procurement.*

Discussion: Any long lead-time items are identified and procured in advance of their need for maintenance work.

- l. Deficient or nonconforming items are resolved in an effective and timely manner.*

Discussion: Deficient or nonconforming items are placed in a locked area for physical control, and a Nonconformance Report issued in accordance with PNL-MA-70, "Quality Assurance Manual," Section PAP-70-1501, Nonconformance Reports. Resolution of the problem is then negotiated with the supplier through the Quality Programs and Procurement Departments.

- m. Quality assurance records are controlled and maintained to provide documentation for qualified parts and materials and to ensure traceability.*

Discussion: When requested and documented on the QCR Form for specific maintenance work, QA records are obtained, controlled and maintained for their intended purpose. This process is controlled by PNL-MA-70, "Quality Assurance Manual," Section PAP-70-404, Obtaining Services.

- n. Material Safety Data Sheets (MSDS) are obtained for hazardous materials and chemicals procured.*

Discussion: Craft Services maintains an MSDS file for hazardous materials and chemicals procured and used by Craft Services.

- o. Identification of the need for specialized services from vendors is made early to provide for timely submittal of, bidding on, and award of contracts.*

Discussion: This is conducted on a routine basis.

- p. Applicable quality assurance provisions of reference g., are followed.*

Discussion: The applicable QA provisions of reference g., above, are incorporated into PNL-MA-70, "Quality Assurance Manual." Craft Services maintains compliance with applicable sections of the "Quality Assurance Manual," which is documented in Craft Services' QA Plan, CSD-1, Revision 2.

Improvements: No improvements are planned at this time.

4.5.3 Materials Control

Objective: *All phases of receiving, inspecting, handling, storing, retrieving, and issuing of equipment, parts, and materials for maintenance should be covered by effectively implemented policies and procedures from the time an item is received until it is installed at the facility.*

- a. Effective material control is practical and is achieved when the right materials in the correct quantities are delivered to the job location at the proper time.*

Discussion: Craft Services feels that they achieve effective material control by obtaining correct quantities of materials that are delivered to the work location at the proper time.

- b. Policies and procedures are prepared to specifically describe the responsibilities and techniques for receiving, inspecting, handling, storing, retrieving, and issuing equipment, parts, and materials.*

Discussion: Craft Services P&P, Section 8.0, "Materials Control," contains a series of procedures for controlling various types of material and parts from receipt to installation. These are also enhanced by PNL-MA-70, "Quality Assurance Manual" PAP-70-1401, Inspection and Testing Status and Tagging; PAP-70-1301, Handling, Storage, and Shipping; PAP-70-1001, In-Process and Final Inspection; PAP-70-803, Item Identification and Control; PAP-70-706, Receiving Inspection; and PAP-70-401, Purchase Requisitions.

- c. *Procedures/instructions are available for items requiring special handling.*

Discussion: Currently, there are no items within Craft Services which require special handling; therefore, there are no applicable procedures/instructions. However, the "Quality Assurance Manual" procedures remain a reminder that if an item does need special handling a procedure is required.

- d. *Material is inspected to ensure conformance to purchasing requirements prior to release for use and storage.*

Discussion: Materials are inspected to ensure conformance to requirements by the individual purchaser. In some cases, when warranted and/or required by compliance criteria, materials are inspected by a third party individual.

- e. *Documentation for received material can be accounted for and is retrievable.*

Discussion: Materials are accompanied by a Material Receiving Report, which is traceable to the applicable purchase order number. These reports are in computer files.

- f. *Nonconforming items are identified with tags or labels and controlled to prevent unauthorized use.*

Discussion: Nonconforming items are tagged and locked up in designated areas until the item is returned to the vendor or the nonconformance is dispositioned. This process is controlled by PNL-MA-70, "Quality Assurance Manual," Section PAP-70-1501, Nonconformance Reports.

- g. *Effective material procurement status is provided, including accurate stock records and tracking of purchase orders.*

Discussion: Effective material procurement status and

tracking of purchase orders is provided by PNL's Integrated Procurement and Accounts Payable (IPAP) computerized purchasing program. Craft Services purchases, except emergency cash purchases, are made by computer directly to the Purchasing Department. The status of an order can be obtained at any time.

- h. Materials are stored, protected, and identified in a manner that provides ready availability for its intended use.*

Discussion: Materials are stored, protected, and identified, which provides ready availability.

- i. A shelf-life control program is provided for store items that are important to safe and reliable facility operation.*

Discussion: No shelf-life control program is currently in place with Craft Services for facility material/parts. Craft Services is aware of the need for such programs; however, there are no currently stocked items which have shelf-life restrictions. If needed in the future, a shelf-life control program will be implemented.

- j. Safety-related and nonsafety-related materials and equipment are segregated from each other to prevent inadvertent use of the wrong category of item.*

Discussion: Safety-related items, when designated by the controlling organization (Safety, Security, Facilities Engineering, etc.), are segregated, maintained under lock and key conditions, and only issued for specific maintenance functions. Two current programs in place are controlled by Craft Services P&P 8.1.8, "Security Spare Parts Inventory," and 8.1.9, "Fire System Spare Parts Inventory."

- k. Periodic inspections of staging areas, stores, and warehouses are performed.*

Discussion: These areas are routinely inspected at least quarterly by Craft Services management, and at least monthly by supervisors.

- l. The quality of stored equipment, parts, and materials is maintained in accordance with vendor information by appropriate means, such as environmental and shelf-life controls and preventive maintenance activities, if necessary.*

Discussion: Materials are stored within vendor provided

guidance and/or industry guidance. Environmental and shelf-life controls are provided, if necessary. Currently, no materials are on hand which require either the environmental or shelf-life control systems.

- m. *Parts and materials issued for installation are properly controlled. Unused parts and materials should be promptly returned to a controlled storage area. Completed work requests/orders document material traceability.*

Discussion: Parts and materials are issued for use and are properly controlled, with unused materials returned to controlled storage areas when warranted by the job (example, weld rod). Completed work documents will document material traceability when requested by the customer.

- n. *Critical parts are readily traceable from purchase to installation.*

Discussion: Critical parts will show traceability from purchase to installation, when requested, and be documented on the QCR Form.

- o. *Flammable and hazardous materials are identified, segregated, and properly controlled during receipt inspection, storage, and issuance.*

Discussion: Flammable and hazardous materials are identified, segregated, and properly controlled per PNL-MA-43, "Industrial Hygiene, Occupational Safety, and Fire Protection Programs." Craft Services maintains constant compliance to this manual.

- p. *Equipment and materials used by nonfacility personnel (personnel not directly employed by the facility operating contractor) are subject to inspection, storage, and issuance controls equivalent to items received through normal facility processes.*

Discussion: Facilities Engineering controls contracted out work (work by nonfacility personnel).

- q. *For items requiring special handling instructions, procedures are prepared that include such items as the weight, size, chemical reactivity, radioactivity and susceptibility to physical shock, damage, or electrostatic sensitivity. This also includes lifting instructions.*

Discussion: Currently, Craft Services does not have any items requiring special handling instructions. If a

procedure was necessary, the above criteria would be reviewed for applicability.

Improvements: No improvements are planned at this time.

4.5.4 Control and Calibration of Measuring and Test Equipment

Objective: *A program for control and calibration of measuring and test equipment (M&TE) should be instituted to ensure the availability of tools and equipment necessary for maintenance, repair, and calibration of installed equipment and instruments.*

- a. M&TE includes all devices or systems used to inspect, test, calibrate, measure, or troubleshoot in order to control or acquire data for verifying the conformance of an instrument or piece of equipment to specified requirements.*

Discussion: Craft Services feels it is in compliance with the statement made in criteria a., above.

- b. M&TE does not include permanently installed system instrumentation, nor does it include test equipment used for preliminary checks where data obtained will not be used to determine acceptability or verify conformance to established criteria.*

Discussion: Craft Services feels it is in compliance with the statement made in criteria b., above.

- c. All M&TE devices have unique identification numbers that accurately identify the specific devices and provide positive traceability.*

Discussion: Craft Services M&TE devices have unique numbers assigned to them by the Westinghouse Hanford Calibration Standards Laboratory when they are first calibrated. PNL contracts Westinghouse for its calibration services.

- d. A master list identifying all M&TE is developed and kept current.*

Discussion: Craft Services maintains a master listing of M&TE. This listing is kept current and provided to the Quality Programs Department on an annual basis.

- e. The M&TE calibration program is based on standards that are traceable to a national standard or that are recognized standards unto themselves.*

Discussion: Craft Services M&TE items are calibrated with standards that are traceable to the National Institute of Standards and Technology.

- f. Procedures are used to calibrate M&TE control the performance of calibrations, provide repeatable calibrations, and provide acceptance criteria.*

Discussion: Craft Services maintains the Craft Services CAL Manual which contains policy for the Calibration Program and actual calibration procedures. This manual is in compliance with PNL-MA-70, "Quality Assurance Manual," Section PAP-70-1201, Calibration Control System.

- g. A calibration frequency that helps maintain M&TE accuracy and availability is established.*

Discussion: Calibration frequencies are established for each piece of M&TE within the guidance set down in Craft Services' CAL Manual.

- h. Procedures specify that M&TE should be functionally checked before use.*

Discussion: If a particular piece of M&TE needs to be functionally checked before use, the calibration procedure describes the check to be performed.

- i. Facilities are provided to control storage, issuance, and calibration of M&TE.*

Discussion: M&TE is provided designated storage areas to control, issue and maintain its calibrated accuracies.

- j. Any M&TE with suspected or actual deficiencies is segregated and marked to prohibit its use.*

Discussion: Suspect or deficient M&TE is segregated, tagged, and over-checked for accuracy. Equipment calibrated, or checked, with the suspect M&TE rechecked for accuracy.

- k. M&TE devices that are not fully calibrated or usable are clearly marked to indicate their limitations.*

Discussion: M&TE in this category have what is designated a limited calibration. They receive a special colored calibration label which documents the instrument's limitations.

- l. M&TE documentation includes records for accountability and*

traceability of use. A recall system is developed for recalibrations.

Discussion: Craft Services has a computerized recall system for recalibration efforts, which also provides accountability and traceability of calibrations made by any M&TE.

- m. M&TE devices found out of calibration or defective receive timely evaluations to determine the validity of all measurements/tests for which they were used.*

Discussion: M&TE found out of calibration or defective are immediately tagged out of service, segregated from other M&TE, and their accuracy over-checked to determine margins of error. Then all instrumentation/equipment checked by the M&TE is over-checked for accuracy.

- n. M&TE reliability problems are trended to determine any corrective actions needed.*

Discussion: M&TE reliability problems are trended to correct any negative trends. A maintenance/calibration history is maintained on all M&TE.

- o. Periodic reviews are conducted to determine that the control of M&TE is effective.*

Discussion: Craft Services' M&TE Program is routinely audited by the Quality Programs Department, and various other auditing organizations, in order to evaluate the effectiveness of the program.

- p. Critical equipment calibrated with out-of-tolerance test equipment are evaluated in a timely manner for operability and should be recalibrated as necessary.*

Discussion: As soon as out-of-tolerance M&TE is identified, a computer printout is obtained which lists all equipment/instruments calibrated with the defective M&TE. The calibration accuracy of these pieces of equipment/instruments will be over-checked and recalibrated, as required.

- q. Results of M&TE calibrations are trended, and corrective actions are determined for any M&TE reliability problems.*

Discussion: M&TE results are trended for abnormalities, and any reliability issues are addressed and resolved.

Improvements: No improvements are planned at this time.

4.5.5 Maintenance Tools and Equipment Control

Objective: *Methods should be established to provide for the storage, issue, and maintenance of an adequate and readily available supply of tools and equipment and also for the development of special tools and equipment needed in the maintenance program.*

- a. *Proper tools, equipment, and consumable supplies are available to support work requirements.*

Discussion: Craft Services provides tools, equipment, and supplies needed to support maintenance activities. Special or recommended tools, equipment and supplies needed by craftsmen are purchased.

- b. *The process of providing tools and equipment for the facility includes proper storage and issue controls.*

Discussion: Tools and equipment are correctly stored and controlled within the guidelines of PNL-MA-69, "Property Management."

- c. *Special tools, jigs, and fixtures should be identified and stored to permit retrieval when needed.*

Discussion: Special tools, jigs, and fixtures are identified and have designated storage areas.

- d. *Proper loading, lifting, and transporting equipment are available for movement of large equipment.*

Discussion: If proper loading, lifting, and transporting equipment is not available for a specific task, it will be obtained.

- e. *Maintenance tools and other support equipment are included in the preventive maintenance program.*

Discussion: When the tools/equipment design designates required maintenance, it is added to the PM Program for maintenance.

- f. *Special tools, test rigs, special equipment, lifting and rigging equipment, and mockups are suitable for their intended use and properly identified.*

Discussion: Craft Services equipment/tools are properly identified and suitable for their intended function.

- g. *Specific instructions are provided to control the use of lifting and rigging equipment.*

Discussion: The Site-wide Hanford Hoisting and Rigging Manual, WHC-CM-6-4, is required to be used by all Hanford Contractors. PNL is in full compliance with this manual.

- h. Scaffolding and rigging equipment are identified, tested, and properly stored.*

Discussion: Scaffolding and rigging equipment is controlled by the Hanford Hoisting and Rigging Manual, and PNL-MA-43, "Industrial Hygiene, Occupational Safety, and Fire Protection Programs."

- i. Equipment and tools are maintained in a high state of readiness.*

Discussion: Defective or broken tools/equipment are immediately discarded or repaired. Only tools/equipment in good working order are available for use.

- j. Fixed local area hoists and work platforms are provided, as needed, to facilitate maintenance access to facility equipment.*

Discussion: Facility equipment requiring maintenance has some form of safe access.

- k. The process of providing and developing tools and equipment for the facility include consideration of safety, availability for future use, cost-effectiveness, control, and storage.*

Discussion: All aspects of this criteria are considered when obtaining or developing tools and equipment.

- l. Worn, defective, or otherwise unusable tools are identified, segregated, and disposed of so that only safe, usable tools are available for use.*

Discussion: Defective tools are immediately excessed, disposed of, or repaired. Only safe usable tools are available for craftsmen's use.

Improvements: No improvements are planned at this time.

4.6 Implementation of Maintenance Activities

4.6.1 Surveillance and Preventive Maintenance

Objective: *Surveillance, inspecting, and testing activities should provide assurance that the equipment needed for safe and reliable facility operation performs within required limits and that preventive maintenance (PM), defined as*

including periodic and planned maintenance, is utilized to maintain a piece of equipment within design operating conditions and to realize its maximum reasonable useful life.

- a. *A master list of equipment to be included in the PM program is developed and analyzed for cost-effectiveness.*

Discussion: A master list of equipment in the PM Program does exist, along with a listing of items submitted for inclusion into the program. Craft Services does an annual review of this listing to adjust frequency and eliminate equipment from the system, when appropriate.

- b. *An effective preventive maintenance program is implemented and includes systems and equipment that affect safe and reliable facility operation.*

Discussion: Craft Services' PM Program is documented in Craft Services P&P 11.1.0, "PM Program," which sets down operation performance parameters. This procedure should be expanded to address all criteria listed in Section 3.6.1. The PM Program includes equipment that affects safe and reliable facility operations. This equipment is assigned Safety Classifications which define safety importance and the degree of detailed maintenance which is provided. Equipment is assigned Safety Classifications by the interim procedure for Implementation of the Safety Classification System.

- c. *Preventive maintenance is performed at predetermined and scheduled intervals and seeks to maximize equipment availability.*

Discussion: PM Checklist Standards are performed at predetermined scheduled intervals. These intervals are determined by vendor recommendations, engineering input, and equipment history.

- d. *Considerations such as operational experience, vendor recommendations, engineering analysis, cost/benefit analysis, and especially reliability considerations are used as a basis to establish preventive maintenance tasks and intervals.*

Discussion: Sources of data listed in criteria d. are used if available. PM tasks and intervals are processed through the Craft Services' PM Specialist and must be approved by the various organizations who approve the PM Standard Checklists.

- e. *Preventive maintenance activities are scheduled and performed within established intervals and, when possible,*

combined with corrective maintenance activities on the same equipment. Preventive maintenance is waived or deferred only with management approval.

Discussion: PM activities are scheduled and performed within established intervals. A PM Waiver can only be approved by management.

- f. Preventive maintenance documentation provides a record of activities performed, data collected, and, where appropriate, the "as-found" and "as-left" condition of the equipment.*

Discussion: PMs are documented on Craft Services PM Standard Checklists. These Checklists are filled out as the maintenance is performed by the craftsman in the field. Requested data information is also filled in at the time of performance.

- g. Preventive maintenance is utilized to assess equipment performance, make adjustments, and perform other corrective actions where needed.*

Discussion: All functions in criteria g. are performed within the PM Program.

- h. Preventive maintenance work procedures are utilized for facility equipment requiring special permits, special plant conditions or line up, and/or special tools, parts, or lubricants.*

Discussion: All items in criteria h., when warranted, are incorporated into the PM Standard Checklist for the specific piece of equipment.

- i. As part of the maintenance surveillance program, functional tests of installed equipment and/or systems (such as standby equipment or nonoperating equipment scheduled for rotation) are conducted and documented.*

Discussion: Many pieces of equipment and/or systems within the PM Program are on a functional testing program. The majority of this equipment is on a standby basis. A good example of this equipment is the emergency back-up generators.

- j. Trending data is acquired as part of the maintenance surveillance program for long-term performance evaluations, such as bearing temperatures, pump speed, and vibration data.*

Discussion: Vibration analysis routes, which gather

vibration data for trending, are performed on a routine basis. For designated rotating equipment such as fans, pumps, etc., temperatures and speeds are also recorded on selected pieces of equipment.

- k. Administrative systems and controls provide for timely completion and review of required surveillances.*

Discussion: Craft Services P&P 11.1.0, "PM Program," requires that assigned PMs for a particular month be performed and returned to the PM Specialist by the third working day of the following month for review. This requirement is strictly applied in order for the PM Program to function as scheduled.

- l. Maintenance surveillance testing programs result in a degree of reliability in the equipment needed for safe facility operation.*

Discussion: Surveillance testing programs such as the Vibration Analysis Program produces a high degree of reliability at a substantial cost savings.

- m. The effectiveness of the surveillance program is periodically evaluated at an appropriate level of management and the results used to make program improvements.*

Discussion: The effectiveness of the surveillance programs are consistently under management evaluation in order to gain program improvements.

- n. Abnormalities found during surveillances or preventive maintenance are immediately reported to higher authority.*

Discussion: Abnormalities are documented on the PM Standard Checklist. Completed Checklists are reviewed by the assigned supervisor and PM Specialist for satisfactory completion of work and for any abnormalities which must be corrected. If the abnormality is safety related, the craftsman has the responsibility to immediately report the condition to his/her supervisor and/or the Laboratory Safety Department.

- o. The basis for the planned preventive maintenance program is documented. Any deferral of preventive maintenance tasks has a technical basis.*

Discussion: The basis for the PM Program is documented in Craft Services P&P 11.1.0, PM Program. Deferral of a PM is processed on a PM Waiver. PM Waivers that are granted are technical in nature.

Improvements: No improvements are planned at this time.

4.6.2 Predictive Maintenance

Objective: *A predictive maintenance program should be established and utilized to monitor; determine trends; analyze parameters, properties, and performance characteristics or signatures of equipment in order to forecast equipment degradation so that "as-needed" planned maintenance can be performed prior to equipment failure.*

- a. Predictive maintenance techniques, such as reliability-centered maintenance (RCM) programs, are used to identify the need for preventive maintenance prior to equipment failure so that the predictive maintenance program is effective in reducing the failure of structures, systems, and components.*

Discussion: Performance of predictive maintenance is documented under Craft Services P&P 11.1.0, PM Program. Vibration analysis on rotating equipment and oil analysis is mainly used. These programs can determine failure modes, so that the PM can be performed before failure on a routine basis instead of an emergency basis after failure.

- b. The data gathered from tests, diagnostic equipment, fluid analysis, and other similar methods are analyzed, trends identified, and action plans/corrective actions defined.*

Discussion: The Vibration Analysis Program is a computerized analysis program which plots vibration trends and predicts bearing failures. From this data, bearings are replaced as a step in the routine PM before they fail. This procedure will be applied to other predictive maintenance techniques as they are developed.

- c. In-process monitoring of equipment is controlled by establishing the proper conditions, systems configuration, and operating parameters to help ensure that the data collected are comparable and trendable.*

Discussion: Parameters for the various predictive maintenance activities are determined and controlled in order to obtain comparable results.

- d. Equipment monitoring locations are identified and marked to obtain consistent readings each time predictive maintenance data are recorded.*

Discussion: Vibration analysis routes are established and each piece of equipment is identified. Probe sensing

locations are marked on each piece of equipment so repeat monitoring results can be compared.

- e. *Mechanisms are established to provide feedback to the facility maintenance program in time to preclude equipment failure.*

Discussion: Craft Services P&P 11.1.0, "PM Program," documents the method and frequency of documenting Predictive Maintenance Program results so equipment failures can be avoided.

- f. *The predictive maintenance program provides data to the preventive maintenance program and provides for retrieval of equipment history data.*

Discussion: The Predictive Maintenance Program is part of the PM program, which does provide equipment history data.

- g. *For all system/component/part failures, the root cause is determined, if possible, and the preventive maintenance program modified, as required, by feed-back of actions taken or results.*

Discussion: If any failures develop a common trend, the PM Program will be modified to aid in eliminating any negative trends.

- h. *Because all equipment conditions and failure modes cannot be monitored, predictive maintenance is selectively applied where experience indicates that it is most cost-effective or best enhances safety.*

Discussion: Predictive maintenance is selectively applied to high safety risk equipment/systems and where the most cost-effective results can be obtained.

Improvements: No improvements are planned at this time.

4.6.3 Corrective (Repair) Maintenance

Objective: *Corrective (repair) maintenance should be performed in a manner ensuring that quality repairs are performed and that equipment failing or malfunctioning during service is restored in a timely manner.*

- a. *A detailed master list of equipment, components, and structures to be included in the maintenance program is developed.*

Discussion: A master list of critical equipment,

components, systems, and structures is maintained for the PM Program.

- b. *Maintenance personnel are attentive to identifying and correcting facility deficiencies with a goal of maintaining equipment/systems in optimum operating condition.*

Discussion: Maintenance personnel are attentive to identifying and correcting facility deficiencies.

- c. *Corrective maintenance activities are controlled to ensure equipment and/or systems are returned to normal operating configuration.*

Discussion: Corrective maintenance activities are controlled per Craft Services P&P 9.2.0, "Facilities Work Control Procedure."

- d. *Good maintenance work practices are followed, including:*

- (1) *Proper tools and equipment are used;*
- (2) *Good safety practices are followed;*
- (3) *Foreign materials and contaminants are excluded from open systems and equipment;*
- (4) *Prejob briefings; training; job procedure use; quality workmanship, materials, and parts; and proper postjob reporting are utilized; and*
- (5) *Work sites are clean and orderly.*

Discussion: Good maintenance work practices are established and followed.

- e. *Corrective maintenance activities should ensure that the condition that caused the failure is identified, corrected, and documented.*

Discussion: This is a routine step for corrective maintenance activities.

Improvements: No improvements are planned at this time.

4.6.4 Modification Work (Non-Davis-Bacon)

Objective: *Facility modification and temporary modification work should be accomplished under the same basic administrative controls as those applied to facility maintenance activities. Changes to the maintenance program to incorporate facility modifications should be commensurate with the complexity of the task, the extent of the modification, and the importance of the equipment.*

- a. *Temporary modifications, defined as temporary repairs to the facility allowing equipment to remain in or be returned to service in a condition that is not the same as the original design specification, receive appropriate reviews prior to implementation to ensure the adequacy of the repair and to assess its effect on personnel and equipment safety and reliability.*

Discussion: Temporary modifications are required to be approved by Facilities Engineering, and depending on the type of modification they will be reviewed and approved by Laboratory Safety. This is covered by Craft Services P&P 9.2.0, "Facilities Work Control Procedure."

- b. *Temporary modifications are tracked after their completion for consideration of permanent repairs. Permanent corrective action is taken as soon as practicable.*

Discussion: When temporary/emergency modifications are performed, an Engineering Request is issued and tracked to ensure that a permanent fix/modification is obtained.

- c. *Prior to implementation, a review is performed to look at facility modifications to determine future required maintenance activities and to specify that these activities be added to the maintenance surveillance, preventative, and predictive programs, as applicable.*

Discussion: Modification permits are reviewed by members of the PM review committee to select equipment/systems which will require maintenance and incorporate them into the PM Program.

- d. *Changes to facility processes, alarm setpoints, and computer software required by facility modifications are controlled.*

Discussion: Changes to facility processes, alarms, etc., requires Facilities Engineering approval. This process is controlled by Craft Services P&P 9.2.0, "Facilities Work Control Procedure."

- e. *The modifications packages identify changes to the spare parts system, dispositions of parts/material reused, etc.*

Discussion: Modification permits and associated work documents will identify necessary spare parts and/or disposition of parts/materials reused.

- f. *Documents affected by plant modifications, such as drawings and procedures commonly used for system*

operation, tagouts, and maintenance, are updated prior to operation of the system or equipment.

Discussion: Documents affected by modifications such as drawings, etc., are the responsibility of Facilities Engineering to be as-built. The person or organization responsible for affected procedures is responsible for their revisions.

- g. On-site modifications, rework, and repairs performed by vendors or construction forces are controlled in a similar manner as other work activities.*

Discussion: Work performed by vendors or construction forces is controlled by Facilities Engineering within the guidelines of PNL-MA-90, "Design: Preparation, Control, and Implementation."

Improvements: No improvements are planned at this time.

4.7 Maintenance Evaluation and Analysis

4.7.1 Analysis of Root Causes of Problems

Objective: *A systematic analysis methodology should be used to determine and correct root causes of problems, unplanned events, and occurrences related to maintenance.*

- a. Recurring maintenance problems are reduced by identifying and resolving the root causes of the problems.*

Discussion: Craft Services identifies and corrects root causes of unplanned events, and occurrences related to maintenance in accordance with DOE Order 5000.3A, Occurrence Reporting.

- b. An analysis program is established to investigate unplanned occurrences that have an impact on safety or reliability or are of a recurring nature. This program includes the methodical collection of facts describing the unplanned occurrence.*

- (1) All available information analyzed and probable causes of an incident or problem should be evaluated.*
- (2) Analyses of information should include one or more analysis techniques, including the following techniques: event and causal factor charting; barrier analysis; walk-through task analysis; change analysis; and fault tree analysis.*
- (3) Outside experts are utilized when required.*

Discussion: PNL uses DOE Order 5000.3A, Occurrence Reporting and Processing of Operations Information.

c. An acceptable root cause will meet the following criteria:

- (1) Its correction prevents recurrence of the unplanned occurrence;*
- (2) Its correction is feasible; and*
- (3) Its correction does not adversely impact safety, reliability, or operational goals.*

Discussion: The topic of root causes is covered in DOE Order 5000.3A, Occurrence Reporting and Processing of Operations, which satisfies the topics addressed in criteria c.

d. Root causes are categorized in terms of either human performance or equipment performance.

Discussion: These two categories are used; however, DOE Order 5000.3A breaks root causes down into other categories such as procedure-related, etc.

e. When all root causes involved have been determined, a corrective action plan is developed, executed, and tracked to completion.

Discussion: This is covered in DOE Order 5000.3A. Corrective actions are tracked by the Performance Assurance Group.

f. The analysis program addresses any generic corrective actions that need to be taken after problems with the specific piece of equipment have been determined and corrected.

Discussion: This is covered in DOE Order 5000.3A.

g. After analysis is performed to determine the root cause(s) of failure, corrective action is taken that includes feedback into the preventive and predictive maintenance programs and maintenance training and qualification programs.

Discussion: This is covered in DOE Order 5000.3A, and Occurrence Reports.

Improvements: No improvements are planned at this time.

4.7.2 Periodic Review and Analysis

Objective: *Facility and/or maintenance managers should*

develop and utilize standardized procedures, methodologies, and systems for the review and analyses of the efficiency of their maintenance programs.

- a. *A periodic assessment of equipment, systems, and facilities is conducted to adjust preventive maintenance actions and tools and equipment availability and to determine inadequacies.*

Discussion: Refer to Section 3.2.2, Condition Assessment Surveys. This section answers criteria a.

- b. *Reviews of the overall effectiveness and efficiency of the procurement and material control process are conducted.*

Discussion: Craft Services monitors the effectiveness and efficiency of the procurement and material control process on a continuous basis. In addition, the Quality Programs Department conducts an annual audit of Craft Services' QA Plan, which covers procurement and material control.

- c. *Measuring and test equipment is periodically reviewed to verify that it is supporting the safe and reliable operation of the facility.*

Discussion: Craft Services continuously reviews measuring and testing equipment to verify safe and reliable operation. This program also receives independent audits and surveys from the Quality Programs Department and DOE.

- d. *The maintenance training program is periodically reviewed to identify training program enhancements or changes in emphasis.*

Discussion: Craft Services monitors this program to gain enhancements of performance. This program is also extensively audited by third party organizations.

- e. *The work control system is periodically reviewed to ensure that documentation is consistent with the work accomplished and that all necessary work is being accomplished.*

Discussion: This program is monitored by Craft Services and audited/surveyed by the Quality Programs Department.

- f. *Review of a consistent broad range of performance indicators is performed periodically.*

Discussion: Craft Services has a broad range of performance indicators which are reviewed periodically.

- g. The results of this review and analysis are used as the basis for program improvements such as the following:*
- (1) Adjustments to preventive maintenance frequencies;*
 - (2) Addition or deletion of preventive maintenance activities;*
 - (3) Proposed design changes;*
 - (4) Adjustments to spare parts and materials stock levels;*
 - (5) Adjustments to manpower and/or training; and*
 - (6) Adjustments in tools, equipment, and facilities or modifications to improve facility equipment maintainability.*

Discussion: All items in criteria g. have been, and will continue to be, affected by the PM Program performance indicators.

- h. The backlog management program is periodically reviewed to verify that actions are effective in maintaining or reducing the backlog to comply with the Backlog Work Control criteria*

Discussion: The PM Program backlog is reviewed monthly to verify that actions are effective in maintaining or reducing the backlog.

Improvements: No improvements are planned at this time.

4.7.3 Performance Measurement and Improvement

Objective: *Management and maintenance organizations should have a quantitative means of measuring performance and effectiveness to improve the maintenance systems.*

- a. Each maintenance organization develops a method of measuring maintenance system performance (such as the maintenance and repair costs of buildings measured in dollars per square foot, the growth of backlog of maintenance and repair, the amount of unscheduled maintenance and repair costs, the amount of emergency maintenance costs, or other similar items).*

Discussion: Craft Services tracks repair cost of buildings measured in costs per square foot, amount of emergency maintenance cost, and backlog of maintenance and repair on a regular basis.

- b. Programs are routinely implemented to monitor, collect, trend, and analyze performance data (including thermal, hydraulic, electrical, acoustical, and mechanical data) for equipment, systems, and components important to facility reliability and efficiency.*

Discussion: Various programs are implemented into the PM Program which monitor, collect, trend and analyze performance data. Examples of these are the Vibrations Analysis Program; Oil Analysis Program; and Third Party Inspection Programs for pressure vessels, safety relief valves, and elevators.

- c. *Performance data is analyzed and the results used to determine the reliability of key facility systems and components and to identify ways to optimize facility reliability and efficiency.*

Discussion: The results of the various monitoring programs are analyzed and the results used to determine equipment/system reliability.

- d. *Maintenance performance indicators and trends such as the following are used to focus management attention on areas that should be documented and addressed:*

- (1) Post-maintenance test results;*
- (2) Periodic surveillance test results;*
- (3) Ratio of preventive maintenance costs to corrective maintenance costs;*
- (4) Maintenance work request backlog;*
- (5) Time to restore component function after failure discovery; and*
- (6) Frequency of maintenance rework.*

Discussion: Maintenance performance indicators are established throughout the Maintenance Program in order to measure performance and efficiency, as needed. The aspects in criteria d. are utilized as appropriate in the Craft Services maintenance program.

- e. *Performance indicators enable a maintenance manager to quantitatively track progress toward defined goals.*

Discussion: Goals and parameters are established for performance indicators, in order to monitor performance within acceptable limits and to measure success or failure of specific goals.

Improvements: No improvements are planned at this time.

4.7.4 Management Involvement

Objective: *To enhance the safety of facility operations, maintenance managers should be sufficiently involved with facility operations and maintenance to be technically informed and personally familiar with conditions at the operating facility.*

- a. *Maintenance managers are involved and know what is going on by frequently touring the facility. Effective corrective actions are taken for noted problems. The maintenance program is periodically reviewed by facility management in self-assessments.*

Discussion: Maintenance managers tour their facilities at every opportunity using walk-throughs, specific shop visits, or staff meetings in facility areas. Formal documented inspections are conducted by maintenance managers on a quarterly basis.

- b. *Maintenance performance is checked by observing people at work and also by inspecting, monitoring, and checking equipment and by timely follow-up of corrective actions. Personnel perform at a higher level when their activities are observed, appropriately recognized, and supported.*

Discussion: Craft Services currently meets this performance objective.

- c. *Maintenance managers include time in their routine schedules for walking through the facility.*

Discussion: See response to criteria a., above.

- d. *Facility tours and personnel contacts are also performed during "off-shifts" and cover selected facility areas and personnel activities. The results and observations of these tours are documented and corrective action plans created where appropriate.*

Discussion: Craft Services does not have any off-shifts. Overtime is directed by supervisors.

- e. *Senior managers monitor the assessment activities of their subordinate managers and supervisors.*

Discussion: The Manager, Craft Services, receives copies of assessment activities being performed within Craft Services. There is also a corrective actions log, which allows Craft Services management to monitor progress on activities to ensure timely completion of actions.

- f. *Management and supervisory assessment and improvement efforts are performance oriented. Line managers and supervisors are responsible for determining and implementing corrective actions.*

Discussion: Line managers and supervisors are responsible for determining and implementing corrective actions, which are monitored by the QA and Compliance Specialist.

- g. Selected operational data reflecting facility performance are analyzed and trended, and the results are forwarded to appropriate levels of management.*

Discussion: Selected performance data, which exhibit negative trends and results, are forwarded to the appropriate levels of management for notification and input to corrective actions.

- h. Root causes are determined for problems identified during monitoring of facility activities and by analysis of trends. Corrective actions are initiated and tracked to completion.*

Discussion: Root causes are determined for identified problems, and corrective actions tracked by Craft Services Action Item Log.

- i. Management assessments are conducted to determine the reasons for success or failure in achieving objectives. Results are incorporated into future objectives.*

Discussion: A Management Assessment self-appraisal to DOE-EH 0135, "Performance Objectives and Criteria for Technical Safety Appraisals at Department of Energy Facilities and Sites," was completed on August 30, 1991. A schedule to perform self-assessments to DOE Order 4330.4A, Section 4.1, "Self-Assessments" has been established.

- j. Maintenance management establishes the percentage of time that first line supervisors are expected to spend supervising field work.*

Discussion: Maintenance management does establish guidelines for first line supervisors' performance and time expected supervising field work.

- k. A key element of management involvement is the establishment of a feedback system to identify problem areas and create participation in improvements.*

Discussion: Adequate and effective feedback systems are currently in place in Craft Services. These include the open door policy, crafts safety committee, safety inspection walk-throughs performed by Craft Services management, safety inspections by Laboratory Safety, and various audit/surveillance programs.

Improvements: No improvements are planned at this time.

4.7.5 Work Sampling

Objective: *A work-sampling program for the purpose of determining the extent of various craft activities and their related delay times should be established such that they may be used to measure the utilization of crafts in performing work in a maintenance management program.*

- a. When performing work sampling, the craft or shop group is utilized as the unit of measure, not the individual craftsman.*
- b. When performing work sampling, the categories of time affecting the total job (such as travel, job preparation, direct work, and delay time or idle status associated with the work activities) are determined and utilized.*
- c. Work sampling provides a base case or basis against which all subsequent improvements can be measured.*
- d. Work sampling is utilized to measure the effects of planned improvements to craft utilization.*
- e. Maintenance performance is checked by observing people at work.*

Discussion: *Craft Services does not have a formal work-sampling program.*

Improvements: *Develop a work-sampling program and procedures by August 31, 1993.*

4.7.6 Cost Identification and Control

Objective: *Cost accumulation and reporting systems should be established to facilitate the work control system utilized to evaluate maintenance performance.*

- a. Accounting for maintenance is established to allow management to understand clearly the scope of planned maintenance efforts for the funding allotted.*

Discussion: *PNL accounting practices are outlined in PNL's Management Guide. Craft Services' accounting practices are outlined in Craft Services P&P, Section 7, "Budgets and Cost Control." These procedures document the process for establishing the scope of planned maintenance efforts for allotted funding. Craft Services P&P, Section 7, needs to be revised to reflect current practice.*

- b. Procedures are in place to define proper cost coding and cost verification.*

Discussion: Cost Accounting has provided a manual which defines proper charging guidelines.

- c. *Managers and supervisors review cost data to prevent overruns and to detect adverse trends.*

Discussion: Craft Services Management reviews cost data on a routine monthly basis, and more frequently if a particular account is having problems.

- d. *Estimated job costs from the planning effort are evaluated against final job costs.*

Discussion: Estimated job costs are compared to actual costs.

- e. *Budgets are justified by factual or historical maintenance costs or by some other industry-recognized method that provides information on the resources required to maintain the capital asset in a state of good repair.*

Discussion: Budgets are justified based upon historical maintenance costs, with provisions for justified new initiatives, i.e., compliance with new Orders, codes, and/or law.

Improvements: Revise Craft Services P&P, Section 7, "Budgets and Cost Control," to reflect current practice by September 30, 1993.

4.7.7 Audits and Lessons Learned

Objective: *External and internal audits, such as self-assessments, lessons learned, and experience from other DOE sites, should be utilized and evaluated and appropriate changes to systems, procedures, and management concepts should be made to obtain needed improvements and/or to delete nonessential, noncost-effective, or redundant activities.*

- a. *Inspections, audits, reviews, investigations, and self-assessments are utilized to provide feedback to the maintenance program.*

Discussion: All aspects of criteria a. are used to provide feedback and improvements in the maintenance program.

- b. *The ability to apply lessons learned from in-house maintenance experiences (and the experiences of others) is considered an essential aspect for long-term success.*

Discussion: In-house lessons learned on maintenance

experiences are obtained from the Craft Services' In-house Surveillance Program, conducted by the Craft Services QA and Compliance Specialist. This individual also monitors and maintains the Craft Services audit log which tracks and trends action items from the various audits/surveys, etc. The experience of others is obtained from the DOE Order 5000.3A reporting program printouts.

- c. *Related maintenance experience at other facilities or DOE sites is evaluated and appropriate changes made to systems procedures, and management concepts.*

Discussion: Reports generated by the DOE 5000.3A reporting program are reviewed periodically to determine trends, comparisons, and evaluate corrective actions taken to preclude similar situations at other DOE sites.

- d. *Procedures are in place to assign responsibility for areas needing improvement, corrective action and follow-up. Corrective actions are tracked and reported until completion.*

Discussion: The Craft Services Audit Log is maintained, evaluated, and distributed by the QA and Compliance Specialist. Corrective action items are tracked and reported until completed on this logging system.

- e. *Quality assurance/quality control, safety, and environmental audits and inspections are promptly evaluated and appropriate action taken.*

Discussion: Audits/inspection results are promptly evaluated within the required due dates and appropriate actions taken.

- f. *Changes or modifications resulting from audits and lessons learned are documented in policies and procedures.*

Discussion: Changes or modifications resulting from audits and lessons learned are documented in the appropriate documents.

Improvements: No improvements are planned at this time.

4.8 Additional Maintenance Management Requirements

4.8.1 Self-Assessments

Objective: *A self-assessment of facility maintenance programs should be conducted by DOE contractors responsible for maintenance, and should address each of the elements identified in...(DOE Order 4330.4A). The schedule for such*

assessments may be established at the contractor's discretion but should ensure that every maintenance program element is assessed at least every other year. Deficiencies identified in the self-assessments should be dispositioned with appropriate action plans.

Discussion: The Facilities and Operations' Self-Assessment Program applies to programs, activities, operations, and facilities under the sponsorship or direction of DOE. This program emphasizes the effective analysis and use of existing assessment activities, supplemented by special assessments as needed.

This program requires Facility and Operations managers to perform formal periodic reviews of their work activities and to identify successes and opportunities for improvement. The self-assessment program accomplishes this in an efficient manner by establishing a framework for the collection, analysis, and distribution of assessment data. One element of the self-assessment program is the process whereby managers continuously and candidly evaluate their organization's performance based on available information and commit to improvement actions as necessary. The formal self-assessment process focuses on compliance with DOE Orders and is formally documented. Improvement actions are also documented and tracked to completion.

Assessments will be augmented by periodic program surveillances by management and other responsible overview organizations. Results of assessments and surveillances will be reviewed by appropriate levels of management, necessary corrective actions initiated, final assessment reports issued, and changes to the Maintenance Implementation Plan made as necessary.

The first self-assessment to DOE Order 4330.4A, all sections, was completed during September, 1991. The Craft Services QA and Compliance Specialist has been assigned the task to conduct future self-assessments.

Improvements: No improvements are planned at this time.

4.8.2 Seasonal Facility Preservation Requirements

Objective: *Since seasonal variations in temperature and other weather conditions impact facility preservation activities, a freeze protection plan should be developed for any facility that may be at risk. A more comprehensive seasonal transition plan should provide for inspections, PM, and corrective maintenance of heating or cooling equipment prior to use and should encompass freeze protection as a part of the plan.*

Discussion: A procedure for a formal freeze protection program has been developed and implemented. The PM Program has a winterization program aspect that ensures equipment/systems are ready for winter conditions, which allows for winter time frame monitoring activities. There is also a spring/summer program to ensure that air-conditioning equipment, etc., is ready for use.

Improvements: No improvements are planned at this time.

4.8.3 Maintenance Standards and Workmanship Standards

Objective: *The above maintenance management program elements provide an environment for quality maintenance performance. To ensure that an appropriate level of performance expectation is provided to craftsmen, national consensus standards and/or field-tested workmanship standards should be established for those maintenance activities covered by these standards. Where maintenance activities are not covered by such standards and could impact safety of personnel or the continuity of facility operation, applicable maintenance procedures or standards should be created.*

Discussion: Craft Services maintains numerous volumes of Craft Services Procedures. These include CAL, SMP, P&P, and Welding Procedures. In addition, approximately one thousand PM Standard Checklists are maintained in a current condition. These procedures/checklists are designed to reference, assist, or cover gaps in national consensus standards and/or field-tested workmanship standards.

Improvements: No improvements are planned at this time.

4.8.4 Warranty/Guarantee Information

Objective: *Warranty/guarantee information on items, components, or systems received from vendors must be evaluated to determine whether utilization of the warranty or guarantee would be economical at a later date. If it is determined that a warranty or guarantee is of economic value, procedures should be established "to flag" future work on this item to ensure that craftsmen and supervisors do not void the agreement by accomplishment of unauthorized maintenance or repair.*

Discussion: Craft Services P&P 8.1.7, "Warranty/Guaranteed Items," meets the stated objective.

Improvements: No improvements are planned at this time.

5.0 DEVIATIONS

PNL does not request any deviations.

6.0 PROJECTED BUDGET AND BACKLOG OF MAINTENANCE

***** ESTIMATE *****

CURRENT	PLAN	FUTURE	FUTURE
BUDGET	YEAR	YEAR	YEAR
FY 1992	FY 1993	FY 1994	FY 1995

(\$000)

6.1 OPERATING EXPENSES FOR MAINTENANCE AND REPAIR OF REAL PROPERTY

(1) In-house Work Effort.....	\$11,769	\$15,852	\$16,644	\$17,474
and number of related FTEs.....	156.9	205.2	211.0	216.0
(2) Contracted Maintenance and Repair.....	1,145	2,948	3,096	3,250
(3) Contracted Services.....	45	76	80	84
(4) Other (explain by note)	0	0	0	0
Fiscal Year Totals	\$12,959	\$18,876	\$19,820	\$20,808

6.2 TYPES OF MAINTENANCE AND REPAIR OF REAL PROPERTY

(1) Scheduled Maintenance.....	\$7,786	\$9,907	\$10,403	\$10,921
(2) Preventive Maintenance.....	2,463	3,646	3,828	4,019
(3) Repair Maintenance.....	333	268	282	295
(4) Emergency Maintenance.....	331	504	529	556
(5) Improvements.....	2,046	4,551	4,778	5,017
(6) Other Maintenance	0	0	0	0
Fiscal Year Totals	\$12,959	\$18,876	\$19,820	\$20,808

6.3 MAINTENANCE AND REPAIR FOR ASSET TYPE CODES 670 AND 680

(1) Process Systems (670).....	\$109	\$114	\$120	\$126
(2) Reactors and Accelerators (680).....	35	37	39	41
Fiscal Year Totals	\$145	\$151	\$159	\$167

***** ESTIMATE *****

CURRENT	PLAN	FUTURE	FUTURE
BUDGET	YEAR	YEAR	YEAR
FY 1992	FY 1993	FY 1994	FY 1995

(\$000)

6.4 OPERATING EXPENSE FUNDED MAINTENANCE OF EQUIPMENT OTHER THAN REAL PROPERTY

(1) General Equipment Maintenance.....	\$13,753	\$14,089	\$14,794	\$15,533
and related in-house FTEs.....	70.1	74.0	74.0	74.0
(2) Vehicle and Mobile Equipment Support - subtotal	\$0	\$0	\$0	\$0
(a) Licensed Vehicles (1).....	0	0	0	0
(b) Other Mobile Equipment (1).....	0	0	0	0
(3) Other (explain by note).....	0	0	0	0
	-----	-----	-----	-----
Fiscal Year Totals	\$13,753	\$14,089	\$14,794	\$15,533

6.5 CONSOLIDATED SUMMARY OF ESTIMATES (\$000)

(1) Operating Expense (2).....	\$266,816	\$299,398	\$323,889	\$334,459
(2) Capital Equipment.....	1,800	3,500	3,500	4,700
(3) Plant.....	35,600	71,300	88,500	51,900
	-----	-----	-----	-----
Fiscal Year Totals	\$304,216	\$374,198	\$415,889	\$391,059

NOTES:

- (1) PNL Vehicle and Mobile Equipment maintenance cost is reported by WMC.
- (2) Expense funded maintenance of real property is for DOE facilities. The total operating expense has been adjusted to reflect work performed in DOE facilities only and does not include cost of BMW private facilities.

6.6 Backlog of Maintenance and Repair

<u>Backlog of Maintenance and Repair</u>	<u>Building</u>	<u>Type Funding</u>	<u>Estimated Cost (\$000)</u>
Equipment Room Crane Upgrade	324	Expense	3
Airlock Room 11	324	Expense	10
Install Process Line Flow Meter	331	Expense	5
Correct Fire Assessment Deficiencies	306W	Expense	25
Exhaust Canopy HEPA	332	Expense	35
Deactivate Floor Drains	323	Expense	7
HEPA Fire Protection	324	Expense	25
Fire System Backflow Modification	350	Expense	25
Weld Shop Backflow Modification	350	Expense	10
Remove Heat Recovery Coil	331	Expense	10
Backflow Prevention Modification	318T4	Expense	5
Fire System Backflow	3708	Expense	20
Fire System Backflow	327	Expense	45
Eyewash Stations	3730	Expense	8
Fire System Backflow	3745	Expense	20
Feed Water Modification	329	Expense	7
Fire System Backflow	323	Expense	15
Feed Water Modification	3730	Expense	7
Service Power Modification	3708	Expense	15
HVAC Improvement	747A	Expense	20
Eyewash Cross Connection	324	Expense	7
Damper Control Modification	325	Expense	22
Fan Control Replacement	327	Expense	40
Fire System Backflow Modification	3718A	Expense	25
Fire System Backflow Modification	326	Expense	60
Fire System Backflow Modification	3762	Expense	15
Lobby Modification	747A	Expense	25
Fire System Backflow Modification	306W	Expense	40
Safety Rail	3708	Expense	8
Fire System Backflow Modification	305B	Expense	20
Fire System Backflow Modification	318T4	Expense	10
Fire System Backflow Modification	314	Expense	20
Roof Repair	3760	Expense	15
Atmosphere HVAC Modification	324	Expense	25
Change/Equipment Room Exhaust	327	Expense	5
Sump Pump Controls Modification	327	Expense	4
Fire System Backflow Modification	3746A	Expense	20
Fire System Backflow Modification	3745B	Expense	20
Fire System Backflow Modification	331H	Expense	20
Safety Shower Modification	327	Expense	15
Zone I Damper Replacement	324	Expense	15
Backflow Preventer Modification	325	Expense	10
Backflow Preventer Modification	3730	Expense	10

<u>Backlog of Maintenance and Repair</u>	<u>Building</u>	<u>Type Funding</u>	<u>Estimated Cost (\$000)</u>
Eyewash Cross Connection	3746A	Expense	4
Main Entrance Door Window	329	Expense	3
Backflow Preventer Modification	323	Expense	10
Backflow Preventer Modification	3760	Expense	10
Backflow Preventer Modification	324	Expense	10
Fire Protection Modification	323	Expense	20
C Section Emergency Lights	329	Expense	5
RPS Tunnel Modification	325	Expense	15
Install Air Sample Pump	3730	Expense	15
Maintenance Shop Ventilation	325	Expense	5
Fire System Backflow	3760	Expense	15
Change RM HEPA 700 Hall	325	Expense	20
Electrical Mod to 5 Ton Crane	324	Expense	5
HVAC Upgrade	306W	Expense	15
Vacuum Sampler Discharge	324	Expense	50
Stack Pump/Alarm Upgrade	324A	Expense	38
Telephone Room Door	3767	Expense	3
Install Backflow Preventer	331C	Expense	10
Fire System Backflow Modification	331	Expense	20
Relocate Backflow Preventer	331	Expense	10
Relocate Backflow Preventer	331B	Expense	10
Vacuum System HEPA	331	Expense	5
Cylinder Storage	327	Expense	15
Criticality Alarm System	327	Expense	30
Parallel HEPA Filter	325	Expense	20
Backflow Prevention Modification	3764	Expense	10
Backflow Prevention Modification	622R	Expense	10
Backflow Prevention Modification	6652C	Expense	10
Backflow Prevention Modification	320	Expense	10
HVAC Zone Pressure Controls	325	Expense	40
Backflow Prevention Modification	337	Expense	10
Install Air Sampler System	323	Expense	10
Ashing Lab Filter Housing	331	Expense	15
Hot Cell Lab Modification	3730	Expense	50
Main Corridor Modification	3760	Expense	20
Machine Shop Ventilation	329	Expense	10
Compressor Cross Connection	324	Expense	10
Backflow Prevention Modification	3720	Expense	10
Move Thermostat	326	Expense	5
NEC Violation Corrections	331	Expense	5
Emergency Lights	3708	Expense	5
Fire Alarm Supervisor System	327	Expense	10
NEC Violation Corrections	3760	Expense	2
NEC Violation Corrections	320	Expense	5
Duct Heater Cabinet Modification	325	Expense	7

<u>Backlog of Maintenance and Repair</u>	<u>Building</u>	<u>Type Funding</u>	<u>Estimated Cost (\$000)</u>
Fire System Backflow Modification	331	Expense	20
NEC Violation Corrections	331D	Expense	2
NEC Violation Corrections	329	Expense	7
Fire Alarm Bell Addition	326	Expense	15
Eyewash Stations	331	Expense	20
NEC Violation Corrections	326	Expense	35
NEC Violation Corrections	331G	Expense	10
Room 601 Panel Modification	325	Expense	10
NEC Violation Corrections	3720	Expense	2
NEC Violation Corrections	331H	Expense	5
NEC Violation Corrections	3708	Expense	2
Fire Appraisal Deficiency	306W	Expense	30
Fire Alarm Audible System	324	Expense	5
Cross Connection Room 1C/8C	329	Expense	10
Install Air Sampler System	323	Expense	22
Eyewash Stations	6652	Expense	20
Sprinkler Protection	331	Expense	10
Cell Alarm	3730	Expense	10
Backflow Preventer Modification	3760	Expense	38
Electrical Mod Cold Equipment Room	327	Expense	30
Unused Line Removal	326	Expense	375
Abandoned Line Removal	325	Expense	375
Install Jib Crane	3745B	Expense	2
Vent Drain/Backflow Prevention	3746A	Expense	5
Rebuild Service Platform	331B	Expense	10
Exit Sign	331	Expense	5
Fire System Backflow Modification	3731A	Expense	20
Backflow Preventers	3745B	Expense	10
Remove Abandoned Lines	324	Expense	375
Roof Hazards	331	Expense	30
Fire Separation	324	Expense	60
Fire Separation	325	Expense	60
Exit Stair	329	Expense	54
Roll-Up Door Modification	324	Expense	10
Backflow Devices RLWS/PS	325	Expense	10
Sprinkler Piping Modification	325	Expense	50
Air Handler Process Water	3714	Expense	10
Sprinkler Piping Modification	327	Expense	30
Fall Protection Devices	300	Expense	30
Crane Evaluation	331	Expense	25
Safety Shower Flush Lines	DOE	Expense	1000
Work Platform 305B/306W	300	Expense	50
Mt. Rainier Room Modification	337	Expense	20
Fire Sprinkler Pipe Support	331	Expense	1
Smoke Detector Access	324	Expense	15

<u>Backlog of Maintenance and Repair</u>	<u>Building</u>	<u>Type Funding</u>	<u>Estimated Cost (\$000)</u>
Floor Loading	331	Expense	7
Backflow Preventer Modification	3714	Expense	10
Process Water Header Replacement	329	Expense	200
Floor Loading Accel Fac	300	Expense	5
Install Ladder	350D	Expense	2
Annunciator Panel Modification	324	Expense	10
Women's Rest Room Modification	314	Expense	20
Roof Access Stairway	326	Expense	5
Stairway Handrail Modification	329	Expense	10
Install Backflow Preventer	324	Expense	15
Upgrade Docks	325	Expense	50
Floor Load Signs	300	Expense	7
HVAC Modification Lab 101	324	Expense	50
Permanent Gas Bottle Manifold	326	Expense	30
Animal Sewer Sump	331	Expense	75
Air Sampler System Modification	3730	Expense	15
Air Sampler Room 17A, 47/48C	326	Expense	25
Canyon Exhaust Modification	327	Expense	150
New Doors	3708	Expense	30
Emergency Control Circuits	331	Expense	50
Incoming Air Filters	331	Expense	100
Exhaust Duct Air Samplers	325	Expense	150
Study Covering Stairway	3760	Expense	50
Vent Improvements 1C/2C/3C	326	Expense	25
Mechanical Room Ventilation	3708	Expense	30
Replace Ceiling Tile	327	Expense	20
Back Dock Sprinklers	331	Expense	10
Hot Water System	337	Expense	40
Sump Pump Backup	329	Expense	20
RPS Check Valve	329	Expense	50
Crane Speed Control	336	Expense	50
Remodel Lunchroom	318	Expense	20
Electrical Problems	325A	Expense	10
Exhaust Duct Smoke Sampler	325	Expense	15
Heating/Cooling Controls	318	Expense	30
Pit Lighting Improvements	336	Expense	10
Controls for HVAC	331H	Expense	5
Fire Alarm Supervisory System	325	Expense	15
Review Room 15 Air Conditioning	320	Expense	15
North Equip Room Cross Connection	3720	Expense	15
Cross Connection	3720	Expense	15
East Mech Room Cross Connection	3720	Expense	15
West Mech Room Cross Connection	3720	Expense	15
Eyewash Cross Connection	3720	Expense	8
Perchloric Hood	325	Capital	200

<u>Backlog of Maintenance and Repair</u>	<u>Building</u>	<u>Type Funding</u>	<u>Estimated Cost (\$000)</u>
C Section Modification	329	Capital	300
Fume Hood Replacement	331	Capital	200
Building Upgrade	306W	Capital	300
Booster Coils	329	Capital	150
Exhaust System Upgrade	329	Capital	300
HVAC Upgrade	306W	Capital	300
Room 192/194 HVAC	331	Capital	200
Process Sewer	329	Capital	100
Vacuum Air Sampler	326	Capital	100
Craft Shop Extension	350	Capital	300
Wet Pipe Sprinkler System	6652J	Capital	50
Fire Protection	3731	Capital	50
Stack Sampler	327	Capital	100
Final Stage HEPA	324	Capital	300
Switchgear Replacement	327	Capital	150
HEPA Filter Housing	327	Capital	200
Manipulator Repair Facility	327	Capital	200
Process Water Piping Replacement	325	Capital	300
Backup Motor Generator	325	Capital	100
Process Water Replacement	327	Capital	300
Condensate Piping Replacement	324	Capital	300
Gamma Pit Crane	3730	Capital	50
Steam Pipe Replacement	324	Capital	300
Room 603 Air Conditioner	325	Capital	50
Evaporative Cooler Replacement	324	Capital	100
HVAC Refurbishment	3730	Capital	50
Dry Pipe Sprinklers	3760T2	Capital	20
Vacuum Air Sampler	324	Capital	100
Process Sewer	325	Capital	300

7.0 IMPLEMENTATION SCHEDULE

Reference section 4.2.1, Facility Condition Inspections:

- Action: Craft Services P&P 19.1.0, "Housekeeping and Safety," will be revised to reflect current practice.

Commitment Date: September 30, 1992

Responsible Individual: RE Hawks

- Action: Inspection checklists designed for each specific shop area/equipment will be implemented.

Commitment Date: September 30, 1992

Responsible Individual: RE Hawks

- Action: A method for trending housekeeping deficiencies and facility assessment deficiencies will be implemented.

Commitment Date: June 30, 1993

Responsible Individual: RE Hawks

Reference section 4.4.1, Work Request (Order) System:

- Action: Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," will be revised to reflect current practice (also reference 4.4.2, 4.4.4, 4.4.6 & 4.4.8).

Commitment Date: May 31, 1993

Responsible Individual: CC Wentz

Reference section 4.4.2, Formal Job Planning and Estimating:

- Action: Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," will be revised to reflect current practice (also reference 4.4.1, 4.4.4, 4.4.6 & 4.4.8).

Commitment Date: May 31, 1993

Responsible Individual: CC Wentz

Reference section 4.4.3, Work Performance (Time) Standards:

- Action: A work standards program will be evaluated for application to Craft Services. The results of this evaluation, along with the implemented program will be documented.

Commitment Date: August 31, 1993

Responsible Individual: CC Wentz

Reference section 4.4.4, Priority System:

- Action: Revise Craft Services P&P 10.1.1, "Planning and Scheduling Procedure," to reflect current practice (also reference 4.4.1, 4.4.2, 4.4.6 & 4.4.8).

Commitment Date: May 31, 1993

Responsible Individual: CC Wentz

Reference section 4.4.5, Maintenance Procedures and Other Work-Related Documents:

- Action: Work with Design and Drafting Services Section and Facilities Management Department to develop a plan to improve status of as-built drawings.

Commitment Date: August 31, 1993

Responsible Individual: CC Wentz

- Action: Both Craft Services P&P 11.1.0, "PM Program," and 17.1.0, "Craft Services Procedures" will be revised. A procedure writer's guide will be developed and placed in the appropriate Craft Services P&P Manual Section. P&P 11.1.0 will be expanded to include procedure verification and validation.

Commitment Date: March 30, 1993

Responsible Individual: CC Wentz

Reference section 4.4.6, Scheduling System:

- Action: Craft Services P&P 10.1.1, "Planning and Scheduling," will be revised to reflect current practice (also reference 4.4.1, 4.4.2, 4.4.4 & 4.4.8).

Commitment Date: May 31, 1993

Responsible Individual: CC Wentz

Reference section 4.4.7, Post-Maintenance Testing:

- Action: Evaluate PM Program for effectiveness, and adequacy of Post-Maintenance Testing Program to DOE Order 4330.4A requirements. Evaluation results will be incorporated into a revision of Craft Services P&P 11.1.0, "PM Program," which must also be revised to

reflect current practice. Craft Services P&P 9.2.0, "Facility Work Control Procedure," will also be evaluated for adequacy and adjusted to meet compliance criteria.

Commitment Date: August 31, 1993

Responsible Individual: CC Wentz/RE Hawks

- Action: The term "rework" will be defined for Craft Services application and a procedure developed for implementation.

Commitment Date: May 31, 1993

Responsible Individual: DD Hatley

- Action: Make arrangements for formal involvement in ATP with facilities Engineering.

Commitment Date: December 31, 1992

Responsible Individual: DD Hatley

Reference section 4.4.8, Backlog Work Control:

- Action: Craft Services P&P 10.1.1, "Planning and Scheduling," will be revised to reflect current practice (also reference 4.4.1, 4.4.2, 4.4.4 & 4.4.6).

Commitment Date: May 31, 1993

Responsible Individual: CC Wentz

- Action: Maintenance backlog will be documented in the Site Maintenance Plan.

Commitment Date: September 30, 1992

Responsible Individual: JD Bright

Reference section 4.4.9, Equipment Repair History and Vendor Information:

- Action: A new procedure will be established to cover equipment history to comply with DOE Order 4330.4A.

Commitment Date: August 30, 1993

Responsible Individual: CC Wentz

- Action: Craft Services P&P 16.1.0, "CVI Files," will be revised to

provide better detail of how Craft Services uses the filing system and what it can provide.

Commitment Date: August 30, 1993

Responsible Individual: CC Wentz

Reference section 4.7.5, Work Sampling:

- Action: Develop a work-sampling program and procedures.

Commitment Date: August 31, 1993

Responsible Individual: RE Hawks/JD Bright

Reference section 4.7.6, Cost Identification and Control:

- Action: Revise Craft Services P&P, Section 7, "Budgets and Cost Control," to reflect current practice.

Commitment Date: September 30 1993

Responsible Individual: JD Bright

EXHIBIT 1 **PNL MAINTENANCE PROGRAM RISK CRITERIA**

<div><div>A. LAWS/ACTS/REGS Incl. ENVIRONMENTAL COMPLIANCE</div><div><ul style="list-style-type: none">Safety Class I structures, systems and components as defined in PNL-MA-44.OSR & SAR related equipment.</div></div>	<div><div>B. PROGRAMMATIC/MISSION</div><div><ul style="list-style-type: none">Ensure ability to start program/mission/process.<ul style="list-style-type: none">Production equipmentSubstations and switchgearNontoxic waste systemsMeet major milestones.Ensure production rate is maintained.Ensure ability to meet mission goals.Enhance operations to ensure operations are not highly jeopardized.Enhance operations to prevent potential significant impact on established milestones.Ensure ability to meet cost/schedule improvement milestones.</div></div>	<div><div>C. FACILITY PRESERVATION</div><div><ul style="list-style-type: none">Adopt widely accepted practices which could reduce risks to facilities.Keep equipment or instrumentation maintained or calibrated.Develop and execute training and qualification programs.Provide infrastructure/support facility maintenance of electrical power systems, hoists, and fire alarms.</div></div>	HIGH RISK
<div><div>Safety Class III structures, systems and components as defined in PNL-MA-44.</div></div>	<div><ul style="list-style-type: none">Enhance operation to increase production.Prevent damage to production facilities.Minimize risk to current operations or ability to meet milestones.Achieve minor reduction of costs, or delays.Correct problems which impact reliability of equipment/facilities.Enhance operations.Increase probability of meeting future missions.Mission and risk to be established.</div>	<div><ul style="list-style-type: none">Keep up-to-date equipment or instrumentation maintenance or calibrationProvide infrastructure/support facility maintenance for filters, belts, rotating equipment, HVAC units, pumps, and motors.Bring equipment or instrumentation records up-to-date.Provide infrastructure/support facility planned monthly/yearly maintenance (painting, road sealing, and lighting replacements).Replace as broken or end of life infrastructure/support facility features such as doors, windows, swamp cooler pumps, etc.</div>	LOW RISK

EXHIBIT 2

PNL MAINTENANCE MANAGEMENT PROGRAM GRADED APPROACH

Risk- Based Categories	Preventive Maintenance	Written Maintenance Procedures	Maintenance Training	Post Maintenance Testing	Configuratio n Control	Procuremen t
HIGH RISK	Scheduled: Mandatory Bypass: Waiver Controlled	Required: Preventive/ Corrective Maintenance	Qualified Crafts	Required: Preventive/ Corrective Maintenance	Controlled	Controlled
MEDIUM RISK	Scheduled: Mandatory Bypass: Waiver Controlled	Limited to PM Procedures	Limited Training	Specified by Work Control Documents	Limited Control	Partly Controlled
LOW RISK	As Determined Cost Effective	Industrial Practice	Normal Craft Qualification	Normal Industrial Practice	None	Off Shelf

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

2 DOE/Office of Scientific and
Technical Information

L. E. Eberhardt
A. M. Fillion
K. J. Gaither
B. A. Grasher
D. D. Hatley

R. E. Hawks

G. R. Hoenes

R. R. King

J. E. Milliorn

M. E. Olson

C. C. Wentz

M. A. Williams

Publishing Coordination

Technical Report Files (5)

ONSITE

3 DOE Richland Field Office

J. J. Sutey

B. E. Hill

J. D. Davidson

20 Pacific Northwest Laboratory

J. D. Bright

T. D. Chikalla

END

**DATE
FILMED**

12 / 17 / 92