1 of 1

GENERAL ELECTRIC
COMPANY

RICHLAND, WASHINGTON . . . TELEPHONE - AREA CODE 509, 942-1111

HW-30405

HANFORD ATOMIC
PRODUCTS OPERATION

HANFORD LABORATORIES

DECLASSIFIED

January 14, 1964.

RESTRICTED DATA

THIS DOCUMENT CONTAINS RESTRICTED DATA
AS APPLICABLE IN THE HANFORD ENERGY AREA
UNAUTHORIZED DISCLOSURE SUBJECT
TO ADMINISTRATIVE AND CRIMINAL SANCTIONS.

This document consists of
1 pages. No. 1 of
1 copies.

SERIES BMB

U. S. Atomic Energy Commission
Richland Operations Office
Richland, Washington

ATTENTION: Mr. A. T. Gifford, Director
Production Division

Gentlemen:

CLASSIFICATION CANCELLED

Per las May 1973

By 7-19-74

SOURCES OF RADIOACTIVITY

The data on Hanford releases of I-131, Xe-133, Xe-135, and tritium requested in your letter of January 7, 1964, are supplied in the attached Appendix. The I-131 released from the two separations plants is measured continuously. Other potential sources of radioiodine to the atmosphere are also monitored, but the release rates from these other facilities are insignificant. The release rates of tritium, Xe-133 and Xe-135 are not measured, and the data listed for them has been calculated from production data and reactor operating conditions.

Classification Cancelled and Changed To

DECLASSIFIED

Classification Cancelled (Classified to)

RET

Very truly yours,

ORIGINAL SIGNED BY
H. M. PARKER

Manager
Hanford Laboratories

By Authority of SE Gyde

PR-24, 8-30-93

By J E Sawyer 8-30-93

Verified By 93.93

HM Parker:JKS:fo
Attachment
cc: AEC (2)

cc: ~~BJ Brown~~
~~RF Foster~~
~~CH Gregor~~
~~AR Kline~~
~~HM Parker~~
~~JA Warren~~
~~BO Fife~~
Record Copy

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

A PRIME CONTRACTOR FOR THE U.S. ATOMIC ENERGY COMMISSION DISTRIBUTION RESTRICTED TO U.S. ONLY

APPENDIX

DECLASSIFIED

I-131, Xe-133, Xe-135 AND TRITIUM
RELEASED TO THE ATMOSPHERE FROM HANFORD SOURCES

FUEL PROCESSING PLANTS

I-131

The emission rates of I-131 from the Purex and Radex Chemical Separations Plants stacks are measured daily. The normal emission rate has been about 0.2 curie per day since December 1961. The period from September 1961 to December 1961 included a transition to a more restrictive operational guide and the release rate averaged about 0.3 curie per day during that time.

Table I summarizes the I-131 release data for the period September 1961 to December 1963. Only on six days (three separate events) during this period did the I-131 emission reach or exceed 5 curies per day. These periods are detailed in Table II.

Xe-133

Releases of noble gases from the stacks of the Hanford separations plants are not measured but they have been estimated from production data and the age of the fuel processed. During the transition period of September 1961 through November 1961, the monthly average release rate of Xe-133 probably never exceeded 50 curies per day and was more likely on the order of 20 curies per day. After November 1961, following adoption of the more restrictive operational guide for I-131, the

DECLASSIFIED

monthly average release rate was normally less than 3 curies of Xe-133 per day.

During the period September through November 1961, the maximum release probably never exceeded 100 curies in one day and quite likely did not exceed 30 curies in one day. Since November 1961, the maximum emissions have probably been about 5 curies of Xe-133 per day except on a few occasions (detected by I-131 monitoring) when insufficiently aged metal was inadvertently dissolved. The releases on these occasions are also listed in Tables I and II.

Xe-135

The emission rate of Xe-135 from Hanford separations plant stacks has probably never exceeded 1 curie per day during the period September 1961 to December 1963.

Tritium

Tritium as HT or T₂ is released at an estimated average rate of 50 curies per day from the Separations Plant stacks. Another estimated 150 curies per day, as tritium oxide, is released to ground water with the liquid wastes. These estimates were calculated from average production data and no attempt to define the probable maximum release was made. The allocation of 25 per cent of the inventory to release via the stacks and 75 per cent via liquid waste to ground is somewhat arbitrary. An arbitrary division is used because attempts to strike a material balance on the basis of actual measurements have been unsuccessful.

PRODUCTION REACTOR FACILITIES**DECLASSIFIED**I-131

No significant amounts of I-131 are released to the atmosphere from the reactor stacks. There are no routine specific measurements, although monitoring equipment installed to record unusual releases of fission products would detect emissions of 1 millicurie of I-131 per day.

Xe-133 and Xe-135

No measurements of exact quantities of the noble gases Xe-133 and Xe-135 released to the atmosphere from reactor facilities have been made. The normal emission rates are estimated to be well below the level of 5 curies per day, however. Probably as many as 5 times during the period from September 1961 to December 1963 there were releases of Xe-133 and Xe-135 from certain fuel element ruptures. During these few instances about 100 to 1000 curies of Xe-133 (estimated from the exposure history of the fuel elements) could have been released to the atmosphere. The majority of this was released at ground level from the surface of the water in the reactor effluent retention basins. The Xe-135 released during these same instances was about one-half of the Xe-133.

The maximum release of these two isotopes probably occurred on May 12, 1963, during a fuel element rupture at 100-XE. An estimated 1000 curies of Xe-133 and 500 curies of Xe-135 were released at that time.

DECLASSIFIEDTritium

Normal emission rates of tritium to the atmosphere from all reactor stacks is estimated to be on the order of 1 curie per day on the basis of spot measurements. The maximum release in 24 hours has probably never exceeded 5 curies.

PLUTONIUM RECYCLE TEST REACTORI-131

Continuous monitoring of the gaseous effluent discharged from the PRTR stack indicates that the release rate of I-131 from this facility has been less than 1 millicurie per day throughout the period of September 1961 through December 1963.

Xe-133 and Xe-135

Measurements for these two radionuclides have been made in the helium system of the PRTR following the detection of fuel elements failures. These measurements indicate that releases of Xe-133 and Xe-135 from the PRTR stack have probably never exceeded 1 curie per day.

Tritium

Stack releases of tritium can be estimated from the measured tritium content of the primary heavy water system and from heavy water losses from the stack. The latter data is calculated from daily grab samples of the moisture content of the stack gases. Monthly average tritium release rates estimated by this method normally ranged from 1 to 4 curies per day

DECLASSIFIED

for the period from March 1962 through December 1963. No data are available for the period September 1961 through February 1962, but there is no reason to believe that the release rate was any higher than normal during those six months. The highest monthly average was estimated to be 5 curies per day during August 1962. The highest daily emission probably occurred on August 22, 1962, and amounted to approximately 10 curies.

DECLASSIFIED

TABLE I

SUMMARY OF I-131 AND Xe-133 EMISSION RATES
FROM HANFORD SEPARATIONS PLANT STACKS*
SEPTEMBER 1961 THROUGH DECEMBER 1963
Units of Curies Per Day

Month	I-131			Xe-133	
	Average	Max.	Date of Max.	Average	Max.
9/61	0.78	2.0	9/15	20-50	30-100
10/61	0.78	2.1	10/3	20-50	30-100
11/61	0.62	1.8	11/29	20-50	30-100
12/61	0.23	0.81	12/6	<2	~5
1/62	0.31	1.2	1/29	<3	~5
2	0.23	0.74	2/22	<3	~5
3	0.22	0.57	3/17	<3	~5
4	1.5	24**	4/3	10 ³	10 ^{4**}
5	0.04	0.19	5/5	<3	~5
6	0.06	0.14	6/28	<3	~5
7	0.23	0.58	7/27	<3	~5
8	0.26	1.1	8/31	<3	~5
9	0.83	10**	9/13	<3	~5
10	0.11	0.29	10/19	<3	~5
11	0.10	0.34	11/14	<3	~5
12/62	0.31	0.77	12/28	<3	~5
1/63	0.11	0.34	1/5	<3	~5
2	0.07	0.22	2/5	<3	~5
3	0.10	0.28	3/7	<3	~5
4	0.17	0.91	4/3	<3	~5
5	0.14	0.91	5/1	<3	~5
6	0.54	1.3	6/14	<3	~5
7	0.18	1.0	7/2	<3	~5
8	0.10	0.45	8/31	<3	~5
9	2.4	46**	9/2	10 ⁴	10 ^{5**}
10	0.21	0.55	10/16	<3	~5
11	0.18	0.62	11/16	<3	~5
12/63	0.36	2.2**	12/14	10 ²	10 ^{3**}

*The I-131 was measured daily at each Separations Plant stack. Other facilities potentially contributing I-131 were also monitored but these contributed negligible amounts of I-131 during the period in question. The Xe-133 was not measured but was estimated from production data and age of metal dissolved.

**See Table II for detailed emission data.

DECLASSIFIED

TABLE II

PERIODS WITH EMISSION RATES OF I-131 AND Xe-133
FROM HARPONS SEPARATIONS PLATING STACKS
EXCEEDED 5 CURIES PER DAY
Units of curies per day

<u>Date</u>	<u>I-131</u>	<u>Xe-133</u>
4/1/62	0.01	<3
2	8.1	10 ³
3	24	<10 ²
4	6.7	<3
5	1.9	<3
9/12/62	0.32	<3
13	10	<3
14	0.31	<3
9/1/63	0.27	<3
2	46	10 ³
3	14	<10 ³
4	2.5	<3
12/13/63	1.5	<3
14	2.2	10 ³
15	1.5	<10
16	0.4	<3

- Note: 1. The I-131 released was measured daily while the Xe-133 released was estimated from the age of the metal processed and production data.
2. Emission rates just before and after the days when the rates exceeded 5 curies per day are also listed to delineate the periods of maximum release.

**DATE
FILMED**

1 / 11 / 94

END