NUREG/CR-2907
BNL-NUREG-51581
Vol. 11

Radioactive Materials Released from Nuclear Power Plants

Annual Report 1990

RECEIVED
OCT 25 1993
OSTI

Prepared by
J. Tichler, K. Doty, J. Congemi

Brookhaven National Laboratory

Prepared for
U.S. Nuclear Regulatory Commission

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW, Lower Level, Washington, DC 20555-0001
2. The Superintendent of Documents, U.S. Government Printing Office, Mail Stop SSOP, Washington, DC 20402-9328
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Information Resources Management, Distribution Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Radioactive Materials Released from Nuclear Power Plants

Annual Report 1990

Manuscript Completed: September 1993
Date Published: October 1993

Prepared by
J. Tichler, K. Doty, J. Congemi

Brookhaven National Laboratory
Upton, NY 11973

Prepared for
Office of Information Resources Management
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001
NRC FIN B2234

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PREVIOUS REPORTS IN THIS SERIES

1. "Report on Releases of Radioactivity in Effluents and Solid Wastes from Nuclear Power Plants for 1972," Directorate of Regulatory Operations, August 1973.
2. "Summary of Radioactivity Releases in Effluents from Nuclear Power Plants During 1973," NUREG-75/001, January 1975.
3. "Radioactive Materials Released from Nuclear Power Plants, 1974," NUREG-0077, June 1976.
4. "Radioactive Materials Released from Nuclear Power Plants, 1975," NUREG-0218, March 1977.
5. "Radioactive Materials Released from Nuclear Power Plants, 1976," NUREG-0367, March 1978.
6. "Radioactive Materials Released from Nuclear Power Plants, 1977," NUREG-0521, January 1979.
7. "Radioactive Materials Released from Nuclear Power Plants, 1978," NUREG/CR-1497, BNL-NUREG-51192, March 1981.
8. "Radioactive Materials Released from Nuclear Power Plants, 1979," NUREG/CR-2227, BNL-NUREG-51416, November 1981.
9. "Radioactive Materials Released from Nuclear Power Plants, 1980," NUREG/CR-2907, BNL-NUREG-51581, Vol. 1, January 1983.
10. "Radioactive Materials Released from Nuclear Power Plants, 1981," NUREG/CR-2907, BNL-NUREG-51581, Vol. 2, June 1984.
11. "Radioactive Materials Released from Nuclear Power Plants, 1982," NUREG/CR-2907, BNL-NUREG-51581, Vol. 3, February 1986.
12. "Radioactive Materials Released from Nuclear Power Plants, 1983," NUREG/CR-2907, BNL-NUREG-51581, Vol. 4, August 1986.
13. "Radioactive Materials Released from Nuclear Power Plants, 1984," NUREG/CR-2907, BNL-NUREG-51581, Vol. 5, August 1987.
14. "Radioactive Materials Released from Nuclear Power Plants, 1985," NUREG/CR-2907, BNL-NUREG-51581, Vol. 6, January 1988.
15. "Radioactive Materials Released from Nuclear Power Plants, 1986," NUREG/CR-2907, BNL-NUREG-51581, Vol. 7, November 1988.
16. "Radioactive Materials Released from Nuclear Power Plants, 1987," NUREG/CR-2907, BNL-NUREG-51581, Vol. 8, October 1989.
17. "Radioactive Materials Released from Nuclear Power Plants, 1988," NUREG/CR-2907, BNL-NUREG-51581, Vol. 9, July 1991.
18. "Radioactive Materials Released from Nuclear Power Plants, 1989," NUREG/CR-2907, BNL-NUREG-51581, Vol. 10, September 1992.

ABSTRACT

Releases of radioactive materials in airborne and liquid effluents from commercial light water reactors during 1990 have been compiled and reported. The summary data for the years 1971 through 1989 are included for comparison. Data on solid waste shipments as well as selected operating information have been included. This report supplements earlier annual reports issued by the former Atomic Energy Commission and the Nuclear Regulatory Commission. The 1990 release data are summarized in tabular form. Data covering specific radionuclides are summarized.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT.....	iii
LIST OF TABLES.....	xi
ACKNOWLEDGEMENT.....	xiii
1.0 Introduction.....	1
1.1 Purpose.....	1
1.2 Scope.....	1
1.3 Source of Data.....	1
2.0 Tabulated Data.....	1
2.1 Airborne and Liquid Effluents.....	1
2.2 Solid Waste.....	2
2.3 Energy Generation.....	2
2.4 Individual Plant Summaries.....	2
2.5 Numerical Notation.....	3
3.0 Summary.....	3
Appendix A - Individual Plant Summaries	
Arkansas 1 - Unit 1.....	A-1
Arkansas 1 - Unit 2.....	A-3
Beaver Valley 1 & 2.....	A-7
Beaver Valley 1.....	A-9
Beaver Valley 2.....	A-10
Big Rock Point 1.....	A-14
Braidwood 1.....	A-16
Braidwood 2.....	A-18

	<u>Page</u>
Browns Ferry 1, 2 & 3.....	A-22
Brunswick 1 & 2.....	A-25
Byron 1	A-29
Byron 2	A-31
Callaway 1.....	A-35
Calvert Cliffs 1 & 2.....	A-38
Catawba 1.....	A-42
Catawba 2.....	A-45
Clinton 1.....	A-50
Comanche Peak 1.....	A-52
Cook 1 & 2.....	A-53
Cooper.....	A-56
Crystal River 3.....	A-59
Davis Besse 1.....	A-62
Diablo Canyon 1 & 2.....	A-65
Dresden 1, 2 & 3.....	A-69
Dresden 1.....	A-70
Dresden 2 & 3.....	A-71
Duane Arnold.....	A-74
Joseph M. Farley 1.....	A-77
Joseph M. Farley 2.....	A-78
Fermi 2.....	A-80
J.A. Fitzpatrick.....	A-84
Fort Calhoun 1.....	A-87
Fort St. Vrain.....	A-90

	<u>Page</u>
R.E. Ginna.....	A-92
Grand Gulf 1.....	A-95
Haddam Neck.....	A-98
Harris 1.....	A-102
Edwin I. Hatch 1 & 2.....	A-105
Hope Creek 1.....	A-110
Humboldt Bay 3.....	A-113
Indian Point 1 & 2.....	A-115
Indian Point 3.....	A-119
Kewaunee.....	A-122
LaCrosse.....	A-125
LaSalle 1 & 2.....	A-127
LaSalle 1.....	A-128
LaSalle 2.....	A-129
Limerick 1 & 2.....	A-131
Limerick 1.....	A-132
Limerick 2.....	A-133
Maine Yankee.....	A-136
McGuire 1.....	A-139
McGuire 2.....	A-142
Millstone 1.....	A-147
Millstone 2.....	A-151
Millstone 3.....	A-155
Monticello.....	A-159
Nine Mile Point 1.....	A-162

	<u>Page</u>
Nine Mile Point 2.....	A-164
North Anna 1 & 2.....	A-166
Oconeet 1, 2 & 3.....	A-170
Oyster Creek 1.....	A-176
Palisades.....	A-179
Palo Verde 1.....	A-181
Palo Verde 2.....	A-182
Palo Verde 3.....	A-183
Peach Bottom 2 & 3.....	A-186
Perry 1.....	A-189
Pilgrim 1.....	A-192
Point Beach 1 & 2.....	A-195
Prairie Island 1 & 2.....	A-198
Quad-Cities 1 & 2.....	A-201
Rancho Seco 1.....	A-204
River Bend 1.....	A-207
H.B. Robinson 2.....	A-211
Salem 1.....	A-213
Salem 2.....	A-215
San Onofre 1.....	A-218
San Onofre 2 & 3.....	A-221
Seabrook 1.....	A-228
Sequoyah 1 & 2.....	A-229
Shoreham 1.....	A-233
South Texas 1.....	A-235

	<u>Page</u>
South Texas 2.....	A-236
St. Lucie 1.....	A-238
St. Lucie 2.....	A-240
Summer 1.....	A-244
Surry 1 & 2	A-247
Susquehanna 1 & 2	A-251
Three Mile Island 1.....	A-254
Three Mile Island 2.....	A-256
Trojan 1.....	A-258
Turkey Point 3.....	A-262
Turkey Point 4.....	A-264
Vermont Yankee 1.....	A-268
Vogtle 1 & 2.....	A-269
Waterford 3.....	A-272
WNP-2.....	A-275
Wolf Creek 1.....	A-278
Yankee Rowe 1.....	A-281
Zion 1 & 2.....	A-284
Zion 1.....	A-285
Zion 2.....	A-286

List of Tables

	<u>Page</u>
Table 1 Airborne Effluent Comparison by Year, Noble Gases, Boiling Water Reactors.....	6
TABLE 2 Airborne Effluent Comparison by Year, Noble Gases, Pressurized Water Reactors.....	8
TABLE 3 Airborne Effluent Comparison by Year, I-131 and Particulates, Boiling Water Reactors.....	12
TABLE 4 Airborne Effluent Comparison by Year, I-131 and Particulates, Pressurized Water Reactors.....	14
TABLE 5 Liquid Effluent Comparison by Year, Tritium, Boiling Water Reactors.....	18
TABLE 6 Liquid Effluent Comparison by Year, Tritium, Pressurized Water Reactors.....	20
TABLE 7 Liquid Effluent Comparison by Year, Mixed Fission and Activation Products, Boiling Water Reactors.....	24
TABLE 8 Liquid Effluent Comparison by Year, Mixed Fission and Activation Products, Pressurized Water Reactors.....	26
TABLE 9 Solid Waste Summary 1990, Boiling Water Reactors.....	30
TABLE 10 Solid Waste Summary 1990, Pressurized Water Reactors.....	31
TABLE 11 Solid Waste Comparison by Year, Boiling Water Reactors....	32
TABLE 12 Solid Waste Comparison by Year, Pressurized Water Reactors.....	36
TABLE 13 Net Electrical Energy Generation Comparison by Year, Boiling Water Reactors.....	40
TABLE 14 Net Electrical Energy Generation Comparison by Year, Pressurized Water Reactors.....	42
TABLE 15 Thermal Energy Generation Comparison by Year, Boiling Water Reactors.....	46
TABLE 16 Thermal Energy Generation Comparison by Year, Pressurized Water Reactors.....	49

ACKNOWLEDGMENT

Carmen Benkovitz was responsible for the original design of the computer data base in which the effluent data, beginning with the 1978 data, is stored. She was involved in the redesign of the data base when, in 1982, the decision was made to transfer the data base from one computer to another and to change the data base management system being used.

1.0 Introduction

1.1 Purpose

This report, prepared annually for the staff of the U.S. Nuclear Regulatory Commission, presents measured data on radioactive materials in effluents released from licensed commercial reactor power plants. These data were reported by licensees for plant operations during 1990. This information supplements earlier annual reports issued by the former Atomic Energy Commission and Nuclear Regulatory Commission.¹

1.2 Scope

Releases of radioactive materials are governed by 10 CFR Part 20 and 50 and by limits established in the Technical Specifications for each facility. The requirement for reporting effluent releases by nuclear power plant operators is described in 10 CFR 50.36a. Through its Office of Nuclear Reactor Regulation, the Nuclear Regulatory Commission maintains a knowledge of radioactive releases from licensed nuclear reactors to ensure that they are within regulatory requirements. This report summarizes data from the licensed nuclear power plants that were declared by the utilities to be in commercial operation as of December 31, 1990. Data are included for several licensed facilities which are permanently or indefinitely shut down (Browns Ferry 1,2,3, Dresden 1, Fort St. Vrain Humboldt Bay, Indian Point 1, LaCrosse, Three Mile Island 2) and Shoreham which was never in commercial operation.

1.3 Source of Data

The information included in this report was obtained from data reported by the licensees. Individual licensee reports are available in the NRC Public Document Room, Gelman Building, 2120 L Street, Washington, D.C. 20555 and in local Public Document Rooms located near each licensed facility. Licensee reports varied in the format and extent of information provided.

Data from prior years used in the comparison tables were obtained from the nineteen previous annual summaries.

2.0 Tabulated Data

2.1 Airborne and Liquid Effluents

Tables 1 through 4 list for each reactor, the measured quantities of total noble gases and of I-131 and particulates (with half lives greater than 8 days) released in effluents to the atmosphere during each of the years 1971 through 1990. Tables 5 and 6 list the total measured quantities of tritium released in liquid effluents in each of the years. Tables 7 and 8 list the mixed fission and activation products not including noble gases, tritium and alpha released in liquid effluents in each of the years.

¹ Previous reports in this series are listed on page ii.

2.2 Solid Waste

The total volumes, activity and the number of shipments of solid waste for each plant during 1990 are summarized in Tables 9 and 10. A comparison for the years 1977 through 1990 is made in Tables 11 and 12.

2.3 Energy Generation

Tables 13 and 14 present a summary of net electrical energy generated by each plant during 1978-1990. Tables 15 and 16 present a summary of the thermal energy generated by each plant during 1990 and previous years from 1972. The reader is cautioned against making simplistic comparisons of radioactive releases with the energy generated because of the many factors which affect the amount of radioactive materials released; factors include the condition of the fuel, primary system integrity, effluent and radioactive waste treatment systems, maintenance activities and the extent to which these systems are used.

2.4 Individual Plant Summaries

Individual plant summaries are presented in alphabetical order. The summaries include general plant information, power production, effluent and solid waste data, and a summary of specific radionuclides measured in effluents. When the only type of solid waste reported is type "A", this may be because the plant did not break solid waste into different types but reported all types together. The activity released for each nuclide for the year for both airborne and liquid effluents is calculated by summing releases for each quarter. More detailed summaries in the format of Regulatory Guide 1.21 such as were used in the 1978 report² can be made available since all the data for 1978-1990 are stored in digital form.

A wide variation exists in the lists of specific radionuclides reported by utilities (licensees). Individual licensee Technical Specifications require the measurement and reporting of specific sets of radionuclides and "any others identified." The disparities result because of differing analytical methods used by various licensees for their measurements, and their differing operating histories and effluent and emission control methods.

Copies of the summaries included in this report as well as the more detailed summaries maintained in the computer data base were submitted to the licensees for verification before publication. In most cases, the licensees responded either verifying the included data for their plants or providing corrections. Individuals interested in obtaining the more detailed summaries should contact the Office of Information Resources Management of the Nuclear Regulatory Commission.

²"Radioactive Materials Released from Nuclear Power Plants, 1978", NUREG/CR-1497, BNL-NUREG-51192, March, 1981.

2.5 Notation

The following notation is used:

$$1.86\text{E}+06 = 1.86 \times 10^6$$

$$1.86\text{E}-03 = 1.86 \times 10^{-3}$$

N/R = Not Reported

N/D = Not Detected

N/A = Not Applicable

< may actually mean $\leq$

3.0 Summary

Nearly all of the radioactive material reported as being released in effluents are from planned releases. Planned releases result from normal operation or from anticipated operational occurrences. The latter include unplanned releases of radioactive materials from miscellaneous actions such as equipment failure, operator error or procedure error; these releases are not of such consequence as to be considered an accident.

At present, it is difficult to compare effluent releases with those of previous years due to, among other contributors, variability in reporting structure and release requirements. Comparisons with respect to power generation are similarly difficult due to factors which strongly affect the releases such as level of fuel cladding defects, design features of plant radioactive waste treatment systems, operational occurrences and equipment performance.

Though perhaps not identifiable as an important factor at any specific plant from the data in this report, the generic improvement in fuel performance over the last several years has either reduced or has had the potential to reduce the amount of radioactive material released in effluents from most plants. In addition, at Boiling Water Reactors (BWRs), the reduction in the amount of airborne radioactive materials being released at some plants since the early and mid-1970s is due in large part to the installation of augmented offgas (AOG) systems, many of which were required to be installed to meet the provisions of Appendix I to 10CFR Part 50, which was promulgated by the NRC in May 1975.

TABLES

Table 1

Airborne Effluents Comparison By Year

Fission and Activation Gases (Total Curies)

Boiling Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Big Rock Point 1	2.84E+05	2.58E+05	2.30E+05	1.88E+05	5.06E+04	1.52E+04	1.34E+04	1.89E+04	6.67E+03	2.15E+04
Browns Ferry 1,2,& 3				6.40E+04	9.24E+04 <	8.05E+04 <	1.66E+05	1.57E+05 <	2.71E+05 <	1.66E+05
Brunswick 1&2					1.90E+02	1.90E+04	2.46E+05	9.14E+04	1.16E+05	6.93E+04
Clinton 1										
Cooper				2.00E+03	1.98E+04	3.80E+04	1.27E+03	4.09E+03	3.04E+04	5.03E+03
Dresden 1	7.53E+05	8.77E+05	8.40E+05	9.80E+04	5.20E+05	4.52E+05	5.20E+05	8.50E+05	1.83E+02	7.03E+01
Dresden 2-3	5.80E+05	4.29E+05	8.80E+05	6.27E+05	3.69E+05	3.23E+04	3.13E+05	4.06E+04	6.91E+04	4.30E+04
Duane Arnold					1.58E+03	5.26E+03	3.87E+03	1.56E+03	8.71E+03	2.70E+03
Fermi 2										
James A. Fitzpatrick					4.08E+03	4.41E+04	2.33E+04	5.88E+03	3.38E+03	7.68E+04
Grand Gulf 1										
Edwin I. Hatch 1					2.70E+02	2.80E+03	1.90E+03	1.62E+03	1.71E+03	3.82E+04
Edwin I. Hatch 2										2.95E+02
Hope Creek 1										
Humboldt Bay 3	5.14E+05	4.30E+05	3.50E+05	5.72E+05	2.97E+05	9.30E+04	4.40E+05	4.40E+05 <	4.40E+05 <	4.40E+05
LaCrosse	1.00E+03	3.10E+04	9.10E+04	4.90E+04	5.71E+04	1.24E+05	4.25E+04	8.45E+03	1.04E+04	4.71E+03
LaSalle 1&2										
Limerick 1&2										
Millstone 1	2.76E+05	7.26E+05	7.90E+04	9.12E+05	2.97E+06	5.07E+05	6.20E+05	5.66E+05	2.06E+04	1.19E+04
Monticello	7.60E+04	7.51E+05	8.70E+05	1.57E+06	1.55E+05	1.14E+04	6.87E+03	6.42E+03	4.03E+03	3.83E+03
Nine Mile Point 1	2.53E+05	5.17E+05	8.72E+05	5.58E+05	1.30E+06	1.76E+05	3.53E+03	3.02E+03	1.04E+03	5.87E+02
Nine Mile Point 2										
Oyster Creek 1	5.16E+05	8.66E+05	8.10E+05	2.79E+05	2.06E+05	1.67E+05	1.77E+05	9.98E+05	1.01E+06	3.12E+04
Peach Bottom 2&3			< 1.00E+03 <	1.00E+00	1.30E+04	2.09E+05	7.11E+04	3.85E+04	1.90E+05	1.53E+04
Perry 1										
Pilgrim 1		1.80E+04	2.30E+05	5.46E+05	4.60E+04	1.83E+05	4.13E+05	3.27E+04	1.39E+04	2.62E+04
Quad-Cities 1&2		1.32E+05	9.00E+05	9.50E+05	1.10E+05	3.36E+04	2.56E+04	3.24E+04	3.48E+04	2.15E+04
River Bend 1										
Shoreham 1										
Susquehanna 1&2										
Vermont Yankee 1		5.50E+04	1.80E+05	6.40E+04	4.08E+03	3.03E+03	3.35E+03	4.94E+03 <	8.08E+03	1.63E+03
WNP-2										
Total	3.25E+06	5.09E+06 <	6.33E+06 <	6.48E+06	6.22E+06 <	2.20E+06 <	2.65E+06	2.86E+06 <	1.80E+06 <	5.40E+05
• Fort St. Vrain									9.30E+01	9.13E+01

• High temperature gas cooled reactor

Table 1

Airborne Effluents Comparison By Year

Fission and Activation Gases (Total Curies)

Boiling Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Big Rock Point 1	1.97E+04	1.29E+04	1.10E+04	1.41E+05	6.26E+04	6.79E+04	8.35E+03	7.77E+03	7.08E+03	5.55E+03
Browns Ferry 1,2,& 3	4.52E+04	2.76E+05	4.79E+05	< 6.64E+05	< 2.64E+04	< 2.26E+03	3.22E-01	N/D	N/D	N/D
Brunswick 1&2	5.22E+05	4.65E+05	4.87E+05	1.67E+05	1.75E+04	4.51E+04	2.64E+04	1.58E+03	1.36E+03	1.12E+03
Clinton 1							6.83E+00	4.34E+00	1.29E+01	1.09E+01
Cooper	2.48E+03	1.42E+04	1.54E+03	< 1.44E+03	< 1.39E+03	1.72E+03	1.20E+03	1.81E+03	3.44E+02	1.87E+02
Dresden 1	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
Dresden 2-3	3.74E+04	1.04E+04	8.43E+03	1.81E+03	2.94E+03	4.38E+02	2.77E+02	1.68E+02	3.67E+01	2.04E+01
Duane Arnold	< 4.07E+02	9.99E+01	4.81E+02	4.16E+02	2.51E+02	3.10E+02	2.19E+02	7.06E+02	4.38E+01	4.57E+01
Fermi 2							N/D	1.11E+00	1.64E+02	1.61E+02
James A. Fitzpatrick	2.00E+05	2.11E+05	8.57E+04	3.41E+04	1.46E+04	2.65E+03	4.72E+03	3.89E+03	5.60E+02	1.35E+03
Grand Gulf 1			4.51E+01	1.14E+02	1.51E+02	1.34E+02	2.08E+02	9.44E+01	1.44E+02	1.36E+02
Edwin I. Hatch 1	2.77E+04	4.23E+03	1.96E+04	1.02E+04	9.86E+03	8.95E+03	7.40E+03	**	**	**
Edwin I. Hatch 2	2.06E+02	1.04E+03	1.28E+04	2.36E+03	2.76E+03	1.09E+04	1.37E+04	3.46E+03	5.02E+02	1.10E+03
Hope Creek 1							3.80E+01	1.19E+03	1.76E+02	3.34E+02
Humboldt Bay 3	< 4.40E-05	N/D	N/D	N/D	N/D	N/D	N/D	< 6.48E+01	< 6.40E+01	N/D
LaCrosse	5.03E+03	4.26E+03	7.08E+03	1.09E+04	8.58E+03	3.53E+03	2.33E+03	N/D	N/D	N/D
LaSalle 1&2		3.46E+00	1.17E+01	5.66E+02	1.95E+02	2.98E+03	6.51E+03	3.79E+03	1.08E+03	6.87E+02
Limerick 1&2				N/D	N/D	3.70E-01	2.41E+01	1.69E+02	2.58E+02	3.44E+01
Millstone 1	1.43E+04	8.33E+03	6.34E+03	2.80E+03	1.11E+03	3.31E+03	5.84E+03	8.76E+02	1.81E+02	1.17E+02
Monticello	3.74E+03	7.22E+03	3.21E+03	5.15E+02	2.72E+03	2.53E+03	3.95E+03	5.88E+03	3.98E+03	2.96E+03
Nine Mile Point 1	6.10E+02	5.11E+01	2.68E+02	1.02E+03	9.84E+02	4.92E+02	1.97E+02	1.80E+01	1.52E-04	N/D
Nine Mile Point 2							6.00E+00	4.03E+01	8.42E+01	1.63E+02
Oyster Creek 1	5.28E+04	2.29E+04	2.14E+03	3.93E+03	4.15E+04	7.67E+04	3.39E+03	5.05E+03	3.24E+02	7.35E+02
Peach Bottom 2&3	1.58E+04	1.31E+04	3.48E+04	8.09E+04	1.29E+05	2.78E+04	1.15E+04	1.19E+03	2.64E+03	1.12E+04
Perry 1						1.23E+00	1.06E+01	1.25E+03	1.92E+02	8.37E+01
Pilgrim 1	< 5.30E+03	< 1.94E+04	2.01E+04	< 1.84E+01	3.26E+03	1.26E+02	N/D	N/D	6.78E+02	9.07E+02
Quad-Cities 1&2	3.20E+04	1.17E+04	1.20E+04	6.02E+03	2.95E+03	1.48E+03	3.73E+02	3.77E+00	2.87E+02	7.96E+01
River Bend 1						1.70E+03	1.39E+00	2.05E+00	8.31E-01	1.03E+03
Shoreham 1						N/D	N/D	N/D	N/D	N/D
Susquehanna 1&2		< 5.61E+02	1.03E+02	1.18E+02	5.15E+02	2.35E+02	1.23E+02	7.25E+01	1.19E+02	7.21E+01
Vermont Yankee 1	< 3.17E+03	< 3.07E+03	< 3.13E+03	< 3.18E+03	< 3.44E+03	< 1.56E+03	N/D	N/D	1.03E+03	5.07E+03
WNP-2				2.28E+02	2.12E+02	1.66E+02	5.35E+02	9.03E+02	5.46E+03	8.90E+02
Total	< 9.88E+05	< 1.09E+06	< 1.19E+06	< 1.13E+06	< 3.33E+05	< 2.63E+05	9.85E+04	< 3.90E+04	< 2.70E+04	3.45E+04
* Fort St. Vrain	4.34E+01	2.96E+02	1.51E+02	1.17E+02	2.03E+00	5.57E+01	2.03E+02	2.60E+02	1.96E+02	N/D

* High temperature gas cooled reactor

** Included with Edwin I. Hatch 2 total

N/D = Not Detectable

Table 2

Airborne Effluents Comparison By Year

Fission and Activation Gases (Total Curies)

Pressurized Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Arkansas One 1				1.96E+02	1.03E+03	5.69E+03	1.39E+04	7.50E+03	8.51E+03	3.80E+04
Arkansas One 2									4.53E+03	9.37E+03
Beaver Valley 1&2						1.07E+00	4.73E+01	3.90E+02	1.75E+03	8.64E+01
Brakewood 1										
Brakewood 2										
Byron 1&2										
Callaway 1										
Calvert Cliffs 1&2					7.72E+03	9.40E+03	2.23E+04	2.76E+04	1.02E+04	2.96E+03
Catawba 1										
Catawba 2										
Comanche Peak 1										
Donald C. Cook 1&2					2.64E+00	9.75E+02	3.80E+03	4.85E+04	1.09E+04	3.76E+03
Crystal River 3							3.35E+03	6.86E+03	7.26E+04	3.65E+04
Davis-Besse 1							1.27E+03	2.10E+03	< 1.68E+03	< 3.35E+03
Diablo Canyon 1&2										
Joseph M. Farley 1								3.53E+03	3.18E+03	1.92E+04
Joseph M. Farley 2										
Fort Calhoun 1			6.70E+01	3.03E+02	4.29E+02	1.94E+03	3.81E+03	1.36E+03	7.06E+02	2.97E+02
R. E. Ginna	3.20E+01	1.20E+01	5.76E+02	7.57E+02	1.04E+04	5.52E+03	3.20E+03	9.72E+02	7.62E+02	8.61E+02
Haddam Neck	3.00E+00	1.00E+00	3.20E+01	7.00E+00	4.80E+02	4.52E+02	3.12E+03	2.14E+03	5.53E+03	2.68E+03
Harris 1										
Indian Point 1&2			1.50E+01	5.58E+03	8.20E+03	1.16E+04	1.60E+04	1.41E+04	9.03E+03	9.38E+03
Indian Point 3						Shown with	Other Unit	8.09E+02	2.47E+02	1.11E+03
Kewaunee				3.35E+03	2.45E+03	1.40E+03	2.43E+03	4.44E+02	1.52E+02	1.22E+02
** Maine Yankee		< 1.00E+00	1.61E+02	6.36E+03	4.09E+03	1.30E+03	3.57E+03	1.55E+03	2.09E+03	4.07E+03
McGuire 1										
McGuire 2										
Millstone 2						1.57E+03	2.28E+03	7.64E+02	3.59E+02	1.33E+03
Millstone 3										
North Anna 1&2								1.51E+04	6.28E+03	3.50E+03
Oconee 1,2,& 3			9.30E+03	1.94E+04	1.51E+04	4.39E+04	3.56E+04	4.33E+04	4.79E+04	1.92E+04
Palisades		1.00E+00	4.54E+02	< 1.00E+00	2.61E+03	2.99E+01	5.99E+01	3.23E+02	6.84E+01	1.40E+02
Palo Verde 1										
Palo Verde 2										
Palo Verde 3										
Point Beach 1&2	< 1.00E+00	3.00E+00	5.75E+03	9.74E+03	4.45E+04	1.91E+03	1.13E+03	5.16E+02	9.68E+02	6.41E+02
Prairie Island 1&2			8.72E+00	3.62E+02	2.17E+03	1.74E+03	6.73E+02	1.26E+03	6.97E+02	2.60E+02
Rancho Seco 1					1.18E+02	1.27E+02	2.00E+03	7.10E+03	8.81E+03	1.58E+03
H. B. Robinson 2	1.00E+00	< 1.00E+00	3.10E+03	2.31E+03	1.17E+03	6.40E+02	4.76E+02	8.84E+02	1.52E+03	5.82E+02
Salem 1						< 1.00E-02	1.96E+01	1.02E+01	2.49E+02	7.82E+01
Salem 2										7.74E+00
San Onofre 1	8.00E+00	1.90E+01	1.10E+04	1.78E+03	1.11E+03	4.16E+02	1.54E+02	1.81E+03	6.37E+02	1.05E+03
San Onofre 2-3										
Seabrook 1										
Sequoyah 1&2										3.01E+03
South Texas 1										
South Texas 2										
St. Lucie 1						1.72E+03	2.54E+04	2.93E+04	1.54E+04	8.97E+03
St. Lucie 2										
Summer 1										
Surry 1&2		< 1.00E+00	8.66E+02	6.86E+03	8.04E+03	1.91E+04	1.90E+04	4.36E+03	1.78E+03	6.17E+03
Three Mile Island 1				9.16E+02	3.63E+03	2.76E+03	1.66E+04	1.57E+04	2.24E+03	4.64E-03
Three Mile Island 2								8.73E+00	9.97E+06	4.72E+04
TMI 2/Epicor										2.16E+00
* Trojan						7.66E+02	4.45E+03	3.26E+02	9.47E+02	4.10E+02

* Changes to the entries for Trojan for 1976 - 1987 represent corrections which were reported and explained in the Trojan July-December 1990 Effluent and Waste Disposal Report.

** Changes to the entries for Maine Yankee for 1977 - 1988 represent corrections which were reported and explained in the Maine Yankee report "Revised Semiannual Effluent Release Report for 770131 - 901231" Docket Date 92/01/08.

Table 2

Airborne Effluents Comparison By Year

Fission and Activation Gases (Total Curies)

Pressurized Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Turkey Point 3&4			5.30E+02	4.66E+03	1.34E+04	1.56E+04	2.33E+04	2.35E+04	1.06E+04	4.24E+03
Turkey Point 3										
Turkey Point 4										
Vogtle 1&2										
Waterford 3										
Wolf Creek 1										
Yankee Rowe 1	< 1.00E+00	< 1.00E+00	3.50E+01	4.00E+01	2.24E+01	2.57E+01	1.25E+02	6.56E+02	1.82E+02	7.07E+01
Zion 1&2			4.00E+00	2.99E+03	4.88E+04	1.14E+05	3.22E+04	6.77E+04	3.41E+04	5.78E+03
Total	< 4.60E+01	< 4.00E+01	3.19E+04	< 6.56E+04	1.75E+05	< 2.43E+05	2.40E+05	3.30E+05	< 1.02E+07	< 2.36E+05

Table 2

Airborne Effluents Comparison By Year

Fission and Activation Gases (Total Curies)

Pressurized Water Reactors Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Arkansas One 1	3.73E+03	2.10E+03	9.83E+02	2.90E+03	8.10E+03	1.71E+03	3.26E+02	1.24E+03	2.33E+03	7.00E+02
Arkansas One 2	4.35E+03	9.78E+03	1.34E+03	3.26E+03	8.91E+03	3.46E+03	2.06E+02	2.16E+03	2.76E+03	1.89E+02
Beaver Valley 1&2	8.06E+02	1.31E+02	1.98E+02	1.16E+03	3.92E+01	7.57E+01	2.25E+02	9.41E+01	1.57E+02	8.17E+01
Braidwood 1							2.81E-01	4.19E+01	1.17E+03	1.42E+03
Braidwood 2								3.82E+01	5.07E+02	1.02E+03
Byron 1&2					2.79E+02	6.36E+02	1.30E+03	1.78E+03	8.16E+02	1.24E+03
Callaway 1				2.00E+02	1.67E+03	5.19E+03	2.90E+03	6.89E+02	7.22E+02	9.02E+02
Calvert Cliffs 1&2	2.18E+03	8.00E+03	9.75E+03	3.83E+03	3.98E+03	7.65E+03	4.55E+03	5.70E+03	3.28E+03	6.72E+02
Catawba 1					2.77E+02	1.36E+03	2.41E+03	1.56E+03	3.15E+02	5.33E+02
Catawba 2						1.36E+03	2.41E+03	1.56E+03	3.15E+02	5.33E+02
Comanche Peak 1										9.06E+02
Donald C. Cook 1&2	5.42E+03	3.88E+03	3.28E+02	3.50E+03	4.94E+03	3.29E+02	8.75E+02	2.58E+02	1.15E+02	1.88E+02
Crystal River 3	3.96E+04	6.85E+03	3.38E+03	1.96E+03	1.05E+03	2.76E+03	1.10E+03	3.41E+03	4.54E+03	7.31E+03
Davis-Besse 1	1.01E+03	5.35E+02	9.15E+02	5.02E+02	1.18E+02	5.09E+04	3.80E+02	1.09E+02	3.78E+02	1.09E+03
Diablo Canyon 1&2				5.86E-02	5.72E+02	2.32E+03	7.14E+02	3.27E+02	3.35E+02	5.63E+01
Joseph M. Farley 1	2.21E+02	3.81E+04	2.20E+04	3.73E+03	1.70E+03	1.28E+03	1.30E+03	9.60E+02	9.92E+01	8.72E+01
Joseph M. Farley 2	2.60E+00	3.54E+03	8.47E+02	3.99E+03	6.63E+02	1.84E+03	7.22E+02	5.92E+02	1.60E+02	3.38E+01
Fort Calhoun 1	1.22E+03	3.46E+02	8.79E+02	1.52E+03	1.48E+03	5.68E+02	4.23E+02	7.85E+02	1.64E+02	4.59E+02
R. E. Ginna	5.46E+02	1.95E+03	7.12E+02	2.96E+02	4.06E+02	2.09E+02	1.77E+02	5.17E+01	5.11E+02	5.95E+02
Haddam Neck	1.83E+03	7.54E+02	2.76E+03	7.52E+03	2.76E+03	2.33E+03	3.58E+03	2.55E+03	1.71E+04	1.46E+03
Harris 1							1.71E+03	2.25E+03	1.15E+03	5.96E+02
Indian Point 1&2	9.13E+03	7.27E+03	9.58E+03	3.78E+03	1.88E+03	2.05E+03	4.68E+03	2.27E+02	8.77E+01	2.23E+03
Indian Point 3	6.57E+03	2.58E+03	5.60E+02	1.88E+03	1.54E+03	1.93E+03	1.82E+03	3.10E+02	3.14E+02	6.26E+02
Kewaunee	1.18E+02	1.66E+02	2.25E+02	4.04E+01	4.97E+01	6.55E+01	3.19E+01	2.91E+01	6.52E+01	2.31E+00
** Maine Yankee	3.28E+02	1.53E+03	5.07E+01	1.54E+02	4.41E+02	1.07E+03	8.34E+02	9.19E+01	2.02E+01	9.46E+02
McGuire 1	1.58E-01	1.65E-03	1.60E+03	2.28E+03	1.93E+03	1.05E+03	2.04E+03	1.95E+03	7.19E+02	5.18E+02
McGuire 2			1.60E+03	2.28E+03	1.93E+03	1.05E+03	2.04E+03	1.95E+03	7.19E+02	5.18E+02
Millstone 2	2.24E+03	9.09E+03	9.06E+03	4.19E+03	4.00E+02	1.02E+02	3.97E+02	6.34E+02	2.46E+02	2.89E+03
Millstone 3						2.39E+01	1.05E+02	8.44E+01	2.96E+02	2.11E+02
North Anna 1&2	5.30E+03	4.34E+03	2.22E+04	1.76E+04	8.05E+03	5.71E+03	1.05E+03	4.83E+02	1.44E+03	9.52E+02
Oconee 1,2,& 3	1.63E+04	2.41E+04	2.40E+04	2.28E+04	2.35E+04	2.43E+04	1.05E+04	2.59E+04	8.97E+03	8.84E+03
Palisades	3.00E+03	7.38E+03	3.00E+03	2.84E+01	3.68E+03	1.73E+02	1.75E+03	2.43E+03	1.52E+02	1.21E+02
Palo Verde 1					2.53E+02	2.67E+03	1.27E+03	1.84E+03	6.41E+02	7.08E+02
Palo Verde 2						1.97E+03	5.47E+03	2.97E+03	4.29E+02	6.76E+02
Palo Verde 3							2.52E-02	1.36E+02	8.34E+02	1.20E+03
Point Beach 1&2	6.11E+02	9.93E+02	7.68E+02	9.30E+01	1.16E+02	2.78E+01	4.82E+01	8.08E+01	1.50E+01	8.03E+00
Prairie Island 1&2	4.65E+01	5.47E+02	2.76E+02	7.58E+01	4.59E+01	3.03E+01	8.77E-01	1.42E-01	1.73E+02	8.28E+01
Rancho Seco 1	1.37E+03	1.48E+03	6.89E+02	3.83E+03	4.67E+03	9.30E+01	2.16E-02	1.52E+03	2.00E+03	2.20E-01
H. B. Robinson 2	5.13E+02	1.75E+02	2.93E+02	4.90E+01	2.14E+03	6.59E+02	7.70E+02	1.04E+03	2.79E+01	7.20E+00
Salem 1	1.06E+03	2.34E+02	1.25E+02	1.95E+02	1.68E+03	1.39E+03	3.64E+03	5.29E+02	1.39E+03	3.13E+02
Salem 2	6.09E+02	1.11E+03	7.44E+02	1.81E+03	1.15E+03	8.56E+02	1.06E+03	1.18E+03	7.30E+01	1.49E+02
San Onofre 1	4.17E+02	8.61E+01	1.06E+01	8.62E+01	3.83E+03	4.11E+02	9.81E+02	2.99E+03	9.05E+02	1.80E+03
San Onofre 2-3		6.40E+00	7.43E+03	4.00E+04	2.53E+04	8.25E+03	2.18E+04	5.12E+03	2.46E+03	1.16E+03
Seabrook 1									N/D	1.07E+02
Sequoyah 1&2	9.03E+03	5.74E+03	3.92E+03	6.68E+03	4.57E+03	1.21E+00	N/D	2.25E+02	3.85E+03	6.07E+03
South Texas 1								8.64E+02	4.45E+02	1.72E+02
South Texas 2									1.16E+02	1.09E+02
St. Lucie 1	2.30E+04	2.33E+04	2.16E+04	3.53E+04	5.08E+04	3.33E+04	6.21E+03	1.42E+03	4.53E+03	6.19E+02
St. Lucie 2			1.25E+03	7.68E+03	9.55E+03	9.98E+03	8.60E+03	9.16E+03	2.22E+03	5.34E+02
Summer 1		1.40E+02	3.88E+02	1.64E+01	1.40E+02	1.39E+01	6.34E+02	3.32E+02	1.82E+03	7.51E+02
Surry 1&2	1.41E+04	2.11E+04	5.49E+03	6.95E+03	2.07E+03	1.99E+03	3.08E+02	3.66E+02	1.37E+02	4.51E+02
Three Mile Island 1	5.81E-02	7.56E-03	2.01E+01	3.62E-01	1.08E+02	3.80E+03	7.89E+02	1.87E+03	2.10E+03	6.66E+02
Three Mile Island 2	2.88E+02	4.89E+02	1.73E+02	2.07E+02	N/D	2.80E-01	N/D	4.40E-01	N/D	N/D
TMI 2/Epicor	1.84E+02	4.26E+02	3.61E+01	3.99E+01	+	+	+	+	+	+
* Trojan	1.24E+03	9.02E+02	2.29E+02	8.98E+02	1.10E+03	9.42E+02	2.55E+02	4.25E+02	5.94E+02	2.06E+02

* Changes to the entries for Trojan for 1976-1987 are corrections which were reported and explained in the Trojan July-December 1990 Effluent and Waste Disposal Report.

** Changes to the entries for Maine Yankee for 1977 - 1988 are corrections which were reported and explained in the Maine Yankee report "Revised Semiannual Effluent and Release Reports for 770131 - 901231" Docket Date 92/01/08.

*** Included with Three Mile Island 2 total

N/D = Not Detectable

Table 2

Airborne Effluents Comparison By Year

Fission and Activation Gases (Total Curies)

Pressurized Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Turkey Point 3&4	4.33E+03	2.00E+04	1.61E+04	1.16E+04						
Turkey Point 3					1.32E+03	3.64E+03	9.38E+02	1.25E+03	1.70E+03	6.88E+02
Turkey Point 4					1.80E+03	1.01E+03	7.86E+02	1.31E+03	1.71E+03	5.92E+02
Vogtle 1&2							1.07E+02	1.15E+02	5.46E+02	1.88E+02
Waterford 3					8.21E+03	1.12E+04	5.63E+03	5.30E+03	5.59E+02	5.73E+03
Wolf Creek 1					1.72E+02	3.15E+01	1.73E+02	7.92E+02	6.40E+02	9.99E+02
Yankee Rowe 1	1.72E+02	1.55E+02	7.51E+02	1.74E+03	1.47E+03	5.11E+02	3.84E+02	2.06E+02	1.21E+02	1.13E+02
Zion 1&2	6.91E+03	1.61E+04	6.34E+03	3.61E+03	3.88E+03	3.18E+03	1.18E+02	1.39E+03	1.12E+03	1.10E+02
Total	1.68E+05	2.25E+05	< 1.83E+05	< 2.10E+05	< 2.05E+05	< 1.57E+05	< 1.11E+05	< 1.03E+05	8.11E+04	6.21E+04

Table 3

Airborne Effluents Comparison By Year

I-131 and Particulates (Curies)

(Half-Life Equal To or Greater Than 8 Days)

Boiling Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Big Rock Point 1	6.10E-01	1.50E-01	4.60E+00	1.60E-01	1.20E-01	5.00E-02	1.00E-02	8.91E-03	1.90E-03	2.94E-02
Browns Ferry 1,2,& 3				1.20E-01	2.70E-01	< 7.00E-02	1.04E-01	2.27E-01	5.03E-02	1.05E-01
Brunswick 1&2					< 1.00E-02	4.60E-01	9.32E-01	4.07E-01	9.52E-01	2.12E+00
Clinton 1										
Cooper				2.40E-01	5.00E-02	< 4.00E-02	< 1.91E-02	5.41E-03	< 1.79E-01	< 1.52E-01
Dresden 1	6.70E-01	2.75E+00	4.00E-02	6.80E-01	9.60E-01	8.40E-01	4.93E+00	2.28E+00	2.38E-02	1.46E-02
Dresden 2-3	8.68E+00	5.89E+00	6.70E+00	6.50E+00	4.31E+00	5.49E+00	6.86E+00	3.13E+00	6.97E+00	1.10E+01
Duane Arnold					1.10E-03	8.18E-02	2.29E-02	3.65E-02	3.35E-02	8.50E-02
Fermi 2										
James A. Fitzpatrick					< 4.00E-02	6.80E-01	1.73E-01	2.79E-01	1.42E-02	1.25E-01
Grand Gulf 1										
Edwin I. Hatch 1					< 1.00E-02	< 1.00E-02	5.67E-03	4.13E-03	2.59E-02	4.29E-01
Edwin I. Hatch 2										1.33E-02
Hope Creek 1										
Humboldt Bay 3	3.00E-01	4.80E-01	2.90E-01	8.40E-01	1.06E+00	8.36E-02	4.04E-03	7.26E-04	1.07E-04	5.11E-04
LaCrosse	< 1.00E-02	7.10E-01	2.00E-01	4.00E-02	1.00E-01	< 7.06E-02	1.67E-01	2.79E-02	2.53E-02	1.32E-02
LaSalle 1&2										
Limerick 1&2										
Millstone 1	4.00E+00	1.32E+00	2.00E-01	3.26E+00	9.98E+00	2.33E+00	4.86E+00	4.55E+00	5.90E-01	3.32E-01
Monticello	3.60E-02	5.78E-01	1.20E+00	5.70E+00	3.71E+00	1.71E-01	8.51E-02	5.49E-02	3.39E-02	2.83E-02
Nine Mile Point 1	6.00E-02	9.70E-01	1.98E+00	8.90E-01	2.78E+00	2.20E+00	1.99E-01	1.35E-01	4.71E-02	2.55E-02
Nine Mile Point 2										
Oyster Creek 1	2.14E+00	6.48E+00	7.02E+00	3.51E+00	5.64E+00	6.39E+00	9.05E+00	1.81E+01	9.32E+00	1.25E+00
Peach Bottom 2&3			< 1.00E-02	1.00E-02	4.00E-02	9.75E-01	2.73E-01	9.62E-02	2.58E-01	2.94E-02
Perry 1										
Pilgrim 1		3.00E-02	4.70E-01	1.45E+00	2.58E+00	6.74E-01	6.90E-01	1.81E-01	1.45E-01	1.04E-01
Quad-Cities 1&2		7.50E-01	5.50E+00	8.88E+00	1.31E+00	1.33E+00	1.69E+00	2.15E+00	1.57E+00	5.90E-01
River Bend 1										
Shoreham 1										
Susquehanna 1&2										
Vermont Yankee 1		1.70E-01	7.00E-02	3.60E-01	1.00E-02	< 1.00E-02	1.44E-02	2.18E-01	4.43E-01	1.70E-02
WNP-2										
Total	< 1.65E+01	2.03E+01	< 2.83E+01	3.26E+01	< 3.30E+01	< 2.20E+01	< 3.01E+01	3.19E+01	< 2.07E+01	< 1.65E+01
• Fort St. Vrain									6.89E-07	1.25E-06

• High temperature gas cooled reactor

Table 3

Airborne Effluents Comparison By Year

I-131 and Particulates (Curies)

(Half-Life Equal To or Greater Than 8 Days)

Boiling Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Big Rock Point 1	6.10E-03	4.71E-03	3.35E-03	1.32E-01	8.25E-02	7.56E-02	2.94E-02	5.07E-02	4.87E-03	5.71E-03
Browns Ferry 1,2,& 3	N/D	1.89E-01	2.83E-01	1.72E-01	2.49E-02	2.73E-03	1.78E-03	1.76E-03	1.86E-04	1.88E-04
Brunswick 1&2	8.89E-01	1.99E+00	6.25E+00	3.49E-01	6.32E-02	4.69E-02	1.82E-01	1.77E-01	4.84E-02	4.83E-02
Clinton 1							2.58E-04	5.94E-02	9.52E-03	8.71E-03
Cooper	< 1.09E-02	< 1.55E-01	< 2.30E-02	< 1.15E-02	< 2.29E-02	< 1.16E-02	2.67E-02	2.04E-02	5.26E-03	3.53E-04
Dresden 1	9.94E-03	3.36E-04	7.56E-04	1.69E-03	9.23E-05	+	+	+	1.07E-04	2.59E-04
Dresden 2-3	9.87E+00	9.50E-01	6.32E-01	1.70E-01	1.56E-01	7.11E-02	1.45E-01	2.35E-01	1.15E+00	1.51E-01
Duane Arnold	3.25E-02	1.03E-02	1.50E-02	1.53E-02	8.89E-03	7.32E-02	1.37E-01	1.55E-02	3.16E-03	4.45E-03
Fermi 2						2.68E-07	8.56E-03	2.78E-03	1.67E-02	1.54E-02
James A. Fitzpatrick	2.80E-01	7.71E-01	3.80E-01	2.10E-01	1.67E-01	8.66E-02	1.36E-01	7.00E-02	7.12E-02	1.91E-02
Grand Gulf 1			4.50E-05	1.86E-04	7.53E-04	4.85E-04	4.28E-03	4.90E-04	1.08E-03	9.98E-04
Edwin I. Hatch 1	2.12E-01	1.84E-01	6.96E-02	6.57E-02	3.98E-02	1.50E-02	2.54E-01	**	**	**
Edwin I. Hatch 2	9.42E-03	6.83E-02	1.95E-02	1.15E-02	3.47E-02	1.79E-02	1.16E-01	4.29E-02	5.73E-03	7.64E-03
Hope Creek 1						N/D	N/D	N/D	N/D	5.47E-03
Humboldt Bay 3	< 3.82E-04	1.09E-04	2.68E-04	2.68E-04	7.62E-05	1.64E-04	6.78E-05	1.49E-04	3.67E-05	3.85E-05
LaCrosse	1.69E-02	8.35E-03	1.08E-02	6.90E-03	9.62E-03	5.91E-03	2.31E-03	1.11E-05	1.29E-05	1.80E-04
LaSalle 1&2		4.16E-03	1.80E-02	1.06E-02	2.32E-02	7.09E-02	4.97E-02	1.34E-02	8.23E-03	3.44E-03
Limerick 1&2				N/D	N/D	7.45E-03	1.17E-03	6.67E-03	7.60E-03	7.64E-04
Millstone 1	1.48E-01	2.09E-01	6.25E-02	6.24E-02	5.20E-02	4.71E-02	2.50E-02	7.60E-03	9.35E-03	2.60E-03
Monticello	3.45E-02	8.85E-02	4.10E-02	2.93E-02	9.95E-02	6.86E-02	1.73E-01	7.90E-02	1.14E-01	4.34E-02
Nine Mile Point 1	1.49E-02	2.71E-02	1.07E-02	1.75E-02	3.46E-02	1.75E-02	1.61E-02	1.89E-03	3.02E-03	2.72E-03
Nine Mile Point 2							5.17E+00	6.90E-04	5.04E-03	4.95E-03
Oyster Creek 1	2.24E+00	1.04E+00	1.90E-02	4.37E-01	3.04E+00	7.00E-01	1.04E-01	6.35E-02	5.08E-02	3.14E-02
Peach Bottom 2&3	< 4.19E-02	3.90E-02	4.60E-02	1.02E-01	6.88E-02	5.20E-02	2.00E-02	1.50E-03	3.45E-03	1.82E-02
Perry 1						1.13E-06	4.87E-05	4.62E-02	8.54E-03	1.11E-02
Pilgrim 1	< 6.87E-02	< 4.44E-02	< 4.69E-02	< 5.17E-03	< 5.68E-02	< 1.24E-02	< 8.43E-04	3.82E-04	5.62E-03	1.02E-02
Quad-Cities 1&2	1.27E+00	4.12E-01	4.36E-01	8.86E-02	6.06E-01	1.11E-01	9.40E-02	2.46E-02	4.06E-02	3.34E-02
River Bend 1						4.62E-05	4.03E-04	9.66E-04	4.13E-04	5.17E-02
Shoreham 1						N/D	N/D	N/D	N/D	N/D
Susquehanna 1&2		< 8.70E-04	9.43E-04	1.48E-02	2.66E-02	3.39E-03	6.08E-03	1.82E-03	1.11E-03	8.63E-04
Vermont Yankee 1	4.53E-03	1.45E-03	4.14E-03	6.87E-03	< 5.87E-03	< 1.29E-02	1.27E-02	6.58E-03	8.92E-03	7.24E-02
WNP-2				3.77E-01	2.43E-01	7.00E-02	7.71E-02	4.96E-01	1.17E-01	1.50E-01
Total	< 1.52E+01	< 6.20E+00	< 8.37E+00	< 2.26E+00	< 4.87E+00	< 1.58E+00	< 6.79E+00	1.43E+00	1.70E+00	7.05E-01
* Fort St. Vrain	1.40E-06	2.61E-01	7.40E-07	2.78E-06	6.31E-07	N/D	N/D	< 1.79E-05	N/D	N/D

+ Included with Dresden 2-3 total

* High temperature gas cooled reactor

** Included with Edwin I. Hatch 2 total

N/D = Not Detectable

Table 4

Airborne Effluents Comparison By Year

I-131 and Particulates (Curies)
(Half-Life Equal To or Greater Than 8 Days)

Pressurized Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Arkansas One 1				5.00E-02	7.40E-01	5.73E-02	9.04E-03	3.19E-03	4.47E-03	1.66E-01
Arkansas One 2									4.65E-03	6.90E-03
Beaver Valley 1&2						# < 1.00E-02	1.52E-04	7.21E-02	4.07E-04	1.91E-03
Brakewood 1										
Brakewood 2										
Byron 1&2										
Callaway 1										
Calvert Cliffs 1&2					7.00E-02	1.38E-01	3.07E-01	1.35E-01	2.05E+00	7.44E-02
Catawba 1										
Catawba 2										
Comanche Peak 1										
Donald C. Cook 1&2					< 1.00E-02	< 1.00E-02	7.45E-02	1.10E-01	7.36E-02	6.88E-02
Crystal River 3							2.53E-03	1.05E-03	1.88E-02	6.77E-03
Davis-Besse 1							2.57E-04	4.30E-04	5.69E-03	2.01E-03
Diablo Canyon 1&2										
Joseph M. Farley 1								4.11E-02	2.20E-02	2.37E-03
Joseph M. Farley 2										
Fort Calhoun 1			< 1.00E-02	< 1.00E-02	< 1.00E-02	< 2.04E-02	1.34E-02	8.30E-03	1.58E-03	2.42E-03
R. E. Ginna	1.70E-01	4.00E-02	< 1.00E-02	< 1.00E-02	2.00E-02	3.17E-02	2.55E-02	1.04E-02	1.88E-02	9.00E-03
Haddam Neck		2.00E-02	5.00E-02	< 1.00E-02	< 1.00E-02	< 1.00E-02	1.74E-03	5.21E-03	4.77E-02	8.01E-03
Harris 1										
Indian Point 1&2			< 1.00E-02	4.30E-01	1.62E+00	2.42E-01	5.59E-02	2.05E-01	4.50E-01	6.42E-02
Indian Point 3						Shown With Other Unit	1.29E-02	3.89E-03	2.53E-02	
Kewaunee				2.00E-02	6.60E-01	< 1.00E-02	2.40E-02	5.48E-03	6.18E-04	2.61E-04
** Maine Yankee		< 1.00E-02	9.40E-01	5.00E-02	< 1.00E-02	< 1.00E-02	1.07E-02	4.39E-03	1.16E-01	3.67E-03
McGuire 1										
McGuire 2										
Millstone 2					1.00E-02	1.25E-02	4.47E-03	2.97E-03	9.79E-03	1.94E-02
Millstone 3										
North Anna 1&2								3.19E-02	5.71E-02	1.26E-02
Oconee 1,2,& 3			1.00E-02	3.00E-02	1.00E-02	2.72E-01	5.35E-01	2.22E-01	2.28E-01	1.33E-01
Palisades		< 1.00E-02	3.10E-01	1.00E-02	3.80E-01	4.16E-02	1.63E-02	2.07E-02	2.46E-02	2.76E-02
Palo Verde 1										
Palo Verde 2										
Palo Verde 3										
Point Beach 1&2	< 1.00E-02	3.00E-02	5.50E-01	1.60E-01	7.00E-02	1.85E-02	5.02E-03	2.88E-02	1.35E-02	1.28E-03
Prairie Island 1&2			< 1.00E-02	< 1.00E-02	2.12E-02	1.14E-02	7.58E-03	8.96E-04	3.86E-03	1.83E-03
Rancho Seco 1					< 1.00E-02	< 1.00E-02	5.02E-03	3.21E-02	5.75E-03	9.96E-03
H. B. Robinson 2		3.00E-02	3.00E-01	5.00E-02	2.00E-02	9.96E-02	3.88E-03	9.26E-04	4.10E-04	1.13E-03
Salem 1						N/D	2.34E-07	4.01E-02	7.68E-03	2.17E-01
Salem 2										5.44E-05
San Onofre 1	< 1.00E-02	< 1.00E-02	1.61E+00	< 1.00E-02	4.00E-02	< 1.00E-02	1.86E-04	2.71E-03	1.43E-04	8.41E-01
San Onofre 2-3										
Seabrook 1										
Sequoyah 1&2										2.57E-03
South Texas 1										
South Texas 2										
St. Lucie 1						< 1.00E-02	1.48E-01	5.17E-01	2.02E-01	6.20E-02
St. Lucie 2										
Summer 1										
Surry 1&2		< 1.00E-02	4.00E-02	1.40E-01	5.00E-02	3.46E-01	1.20E-01	6.49E-02	7.61E-03	1.85E-02
Three Mile Island 1				< 1.00E-02	< 1.00E-02	1.07E-02	3.39E-02	1.35E-01	1.24E-02	2.93E-04
Three Mile Island 2								2.30E-03	1.42E+01	5.67E-04
TMI 2/Epicor										6.83E-06
* Trojan						2.84E-02	3.56E-02	8.28E-03	2.48E-02	1.84E-02

* Changes to the entries for Trojan for 1976-1987 are corrections which were reported and explained in the Trojan July-December 1990 Effluent and Waste Disposal Report.

I-131 not included

** Changes to the entries for Maine Yankee for 1977 - 1988 are corrections which were reported and explained in the Maine Yankee report "Revised Semiannual Effluent Release Reports for 770131 - 901231" Docket Date 92/01/08.

N/D = Not Detectable

Table 4

Airborne Effluents Comparison By Year

I-131 and Particulates (Curies)
(Half-Life Equal To or Greater Than 8 Days)

Pressurized Water Reactor:

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Turkey Point 3&4			6.00E-02	3.63E+00	4.30E-01	4.22E-01	1.04E+00	4.59E-01	7.91E-02	7.05E-02
Turkey Point 3										
Turkey Point 4										
Vogtle 1&2										
Waterford 3										
Wolf Creek 1										
Yankee Rowe 1	< 1.00E-02	< 1.00E-02	1.90E-01	5.30E-01	1.00E-02	< 1.00E-02	8.70E-05	2.25E-04	2.49E-04	9.56E-05
Zion 1&2			< 1.00E-02	1.00E-02	1.40E-01	9.00E-02	5.38E-02	8.91E-02	6.74E-02	3.00E-03
Total	< 2.00E-01	< 1.70E-01	< 4.11E+00	< 5.17E+00	< 4.35E+00	< 1.93E+00	2.53E+00	2.27E+00	1.78E+01	1.88E+00

Table 4

Airborne Effluents Comparison By Year

I-131 and Particulates (Curies)
(Half-Life Equal To or Greater Than 8 Days)

Pressurized Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Arkansas One 1	5.58E-03	9.07E-04	1.15E-03	1.14E-03	3.50E-03	4.01E-03	3.05E-04	1.03E-03	8.17E-04	8.94E-04
Arkansas One 2	1.41E-02	4.92E-03	5.78E-03	2.54E-04	3.27E-03	2.36E-04	5.12E-05	4.21E-04	5.87E-04	2.03E-04
Beaver Valley 1&2	6.85E-03	4.56E-03	5.25E-02	6.21E-03	1.58E-03	7.83E-03	1.36E-02	3.54E-03	1.11E-02	3.20E-04
Braidwood 1							1.34E-05	2.44E-02	2.54E-04	1.56E-03
Braidwood 2								9.52E-05	2.86E-04	5.61E-04
Byron 1&2					2.18E-03	5.45E-02	9.45E-03	1.28E-02	7.93E-04	4.08E-03
Callaway 1				9.41E-07	3.23E-04	1.18E-03	4.46E-04	3.36E-04	1.66E-04	1.46E-04
Calvert Cliffs 1&2	4.69E-02	1.84E-01	1.02E-01	6.02E-02	5.36E-02	8.73E-02	9.18E-02	1.36E-01	4.81E-02	1.69E-03
Catawba 1					5.71E-04	6.69E-03	7.42E-03	4.05E-03	7.46E-04	8.60E-04
Catawba 2						6.69E-03	7.42E-03	4.05E-03	7.46E-04	8.60E-04
Comanche Peak 1										N/D
Donald C. Cook 1&2	3.55E-01	1.28E-01	5.75E-02	2.09E-02	1.78E-01	2.29E-02	6.44E-02	8.92E-03	3.44E-02	7.35E-02
Crystal River 3	1.78E-02	3.22E-03	1.58E-03	2.07E-04	7.31E-04	1.02E-03	3.49E-03	1.25E-03	2.02E-03	7.68E-04
Davis-Besse 1	5.79E-02	5.28E-03	7.37E-03	1.66E-03	5.13E-04	N/D	1.24E-03	4.76E-04	3.06E-03	2.38E-03
Diablo Canyon 1&2				1.20E-05	2.40E-04	1.44E-03	2.36E-03	1.29E-03	9.75E-04	5.94E-05
Joseph M. Farley 1	6.24E-01	9.09E-02	4.60E-02	5.87E-03	5.60E-03	7.96E-04	3.81E-04	1.60E-03	3.64E-05	N/D
Joseph M. Farley 2	3.22E-03	6.51E-05	5.06E-05	1.54E-03	2.97E-04	1.35E-03	1.49E-04	2.51E-06	7.89E-07	3.15E-06
Fort Calhoun 1	3.63E-03	1.59E-03	9.32E-04	1.25E-02	7.29E-03	1.48E-03	5.11E-03	3.10E-04	1.27E-04	1.81E-03
R. E. Ginna	5.88E-03	1.36E-02	1.53E-02	1.62E-03	9.74E-04	4.04E-04	8.71E-03	5.69E-05	8.38E-04	5.14E-03
Haddam Neck	< 1.28E-02	< 5.41E-04	< 1.02E-02	5.72E-02	1.13E-03	9.36E-03	1.35E-03	3.69E-02	1.50E-02	4.71E-03
Harris 1							4.43E-06	4.59E-05	1.79E-06	7.72E-05
Indian Point 1&2	4.42E-02	4.17E-02	2.06E-02	< 1.51E-01	1.44E+00	4.59E-01	1.57E-02	9.18E-03	3.88E-03	5.36E-03
Indian Point 3	3.63E-03	< 4.28E-03	< 1.53E-04	2.04E-02	1.90E-03	4.01E-03	2.07E-03	3.42E-03	1.36E-03	1.81E-04
Kewaunee	1.21E-04	5.97E-05	< 2.16E-04	< 4.05E-03	2.77E-04	< 5.58E-03	< 1.23E-02	< 1.05E-02	1.75E-02	3.24E-03
** Maine Yankee	1.21E-03	2.55E-04	1.48E-04	7.14E-03	8.17E-04	4.60E-03	5.05E-03	5.10E-04	2.39E-04	1.81E-02
McGuire 1	1.21E-11	9.51E-04	1.89E-03	1.25E-02	1.29E-02	3.03E-02	6.08E-02	6.14E-03	3.76E-03	1.02E-03
McGuire 2			1.89E-03	1.25E-02	1.29E-02	3.03E-02	6.08E-02	6.14E-03	3.76E-03	1.02E-03
Millstone 2	1.06E-01	3.19E-01	5.73E-02	3.71E-02	6.48E-03	5.37E-03	6.51E-03	5.13E-02	3.78E-02	2.08E-02
Millstone 3						< 3.69E-04	5.09E-03	9.89E-03	1.28E-02	2.46E-03
North Anna 1&2	4.81E-01	3.49E-02	3.28E-01	8.65E-02	8.57E-02	2.27E-02	1.73E-02	2.30E-03	4.33E-03	7.05E-03
Oconee 1,2,& 3	3.24E-01	2.55E-01	1.13E-01	1.07E-01	4.92E-03	4.34E-02	1.46E-01	1.63E-01	3.56E-02	9.02E-03
Palisades	4.15E-02	2.30E-02	3.44E-02	9.92E-04	4.92E-02	3.03E-03	2.77E-02	2.65E-02	1.73E-02	2.13E-03
Palo Verde 1					1.43E-03	7.78E-03	5.81E-02	1.82E-03	7.58E-04	2.69E-03
Palo Verde 2						3.49E-03	1.34E-02	4.67E-02	3.03E-03	2.66E-03
Palo Verde 3							N/D	1.24E-04	6.45E-03	6.34E-04
Point Beach 1&2	2.03E-01	8.46E-03	1.82E-02	1.25E-03	9.05E-03	1.69E-03	3.08E-03	2.23E-03	3.27E-03	3.02E-04
Prairie Island 1&2	4.49E-04	3.74E-03	1.40E-02	1.44E-03	7.35E-03	2.22E-03	2.33E-04	7.74E-05	2.10E-05	1.50E-03
Rancho Seco 1	4.65E-03	2.62E-02	2.26E-03	2.37E-02	7.84E-03	1.49E-03	1.54E-06	4.74E-04	2.76E-04	N/D
H. B. Robinson 2	3.32E-04	5.70E-04	1.31E-02	2.47E-04	1.37E-02	9.92E-03	2.08E-02	1.10E-03	1.41E-04	1.34E-04
Salem 1	4.84E-01	7.85E-03	6.25E-02	5.16E-04	4.45E-02	1.17E-03	1.66E-03	2.13E-03	3.62E-03	1.20E-03
Salem 2	6.31E-03	4.54E-03	3.53E-02	5.41E-03	8.95E-02	3.23E-03	1.52E-03	9.91E-04	8.70E-04	2.06E-04
San Onofre 1	1.18E-02	4.66E-07	5.44E-06	9.49E-06	1.17E-03	2.09E-04	4.17E-04	1.08E-02	2.22E-03	7.25E-03
San Onofre 2-3		3.35E-05	1.56E-01	4.12E-01	4.47E-01	1.62E-01	4.20E-01	7.75E-02	4.73E-01	7.05E-03
Seabrook 1									N/D	N/D
Sequoyah 1&2	1.30E-02	1.23E-01	2.22E-03	2.12E-02	3.17E-03	1.56E-03	5.04E-04	1.90E-04	4.22E-04	2.65E-04
South Texas 1								8.26E-04	4.02E-03	1.15E-03
South Texas 2									1.42E-03	5.75E-04
St. Lucie 1	7.69E-02	4.15E-01	2.13E-01	2.60E-01	7.91E-01	2.69E-01	3.95E-02	6.40E-03	5.75E-03	8.36E-03
St. Lucie 2			1.27E-02	2.84E-01	1.92E-01	4.20E-02	5.51E-02	2.86E-02	8.27E-03	5.79E-03
Summer 1		N/D	4.74E-05	9.00E-06	2.55E-05	2.99E-05	7.04E-04	2.33E-03	1.61E-03	5.57E-04
Surry 1&2	6.53E-02	5.96E-02	8.34E-02	5.87E-02	2.67E-02	2.09E-02	2.09E-02	2.02E-02	2.37E-03	2.93E-03
Three Mile Island 1	5.05E-04	1.65E-04	6.55E-05	1.27E-09	2.86E-05	3.97E-04	1.28E-04	1.26E-03	8.22E-03	1.53E-03
Three Mile Island 2	3.69E-05	6.46E-05	2.73E-05	1.61E-05	4.59E-05	1.67E-04	7.27E-05	6.78E-05	3.50E-06	3.74E-06
TMI 2/Epic	2.63E-06	3.71E-06	1.80E-06	7.93E-07	+	+	+	+	+	+
* Trojan	4.97E-02	1.09E-02	5.57E-03	4.65E-03	5.75E-03	8.62E-03	2.61E-03	3.97E-03	4.30E-03	1.64E-03

* Changes to the entries for Trojan for 1976-1987 are corrections which were reported and explained in the Trojan July-December 1990 Effluent and Waste Disposal Report

** Changes to the entries for Maine Yankee for 1977 - 1988 are corrections which are reported and explained in the Maine Yankee report "Revised Semiannual Effluent Release Reports for 770131 - 901231" Docket Date 92/01/08.

• Included with Three Mile Island 2 total

N/D = Not Detectable

Table 4

Airborne Effluents Comparison By Year

I-131 and Particulates (Curies)
(Half-Life Equal To or Greater Than 8 Days)

Pressurized Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Turkey Point 3&4	2.94E-02	2.20E-01	1.44E-01	2.77E-02						
Turkey Point 3					7.98E-03	1.93E-02	1.24E-02	4.83E-03	3.10E-03	4.60E-03
Turkey Point 4					7.88E-03	2.45E-03	1.38E-02	4.78E-03	2.99E-04	1.87E-03
Vogtle 1&2							1.99E-05	1.75E-05	1.25E-03	8.49E-05
Waterford 3					3.48E-03	5.30E-03	1.02E-03	1.24E-03	7.62E-04	5.99E-04
Wolf Creek 1					1.67E-06	2.11E-04	2.14E-04	8.36E-05	2.31E-05	1.71E-04
Yankee Rowe 1	2.13E-04	< 5.75E-04	3.11E-03	< 6.49E-03	< 7.61E-04	2.02E-04	4.10E-05	5.89E-05	< 1.82E-04	1.61E-04
Zion 1&2	1.25E-02	8.57E-02	2.28E-02	4.27E-02	2.55E-02	4.48E-02	4.07E-03	1.40E-02	2.39E-03	1.38E-03
Total	< 3.11E+00 < 2.08E+00 < 1.65E+00 < 1.76E+00 < 3.56E+00 < 1.42E+00 < 1.25E+00 < 7.59E-01 < 7.96E-01 2.25E-01									

Table 5

Liquid Effluents Comparison By Year

Tritium (Curies)

Boiling Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Big Rock Point 1	1.03E+01	1.04E+01	1.97E+01	5.10E+00	5.73E+00	2.41E+00	8.83E+00	4.05E+00	5.45E+00	6.18E+00
Browns Ferry 1,2,& 3				2.80E+00	1.04E+01 <	4.02E+00	2.40E+01	3.08E+01	1.32E+01	2.18E+01
Brunswick 1&2					3.20E+00	5.90E+00	8.93E+00	1.41E+01	3.09E+01	1.28E+01
Clinton 1										
Cooper				1.70E+00	8.25E+00	8.43E+00	9.04E+00	7.51E+00	6.63E+00	8.77E+00
Dresden 1	8.70E+00	4.33E+01	1.85E+01	1.88E+01	2.70E-01	2.00E-02	8.90E-02	1.31E+01	1.50E+00	N/D
Dresden 2-3	3.85E+01	2.59E+01	2.58E+01	2.26E+01	5.40E+01	1.97E+01	5.00E+00	1.92E+01	1.93E+01	6.20E+01
Duane Arnold					3.30E-01	3.40E-01	2.13E-01	1.19E+02	2.90E-01	N/D
Fermi 2										
James A. Fitzpatrick					5.03E+00	4.20E+00	3.35E+00	1.90E+00	1.52E+00	2.81E+00
Grand Gulf 1										
Edwin I. Hatch 1					6.12E+00	8.98E+00	1.20E+01	9.00E+00	1.23E+01	1.42E+01
Edwin I. Hatch 2										1.07E+01
Hope Creek 1										
Humboldt Bay 3	7.50E+00	1.30E+01	5.13E+01	3.17E+01	2.01E+01	1.30E+01	5.26E-01	3.63E-02	3.91E-02	9.70E-02
LaCrosse	9.14E+01	1.20E+02	1.03E+02	1.15E+02	1.27E+02	4.10E+01	4.86E+01	4.72E+01	3.54E+01	7.20E+01
LaSalle 1&2										
Limerick 1&2										
Millstone 1	1.27E+01	2.09E+01	3.70E+00	2.41E+01	8.03E+01	2.01E+01	4.41E+00	3.20E+00	7.92E+00	2.73E+01
Monticello	5.92E-01 <	1.00E-01	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
Nine Mile Point 1	1.24E+01	2.78E+01	4.65E+01	1.87E+01	2.81E+01	2.46E+00	2.49E+00	N/D	6.78E+00	N/D
Nine Mile Point 2										
Oyster Creek 1	2.15E+01	6.16E+01	3.59E+01	1.41E+01	1.79E+01	3.86E+01	1.88E+01	1.96E+01	1.40E+00	1.54E+02
Peach Bottom 2&3			< 1.00E-01	1.00E+01	3.08E+01	7.37E+01	7.09E+01	3.24E+01	4.28E+01	3.73E+01
Perry 1										
Pilgrim 1		4.20E+00	4.00E-01	1.05E+01	1.82E+01	4.67E+01	3.27E+01	2.98E+00	1.34E+01	4.00E+01
Quad-Cities 1&2		4.70E+00	2.45E+01	3.40E+01	5.37E+01	4.98E+01	2.64E+01	1.72E+01	1.76E+01	1.03E+01
River Bend 1										
Shoreham 1										
Susquehanna 1&2										
Vermont Yankee 1			1.00E-01	N/D	N/D	1.60E+00	8.44E-01	N/D	4.04E+00	N/D
WNP-2										
Total	2.04E+02 <	3.32E+02 <	3.30E+02	3.09E+02	4.69E+02 <	3.41E+02	2.77E+02	3.41E+02	2.20E+02	4.80E+02
* Fort St. Vrain									1.23E+02	2.06E+02

* High temperature gas cooled reactor
N/D = Not Detectable

Table 5

Liquid Effluents Comparison By Year

Tritium (Curies)

Boiling Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Big Rock Point 1	3.13E+00	2.98E+00	2.22E+01	1.11E+00	1.27E+00	3.51E-01	5.85E-01	3.47E-01	6.39E-01	5.89E-01
Browns Ferry 1,2,&3	2.42E+01	2.39E+01	3.20E+01	3.18E+01	3.31E+01	7.93E+00	2.03E+00	1.46E+00	7.01E-01	2.07E-01
Brunswick 1&2	2.26E+01	4.88E+01	1.04E+02	3.37E+01	9.88E+00	5.78E+00	1.93E+01	3.10E+01	1.79E+01	4.95E+01
Clinton 1							1.87E+00	2.90E+00	1.49E+00	2.60E+00
Cooper	< 8.37E+00	< 9.08E+00	< 7.60E+00	< 7.20E+00	< 5.05E+00	< 5.56E+00	5.02E+00	4.17E+00	5.45E+00	5.07E+00
Dresden 1	N/D	N/D	N/D	N/D	N/D	N/D	N/D	**	**	**
Dresden 2-3	6.05E+00	1.36E+00	1.45E-03	3.93E+01	7.45E+00	1.27E+01	2.23E+01	1.72E+01	1.83E+01	2.04E+01
Duane Arnold	N/D	2.25E-05	N/D	1.41E-06	3.57E-02	N/D	N/D	N/D	N/D	N/D
Fermi 2						3.00E-01	1.05E+00	9.33E-01	1.30E+00	7.47E-01
James A. Fitzpatrick	4.11E+00	6.55E-01	2.72E+00	4.77E+00	4.20E+00	4.99E+00	2.48E+00	8.87E+00	7.32E-01	3.08E+00
Grand Gulf 1			3.89E-03	7.27E-01	5.17E+00	1.47E+01	1.83E+01	1.34E+01	1.32E+01	1.89E+01
Edwin I. Hatch 1	1.16E+01	1.03E+02	9.47E+01	8.02E+01	3.93E+01	1.85E+01	2.01E+01	+	+	+
Edwin I. Hatch 2	9.28E+00	3.68E+01	3.40E+01	2.13E+01	1.81E+01	1.01E+01	8.10E+00	4.40E+01	4.57E+01	2.26E+01
Hope Creek 1						6.91E-03	9.53E+00	9.36E+00	2.35E+01	1.18E+01
Humboldt Bay 3	< 1.62E-01	5.99E-02	5.38E-02	2.93E-02	1.08E+00	6.67E-02	6.98E-04	9.44E-04	1.14E-03	3.48E-03
LaCrosse	7.74E+01	5.92E+01	1.24E+02	1.25E+02	1.28E+02	5.75E+01	4.66E+01	4.60E+00	2.79E+00	7.74E-01
LaSalle 1&2		9.26E-01	4.25E+00	1.10E+00	3.89E-01	1.37E-01	1.10E+00	1.76E+00	1.07E+00	3.74E-01
Limerick 1&2				N/D	1.15E+00	2.06E+00	6.02E+00	N/D	2.70E+01	3.02E+01
Millstone 1	2.62E+00	6.21E+00	8.38E+00	8.58E+00	1.79E+01	5.33E+00	1.78E+01	3.78E+01	4.58E+01	2.02E+01
Monticello	4.17E-03	2.70E-05	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
Nine Mile Point 1	5.05E+00	5.82E+00	7.89E+00	N/D	N/D	2.19E+00	N/D	N/D	N/D	1.41E+00
Nine Mile Point 2							4.63E-01	7.92E+00	8.10E+00	4.78E+00
Oyster Creek 1	2.67E+01	4.95E+00	8.76E+00	1.03E+01	N/D	1.07E+00	1.96E+00	1.62E+01	3.96E+00	N/D
Peach Bottom 2&3	3.68E+01	2.37E+01	2.02E+01	3.58E+01	5.04E+01	4.46E+01	4.64E+01	9.69E+00	2.00E+01	2.35E+01
Perry 1						2.67E-03	3.49E+00	7.34E+00	6.96E+00	8.79E+00
Pilgrim 1	3.41E+01	5.91E+00	1.56E+01	1.47E+01	7.81E+00	1.00E+01	3.21E+00	5.73E-01	2.37E+00	3.68E+00
Quad-Cities 1&2	1.19E+01	7.80E+00	3.88E+00	5.42E+00	3.41E+00	6.43E+00	6.92E+00	7.28E+00	2.91E+01	2.61E+01
River Bend 1						4.56E+00	6.92E+00	9.65E+00	1.60E+01	8.35E+01
Shoreham 1						3.80E-03	6.04E-03	N/D	N/D	N/D
Susquehanna 1&2		< 8.55E-01	8.98E+00	1.12E+01	9.14E+00	1.54E+01	1.87E+01	1.45E+01	2.74E+01	5.80E+01
Vermont Yankee 1	3.70E-01	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
WNP-2				5.40E-01	1.50E+00	3.29E+00	1.21E+00	1.38E+00	2.03E+00	7.54E-01
Total	< 2.84E+02	< 3.42E+02	< 4.99E+02	< 4.33E+02	< 3.44E+02	< 2.34E+02	2.71E+02	2.52E+02	3.21E+02	3.98E+02
* Fort St. Vrain	2.19E+02	2.62E+02	3.69E+02	1.24E+02	1.53E+01	1.27E+02	5.61E+01	1.61E+02	1.12E+02	3.22E+00

* High temperature gas cooled reactor

** Included with Dresden 2-3 total

+ Included with Edwin I. Hatch 2 total

N/D = Not Detectable

Table 6
Liquid Effluents Comparison By Year

Tritium (Curies)										
Pressurized Water Reactors										
Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Arkansas One 1				2.56E+01	4.60E+02	2.12E+02	2.45E+02	2.94E+02	1.68E+02	2.12E+02
Arkansas One 2									5.27E+01	2.89E+02
Beaver Valley 1&2						8.60E+00	1.08E+02	3.49E+02	9.59E+01	3.98E+01
Braidwood 1										
Braidwood 2										
Byron 1&2										
Callaway 1										
Calvert Cliffs 1&2					2.63E+02	2.74E+02	5.75E+02	4.56E+02	5.14E+02	4.91E+02
Catawba 1										
Catawba 2										
Comanche Peak 1										
Donald C. Cook 1&2					5.64E+01	1.92E+02	2.86E+02	6.24E+02	1.22E+03	7.82E+02
Crystal River 3							1.66E+02	1.54E+02	1.66E+02	1.95E+02
Davis-Besse 1							9.01E+00	2.15E+02	2.45E+02	1.08E+02
Diablo Canyon 1&2										
Joseph M. Farley 1								5.91E+01	9.40E+01	5.70E+02
Joseph M. Farley 2										
Fort Calhoun 1			1.58E+01	1.24E+02	1.11E+02	1.22E+02	1.57E+02	1.50E+02	2.58E+02	5.44E+01
R. E. Ginna	1.54E+02	1.19E+02	2.86E+02	1.95E+02	2.60E+02	2.42E+02	1.19E+02	2.42E+02	2.40E+02	1.60E+02
Haddam Neck	5.83E+03	5.89E+03	3.90E+03	2.24E+03	5.67E+03	4.85E+03	6.67E+03	3.94E+03	3.55E+03	3.29E+03
Harris 1										
Indian Point 1&2			2.75E+01	4.79E+01	7.94E+01	3.32E+02	3.71E+02	5.12E+02	3.75E+02	2.76E+02
Indian Point 3						Shown With Other Unit		2.56E+02	1.15E+02	4.27E+02
Kewaunee				9.24E+01	2.77E+02	1.80E+02	2.95E+02	2.96E+02	2.49E+02	2.33E+02
Maine Yankee		9.20E+00	1.54E+02	2.19E+02	1.77E+02	3.67E+02	1.53E+02	3.15E+02	2.02E+02	2.18E+02
McGuire 1										
McGuire 2										
Millstone 2					7.60E+00	2.77E+02	2.11E+02	2.01E+02	2.54E+02	2.68E+02
Millstone 3										
North Anna 1&2								2.82E+02	3.13E+02	4.03E+02
Oconee 1,2,& 3			7.07E+01	3.50E+02	3.55E+03	2.19E+03	1.92E+03	1.17E+03	8.94E+02	7.12E+02
Palisades		2.08E+02	1.85E+02	8.10E+00	4.16E+01	9.63E+00	5.58E+01	1.01E+02	1.26E+02	7.47E+01
Palo Verde 1										
Palo Verde 2										
Palo Verde 3										
Point Beach 1&2	2.66E+02	5.63E+02	5.56E+02	8.33E+02	8.85E+02	6.94E+02	9.99E+02	1.29E+03	8.92E+02	7.61E+02
Prairie Island 1&2			< 1.00E-01	1.42E+02	4.54E-01	1.00E-01	1.35E+03	5.51E+02	6.25E+02	5.43E+02
Rancho Seco 1					1.32E+02	N/D	8.55E-02	N/D	N/D	1.47E-02
H. B. Robinson 2	1.18E+02	4.05E+02	4.32E+02	4.49E+02	6.24E+02	9.80E+02	6.85E+02	4.73E+02	4.29E+02	1.89E+02
Salem 1						4.00E-02	2.96E+02	4.46E+02	7.26E+02	N/D
Salem 2										N/R
San Onofre 1	4.57E+03	3.48E+03	4.07E+03	3.81E+03	4.00E+03	3.39E+03	1.79E+03	2.50E+03	2.32E+03	1.03E+03
San Onofre 2-3										
Seabrook 1										
Sequoyah 1&2										3.23E-01
South Texas 1										
South Texas 2										
St. Lucie 1						1.33E+01	2.42E+02	1.28E+02	1.28E+02	2.72E+02
St. Lucie 2										
Summer 1										
Surry 1&2		5.00E+00	4.88E+02	2.45E+02	4.42E+02	7.82E+02	4.08E+02	7.47E+02	3.57E+02	3.85E+02
Three Mile Island 1				1.30E+02	4.63E+02	1.89E+02	1.92E+02	1.55E+02	5.59E+01	3.26E+01
Three Mile Island 2								3.83E+01	7.81E+01	6.10E-04
TMI 2/Epicor										N/D
Trojan						3.60E+01	3.11E+02	1.59E+02	6.80E+01	1.24E+02

N/R = Not Reported
N/D = Not Detectable

Table 6

Liquid Effluents Comparison By Year

Tritium (Curies)										
Pressurized Water Reactors										
<u>Facility</u>	<u>1971</u>	<u>1972</u>	<u>1973</u>	<u>1974</u>	<u>1975</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>1979</u>	<u>1980</u>
Turkey Point 3&4			3.29E+02	5.80E+02	7.97E+02	7.71E+02	9.24E+02	1.17E+03	9.40E+02	7.49E+02
Turkey Point 3										
Turkey Point 4										
Vogtle 1&2										
Waterford 3										
Wolf Creek 1										
Yankee Rowe 1	1.68E+03	8.03E+02	6.94E+02	3.14E+02	2.47E+02	1.56E+02	1.39E+02	1.96E+02	1.75E+02	5.84E+01
Zion 1			1.00E+01	2.74E+02	1.03E+03	7.47E+02	7.24E+02	7.25E+02	6.01E+02	7.45E+02
Zion 2										
Total	1.26E+04	1.15E+04	1.12E+04	1.01E+04	1.96E+04	1.70E+04	1.94E+04	1.82E+04	1.65E+04	1.37E+04

Table 6

Liquid Effluents Comparison By Year

Tritium (Curies)										
Pressurized Water Reactors										
Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Arkansas One 1	4.42E+02	2.06E+02	1.09E+02	3.05E+02	3.27E+02	2.12E+02	1.50E+02	2.50E+02	3.81E+02	2.67E+02
Arkansas One 2	2.44E+02	1.39E+02	2.38E+02	3.09E+02	2.41E+02	2.30E+02	3.52E+02	2.44E+02	4.40E+02	5.33E+02
Beaver Valley 1&2	1.40E+02	1.84E+02	4.60E+02	4.12E+02	1.50E+02	2.06E+02	5.72E+02	4.09E+02	6.21E+02	4.91E+02
Braidwood 1							4.12E+01	2.74E+02	5.58E+02	6.50E+02
Braidwood 2								2.44E+02	5.58E+02	6.50E+02
Byron 1&2					2.61E+02	6.70E+01	4.10E+02	1.01E+03	1.29E+03	9.98E+02
Callaway 1				2.90E+01	5.88E+02	4.35E+02	4.48E+02	8.93E+02	6.09E+02	1.02E+03
Calvert Cliffs 1&2	1.00E+03	4.35E+02	7.56E+02	7.87E+02	4.83E+02	7.35E+02	7.38E+02	6.24E+02	2.36E+02	7.29E+01
Catawba 1					1.75E+02		1.18E+02	3.64E+02	3.53E+02	2.97E+02
Catawba 2						1.18E+02	3.64E+02	3.53E+02	4.45E+02	2.97E+02
Comanche Peak 1										1.87E+02
Donald C. Cook 1&2	9.15E+02	1.23E+03	8.85E+02	1.37E+03	1.14E+03	6.95E+02	1.97E+03	1.10E+03	8.74E+02	1.56E+03
Crystal River 3	2.71E+02	1.82E+02	1.99E+02	4.20E+02	1.76E+02	1.73E+02	3.56E+02	5.11E+02	3.44E+02	5.10E+02
Davis-Besse 1	1.57E+02	5.68E+01	1.14E+02	1.22E+02	6.74E+01	2.09E+01	2.46E+02	3.50E+01	2.39E+02	1.27E+02
Diablo Canyon 1&2				1.07E+00	4.28E+02	6.98E+02	6.91E+02	4.29E+02	9.35E+02	9.68E+02
Joseph M. Farley 1	1.65E+02	3.37E+02	4.12E+02	4.23E+02	6.03E+02	7.14E+02	6.37E+02	5.16E+02	6.99E+02	7.35E+02
Joseph M. Farley 2	6.34E+02	3.59E+02	3.17E+02	3.56E+02	5.02E+02	6.22E+02	5.05E+02	7.53E+02	6.08E+02	6.72E+02
Fort Calhoun 1	2.42E+02	3.08E+02	1.53E+02	2.35E+02	1.67E+02	1.84E+02	2.28E+02	2.32E+02	2.28E+02	1.74E+02
R. E. Ginna	2.40E+02	3.08E+02	3.50E+02	4.59E+02	5.01E+02	3.57E+02	5.64E+02	3.47E+02	5.92E+02	3.21E+02
Haddam Neck	5.29E+03	4.05E+03	3.90E+03	3.66E+03	5.76E+03	2.58E+03	3.17E+03	1.18E+03	4.81E+03	9.89E+02
Harris 1							2.48E+02	4.01E+02	4.58E+02	7.26E+02
Indian Point 1&2	2.41E+02	1.72E+02	3.43E+02	2.22E+02	3.51E+02	3.36E+02	5.63E+02	4.39E+02	5.60E+02	6.44E+02
Indian Point 3	6.42E+02	1.94E+02	3.19E+01	5.87E+02	3.40E+02	5.67E+02	3.40E+02	5.73E+02	3.51E+02	3.33E+02
Kewaunee	2.51E+02	3.18E+02	2.92E+02	4.40E+02	3.79E+02	2.94E+02	3.51E+02	3.32E+02	3.41E+02	3.79E+02
Maine Yankee	2.16E+02	1.85E+02	2.87E+02	1.72E+02	1.84E+02	3.50E+02	1.18E+02	2.91E+02	4.22E+02	2.43E+02
McGuire 1	6.25E+00	1.60E+02	1.49E+02	3.23E+02	4.02E+02	4.58E+02	4.92E+02	5.29E+02	4.23E+02	4.58E+02
McGuire 2			1.49E+02	3.23E+02	4.02E+02	4.58E+02	4.92E+02	5.29E+02	4.23E+02	4.58E+02
Millstone 2	3.71E+02	2.91E+02	1.21E+02	3.97E+02	1.66E+02	2.80E+02	2.86E+02	2.59E+02	3.66E+02	5.28E+02
Millstone 3						5.41E+02	5.90E+02	5.47E+02	6.97E+02	7.74E+02
North Anna 1&2	1.28E+03	5.71E+02	1.61E+03	6.20E+02	1.48E+03	1.56E+03	8.36E+02	1.94E+03	1.40E+03	1.67E+03
Oconee 1,2,& 3	5.07E+02	3.54E+02	1.28E+03	1.28E+03	1.24E+03	1.34E+03	9.49E+02	7.10E+02	1.02E+03	9.92E+02
Palisades	2.78E+02	1.79E+02	2.35E+02	6.95E+01	4.29E+02	6.32E+01	1.19E+02	2.83E+02	8.06E+01	1.49E+02
Palo Verde 1					N/D	N/D	N/D	N/D	N/D	N/D
Palo Verde 2						N/D	N/D	N/D	N/D	N/D
Palo Verde 3							N/D	N/D	N/D	N/D
Point Beach 1&2	6.52E+02	5.03E+02	5.39E+02	2.10E+03	8.05E+02	8.11E+02	7.09E+02	3.57E+02	5.59E+02	8.72E+02
Prairie Island 1&2	5.62E+02	6.00E+02	5.20E+02	6.41E+02	6.96E+02	6.70E+02	4.49E+02	4.05E+02	4.64E+02	3.98E+02
Rancho Seco 1	8.35E+01	6.46E+01	7.43E+01	2.97E+02	9.00E+01	6.50E+01	1.83E+01	1.01E+02	7.29E+01	1.37E+01
H. B. Robinson 2	1.86E+02	9.51E+01	2.40E+02	1.34E+01	3.09E+02	3.42E+02	2.74E+02	5.36E+02	1.64E+02	3.53E+02
Salem 1	4.93E+02	7.22E+02	2.08E+02	3.30E+02	9.23E+02	4.10E+02	3.79E+02	6.35E+02	6.09E+02	3.53E+02
Salem 2	8.42E+02	5.25E+02	2.23E+02	3.08E+02	5.77E+02	4.38E+02	6.61E+02	3.68E+02	5.11E+02	3.03E+02
San Onofre 1	2.97E+02	5.45E+02	1.57E+01	3.39E+01	2.38E+03	4.53E+02	2.27E+03	1.53E+03	9.62E+02	1.42E+03
San Onofre 2-3		8.92E+00	2.38E+02	4.55E+02	4.75E+02	7.41E+02	8.20E+02	6.43E+02	1.30E+03	9.27E+02
Seabrook 1									1.33E+03	1.13E+02
Sequoyah 1&2	7.65E+01	9.34E+02	7.35E+02	1.82E+03	6.33E+02	2.46E+02	1.19E+02	2.01E+02	1.15E+03	8.53E+02
South Texas 1								1.99E+02	3.17E+02	3.45E+02
South Texas 2									2.72E+02	4.70E+02
St. Lucie 1	3.25E+02	3.21E+02	3.46E+02	2.21E+02	2.86E+02	2.78E+02	3.38E+02	2.75E+02	4.05E+02	2.84E+02
St. Lucie 2			3.77E+01	2.21E+02	3.64E+02	2.78E+02	3.38E+02	2.75E+02	4.05E+02	2.84E+02
Summer 1		3.19E-01	2.27E+02	2.25E+02	3.11E+02	3.75E+02	7.36E+02	7.55E+02	6.85E+02	4.22E+02
Surry 1&2	5.31E+02	9.10E+02	7.17E+02	8.12E+02	7.50E+02	8.73E+02	8.15E+02	4.94E+02	4.29E+02	1.11E+03
Three Mile Island 1	7.11E+00	3.91E+00	3.09E+00	1.72E+00	9.06E+00	1.69E+02	1.97E+02	3.02E+02	3.73E+02	2.10E+02
Three Mile Island 2	5.06E-02	7.20E-02	3.75E-04	1.56E-04	2.22E-03	1.60E-03	1.48E-03	5.49E-03	9.76E-04	8.80E-04
TMI 2/Epicor	N/D	N/D	N/D	N/D	**	**	**	**	**	**
Trojan	1.03E+02	2.00E+02	2.34E+02	1.87E+02	2.65E+02	2.43E+02	1.75E+02	3.75E+02	3.18E+02	2.19E+02

** Included with Three Mile Island 2 total

N/D = Not Detectable

Table 6

Liquid Effluents Comparison By Year

Tritium (Curies)

Pressurized Water Reactors

<u>Facility</u>	<u>1981</u>	<u>1982</u>	<u>1983</u>	<u>1984</u>	<u>1985</u>	<u>1986</u>	<u>1987</u>	<u>1988</u>	<u>1989</u>	<u>1990</u>
Turkey Point 3&4	1.95E+02	6.27E+02	7.12E+02	8.91E+02						
Turkey Point 3					4.33E+02	3.64E+02	2.69E+02	2.99E+02	2.29E+02	3.22E+02
Turkey Point 4					4.33E+02	3.64E+02	2.69E+02	2.99E+02	2.29E+02	3.22E+02
Vogtle 1&2							3.21E+02	3.90E+02	9.18E+02	1.17E+03
Waterford 3					2.54E+01	4.31E+02	5.25E+02	5.03E+02	3.58E+02	7.12E+02
Wolf Creek 1					1.83E+02	3.77E+02	3.17E+02	4.06E+02	5.88E+02	5.90E+02
Yankee Rowe 1	1.03E+02	1.86E+02	1.68E+02	1.64E+02	2.28E+02	1.76E+02	2.19E+02	1.96E+02	1.68E+02	1.92E+02
Zion 1	6.04E+02	6.76E+02	1.74E+02	1.74E+02	1.35E+02	2.67E+02	2.16E+02	4.11E+02	1.81E+02	2.90E+02
Zion 2	2.66E+02	3.77E+02	2.56E+02	5.11E+02	5.21E+02	4.46E+02	4.40E+02	5.58E+02	8.66E+02	3.91E+02
Total	1.89E+04	1.75E+04	1.81E+04	2.27E+04	2.78E+04	2.32E+04	2.81E+04	2.71E+04	3.40E+04	3.18E+04

Table 7

Liquid Effluents Comparison By Year

Mixed Fission and Activation Products (Curies)

Boiling Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Big Rock Point 1	3.50E+00	1.10E+00	2.70E+00	1.10E+00	2.02E+00	7.70E-01	3.92E-01	2.74E-01	9.03E-01	7.82E-01
Browns Ferry 1,2,& 3				8.00E-01	2.70E+00	3.95E+00	1.19E+00	1.32E+01	1.02E+01	9.38E+00
Brunswick 1&2					1.89E+00	3.29E+00	6.22E+00	3.48E+00	5.10E+00	1.28E+00
Clinton 1										
Cooper				1.40E+00	1.74E+00	7.00E-02	7.50E-01	3.05E+00	< 2.48E+00	< 1.10E+01
Dresden 1	6.20E+00	6.80E+00	9.20E+00	6.90E+00	8.40E-01	3.80E-01	6.00E-01	3.26E-01	2.65E-02	N/D
Dresden 2-3	2.30E+01	2.20E+01	2.59E+01	3.31E+01	8.10E-01	1.21E+00	4.40E-01	3.99E-01	2.65E-01	7.16E-01
Duane Arnold					< 1.00E-02	< 1.00E-02	2.32E-03	2.73E-01	5.10E-04	N/D
Fermi 2										
James A. Fitzpatrick					5.32E+00	6.01E+00	8.85E-01	1.58E+00	6.46E-01	1.51E+00
Grand Gulf 1										
Edwin I. Hatch 1					6.00E-02	4.00E-02	2.50E+01	4.03E-02	4.82E-02	6.83E-02
Edwin I. Hatch 2										4.57E-02
Hope Creek 1										
Humboldt Bay 3	1.80E+00	1.40E+00	2.40E+00	4.40E+00	3.79E+00	9.90E-01	9.17E-01	1.95E-01	9.55E-02	1.39E-01
LaCrosse	1.71E+01	4.85E+01	3.59E+01	1.31E+01	1.42E+01	< 5.78E+00	2.13E+01	8.86E+00	1.67E+00	2.13E+00
LaSalle 1&2										
Limerick 1&2										
Millstone 1	1.97E+01	5.15E+01	3.34E+01	1.98E+02	1.99E+02	9.65E+00	5.27E-01	1.75E-01	2.10E-01	7.24E-01
Monticello	< 1.00E-01	< 1.00E-01	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
Nine Mile Point 1	3.22E+01	3.46E+01	4.08E+01	2.56E+01	2.10E+01	2.14E+00	3.03E-01	N/D	1.89E+00	N/D
Nine Mile Point 2										
Oyster Creek 1	1.20E+01	1.00E+01	4.20E+00	7.00E-01	4.10E-01	2.20E-01	9.81E-02	1.53E-02	6.59E-03	5.06E-01
Peach Bottom 2&3			< 1.00E-01	9.00E-01	9.30E-01	3.38E+00	2.23E+00	5.11E+00	1.95E+01	1.90E+00
Perry 1										
Pilgrim 1		1.50E+00	9.00E-01	4.20E+00	8.01E+00	2.33E+00	3.41E+00	1.77E+00	5.12E-01	2.73E+00
Quad-Cities 1&2		2.40E+00	2.14E+01	3.88E+01	1.71E+01	6.99E+00	1.34E+00	2.24E+00	1.31E+00	1.31E+01
River Bend 1										
Shoreham 1										
Susquehanna 1&2										
Vermont Yankee 1			< 1.00E-01	N/D	< 1.00E-02	< 1.00E-02	1.55E-01	N/D	2.40E-04	N/D
WNP-2										
Total	< 1.16E+02	< 1.80E+02	< 1.77E+02	3.29E+02	< 2.80E+02	< 4.72E+01	6.58E+01	4.10E+01	< 4.49E+01	< 4.60E+01

* Fort St. Vrain

1.89E-04 6.37E-05

* High temperature gas cooled reactor

N/D = Not Detectable

Table 7

Liquid Effluents Comparison By Year

Mixed Fission and Activation Products (Curies)

Boiling Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Big Rock Point 1	3.91E-01	2.60E-01	7.82E-02	1.48E-01	1.53E-01	7.09E-02	2.73E-01	2.18E-01	2.32E-01	3.64E-02
Browns Ferry 1,2,& 3	2.24E+00	5.36E+01	1.28E+01	6.30E+00	1.34E+00	5.39E-01	3.25E-01	2.42E-01	1.71E-01	3.02E-01
Brunswick 1&2	2.20E+00	2.32E+00	1.08E+00	5.65E-01	1.15E-01	1.26E-01	7.15E-01	8.32E-01	1.56E+00	4.57E-01
Clinton 1							1.54E-02	1.10E-01	1.74E-02	2.53E-02
Cooper	< 3.61E+00	< 5.44E+00	< 1.23E+01	< 6.30E+00	< 1.30E+01	< 7.43E+00	2.25E+00	2.33E+00	2.19E+00	2.04E+00
Dresden 1	N/D	N/D	N/D	N/D	N/D	N/D	N/D	+	+	+
Dresden 2-3	6.12E-02	1.91E-02	1.24E-02	1.15E-01	2.03E+00	2.14E-01	3.78E-01	1.16E-01	6.53E-01	7.12E-01
Duane Arnold	N/D	4.16E-06	N/D	1.90E-09	8.24E-04	N/D	N/D	N/D	N/D	N/D
Fermi 2						3.67E-03	2.10E-02	7.41E-02	1.68E-01	2.18E-01
James A. Fitzpatrick	2.51E+00	6.50E-01	7.71E-01	9.79E-02	1.80E-01	1.92E-02	7.84E-02	4.86E-02	5.46E-02	2.74E-02
Grand Gulf 1			4.42E-03	3.16E-02	2.13E-01	3.01E-01	3.64E-01	3.96E-01	3.20E-01	6.45E-01
Edwin I. Hatch 1	3.73E-01	7.00E-01	9.09E-01	1.05E+00	4.80E-01	4.88E-01	6.85E-01	**	**	**
Edwin I. Hatch 2	1.63E-01	1.83E-01	3.29E-01	2.67E-01	2.63E-01	3.02E-01	1.30E-01	9.83E-01	2.48E-01	3.01E-01
Hope Creek 1						7.56E-01	1.62E+00	7.24E-01	1.05E+00	1.49E+00
Humboldt Bay 3	1.55E-01	3.46E-01	9.89E-02	1.64E-01	1.25E-01	4.69E-02	1.19E-02	7.60E-03	8.42E-03	5.77E-03
LaCrosse	2.26E-01	5.83E+00	3.75E+00	3.26E+00	1.83E+00	5.00E+00	1.16E+00	4.47E-01	1.69E-01	6.86E-02
LaSalle 1&2		9.82E-01	8.60E+00	8.48E-02	3.84E+00	1.78E-02	8.89E-01	1.10E+01	4.01E-01	2.46E-02
Limerick 1&2				6.45E-04	2.18E-02	5.74E-03	7.45E-02	N/D	1.12E-01	3.43E-01
Millstone 1	3.94E-01	1.15E+00	8.08E-01	3.78E-02	4.66E-01	7.73E-01	1.14E+00	1.08E+00	9.06E-01	1.39E-01
Monticello	3.11E-06	5.80E-07	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
Nine Mile Point 1	5.35E+00	2.51E-03	1.11E-02	N/D	N/D	< 6.70E-04	N/D	N/D	N/D	1.95E-03
Nine Mile Point 2							1.30E+00	3.08E+00	2.20E-01	6.34E-02
Oyster Creek 1	2.48E-01	8.10E-02	3.63E-03	6.84E-03	N/D	N/D	6.63E-03	2.68E-02	5.01E-02	6.70E-05
Peach Bottom 2&3	1.97E+00	9.33E+00	2.24E+00	6.15E+00	2.16E+00	4.59E-01	3.31E-01	2.02E-01	1.13E-01	1.36E-02
Perry 1						3.67E-03	1.47E-02	2.50E-01	1.16E+00	6.10E-01
Pilgrim 1	1.94E+00	8.72E-01	9.35E-01	4.75E+00	1.06E+00	< 2.11E-01	< 1.47E+00	3.56E-02	2.49E-02	1.56E-02
Quad-Cities 1&2	3.27E+00	4.03E-01	1.37E-01	7.23E-02	1.46E+00	2.36E-01	7.10E-02	5.60E-02	4.84E-01	1.13E-01
River Bend 1						1.06E-01	7.96E-02	5.58E-01	1.11E+00	7.37E-01
Shoreham 1						7.17E-03	3.41E-03	1.98E-05	1.78E-05	N/D
Susquehanna 1&2		< 1.99E-01	2.49E+00	1.45E-01	6.35E-01	7.92E-01	3.12E-01	9.48E-02	1.02E-01	1.34E-01
Vermont Yankee 1	1.02E-02	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D	N/D
WNP-2				2.74E-02	1.09E-02	2.32E-02	1.21E-02	6.10E-03	5.04E-02	1.53E-02
Total	< 2.51E+01	< 8.24E+01	< 4.74E+01	< 2.96E+01	< 2.94E+01	< 1.79E+01	< 1.37E+01	2.29E+01	1.16E+01	8.54E+00
* Fort St. Vrain	3.64E-04	4.34E-04	1.73E-02	1.27E-03	1.84E-03	2.30E-05	1.18E-06	1.69E-04	1.22E-05	8.22E-05

* High temperature gas cooled reactor

** Included with Edwin I. Hatch 2 total

+ Included with Dresden 2-3 total

N/D = Not Detectable

Table 8

Liquid Effluents Comparison By Year

Mixed Fission and Activation Products (Curies)

Pressurized Water Reactors

Facility	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
Arkansas One 1				6.50E+00	3.11E+00	1.31E+01	4.50E+00	6.05E+00	3.09E+00	3.42E+00
Arkansas One 2									1.30E+00	4.13E+00
Beaver Valley 1&2						1.70E-01	6.52E-01	2.63E-01	1.21E-01	1.04E-01
Braidwood 1										
Braidwood 2										
Byron 1&2										
Callaway 1										
Calvert Cliffs 1&2					1.44E+00	1.18E+00	3.48E+00	6.13E+00	7.80E+00	4.53E+00
Catawba 1										
Catawba 2										
Comanche Peak 1										
Donald C. Cook 1&2					2.60E-01	1.87E+00	1.52E+00	1.48E+00	2.58E+00	1.37E+00
Crystal River 3							1.54E-02	2.96E-02	4.16E-01	1.46E-01
Davis-Besse 1							2.60E-02	9.01E-02	4.28E-02	2.07E-01
Diablo Canyon 1&2										
Joseph M. Farley 1								1.03E-01	5.86E-02	6.18E-02
Joseph M. Farley 2										
Fort Calhoun 1			< 1.00E-01	2.30E+00	3.60E-01	5.50E-01	3.63E-01	5.95E-01	2.45E-01	5.33E-01
R. E. Ginna	9.00E-01	3.00E-01	1.00E-01	1.00E-01	4.20E-01	6.90E-01	6.47E-02	6.07E-02	8.63E-02	1.96E-02
Haddam Neck	5.90E+00	4.80E+00	3.00E+00	2.20E+00	1.20E+00	1.30E-01	1.71E+00	9.50E-01	8.67E-01	2.78E-01
Harris 1										
Indian Point 1&2			2.20E+00	4.20E+00	4.93E+00	< 4.98E+00	3.02E+00	1.99E+00	1.94E+00	1.28E+00
Indian Point 3						Shown With Other Unit	1.03E+00	4.02E-01	2.90E+00	
Kewaunee				4.00E-01	7.20E-01	2.83E+00	1.26E+00	6.99E-01	8.94E-01	6.17E-01
Maine Yankee		< 1.00E-01	< 1.00E-01	4.00E+00	3.21E+00	< 2.84E+00	4.42E-01	1.04E-01	4.63E-01	2.97E-01
McGuire 1										
McGuire 2										
Millstone 2					2.00E-02	2.60E-01	1.56E+00	2.79E+00	4.87E+00	2.81E+00
Millstone 3										
North Anna 1&2								2.68E-01	5.89E-01	1.05E+00
Oconee 1,2,& 3			2.80E+00	1.90E+00	5.05E+00	7.93E+00	3.62E+01	6.51E+00	9.24E-01	1.54E+00
Palisades		6.80E+00	2.78E+01	5.90E+00	3.45E+00	4.40E-01	9.29E-02	9.65E-02	1.28E-01	8.73E-03
Palo Verde 1										
Palo Verde 2										
Palo Verde 3										
Point Beach 1&2	1.00E-01	1.50E+00	8.00E-01	2.00E-01	2.34E+00	3.24E+00	1.50E+00	6.86E-01	7.25E-01	6.29E-01
Prairie Island 1&2			< 1.00E-01	< 1.00E-01	4.50E-01	1.00E-01	1.33E-02	4.94E-03	9.00E-03	1.32E-02
Rancho Seco 1					< 1.00E-02	N/D	N/D	N/D	N/D	3.78E-03
H. B. Robinson 2	7.00E-01	8.00E-01	6.00E-01	2.50E+00	4.50E-01	3.80E-01	3.29E-01	1.78E-01	2.99E-01	3.58E-01
Salem 1						< 1.00E-02	2.88E+00	4.02E+00	3.98E+00	2.65E+00
Salem 2										3.89E-01
San Onofre 1	1.50E+00	3.03E+01	1.60E+01	5.00E+00	1.22E+00	7.43E+00	9.84E+00	1.18E+01	1.10E+01	1.12E+01
San Onofre 2-3										
Seabrook 1										
Sequoyah 1&2										N/R
South Texas 1										
South Texas 2										
St. Lucie 1						8.00E-02	5.80E+00	2.80E+00	2.67E+00	2.36E+00
St. Lucie 2										
Summer 1										
Surry 1&2		2.00E-01	1.00E-01	3.80E+00	9.27E+00	3.37E+01	6.55E+01	2.41E+00	2.53E+00	3.85E+00
Three Mile Island 1				1.30E+00	7.00E-02	1.00E-01	1.94E-01	6.14E-01	4.91E-01	1.83E-01
Three Mile Island 2								3.92E-01	3.31E-01	1.45E-05
TMI 2/Epicor										N/D
Trojan						2.77E+00	4.19E+00	7.07E-01	5.55E-01	7.87E-01

N/R = Not Reported
N/D = Not Detectable

Table 8

Liquid Effluents Comparison By Year

Mixed Fission and Activation Products (Curies)

Pressurized Water Reactors

<u>Facility</u>	<u>1971</u>	<u>1972</u>	<u>1973</u>	<u>1974</u>	<u>1975</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>1979</u>	<u>1980</u>
Turkey Point 3&4			< 1.00E-01	1.60E+00	3.07E+00	< 8.65E+00	8.90E+00	3.32E+00	4.10E-01	6.78E-01
Turkey Point 3										
Turkey Point 4										
Yankee Rowe 1	< 1.00E-01	< 1.00E-01	< 1.00E-01	< 1.00E-01	2.00E-02	< 1.00E-02	1.80E-02	8.14E-02	1.17E-02	1.75E-02
Zion 1			< 1.00E-01	< 1.00E-01	< 1.00E-02	1.60E-01	9.50E-01	9.51E-01	7.00E-01	4.74E-01
Zion 2										
Total	< 9.20E+00	< 4.49E+01	< 5.40E+01	< 4.22E+01	< 4.11E+01	< 9.36E+01	1.55E+02	5.72E+01	5.05E+01	4.89E+01

Table 8

Liquid Effluents Comparison By Year

Mixed Fission and Activation Products (Curies)

Pressurized Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Arkansas One 1	7.50E+00	5.80E+00	4.30E+00	4.10E+00	3.53E+00	5.09E+00	2.45E+00	3.73E+00	2.04E+00	2.36E+00
Arkansas One 2	2.95E+00	5.90E+00	3.70E+00	2.48E+00	4.36E+00	3.43E+00	1.85E+00	4.46E+00	2.65E+00	2.52E-01
Beaver Valley 1&2	1.44E-01	1.47E-01	6.09E-02	2.03E-01	1.13E-01	1.19E-01	6.69E-01	1.02E-01	5.45E-01	2.55E+00
Bradwood 1							5.00E-02	8.57E+00	2.50E+00	2.13E+00
Bradwood 2								3.04E+00	2.52E+00	2.13E+00
Byron 1&2					1.63E+01	4.05E+00	2.48E+00	1.40E+00	6.35E-01	1.18E+00
Callaway 1				1.07E-03	4.97E-03	3.83E-02	4.92E-01	7.74E-02	1.01E-02	3.86E-02
Calvert Cliffs 1&2	2.68E+00	5.26E+00	2.24E+00	1.64E+00	2.38E+00	1.79E+00	5.19E+00	2.64E+00	2.07E+00	1.42E+00
Catawba 1					1.26E+00	3.82E-01	6.53E-01	5.42E-01	3.42E-01	9.78E-01
Catawba 2						3.82E-01	6.53E-01	5.42E-01	3.42E-01	9.78E-01
Comanche Peak 1										1.19E-02
Donald C. Cook 1&2	1.86E+00	1.90E+00	6.83E-01	1.19E+00	2.26E+00	3.34E-01	2.00E+00	4.44E-01	8.06E-01	1.61E+00
Crystal River 3	1.29E-01	1.07E-01	1.50E-01	2.34E-01	1.51E+00	8.12E-01	9.55E-01	2.31E-01	2.36E-01	6.19E-01
Davis-Besse 1	7.92E-01	2.19E-01	5.39E-01	1.89E-01	1.85E-01	6.15E-02	6.51E-02	1.68E-01	1.84E-01	1.41E-01
Diablo Canyon 1&2				1.16E-02	3.20E+00	1.11E+01	2.86E+00	2.00E+00	1.61E+00	2.80E+00
Joseph M. Farley 1	1.31E-01	5.94E-02	5.75E-02	6.34E-02	6.72E-02	1.02E-01	5.09E-02	7.97E-02	7.31E-02	7.47E-02
Joseph M. Farley 2	2.69E-02	2.90E-02	2.04E-02	8.63E-02	3.77E-02	8.28E-02	4.63E-02	8.53E-02	7.34E-02	8.29E-02
Fort Calhoun 1	1.75E-01	2.03E-01	1.44E-01	2.91E+00	2.88E-01	8.37E-02	2.03E-01	3.08E-01	5.62E-01	8.05E+01
R. E. Ginna	3.85E-02	6.17E-01	1.93E-01	1.69E-01	5.22E-01	6.47E-02	5.88E-02	3.43E-02	8.12E-02	1.50E-01
Haddam Neck	7.12E-01	6.93E-02	4.80E-01	2.63E-01	8.44E-02	3.10E-01	4.26E-01	6.87E-01	3.90E-01	2.69E+00
Harris 1							9.08E-01	8.04E-02	2.42E-01	7.31E-01
Indian Point 1&2	5.67E+00	2.41E+00	4.02E+00	2.67E+00	1.85E+00	3.61E+00	6.02E+00	2.84E+00	6.38E-01	1.06E+00
Indian Point 3	2.62E+00	5.46E-01	5.44E-01	1.26E+00	4.18E-01	1.95E-01	3.47E-01	3.22E-01	5.92E-01	3.09E-01
Kewaunee	8.15E-01	1.52E+00	5.43E-01	1.01E+00	1.35E+00	5.33E-01	1.29E+00	5.01E-01	1.22E+00	2.06E-01
Maine Yankee	4.36E-01	7.03E-01	1.99E-01	8.62E-02	3.11E-02	2.99E-01	8.81E-01	3.49E-01	1.83E-01	1.87E-01
McGuire 1	3.94E-01	1.75E+00	1.87E+00	1.51E+00	6.21E-01	7.73E-01	1.57E+00	2.57E+00	1.54E+00	2.00E+00
McGuire 2			1.87E+00	1.51E+00	6.21E-01	7.73E-01	1.57E+00	2.57E+00	1.54E+00	2.00E+00
Millstone 2	4.18E+00	1.39E+01	7.81E+00	3.55E+00	4.60E+00	4.49E+00	4.07E+00	8.89E+00	1.06E+01	8.76E+00
Millstone 3						3.01E+00	5.40E+00	3.15E+00	5.94E+00	2.47E+00
North Anna 1&2	6.76E-01	1.32E+00	5.88E+00	4.51E+00	5.07E+00	9.41E-01	1.33E+00	4.32E-01	1.16E+00	6.75E-01
Oconee 1,2,& 3	1.75E+00	1.04E+00	1.43E+00	1.58E+00	4.16E+00	3.02E+00	2.90E+00	3.10E+00	3.82E+00	3.11E+00
Palisades	3.31E-02	1.27E-01	7.48E-02	3.68E-02	5.83E-02	1.40E-01	9.23E-02	3.43E-02	3.75E-03	7.75E-03
Palo Verde 1					N/D	N/D	N/D	N/D	N/D	N/D
Palo Verde 2						N/D	N/D	N/D	N/D	N/D
Palo Verde 3							N/D	N/D	N/D	N/D
Point Beach 1&2	1.01E+00	2.95E+00	1.27E+00	1.22E+01	1.90E+00	1.60E+01	7.55E-01	9.58E-02	5.58E-02	1.16E-02
Prairie Island 1&2	9.12E-03	2.23E-03	3.16E-02	1.91E-02	2.75E-02	6.01E-01	6.04E-02	2.55E-01	1.73E-01	1.30E-01
Rancho Seco 1	5.92E-01	2.16E-01	2.81E-01	6.33E-01	7.39E-03	1.45E-03	5.78E-04	5.79E-03	2.15E-03	2.08E-04
H. B. Robinson 2	1.84E+00	1.20E+00	8.23E-01	3.90E-01	9.41E-02	2.61E-01	7.36E-01	9.64E-01	2.82E-01	3.60E-01
Salem 1	2.80E+00	3.22E+00	2.97E+00	3.31E+00	2.88E+00	4.35E+00	3.33E+00	3.21E+00	3.11E+00	3.00E+00
Salem 2	1.51E+00	3.21E+00	2.85E+00	2.75E+00	2.80E+00	6.11E+00	4.07E+00	3.23E+00	3.56E+00	3.14E+00
San Onofre 1	3.64E+00	2.15E+00	1.22E+00	2.74E+00	7.79E+00	8.51E-01	8.42E-01	7.11E-01	6.87E-01	4.03E-01
San Onofre 2-3		6.32E-01	2.79E+00	1.30E+01	1.12E+01	8.20E-01	5.37E-01	1.16E+00	9.19E-01	2.02E-01
Seabrook 1									1.09E-04	2.21E-03
Sequoyah 1&2	2.76E+00	9.82E+00	4.61E+00	3.23E+00	1.45E+00	1.65E-01	4.66E-01	4.48E-01	3.54E-01	1.22E+00
South Texas 1								2.24E-01	3.02E+00	7.09E+00
South Texas 2									1.17E-02	5.72E+00
St. Lucie 1	2.46E+00	3.07E+00	2.99E+00	1.93E+00	2.72E+00	2.53E+00	5.95E-01	2.64E-01	2.56E-01	8.27E-01
St. Lucie 2			4.37E-01	1.93E+00	2.75E+00	2.43E+00	5.42E-01	2.59E-01	2.53E-01	7.68E-01
Summer 1		1.24E-04	1.47E+00	4.54E+00	7.09E-01	3.26E-01	4.88E-01	7.55E-01	1.37E+00	3.56E-01
Surry 1&2	6.11E+00	6.68E+00	1.45E+01	9.73E+00	8.55E+00	8.77E+00	5.17E+00	2.41E+00	3.87E+00	4.60E+00
Three Mile Island 1	8.69E-02	5.29E-02	8.12E-02	3.41E-02	6.30E-03	1.41E-02	4.41E-02	4.68E-02	1.61E-02	2.36E-02
Three Mile Island 2	2.22E-05	4.25E-05	9.03E-05	6.46E-04	1.77E-04	1.87E-04	1.16E-04	1.12E-03	3.15E-04	1.77E-04
TMI 2/Epicor	N/D	N/D	N/D	N/D	**	**	**	**	**	**
Trojan	9.94E-01	8.56E-01	3.10E-01	3.49E-01	4.65E-01	2.64E-01	2.09E-01	2.01E-01	1.61E-01	1.44E-01

** Included with Three Mile Island 2 total

N/D = Not Detectable

Table 8

Liquid Effluents Comparison By Year

Mixed Fission and Activation Products (Curies)

Pressurized Water Reactors

Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990
Turkey Point 3&4	3.03E-01	1.68E+00	1.13E+00	2.27E-01						
Turkey Point 3					4.48E-01	2.53E-01	3.74E-01	3.27E-01	1.58E-01	1.41E-01
Turkey Point 4					4.48E-01	2.53E-01	3.74E-01	3.26E-01	1.58E-01	1.40E-01
Vogtle 1&2							5.77E-01	1.66E+00	4.03E-01	1.01E+00
Waterford 3					2.88E-01	4.02E+00	1.28E+00	1.41E+00	1.28E+00	7.30E-01
Wolf Creek 1					6.35E-01	2.26E+00	2.90E-01	3.79E-01	7.23E-01	3.15E-01
Yankee Rowe 1	1.43E-02	9.53E-03	1.30E-02	3.06E-02	1.69E-02	1.36E-02	1.56E-02	7.10E-02	4.88E-03	4.17E-03
Zion 1	1.61E+00	7.22E-01	1.50E+00	6.82E+00	3.24E-01	5.57E-01	7.53E-01	1.61E+00	9.07E-01	2.65E+00
Zion 2	1.05E+00	1.65E+00	1.15E+00	7.06E+00	2.05E+00	1.04E+00	8.20E-01	1.97E+00	2.57E+00	9.26E-01
Total	6.05E+01	8.17E+01	7.72E+01	1.02E+02	1.02E+02	9.79E+01	6.99E+01	7.60E+01	6.95E+01	1.58E+02

Table 9

Solid Waste Summary 1990

Boiling Water Reactors			
Facility	Volume (Cubic Meters)	Activity (Curies)	No. Of Shipments
Big Rock Point 1	8.30E+01	1.26E+02	0
Browns Ferry 1,2,&3	2.12E+02	1.04E+02	121
Brunswick 1&2	4.89E+02	1.26E+03	82
Clinton 1	2.72E+02	5.44E+02	43
Cooper	3.08E+02	3.69E+02	34
Dresden 1,2,&3	2.41E+03	5.09E+02	136
Duane Arnold	3.34E+02	3.79E+04	25
Fermi 2	1.23E+03	2.09E+04	55
James A. Fitzpatrick	2.83E+02	2.05E+03	37
Grand Gulf 1	1.62E+02	1.35E+03	41
Edwin I. Hatch 1&2	1.38E+03	2.85E+04	101
Hope Creek 1	3.06E+02	2.30E+03	64
Humboldt Bay 3	2.93E+01	9.06E-02	1
LaCrosse	4.59E+00	7.44E-01	7
LaSalle 1&2	9.04E+02	2.95E+03	92
Limerick 1&2	6.86E+02	1.24E+03	180
Millstone 1	2.94E+02	3.41E+04	41
Monticello	9.40E+01	1.17E+03	14
Nine Mile Point 1	2.45E+02	4.34E+02	89
Nine Mile Point 2	3.40E+02	6.73E+02	72
Oyster Creek 1	3.23E+02	1.13E+03	58
Peach Bottom 2&3	8.08E+02	3.02E+04	216
Perry 1	1.36E+03	1.94E+03	37
Pilgrim 1	3.71E+02	6.62E+02	63
Quad-Cities 1&2	1.21E+03	1.24E+03	83
River Bend 1	2.44E+02	4.02E+02	38
Shoreham 1	5.04E+01	3.17E-01	3
Susquehanna 1&2	4.07E+02	2.95E+03	54
Vermont Yankee 1	0.00E+00	0.00E+00	0
WNP-2	3.34E+02	1.29E+03	40
Total	1.52E+04	1.76E+05	1827
* Fort St. Vrain	1.01E+02	2.30E+00	13

* High temperature gas cooled reactor

Note: If the volume before compaction and the volume after compaction were both given, the volume used for this table is the volume after compaction. If more than one volume was given, both are shown in the individual plant report. If a description of what the volume represents was given, that is also shown in the individual plant report.

Table 10

Solid Waste Summary 1990

Pressurized Water Reactors			
Facility	Volume (Cubic Meters)	Activity (Curies)	No. Of Shipments
Arkansas One 1&2	1.69E+02	1.43E+01	25
Beaver Valley 1&2	1.57E+02	5.44E+02	26
Braidwood 1&2	1.48E+02	8.55E+01	16
Byron 1&2	2.43E+02	4.99E+02	32
Callaway 1	8.70E+01	3.12E+02	17
Calvert Cliffs 1&2	1.35E+02	4.12E+03	17
Catawba 1&2	1.19E+02	2.09E+01	5
Comanche Peak 1	0.00E+00	0.00E+00	0
Donald C. Cook 1&2	1.95E+02	1.44E+02	89
Crystal River 3	9.22E+02	2.20E+02	28
Davis-Besse 1	3.99E+02	2.26E+03	5
Diablo Canyon 1&2	8.32E+01	2.91E+02	28
Joseph M. Farley 1&2	1.51E+02	2.88E+02	52
Fort Calhoun 1	1.22E+02	7.48E+00	55
R.E.Ginna	1.98E+02	2.32E+02	44
Haddam Neck	1.66E+02	2.21E+05	31
Harris 1	7.73E+01	6.25E+01	49
Indian Point 1&2	2.60E+02	2.08E+03	36
Indian Point 3	6.66E+02	1.50E+02	30
Kewaunee	1.11E+02	3.54E+02	9
Maine Yankee	1.70E+02	1.85E+02	22
McGuire 1&2	2.63E+02	9.80E+02	46
Millstone 2	1.59E+02	9.34E+00	27
Millstone 3	7.60E+01	1.76E+02	6
North Anna 1&2	2.13E+02	7.24E+02	35
Oconee 1,2,&3	4.39E+02	1.79E+03	163
Palisades	2.85E+02	8.74E+01	15
Palo Verde 1,2,&3	7.66E+02	2.40E+02	78
Point Beach 1&2	1.30E+02	2.07E+02	26
Prairie Island 1&2	5.54E+01	3.23E+02	9
Rancho Seco 1	2.16E+01	3.69E+02	5
H.B. Robinson 2	6.99E+01	1.44E+01	61
Salem 1&2	8.92E+01	1.45E+02	20
* San Onofre	2.12E+01	1.04E+00	22
San Onofre 1	5.81E+01	1.27E+01	0
San Onofre 2-3	1.75E+02	3.34E+01	0
Seabrook 1	0.00E+00	0.00E+00	0
Sequoyah 1&2	2.59E+02	9.06E+02	209
South Texas 1&2	5.76E+01	1.38E+01	11
St. Lucie 1&2	2.26E+02	5.89E+03	59
Summer 1	1.10E+02	2.22E+02	65
Surry 1&2	1.48E+02	1.13E+03	27
Three Mile Island 1	5.83E+02	6.53E+02	29
Three Mile Island 2	3.40E+02	7.74E+03	17
TMI 2/Epicor	**	**	**
Trojan	1.80E+02	5.84E+02	8
Turkey Point 3&4	2.15E+02	6.94E+02	29
Vogtle 1&2	9.29E+01	1.64E+02	18
Waterford 3	5.50E+01	5.91E+02	10
Wolf Creek 1	8.31E+01	3.17E+01	6
Yankee Rowe 1	1.82E+02	1.69E+02	11
Zion 1&2	1.44E+02	2.02E+03	29
Total	1.01E+04	2.59E+05	1657

* Represents solid waste shipped by plant but not broken down into units 1, 2, & 3

** Included with Three Mile Island 2 totals

Note: If the volume before compaction and the volume after compaction were both given, the volume used for this table is the volume after compaction. If more than one volume was given, both are shown in the individual plant report. If a description of what the volume represents was given, that is also shown in the individual plant report.

Table 11

Solid Waste Comparison By Year

Boiling Water Reactors

Volume (Cubic Meters) - Activity (Curies)

Facility	1977		1978		1979		1980	
Big Rock Point 1	7.22E+01	9.68E+02	3.10E+01	2.56E+01	8.99E+01	2.77E+02	4.20E+01	3.09E+01
Browns Ferry 1,2,&3	1.82E+03	1.10E+04	2.90E+03	1.33E+03	2.29E+03	4.17E+03	2.49E+03	6.46E+03
Brunswick 1&2	2.47E+03	3.24E+03	2.02E+03	2.14E+03	3.09E+03	4.29E+03	6.73E+03	7.55E+03
Clinton 1								
Cooper	2.83E+02	2.85E+02	3.29E+02	3.84E+02	5.65E+02	9.69E+01	4.35E+02	7.05E+02
Dresden 1,2, & 3	2.25E+03	1.13E+04	1.77E+03	1.88E+03	1.04E+03	8.45E+02	1.16E+03	4.46E+03
Duane Arnold	5.45E+02	4.98E+02	1.10E+03	1.86E+03	7.99E+02	8.01E+02	7.35E+02	7.00E+02
Fermi 2								
James A. Fitzpatrick	1.23E+03	6.17E+03	8.70E+02	3.19E+02	8.04E+02	1.06E+03	7.50E+02	8.86E+02
Grand Gulf 1								
Edwin I. Hatch 1	5.39E+02	3.81E+02	7.50E+02	1.09E+04	9.78E+02	2.70E+02	4.64E+02	9.62E+02
Edwin I. Hatch 2							2.59E+02	8.27E+01
Hope Creek 1								
Humboldt Bay 3	3.77E+02	2.00E+01	1.78E+02	7.91E-01	9.06E+01	3.35E+03	8.20E+01	6.95E+01
LaCrosse	4.65E+00	5.88E+02	3.80E+01	6.18E+01	5.09E+00	1.25E+02	4.32E+01	2.02E+01
LaSalle 1&2								
Limerick 1&2								
Millstone 1	1.77E+03	3.03E+03	2.00E+03	8.15E+04	2.11E+03	1.16E+03	2.30E+03	2.36E+03
Monticello	5.73E+02	2.91E+04	4.99E+02	6.35E+04	4.74E+02	1.31E+04	7.42E+02	7.57E+02
Nine Mile Point 1	6.65E+02	2.51E+04	3.85E+02	2.24E+04	4.97E+02	1.52E+03	8.14E+02	2.32E+04
Nine Mile Point 2								
Oyster Creek 1	1.74E+03	2.73E+02	1.54E+03	1.15E+03	1.13E+03	1.34E+03	2.03E+03	1.32E+03
Peach Bottom 2&3	2.52E+03	1.82E+03	1.96E+03	4.97E+03	2.40E+03	8.03E+03	2.64E+03	6.69E+03
Perry 1								
Pilgrim 1	5.84E+02	5.70E+03	1.97E+03	4.92E+04	3.03E+03	2.22E+04	2.94E+03	1.60E+03
Quad-Cities 1&2	1.20E+03	7.53E+03	1.34E+03	3.27E+03	7.82E+02	4.26E+03	1.67E+03	4.07E+03
River Bend 1								
Shoreham 1								
Susquehanna 1&2								
Vermont Yankee 1	1.08E+02	1.76E+02	3.99E+02	5.39E+04	2.71E+02	9.99E+02	4.84E+02	9.20E+02
WNP-2								
Total	1.88E+04	1.07E+05	2.01E+04	2.99E+05	2.04E+04	6.79E+04	2.68E+04	6.28E+04
• Fort St. Vrain					0.00E+00	0.00E+00	0.00E+00	0.00E+00

• High temperature gas cooled reactor

Table 11

Solid Waste Comparison By Year

Boiling Water Reactors		Volume (Cubic Meters) - Activity (Curies)							
Facility	1981	1982	1983	1984	1985	1986	1987	1988	1989
Big Rock Point 1	1.44E+02	3.17E+02	1.09E+02	4.33E+00	1.01E+02	2.74E+02	3.67E+01	2.13E+00	
Browns Ferry 1,2,& 3	2.23E+03	4.78E+03	5.91E+03	5.51E+03	3.72E+03	6.90E+03	1.92E+03	2.15E+03	
Brunswick 1&2	4.30E+03	7.47E+03	3.53E+02	5.50E+03	3.51E+03	8.36E+03	1.37E+03	3.45E+03	
Clinton 1									
Cooper	4.99E+02	4.43E+02	4.45E+02	4.27E+02	5.03E+02	8.53E+02	4.37E+02	4.91E+02	
Dresden 1,2,& 3	1.14E+03	4.59E+03	8.99E+02	1.66E+05 +	1.42E+03	2.91E+03	1.26E+03	4.37E+03	
Duane Arnold	6.97E+02	1.07E+03	4.57E+02	1.27E+03	6.81E+02	1.44E+03	2.68E+02	9.13E+02	
Fermi 2									
James A. Fitzpatrick	8.61E+02	1.63E+03	1.64E+03	7.89E+02	7.11E+02	7.03E+02	4.31E+02	1.26E+03	
Grand Gulf 1					3.12E+02	7.21E+00	4.31E+02	9.09E+00	
Edwin I. Hatch 1	1.29E+03	4.46E+03	9.13E+02	3.10E+03	1.87E+03	2.27E+03	2.50E+03	2.58E+03	
Edwin I. Hatch 2	1.40E+03	3.05E+02	7.79E+02	9.40E+02	**	**	**	**	
Hope Creek 1									
Humboldt Bay 3	8.43E+01	5.46E-01	7.71E+01	1.34E+00	2.78E+01	1.75E+04	6.56E+01	7.29E+00	
LaCrosse	4.82E+00	6.11E+01	3.53E+01	5.26E+01	1.20E+01	1.88E+02	4.22E+01	1.93E+02	
LaSalle 1&2			0.00E+00	0.00E+00	6.83E+02	3.01E+01	8.40E+02	1.80E+02	
Limerick 1&2							0.00E+00	0.00E+00	
Millstone 1	1.96E+03	1.82E+03	9.77E+02	1.08E+03	6.93E+02	6.81E+02	9.40E+02	1.97E+03	
Monticello	5.54E+02	4.42E+02	7.50E+02	3.89E+03	3.57E+02	4.43E+04	1.24E+03	5.73E+02	
Nine Mile Point 1	5.31E+02	1.72E+03	5.76E+02	7.07E+03	7.21E+02	5.42E+04	6.29E+02	1.34E+04	
Nine Mile Point 2									
Oyster Creek 1	1.78E+03	4.21E+02	9.96E+02	4.67E+03	1.00E+03	5.61E+02	1.39E+03	4.39E+04	
Peach Bottom 2&3	2.34E+03	5.33E+03	3.23E+03	4.51E+03	2.68E+03	2.24E+04	2.26E+03	9.22E+04	
Perry 1									
Pilgrim 1	1.06E+03	9.38E+02	2.28E+03	9.59E+02	6.65E+02	1.48E+03	3.12E+03	1.54E+03	
Quad-Cities 1&2	1.72E+03	5.16E+03	1.46E+03	3.98E+03	1.58E+03	5.85E+03	1.35E+03	4.06E+04	
River Bend 1									
Shoreham 1									
Susquehanna 1&2			4.51E+01	6.52E-02	1.26E+03	2.84E+02	1.30E+03	9.27E+02	
Vermont Yankee 1	4.39E+02	1.11E+03	4.51E+02	2.09E+02	4.15E+02	5.75E+04	3.48E+02	2.85E+02	
WNP-2							3.87E+02	3.58E+01	
Total	2.30E+04	4.21E+04	2.56E+04	2.10E+05	2.29E+04	2.29E+05	2.26E+04	2.11E+05	
• Fort St. Vrain	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.39E+01	1.84E+01	0.00E+00	0.00E+00	

• High temperature gas cooled reactor

+ Includes 12 shipments of poison curtains (irradiated components) to Barnwell, SC

** Included with Edwin I. Hatch 1 totals

Table 11

Solid Waste Comparison By Year

Boiling Water Reactors			Volume (Cubic Meters) - Activity (Curies)					
Facility	1985		1986		1987		1988	
Big Rock Point 1	5.22E+01	1.14E+02	9.46E+00	2.52E+02	7.40E+01	2.30E+03	4.44E+01	7.28E+02
Browns Ferry 1,2,& 3	2.30E+03	3.08E+03	1.36E+03	1.49E+03	1.32E+03	6.44E+02	7.81E+02	5.72E+02
Brunswick 1&2	1.32E+03	2.50E+03	9.35E+02	9.83E+03	8.43E+02	4.48E+04	6.89E+02	3.07E+03
Clinton 1					5.10E+01	1.41E-01	2.87E+02	6.14E+01
Cooper	6.35E+02	2.98E+04	4.49E+02	5.83E+02	3.41E+02	3.60E+02	3.09E+02	1.47E+02
Dresden 1,2,& 3	1.05E+04	6.63E+04	2.14E+03	3.74E+04	1.80E+03	8.26E+02	2.35E+03	1.54E+03
Duane Arnold	7.93E+02	5.24E+02	2.17E+02	2.15E+04	4.94E+02	2.62E+02	2.12E+02	4.06E+02
Fermi 2			1.48E+02	2.12E+01	2.36E+02	9.37E+01	2.38E+02	2.81E+02
James A. Fitzpatrick	7.77E+02	7.79E+02	4.62E+02	7.21E+02	5.13E+02	6.44E+02	3.81E+02	1.32E+04
Grand Gulf 1	6.02E+02	2.60E+02	4.39E+02	1.36E+03	3.92E+02	1.65E+03	4.99E+02	7.15E+02
Edwin I. Hatch 1	2.04E+03	3.83E+04	1.36E+03	8.82E+02	7.78E+02	1.82E+03	8.36E+02	2.02E+03
Edwin I. Hatch 2	**	**	**	**	**	**	**	**
Hope Creek 1			8.45E+01	5.14E+00	4.21E+02	3.63E+02	2.91E+02	3.23E+03
Humboldt Bay 3	8.31E+02	2.60E+02	5.99E+02	3.50E+02	0.00E+00	0.00E+00	3.99E+01	9.91E-02
LaCrosse	6.30E+01	2.35E+02	4.81E+00	7.78E+01	2.93E+01	2.86E-03	6.52E+00	7.03E+01
LaSalle 1&2	1.21E+03	4.87E+02	8.02E+02	1.20E+03	7.66E+02	2.30E+03	9.25E+02	3.38E+03
Limerick 1&2	3.06E+02	2.06E+01	5.76E+02	7.53E+02	3.81E+02	2.15E+03	8.95E+02	9.70E+02
Millstone 1	1.17E+03	9.36E+04	7.00E+02	7.85E+02	6.66E+02	5.05E+02	2.79E+02	9.54E+04
Monticello	5.44E+02	4.87E+03	2.94E+02	2.81E+04	2.19E+02	5.66E+02	1.48E+02	2.93E+02
Nine Mile Point 1	5.75E+00	6.80E+03	1.08E+03	7.27E+02	5.07E+02	2.30E+02	2.72E+02	3.07E+02
Nine Mile Point 2					9.89E+01	1.14E+01	3.78E+02	3.88E+02
Oyster Creek 1	4.62E+02	6.30E+02	5.92E+02	7.96E+02	2.36E+02	3.48E+04	1.81E+02	6.29E+03
Peach Bottom 2&3	2.33E+03	1.21E+05	1.49E+03	1.88E+04	1.58E+03	3.89E+03	8.38E+02	1.19E+03
Perry 1			0.00E+00	0.00E+00	4.89E+02	4.52E+01	4.95E+02	5.59E+02
Pilgrim 1	1.41E+03	7.48E+04	6.01E+02	4.38E+02	5.27E+02	3.15E+02	2.72E+02	2.19E+02
Quad-Cities 1&2	1.33E+03	5.53E+04	1.32E+03	2.14E+03	9.19E+02	2.90E+04	9.25E+02	6.26E+02
River Bend 1			4.63E+02	7.99E+01	4.07E+02	3.45E+02	3.06E+02	3.50E+02
Shoreham 1			4.47E+01	1.47E-01	6.26E+01	9.57E-02	6.26E+01	1.86E-02
Susquehanna 1&2	1.13E+03	2.07E+03	8.68E+02	2.53E+03	7.18E+02	2.11E+03	1.33E+03	2.65E+03
Vermont Yankee 1	5.43E+02	1.73E+04	3.10E+02	3.33E+02	2.23E+02	1.19E+04	1.73E+02	4.25E+02
WNP-2	4.02E+02	2.96E+02	3.02E+02	5.07E+02	3.75E+02	1.09E+03	4.70E+02	1.01E+03
Total	3.13E+04	5.19E+05	1.77E+04	1.32E+05	1.55E+04	1.43E+05	1.49E+04	1.40E+05
* Fort St. Vrain	1.10E+02	4.19E+02	0.00E+00	0.00E+00	3.02E+01	1.03E+02	7.00E+00	3.10E-01

* High temperature gas cooled reactor

** Included with Edwin I. Hatch 1 totals

Table 11

Solid Waste Comparison By Year

Boiling Water Reactors

Volume (Cubic Meters) - Activity (Curies)

Facility	1989		+ 1990	
Big Rock Point 1	7.35E+01	3.71E+02	8.30E+01	1.26E+02
Browns Ferry 1,2,& 3	5.84E+02	2.95E+02	2.12E+02	1.04E+02
Brunswick 1&2	6.20E+02	6.06E+03	4.89E+02	1.26E+03
Clinton 1	3.99E+02	1.89E+03	2.72E+02	5.44E+02
Cooper	2.92E+02	3.06E+02	3.08E+02	3.69E+02
Dresden 1,2,& 3	2.24E+03	2.54E+03	2.41E+03	5.09E+02
Duane Arnold	1.46E+02	1.69E+04	3.34E+02	3.79E+04
Fermi 2	3.66E+02	7.01E+02	1.23E+03	2.09E+04
James A. Fitzpatrick	2.50E+02	9.39E+04	2.83E+02	2.05E+03
Grand Gulf 1	2.72E+02	2.06E+02	1.62E+02	1.35E+03
Edwin I. Hatch 1	8.53E+02	1.91E+03	1.38E+03	2.85E+04
Edwin I. Hatch 2	**	**	**	**
Hope Creek 1	1.67E+02	5.27E+02	3.06E+02	2.30E+03
Humboldt Bay 3	0.00E+00	0.00E+00	2.93E+01	9.06E-02
LaCrosse	6.74E+00	3.21E+01	4.59E+00	7.44E-01
LaSalle 1&2	8.80E+02	4.36E+03	9.04E+02	2.95E+03
Limerick 1&2	5.76E+02	3.40E+04	6.86E+02	1.24E+03
Millstone 1	4.28E+02	1.99E+04	2.94E+02	3.41E+04
Monticello	2.48E+02	5.97E+04	9.40E+01	1.17E+03
Nine Mile Point 1	2.37E+02	2.48E+02	2.45E+02	4.34E+02
Nine Mile Point 2	4.22E+02	4.89E+02	3.40E+02	6.73E+02
Oyster Creek 1	4.20E+02	2.33E+05	3.23E+02	1.13E+03
Peach Bottom 2&3	8.92E+02	1.73E+03	8.08E+02	3.02E+04
Perry 1	9.68E+02	9.18E+02	1.36E+03	1.94E+03
Pilgrim 1	2.02E+02	2.76E+02	3.71E+02	6.62E+02
Quad-Cities 1&2	9.79E+02	1.33E+05	1.21E+03	1.24E+03
River Bend 1	5.16E+02	8.41E+02	2.44E+02	4.02E+02
Shoreham 1	1.79E+01	3.51E-02	5.04E+01	9.17E-01
Susquehanna 1&2	4.28E+02	1.34E+03	4.07E+02	2.95E+03
Vermont Yankee 1	4.84E+00	2.15E+00	0.00E+00	0.00E+00
WNP-2	3.64E+02	1.10E+03	3.34E+02	1.29E+03
Total	1.39E+04	6.17E+05	1.52E+04	1.76E+05
* Fort St. Vrain	4.57E+00	1.08E+03	1.01E+02	2.30E+00

* High temperature gas cooled reactor

** Included with Edwin I. Hatch 1 totals

+ Note: If the volume before compaction and the volume after compaction were both given, the volume used for this table is the volume after compaction. If more than one volume was given, both are shown in the individual plant report. If a description of what the volume represents was given, that is also shown in the individual plant report.

Table 12

Solid Waste Comparison By Year

Pressurized Water Reactors

Volume (Cubic Meters) - Activity (Curies)

Facility	1977		1978		1979		1980	
Arkansas One 1&2	3.17E+02	1.26E+02	N/R	N/R	N/R	N/R	N/R	N/R
Beaver Valley 1&2	2.67E+02	8.18E+00	4.39E+02	2.25E+02	2.44E+02	2.95E+02	2.84E+02	5.34E+02
Braidwood 1&2								
Byron 1&2								
Callaway 1								
Calvert Cliffs 1&2	3.09E+02	9.83E+02	6.03E+02	1.12E+03	4.32E+02	9.71E+02	2.51E+02	1.48E+04
Catawba 1&2								
Comanche Peak 1								
Donald C. Cook 1&2	6.84E+02	8.28E+01	1.28E+03	2.25E+02	1.09E+03	3.37E+02	2.10E+03	1.04E+03
Crystal River 3	4.48E+02	3.48E+00	6.87E+02	2.72E+04	1.24E+03	1.20E+03	9.27E+02	2.05E+03
Davis-Besse 1	0.00E+00	0.00E+00	3.40E+02	3.30E+00	2.60E+02	2.86E+00	3.30E+02	3.00E+01
Diablo Canyon 1&2								
Joseph M. Farley 1&2			2.69E+02	5.72E+00	1.11E+03	2.32E+02	4.41E+02	2.26E+02
Fort Calhoun 1	5.97E+02	6.46E+02	5.84E+02	1.06E+02	2.44E+02	2.99E+01	4.06E+02	1.32E+03
R. E. Ginna	3.49E+02	6.90E+02	5.96E+01	6.27E+02	3.08E+02	1.53E+02	4.00E+02	4.60E+02
Haddam Neck	1.68E+03	8.41E+02	2.29E+02	1.44E+02	1.29E+03	3.05E+02	1.26E+03	4.89E+02
Harris 1								
Indian Point 1&2	1.06E+03	1.45E+03	8.43E+03	2.37E+03	1.17E+03	2.16E+03	1.03E+03	3.32E+02
Indian Point 3	Shown With Other Unit		5.94E+02	6.49E+01	2.25E+02	1.63E+02	3.47E+02	2.02E+02
Kewaunee	3.37E+01	3.66E+02	7.98E+01	1.50E+03	1.70E+02	3.54E+02	1.03E+02	1.37E+03
Maine Yankee	1.84E+02	1.53E+04	5.81E+02	4.14E+03	3.63E+02	2.77E+03	4.57E+02	4.79E+03
McGuire 1&2								
Millstone 2	9.35E+01	5.80E+01	1.55E+02	1.70E+01	2.46E+02	1.78E+03	7.51E+00	2.28E+02
Millstone 3								
North Anna 1&2			2.14E+01	3.59E+00	2.95E+02	5.89E+01	2.64E+02	1.54E+02
Onondaga 1,2,& 3	1.07E+03	7.37E+03	1.58E+03	5.93E+03	1.63E+03	2.59E+03	1.32E+03	2.91E+03
Palisades	4.43E+02	8.71E+01	7.17E+02	3.40E+03	6.84E+02	3.92E+02	7.31E+02	1.18E+02
Palo Verde 1,2,&3								
Point Beach 1&2	6.84E+03	5.68E+02	1.61E+02	1.51E+03	2.69E+02	1.22E+03	4.49E+02	9.35E+02
Prairie Island 1&2	6.43E+02	2.46E+02	1.95E+02	1.53E+02	1.99E+01	8.83E+01	5.25E+02	1.98E+02
Rancho Seco 1	5.06E+01	1.21E+03	1.29E+02	1.27E+03	1.01E+02	4.03E+00	4.60E+02	1.12E+02
H. B. Robinson 2	2.59E+02	1.24E+03	8.22E+02	2.40E+02	8.34E+02	8.72E+01	3.99E+03	3.08E+02
Salem 1&2	4.25E+02	2.20E+00	2.27E+02	1.94E+02	6.86E+02	1.28E+02	1.01E+03	4.59E+02
San Onofre								
San Onofre 1	3.68E+02	6.02E+01	1.31E+02	7.17E+00	8.35E+01	9.24E+01	7.12E+02	4.35E+02
San Onofre 2-3								
Seabrook 1								
Sequoyah 1&2							N/R	N/R
South Texas 1&2								
St. Lucie 1&2	3.85E+02	3.27E+03	3.58E+02	1.26E+04	3.08E+02	1.79E+02	3.12E+02	7.46E+02
Summer 1								
Surry 1&2	7.93E+02	6.10E+02	6.03E+02	5.66E+02	2.74E+03	3.45E+02	2.01E+03	7.06E+02
Three Mile Island 1	2.18E+02	4.73E+01	3.89E+02	2.34E+02	7.51E+02	3.12E+01	4.62E+02	2.30E+02
Three Mile Island 2			Shown With Other Unit		Shown With Other Unit		7.67E+02	1.26E+02
TMI 2/Epicor							0.00E+00	0.00E+00
Trojan	1.01E+02	8.31E+01	2.26E+02	4.48E+02	6.37E+02	3.30E+02	5.14E+02	4.59E+01
Turkey Point 3&4	1.07E+03	4.26E+02	1.75E+03	1.72E+03	9.20E+02	2.48E+02	7.24E+02	1.61E+02
Vogtle 1&2								
Waterford 3								
Wolf Creek 1								
Yankee Rowe 1	2.81E+02	3.54E+00	2.60E+02	9.75E+00	2.36E+02	1.63E+02	2.07E+02	9.57E+01
Zion 1&2	1.97E+03	2.25E+02	1.63E+03	1.86E+03	5.97E+02	2.69E+03	1.64E+03	2.55E+03
Total	2.09E+04	3.60E+04	2.35E+04	6.79E+04	1.92E+04	1.94E+04	2.44E+04	3.82E+04

N/R = Not Reported

Table 12

Solid Waste Comparison By Year

Pressurized Water Reactors

Volume (Cubic Meters) - Activity (Curies)

Facility	1981		1982		1983		1984	
Arkansas One 1&2	N/R	N/R	N/R	N/R	7.06E+02	2.09E+03	8.10E+02	1.46E+03
Beaver Valley 1&2	2.13E+02	9.30E+01	2.94E+02	3.83E+02	2.19E+02	4.75E+02	1.56E+02	7.11E+02
Braidwood 1&2								
Byron 1&2								
Callaway 1							0.00E+00	0.00E+00
Calvert Cliffs 1&2	5.00E+02	9.86E+01	1.57E+02	9.16E+02	5.06E+02	1.07E+02	5.28E+02	3.77E+04
Catawba 1&2								
Comanche Peak 1								
Donald C. Cook 1&2	9.63E+02	1.43E+03	7.14E+02	8.45E+02	6.68E+02	2.01E+03	4.94E+02	6.69E+02
Crystal River 3	1.27E+03	1.38E+03	6.62E+02	6.28E+02	5.40E+02	1.55E+03	4.11E+02	1.15E+03
Davis-Besse 1	3.25E+02	3.95E+01	0.00E+00	0.00E+00	1.13E+02	6.37E+02	1.51E+02	4.73E+02
Diablo Canyon 1&2							0.00E+00	0.00E+00
Joseph M. Farley 1&2	5.64E+02	7.20E+02	3.46E+02	1.03E+02	4.41E+02	1.05E+03	5.62E+02	2.98E+02
Fort Calhoun 1	2.53E+02	1.01E+02	3.42E+02	3.54E+01	4.65E+02	7.00E+02	3.93E+02	7.17E+01
R. E. Ginna	3.76E+02	6.35E+02	4.89E+02	2.02E+02	3.36E+02	5.21E+02	2.52E+02	3.23E+02
Haddam Neck	4.38E+02	6.61E+02	3.12E+02	2.57E+02	6.52E+02	1.52E+03	4.28E+02	3.75E+02
Harris 1								
Indian Point 1&2	1.58E+03	1.71E+03	1.17E+03	6.46E+03	1.29E+03	2.12E+03	9.81E+02	2.03E+03
Indian Point 3	3.17E+02	6.40E+01	3.79E+02	6.14E+01	3.16E+02	7.32E+02	1.53E+02	4.12E+02
Kewaunee	7.38E+01	1.98E+02	6.73E+01	2.74E+02	5.52E+01	6.85E+02	6.32E+01	1.60E+03
Maine Yankee	4.14E+02	1.67E+03	2.20E+02	3.09E+01	3.37E+02	1.03E+02	3.49E+02	3.59E+02
McGuire 1&2	1.98E+01	1.31E+01	9.91E+01	6.43E+00	2.44E+02	2.82E+01	4.14E+02	1.89E+03
Millstone 2	1.63E+01	3.21E+02	6.85E+00	4.84E+02	4.48E+01	2.58E+02	6.08E+01	1.10E+05
Millstone 3								
North Anna 1&2	3.02E+02	2.62E+03	4.21E+02	3.05E+02	5.39E+02	1.87E+03	9.00E+02	9.53E+02
Oconee 1,2,& 3	2.48E+03	1.12E+04	3.06E+03	1.09E+04	1.16E+03	2.84E+03	9.36E+02	6.17E+03
Palisades	8.54E+02	1.57E+04	7.08E+02	7.98E+01	5.75E+02	2.56E+04	4.48E+02	2.58E+02
Palo Verde 1,2,&3								
Point Beach 1&2	1.77E+02	4.87E+02	2.52E+02	9.46E+02	7.11E+02	1.12E+03	7.12E+02	1.64E+03
Prairie Island 1&2	2.97E+02	5.64E+01	9.91E+01	3.64E+02	2.39E+02	1.92E+02	4.19E+01	1.19E+01
Rancho Seco 1	2.31E+02	1.44E+02	2.40E+02	4.66E+02	2.72E+02	2.25E+02	4.25E+02	4.60E+01
H. B. Robinson 2	9.02E+02	1.88E+01	1.38E+03	6.38E+01	1.09E+03	4.62E+01	3.05E+03	1.95E+02
Salem 1&2	9.36E+02	1.14E+03	1.91E+03	3.19E+02	2.07E+03	2.99E+02	1.52E+03	6.23E+02
San Onofre								
San Onofre 1	1.62E+03	1.26E+03	9.27E+02	7.52E+01	3.33E+02	2.27E+02	2.91E+02	1.54E+01
San Onofre 2-3			0.00E+00	0.00E+00	1.89E+02	7.98E+00	2.02E+02	5.49E+02
Seabrook 1								
Sequoyah 1&2	1.61E+02	2.92E+01	3.58E+02	2.28E+02	6.93E+02	2.30E+03	9.67E+02	2.43E+03
South Texas 1&2								
St. Lucie 1&2	2.50E+02	2.96E+02	3.07E+02	7.95E+02	6.20E+02	9.39E+04	1.22E+03	6.36E+04
Summer 1			0.00E+00	0.00E+00	9.25E+01	1.37E+01	4.80E+02	1.55E+02
Surry 1&2	2.80E+03	1.36E+03	2.17E+03	9.89E+02	3.08E+03	3.56E+03	9.45E+02	1.16E+03
Three Mile Island 1	7.98E+02	2.34E+02	5.32E+02	8.91E+00	6.05E+02	6.84E+02	4.34E+02	4.18E+02
Three Mile Island 2	2.74E+02	5.11E+01	1.80E+02	1.22E+01	3.16E+02	5.17E+05	2.56E+02	9.89E+03
TMI 2/Epicor	1.51E+02	3.50E+02	0.00E+00	0.00E+00	2.23E+02	4.62E+04	4.53E+00	2.35E-01
Trojan	3.75E+02	1.04E+03	2.17E+01	2.87E+02	2.28E+02	1.67E+03	2.30E+02	5.85E+01
Turkey Point 3&4	1.25E+03	1.17E+02	1.01E+03	1.13E+03	1.21E+03	9.26E+02	8.50E+02	1.91E+03
Vogtle 1&2								
Waterford 3								
Wolf Creek 1								
Yankee Rowe 1	3.08E+02	6.79E+01	2.09E+02	2.81E+01	1.58E+02	5.12E+00	2.00E+02	1.63E+02
Zion 1&2	1.53E+03	3.44E+03	8.82E+02	2.17E+03	9.21E+02	2.97E+03	6.43E+02	2.62E+03
Total	2.30E+04	4.87E+04	1.99E+04	2.99E+04	2.23E+04	7.16E+05	2.10E+04	2.52E+05

N/R = Not Reported

Table 12

Solid Waste Comparison By Year

Pressurized Water Reactors

Volume (Cubic Meters) - Activity (Curies)

Facility	1985		1986		1987		1988	
Arkansas One 1&2	6.88E+02	1.75E+03	1.21E+02	2.18E+02	5.23E+02	1.63E+03	1.97E+02	8.22E+02
Beaver Valley 1&2	1.56E+02	9.71E+01	9.49E+01	4.45E+02	7.65E+01	3.22E+01	2.33E+02	4.29E+02
Braidwood 1&2					0.00E+00	0.00E+00	8.32E+01	3.51E+00
Byron 1&2	1.78E+02	1.39E+01	3.18E+02	9.90E+01	3.06E+02	8.65E+02	3.09E+02	5.09E+02
Callaway 1	1.39E+02	6.29E+00	1.66E+02	1.91E+01	1.98E+02	3.13E+02	9.58E+01	9.46E+02
Calvert Cliffs 1&2	3.89E+02	1.51E+04	2.12E+02	4.51E+02	2.44E+02	6.41E+02	5.25E+01	1.12E+03
Catawba 1&2	3.48E+01	6.90E-02	1.93E+02	1.33E+01	2.73E+02	2.79E+02	2.56E+02	7.05E+02
Comanche Peak 1								
Donald C. Cook 1&2	8.28E+02	2.00E+03	5.28E+02	1.59E+03	4.63E+02	2.30E+03	2.46E+02	5.58E+02
Crystal River 3	4.98E+02	4.60E+03	3.64E+02	1.35E+03	2.90E+02	6.75E+02	2.26E+02	1.07E+03
Davis-Besse 1	1.97E+02	9.58E+01	1.40E+02	2.19E+00	8.48E+01	3.20E+00	1.72E+02	1.76E+02
Diablo Canyon 1&2	3.11E+01	4.40E+01	9.06E+01	6.97E+00	1.65E+02	1.21E+02	2.10E+02	3.92E+02
Joseph M. Farley 1&2	4.95E+02	8.20E+02	2.45E+02	1.80E+03	5.32E+02	3.34E+02	4.96E+02	1.47E+03
Fort Calhoun 1	3.43E+02	2.24E+02	1.16E+02	2.82E+01	1.28E+02	5.47E+02	4.87E+01	1.75E+01
R. E. Ginna	2.23E+02	1.19E+02	1.12E+02	1.39E+02	1.65E+02	2.16E+02	1.67E+02	3.80E+02
Haddam Neck	1.73E+02	5.33E+01	4.14E+02	5.86E+02	3.20E+02	5.45E+02	1.31E+02	3.37E+02
Harris 1					1.05E+02	2.61E+00	1.50E+02	1.05E+01
Indian Point 1&2	6.89E+02	5.75E+02	5.30E+02	2.52E+02	2.30E+02	8.34E+02	2.41E+02	4.67E+02
Indian Point 3	2.39E+02	5.49E+02	8.29E+01	2.58E+01	3.17E+02	3.33E+02	1.82E+02	3.57E+02
Kewaunee	7.77E+01	9.56E+02	5.31E+01	1.33E+02	8.25E+01	4.58E+02	7.49E+01	4.83E+02
Maine Yankee	3.59E+02	1.11E+02	1.96E+02	1.64E+02	7.50E+01	1.90E+02	1.37E+02	4.36E+02
McGuire 1&2	6.60E+02	1.97E+02	7.83E+02	6.73E+02	6.92E+02	3.23E+02	5.16E+02	6.49E+02
Millstone 2	2.87E+01	6.16E+03	8.85E+01	6.17E+03	1.38E+02	2.13E+04	1.59E+02	5.06E+01
Millstone 3			5.47E+00	5.17E-01	9.95E+01	5.91E+01	1.63E+02	5.34E+02
North Anna 1&2	6.50E+02	2.90E+02	5.30E+02	7.97E+02	4.89E+02	1.64E+03	2.95E+02	7.71E+02
Oconee 1,2,& 3	4.33E+02	1.41E+03	7.60E+02	8.51E+02	8.53E+02	2.01E+03	7.23E+02	1.42E+04
Palisades	4.76E+02	1.83E+02	2.39E+02	2.65E+02	2.23E+02	1.06E+02	1.87E+02	1.38E+03
Palo Verde 1,2,&3	8.42E+01	6.80E+01	1.16E+02	4.22E+01	4.63E+02	9.76E+02	7.78E+02	7.78E+02
Point Beach 1&2	2.81E+02	1.25E+03	1.08E+02	1.35E+03	1.55E+02	1.43E+03	1.95E+02	6.61E+02
Prairie Island 1&2	1.73E+02	4.02E+02	1.28E+02	1.55E+02	1.42E+02	4.30E+02	5.68E+01	1.38E+02
Rancho Seco 1	9.76E+02	1.57E+03	1.56E+02	1.00E+03	1.59E+02	3.51E+00	3.46E+02	6.25E+01
H. B. Robinson 2	6.42E+02	3.35E+03	4.53E+02	1.58E+02	1.01E+02	2.59E+02	8.42E+01	3.76E+02
Salem 1&2	4.55E+02	2.02E+03	4.71E+02	4.53E+02	3.29E+02	9.69E+02	3.59E+02	3.80E+02
* San Onofre	1.56E+01	8.96E-01	2.33E+00	4.65E-01	4.04E+00	4.32E-01	4.24E-01	1.63E-01
San Onofre 1	1.80E+02	6.04E+00	2.51E+02	3.82E+02	3.69E+01	4.98E+01	3.08E+01	4.06E+00
San Onofre 2-3	5.45E+02	1.72E+03	2.94E+02	1.93E+02	2.45E+02	2.71E+02	2.60E+02	2.55E+03
Seabrook 1								
Sequoyah 1&2	7.52E+02	2.45E+03	4.27E+02	1.33E+04	4.12E+02	9.78E+02	6.07E+02	2.92E+02
South Texas 1&2							0.00E+00	0.00E+00
St. Lucie 1&2	5.45E+02	1.59E+03	4.60E+02	2.13E+03	3.53E+02	1.05E+03	4.67E+02	1.29E+04
Summer 1	4.46E+02	1.30E+02	1.12E+02	1.50E+01	3.80E+02	6.76E+02	1.61E+02	1.22E+02
Surry 1&2	2.02E+03	1.21E+03	6.39E+02	1.16E+03	5.15E+02	2.94E+04	7.30E+02	1.94E+02
Three Mile Island 1	4.69E+02	1.94E+01	2.13E+02	7.70E+00	2.49E+02	2.38E+02	2.37E+02	6.92E+02
Three Mile Island 2	4.83E+02	6.35E+03	3.29E+02	5.81E+01	6.59E+02	3.18E+02	9.17E+02	7.18E+03
TMI 2/Epicor	**	**	**	**	**	**	**	**
Trojan	3.09E+02	3.52E+03	2.49E+02	6.25E+02	3.31E+02	4.09E+02	2.48E+02	4.33E+02
Turkey Point 3&4	6.08E+02	1.50E+03	3.23E+02	8.87E+01	3.07E+02	9.32E+02	1.07E+02	7.05E+02
Vogtle 1&2					0.00E+00	0.00E+00	4.72E+01	2.55E+01
Waterford 3	2.82E+02	3.39E+01	1.74E+02	3.75E+01	3.83E+02	1.78E+02	2.81E+02	4.43E+03
Wolf Creek 1	0.00E+00	0.00E+00	1.73E+02	1.48E+02	1.28E+02	1.15E+01	1.24E+02	1.27E+03
Yankee Rowe 1	2.00E+02	2.68E+02	1.12E+02	5.21E+00	1.86E+02	8.83E+00	1.22E+02	8.85E+03
Zion 1&2	6.73E+02	2.69E+03	3.31E+02	6.74E+02	4.11E+02	7.13E+02	3.59E+02	2.50E+03
Total	1.81E+04	6.55E+04	1.19E+04	3.81E+04	1.30E+04	7.51E+04	1.23E+04	7.28E+04

* Represents solid waste shipped by plant but not broken down into units 1, 2, & 3

** Included with Three Mile Island 2 totals

Table 12

Solid Waste Comparison By Year

Pressurized Water Reactors

Volume (Cubic Meters) - Activity (Curies)

Facility	1989		+ 1990	
Arkansas One 1&2	2.22E+02	2.96E+02	1.69E+02	1.43E+01
Beaver Valley 1&2	1.96E+03	1.35E+03	1.57E+02	5.44E+02
Braidwood 1&2	3.10E+02	3.89E+02	1.48E+02	8.55E+01
Byron 1&2	3.65E+02	1.28E+03	2.43E+02	4.99E+02
Callaway 1	2.09E+02	6.00E+02	8.70E+01	3.12E+02
Calvert Cliffs 1&2	2.07E+02	4.14E+02	1.35E+02	4.12E+03
Catawba 1&2	2.16E+02	3.17E+02	1.19E+02	2.09E+01
Comanche Peak 1			0.00E+00	0.00E+00
Donald C. Cook 1&2	3.88E+02	1.17E+03	1.95E+02	1.44E+02
Crystal River 3	3.47E+02	2.40E+03	9.22E+02	2.20E+02
Davis-Besse 1	1.18E+02	2.08E+02	3.99E+02	2.26E+03
Diablo Canyon 1&2	1.87E+02	4.29E+02	8.32E+01	2.91E+02
Joseph M. Farley 1&2	4.85E+02	4.00E+02	1.51E+02	2.88E+02
Fort Calhoun 1	1.75E+02	8.76E+00	1.22E+02	7.48E+00
R. E. Ginna	2.33E+02	7.99E+01	1.98E+02	2.32E+02
Haddam Neck	1.53E+02	6.55E+02	1.66E+02	2.21E+05
Harris 1	1.60E+02	2.54E+01	7.73E+01	6.25E+01
Indian Point 1&2	4.78E+02	3.60E+02	2.60E+02	2.08E+03
Indian Point 3	5.77E+02	3.50E+02	6.66E+02	1.50E+02
Kewaunee	7.00E+01	7.74E+02	1.11E+02	3.54E+02
Maine Yankee	1.95E+02	2.36E+02	1.70E+02	1.85E+02
McGuire 1&2	4.36E+02	6.32E+02	2.63E+02	9.80E+02
Millstone 2	2.47E+02	5.55E+02	1.59E+02	9.34E+00
Millstone 3	1.47E+02	7.37E+02	7.60E+01	1.76E+02
North Anna 1&2	6.77E+02	1.72E+03	2.13E+02	7.24E+02
Oconee 1,2,& 3	4.25E+02	1.46E+03	4.39E+02	1.79E+03
Palisades	2.19E+02	8.32E+03	2.95E+02	8.74E+01
Palo Verde 1,2,&3	8.74E+02	6.74E+02	7.68E+02	2.40E+02
Point Beach 1&2	1.06E+02	2.54E+02	1.30E+02	2.07E+02
Prairie Island 1&2	1.25E+02	1.03E+02	5.54E+01	3.23E+02
Rancho Seco 1	2.44E+02	3.27E+02	2.16E+01	3.69E+02
H. B. Robinson 2	9.69E+01	1.86E+02	6.99E+01	1.44E+01
Salem 1&2	1.22E+02	5.65E+04	8.92E+01	1.45E+02
* San Onofre	0.00E+00	0.00E+00	2.12E-01	1.04E+00
San Onofre 1	1.19E+02	1.72E+03	5.81E+01	1.27E+01
San Onofre 2-3	3.28E+02	2.72E+03	1.75E+02	3.34E+01
Seabrook 1	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Sequoyah 1&2	4.65E+02	2.64E+03	2.59E+02	9.06E+02
South Texas 1&2	5.03E+01	7.24E+00	5.76E+01	1.38E+01
St. Lucie 1&2	3.18E+02	1.69E+02	2.26E+02	5.89E+03
Summer 1	1.40E+02	3.76E+02	1.10E+02	2.22E+02
Surry 1&2	5.38E+02	1.31E+03	1.48E+02	1.13E+03
Three Mile Island 1	3.32E+02	5.05E+01	5.83E+02	6.53E+02
Three Mile Island 2	1.18E+03	1.39E+04	3.40E+02	7.74E+03
TMI 2/Epicor	**	**	**	**
Trojan	2.59E+02	4.47E+02	1.80E+02	5.84E+02
Turkey Point 3&4	3.46E+02	2.26E+00	2.15E+02	6.94E+02
Vogtle 1&2	1.00E+02	1.51E+01	9.29E+01	1.64E+02
Waterford 3	7.61E+02	4.07E+02	5.50E+01	5.91E+02
Wolf Creek 1	1.51E+02	1.26E+03	8.31E+01	3.17E+01
Yankee Rowe 1	2.98E+02	1.78E+01	1.82E+02	1.69E+02
Zion 1&2	2.14E+02	3.58E+03	1.44E+02	2.02E+03
Total	1.64E+04	1.12E+05	1.01E+04	2.59E+05

* Represents solid waste shipped by plant but not broken down into units 1, 2, & 3

** Included with Three Mile Island 2 totals

+ Note: If the volume before compaction and the volume after compaction were both given, the volume used for this table is the volume after compaction. If more than one volume was given, both are shown in the individual plant report. If a description of what the volume represents was given, that is also shown in the individual plant report.

Table 15

Net Electrical Energy Generation Comparison By Year

		Megawatt Hours								
Boiling Water Reactors		Initial	Commercial							
Facility	Criticality	Operation	1978	1979	1980	1981	1982	1983	1984	
Big Rock Point 1	09/27/62	03/29/63	4.01E+05	1.14E+05	4.05E+05	4.70E+05	3.60E+05	3.49E+05	4.18E+05	
Browns Ferry 1	08/17/73	08/01/74	1.69E+07	2.04E+07	6.06E+06	4.41E+06	7.88E+06	2.18E+06	7.85E+06	
Browns Ferry 2	07/20/74	03/01/75			5.82E+06	7.47E+06	4.45E+06	6.39E+06	4.04E+06	
Browns Ferry 3	08/08/76	03/01/77			6.94E+06	6.28E+06	4.89E+06	5.39E+06	2.91E+05	
Brunswick 1	10/08/76	03/18/77	9.91E+06	6.82E+06	3.94E+06	2.56E+06	2.92E+06	1.39E+06	5.03E+06	
Brunswick 2	03/20/75	11/03/75			1.86E+05	3.28E+06	1.91E+06	3.94E+06	1.39E+06	
Clinton 1	02/27/87	11/24/87								
Cooper	02/21/74	07/01/74	4.89E+06	4.99E+06	3.79E+06	3.85E+06	5.28E+06	3.34E+06	3.47E+06	
Dresden 1	10/15/59	07/04/60	7.59E+05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.46E+06	
Dresden 2	01/07/70	06/09/70	9.53E+06	8.42E+06	4.58E+06	3.41E+06	5.12E+06	3.40E+06	2.11E+06	
Dresden 3	01/31/71	11/16/71			4.33E+06	5.18E+06	3.89E+06	4.15E+06	2.11E+06	
Duane Arnold	03/23/74	02/01/75	1.23E+06	2.90E+06	2.80E+06	2.22E+06	2.28E+06	2.32E+06	2.72E+06	
Fermi 2	06/21/85	01/23/86								
James A. Fitzpatrick	11/17/74	07/28/75	4.20E+06	2.98E+06	4.33E+06	4.78E+06	4.96E+06	4.63E+06	4.90E+06	
Grand Gulf 1	08/18/82	07/01/85						0.00E+00	1.65E+05	
Edwin I. Hatch 1	09/12/74	12/31/75	4.77E+06	5.10E+06	4.79E+06	2.76E+06	2.88E+06	3.96E+06	3.60E+06	
Edwin I. Hatch 2	07/04/78	09/05/79			3.84E+06	4.48E+06	3.73E+06	3.81E+06	1.88E+06	
Hope Creek 1	06/28/86	12/20/86								
Humboldt Bay 3	02/16/63	08/ / 63	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
LaCrosse	07/11/67	11/01/69	1.74E+05	2.01E+05	2.15E+06	2.41E+05	1.38E+05	2.01E+05	3.19E+05	
LaSalle 1	06/21/82	01/01/84					4.61E+05	1.64E+06	5.21E+06	
LaSalle 2	03/10/84	10/19/84							1.39E+06	
Limerick 1	12/22/84	02/01/86							0.00E+00	
Limerick 2	08/12/89	01/08/90								
Millstone 1	10/26/70	03/01/71	4.65E+06	4.22E+06	3.40E+06	2.52E+06	4.08E+06	5.35E+06	4.32E+06	
Monticello	12/10/70	06/30/71	3.86E+06	4.40E+06	3.45E+06	3.26E+06	2.42E+06	4.15E+06	2.63E+05	
Nine Mile Point 1	09/05/69	12/01/69	4.47E+06	3.00E+06	4.54E+06	3.27E+06	1.13E+06	2.80E+06	3.64E+06	
Nine Mile Point 2	05/23/87	04/05/88								
Oyster Creek 1	05/03/69	12/01/69	3.85E+06	4.56E+06	1.96E+06	2.63E+06	2.01E+06	2.05E+05	2.79E+05	
Peach Bottom 2	09/16/73	07/05/74	1.38E+07	1.47E+07	4.34E+06	6.63E+06	4.79E+06	4.45E+06	2.43E+06	
Peach Bottom 3	08/07/74	12/23/74			7.23E+06	3.13E+06	8.53E+06	2.42E+06	7.45E+06	
Perry 1	06/06/86	11/18/87								
Pilgrim 1	06/16/72	12/01/72	4.38E+06	4.84E+06	3.04E+06	3.44E+06	3.29E+06	4.71E+06	3.52E+03	
Quad-Cities 1	10/18/71	02/18/73	9.15E+06	8.76E+06	3.44E+06	5.73E+06	3.24E+06	5.78E+06	3.35E+06	
Quad-Cities 2	04/26/72	03/10/73			3.61E+06	3.77E+06	5.06E+06	3.15E+06	4.98E+06	
River Bend 1	10/31/85	06/16/86								
Shoreham 1	02/15/85									
Susquehanna 1	09/10/82	06/08/83					3.21E+05	3.54E+06	6.09E+06	
Susquehanna 2	05/08/84	02/12/85							9.32E+05	
Vermont Yankee 1	03/24/72	11/30/72	3.24E+06	3.45E+06	2.98E+06	3.57E+06	4.17E+06	2.87E+06	3.34E+06	
WNP-2	01/19/84	12/13/84							4.10E+05	
Total			1.00E+08	9.98E+07	9.16E+07	8.93E+07	9.02E+07	8.65E+07	8.88E+07	
* Fort St. Vrain 1	01/31/74	07/01/79	6.09E+05	1.24E+05	6.76E+05	7.55E+05	5.69E+05	7.48E+05	5.67E+04	

* High temperature gas cooled reactor

Table 13

**Net Electrical Energy Generation Comparison By Year
Megawatt Hours**

Boiling Water Reactors

Facility	Initial Criticality	Commercial Operation	1985	1986	1987	1988	1989	1990
Big Rock Point 1	09/27/62	03/29/63	3.62E+05	5.06E+05	3.75E+05	3.84E+05	4.17E+05	4.26E+05
Browns Ferry 1	08/17/73	08/01/74	1.54E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Browns Ferry 2	07/20/74	03/01/75	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Browns Ferry 3	08/08/76	03/01/77	1.47E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Brunswick 1	10/08/76	03/18/77	1.91E+06	5.97E+06	4.05E+06	4.45E+06	4.18E+06	4.32E+06
Brunswick 2	03/20/75	11/03/75	5.02E+06	2.91E+06	5.69E+06	3.92E+06	4.19E+06	4.05E+06
Clinton 1	02/27/87	11/24/87			6.84E+05	5.86E+06	2.86E+06	3.60E+06
Cooper	02/21/74	07/01/74	1.07E+06	4.05E+06	5.52E+06	4.20E+06	4.79E+06	5.11E+06
Dresden 1	10/15/59	07/04/60	0.00E+00	0.00E+00	0.00E+00			
Dresden 2	01/07/70	06/09/70	3.09E+06	4.65E+06	3.34E+06	4.32E+06	4.75E+06	4.08E+06
Dresden 3	01/31/71	11/16/71	4.39E+06	1.48E+06	4.40E+06	4.16E+06	5.12E+06	5.14E+06
Duane Arnold	03/23/74	02/01/75	1.94E+06	3.01E+06	2.54E+06	3.14E+06	3.14E+06	3.01E+06
Fermi 2	06/21/85	01/23/86		0.00E+00	1.39E+06	4.06E+06	5.22E+06	7.10E+06
James A. Fitzpatrick	11/17/74	07/28/75	4.17E+06	6.02E+06	4.20E+06	4.36E+06	6.16E+06	4.60E+06
Grand Gulf 1	08/18/82	07/01/85	2.65E+06	4.10E+06	7.73E+06	9.59E+06	7.85E+06	7.40E+06
Edwin I. Hatch 1	09/12/74	12/31/75	4.76E+06	3.65E+06	5.08E+06	4.11E+06	6.48E+06	4.07E+06
Edwin I. Hatch 2	07/04/78	09/05/79	5.38E+06	3.62E+06	5.76E+06	4.25E+06	4.14E+06	6.53E+06
Hope Creek 1	06/28/86	12/20/86		1.03E+06	7.28E+06	6.99E+06	6.61E+06	4.07E+06
Humboldt Bay 3	02/16/63	08/ /63	0.00E+00	0.00E+00	0.00E+00			
LaCrosse	07/11/67	11/01/69	3.23E+05	1.57E+05				
LaSalle 1	06/21/82	01/01/84	4.81E+06	2.02E+06	4.08E+06	5.44E+06	6.16E+06	8.64E+06
LaSalle 2	03/10/84	10/19/84	3.43E+06	5.72E+06	4.54E+06	5.66E+06	6.50E+06	6.18E+06
Limerick 1	12/22/84	02/01/86	1.14E+06	6.85E+06	5.32E+06	6.67E+06	5.21E+06	5.62E+06
Limerick 2	08/12/89	01/08/90					1.06E+06	7.23E+06
Millstone 1	10/26/70	03/01/71	4.59E+06	5.25E+06	4.38E+06	5.54E+06	4.64E+06	5.09E+06
Monticello	12/10/70	06/30/71	4.29E+06	3.38E+06	3.53E+06	4.57E+06	2.65E+06	4.51E+06
Nine Mile Point 1	09/05/69	12/01/69	4.93E+06	3.15E+06	4.62E+06	0.00E+00	0.00E+00	1.28E+06
Nine Mile Point 2	05/23/87	04/05/88			2.61E+05	2.51E+06	4.25E+06	4.14E+06
Oyster Creek 1	05/03/69	12/01/69	3.75E+06	1.30E+06	3.11E+06	3.54E+06	2.40E+06	4.31E+06
Peach Bottom 2	09/16/73	07/05/74	2.33E+06	6.90E+06	1.55E+06	0.00E+00	3.86E+06	6.70E+06
Peach Bottom 3	08/07/74	12/23/74	3.28E+06	4.85E+06	1.46E+06	0.00E+00	1.89E+05	7.53E+06
Perry 1	06/06/86	11/18/87			8.28E+05	7.23E+06	5.32E+06	6.59E+06
Pilgrim 1	06/16/72	12/01/72	4.95E+06	1.03E+06	0.00E+00	0.00E+00	1.71E+06	4.24E+06
Quad-Cities 1	10/18/71	02/18/73	6.07E+06	4.42E+06	4.46E+06	5.66E+06	4.28E+06	5.33E+06
Quad-Cities 2	04/26/72	03/10/73	4.56E+06	4.72E+06	4.95E+06	4.18E+06	5.74E+06	4.35E+06
River Bend 1	10/31/85	08/16/86		3.00E+06	4.96E+06	7.25E+06	4.79E+06	5.59E+06
Shoreham 1	02/15/85							
Susquehanna 1	09/10/82	06/08/83	5.26E+06	5.83E+06	6.13E+06	8.41E+06	6.47E+06	6.44E+06
Susquehanna 2	05/08/84	02/12/85	6.95E+06	5.45E+06	8.60E+06	5.90E+06	6.77E+06	8.29E+06
Vermont Yankee 1	03/24/72	11/30/72	3.00E+06	2.06E+06	3.54E+06	4.11E+06	3.61E+06	3.62E+06
WNP-2	01/19/84	12/13/84	5.18E+06	5.18E+06	5.40E+06	6.00E+06	6.12E+06	5.74E+06
Total			1.07E+08	1.12E+08	1.30E+08	1.46E+08	1.48E+08	1.75E+08

* Fort St. Vrain 1 01/31/74 07/01/79 0.00E+00 5.20E+04 1.81E+05 6.60E+05

* High temperature gas cooled reactor

Table 14

Net Electrical Energy Generation Comparison By Year

		Megawatt Hours								
Pressurized Water Reactors		Initial	Commercial							
Facility	Criticality	Operation	1978	1979	1980	1981	1982	1983	1984	
Arkansas One 1	08/08/74	12/19/74	5.25E+06	3.32E+06	3.78E+06	4.90E+06	3.72E+06	3.22E+06	4.60E+06	
Arkansas One 2	12/05/78	03/26/80	3.98E+03	8.81E+05	3.65E+06	4.32E+06	3.81E+06	4.43E+06	6.20E+06	
Beaver Valley 1	05/10/76	10/01/76	2.48E+06	1.79E+06	3.01E+05	4.66E+06	2.69E+06	4.68E+06	4.75E+06	
Beaver Valley 2	08/04/87	11/17/87								
Braidwood 1	05/29/87	07/29/88								
Braidwood 2	03/08/88	10/17/88								
Byron 1	02/02/85	09/16/85								
Byron 2	01/09/87	08/21/87								
Callaway 1	10/02/84	12/19/84								3.23E+05
Calvert Cliffs 1	10/07/74	05/08/75	9.91E+06	9.68E+06	4.53E+06	6.11E+06	5.36E+06	5.57E+06	6.22E+06	
Calvert Cliffs 2	11/30/76	04/01/77			6.41E+06	5.42E+06	5.00E+06	6.11E+06	5.34E+06	
Catawba 1	01/07/85	06/29/85								
Catawba 2	05/08/86	08/19/86								
Comanche Peak 1	04/03/90	08/13/90								
Donald C. Cook 1	01/18/75	08/27/75	1.01E+07	1.16E+07	6.46E+06	6.78E+06	5.35E+06	5.29E+06	7.75E+06	
Donald C. Cook 2	03/10/78	07/01/78			6.70E+06	6.38E+06	7.00E+06	7.01E+06	5.36E+06	
Crystal River 3	01/14/77	03/13/77	2.59E+06	3.78E+06	3.35E+06	4.01E+06	4.92E+06	3.77E+06	6.48E+06	
Davis-Besse 1	08/12/77	07/31/78	2.61E+06	3.13E+06	2.09E+06	4.36E+06	3.22E+06	4.88E+06	4.29E+06	
Diablo Canyon 1	04/29/84	05/07/85								2.04E+05
Diablo Canyon 2	09/19/85	03/13/86								
Joseph M. Farley 1	08/09/77	12/01/77	5.92E+06	1.74E+06	4.60E+06	2.62E+06	5.22E+06	5.26E+06	5.43E+06	
Joseph M. Farley 2	05/05/81	07/30/81				2.92E+06	5.30E+06	5.98E+06	6.62E+06	
Fort Calhoun 1	08/06/73	06/20/74	2.85E+06	3.67E+06	2.01E+06	2.15E+06	3.48E+06	2.75E+06	2.33E+06	
R. E. Ginna	11/08/69	07/01/70	3.22E+06	2.96E+06	3.09E+06	3.32E+06	2.41E+06	3.04E+06	3.16E+06	
Haddam Neck	07/24/67	01/01/68	4.71E+06	4.12E+06	3.56E+06	4.06E+06	4.54E+06	3.78E+06	3.36E+06	
Harris 1	01/03/87	05/02/87								
Indian Point 1	08/02/62	10/ /62	4.37E+06	4.80E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
Indian Point 2	05/22/73	08/01/74			4.26E+06	3.06E+06	4.45E+06	5.90E+06	2.89E+06	
Indian Point 3	04/06/76	08/30/76	5.46E+06	4.79E+06	3.07E+06	3.03E+06	1.44E+06	6.07E+04	6.04E+06	
Kewaunee	03/07/74	06/16/74	3.89E+06	3.44E+06	3.63E+06	3.77E+06	3.82E+06	3.71E+06	3.81E+06	
Maine Yankee	10/23/72	12/28/72	5.35E+06	4.54E+06	4.40E+06	5.21E+06	4.52E+06	0.00E+00	5.13E+06	
McGuire 1	08/08/81	12/01/81				1.91E+04	4.30E+06	4.63E+06	6.42E+06	
McGuire 2	05/08/83	03/01/84						0.00E+00	6.56E+06	
Millstone 2	10/17/75	12/26/75	4.50E+06	4.36E+06	4.88E+06	6.09E+06	5.01E+06	2.45E+06	6.61E+06	
Millstone 3	01/23/86	04/23/86								
North Anna 1	04/05/78	06/06/78	3.66E+06	4.19E+06	5.63E+06	4.64E+06	2.40E+06	5.31E+06	3.78E+06	
North Anna 2	06/12/80	12/14/80			3.50E+05	5.65E+06	4.05E+06	5.80E+06	4.72E+06	
Oconee 1	04/19/73	07/15/73	1.59E+07	1.32E+07	5.12E+06	3.00E+06	5.15E+06	5.67E+06	6.17E+06	
Oconee 2	11/11/73	09/09/74			3.88E+06	5.19E+06	3.44E+06	5.14E+06	7.30E+06	
Oconee 3	09/05/74	12/16/74			5.22E+06	5.64E+06	2.12E+06	7.10E+06	5.35E+06	
Palisades	05/24/71	12/31/71	2.62E+06	3.43E+06	2.38E+06	3.46E+06	3.35E+06	3.77E+06	8.12E+05	
Palo Verde 1	05/25/85	02/13/86								
Palo Verde 2	04/18/86	09/19/86								
Palo Verde 3	10/25/87	01/08/88								
Point Beach 1	11/02/70	12/21/70	7.65E+06	6.77E+06	2.48E+06	2.61E+06	2.70E+06	2.38E+06	3.11E+06	
Point Beach 2	05/30/72	10/01/71			3.59E+06	3.72E+06	3.61E+06	3.02E+06	3.51E+06	
Prairie Island 1	12/01/73	12/16/73	7.73E+06	7.10E+06	3.11E+06	3.84E+06	3.92E+06	3.89E+06	4.16E+06	
Prairie Island 2	12/17/74	12/21/74			3.47E+06	3.09E+06	3.86E+06	3.72E+06	3.91E+06	
Rancho Seco 1	09/16/74	04/17/75	4.99E+06	5.71E+06	4.42E+06	2.83E+06	3.37E+06	2.85E+06	3.77E+06	
H. B. Robinson 2	09/20/70	03/07/71	3.98E+06	4.00E+06	3.21E+06	3.50E+06	2.25E+06	3.35E+06	1.90E+05	
Salem 1	12/11/76	06/30/77	4.53E+06	2.04E+06	5.68E+06	6.19E+06	4.09E+06	5.38E+06	2.13E+06	
Salem 2	08/08/80	10/13/81			0.00E+00	1.83E+06	7.94E+06	7.44E+05	3.20E+06	
San Onofre 1	06/14/67	01/01/68	2.68E+06	3.36E+06	8.17E+05	7.79E+05	5.10E+05	0.00E+00	2.67E+05	
San Onofre 2	07/26/82	08/08/83					1.26E+05	3.76E+06	5.27E+06	
San Onofre 3	08/29/83	04/01/84						9.97E+05	4.10E+06	
Seabrook 1	06/13/89	08/19/90								
Sequoyah 1	07/05/80	07/01/81			5.18E+05	2.53E+06	4.91E+06	7.34E+06	6.10E+06	
Sequoyah 2	11/05/81	06/01/82						6.69E+06	6.40E+06	
South Texas 1	03/08/88	08/25/88								
South Texas 2	03/12/89	06/19/89								

Table 14

Net Electrical Energy Generation Comparison By Year

Megawatt Hours									
Pressurized Water Reactors									
Facility	Initial Criticality	Commercial Operation	1978	1979	1980	1981	1982	1983	1984
St. Lucie 1	04/22/76	12/21/76	5.00E+06	4.88E+06	5.20E+06	4.95E+06	6.78E+06	1.07E+06	4.23E+06
St. Lucie 2	06/02/83	08/08/83						2.40E+06	5.56E+06
Summer 1	10/22/82	01/01/84					1.91E+05	4.33E+06	4.20E+06
Surry 1	07/01/72	12/22/72	1.01E+07	2.87E+06	2.47E+06	2.38E+06	5.48E+06	3.52E+06	3.33E+06
Surry 2	03/07/73	05/01/73			2.24E+06	5.15E+06	5.49E+06	4.09E+06	5.21E+06
Three Mile Island 1	06/05/74	09/02/74	5.67E+06	8.48E+05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Three Mile Island 2	03/28/78	12/30/78	5.77E+05	N/R	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Trojan	12/15/75	05/20/76	1.67E+06	5.27E+06	6.07E+06	6.42E+06	4.80E+06	4.08E+06	4.74E+06
Turkey Point 3	10/20/72	12/14/72	8.29E+06	6.71E+06	4.39E+06	9.12E+05	3.77E+06	4.33E+06	4.78E+06
Turkey Point 4	06/11/73	09/07/73			3.85E+06	4.50E+06	3.84E+06	2.97E+06	3.08E+06
Vogtle 1	03/09/87	05/31/87							
Vogtle 2	03/28/89	05/20/89							
Waterford 3	03/04/85	09/24/85							
Wolf Creek 1	05/22/85	09/03/85							
Yankee Rowe 1	08/19/60	07/01/61	1.19E+06	1.23E+06	2.92E+05	8.85E+05	8.82E+05	1.34E+06	1.03E+06
Zion 1	06/19/73	12/31/73	1.35E+07	1.03E+07	8.51E+06	6.19E+06	4.70E+06	4.02E+06	5.69E+06
Zion 2	12/24/73	09/17/74			5.28E+06	5.26E+06	5.16E+06	6.18E+06	5.99E+06
Total			1.73E+08	1.50E+08	1.57E+08	1.78E+08	1.84E+08	1.98E+08	2.32E+08

N/R = Not Reported

Table 14

Net Electrical Energy Generation Comparison By Year

Megawatt Hours								
Pressurized Water Reactors								
Facility	Initial Criticality	Commercial Operation	1985	1986	1987	1988	1989	1990
Arkansas One 1	08/06/74	12/19/74	5.19E+06	3.57E+06	4.76E+06	3.95E+06	3.37E+06	4.12E+06
Arkansas One 2	12/05/78	03/26/80	4.70E+06	5.31E+06	6.61E+06	4.95E+06	5.47E+06	7.13E+06
Beaver Valley 1	05/10/76	10/01/76	5.90E+06	4.78E+06	5.62E+06	4.98E+06	3.79E+06	6.17E+06
Beaver Valley 2	08/04/87	11/17/87			7.38E+05	6.48E+06	4.54E+06	4.29E+06
Braidwood 1	05/29/87	07/29/88			1.46E+06	3.42E+06	4.63E+06	8.26E+06
Braidwood 2	03/08/88	10/17/88				1.35E+06	7.14E+06	6.33E+06
Byron 1	02/02/85	09/16/85	1.01E+06	7.40E+06	5.33E+06	6.29E+06	8.95E+06	6.93E+06
Byron 2	01/09/87	08/21/87			1.97E+06	6.36E+06	6.06E+06	6.01E+06
Callaway 1	10/02/84	12/19/84	8.05E+06	7.20E+06	6.32E+06	8.94E+06	8.35E+06	8.01E+06
Calvert Cliffs 1	10/07/74	05/08/75	4.36E+06	5.83E+06	5.27E+06	5.16E+06	1.35E+06	1.34E+06
Calvert Cliffs 2	11/30/76	04/01/77	5.61E+06	7.01E+06	4.83E+06	6.60E+06	4.53E+06	0.00E+00
Catawba 1	01/07/85	06/29/85	3.44E+06	5.18E+06	6.38E+06	7.63E+06	7.76E+06	6.87E+06
Catawba 2	05/08/86	08/19/86		1.30E+06	7.17E+06	6.17E+06	6.51E+06	6.44E+06
Comanche Peak 1	04/03/90	08/13/90						2.51E+06
Donald C. Cook 1	01/18/75	08/27/75	2.12E+06	6.65E+06	5.03E+06	7.47E+06	5.43E+06	6.30E+06
Donald C. Cook 2	03/10/78	07/01/78	5.68E+06	4.34E+06	5.03E+06	2.32E+06	6.66E+06	4.81E+06
Crystal River 3	01/14/77	03/13/77	2.85E+06	2.65E+06	3.62E+06	5.77E+06	2.93E+06	4.14E+06
Davis-Besse 1	08/12/77	07/31/78	1.94E+06	3.49E+03	5.06E+06	1.16E+06	7.32E+06	4.16E+06
Diablo Canyon 1	04/29/84	05/07/85	5.23E+06	5.29E+06	8.28E+06	5.26E+06	7.20E+06	8.71E+06
Diablo Canyon 2	09/19/85	03/13/86	5.41E+06	6.55E+06	5.72E+06	6.23E+06	8.62E+06	7.56E+06
Joseph M. Farley 1	08/09/77	12/01/77	5.87E+06	5.73E+06	6.44E+06	5.91E+06	6.02E+06	6.91E+06
Joseph M. Farley 2	05/05/81	07/30/81	5.47E+06	5.96E+06	4.90E+06	7.17E+06	5.62E+06	5.25E+06
Fort Calhoun 1	08/06/73	06/20/74	3.07E+06	3.61E+06	3.06E+06	2.63E+06	3.30E+06	2.42E+06
R. E. Ginna	11/08/69	07/01/70	3.62E+06	3.61E+06	3.80E+06	3.53E+06	3.07E+06	3.45E+06
Haddam Neck	07/24/67	01/01/68	4.64E+06	2.13E+06	2.53E+06	3.31E+06	2.96E+06	1.15E+06
Harris 1	01/03/87	05/02/87			3.38E+06	5.33E+06	5.63E+06	6.34E+06
Indian Point 1	08/02/62	10/ /62	0.00E+00	0.00E+00	0.00E+00			
Indian Point 2	05/22/73	08/01/74	6.67E+06	3.81E+06	5.15E+06	6.06E+06	4.47E+06	5.21E+06
Indian Point 3	04/06/76	08/30/76	4.73E+06	5.53E+06	4.85E+06	6.71E+06	4.97E+06	5.03E+06
Kewaunee	03/07/74	06/16/74	3.70E+06	3.85E+06	4.01E+06	3.91E+06	3.74E+06	3.90E+06
Maine Yankee	10/23/72	12/28/72	5.35E+06	6.24E+06	4.04E+06	5.02E+06	6.94E+06	4.86E+06
McGuire 1	08/08/81	12/01/81	6.78E+06	5.16E+06	7.35E+06	7.39E+06	7.80E+06	4.73E+06
McGuire 2	05/08/83	03/01/84	5.60E+06	6.21E+06	7.57E+06	8.05E+06	7.41E+06	6.46E+06
Millstone 2	10/17/75	12/26/75	3.50E+06	5.16E+06	6.89E+06	5.73E+06	4.89E+06	5.30E+06
Millstone 3	01/23/86	04/23/86		5.86E+06	6.74E+06	7.67E+06	7.08E+06	8.22E+06
North Anna 1	04/05/78	06/06/78	5.80E+06	6.31E+06	3.57E+06	6.90E+06	4.30E+06	7.23E+06
North Anna 2	06/12/80	12/14/80	6.81E+06	6.02E+06	5.65E+06	7.88E+06	5.90E+06	5.98E+06
Oconee 1	04/19/73	07/15/73	7.07E+06	4.78E+06	5.03E+06	7.19E+06	5.94E+06	6.45E+06
Oconee 2	11/11/73	09/09/74	5.06E+06	5.80E+06	6.23E+06	5.54E+06	6.01E+06	6.27E+06
Oconee 3	09/05/74	12/16/74	4.86E+06	6.06E+06	5.08E+06	5.97E+06	6.34E+06	7.43E+06
Palisades	05/24/71	12/31/71	5.30E+06	8.41E+05	2.63E+06	3.44E+06	3.64E+06	3.01E+06
Palo Verde 1	05/25/85	02/13/86	1.13E+06	5.85E+06	5.27E+06	6.67E+06	1.80E+06	4.72E+06
Palo Verde 2	04/18/86	09/19/86		2.65E+06	8.19E+06	6.75E+06	4.70E+06	6.24E+06
Palo Verde 3	10/25/87	01/08/88			3.20E+05	3.55E+04	1.33E+06	9.64E+06
Point Beach 1	11/02/70	12/21/70	3.35E+06	3.77E+06	3.57E+06	3.83E+06	3.61E+06	3.53E+06
Point Beach 2	05/30/72	10/01/71	3.60E+06	3.42E+06	3.61E+06	3.72E+06	3.49E+06	3.79E+06
Prairie Island 1	12/01/73	12/16/73	3.68E+06	3.82E+06	3.59E+06	3.82E+06	4.39E+06	3.83E+06
Prairie Island 2	12/17/74	12/21/74	3.61E+06	3.86E+06	4.43E+06	3.89E+06	3.89E+06	3.80E+06
Rancho Seco 1	09/16/74	04/17/75	1.94E+06	0.00E+00	0.00E+00	2.81E+06	1.41E+06	0.00E+00
H. B. Robinson 2	09/20/70	03/07/71	5.24E+06	4.80E+06	4.23E+06	3.18E+06	2.78E+06	3.31E+06
Salem 1	12/11/76	06/30/77	9.01E+06	7.08E+06	6.21E+06	7.41E+06	6.21E+06	5.96E+06
Salem 2	08/08/80	10/13/81	5.02E+06	5.31E+06	6.17E+06	5.97E+06	7.82E+06	5.41E+06
San Onofre 1	06/14/67	01/01/68	2.46E+06	8.74E+05	2.71E+06	1.37E+06	1.17E+06	1.54E+06
San Onofre 2	07/26/82	08/08/83	5.15E+06	6.36E+06	6.23E+06	9.00E+06	5.22E+06	8.31E+06
San Onofre 3	08/29/83	04/01/84	3.71E+06	6.76E+06	7.52E+06	6.13E+06	8.84E+06	6.58E+06
Seabrook 1	06/13/89	08/19/90						4.09E+06
Sequoyah 1	07/05/80	07/01/81	4.06E+06	0.00E+00	0.00E+00	6.71E+04	9.55E+06	6.82E+06
Sequoyah 2	11/05/81	06/01/82	5.61E+06	0.00E+00	0.00E+00	3.88E+06	9.55E+06	7.18E+06
South Texas 1	03/08/88	08/25/88				2.79E+06	6.28E+06	6.00E+06
South Texas 2	03/12/89	06/19/89					3.02E+06	6.43E+06

Table 14

Net Electrical Energy Generation Comparison By Year

Pressurized Water Reactors								
Facility	Initial	Commercial	Megawatt Hours					
	Criticality	Operation	1985	1986	1987	1988	1989	1990
St. Lucie 1	04/22/76	12/21/76	5.87E+06	7.05E+06	5.72E+06	6.25E+06	6.95E+06	4.49E+06
St. Lucie 2	06/02/83	08/08/83	6.11E+06	6.15E+06	5.95E+06	7.41E+06	5.44E+06	5.32E+06
Summer 1	10/22/82	01/01/84	5.23E+06	7.16E+06	5.15E+06	5.05E+06	5.41E+06	6.11E+06
Surry 1	07/01/72	12/22/72	5.62E+06	4.49E+06	4.63E+06	2.69E+06	3.17E+06	4.77E+06
Surry 2	03/07/73	05/01/73	4.07E+06	4.50E+06	4.79E+06	3.57E+06	8.94E+05	5.84E+06
Three Mile Island 1	06/05/74	09/02/74	8.12E+05	4.82E+06	5.03E+06	5.47E+06	7.22E+06	5.30E+06
Three Mile Island 2	03/28/78	12/30/78	0.00E+00	0.00E+00	0.00E+00			
Trojan	12/15/75	05/20/76	6.91E+06	7.09E+06	4.35E+06	6.34E+06	5.53E+06	6.07E+06
Turkey Point 3	10/20/72	12/14/72	3.41E+06	4.51E+06	8.56E+05	3.45E+06	3.59E+06	3.36E+06
Turkey Point 4	06/11/73	09/07/73	5.18E+06	1.72E+06	2.64E+06	3.26E+06	2.09E+06	4.38E+06
Vogtle 1	03/09/87	05/31/87			3.92E+06	6.79E+06	8.71E+06	7.34E+06
Vogtle 2	03/28/89	05/20/89					5.55E+06	6.85E+06
Waterford 3	03/04/85	09/24/85	1.81E+06	7.30E+06	7.43E+06	6.54E+06	7.61E+06	8.60E+06
Wolf Creek 1	05/22/85	09/03/85	2.94E+06	6.97E+06	6.50E+06	6.66E+06	9.71E+06	7.87E+06
Yankee Rowe 1	08/19/60	07/01/61	1.18E+06	1.39E+06	1.14E+06	1.12E+06	1.31E+06	8.26E+05
Zion 1	06/19/73	12/31/73	4.81E+06	4.90E+06	6.06E+06	6.34E+06	5.00E+06	4.45E+06
Zion 2	12/24/73	09/17/74	5.11E+06	7.33E+06	5.11E+06	6.65E+06	7.69E+06	2.65E+06
Total			2.72E+08	2.96E+08	3.19E+08	3.65E+08	3.88E+08	3.97E+08

Table 15

Thermal Energy Generation Comparison By Year

		Megawatt Hours							
Boiling Water Reactors		Initial	Commercial						
Facility	Criticality	Operation	1972	1973	1974	1975	1976	1977	1978
Big Rock Point 1	09/27/62	03/29/63	1.20E+06	1.41E+06	1.13E+06	9.80E+05	8.30E+05	1.23E+06	1.37E+06
Browns Ferry 1	08/17/73	08/01/74		1.37E+06	1.64E+07	8.75E+06	1.34E+07	5.37E+07	5.32E+07
Browns Ferry 2	07/20/74	03/01/75							
Browns Ferry 3	08/08/76	03/01/77							
Brunswick 1	10/08/76	03/18/77				4.72E+06	7.81E+06	1.59E+07	3.07E+07
Brunswick 2	03/20/75	11/03/75							
Clinton 1	02/27/87	11/24/87							
Cooper	02/21/74	07/01/74			6.90E+06	1.24E+07	1.19E+07	1.45E+07	1.54E+07
Dresden 1	10/15/59	07/04/60	3.76E+06	2.43E+06	1.36E+06	2.56E+06	3.42E+06	2.21E+06	2.73E+06
Dresden 2	01/07/70	06/09/70	2.52E+07	2.83E+07	2.18E+07	1.70E+07	2.74E+07	2.89E+07	3.13E+07
Dresden 3	01/31/71	11/16/71							
Duane Arnold	03/23/74	02/01/75				7.42E+06	8.02E+06	9.32E+06	3.96E+06
Fermi 2	06/21/85	01/23/86							
James A. Fitzpatrick	11/17/74	07/28/75				6.81E+06	1.26E+07	1.18E+07	1.30E+07
Grand Gulf 1	08/18/82	07/01/85							
Edwin I. Hatch 1	09/12/74	12/31/75				9.75E+06	1.38E+07	1.22E+07	3.37E+07
Edwin I. Hatch 2	07/04/78	09/05/79							
Hope Creek 1	06/28/86	12/20/86							
Humboldt Bay 3	02/16/63	08/ / 63	1.25E+06	1.47E+06	1.27E+06	1.32E+06	6.80E+05	0.00E+00	0.00E+00
LaCrosse	07/11/67	11/01/69	8.20E+05	6.90E+05	1.08E+06	9.20E+05	6.10E+05	3.43E+05	6.54E+05
LaSalle 1	06/21/82	01/01/84							
LaSalle 2	03/10/84	10/19/84							
Limerick 1	12/22/84	02/01/86							
Limerick 2	08/12/89	01/08/90							
Millstone 1	10/26/70	03/01/71	9.69E+06	5.96E+06	1.12E+07	1.21E+07	1.16E+07	1.48E+07	1.43E+07
Monticello	12/10/70	06/30/71	1.10E+07	9.90E+06	8.28E+06	8.88E+06	1.23E+07	1.10E+07	1.18E+07
Nine Mile Point 1	09/05/69	12/01/69	1.00E+07	1.10E+07	1.05E+07	9.68E+06	1.31E+07	9.15E+06	1.39E+07
Nine Mile Point 2	05/23/87	04/05/88							
Oyster Creek 1	05/03/69	12/01/69	1.30E+07	1.09E+07	1.13E+07	9.81E+06	1.18E+07	9.82E+06	1.10E+07
Peach Bottom 2	09/16/73	07/05/74			1.23E+07	3.34E+07	3.72E+07	2.86E+07	4.39E+07
Peach Bottom 3	08/07/74	12/23/74							
Perry 1	06/06/86	11/18/87							
Pilgrim 1	06/16/72	12/01/72	2.65E+06	1.25E+07	6.00E+06	8.10E+06	7.60E+06	8.26E+06	1.33E+07
Quad-Cities 1	10/18/71	02/18/73	1.25E+07	3.17E+07	2.61E+07	2.31E+07	2.59E+07	2.68E+07	3.14E+07
Quad-Cities 2	04/26/72	03/10/73							
River Bend 1	10/31/85	06/16/86							
Shoreham 1	02/15/85								
Susquehanna 1	09/10/82	06/08/83							
Susquehanna 2	05/08/84	02/12/85							
Vermont Yankee 1	03/24/72	11/30/72	1.48E+06	6.08E+06	8.20E+06	1.13E+07	1.02E+07	1.11E+07	1.00E+07
WNP-2	01/19/84	12/13/84							
Total			9.26E+07	1.24E+08	1.44E+08	1.89E+08	2.30E+08	2.70E+08	3.36E+08
* Fort St. Vrain 1	01/31/74	07/01/79							2.04E+06

* High temperature gas cooled reactor

Table 15

Thermal Energy Generation Comparison By Year

Megawatt Hours									
Boiling Water Reactors									
Facility	Initial Criticality	Commercial Operation	1979	1980	1981	1982	1983	1984	1985
Big Rock Point 1	09/27/62	03/29/63	3.96E+05	1.40E+06	1.63E+06	1.20E+06	1.14E+06	1.37E+06	1.19E+06
Browns Ferry 1	08/17/73	08/01/74	6.31E+07	1.92E+07	1.36E+07	2.49E+07	6.78E+06	2.45E+07	4.95E+06
Browns Ferry 2	07/20/74	03/01/75		1.74E+07	2.31E+07	1.38E+07	1.97E+07	1.31E+07	0.00E+00
Browns Ferry 3	08/08/76	03/01/77		2.13E+07	1.95E+07	1.55E+07	1.70E+07	9.11E+05	4.65E+06
Brunswick 1	10/08/76	03/18/77	2.12E+07	1.23E+07	8.29E+06	9.48E+06	4.53E+06	1.56E+07	6.06E+06
Brunswick 2	03/20/75	11/03/75		5.38E+06	1.04E+07	6.30E+06	1.23E+07	4.53E+06	1.57E+07
Clinton 1	02/27/87	11/24/87							
Cooper	02/21/74	07/01/74	1.58E+07	1.36E+07	1.39E+07	1.64E+07	1.05E+07	1.09E+07	3.42E+06
Dresden 1	10/15/59	07/04/60	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.46E+07	0.00E+00
Dresden 2	01/07/70	06/09/70	2.77E+07	1.57E+07	1.13E+07	1.69E+07	1.13E+07	7.10E+06	1.03E+07
Dresden 3	01/31/71	11/16/71		1.42E+07	1.71E+07	1.27E+07	1.37E+07	7.10E+06	1.47E+07
Duane Arnold	03/23/74	02/01/75	9.07E+06	8.87E+06	7.05E+06	7.32E+06	1.38E+06	8.71E+06	6.15E+06
Fermi 2	06/21/85	01/23/86							
James A. Fitzpatrick	11/17/74	07/28/75	8.97E+06	1.30E+07	1.42E+07	1.51E+07	1.42E+07	1.52E+07	1.28E+07
Grand Gulf 1	08/18/82	07/01/85					0.00E+00	8.80E+05	9.80E+06
Edwin I. Hatch 1	09/12/74	12/31/75	1.62E+07	1.54E+07	8.97E+06	9.42E+06	1.29E+07	1.20E+07	1.53E+07
Edwin I. Hatch 2	07/04/78	09/05/79		1.16E+07	1.47E+07	1.18E+07	1.19E+07	5.99E+06	1.70E+07
Hope Creek 1	06/28/86	12/20/86							
Humboldt Bay 3	02/16/63	08/ /63	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
LaCrosse	07/11/67	11/01/69	7.48E+05	8.00E+05	9.11E+05	5.27E+05	7.60E+05	1.07E+06	1.11E+06
LaSalle 1	06/21/82	01/01/84				2.09E+06	5.86E+06	2.30E+07	1.54E+07
LaSalle 2	03/10/84	10/19/84						4.51E+06	1.10E+07
Limerick 1	12/22/84	02/01/86						0.00E+00	4.42E+06
Limerick 2	08/12/89	01/08/90							
Millstone 1	10/26/70	03/01/71	1.30E+07	1.04E+07	8.60E+06	1.36E+07	1.64E+07	1.34E+07	1.42E+07
Monticello	12/10/70	06/30/71	1.35E+07	1.07E+07	1.01E+07	7.68E+06	1.30E+07	8.98E+05	1.31E+07
Nine Mile Point 1	09/05/69	12/01/69	9.67E+06	1.41E+07	1.01E+07	3.42E+06	8.72E+06	1.12E+07	1.52E+07
Nine Mile Point 2	05/23/87	04/05/88							
Oyster Creek 1	05/03/69	12/01/69	1.38E+07	6.27E+06	8.44E+06	6.79E+06	9.23E+05	1.04E+06	1.16E+07
Peach Bottom 2	09/16/73	07/05/74	4.58E+07	1.37E+07	2.08E+07	1.53E+07	1.40E+07	7.87E+06	7.85E+06
Peach Bottom 3	08/07/74	12/23/74		2.26E+07	9.85E+06	2.65E+07	7.82E+06	2.32E+07	1.08E+07
Perry 1	06/06/86	11/18/87							
Pilgrim 1	06/16/72	12/01/72	1.47E+07	9.20E+06	1.05E+07	9.90E+06	1.42E+07	4.99E+05	1.50E+07
Quad-Cities 1	10/18/71	02/18/73	3.00E+07	1.17E+07	1.88E+07	1.12E+07	1.89E+07	1.06E+07	1.92E+07
Quad-Cities 2	04/26/72	03/10/73		1.22E+07	1.27E+07	1.67E+07	1.08E+07	1.61E+07	1.46E+07
River Bend 1	10/31/85	06/16/86							
Shoreham 1	02/15/85								
Susquehanna 1	09/10/82	06/08/83				1.16E+06	1.12E+07	1.94E+07	1.70E+07
Susquehanna 2	05/08/84	02/12/85						3.23E+06	2.20E+07
Vermont Yankee 1	03/24/72	11/30/72	1.08E+07	9.38E+06	1.13E+07	1.31E+07	9.12E+06	1.04E+07	9.55E+06
WNP-2	01/19/84	12/13/84						1.21E+06	1.64E+07
Total			3.14E+08	2.90E+08	2.86E+08	2.89E+08	2.75E+08	2.90E+08	3.40E+08
* Fort St. Vrain 1	01/31/74	07/01/79	4.78E+05	2.23E+06	2.23E+06	1.86E+06	2.58E+06	3.40E+05	3.34E+04

* High temperature gas cooled reactor

Table 15

Thermal Energy Generation Comparison By Year

			Megawatt Hours				
Boiling Water Reactors							
	Initial	Commercial					
Facility	Criticality	Operation	1986	1987	1988	1989	1990
Big Rock Point 1	09/27/62	03/29/63	1.66E+06	1.23E+06	1.26E+06	1.14E+07	1.40E+06
Browns Ferry 1	08/17/73	08/01/74	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Browns Ferry 2	07/20/74	03/01/75	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Browns Ferry 3	08/08/76	03/01/77	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Brunswick 1	10/08/76	03/18/77	1.89E+07	1.29E+07	1.43E+07	1.32E+07	1.37E+07
Brunswick 2	03/20/75	11/03/75	9.43E+06	1.83E+07	1.24E+07	1.34E+07	1.30E+07
Clinton 1	02/27/87	11/24/87		2.15E+06	1.86E+07	9.26E+06	1.15E+07
Cooper	02/21/74	07/01/74	1.26E+07	1.72E+07	1.31E+07	1.50E+07	1.59E+07
Dresden 1	10/15/59	07/04/60	0.00E+00	0.00E+00			
Dresden 2	01/07/70	06/09/70	1.52E+07	1.11E+07	1.45E+07	1.56E+07	1.35E+07
Dresden 3	01/31/71	11/16/71	5.04E+06	1.46E+07	1.36E+07	1.67E+07	1.67E+07
Duane Arnold	03/23/74	02/01/75	9.48E+06	7.96E+06	9.97E+06	1.00E+07	9.64E+06
Fermi 2	06/21/85	01/23/86	2.23E+05	5.99E+06	1.30E+07	1.63E+07	2.25E+07
James A. Fitzpatrick	11/17/74	07/28/75	1.84E+07	1.31E+07	1.34E+07	1.88E+07	1.42E+07
Grand Gulf 1	08/18/82	07/01/85	1.47E+07	2.55E+07	3.05E+07	2.51E+07	2.43E+07
Edwin I. Hatch 1	09/12/74	12/31/75	1.18E+07	1.65E+07	1.35E+07	2.09E+07	1.35E+07
Edwin I. Hatch 2	07/04/78	09/05/79	1.19E+07	1.83E+07	1.36E+07	1.35E+07	2.08E+07
Hope Creek 1	06/28/86	12/20/86	3.62E+06	2.29E+07	2.22E+07	2.10E+07	1.35E+07
Humboldt Bay 3	02/16/63	08/ / 63	0.00E+00	0.00E+00			
LaCrosse	07/11/67	11/01/69	5.58E+05				
LaSalle 1	06/21/82	01/01/84	6.54E+06	1.31E+07	1.69E+07	1.91E+07	2.64E+07
LaSalle 2	03/10/84	10/19/84	1.80E+07	1.43E+07	1.81E+07	2.04E+07	1.91E+07
Limerick 1	12/22/84	02/01/86	2.16E+07	1.73E+07	2.19E+07	1.71E+07	1.82E+07
Limerick 2	08/12/89	01/08/90				3.54E+06	2.29E+07
Millstone 1	10/26/70	03/01/71	1.61E+07	1.34E+07	1.70E+07	1.42E+07	1.56E+07
Monticello	12/10/70	06/30/71	1.04E+07	1.10E+07	1.43E+07	8.48E+06	1.40E+07
Nine Mile Point 1	09/05/69	12/01/69	9.76E+06	1.42E+07	0.00E+00	0.00E+00	4.07E+06
Nine Mile Point 2	05/23/87	04/05/88		1.53E+06	8.32E+06	1.41E+07	1.34E+07
Oyster Creek 1	05/03/69	12/01/69	4.12E+06	9.69E+06	1.09E+07	7.75E+06	1.36E+07
Peach Bottom 2	09/16/73	07/05/74	2.16E+07	4.98E+06	0.00E+00	1.25E+07	2.11E+07
Peach Bottom 3	08/07/74	12/23/74	1.55E+07	4.76E+06	0.00E+00	8.84E+05	2.37E+07
Perry 1	06/06/86	11/18/87		2.56E+06	2.23E+07	1.62E+07	2.00E+07
Pilgrim 1	06/16/72	12/01/72	3.09E+06	0.00E+00	0.00E+00	5.48E+06	1.29E+07
Quad-Cities 1	10/18/71	02/18/73	1.41E+07	1.42E+07	1.83E+07	1.40E+07	1.70E+07
Quad-Cities 2	04/26/72	03/10/73	1.52E+07	1.60E+07	1.36E+07	1.85E+07	1.38E+07
River Bend 1	10/31/85	06/16/86	9.85E+06	1.55E+07	2.25E+07	1.53E+07	1.78E+07
Shoreham 1	02/15/85						
Susquehanna 1	09/10/82	06/08/83	1.87E+07	1.98E+07	2.65E+07	2.05E+07	2.05E+07
Susquehanna 2	05/08/84	02/12/85	1.74E+07	2.72E+07	1.87E+07	2.14E+07	2.63E+07
Vermont Yankee 1	03/24/72	11/30/72	6.57E+06	1.11E+07	1.30E+07	1.13E+07	1.13E+07
WNP-2	01/19/84	12/13/84	1.61E+07	1.67E+07	1.87E+07	1.92E+07	1.80E+07
Total			3.58E+08	4.15E+08	4.65E+08	4.80E+08	5.54E+08
* Fort St. Vrain 1	01/31/74	07/01/79	3.70E+05	6.68E+05	1.95E+06		

* High temperature gas cooled reactor

Table 16

Thermal Energy Generation Comparison By Year

		Megawatt Hours							
Pressurized Water Reactors		Initial	Commercial						
Facility	Criticality	Operation	1972	1973	1974	1975	1976	1977	1978
Arkansas One 1	08/06/74	12/19/74			1.99E+06	1.54E+07	1.21E+07	1.64E+07	1.64E+07
Arkansas One 2	12/05/78	03/26/80							4.45E+04
Beaver Valley 1	05/10/76	10/01/76					1.97E+06	1.01E+07	8.80E+06
Beaver Valley 2	08/04/87	11/17/87							
Braidwood 1	05/29/87	07/29/88							
Braidwood 2	03/08/88	10/17/88							
Byron 1	02/02/85	09/16/85							
Byron 2	01/09/87	08/21/87							
Callaway 1	10/02/84	12/19/84							
Calvert Cliffs 1	10/07/74	05/08/75				1.40E+07	1.98E+07	2.97E+07	3.14E+07
Calvert Cliffs 2	11/30/76	04/01/77							
Catawba 1	01/07/85	06/29/85							
Catawba 2	05/08/86	08/19/86							
Comanche Peak 1	04/03/90	08/13/90							
Donald C. Cook 1	01/18/75	08/27/75				1.46E+07	2.15E+07	1.55E+07	3.29E+07
Donald C. Cook 2	03/10/78	07/01/78							
Crystal River 3	01/14/77	03/13/77						1.26E+07	7.97E+06
Davis-Besse 1	08/12/77	07/31/78						1.66E+06	8.52E+06
Diablo Canyon 1	04/29/84	05/07/85							
Diablo Canyon 2	08/19/85	03/13/86							
Joseph M. Farley 1	08/09/77	12/01/77							1.95E+07
Joseph M. Farley 2	05/05/81	07/30/81							
Fort Calhoun 1	08/06/73	06/20/74		2.03E+06	7.58E+06	6.71E+06	7.15E+06	9.40E+06	8.98E+06
R. E. Ginna	11/08/69	07/01/70	7.71E+06	1.08E+07	6.71E+06	9.71E+06	6.98E+06	1.11E+07	1.05E+07
Haddam Neck	07/24/67	01/01/68	1.38E+07	7.73E+06	1.42E+07	1.34E+07	1.30E+07	1.31E+07	1.51E+07
Harris 1	01/03/87	05/02/87							
Indian Point 1	08/02/62	10/ /62		1.47E+06	1.15E+07	1.64E+07	7.60E+06	3.50E+07	1.48E+07
Indian Point 2	05/22/73	08/01/74							
Indian Point 3	04/06/76	08/30/76							1.70E+07
Kewaunee	03/07/74	06/16/74			5.03E+06	1.08E+07	1.08E+07	1.11E+07	1.24E+07
Maine Yankee	10/23/72	12/28/72	1.44E+06	1.08E+07	1.14E+07	1.47E+07	1.94E+07	1.65E+07	1.69E+07
McGuire 1	08/08/81	12/01/81							
McGuire 2	05/08/83	03/01/84							
Millstone 2	10/17/75	12/26/75				6.40E+05	1.52E+07	1.42E+07	1.44E+07
Millstone 3	01/23/86	04/23/86							
North Anna 1	04/05/78	06/06/78							1.22E+07
North Anna 2	06/12/80	12/14/80							
Oconee 1	04/19/73	07/15/73		6.62E+06	1.70E+07	4.68E+07	3.97E+07	4.00E+07	4.84E+07
Oconee 2	11/11/73	09/09/74							
Oconee 3	09/05/74	12/16/74							
Palisades	05/24/71	12/31/71	5.91E+06	7.80E+06	4.00E+05	8.91E+06	9.66E+06	1.73E+07	9.44E+06
Palo Verde 1	05/25/85	02/13/86							
Palo Verde 2	04/19/86	09/19/86							
Palo Verde 3	10/25/87	01/08/88							
Point Beach 1	11/02/70	12/21/70	9.96E+06	1.84E+07	2.04E+07	2.09E+07	2.18E+07	2.23E+07	2.33E+07
Point Beach 2	05/30/72	10/01/71							
Prairie Island 1	12/01/73	12/16/73		1.28E+05	5.26E+06	2.25E+07	2.06E+07	2.46E+07	2.52E+07
Prairie Island 2	12/17/74	12/21/74							
Rancho Seco 1	09/16/74	04/17/75				4.11E+06	6.91E+06	1.81E+07	1.59E+07
H. B. Robinson 2	09/20/70	03/07/71	1.55E+07	1.25E+07	1.56E+07	1.36E+07	1.59E+07	1.43E+07	1.33E+07
Salem 1	12/11/76	06/30/77					5.00E+04	6.70E+06	1.43E+07
Salem 2	08/08/80	10/13/81							
San Onofre 1	06/14/67	01/01/68	8.53E+06	7.09E+06	9.73E+06	1.00E+07	7.75E+06	7.29E+06	8.54E+06
San Onofre 2	07/26/82	08/08/83							
San Onofre 3	08/29/83	04/01/84							
Seabrook 1	06/13/89	08/19/90							
Sequoyah 1	07/05/80	07/01/81							
Sequoyah 2	11/05/81	06/01/82							
South Texas 1	03/08/88	08/25/88							
South Texas 2	03/12/89	06/19/89							

Table 16

Thermal Energy Generation Comparison By Year

Pressurized Water Reactors									
Facility	Initial	Commercial	Megawatt Hours						
	Criticality	Operation	1972	1973	1974	1975	1976	1977	1978
St. Lucie 1	04/22/76	12/21/76					3.50E+05	1.75E+07	1.64E+07
St. Lucie 2	06/02/83	08/08/83							
Summer 1	10/22/82	01/01/84							
Surry 1	07/01/72	12/22/72	1.29E+06	2.26E+07	1.92E+07	2.90E+07	2.51E+07	3.10E+07	3.27E+07
Surry 2	03/07/73	05/01/73							
Three Mile Island 1	06/05/74	09/02/74			6.20E+06	1.76E+07	1.39E+07	1.76E+07	1.83E+07
Three Mile Island 2	03/28/78	12/30/78							3.16E+06
Trojan	12/15/75	05/20/76					7.54E+06	2.12E+07	5.63E+06
Turkey Point 3	10/20/72	12/14/72	2.90E+05	1.53E+07	2.55E+07	2.78E+07	2.68E+07	2.70E+07	2.81E+07
Turkey Point 4	06/11/73	09/07/73							
Vogtle 1	03/09/87	05/31/87							
Vogtle 2	03/28/89	05/20/89							
Waterford 3	03/04/85	09/24/85							
Wolf Creek 1	05/22/85	09/03/85							
Yankee Rowe 1	08/19/80	07/01/81	2.40E+06	3.57E+06	3.07E+06	4.02E+06	4.25E+06	3.52E+06	4.16E+06
Zion 1	06/19/73	12/31/73		2.73E+06	1.69E+07	3.28E+07	3.11E+07	3.66E+07	4.30E+07
Zion 2	12/24/73	09/17/74							
Total			6.68E+07	1.30E+08	1.98E+08	3.54E+08	3.67E+08	5.01E+08	5.58E+08

Table 16

Thermal Energy Generation Comparison By Year

Megawatt Hours									
Pressurized Water Reactors									
Facility	Initial Criticality	Commercial Operation	1979	1980	1981	1982	1983	1984	1985
Arkansas One 1	08/06/74	12/19/74	1.05E+07	1.29E+07	1.54E+07	1.22E+07	1.02E+07	1.44E+07	1.62E+07
Arkansas One 2	12/05/78	03/26/80	3.45E+06	1.18E+07	1.39E+07	1.25E+07	1.43E+07	1.95E+07	1.50E+07
Beaver Valley 1	05/10/76	10/01/76	6.11E+06	1.13E+06	1.55E+07	8.88E+06	1.51E+07	1.58E+07	1.96E+07
Beaver Valley 2	08/04/87	11/17/87							
Braidwood 1	05/29/87	07/29/88							
Braidwood 2	03/08/88	10/17/88							
Byron 1	02/02/85	09/16/85							3.34E+06
Byron 2	01/09/87	08/21/87							
Callaway 1	10/02/84	12/19/84						1.00E+06	2.49E+07
Calvert Cliffs 1	10/07/74	05/08/75	3.15E+07	1.52E+07	1.96E+07	1.68E+07	1.75E+07	1.96E+07	1.35E+07
Calvert Cliffs 2	11/30/76	04/01/77		2.05E+07	1.71E+07	1.62E+07	1.96E+07	1.69E+07	1.78E+07
Catawba 1	01/07/85	06/29/85							1.07E+07
Catawba 2	05/08/86	08/19/86							
Comanche Peak 1	04/03/90	08/13/90							
Donald C. Cook 1	01/18/75	08/27/75	3.68E+07	2.02E+07	2.11E+07	1.69E+07	1.68E+07	2.41E+07	6.83E+06
Donald C. Cook 2	03/10/78	07/01/78		2.14E+07	2.04E+07	2.22E+07	2.22E+07	1.70E+07	1.82E+07
Crystal River 3	01/14/77	03/13/77	1.17E+07	1.04E+07	1.27E+07	1.52E+07	1.14E+07	1.97E+07	1.17E+07
Davis-Besse 1	08/12/77	07/31/78	1.00E+07	6.71E+06	1.40E+07	1.03E+07	1.57E+07	1.39E+07	6.31E+06
Diablo Canyon 1	04/29/84	05/07/85						9.48E+05	1.66E+07
Diablo Canyon 2	08/19/85	03/13/86							2.12E+06
Joseph M. Farley 1	08/09/77	12/01/77	5.77E+06	1.54E+07	8.96E+06	1.75E+07	1.76E+07	1.78E+07	1.90E+07
Joseph M. Farley 2	05/05/81	07/30/81			9.47E+06	1.75E+07	1.99E+07	2.15E+07	1.74E+07
Fort Calhoun 1	08/06/73	06/20/74	1.16E+07	6.48E+06	6.98E+06	1.09E+07	9.14E+06	7.43E+06	9.56E+06
R. E. Ginna	11/08/69	07/01/70	9.35E+06	9.93E+06	1.07E+07	7.68E+06	9.67E+06	1.00E+07	1.14E+07
Haddam Neck	07/24/67	01/01/68	1.32E+07	1.14E+07	1.31E+07	1.45E+07	1.22E+07	1.08E+07	1.49E+07
Harris 1	01/03/87	05/02/87							
Indian Point 1	08/02/62	10/ /62	1.61E+07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Indian Point 2	05/22/73	08/01/74		1.50E+07	1.05E+07	1.51E+07	1.96E+07	1.17E+07	2.21E+07
Indian Point 3	04/06/76	08/30/76	1.57E+07	1.15E+07	1.14E+07	5.06E+06	2.82E+05	1.93E+07	1.51E+07
Kewaunee	03/07/74	06/16/74	1.09E+07	1.15E+07	1.21E+07	1.23E+07	1.19E+07	1.21E+07	1.16E+07
Maine Yankee	10/23/72	12/28/72	1.41E+07	1.41E+07	1.67E+07	1.47E+07	1.83E+07	1.62E+07	1.67E+07
McGuire 1	08/08/81	12/01/81			8.50E+04	1.34E+07	1.39E+07	1.94E+07	2.06E+07
McGuire 2	05/08/83	03/01/84					0.00E+00	1.94E+07	1.68E+07
Millstone 2	10/17/75	12/26/75	1.38E+07	1.55E+07	1.92E+07	1.60E+07	7.88E+06	2.14E+07	1.12E+07
Millstone 3	01/23/86	04/23/86							
North Anna 1	04/05/78	06/06/78	1.41E+07	1.89E+07	1.51E+07	7.95E+06	1.68E+07	1.18E+07	1.81E+07
North Anna 2	06/12/80	12/14/80		1.12E+06	1.77E+07	1.29E+07	1.87E+07	1.51E+07	2.16E+07
Oconee 1	04/19/73	07/15/73	4.37E+07	1.52E+07	9.00E+06	1.57E+07	1.72E+07	1.86E+07	2.14E+07
Oconee 2	11/11/73	09/09/74		1.20E+07	1.59E+07	1.06E+07	1.58E+07	2.23E+07	1.56E+07
Oconee 3	09/05/74	12/16/74		1.59E+07	1.72E+07	6.53E+06	2.14E+07	1.63E+07	1.49E+07
Palisades	05/24/71	12/31/71	1.20E+07	8.19E+06	1.17E+07	1.12E+07	1.27E+07	2.72E+06	1.75E+07
Palo Verde 1	05/25/85	02/13/86							4.39E+06
Palo Verde 2	04/18/86	09/19/86							
Palo Verde 3	10/25/87	01/08/88							
Point Beach 1	11/02/70	12/21/70	2.08E+07	8.09E+06	8.51E+06	8.60E+06	7.59E+06	9.41E+06	1.02E+07
Point Beach 2	05/30/72	10/01/71		1.11E+07	1.15E+07	1.13E+07	9.38E+06	1.09E+07	1.11E+07
Prairie Island 1	12/01/73	12/16/73	1.12E+08	1.06E+07	1.25E+07	1.27E+07	1.24E+07	1.33E+07	1.18E+07
Prairie Island 2	12/17/74	12/21/74		1.14E+07	1.01E+07	1.26E+07	1.19E+07	1.24E+07	1.15E+07
Rancho Seco 1	09/16/74	04/17/75	1.79E+07	1.39E+07	8.92E+06	1.09E+07	9.16E+06	1.21E+07	6.26E+06
H. B. Robinson 2	09/20/70	03/07/71	1.30E+07	1.07E+07	1.19E+07	7.67E+06	1.13E+07	7.84E+05	1.66E+07
Salem 1	12/11/76	06/30/77	6.60E+06	1.84E+07	2.02E+07	1.31E+07	1.67E+07	6.95E+06	2.77E+07
Salem 2	08/08/80	10/13/81		0.00E+00	5.1'E+06	2.54E+07	2.95E+06	1.03E+07	1.60E+07
San Onofre 1	06/14/67	01/01/68	1.05E+07	2.55E+06	2.59E+06	1.59E+06	0.00E+00	9.24E+05	8.12E+06
San Onofre 2	07/26/82	08/08/83				9.28E+05	1.23E+07	1.66E+07	1.65E+07
San Onofre 3	08/29/83	04/01/84					3.55E+06	1.29E+07	1.21E+07
Seabrook 1	06/13/89	08/19/90							
Sequoyah 1	07/05/80	07/01/81		1.67E+06	8.06E+06	1.52E+07	2.22E+07	1.92E+07	1.24E+07
Sequoyah 2	11/05/81	06/01/82					2.03E+07	1.96E+07	1.71E+07
South Texas 1	03/08/88	08/25/88							
South Texas 2	03/12/89	06/19/89							

Table 16

Thermal Energy Generation Comparison By Year

Pressurized Water Reactors									
Facility	Initial	Commercial	Megawatt Hours						
	Criticality	Operation	1979	1980	1981	1982	1983	1984	1985
St. Lucie 1	04/22/76	12/21/76	1.60E+07	1.70E+07	1.61E+07	2.18E+07	3.53E+06	1.35E+07	1.88E+07
St. Lucie 2	06/02/83	08/08/83					7.66E+06	1.77E+07	1.93E+07
Summer 1	10/22/82	01/01/84				7.95E+05	1.38E+07	1.33E+07	1.65E+07
Surry 1	07/01/72	12/22/72	9.32E+06	8.67E+06	7.94E+06	1.83E+07	1.22E+07	1.11E+07	1.79E+07
Surry 2	03/07/73	05/01/73		7.26E+06	1.68E+07	1.79E+07	1.35E+07	1.73E+07	1.33E+07
Three Mile Island 1	06/05/74	09/02/74	2.83E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.82E+06
Three Mile Island 2	03/28/78	12/30/78	N/R	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Trojan	12/15/75	05/20/76	1.70E+07	1.97E+07	2.10E+07	1.56E+07	1.34E+07	1.54E+07	2.25E+07
Turkey Point 3	10/20/72	12/14/72	2.28E+07	1.47E+07	3.03E+06	1.22E+07	1.41E+07	1.56E+07	1.11E+07
Turkey Point 4	06/11/73	09/07/73		1.32E+07	1.48E+07	1.27E+07	9.83E+06	1.04E+07	1.69E+07
Vogtle 1	03/09/87	05/31/87							
Vogtle 2	03/28/89	05/20/89							
Waterford 3	03/04/85	09/24/85							5.64E+06
Wolf Creek 1	05/22/85	09/03/85							8.87E+06
Yankee Rowe 1	08/19/60	07/01/61	4.17E+06	1.13E+06	3.83E+06	3.69E+06	4.69E+06	3.61E+06	4.19E+06
Zion 1	06/19/73	12/31/73	3.31E+07	2.22E+07	1.98E+07	1.52E+07	1.34E+07	1.83E+07	1.85E+07
Zion 2	12/24/73	09/17/74		1.75E+07	1.77E+07	1.71E+07	2.00E+07	1.92E+07	2.16E+07
Total			5.76E+08	5.12E+08	5.76E+08	5.96E+08	6.52E+08	7.37E+08	8.58E+08

N/R = Not Reported

Table 16

Thermal Energy Generation Comparison By Year

		Megawatt Hours					
Pressurized Water Reactors		Initial	Commercial				
Facility	Criticality	Operation	1986	1987	1988	1989	1990
Arkansas One 1	08/06/74	12/19/74	1.11E+07	1.51E+07	1.24E+07	1.07E+07	1.30E+07
Arkansas One 2	12/05/78	03/26/80	1.68E+07	2.10E+07	1.58E+07	1.76E+07	2.26E+07
Reaver Valley 1	05/10/76	10/01/76	1.55E+07	1.84E+07	1.64E+07	1.27E+07	2.02E+07
Beaver Valley 2	08/04/87	11/17/87		2.39E+06	2.13E+07	1.51E+07	1.43E+07
Braidwood 1	05/29/87	07/29/88		5.02E+06	1.04E+07	1.44E+07	2.48E+07
Braidwood 2	03/08/88	10/17/88			4.08E+06	2.18E+07	1.95E+07
Byron 1	02/02/85	09/16/85	2.32E+07	1.71E+07	1.99E+07	2.77E+07	2.16E+07
Byron 2	01/09/87	08/21/87		6.47E+06	2.04E+07	1.87E+07	1.87E+07
Callaway 1	10/02/84	12/19/84	2.26E+07	1.98E+07	2.76E+07	3.15E+07	2.45E+07
Calvert Cliffs 1	10/07/74	05/08/75	1.82E+07	1.65E+07	1.62E+07	4.23E+06	4.34E+06
Calvert Cliffs 2	11/30/76	04/01/77	2.18E+07	1.50E+07	2.07E+07	1.45E+06	0.00E+00
Catawba 1	01/07/85	06/29/85	1.59E+07	1.95E+07	2.29E+07	2.36E+07	2.08E+07
Catawba 2	05/08/86	08/19/86	4.04E+06	2.17E+07	1.88E+07	1.95E+07	1.93E+07
Comanche Peak 1	04/03/90	08/13/90					8.16E+06
Donald C. Cook 1	01/18/75	08/27/75	2.16E+07	1.64E+07	2.42E+07	1.74E+07	2.05E+07
Donald C. Cook 2	03/10/78	07/01/78	1.44E+07	1.65E+07	7.41E+06	2.13E+07	1.53E+07
Crystal River 3	01/14/77	03/13/77	8.14E+06	1.11E+07	1.78E+07	9.14E+06	1.28E+07
Davis-Besse 1	08/12/77	07/31/78	1.29E+05	1.65E+07	3.91E+06	2.35E+07	1.32E+07
Diablo Canyon 1	04/29/84	05/07/85	1.70E+07	2.54E+07	1.66E+07	2.25E+07	2.72E+07
Diablo Canyon 2	08/19/85	03/13/86	2.11E+07	1.82E+07	1.98E+07	2.69E+07	2.39E+07
Joseph M. Farley 1	08/09/77	12/01/77	1.85E+07	2.11E+07	1.92E+07	1.96E+07	2.25E+07
Joseph M. Farley 2	05/05/81	07/30/81	1.91E+07	1.60E+07	2.29E+07	1.81E+07	1.69E+07
Fort Calhoun 1	08/06/73	06/20/74	1.13E+07	9.48E+06	8.34E+06	1.07E+07	7.67E+06
R. E. Ginna	11/08/69	07/01/70	1.13E+07	1.19E+07	1.10E+07	9.65E+06	1.07E+07
Haddam Neck	07/24/67	01/01/68	7.26E+06	8.39E+06	1.06E+07	9.47E+06	3.81E+06
Harris 1	01/03/87	05/02/87		1.12E+07	1.71E+07	1.83E+07	2.05E+07
Indian Point 1	08/02/62	10/ /62	0.00E+00	0.00E+00			
Indian Point 2	05/22/73	08/01/74	1.29E+07	1.71E+07	1.95E+07	1.45E+07	1.66E+07
Indian Point 3	04/06/76	08/30/76	1.77E+07	1.58E+07	2.14E+07	1.55E+07	1.57E+07
Kewaunee	03/07/74	06/16/74	1.21E+07	1.26E+07	1.22E+07	1.18E+07	1.24E+07
Maine Yankee	10/23/72	12/28/72	1.93E+07	1.31E+07	1.67E+07	2.11E+07	1.50E+07
McGuire 1	08/08/81	12/01/81	1.56E+07	2.21E+07	2.26E+07	2.38E+07	1.48E+07
McGuire 2	05/08/83	03/01/84	1.96E+07	2.25E+07	2.41E+07	2.19E+07	1.93E+07
Millstone 2	10/17/75	12/26/75	1.66E+07	2.18E+07	1.81E+07	1.55E+07	1.69E+07
Millstone 3	01/23/86	04/23/86	2.17E+07	2.05E+07	2.33E+07	2.17E+07	2.52E+07
North Anna 1	04/05/78	06/06/78	1.98E+07	1.14E+07	2.20E+07	1.37E+07	2.31E+07
North Anna 2	06/12/80	12/14/80	1.92E+07	1.80E+07	2.50E+07	1.88E+07	1.91E+07
Oconee 1	04/19/73	07/15/73	1.46E+07	1.56E+07	2.21E+07	1.82E+07	1.96E+07
Oconee 2	11/11/73	09/09/74	1.79E+07	1.93E+07	1.72E+07	1.84E+07	1.90E+07
Oconee 3	09/05/74	12/16/74	1.88E+07	1.55E+07	1.80E+07	1.94E+07	2.23E+07
Palisades	05/24/71	12/31/71	2.76E+06	8.83E+06	1.14E+07	1.21E+07	1.01E+07
Palo Verde 1	05/25/85	02/13/86	1.82E+07	1.61E+07	2.03E+07	5.57E+06	1.45E+07
Palo Verde 2	04/18/86	09/19/86	7.02E+06	2.49E+07	2.07E+07	1.47E+07	1.91E+07
Palo Verde 3	10/25/87	01/08/88		1.24E+06	3.03E+07	4.10E+06	2.92E+07
Point Beach 1	11/02/70	12/21/70	1.15E+07	1.09E+07	1.17E+07	1.11E+07	1.09E+07
Point Beach 2	05/30/72	10/01/71	1.06E+07	1.11E+07	1.14E+07	1.06E+07	1.16E+07
Prairie Island 1	12/01/73	12/16/73	1.22E+07	1.14E+07	1.23E+07	1.40E+07	1.23E+07
Prairie Island 2	12/17/74	12/21/74	1.23E+07	1.41E+07	1.26E+07	1.25E+07	1.22E+07
Rancho Seco 1	09/16/74	04/17/75	0.00E+00	0.00E+00	9.47E+06	4.62E+06	0.00E+00
H. B. Robinson 2	09/20/70	03/07/71	1.52E+07	1.35E+07	1.06E+07	8.66E+06	1.08E+07
Salem 1	12/11/76	06/30/77	2.24E+07	1.96E+07	2.32E+07	1.97E+07	1.90E+07
Salem 2	08/08/80	10/13/81	1.74E+07	1.96E+07	1.90E+07	2.44E+07	1.69E+07
San Onofre 1	06/14/67	01/01/68	3.00E+06	8.82E+06	4.52E+06	3.92E+06	5.04E+06
San Onofre 2	07/26/82	08/08/83	2.01E+07	1.93E+07	2.75E+07	1.63E+07	2.55E+07
San Onofre 3	08/29/83	04/01/84	2.13E+07	2.32E+07	1.89E+07	2.73E+07	2.04E+07
Seabrook 1	06/13/89	08/19/90					1.26E+07
Sequoyah 1	07/05/80	07/01/81	0.00E+00	0.00E+00	5.16E+05	2.88E+07	2.10E+07
Sequoyah 2	11/05/81	06/01/82	0.00E+00	0.00E+00	1.26E+07	2.88E+07	2.19E+07
South Texas 1	03/08/88	08/25/88			8.81E+06	1.99E+07	1.90E+07
South Texas 1	03/12/89	06/19/89				9.52E+06	2.02E+07

Table 16

Thermal Energy Generation Comparison By Year

		Megawatt Hours					
Pressurized Water Reactors		Initial	Commercial				
Facility	Criticality	Operation	1986	1987	1988	1989	1990
St. Lucie 1	04/22/76	12/21/76	2.23E+07	1.81E+07	1.97E+07	2.19E+07	1.43E+07
St. Lucie 2	08/02/83	08/08/83	1.94E+07	1.90E+07	2.35E+07	1.73E+07	1.70E+07
Summer 1	10/22/82	01/01/84	2.26E+07	1.64E+07	1.61E+07	1.76E+07	1.93E+07
Surry 1	07/01/72	12/22/72	1.42E+07	1.47E+07	8.45E+06	9.95E+06	1.51E+07
Surry 2	03/07/73	05/01/73	1.45E+07	1.54E+07	1.16E+07	2.87E+06	1.85E+07
Three Mile Island 1	06/05/74	09/02/74	1.56E+07	1.56E+07	1.69E+07	2.22E+07	1.69E+07
Three Mile Island 2	03/28/78	12/30/78	0.00E+00	0.00E+00			
Trojan	12/15/75	05/20/76	2.29E+07	1.39E+07	1.98E+07	1.73E+07	1.90E+07
Turkey Point 3	10/20/72	12/14/72	1.46E+07	2.96E+06	1.14E+07	1.18E+07	1.12E+07
Turkey Point 4	06/11/73	09/07/73	5.73E+06	8.69E+06	1.08E+07	7.14E+06	1.44E+07
Vogtle 1	03/09/87	05/31/87		1.27E+07	2.18E+07	2.76E+07	2.32E+07
Vogtle 2	03/28/89	05/20/89				1.72E+07	2.17E+07
Waterford 3	03/04/85	09/24/85	2.27E+07	2.31E+07	2.08E+07	2.37E+07	2.69E+07
Wolf Creek 1	05/22/85	09/03/85	2.09E+07	1.97E+07	2.01E+07	2.88E+07	2.36E+07
Yankee Rowe 1	08/19/60	07/01/61	4.90E+06	4.03E+06	4.03E+06	4.66E+06	2.94E+06
Zion 1	06/19/73	12/31/73	1.58E+07	1.88E+07	1.97E+07	1.56E+07	1.41E+07
Zion 2	12/24/73	09/17/74	2.30E+07	1.61E+07	2.08E+07	2.40E+07	8.42E+06
Total			9.38E+08	1.01E+09	1.18E+09	1.21E+09	1.24E+09

APPENDIX A

Installation: Arkansas One
Unit No.(s): 1

Location: 6 Mi WNW Russellville, AR

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-313

Thermal Power(MWH): 1.30E+07

Commercial Operation: 12/19/74

Cooling Water Source: Dardanelle Reservoir

Licensee: Arkansas Power & Light

Licensed Power(MWT): 2.57E+03

Net Electrical Power(MWH): 4.12E+06

Initial Criticality: 08/06/74

Airborne Effluents

Nuclide Released	Activity (Ci)
CO-58	2.19E-06
CO-60	6.09E-06
KR-85	2.78E+01
KR-85M	7.71E-02
RB-88	1.99E+01
SR-89	2.30E-06
SR-90	2.87E-06
NB-97	9.13E-07
SB-122	5.91E-07
I-131	1.57E-04
XE-131M	6.42E+00
I-132	1.58E-06
I-133	1.15E-05
XE-133	6.50E+02
XE-133M	4.69E+00
CS-134	2.67E-06
XE-135	1.10E+01
CS-137	7.21E-04

Total Airborne Tritium Released 9.09E+00 Ci

Installation: Arkansas One
Unit No.(s): 1

Location: 6 Mi WNW Russellville, AR

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-313
Thermal Power(MWH): 1.30E+07
Commercial Operation: 12/19/74
Cooling Water Source: Dardanelle Reservoir

Licensee: Arkansas Power & Light
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 4.12E+06
Initial Criticality: 08/06/74

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	4.02E-03
K-40	9.32E-04
CR-51	1.42E-02
MN-54	1.75E-01
FE-55	1.42E-01
CO-57	1.46E-03
CO-58	1.25E+00
FE-59	4.90E-03
CO-60	7.88E-02
CU-64	2.25E-03
ZN-65	5.17E-04
SE-75	3.77E-05
KR-85	6.22E-02
RB-88	1.55E-04
SR-89	8.01E-03
SR-90	5.77E-04
SR-92	2.16E-03
Y-92	1.54E-04
NB-94	8.98E-05
NB-95	4.42E-03
ZR-95	2.58E-03
NB-97	3.28E-04
ZR-97	6.19E-05
MO-99	5.09E-04
TC-99M	8.18E-04
RU-103	7.82E-04
AG-110M	4.92E-02
SN-113	1.77E-04
SB-122	1.09E-04
SB-124	3.98E-03
SB-125	1.65E-01
SB-127	7.67E-05
I-131	1.74E-01
XE-131M	2.57E-01
I-133	3.30E-04
XE-133	1.02E+01
XE-133M	2.02E-02
CS-134	9.99E-02
I-135	4.83E-05
XE-135	3.00E-04
CS-136	6.04E-04
CS-137	1.59E-01
BA-140	3.82E-03
LA-140	9.71E-03

Total Liquid Tritium Released	2.67E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.31E+07 liters
Volume of Dilution Water Used During Period	8.15E+11 liters

Installation: Arkansas One
Unit No.(s): 2

Location: 6 Mi WNW Russellville, AR

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-368

Thermal Power(MWH): 2.26E+07

Commercial Operation: 03/26/80

Cooling Water Source: Dardanelle Reservoir

Licensee: Arkansas Power & Light

Licensed Power(MWT): 2.82E+03

Net Electrical Power(MWH): 7.13E+06

Initial Criticality: 12/05/78

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

K-40	8.53E-05
CO-58	3.81E-05
CO-60	6.41E-06
KR-85	9.15E-02
KR-85M	1.35E-01
SR-89	2.20E-06
NB-95	3.04E-06
NB-97	2.49E-06
AG-110M	1.22E-06
I-131	4.22E-05
XE-131M	3.38E-02
I-133	3.43E-06
XE-133	1.77E+02
XE-133M	5.03E-01
CS-134	6.99E-06
XE-135	1.19E+01
CS-137	2.03E-05
BI-214	1.12E-04
PB-214	1.22E-05

Total Airborne Tritium Released 3.82E+00 Ci

Installation: Arkansas One
Unit No.(s): 2

Location: 6 Mi WNW Russellville, AR

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-368

Thermal Power(MWH): 2.26E+07

Commercial Operation: 03/26/80

Cooling Water Source: Dardanelle Reservoir

Licensee: Arkansas Power & Light

Licensed Power(MWT): 2.82E+03

Net Electrical Power(MWH): 7.13E+06

Initial Criticality: 12/05/78

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	5.08E-05
K-40	3.04E-04
CR-51	3.37E-03
MN-54	3.30E-03
FE-55	3.36E-02
CO-57	2.60E-05
CO-58	3.76E-02
FE-59	4.70E-05
CO-60	1.52E-02
SR-89	7.27E-04
SR-90	1.86E-04
SR-92	1.57E-03
Y-92	8.95E-05
NB-95	1.22E-03
ZR-95	1.03E-03
NB-97	1.90E-04
ZR-97	1.48E-04
TC-99M	9.63E-05
RU-106	3.41E-05
AG-110M	1.77E-02
SB-122	2.21E-04
SB-124	2.61E-03
SB-125	4.49E-02
SB-127	2.96E-04
I-131	2.78E-03
XE-131M	4.63E-02
I-133	8.22E-04
XE-133	2.09E+00
XE-133M	6.37E-03
CS-134	2.10E-02
I-134	1.78E-05
XE-135	2.81E-03
CS-136	5.47E-06
CS-137	6.21E-02
CS-138	2.04E-04
LA-140	4.63E-04
RA-226	1.06E-05

Total Liquid Tritium Released

5.33E+02 Ci

Volume of Liquid Waste Released (Prior to Dilution)

9.32E+06 liters

Volume of Dilution Water Used During Period

8.18E+11 liters

Installation: Arkansas One
Unit No.(s): 1&2

Location: 6 Mi WNW Russellville, AR

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-313
Thermal Power(MWH): 1.30E+07
Commercial Operation: 12/19/74
Cooling Water Source: Dardanelle Reservoir

Licensee: Arkansas Power & Light
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 4.12E+06
Initial Criticality: 08/06/74

Unit Number: 2 Type: PWR
Docket Number: 50-368
Thermal Power(MWH): 2.26E+07
Commercial Operation: 03/26/80
Cooling Water Source: Dardanelle Reservoir

Licensee: Arkansas Power & Light
Licensed Power(MWT): 2.82E+03
Net Electrical Power(MWH): 7.13E+06
Initial Criticality: 12/05/78

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
22	Unshielded Van/Truck	Oak Ridge, TN
2	Unshielded Van/Truck	Wampum, PA

Irradiated Fuel Shipments (Disposition)

Number of Shipments	Mode of Transportation	Destination
1	Spent Fuel Cask	Chalk River, Canada

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-60		3.55E+00
CS-134		2.33E+01
CS-137		7.01E+01
I-131		1.42E+00
SB-124		9.20E-01
XE-131M		6.00E-02
B		
AG-110M	8.00E-01	1.10E-01
C-14	5.00E-01	1.00E+00
CO-58	2.55E+01	1.83E+01
CO-60	6.20E+00	6.62E+00
CR-51		8.00E-02
CS-134	5.10E+00	1.19E+01
CS-137	3.68E+01	3.96E+01
FE-55	1.19E+01	1.29E+01
NB-95	2.60E+00	
NI-63	8.60E+00	9.27E+00
TC-99		1.00E-01
ZR-95	2.00E+00	

Installation: Arkansas One
Unit No.(s): 1&2

Location: 6 Mi WNW Russellville, AR

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.13E+01 C1 1.32E-02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.58E+02 C1 1.42E+01	
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Beaver Valley
Unit No.(s): 1&2

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-334
Thermal Power(MWH): 2.02E+07
Commercial Operation: 10/01/76
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 6.17E+06
Initial Criticality: 05/10/76

Unit Number: 2 Type: PWR
Docket Number: 50-412
Thermal Power(MWH): 1.43E+07
Commercial Operation: 11/17/87
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 4.29E+06
Initial Criticality: 08/04/87

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.96E-04
CO-57	2.07E-07
CO-60	3.65E-06
KR-85	1.19E-01
KR-85M	3.31E-03
MO-99	6.65E-08
TC-99M	6.47E-08
I-131	4.62E-06
I-133	1.10E-06
XE-133	2.39E+00
XE-135	1.39E-01
CS-137	3.08E-06

Total Airborne Tritium Released 8.77E+01 Ci

Installation: Beaver Valley
Unit No.(s): 1&2

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-334
Thermal Power(MWH): 2.02E+07
Commercial Operation: 10/01/76
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 6.17E+06
Initial Criticality: 05/10/76

Unit Number: 2 Type: PWR
Docket Number: 50-412
Thermal Power(MWH): 1.43E+07
Commercial Operation: 11/17/87
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 4.29E+06
Initial Criticality: 08/04/87

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	3.13E-04
AR-41	9.37E-05
CR-51	8.04E-03
MN-54	4.05E-02
FE-55	4.34E-01
CO-57	4.47E-03
CO-58	1.73E+00
FE-59	4.98E-03
CO-60	2.59E-01
ZN-65	2.07E-04
SR-89	1.74E-04
SR-90	2.86E-06
ZR/NB-95	1.50E-03
NB-97	2.84E-03
AG-110M	7.84E-03
SB-124	5.21E-03
SB-125	4.63E-02
I-131	1.43E-05
XE-133	1.34E-03
CS-134	2.20E-04
XE-135	5.01E-04
CS-137	3.03E-03
BA/LA-140	3.68E-05

Total Liquid Tritium Released	4.91E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	7.73E+06 liters
Volume of Dilution Water Used During Period	5.80E+09 liters

Installation: Beaver Valley
Unit No.(s): 1

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-334
Thermal Power(MWH): 2.02E+07
Commercial Operation: 10/01/76
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 6.17E+06
Initial Criticality: 05/10/76

Airborne Effluents

Nuclide Released	Activity (Ci)
CO-57	1.13E-06
CO-58	4.88E-05
CO-60	2.34E-05
KR-85	3.54E+00
NB-95M	3.59E-06
MO-99	1.17E-06
TC-99M	1.14E-06
I-131	1.31E-04
I-133	1.89E-05
XE-133	1.15E+01
XE-133M	1.92E+01
XE-135	1.04E-01
CS-137	9.33E-06

Installation: Beaver Valley
Unit No.(s): 2

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-412
Thermal Power(MWH): 1.43E+07
Commercial Operation: 11/17/87
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 4.29E+06
Initial Criticality: 08/04/87

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	4.08E+00
CO-58	9.08E-05
KR-85	3.58E+00
SR-89	1.22E-07
SR-90	1.21E-06
I-131	2.95E-06
XE-131M	2.78E+00
XE-133	3.29E+01
XE-135	1.29E+00
BA-139	3.24E-04

Installation: Beaver Valley
Unit No.(s): 1&2

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-334
Thermal Power(MWH): 2.02E+07
Commercial Operation: 10/01/76
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 6.17E+06
Initial Criticality: 05/10/76

Unit Number: 2 Type: PWR
Docket Number: 50-412
Thermal Power(MWH): 1.43E+07
Commercial Operation: 11/17/87
Cooling Water Source: Ohio River

Licensee: Duquesne Light
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 4.29E+06
Initial Criticality: 08/04/87

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
6	Truck	Barnwell, SC
2	Truck	Beatty, NV
7	Truck	Oak Ridge, TN via Quadrex
8	Truck	Oak Ridge, TN via SEG
3	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M		5.74E-03
AM-241	3.68E-05	2.34E-04
C-14	4.75E-01	3.56E-02
CE-141		1.22E-04
CE-144/PR-144		5.01E-01
CM-242	6.49E-06	5.81E-05
CM-243/244	3.59E-05	2.35E-04
CO-57	4.94E-01	2.22E-01
CO-58	1.43E+01	5.53E+01
CO-60	3.33E+01	1.73E+01
CR-51		1.03E-02
CS-134		1.07E-01
CS-137	1.30E-01	7.78E-01
FE-55	8.49E+00	1.17E+01
FE-59		1.71E-01
H-3	1.24E+01	3.34E+00
I-129	1.67E-03	1.95E-04
MN-54	1.92E+00	2.32E+00
NB-94		8.95E-04
NB-95		9.45E-03
NI-59	1.38E-01	1.93E-02
NI-63	2.58E+01	6.84E+00
P-32		5.45E-01
PU-238	6.33E-05	5.31E-04
PU-239/240	4.70E-05	3.10E-04

Installation: Beaver Valley
Unit No.(s): 1&2

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

A

PU-241		5.01E-02
RU-103		7.92E-05
SB-124		1.72E-01
SB-125	2.59E+00	4.55E-01
SN-113		7.49E-05
SR-89	5.11E-04	2.28E-02
SR-90	6.05E-03	1.79E-03
TC-99	1.36E-03	1.97E-04
ZN-65		1.29E-02
ZR-95		1.07E-02

B

AG-110M	8.34E-01	1.27E-02
AM-241	6.67E-04	1.35E-03
BA-133		1.97E-03
C-14	1.29E+00	1.10E-01
CL-36		5.63E-06
CM-242	9.03E-04	7.76E-03
CM-243/244	3.89E-04	2.20E-03
CO-57	1.98E-01	2.46E-01
CO-58	3.98E+01	3.04E+01
CO-60	1.22E+01	3.34E+01
CR-51		4.38E+00
CS-134	2.54E+00	1.51E-01
CS-137	3.77E+00	6.46E-01
FE-55	9.26E+00	1.42E+00
FE-59	3.22E-02	1.01E+00
H-3	1.72E+01	9.31E-01
I-129	2.33E-01	7.73E-03
MN-54	8.79E-01	2.84E+00
NB-95	3.15E+00	3.20E+00
NI-59		7.36E+00
NI-63	3.71E+00	7.30E+00
P-32	7.89E-02	2.60E-02
PU-238		3.45E-03
PU-239/240	9.03E-04	2.27E-03
PU-241		3.66E-01
RU-103		7.71E-02
SB-124	2.92E+00	4.45E-02
SB-125	5.26E-02	4.33E-01
SN-113	4.44E-02	1.95E-01
SR-89	5.26E-03	1.69E-02
SR-90	2.92E-03	4.15E-04
TC-99	3.08E-01	5.17E-03
ZN-65		1.94E-01
ZR-95	1.57E+00	5.17E+00

Installation: Beaver Valley
Unit No.(s): 1&2

Location: Shippingport, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.03E+01 Ci 5.38E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 7.46E+02 m3 1.17E+02 Ci 5.85E+00	before volume reduction burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Big Rock Point
Unit No.(s): 1

Location: 4 Mi NE Charlevoix, MI

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-155
Thermal Power(MWH): 1.40E+06
Commercial Operation: 03/29/63
Cooling Water Source: Lake Michigan

Licensee: Consumers Power
Licensed Power(MWT): 2.40E+02
Net Electrical Power(MWH): 4.26E+05
Initial Criticality: 09/27/62

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	1.09E-03
MN-54	1.61E-04
FE-59	7.03E-06
CO-60	1.92E-04
ZN-65	2.04E-05
KR-85M	7.66E+01
KR-87	3.99E+02
KR-88	2.44E+02
SR-89	2.85E-04
SR-90	3.39E-06
AG-110M	8.70E-05
I-131	2.08E-03
I-133	1.47E-02
XE-133	3.33E+01
CS-134	1.40E-05
I-135	5.11E-04
XE-135	3.66E+02
XE-135M	8.47E+02
CS-137	2.19E-04
XE-138	3.58E+03
BA-140	5.19E-04
Unidentified	1.03E-03

Total Airborne Tritium Released 4.84E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	1.40E-03
MN-54	5.42E-03
CO-58	4.91E-05
FE-59	2.64E-04
CO-60	8.50E-03
ZN-65	2.67E-04
SR-89	1.36E-04
SR-90	3.39E-05
AG-110M	1.13E-04
CS-134	7.97E-04
CS-137	1.18E-02
CE-141	4.64E-06
Unidentified	7.60E-03

Total Liquid Tritium Released	5.89E-01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.48E+05 liters
Volume of Dilution Water Used During Period	8.32E+10 liters

Installation: Big Rock Point
Unit No.(s): 1

Location: 4 Mi NE Charlevoix, MI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-155
Thermal Power(MWH): 1.40E+06
Commercial Operation: 03/29/63
Cooling Water Source: Lake Michigan

Licensee: Consumers Power
Licensed Power(MWT): 2.40E+02
Net Electrical Power(MWH): 4.26E+05
Initial Criticality: 09/27/62

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.04E+01 C1 1.03E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.11E+02 m3 6.47E+01 C1 2.13E+00	before processing burial volume
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe) Filters dewatered	m3 7.86E+00 C1 2.05E+01	

Installation: Braidwood
Unit No.(s): 1

Location: 24 Mi SSW of Joliet, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-456
Thermal Power(MWH): 2.48E+07
Commercial Operation: 07/29/88
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 8.26E+06
Initial Criticality: 05/29/87

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.77E+00
CO-58	2.70E-05
KR-85	2.51E+00
KR-85M	6.34E-01
KR-88	1.27E-01
I-131	1.54E-03
XE-131M	3.65E+00
I-132	1.09E-05
I-133	2.67E-04
XE-133	1.34E+03
XE-133M	1.46E+00
I-135	1.03E-03
XE-135	7.35E+01

Total Airborne Tritium Released 7.65E+01 Ci

Installation: Braidwood
Unit No.(s): 1

Location: 24 Mi SSW of Joliet, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-456
Thermal Power(MWH): 2.48E+07
Commercial Operation: 07/29/88
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 8.26E+06
Initial Criticality: 05/29/87

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	5.18E-04
CR-51	2.17E-01
MN-54	1.67E-02
FE-55	9.95E-02
CO-57	1.91E-03
CO-58	1.14E+00
FE-59	1.76E-02
CO-60	8.17E-02
ZN-65	3.08E-05
BR-82	1.14E-02
KR-85M	1.07E-04
KR-88	2.70E-03
SR-89	5.71E-04
NB-95	2.18E-02
ZR-95	5.87E-03
ZR-97	1.44E-04
MO-99	1.61E-04
TC-99M	1.80E-04
RU-105	1.29E-05
AG-110M	9.59E-05
SN-113	7.84E-03
SN-117M	2.06E-05
SB-124	2.31E-02
SB-125	3.08E-01
SB-126	2.02E-04
I-131	2.40E-02
I-132	2.39E-02
I-133	1.75E-03
XE-133	1.09E-01
XE-133M	3.18E-04
CS-134	5.71E-02
I-135	2.59E-04
XE-135	1.20E-02
CS-136	7.81E-04
CS-137	5.90E-02
CS-138	8.99E-04
BA/LA-140	6.25E-04
HF-181	2.54E-05

Total Liquid Tritium Released	6.50E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.32E+07 liters
Volume of Dilution Water Used During Period	2.39E+10 liters

Installation: Braidwood
Unit No.(s): 2

Location: 24 Mi SSW of Joliet, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-457
Thermal Power(MWH): 1.95E+07
Commercial Operation: 10/17/88
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.33E+06
Initial Criticality: 03/08/88

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.96E+00
CO-58	1.25E-05
CO-60	5.01E-06
KR-85	9.93E-01
KR-85M	8.90E-01
KR-87	8.12E-02
KR-88	5.31E-01
I-131	5.44E-04
XE-131	1.09E-02
XE-131M	2.26E+00
I-132	1.77E-06
I-133	1.96E-04
XE-133	9.82E+02
XE-133M	2.10E+00
I-135	1.18E-04
XE-135	3.10E+01

Total Airborne Tritium Released 9.38E+00 Ci

Installation: Braidwood
Unit No.(s): 2

Location: 24 Mi SSW of Joliet, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-457
Thermal Power(MWH): 1.95E+07
Commercial Operation: 10/17/88
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.33E+06
Initial Criticality: 03/08/88

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	5.18E-04
CR-51	2.17E-01
MN-54	1.67E-02
FE-55	9.95E-02
CO-57	1.91E-03
CO-58	1.14E+00
FE-59	1.76E-02
CO-60	8.17E-02
ZN-65	3.78E-05
BR-82	1.14E-02
KR-85M	1.07E-04
KR-88	2.70E-03
SR-89	5.71E-04
SR-90	1.19E-05
NB-95	2.18E-02
ZR-95	5.87E-03
ZR-97	1.44E-04
MO-99	1.61E-04
TC-99M	1.80E-04
RU-105	1.29E-05
AG-110M	9.59E-05
SN-113	7.84E-03
SN-117M	2.06E-05
SB-124	2.31E-02
SB-125	3.08E-01
SB-126	2.02E-04
I-131	2.40E-02
I-132	2.39E-02
I-133	1.75E-03
XE-133	1.09E-01
XE-133M	3.18E-04
CS-134	5.71E-02
I-135	2.59E-04
XE-135	1.20E-02
CS-136	7.81E-04
CS-137	5.90E-02
CS-138	8.99E-04
BA/LA-140	6.25E-04
HF-181	2.54E-05

Total Liquid Tritium Released	6.50E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.32E+07 liters
Volume of Dilution Water Used During Period	2.39E+10 liters

Installation: Braidwood
Unit No.(s): 1&2

Location: 24 Mi SSW of Joliet, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-456
Thermal Power(MWH): 2.48E+07
Commercial Operation: 07/29/88
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 8.26E+06
Initial Criticality: 05/29/87

Unit Number: 2 Type: PWR
Docket Number: 50-457
Thermal Power(MWH): 1.95E+07
Commercial Operation: 10/17/88
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.33E+06
Initial Criticality: 03/08/88

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Exclusive Use Vehicle	Quadrex, Oak Ridge, TN
2	Exclusive Use Vehicle	SEG, Oak Ridge, TN
11	Exclusive Use Vehicle	U.S. Ecology, Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	2.92E-01	1.75E-01
CO-57	2.03E-01	1.02E-01
CO-58	7.46E+01	3.59E+01
CO-60	3.33E+00	3.02E+00
CR-51	3.18E-01	1.62E-01
CS-134	1.88E+00	1.11E+01
CS-137	2.33E+00	1.14E+01
FE-55	1.13E+01	5.97E+00
FE-59	8.89E-02	1.50E-01
H-3	1.56E+00	2.56E+01
I-131		1.03E+00
MN-54	1.26E+00	2.38E+00
NB-95	3.16E-01	1.97E-01
NI-63	2.22E+00	2.55E+00
SB-125	1.04E-01	
ZR-95	1.07E-01	9.27E-02

B

C-14	1.04E-01
CO-57	9.67E-02
CO-58	3.65E+01
CO-60	4.80E+00
CR-51	9.51E-01
CS-134	1.81E-01
CS-137	4.06E-01
FE-55	3.49E+01
FE-59	8.20E-01
MN-54	1.29E+01

Installation: Braidwood
Unit No.(s): 1&2

Location: 24 Mi SSW of Joliet, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

NB-95	1.51E+00
NI-63	6.69E+00
PU-241	2.44E-01
ZN-65	6.80E-02
ZR-95	1.56E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.72E+01 Ci 7.33E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.32E+02 m3 9.04E+01 Ci 1.22E+01	before compaction after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Browns Ferry
Unit No.(s): 1&2&3

Location: 10 Mi NW Decatur, AL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-259
Thermal Power(MWH): 0.00E+00
Commercial Operation: 08/01/74
Cooling Water Source: Tennessee River

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 08/17/73

Unit Number: 2 Type: BWR
Docket Number: 50-260
Thermal Power(MWH): 0.00E+00
Commercial Operation: 03/01/75
Cooling Water Source: Tennessee River

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 07/20/74

Unit Number: 3 Type: BWR
Docket Number: 50-296
Thermal Power(MWH): 0.00E+00
Commercial Operation: 03/01/77
Cooling Water Source: Tennessee River

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 08/08/76

Airborne Effluents

Nuclide Released	Activity (Ci)
SR-89	4.28E-06
SR-90	9.15E-07
CS-137	1.83E-04

Total Airborne Tritium Released 5.94E-01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CO-60	1.92E-02
SR-90	1.17E-04
CS-134	3.49E-02
CS-137	2.48E-01

Total Liquid Tritium Released	2.07E-01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.49E+07 liters
Volume of Dilution Water Used During Period	5.79E+10 liters

Installation: Browns Ferry
Unit No.(s): 1&2&3

Location: 10 Mi NW Decatur, AL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-259
Thermal Power(MWH): 0.00E+00
Commercial Operation: 08/01/74
Cooling Water Source: Tennessee River

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 08/17/73

Unit Number: 2 Type: BWR
Docket Number: 50-260
Thermal Power(MWH): 0.00E+00
Commercial Operation: 03/01/75
Cooling Water Source: Tennessee River

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 07/20/74

Unit Number: 3 Type: BWR
Docket Number: 50-296
Thermal Power(MWH): 0.00E+00
Commercial Operation: 03/01/77
Cooling Water Source: Tennessee River

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 08/08/76

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
120	Sole Use Truck	Barnwell, SC
1	Sole Use Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-60	2.72E+01	3.24E+01
CS-134	5.30E+00	5.26E+00
CS-137	3.89E+01	4.45E+01
FE-55	2.49E+01	3.31E+00
MN-54	5.96E-02	
Others	2.33E+00	1.43E+01
ZN-65	1.28E+00	2.94E-01

B

AG-110M	7.74E-03	1.60E-03
CO-60	4.67E+01	4.69E+01
CS-134	1.04E+00	1.11E+00
CS-137	5.98E+00	6.01E+00
FE-55	4.30E+01	4.33E+01
FE-59	3.78E-03	5.00E-04
MN-54	2.11E-01	8.02E-02
Others	1.15E+00	6.83E-01
ZN-65	1.92E+00	1.92E+00

D

CO-60	4.66E+01
CS-134	1.04E+00
CS-137	3.83E+00
FE-55	4.30E+01

Installation: Browns Ferry
Unit No.(s): 1&2&3

Location: 10 Mi NW Decatur, AL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2&3(continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec
D

MN-54	2.16E-01
Others	3.34E+00
ZN-65	1.91E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.08E+01 Ci 7.35E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.57E+02 Ci 1.46E+01	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)		
Absorbed oily material	m3 1.44E+01 Ci 1.56E+01	

Installation: Brunswick
Unit No.(s): 1&2

Location: 20 Mi S Wilmington, NC

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-325
Thermal Power(MWH): 1.37E+07
Commercial Operation: 03/18/77
Cooling Water Source: Cape Fear River

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.32E+06
Initial Criticality: 10/08/76

Unit Number: 2 Type: BWR
Docket Number: 50-324
Thermal Power(MWH): 1.30E+07
Commercial Operation: 11/03/75
Cooling Water Source: Cape Fear River

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.05E+06
Initial Criticality: 03/20/75

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.25E+01
CR-51	2.69E-02
MN-54	1.72E-03
CO-57	5.12E-07
CO-58	1.34E-03
FE-59	2.97E-05
CO-60	4.47E-03
ZN-65	4.46E-05
KR-85M	1.77E+01
KR-87	3.97E+00
KR-88	4.34E+00
SR-89	7.82E-04
SR-90	4.30E-06
NB-95	4.09E-06
I-131	1.18E-02
I-132	3.23E-02
I-133	4.60E-02
XE-133	2.34E+02
CS-134	8.81E-06
I-134	5.07E-03
I-135	5.03E-02
XE-135	3.27E+02
XE-135M	1.40E+02
CS-137	9.35E-05
XE-137	2.38E+02
XE-138	1.47E+02
BA-140	1.06E-03
LA-140	8.71E-04
CE-141	1.09E-06
CE-144	5.37E-05
HF-181	1.13E-07

Total Airborne Tritium Released 2.66E+01 Ci

Installation: Brunswick
Unit No.(s): 1&2

Location: 20 Mi S Wilmington, NC

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-325
Thermal Power(MWH): 1.37E+07
Commercial Operation: 03/18/77
Cooling Water Source: Cape Fear River

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.32E+06
Initial Criticality: 10/08/76

Unit Number: 2 Type: BWR
Docket Number: 50-324
Thermal Power(MWH): 1.30E+07
Commercial Operation: 11/03/75
Cooling Water Source: Cape Fear River

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.05E+06
Initial Criticality: 03/20/75

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.90E-03
AR-41	6.54E-06
CR-51	1.19E-01
MN-54	4.60E-02
FE-55	3.30E-02
MN-56	8.50E-05
CO-57	2.99E-05
CO-58	2.27E-02
FE-59	7.13E-04
CO-60	1.68E-01
ZN-65	1.38E-03
ZN-69M	1.49E-05
AS-76	7.91E-04
KR-85	2.15E-03
KR-85M	1.29E-04
KR-87	5.54E-05
KR-88	1.90E-04
SR-89	3.37E-05
SR-90	6.65E-05
Y-91	8.44E-04
Y-91M	1.05E-03
SR-92	7.32E-05
Y-92	1.66E-02
Y-93	3.73E-04
NB-95	5.76E-04
ZR-95	3.03E-04
MO-99	8.17E-05
TC-99M	3.66E-03
TC-101	8.60E-05
RU-103	8.72E-04
TC-104	1.57E-04
RU-105	1.72E-03
AG-110M	9.96E-05
SB-125	1.15E-04
I-131	8.67E-04
I-132	2.61E-05
TE-132	3.44E-04

Installation: Brunswick
Unit No.(s): 1&2

Location: 20 Mi S Wilmington, NC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
I-133	2.68E-03
XE-133	2.89E-02
XE-133M	1.43E-04
CS-134	9.20E-03
I-134	1.17E-04
I-135	5.32E-04
XE-135	1.61E-01
XE-135M	5.28E-04
CS-137	1.68E-02
BA-139	1.12E-04
LA-140	5.86E-04
CE-141	9.57E-05
LA-141	1.12E-03
LA-142	6.61E-04
CE-144	3.17E-04
W-187	1.17E-03
NP-239	2.60E-03

Total Liquid Tritium Released	4.95E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.74E+07 liters
Volume of Dilution Water Used During Period	1.40E+12 liters

Installation: Brunswick
Unit No.(s): 1&2

Location: 20 Mi S Wilmington, NC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-325
Thermal Power(MWH): 1.37E+07
Commercial Operation: 03/18/77
Cooling Water Source: Cape Fear River

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.32E+06
Initial Criticality: 10/08/76

Unit Number: 2 Type: BWR
Docket Number: 50-324
Thermal Power(MWH): 1.30E+07
Commercial Operation: 11/03/75
Cooling Water Source: Cape Fear River

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.05E+06
Initial Criticality: 03/20/75

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
75	Sole Use	CNSI/Barnwell, SC

Irradiated Fuel Shipments (Disposition)

Number of Shipments	Mode of Transportation	Destination
4	Railcar/IF300 cask Sole Use	CP&L/SHNPP
3	Sole Use/Rail	CP&L/SHNPP

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58	7.78E+00	1.28E+00
CO-60	2.01E+01	2.06E+01
CS-134	1.06E+00	
CS-137	2.19E+00	1.71E+00
FE-55	5.84E+01	6.49E+01
MN-54	7.57E+00	6.40E+00
NI-63	1.84E+00	2.34E+00
B		
CO-60	1.07E+01	1.08E+01
FE-55	8.24E+01	8.28E+01
MN-54	6.09E+00	5.96E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.75E+02 Ci 1.17E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.15E+02 Ci 9.15E+01	after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Byron
Unit No.(s): 1

Location: 3 Mi SW Byron, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-454
Thermal Power(MWH): 2.16E+07
Commercial Operation: 09/16/85
Cooling Water Source: Rock River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.93E+06
Initial Criticality: 02/02/85

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.27E-01
CO-58	5.80E-06
KR-85	7.24E+00
KR-85M	3.40E-01
KR-87	3.78E-03
KR-88	1.39E-01
I-131	1.52E-03
XE-131M	3.76E+00
I-132	7.48E-05
I-133	2.19E-04
XE-133	4.13E+02
XE-133M	3.42E+00
CS-134	1.26E-05
I-135	1.01E-04
XE-135	1.54E+01
XE-135M	1.35E-01
CS-137	8.60E-06

Total Airborne Tritium Released 3.96E-01 Ci

Installation: Byron
Unit No.(s): 1

Location: 3 Mi SW Byron, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-454
Thermal Power(MWH): 2.16E+07
Commercial Operation: 09/16/85
Cooling Water Source: Rock River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.93E+06
Initial Criticality: 02/02/85

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	5.78E-02
MN-54	1.88E-02
FE-55	1.04E-01
CO-57	6.27E-04
CO-58	2.24E-01
FE-59	1.63E-02
CO-60	1.17E-01
ZN-65	2.29E-03
SR-89	1.85E-14
SR-90	2.60E-03
SR-92	3.73E-06
NB-95	1.21E-02
ZR-95	7.09E-03
MO-99	1.98E-04
TC-99M	2.04E-05
RU-103	2.37E-03
AG-110M	2.25E-04
SN-113	2.72E-03
SB-124	6.32E-04
SB-125	4.29E-03
I-131	3.24E-03
XE-131M	1.59E-02
I-132	2.85E-05
TE-132	6.85E-06
BA-133	5.58E-04
I-133	1.04E-04
XE-133	1.52E+00
XE-133M	1.09E-02
CS-134	5.68E-03
I-134	1.17E-04
XE-135	2.87E-03
CS-136	3.41E-04
CS-137	4.77E-03
CS-138	1.39E-05
BA/LA-140	2.38E-04
CE-141	1.59E-04
CE-144	3.15E-04
HF-181	3.17E-04

Total Liquid Tritium Released	4.99E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.63E+07 liters
Volume of Dilution Water Used During Period	1.06E+10 liters

Installation: Byron
Unit No.(s): 2

Location: 3 Mi SW Byron, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-455

Thermal Power(MWH): 1.87E+07

Commercial Operation: 08/21/87

Cooling Water Source: Rock River

Licensee: Commonwealth Edison Co.

Licensed Power(MWT): 3.41E+03

Net Electrical Power(MWH): 6.01E+06

Initial Criticality: 01/09/87

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.47E-01
CO-58	1.10E-05
KR-85	7.24E+00
KR-85M	5.40E-01
KR-87	5.13E-03
KR-88	2.33E-01
SR-90	1.29E-07
I-131	2.52E-03
XE-131M	4.35E+00
I-132	5.31E-05
I-133	1.13E-04
XE-133	7.54E+02
XE-133M	9.52E+00
I-134	2.44E-05
I-135	1.74E-04
XE-135	1.87E+01
XE-135M	1.35E-01

Total Airborne Tritium Released 6.74E-01 Ci

Installation: Byron
Unit No.(s): 2

Location: 3 Mi SW Byron, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-455
Thermal Power(MWH): 1.87E+07
Commercial Operation: 08/21/87
Cooling Water Source: Rock River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.01E+06
Initial Criticality: 01/09/87

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	5.78E-02
MN-54	1.88E-02
FE-55	1.04E-01
CO-57	6.27E-04
CO-58	2.24E-01
FE-59	1.63E-02
CO-60	1.17E-01
ZN-65	2.29E-03
SR-89	1.85E-14
SR-90	2.60E-03
SR-92	3.73E-06
NB-95	1.21E-02
ZR-95	7.09E-03
MO-99	1.98E-04
TC-99M	2.04E-05
RU-103	2.37E-03
AG-110M	2.25E-04
SN-113	2.72E-03
SB-124	6.32E-04
SB-125	4.29E-03
I-131	3.24E-03
XE-131M	1.59E-02
I-132	2.85E-05
TE-132	6.85E-06
BA-133	5.58E-04
I-133	1.04E-04
XE-133	1.52E+00
XE-133M	1.09E-02
CS-134	5.68E-03
I-134	1.17E-04
XE-135	2.87E-03
CS-136	2.41E-04
CS-137	4.77E-03
CS-138	1.39E-05
BA/LA-140	2.38E-04
CE-141	1.59E-04
CE-144	3.15E-04
HF-181	3.17E-04

Total Liquid Tritium Released	4.99E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.73E+07 liters
Volume of Dilution Water Used During Period	1.60E+10 liters

Installation: Byron
Unit No.(s): 1&2

Location: 3 Mi SW Byron, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-454
Thermal Power(MWH): 2.16E+07
Commercial Operation: 09/16/85
Cooling Water Source: Rock River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.93E+06
Initial Criticality: 02/02/85

Unit Number: 2 Type: PWR
Docket Number: 50-455
Thermal Power(MWH): 1.87E+07
Commercial Operation: 08/21/87
Cooling Water Source: Rock River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.01E+06
Initial Criticality: 01/09/87

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
21	Exclusive Use	Barnwell, SC
11	Exclusive Use	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AM-241	1.00E-01	1.00E-04
C-14	3.83E+00	3.83E+00
CM-244	1.00E-01	1.00E-04
CO-58	4.25E+00	4.25E+00
CO-60	1.41E+01	1.41E+01
CS-134	3.12E+00	3.12E+00
CS-137	5.04E+00	5.04E+00
FE-55	4.70E+01	4.70E+01
H-3	4.00E-01	4.00E-01
I-129	4.00E-04	4.00E-04
MN-54	1.93E+01	1.93E+01
NI-63	3.03E+00	3.03E+00
PU-238	1.00E-04	1.00E-04
PU-239	1.00E-04	1.00E-04
PU-241	4.00E-03	4.00E-03
SR-90	1.60E-03	1.60E-03
TC-99	2.60E-03	2.60E-03

B

C-14	4.30E+00	1.44E+00
CO-58	1.33E+01	1.10E+00
CO-60	1.55E+01	3.10E+00
CS-134	1.30E+00	2.00E-01
CS-137	1.40E+00	8.00E-01
FE-55	6.06E+01	7.06E+01
I-129	1.00E-04	2.30E-02
MN-54	1.53E+00	3.00E-01
NI-63	2.06E+00	2.24E+01
TC-99	5.00E-03	2.30E-02

Installation: Byron
Unit No.(s): 1&2

Location: 3 Mi SW Byron, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.13E+02 C1 4.75E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.30E+02 C1 2.38E+01	(not all in final burial form)
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Callaway
Unit No.(s): 1

Location: 10 Mi SE Fulton, MO

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Licensee: Union Electric Company

Docket Number: 50-483

Licensed Power(MWT): 3.57E+03

Thermal Power(MWH): 2.45E+07

Net Electrical Power(MWH): 8.01E+06

Commercial Operation: 12/19/84

Initial Criticality: 10/02/84

Cooling Water Source: Missouri River

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	9.42E-01
CO-57	2.91E-10
CO-58	2.48E-06
CO-60	1.28E-06
KR-85	1.56E+00
KR-85M	7.54E+01
KR-87	6.95E-05
KR-88	1.20E-01
RB-88	1.55E-07
SR-90	3.25E-08
I-131	1.42E-04
XE-131M	5.90E+00
I-132	7.63E-07
I-133	6.83E-07
XE-133	7.72E+02
XE-133M	4.89E+00
XE-135	4.16E+01

Total Airborne Tritium Released 3.69E+01 Ci

Installation: Callaway
Unit No.(s): 1

Location: 10 Mi SE Fulton, MO

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-483

Thermal Power(MWH): 2.45E+07

Commercial Operation: 12/19/84

Cooling Water Source: Missouri River

Licensee: Union Electric Company

Licensed Power(MWT): 3.57E+03

Net Electrical Power(MWH): 8.01E+06

Initial Criticality: 10/02/84

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CR-51	6.17E-03
MN-54	2.67E-03
CO-58	1.73E-02
FE-59	4.47E-04
CO-60	6.63E-03
ZN-65	9.50E-05
SR-89	5.48E-06
SR-90	5.67E-06
NB-95	2.23E-03
ZR-95	1.34E-03
MO-99	4.30E-06
TC-99M	4.30E-06
AG-110M	5.29E-05
SN-113	1.17E-04
SB-125	1.02E-04
I-131	2.69E-04
XE-131M	2.96E-03
I-133	9.70E-07
XE-133	4.54E-01
XE-133M	4.54E-03
CS-134	4.79E-04
XE-135	2.71E-03
CS-137	4.93E-04
BA-139	8.41E-05
BA-140	3.33E-05
CE-144	1.13E-04
HF-181	1.59E-05

Total Liquid Tritium Released

1.02E+03 Ci

Volume of Liquid Waste Released (Prior to Dilution)

6.86E+07 liters

Volume of Dilution Water Used During Period

1.63E+09 liters

Installation: Callaway
Unit No.(s): 1

Location: 10 Mi SE Fulton, MO

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-483
Thermal Power(MWH): 2.45E+07
Commercial Operation: 12/19/84
Cooling Water Source: Missouri River

Licensee: Union Electric Company
Licensed Power(MWT): 3.57E+03
Net Electrical Power(MWH): 8.01E+06
Initial Criticality: 10/02/84

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
2	Cask	Barnwell, SC
4	Truck	Oak Ridge, TN (Quadrex)
5	Truck	Oak Ridge, TN (SEG)
1	Cask	Richland, WA
5	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58		1.20E+00
CO-60	1.10E+00	2.62E+01
CS-134		1.00E+01
CS-137	1.20E+00	1.81E+01
FE-55	5.72E+01	2.36E+01
H-3	4.03E+01	
MN-54		7.60E+00
NI-63		1.24E+01
B		
C-14	2.60E+00	
CO-58	1.93E+01	2.22E+01
CO-60	1.43E+01	1.35E+01
CR-51	1.50E+00	
FE-55	5.02E+01	4.64E+01
MN-54	3.70E+00	7.30E+00
NB-95	1.80E+00	8.80E+00
NI-63	4.70E+00	
ZR-95	1.50E+00	1.80E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.30E+01 Ci 3.10E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.40E+01 Ci 1.88E+00	burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Calvert Cliffs
Unit No.(s): 1&2

Location: 45 Mi SE Washington D.C.

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-317
Thermal Power(MWH): 4.34E+06
Commercial Operation: 05/08/75
Cooling Water Source: Chesapeake Bay

Licensee: Baltimore Gas & Electric
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 1.34E+06
Initial Criticality: 10/07/74

Unit Number: 2 Type: PWR
Docket Number: 50-318
Thermal Power(MWH): 0.00E+00
Commercial Operation: 04/01/77
Cooling Water Source: Chesapeake Bay

Licensee: Baltimore Gas & Electric
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 11/30/76

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.35E-03
CR-51	2.67E-05
KR-85	1.19E+00
KR-85M	3.13E-01
KR-87	3.55E-04
KR-88	3.52E-03
SR-89	1.00E-04
SR-90	1.38E-05
I-131	1.45E-03
XE-131M	1.69E+01
I-133	1.54E-03
XE-133	6.35E+02
XE-133M	4.98E+00
XE-135	1.34E+01
CS-137	1.05E-04

Total Airborne Tritium Released 4.52E-01 Ci

Installation: Calvert Cliffs
Unit No.(s): 1&2

Location: 45 Mi SE Washington D.C.

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-317
Thermal Power(MWH): 4.34E+06
Commercial Operation: 05/08/75
Cooling Water Source: Chesapeake Bay

Licensee: Baltimore Gas & Electric
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 1.34E+06
Initial Criticality: 10/07/74

Unit Number: 2 Type: PWR
Docket Number: 50-318
Thermal Power(MWH): 0.00E+00
Commercial Operation: 04/01/77
Cooling Water Source: Chesapeake Bay

Licensee: Baltimore Gas & Electric
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 11/30/76

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	1.28E-04
CR-51	3.70E-03
MN-54	3.48E-02
CO-57	6.62E-03
CO-58	6.69E-02
CO-60	5.16E-01
SR-89	1.22E-04
SR-90	2.54E-03
SR-92	1.09E-05
NB-95	5.49E-03
ZR-95	1.19E-03
NB-97	6.67E-05
MO-99	1.94E-04
TC-99M	1.18E-03
RU-106	1.27E-02
AG-110M	8.74E-02
SN-113	4.98E-04
SB-122	4.03E-05
SB-125	1.96E-01
I-131	2.69E-02
XE-131M	3.52E-04
TE-132	4.82E-06
I-133	8.00E-03
XE-133	1.21E-01
XE-133M	2.01E-03
CS-134	7.51E-02
I-135	1.63E-04
XE-135	3.87E-04
XE-135M	5.71E-04
CS-136	6.79E-05
CS-137	3.40E-01
CE-139	1.05E-06
BA-140	3.09E-05
LA-140	2.23E-04
CE-141	4.12E-06
CE-144	2.88E-02
W-187	4.63E-04

Total Liquid Tritium Released	7.29E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.45E+07 liters
Volume of Dilution Water Used During Period	1.72E+12 liters

Installation: Calvert Cliffs
Unit No.(s): 1&2

Location: 45 M1 SE Washington D.C.

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-317
Thermal Power(MWH): 4.34E+06
Commercial Operation: 05/08/75
Cooling Water Source: Chesapeake Bay

Licensee: Baltimore Gas & Electric
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 1.34E+06
Initial Criticality: 10/07/74

Unit Number: 2 Type: PWR
Docket Number: 50-318
Thermal Power(MWH): 0.00E+00
Commercial Operation: 04/01/77
Cooling Water Source: Chesapeake Bay

Licensee: Baltimore Gas & Electric
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 11/30/76

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
5	Motor surface transit	CNSI - Barnwell, SC
12	Motor surface transit	SEG - Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	1.10E+00	
CO-58	1.44E+00	4.91E+00
CO-60	1.41E+01	
CS-134	3.03E+00	8.18E+00
CS-137	1.10E+01	2.75E+01
FE-55	4.47E+01	8.44E+00
H-3	3.14E+00	
MN-54		2.64E+00
NI-63	1.73E+01	3.85E+01
SB-125	1.42E+00	3.72E+00

B

C-14		1.10E+00
CO-58		1.44E+00
CO-60		1.41E+01
CS-134		3.03E+00
CS-137		1.10E+01
FE-55		4.47E+01
H-3		3.14E+00
NI-63		1.73E+01
SB-125		1.42E+00

C

CO-60		4.53E+01
FE-55		4.96E+01
NI-63		4.80E+00

Installation: Calvert Cliffs
Unit No.(s): 1&2

Location: 45 Mi SE Washington D.C.

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.70E+00 Ci 6.19E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.30E+02 Ci 9.24E+00	after compaction
C. Irradiated Components, Control Rods, etc.	m3 1.24E+00 Ci 4.05E+03	
D. Other (describe)	m3 Ci	

Installation: Catawba
Unit No.(s): 1

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-413
Thermal Power(MWH): 2.08E+07
Commercial Operation: 06/29/85
Cooling Water Source: Lake Wylie

Licensee: Duke Power Co
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.87E+06
Initial Criticality: 01/07/85

Airborne Effluents

Nuclide Released	Activity (Ci)
F-18	2.99E-02
AR-41	5.81E+00
CO-58	1.13E-04
CO-60	1.04E-05
ZN-69M	2.49E-06
BR-80M	8.54E-08
BR-82	2.50E-07
KR-85	1.26E+02
KR-85M	7.67E-01
KR-87	1.60E-01
KR-88	1.06E+00
RB-88	5.28E-05
SR-89	3.61E-05
SR-90	3.67E-06
Y-93	2.68E-05
NB-97	2.65E-09
ZR-97	2.17E-07
MO-99	1.46E-05
TC-99M	7.01E-06
SN-113	1.02E-06
SB-125	1.56E-06
SB-126	7.37E-08
I-131	6.90E-04
XE-131M	3.23E+00
I-132	1.90E-03
I-133	3.15E-03
XE-133	3.76E+02
XE-133M	3.65E+00
CS-134	3.35E-07
I-134	2.67E-06
I-135	2.24E-04
XE-135	1.65E+01
XE-135M	6.35E-02
CS-136	2.15E-06
CS-137	4.17E-10
CS-138	5.90E-04
XE-138	5.47E-04
CE-141	2.15E-06

Total Airborne Tritium Released 4.55E+01 Ci

Installation: Catawba
Unit No.(s): 1

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-413
Thermal Power(MWH): 2.08E+07
Commercial Operation: 06/29/85
Cooling Water Source: Lake Wylie

Licensee: Duke Power Co
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.87E+06
Initial Criticality: 01/07/85

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

BE-7	6.28E-04
F-18	2.86E-03
NA-24	1.18E-04
CR-51	2.96E-02
MN-54	1.72E-02
FE-55	5.77E-01
CO-57	4.96E-04
CO-58	1.22E-01
FE-59	1.80E-03
CO-60	6.34E-02
ZN-65	3.94E-04
BR-80M	4.76E-05
KR-85	1.19E-03
RB-88	4.21E-05
SR-89	1.04E-02
SR-90	4.85E-04
SR-92	4.09E-04
NB-95	5.86E-03
ZR-95	3.27E-03
NB-97	2.78E-03
ZR-97	1.22E-04
MO-99	4.33E-04
TC-99M	1.16E-03
RU-103	2.81E-04
RU-106	8.02E-04
AG-110M	1.21E-03
SN-113	6.58E-04
CD-115	9.82E-07
SB-122	6.18E-04
SB-124	4.45E-03
SB-125	4.14E-02
SB-126	1.33E-04
I-131	5.94E-03
TE-131M	2.13E-05
XE-131M	1.68E-05
I-132	2.50E-05
I-133	5.89E-04
XE-133	3.33E-02
XE-133M	4.40E-04
CS-134	5.12E-03
I-135	9.45E-06
XE-135	8.38E-03
XE-135M	3.68E-07
CS-136	1.52E-04

Installation: Catawba
Unit No.(s): 1

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
CS-137	8.83E-03
CS-138	4.48E-02
BA-140	6.32E-04
LA-140	2.44E-03
CE-141	8.44E-06
CE-144	3.82E-04
W-187	1.99E-04
BI-214	4.72E-05
PB-214	6.37E-05
AC-228	3.22E-06
TH-228	1.88E-02
NP-239	1.23E-04

Total Liquid Tritium Released	2.97E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.06E+08 liters
Volume of Dilution Water Used During Period	1.12E+11 liters

Installation: Catawba
Unit No.(s): 2

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-414
Thermal Power(MWH): 1.93E+07
Commercial Operation: 08/19/86
Cooling Water Source: Lake Wylie

Licensee: Duke Power Co
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.44E+06
Initial Criticality: 05/08/86

Airborne Effluents

Nuclide Released	Activity (Ci)
F-18	2.99E-02
AR-41	5.81E+00
CO-58	1.13E-04
CO-60	1.04E-05
ZN-69M	2.49E-06
BR-80M	8.54E-08
BR-82	2.50E-07
KR-85	1.26E+02
KR-85M	7.67E-01
KR-87	1.60E-01
KR-88	1.06E+00
RB-88	5.28E-05
SR-89	3.61E-05
SR-90	3.67E-06
Y-93	2.68E-05
NB-97	2.65E-09
ZR-97	2.17E-07
MO-99	1.46E-05
TC-99M	7.01E-06
SN-113	1.02E-06
SB-125	1.56E-06
SB-126	7.37E-08
I-131	6.90E-04
XE-131M	3.23E+00
I-132	1.90E-03
I-133	3.15E-03
XE-133	3.76E+02
XE-133M	3.65E+00
CS-134	3.35E-07
I-134	2.67E-06
I-135	2.24E-04
XE-135	1.65E+01
XE-135M	6.35E-02
CS-136	2.15E-06
CS-137	4.17E-10
CS-138	5.90E-04
XE-138	5.47E-04
CE-141	2.15E-06

Total Airborne Tritium Released 4.55E+01 Ci

Installation: Catawba
Unit No.(s): 2

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-414
Thermal Power(MWH): 1.93E+07
Commercial Operation: 08/19/86
Cooling Water Source: Lake Wylie

Licensee: Duke Power Co
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.44E+06
Initial Criticality: 05/08/86

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	6.28E-04
F-18	2.86E-03
NA-24	1.18E-04
CR-51	2.96E-02
MN-54	1.72E-02
FE-55	5.77E-01
CO-57	4.96E-04
CO-58	1.22E-01
FE-59	1.80E-03
CO-60	6.34E-02
ZN-65	3.94E-04
BR-80M	4.76E-05
KR-85	1.19E-03
RB-88	4.21E-05
SR-89	1.04E-02
SR-90	4.85E-04
SR-92	4.09E-04
NB-95	5.86E-03
ZR-95	3.27E-03
NB-97	2.78E-03
ZR-97	1.22E-04
MO-99	4.33E-04
TC-99M	1.16E-03
RU-103	2.81E-04
RU-106	8.02E-04
AG-110M	1.21E-03
SN-113	6.58E-04
CD-115	9.28E-07
SB-122	6.18E-04
SB-124	4.45E-03
SB-125	4.14E-02
SB-126	1.33E-04
I-131	5.94E-03
TE-131M	2.13E-05
XE-131M	1.68E-05
I-132	2.50E-05
I-133	5.89E-04
XE-133	3.33E-02
XE-133M	4.40E-04
CS-134	5.12E-03
I-135	9.45E-06
XE-135	8.38E-03
XE-135M	3.68E-07
CS-136	1.52E-04

Installation: Catawba
Unit No.(s): 2

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
CS-137	8.83E-03
CS-138	4.48E-02
BA-140	6.32E-04
LA-140	2.44E-03
CE-141	8.44E-06
CE-144	3.82E-04
W-187	1.99E-04
BI-214	4.72E-05
PB-214	6.37E-05
AC-228	3.22E-06
TH-228	1.88E-02
NP-239	1.23E-04

Total Liquid Tritium Released	2.97E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.06E+08 liters
Volume of Dilution Water Used During Period	1.12E+11 liters

Installation: Catawba
Unit No.(s): 1&2

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-413
Thermal Power(MWH): 2.08E+07
Commercial Operation: 06/29/85
Cooling Water Source: Lake Wylie

Licensee: Duke Power Co
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.87E+06
Initial Criticality: 01/07/85

Unit Number: 2 Type: PWR
Docket Number: 50-414
Thermal Power(MWH): 1.93E+07
Commercial Operation: 08/19/86
Cooling Water Source: Lake Wylie

Licensee: Duke Power Co
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.44E+06
Initial Criticality: 05/08/86

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
* 5		

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58		9.90E+00
CO-60		6.90E+00
CS-134		2.55E+01
CS-137		2.80E+01
I-131		1.34E+01
MN-54		1.54E+01
ZN-69M		1.10E+00

B

CO-58	1.92E+01	1.87E+01
CO-60	1.86E+01	1.87E+01
CR-51	1.40E+00	1.25E+00
FE-55	4.28E+01	4.34E+01
MN-54	1.11E+01	1.11E+01
NB-95	2.60E+00	2.55E+00
NI-63	1.90E+00	1.95E+00
ZR-95	1.40E+00	1.35E+00

D

CO-58	2.89E+01
CO-60	2.16E+01
CR-51	1.40E+00
FE-55	2.89E+01
MN-54	1.50E+01
NB-95	1.20E+00
NI-63	3.10E+00

* Solid waste shipments do not include brokered totals

Installation: Catawba
Unit No.(s): 1&2

Location: 6 Mi NNW of Rock Hill, SC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.35E+01 Ci 7.04E-05	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 9.25E+01 Ci 1.42E+01	non-compacted & brokered
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) dewatered mechanical filters	m3 3.41E+00 Ci 6.74E+00	

Installation: Clinton
Unit No.(s): 1

Location: 6 Mi E Clinton, IL

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-461

Thermal Power(MWH): 1.15E+07

Commercial Operation: 11/24/87

Cooling Water Source: Salt Creek

Licensee: Illinois Power

Licensed Power(MWT): 2.89E+03

Net Electrical Power(MWH): 3.60E+06

Initial Criticality: 02/27/87

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	8.20E-03
MN-54	5.56E-05
CO-58	3.02E-05
CO-60	2.01E-04
KR-85	9.20E+00
KR-87	1.72E+00
SR-89	6.56E-05
I-131	1.53E-04
I-133	1.50E-04

Total Airborne Tritium Released 1.88E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	2.50E-03
MN-54	5.25E-03
FE-55	4.82E-04
CO-58	3.99E-04
CO-60	1.65E-02
AG-110M	1.34E-04

Total Liquid Tritium Released	2.60E+00 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.20E+06 liters
Volume of Dilution Water Used During Period	2.67E+08 liters

Installation: Clinton
Unit No.(s): 1

Location: 6 Mi E Clinton, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-461
Thermal Power(MWH): 1.15E+07
Commercial Operation: 11/24/87
Cooling Water Source: Salt Creek

Licensee: Illinois Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 3.60E+06
Initial Criticality: 02/27/87

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
9	Truck	Barnwell, SC
34	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58		1.30E+00
CO-60	1.93E+01	3.47E+01
CR-51	4.57E+00	1.86E+00
FE-55	6.50E+01	5.15E+01
FE-59	1.52E+00	
MN-54	8.65E+00	9.57E+00
Others	9.70E-01	1.07E+00
B		
AG-110M	1.76E+01	
CO-58	4.37E+00	
CO-59		1.74E+00
CO-60	2.48E+01	2.44E+01
CR-51	2.03E+00	1.12E+01
FE-55	3.27E+01	5.43E+01
MN-54	1.85E+01	8.54E+00
Others	4.00E-02	6.00E-03

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.06E+02 Ci 5.43E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 6.59E+01 Ci 8.53E-01	after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Comanche Peak
Unit No.(s): 1

Location: 4.5 Mi N of Glen Rose, TX

Effluent and Waste Disposal Annual Report for 1990

Type: PWR	Licensee: TU Electric Company
Docket Number: 50-445	Licensed Power(MWT): 3.41E+03
Thermal Power(MWH): 8.16E+06	Net Electrical Power(MWH): 2.51E+06
Commercial Operation: 08/13/90	Initial Criticality: 04/03/90
Cooling Water Source: Squaw Creek Reservoir	

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.04E-01
BR-82	3.86E-05
KR-85	1.99E+01
KR-85M	3.08E-03
KR-88	6.32E-04
XE-131M	1.78E+00
XE-133	8.82E+02
XE-133M	1.64E+00
XE-135	9.99E-01

Total Airborne Tritium Released 6.07E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	8.73E-06
NA-24	2.52E-05
CR-51	1.74E-03
MN-54	1.37E-04
CO-58	7.83E-03
FE-59	1.02E-04
CO-60	1.66E-04
KR-85M	1.27E-05
KR-88	5.42E-06
NB-95	4.64E-04
ZR-95	3.58E-04
MO-99	1.91E-05
TC-99M	2.02E-05
RU-105	2.40E-05
SN-113	2.01E-06
SN-117M	9.91E-07
SB-122	1.21E-05
SB-124	3.87E-05
I-131	1.68E-04
XE-131M	3.77E-03
I-133	3.18E-05
XE-133	3.22E-01
XE-133M	1.05E-03
CS-134	3.24E-05
XE-135	5.24E-04
CS-137	6.87E-04
BA-140	1.06E-06
BA-141	1.43E-06
BA-142	6.44E-05
ND-147	2.01E-06

Total Liquid Tritium Released	1.87E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	6.70E+06 liters
Volume of Dilution Water Used During Period	8.14E+10 liters

Installation: Donald C. Cook
Unit No.(s): 1&2

Location: 11 Mi SSW St. Joseph, MI

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-315
Thermal Power(MWH): 2.05E+07
Commercial Operation: 08/27/75
Cooling Water Source: Lake Michigan

Licensee: Indiana Michigan Power Co.
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 6.30E+06
Initial Criticality: 01/18/75

Unit Number: 2 Type: PWR
Docket Number: 50-316
Thermal Power(MWH): 1.53E+07
Commercial Operation: 07/01/78
Cooling Water Source: Lake Michigan

Licensee: Indiana Michigan Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.81E+06
Initial Criticality: 03/10/78

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	6.72E-05
AR-41	2.09E+00
CR-51	4.49E-02
CO-58	2.57E-05
CO-60	1.18E-04
KR-85	5.24E+00
KR-85M	3.97E-02
KR-87	2.41E-04
RB-88	1.64E-04
SR-89	4.05E-06
SR-90	5.07E-06
ZR-95	4.27E-08
MO-99	8.46E-07
RU-103	2.24E-07
CD-109	4.10E-06
I-131	3.17E-03
XE-131M	1.23E+00
I-133	6.74E-04
XE-133	1.74E+02
XE-133M	6.25E-01
CS-134	1.13E-04
XE-135	5.28E+00
XE-135M	3.79E-05
CS-137	2.52E-02
CS-138	3.67E-07

Total Airborne Tritium Released 9.89E+00 Ci

Installation: Donald C. Cook
Unit No.(s): 1&2

Location: 11 Mi SSW St. Joseph, MI

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-315
Thermal Power(MWH): 2.05E+07
Commercial Operation: 08/27/75
Cooling Water Source: Lake Michigan

Licensee: Indiana Michigan Power Co.
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 6.30E+06
Initial Criticality: 01/18/75

Unit Number: 2 Type: PWR
Docket Number: 50-316
Thermal Power(MWH): 1.53E+07
Commercial Operation: 07/01/78
Cooling Water Source: Lake Michigan

Licensee: Indiana Michigan Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.81E+06
Initial Criticality: 03/10/78

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	5.03E-03
CR-51	1.95E-02
MN-54	1.36E-02
FE-55	1.14E-01
CO-57	5.32E-04
CO-58	2.34E-01
FE-59	2.26E-03
CO-60	4.08E-02
ZN-65	3.23E-04
SE-75	5.67E-05
AS-76	4.04E-05
KR-85	5.61E-02
SR-85	2.41E-04
SR-89	7.69E-01
SR-90	1.02E-01
ZR/NB-95	1.39E-03
ZR-97	3.10E-03
MO-99	2.17E-06
CD-109	8.62E-04
AG-110M	1.81E-01
SN-113	2.49E-04
SB-122	2.60E-03
SB-124	3.33E-02
SB-125	3.77E-02
I-131	8.19E-04
XE-131M	5.05E-03
TE-132	1.21E-05
I-133	4.10E-04
XE-133	3.08E-01
XE-133M	2.37E-03
CS-134	1.48E-02
XE-135	1.99E-03
XE-135M	8.93E-06
CS-136	6.85E-03
CS-137	2.45E-02
BA/LA-140	2.45E-05

Total Liquid Tritium Released	1.56E+03 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.52E+08 liters
Volume of Dilution Water Used During Period	2.65E+12 liters

Installation: Donald C. Cook
Unit No.(s): 1&2

Location: 11 Mi SSW St. Joseph, MI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-315
Thermal Power(MWH): 2.05E+07
Commercial Operation: 08/27/75
Cooling Water Source: Lake Michigan

Licensee: Indiana Michigan Power Co.
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 6.30E+06
Initial Criticality: 01/18/75

Unit Number: 2 Type: PWR
Docket Number: 50-316
Thermal Power(MWH): 1.53E+07
Commercial Operation: 07/01/78
Cooling Water Source: Lake Michigan

Licensee: Indiana Michigan Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.81E+06
Initial Criticality: 03/10/78

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
88	Truck	Barnwell, SC
1	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	8.00E+00	2.00E+00
CO-60	2.50E+01	1.00E+00
CS-134	9.00E+00	4.90E+01
CS-137	2.40E+01	4.50E+01
FE-55	5.00E+00	1.00E+00
H-3		1.00E+00
MN-54	1.00E+00	
NI-63	2.70E+01	1.00E+00

B

C-14	7.00E+00	3.00E+00
CO-58	3.00E+00	3.00E+00
CO-60	1.50E+01	8.00E+00
CS-134	3.00E+00	1.00E+00
CS-137	1.50E+01	8.00E+00
FE-55	3.10E+01	4.50E+01
H-3		2.00E+00
NI-63	2.50E+01	3.00E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.73E+01 Ci 5.67E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.68E+02 Ci 8.75E+01	after volume reduction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Cooper
Unit No.(s): 1

Location: 70 Mi S Omaha, NE

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-298
Thermal Power(MWH): 1.59E+07
Commercial Operation: 07/01/74
Cooling Water Source: Missouri River

Licensee: Nebraska Public Power District
Licensed Power(MWT): 2.38E+03
Net Electrical Power(MWH): 5.11E+06
Initial Criticality: 02/21/74

Airborne Effluents

Nuclide Released	Activity (Ci)
KR-83M	1.25E+00
KR-85	6.96E+00
KR-85M	2.67E+00
KR-87	8.23E+00
KR-88	8.84E+00
KR-89	3.52E+01
SR-91	1.54E-04
I-131	3.53E-04
I-132	3.98E-05
I-133	4.23E-04
XE-133	2.09E+01
XE-133M	1.05E-01
I-135	2.40E-04
XE-135	1.56E+01
XE-135M	6.82E+00
XE-137	4.13E+01
CS-138	5.99E-04
XE-138	3.92E+01

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	2.97E-04
CR-51	2.57E-02
MN-54	4.82E-01
FE-55	5.77E-02
CO-58	1.67E-01
FE-59	1.92E-03
CO-60	1.07E+00
ZN-65	5.39E-04
KR-85	5.17E-03
SR-89	1.47E-02
SR-90	1.13E-03
AG-110M	2.59E-02
SB-124	6.25E-04
I-131	6.24E-04
CS-134	6.82E-02
CS-136	2.00E-04
CS-137	1.14E-01

Total Liquid Tritium Released	5.07E+00 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.41E+06 liters
Volume of Dilution Water Used During Period	5.63E+10 liters

Installation: Cooper
Unit No.(s): 1

Location: 70 Mi S Omaha, NE

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-298
Thermal Power(MWH): 1.59E+07
Commercial Operation: 07/01/74
Cooling Water Source: Missouri River

Licensee: Nebraska Public Power District
Licensed Power(MWT): 2.38E+03
Net Electrical Power(MWH): 5.11E+06
Initial Criticality: 02/21/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Exclusive use vehicle	Beatty, NV
31	Exclusive use vehicle	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	1.49E+00	2.17E+00
C-14	5.14E-01	6.77E-01
CM-242	2.97E-05	2.35E-05
CO-58	3.29E+00	2.59E+00
CO-60	4.86E+01	5.00E+01
CR-51	2.49E-01	4.53E+00
CS-134	3.87E+00	2.88E+00
CS-137	7.50E+00	4.01E+00
FE-55	1.94E+01	1.58E+01
FE-59	1.83E-01	
H-3	1.15E-02	1.40E-02
I-131	1.36E-02	1.68E-02
MN-54	1.33E+01	1.57E+01
NI-59	1.36E-02	1.10E-02
NI-63	1.36E+00	1.10E+00
PU-241	2.40E-03	2.15E-03
SR-90	1.00E-02	7.50E-03
TC-99	7.74E-04	7.92E-04
ZN-65	2.45E-01	4.86E-01

B

AG-110M	2.89E-01	1.86E-01
C-14	2.05E-02	2.28E-02
CM-242	5.46E-05	5.89E-05
CO-58	3.63E-02	9.77E-03
CO-60	6.38E+01	6.59E+01
CS-134	3.29E+00	3.20E+00
CS-137	5.20E+00	5.81E+00
FE-55	2.13E+01	2.04E+01
H-3	4.16E-02	4.83E-02
MN-54	4.04E+00	2.94E+00
NI-59	2.54E-01	7.81E-02
NI-63	1.64E+00	1.42E+00
PU-241	5.40E-03	5.87E-03
SB-125	6.51E-02	1.75E-02
SR-90	8.86E-05	6.38E-05
TC-99	2.16E-04	2.35E-04

Installation: Cooper
Unit No.(s): 1

Location: 70 Mi S Omaha, NE

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.30E+02 Ci 3.58E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.78E+02 Ci 1.13E+01	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Crystal River
Unit No.(s): 3

Location: 70 Mi N Tampa, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-302

Thermal Power(MWH): 1.28E+07

Commercial Operation: 03/13/77

Cooling Water Source: Gulf of Mexico

Licensee: Florida Power

Licensed Power(MWT): 2.54E+03

Net Electrical Power(MWH): 4.14E+06

Initial Criticality: 01/14/77

Airborne Effluents

Nuclide Released	Activity (Ci)
CO-58	3.96E-07
CO-60	3.09E-06
KR-85	2.62E+01
KR-85M	1.16E+00
KR-87	1.17E+00
SR-89	1.48E-07
SR-90	1.11E-06
I-131	7.63E-04
XE-131M	7.41E+01
I-133	1.07E-04
XE-133	7.10E+03
XE-133M	6.22E+01
XE-135	4.53E+01

Total Airborne Tritium Released 2.64E+01 Ci

Installation: Crystal River
Unit No.(s): 3

Location: 70 Mi N Tampa, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-302
Thermal Power(MWH): 1.28E+07
Commercial Operation: 03/13/77
Cooling Water Source: Gulf of Mexico

Licensee: Florida Power
Licensed Power(MWT): 2.54E+03
Net Electrical Power(MWH): 4.14E+06
Initial Criticality: 01/14/77

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.88E-05
AR-41	9.06E-06
CR-51	3.54E-02
MN-54	1.43E-02
FE-55	4.99E-02
CO-58	2.28E-01
FE-59	3.71E-03
CO-60	1.27E-01
KR-85	1.21E-01
KR-85M	6.02E-04
KR-88	4.41E-04
RB-88	6.35E-03
SR-89	3.06E-04
SR-90	3.29E-04
Y-91M	1.35E-07
SR-92	8.53E-03
Y-92	3.64E-05
NB-95	1.45E-02
ZR-95	6.38E-03
ZR-97	1.07E-03
MO-99	2.78E-03
TC-99M	4.82E-03
RU-103	2.46E-03
RU-106	7.63E-03
AG-110M	2.33E-02
I-131	9.50E-03
XE-131M	4.74E-01
TE-132	5.23E-04
I-133	4.88E-04
XE-133	3.69E+00
XE-133M	3.76E-01
CS-134	2.24E-02
XE-135	2.47E-01
CS-137	3.83E-02
BA-139	2.60E-04
BA-140	1.16E-04
LA-140	9.16E-03
CE-141	2.86E-04
CE-144	1.45E-03

Total Liquid Tritium Released	5.10E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.23E+07 liters
Volume of Dilution Water Used During Period	9.32E+10 liters

Installation: Crystal River
Unit No.(s): 3

Location: 70 Mi N Tampa, FL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR	Licensee: Florida Power
Docket Number: 50-302	Licensed Power(MWT): 2.54E+03
Thermal Power(MWH): 1.28E+07	Net Electrical Power(MWH): 4.14E+06
Commercial Operation: 03/13/77	Initial Criticality: 01/14/77
Cooling Water Source: Gulf of Mexico	

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
11	Exclusive use vehicle	Barnwell, SC (CNSI)
17	Exclusive use vehicle	Oak Ridge, TN (SEG)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58	1.20E+01	1.20E+01
CO-60	8.75E+00	1.18E+01
CS-134	1.86E+01	1.44E+01
CS-137	2.36E+01	3.79E+01
FE-55	7.15E+00	9.50E+00
H-3	1.71E+01	
NI-63		8.70E+00
SB-122		1.20E+00
B		
C-14		1.00E+00
CO-58	4.73E+00	3.30E+00
CO-60	4.41E+00	5.50E+00
CS-134	2.68E+00	
CS-137	5.48E+00	1.80E+00
FE-55	6.04E+01	7.60E+01
MN-54	2.63E+00	
NI-63	7.89E+00	9.90E+00
C		
CO-60	3.30E+01	
FE-55	6.57E+01	
D		
C-14		1.10E+00
CO-60		4.83E+01
FE-55		1.95E+01
NI-63		3.04E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.84E+01 Ci 7.80E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 8.36E+02 Ci 2.68E+01	
C. Irradiated Components, Control Rods, etc.	m3 4.16E-01 Ci 1.10E+02	
D. Other (describe)		
Solidified phosphoric acid and sludge	m3 2.71E+01 Ci 5.40E+00	

Installation: Davis-Besse
Unit No.(s): 1

Location: 21 Mi E Toledo, OH

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-346

Thermal Power(MWH): 1.32E+07

Commercial Operation: 07/31/78

Cooling Water Source: Lake Erie

Licensee: Toledo Edison Co.

Licensed Power(MWT): 2.77E+03

Net Electrical Power(MWH): 4.16E+06

Initial Criticality: 08/12/77

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.99E-04
MN-54	4.51E-07
CO-58	1.51E-07
CO-60	2.75E-07
KR-85	1.66E+01
KR-85M	8.89E-02
KR-87	4.31E-03
KR-88	6.85E-02
RB-88	3.73E-05
I-131	2.35E-03
XE-131M	2.61E+00
I-132	1.34E-06
I-133	1.04E-03
XE-133	1.05E+03
XE-133M	8.29E+00
CS-134	7.44E-06
I-134	1.19E-06
I-135	3.59E-04
XE-135	1.36E+01
XE-135M	4.55E-03
CS-137	1.49E-05
CS-138	3.58E-06
XE-138	2.46E-03
CE-143	5.24E-08

Total Airborne Tritium Released 2.89E+01 Ci

Installation: Davis-Besse
Unit No.(s): 1

Location: 21 Mi E Toledo, OH

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-346
Thermal Power(MWH): 1.32E+07
Commercial Operation: 07/31/78
Cooling Water Source: Lake Erie

Licensee: Toledo Edison Co.
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 4.16E+06
Initial Criticality: 08/12/77

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CR-51	1.44E-03
MN-54	4.33E-04
FE-55	3.40E-02
CO-57	4.54E-04
CO-58	1.52E-02
FE-59	1.45E-04
CO-60	3.72E-02
KR-85	1.26E-02
NB-95	9.68E-06
ZR-95	8.77E-05
NB-97	6.15E-06
ZR-97	9.59E-04
TC-99M	1.86E-05
RU-103	2.62E-05
AG-110M	2.18E-02
SN-113	7.42E-04
SB-125	5.46E-03
I-131	4.62E-03
XE-131M	1.08E-02
I-133	4.07E-04
XE-133	1.86E-01
XE-133M	1.31E-03
CS-134	6.13E-03
XE-135	9.64E-04
CS-136	9.44E-05
CS-137	1.15E-02
LA-140	1.77E-05
CE-144	2.36E-04

Total Liquid Tritium Released	1.27E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.21E+08 liters
Volume of Dilution Water Used During Period	2.52E+10 liters

Installation: Davis-Besse
Unit No.(s): 1

Location: 21 Mi E Toledo, OH

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-346
Thermal Power(MWH): 1.32E+07
Commercial Operation: 07/31/78
Cooling Water Source: Lake Erie

Licensee: Toledo Edison Co.
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 4.16E+06
Initial Criticality: 08/12/77

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
5	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A			
	CO-60	2.00E+01	1.00E+01
	CS-137		1.20E+01
	FE-55	5.00E+01	4.40E+01
	NI-63	1.20E+01	1.90E+01
B			
	CO-60	2.00E+01	1.90E+01
	FE-55	5.00E+01	4.80E+01
	NI-63	1.20E+01	1.00E+00
C			
	CO-60		6.40E+01
	FE-55		7.00E+00
	NI-63		1.20E+01
	SB-125		1.20E+01
D			
	CO-60		1.69E+01
	CS-134		1.79E-01
	CS-137		2.15E+00
	FE-55		5.75E+01
	NI-63		1.58E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.82E+01 Ci 7.96E+00	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.12E+02 Ci 4.89E+00	
C. Irradiated Components, Control Rods, etc.	m3 3.20E+00 Ci 2.23E+03	
D. Other (describe) filters, contaminated wood,metal, waste oil	m3 2.25E+02 Ci 1.56E+01	

Installation: Diablo Canyon
Unit No.(s): 1&2

Location: 12 Mi WSW of San Luis Obispo

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-275
Thermal Power(MWH): 2.72E+07
Commercial Operation: 05/07/85
Cooling Water Source: Pacific Ocean

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 3.34E+03
Net Electrical Power(MWH): 8.71E+06
Initial Criticality: 04/29/84

Unit Number: 2 Type: PWR
Docket Number: 50-323
Thermal Power(MWH): 2.39E+07
Commercial Operation: 03/13/86
Cooling Water Source: Pacific Ocean

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.56E+06
Initial Criticality: 08/19/85

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.56E+00
CO-58	7.60E-06
CO-60	6.46E-06
KR-85	2.61E+00
KR-85M	7.65E-05
ZR-95	1.35E-07
I-131	4.33E-05
XE-131M	3.77E-02
I-133	6.97E-05
XE-133	4.65E+01
XE-133M	3.33E-01
XE-135	5.31E+00
CS-137	1.88E-06

Total Airborne Tritium Released 5.59E+01 Ci

Installation: Diablo Canyon
Unit No.(s): 1&2

Location: 12 Mi WSW of San Luis Obispo

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-275
Thermal Power(MWH): 2.72E+07
Commercial Operation: 05/07/85
Cooling Water Source: Pacific Ocean

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 3.34E+03
Net Electrical Power(MWH): 8.71E+06
Initial Criticality: 04/29/84

Unit Number: 2 Type: PWR
Docket Number: 50-323
Thermal Power(MWH): 2.39E+07
Commercial Operation: 03/13/86
Cooling Water Source: Pacific Ocean

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.56E+06
Initial Criticality: 08/19/85

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	9.68E-04
NA-24	2.15E-03
CR-51	7.60E-03
MN-54	2.97E-02
FE-55	1.62E+00
CO-57	3.22E-03
CO-58	4.94E-01
FE-59	9.68E-04
CO-60	2.51E-01
BR-82	1.92E-04
SR-89	1.77E-03
SR-90	1.19E-04
SR-91	9.57E-05
SR-92	3.72E-06
ZR-95	3.41E-03
MO-99	3.87E-03
AG-110M	2.71E-03
SN-113	3.67E-04
SN-117M	1.11E-05
SB-122	3.93E-03
SB-124	2.47E-02
SB-125	1.82E-01
TE-129M	2.08E-03
I-131	2.13E-02
TE-131M	4.80E-05
I-132	1.04E-04
TE-132	1.08E-03
I-133	1.83E-02
XE-133	2.92E-02
CS-134	5.01E-02
I-134	6.79E-08
I-135	2.02E-03
XE-135	2.96E-03
CS-136	3.37E-04
CS-137	6.08E-02
CS-138	1.28E-09
LA-140	1.67E-03

Installation: Diablo Canyon
Unit No.(s): 1&2

Location: 12 Mi WSW of San Luis Obispo

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CE-144	2.80E-04
--------	----------

W-187	3.08E-04
-------	----------

Total Liquid Tritium Released	9.68E+02 Ci
-------------------------------	-------------

Volume of Liquid Waste Released (Prior to Dilution)	5.14E+08 liters
---	-----------------

Volume of Dilution Water Used During Period	6.77E+11 liters
---	-----------------

Installation: Diablo Canyon
Unit No.(s): 1&2

Location: 12 Mi WSW of San Luis Obispo

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-275
Thermal Power(MWH): 2.72E+07
Commercial Operation: 05/07/85
Cooling Water Source: Pacific Ocean

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 3.34E+03
Net Electrical Power(MWH): 8.71E+06
Initial Criticality: 04/29/84

Unit Number: 2 Type: PWR
Docket Number: 50-323
Thermal Power(MWH): 2.39E+07
Commercial Operation: 03/13/86
Cooling Water Source: Pacific Ocean

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.56E+06
Initial Criticality: 08/19/85

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
22	Truck	Barnwell, SC
6	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
C-14		1.01E+01
CO-58		3.74E+00
CO-60	5.73E+01	1.33E+01
CS-134		1.16E+01
CS-137		2.45E+01
FE-55	7.90E+00	1.28E+01
H-3		9.54E+00
NI-63	2.19E+01	1.28E+01
B		
CO-58		1.18E+00
CO-60	8.10E+00	4.67E+00
FE-55	3.25E+01	1.79E+01
H-3	4.70E+01	7.10E+01
NI-63	5.40E+00	3.18E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.29E+01 Ci 2.90E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 6.03E+01 Ci 1.77E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Dresden
Unit No.(s): 1&2&3

Location: 14 Mi SW Moline, IL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-10
Thermal Power(MWH):
Commercial Operation: 07/04/60
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 7.00E+02
Net Electrical Power(MWH):
Initial Criticality: 10/15/59

Unit Number: 2 Type: BWR
Docket Number: 50-237
Thermal Power(MWH): 1.35E+07
Commercial Operation: 06/09/70
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 4.08E+06
Initial Criticality: 01/07/70

Unit Number: 3 Type: BWR
Docket Number: 50-249
Thermal Power(MWH): 1.67E+07
Commercial Operation: 11/16/71
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 5.14E+06
Initial Criticality: 01/31/71

Total Airborne Tritium Released 1.31E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

MN-54	5.48E-02
FE-55	1.50E-02
CO-58	5.57E-04
FE-59	3.95E-03
CO-60	1.79E-01
BR-82	1.51E-03
KR-88	2.43E-05
SR-90	1.28E-03
ZR-95	2.13E-05
SB-124	8.23E-05
XE-133	2.70E-05
CS-134	3.91E-03
XE-135	1.27E-05
CS-137	4.51E-01

Total Liquid Tritium Released	2.04E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.64E+07 liters
Volume of Dilution Water Used During Period	9.77E+10 liters

Installation: Dresden
Unit No.(s): 1

Location: 14 Mi SW Joliet, IL

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-10
Thermal Power(MWH):
Commercial Operation: 07/04/60
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 7.00E+02
Net Electrical Power(MWH):
Initial Criticality: 10/15/59

Airborne Effluents

Nuclide Released	Activity (Ci)
MN-54	5.94E-07
FE-55	1.22E-04
CO-60	4.08E-05
SR-89	6.67E-05
SR-90	1.10E-06
CS-137	2.79E-05

Installation: Dresden
Unit No.(s): 2&3

Location: 14 Mi SW Joliet, IL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 2 Type: BWR
Docket Number: 50-237
Thermal Power(MWH): 1.35E+07
Commercial Operation: 06/09/70
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 4.08E+06
Initial Criticality: 01/07/70

Unit Number: 3 Type: BWR
Docket Number: 50-249
Thermal Power(MWH): 1.67E+07
Commercial Operation: 11/16/71
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 5.14E+06
Initial Criticality: 01/31/71

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	2.71E-06
AR-41	6.22E-02
CR-51	8.79E-03
MN-54	5.25E-03
FE-55	8.29E-02
CO-58	1.88E-03
FE-59	2.30E-03
CO-60	1.67E-02
ZN-65	5.48E-04
KR-85	1.45E-02
KR-88	8.76E-01
SR-89	6.18E-04
SR-90	5.66E-06
MO-99	5.60E-03
AG-110M	2.42E-04
SB-124	1.40E-04
I-131	3.72E-03
I-133	1.91E-02
I-135	3.17E-02
XE-135	1.87E+01
XE-135M	8.18E-01
CS-137	2.70E-04
BA-140	2.73E-02
LA-140	7.35E-03

Liquid Effluents

Nuclide Released	Activity (Ci)
MN-54	1.54E-05
FE-55	6.90E-05
CO-60	1.42E-04
I-132	1.21E-06
CS-134	1.81E-05
I-135	1.76E-06
CS-137	5.78E-05

Installation: Dresden
Unit No.(s): 1&2&3

Location: 14 Mi SW Joliet, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-10
Thermal Power(MWH):
Commercial Operation: 07/04/60
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 7.00E+02
Net Electrical Power(MWH):
Initial Criticality: 10/15/59

Unit Number: 2 Type: BWR
Docket Number: 50-237
Thermal Power(MWH): 1.35E+07
Commercial Operation: 06/09/70
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 4.08E+06
Initial Criticality: 01/07/70

Unit Number: 3 Type: BWR
Docket Number: 50-249
Thermal Power(MWH): 1.67E+07
Commercial Operation: 11/16/71
Cooling Water Source: Kankakee River

Licensee: Commonwealth Edison
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 5.14E+06
Initial Criticality: 01/31/71

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
49	Motor freight(excl. use)	Barnwell, SC
48	Motor freight(excl. use)	CNSI, Barnwell, SC
11	Motor freight(excl. use)	CNSI, Channahon, IL
13	Motor freight(excl. use)	Quadrex, Oak Ridge, TN
9	Motor freight(excl. use)	SEG, Oak Ridge, TN
6	Motor freight(excl. use)	Westinghouse DDR, PA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	2.17E+00	
CO-60	4.51E+01	9.99E+00
CS-137	1.13E+01	
FE-55	1.80E+01	5.69E+01
FE-59		9.20E-01
MN-54	1.65E+01	3.16E+01
NI-63	5.41E+00	
Other	1.52E+00	

B

CO-60	2.54E+01	2.24E+01
CS-137	4.65E+00	
FE-55	6.20E+01	6.35E+01
FE-59		2.10E+00
MN-54	6.59E+00	9.51E+00
NI-63		1.16E+00
Other	1.36E+00	

Installation: Dresden
Unit No.(s): 1&2&3

Location: 14 Mi SW Joliet, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2&3(continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

D

CO-60	2.11E+01
CS-137	9.35E+00
FE-55	6.00E+01
H-3	4.72E+00
NI-63	1.10E+00
SR-90	3.06E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.46E+02 Ci 4.78E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.78E+03 Ci 3.05E+01	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 3.88E+02 Ci 9.08E-01	

Installation: Duane Arnold
Unit No.(s): 1

Location: 8 Mi NW Cedar Rapids, IA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-331
Thermal Power(MWH): 9.64E+06
Commercial Operation: 02/01/75
Cooling Water Source: Cedar River

Licensee: Iowa Electric Light & Power
Licensed Power(MWT): 1.66E+03
Net Electrical Power(MWH): 3.01E+06
Initial Criticality: 03/23/74

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	5.82E-04
MN-54	7.65E-04
CO-58	2.80E-04
FE-59	4.40E-05
CO-60	2.49E-03
KR-85	2.90E-04
SR-89	2.14E-05
SR-90	1.23E-07
I-131	2.59E-04
XE-131M	7.21E-05
I-132	3.50E-06
I-133	3.84E-04
XE-133	5.30E-01
I-135	1.05E-05
XE-135	2.29E+01
XE-135M	2.23E+01
CS-137	6.67E-06
BA/LA-140	2.48E-06

Total Airborne Tritium Released 1.63E+01 Ci

Installation: Duane Arnold
Unit No.(s): 1

Location: 8 Mi NW Cedar Rapids, IA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-331
Thermal Power(MWH): 9.64E+06
Commercial Operation: 02/01/75
Cooling Water Source: Cedar River

Licensee: Iowa Electric Light & Power
Licensed Power(MWT): 1.66E+03
Net Electrical Power(MWH): 3.01E+06
Initial Criticality: 03/23/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
13	Truck	Barnwell, SC
2	Truck	Madison, PA
7	Truck	Oak Ridge, TN
3	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M, CO-57, I-131, SR-89, SR-90, FE-59		1.23E+00
AG-110M, I-131, SR-89, SR-90, FE-59	5.84E-01	
C-14	7.25E-02	2.40E-02
CO-58	5.55E+00	8.17E+00
CO-60	3.30E+01	3.64E+01
CR-51	2.40E+00	5.67E+00
CS-134	7.55E+00	8.17E-01
CS-137	9.19E+00	1.24E+00
FE-55	3.20E+01	2.88E+01
H-3	5.06E-02	3.59E-03
MN-54	8.01E+00	1.69E+01
NI-63	1.62E+00	7.49E-01
TRUs	1.28E-03	1.21E-04

B

CE-144, CR-51, CS-137, CS-134, FE-59, ZN-65	7.90E-01	
CE-144, CS-137, CS-134, CR-51, ZN-65		9.02E-01
CM-242	3.78E-03	4.28E-03
CO-58	1.59E+00	1.81E+00
CO-60	1.76E+01	2.00E+01
FE-55	5.94E+01	6.77E+01
FE-59	1.94E+00	2.20E+00
MN-54	5.14E+00	5.83E+00
NI-63	1.35E+01	1.53E+00
PU-241	3.51E-02	3.97E-02
TRUs	1.21E-03	1.23E-03

C

C-14	1.29E-03	
CM-242	8.05E-08	
CO-60	4.19E+01	
CS-137, NB-94, NI-59, CO-58, CO-57, SR-90	4.29E-01	
FE-55	4.97E+01	
H-3	1.67E-02	
I-129	4.30E-11	

Installation: Duane Arnold
Unit No.(s): 1

Location: 8 Mi NW Cedar Rapids, IA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

C

MN-54	4.54E+00
NI-63	3.45E+00
PU-241	6.67E-07
TC-99	5.15E-06
TRUs	8.33E-07
U-233	1.70E-12
U-235	1.90E-10

D

CE-144, CS-134, CS-137, CR-51, ZN-65	8.04E-01
CM-242	3.82E-03
CO-58	1.62E+00
CO-60	1.79E+01
FE-55	6.05E+01
FE-59	1.98E+00
MN-54	5.22E+00
NI-63	1.20E+01
PU-241	3.55E-02
TRUs	1.09E-03

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 6.68E+01	
	C1 1.52E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.53E+02	
	C1 2.67E+01	
C. Irradiated Components, Control Rods, etc.	m3 3.25E+00	
	C1 3.63E+04	
D. Other (describe)		
wet trash	m3 1.04E+01	
	C1 1.90E+00	

Installation: Joseph M. Farley
Unit No.(s): 1

Location: Dothan, AL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-348

Thermal Power(MWH): 2.25E+07

Commercial Operation: 12/01/77

Cooling Water Source: Chatahoochee River

Licensee: Alabama Power

Licensed Power(MWT): 2.65E+03

Net Electrical Power(MWH): 6.91E+06

Initial Criticality: 08/09/77

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.34E+01
KR-85	7.20E-01
KR-85M	1.59E-03
KR-88	7.36E-04
XE-131M	2.39E-02
I-133	5.19E-06
XE-133	2.33E+01
XE-133M	2.85E-02
XE-135	3.97E+01

Total Airborne Tritium Released 3.32E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	5.43E-03
MN-54	3.21E-04
FE-55	2.09E-02
CO-57	7.79E-07
CO-58	1.17E-02
FE-59	1.69E-03
CO-60	1.40E-02
ZN-65	4.27E-06
KR-85M	1.93E-06
KR-87	6.69E-07
RB-88	3.17E-04
SR-90	1.65E-05
SR-92	2.63E-05
NB-95	1.15E-03
ZR-95	2.49E-04
NB-97	1.50E-04
TC-99M	7.32E-06
RU-103	1.82E-05
RU-105	1.84E-05
RU-106	2.17E-04
AG-110M	2.84E-03
SB-124	1.40E-05
SB-125	9.97E-03
I-131	1.01E-05
I-133	4.59E-06
XE-133	3.42E-03
XE-133M	3.90E-06
CS-134	1.09E-03
XE-135	1.09E-03
CS-137	4.62E-03
CS-138	1.44E-05

Total Liquid Tritium Released

7.35E+02 Ci

Volume of Liquid Waste Released (Prior to Dilution)

4.18E+08 liters

Volume of Dilution Water Used During Period

5.56E+10 liters

Installation: Joseph M. Farley
Unit No.(s): 2

Location: Dothan, AL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-364
Thermal Power(MWH): 1.69E+07
Commercial Operation: 07/30/81
Cooling Water Source: Chatahoochee River

Licensee: Alabama Power
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 5.25E+06
Initial Criticality: 05/05/81

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.21E+01
KR-85	8.34E-02
I-131	3.15E-06
XE-133	1.58E+00
XE-133M	1.51E-03
XE-135	1.69E-02

Total Airborne Tritium Released 5.43E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	9.88E-03
MN-54	3.18E-04
FE-55	2.82E-02
CO-57	9.78E-07
CO-58	9.75E-03
FE-59	3.01E-03
CO-60	1.03E-02
RB-88	1.46E-05
SR-92	2.78E-05
NB-95	1.20E-03
ZR-95	2.45E-04
NB-97	2.63E-04
RU-103	4.24E-06
RU-105	1.48E-05
RU-106	9.65E-05
AG-110M	2.10E-03
SB-124	8.13E-06
SB-125	1.21E-02
I-131	1.21E-06
XE-133	4.60E-03
CS-134	1.22E-03
XE-135	6.81E-06
CS-137	4.24E-03
ND-147	1.50E-06

Total Liquid Tritium Released	6.72E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.25E+08 liters
Volume of Dilution Water Used During Period	5.96E+10 liters

Installation: Joseph M. Farley
Unit No.(s): 1&2

Location: Dothan, AL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-348
Thermal Power(MWH): 2.25E+07
Commercial Operation: 12/01/77
Cooling Water Source: Chatahoochee River

Licensee: Alabama Power
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 6.91E+06
Initial Criticality: 08/09/77

Unit Number: 2 Type: PWR
Docket Number: 50-364
Thermal Power(MWH): 1.69E+07
Commercial Operation: 07/30/81
Cooling Water Source: Chatahoochee River

Licensee: Alabama Power
Licensed Power(MWT): 2.65E+03
Net Electrical Power(MWH): 5.25E+06
Initial Criticality: 05/05/81

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
52	Highway	CNSI, Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
C-14	2.20E+00	
CO-58		1.08E+01
CO-60	3.19E+01	3.31E+01
CS-137		2.10E+00
FE-55	5.02E+01	2.42E+01
MN-54		3.00E+00
NI-63	1.07E+01	2.17E+01
PU-241	1.00E+00	
SB-125		1.10E+00
B		
AG-110M		1.40E+00
CO-58	2.96E+01	9.20E+00
CO-60	8.00E+00	2.23E+01
CR-51	5.20E+00	3.00E+00
FE-55	3.72E+01	3.69E+01
H-3	3.70E+00	1.49E+01
MN-54	2.90E+00	1.80E+00
NB-95	2.80E+00	1.40E+00
NI-63	5.70E+00	6.10E+00
ZR-95	1.50E+00	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 7.01E+01 Ci 2.84E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 8.09E+01 Ci 4.78E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Fermi
Unit No.(s): 2

Location: Laguna Beach, MI

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-341
Thermal Power(MWH): 2.25E+07
Commercial Operation: 01/23/88
Cooling Water Source: Lake Erie

Licensee: Detroit Edison Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 7.10E+06
Initial Criticality: 06/21/85

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	1.00E-02
AR-41	9.78E+01
CR-51	9.43E-03
MN-54	6.77E-05
MN-56	2.01E-03
CO-58	2.22E-04
FE-59	7.82E-06
CO-60	1.56E-04
ZN-65	1.96E-04
ZN-69M	3.95E-05
SE-75	5.11E-07
AS-76	1.90E-04
BR-82	4.86E-06
KR-85M	3.83E+00
KR-87	1.18E-01
KR-88	1.02E+01
KR-89	1.02E+01
RB-89	1.27E+00
SR-89	4.61E-04
SR-90	6.01E-06
SR-91	1.81E-02
Y-91M	1.04E-02
TC-99M	2.46E-02
AG-110M	3.89E-05
BA-131	7.21E-06
I-131	3.42E-03
I-132	1.62E-02
I-133	2.03E-02
XE-133	1.26E+00
I-134	2.84E-03
I-135	1.97E-02
XE-135	5.80E-01
XE-135M	3.35E+00
XE-137	2.49E+01
CS-138	1.00E+00
XE-138	8.84E+00
BA-139	1.82E+00
BA-140	1.41E-03
LA-140	9.63E-04
W-187	4.14E-05

Installation: Fermi
Unit No.(s): 2

Location: Laguna Beach, MI

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-341

Thermal Power(MWH): 2.25E+07

Commercial Operation: 01/23/88

Cooling Water Source: Lake Erie

Licensee: Detroit Edison Company

Licensed Power(MWT): 3.29E+03

Net Electrical Power(MWH): 7.10E+06

Initial Criticality: 06/21/85

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	5.30E-02
CR-51	1.43E-01
MN-54	7.95E-04
FE-55	6.47E-05
CO-58	1.57E-03
CO-60	1.18E-03
ZN-65	2.34E-03
AS-76	2.70E-03
SR-89	1.07E-04
SR-90	5.45E-07
MO-99	3.29E-03
TC-99M	8.45E-03
AG-110M	9.28E-06
SB-122	1.84E-04
BA-131	1.61E-04
I-131	2.85E-04
I-133	6.93E-04
XE-135	3.11E-04
W-187	2.76E-04

Total Liquid Tritium Released

7.47E-01 Ci

Volume of Liquid Waste Released (Prior to Dilution)

8.34E+05 liters

Volume of Dilution Water Used During Period

1.75E+10 liters

Installation: Fermi
Unit No.(s): 2

Location: Laguna Beach, MI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-341
Thermal Power(MWH): 2.25E+07
Commercial Operation: 01/23/88
Cooling Water Source: Lake Erie

Licensee: Detroit Edison Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 7.10E+06
Initial Criticality: 06/21/85

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
38	Truck	Barnwell, SC
4	Truck	Channahon, IL
13	Truck	Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	5.00E-01	
C-14	2.00E-01	3.00E-01
CO-58	3.10E+00	4.90E+00
CO-60	1.24E+01	1.21E+01
CR-51	4.50E+00	2.51E+01
FE-55	5.35E+01	3.69E+01
FE-59	4.00E-01	1.00E-01
H-3	1.00E-01	
MN-54	1.05E+01	7.50E+00
NI-63	4.00E-01	3.00E-01
ZN-65	1.42E+01	1.16E+01
ZR-95		1.30E+00

B

C-14		1.00E-01
CO-58	1.80E+00	3.00E+00
CO-60	1.02E+01	9.40E+00
CR-51	2.60E+00	3.40E+00
FE-55	7.67E+01	7.42E+01
FE-59	1.20E+00	1.80E+00
MN-54	6.80E+00	8.00E+00
NI-63	3.00E-01	

C

CO-60		3.07E+01
FE-55		5.90E+01
H-3		3.00E-01
MN-54		6.10E+00
NI-63		1.20E+00
SB-124		2.50E+00
SB-125		3.00E-01

Installation: Fermi
Unit No.(s): 2

Location: Laguna Beach, MI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.86E+02 Ci 1.06E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 9.39E+02 Ci 1.55E+01	compacted; before super compaction
C. Irradiated Components, Control Rods, etc.	m3 3.25E+00 Ci 1.98E+04	compacted; before super compaction
D. Other (describe)	m3 Ci	

Installation: James A. Fitzpatrick
Unit No.(s): 1

Location: 36 Mi N Syracuse, NY

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-333
Thermal Power(MWH): 1.42E+07
Commercial Operation: 07/28/75
Cooling Water Source: Lake Ontario

Licensee: Power Authority of the State of NY
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.60E+06
Initial Criticality: 11/17/74

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.77E+01
CR-51	7.13E-03
MN-54	1.14E-04
CO-57	2.52E-07
CO-58	2.33E-04
FE-59	1.82E-05
CO-60	4.53E-04
ZN-65	8.91E-03
KR-85M	9.55E+01
KR-87	4.98E+01
KR-88	1.30E+02
SR-89	9.70E-05
SR-90	1.38E-06
RU-103	8.03E-07
AG-110M	2.36E-07
SB-124	1.29E-06
I-131	1.97E-03
XE-131M	3.55E+01
I-133	7.05E-03
XE-133	3.52E+02
XE-133M	9.29E+01
XE-135	1.72E+02
XE-135M	3.87E+01
CS-137	3.93E-05
XE-137	1.98E+02
XE-138	1.46E+02
BA/LA-140	1.13E-04
CE-141	1.86E-06
CE-144	2.32E-05

Total Airborne Tritium Released 1.21E+01 Ci

Installation: James A. Fitzpatrick
Unit No.(s): 1

Location: 36 Mi N Syracuse, NY

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-333
Thermal Power(MWH): 1.42E+07
Commercial Operation: 07/28/75
Cooling Water Source: Lake Ontario

Licensee: Power Authority of the State of NY
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.60E+06
Initial Criticality: 11/17/74

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.30E-04
CR-51	9.41E-06
MN-54	2.29E-03
FE-55	5.81E-03
CO-58	1.82E-05
FE-59	1.64E-05
CO-60	3.11E-03
ZN-65	1.40E-02
SR-89	2.41E-05
SR-90	1.93E-05
TC-99M	2.01E-06
CS-134	4.95E-04
XE-135	2.44E-04
CS-137	1.49E-03
CE-141	6.04E-07
CE-144	1.80E-06

Total Liquid Tritium Released	3.08E+00 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.93E+06 liters
Volume of Dilution Water Used During Period	6.56E+11 liters

Installation: James A. Fitzpatrick
Unit No.(s): 1

Location: 36 Mi N Syracuse, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-333
Thermal Power(MWH): 1.42E+07
Commercial Operation: 07/28/75
Cooling Water Source: Lake Ontario

Licensee: Power Authority of the State of NY
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.60E+06
Initial Criticality: 11/17/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
32	Truck	Barnwell, SC
5	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	9.51E-03	8.69E-03
CO-58		5.17E-01
CO-60	1.39E+01	1.24E+01
CR-51		4.01E+00
CS-134	7.46E-01	4.74E-01
CS-137	1.71E+00	1.29E+00
FE-55	1.35E+01	8.96E+00
FE-59		1.52E-01
H-3		3.07E-03
MN-54	2.73E+00	2.91E+00
NI-59		7.69E-05
NI-63	4.78E-01	4.66E-01
SR-89		3.07E-02
ZN-65	6.58E+01	6.87E+01
ZR-95		1.03E-02

B

C-14		2.11E-02
CO-58	1.00E+00	1.11E+00
CO-60	3.54E+01	3.53E+01
CS-134	2.41E+00	2.36E+00
CS-137	3.67E+00	3.56E+00
FE-55	1.97E+01	1.96E+01
MN-54	4.67E+00	4.61E+00
NI-63	1.56E+00	1.55E+00
ZN-65	3.20E+01	3.19E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.26E+02 Ci 2.04E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.57E+02 Ci 1.68E+01	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Fort Calhoun
Unit No.(s): 1

Location: 19 Mi N Omaha, NE

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-285

Thermal Power(MWH): 7.67E+06

Commercial Operation: 06/20/74

Cooling Water Source: Missouri River

Licensee: Omaha Public Power

Licensed Power(MWT): 1.50E+03

Net Electrical Power(MWH): 2.42E+06

Initial Criticality: 08/06/73

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.19E+00
FE-55	1.87E-05
CO-58	1.67E-05
KR-85	7.38E-01
KR-85M	3.53E-02
KR-87	1.66E-03
KR-88	2.38E-03
SR-90	5.22E-08
I-131	1.77E-03
XE-131M	2.46E+00
I-133	1.37E-03
XE-133	4.50E+02
XE-133M	2.58E+00
XE-135	2.92E+00
XE-135M	6.48E-03
XE-138	6.30E-03

Total Airborne Tritium Released 7.38E+00 Ci

Installation: Fort Calhoun
Unit No.(s): 1

Location: 19 Mi N Omaha, NE

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-285
Thermal Power(MWH): 7.67E+06
Commercial Operation: 06/20/74
Cooling Water Source: Missouri River

Licensee: Omaha Public Power
Licensed Power(MWT): 1.50E+03
Net Electrical Power(MWH): 2.42E+06
Initial Criticality: 08/06/73

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	1.11E-02
MN-54	4.94E-04
FE-55	1.09E-01
CO-57	9.09E-05
CO-58	2.48E-01
CO-60	2.31E-02
ZN-65	2.83E-05
SE-75	2.60E-04
SR-89	2.42E-03
SR-90	3.57E-04
NB-95	5.26E-03
ZR-95	2.13E-03
TC-99M	2.48E-05
RU-103	3.95E-04
RU-106	1.02E-04
AG-110M	6.98E-03
SB-124	5.24E-03
SB-125	1.02E-01
SB-126	1.31E-04
I-129	7.94E-05
I-131	3.11E-02
XE-131M	6.96E-03
XE-133	9.71E-01
XE-133M	1.83E-03
CS-134	4.29E-02
XE-135	2.86E-04
CS-137	2.08E-01
BA-140	4.42E-04
LA-140	5.11E-03

Total Liquid Tritium Released	1.74E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.19E+08 liters
Volume of Dilution Water Used During Period	5.36E+11 liters

Installation: Fort Calhoun
Unit No.(s): 1

Location: 19 Mi N Omaha, NE

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR	Licensee: Omaha Public Power
Docket Number: 50-285	Licensed Power(MWT): 1.50E+03
Thermal Power(MWH): 7.67E+06	Net Electrical Power(MWH): 2.42E+06
Commercial Operation: 06/20/74	Initial Criticality: 08/06/73
Cooling Water Source: Missouri River	

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
53	Closed Sole Use Vehicle	Barnwell, SC
2	Closed Sole Use Vehicle	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	4.47E+01	3.90E+00
CO-60	1.30E+00	2.90E+00
CS-134	3.38E+01	5.91E+01
CS-137	1.30E+01	2.80E+00
FE-55		1.50E+00
H-3	1.50E+00	3.90E+00
MN-54	1.30E+00	1.50E+00
MO-99		1.14E+01
TC-99	3.60E+00	1.14E+01

B

AG-110M	2.60E+00	2.60E+00
CE-144	2.00E+00	1.90E+00
CO-58	1.18E+01	1.15E+01
CO-60	1.10E+00	1.00E+00
CS-134	5.70E+00	5.60E+00
CS-137	6.12E+01	6.05E+01
MO-99		4.50E+00
PR-144	2.00E+00	1.90E+00
RH-103	2.70E+00	2.70E+00
RH-106	1.80E+00	
RU-103	2.70E+00	2.70E+00
RU-106	1.80E+00	
TC-99	4.70E+00	4.50E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 8.94E+00 Ci 4.73E+00	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.13E+02 Ci 2.75E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Fort St. Vrain
Unit No.(s): 1

Location: 35 Mi N Denver, CO

Effluent and Waste Disposal Annual Report for 1990

Type: HTG
Docket Number: 50-267
Thermal Power(MWH):
Commercial Operation: 07/01/79
Cooling Water Source: South Platte River

Licensee: Public Service Co of Colorado
Licensed Power(MWT): 8.42E+02
Net Electrical Power(MWH):

Total Airborne Tritium Released 7.28E-01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CO-60	6.14E-05
SR-90	9.65E-06
CS-137	1.11E-05

Total Liquid Tritium Released	3.22E+00 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.74E+07 liters
Volume of Dilution Water Used During Period	2.19E+09 liters

Installation: Fort St. Vrain
Unit No.(s): 1

Location: 35 Mi N Denver, CO

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: HTG
Docket Number: 50-267
Thermal Power(MWH):
Commercial Operation: 07/01/79
Cooling Water Source: South Platte River

Licensee: Public Service Co of Colorado
Licensed Power(MWT): 8.42E+02
Net Electrical Power(MWH):
Initial Criticality: 01/31/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
16	Highway	RAMP, Denver, CO
2	Highway	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-60	6.00E-02
CS-137	2.00E-02
FE-55	5.00E-01
H-3	5.90E+01
S-35	4.00E+01

B

CO-60	3.00E+00	2.50E+00
CS-137	2.00E+00	2.50E+00
FE-55	1.80E+01	1.60E+01
H-3	7.00E+01	6.80E+01
S-35	1.00E+01	1.00E+01

D

CO-60	4.00E-02
FE-55	3.60E-01
H-3	9.80E+01
S-35	7.00E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.72E+00 Ci 1.36E-01	uncompacted
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 8.94E+01 Ci 2.05E+00	uncompacted
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Oil	m3 5.95E+00 Ci 1.17E-01	uncompacted

Installation: R. E. Ginna
Unit No.(s): 1

Location: 16 Mi NE Rochester, NY

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-244
Thermal Power(MWH): 1.07E+07
Commercial Operation: 07/01/70
Cooling Water Source: Lake Ontario

Licensee: Rochester Gas & Electric
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.45E+06
Initial Criticality: 11/08/69

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	7.98E-01
CO-60	5.29E-07
KR-85	1.06E+01
KR-85M	9.84E-02
KR-87	8.79E-02
KR-88	1.66E-01
I-131	5.11E-03
XE-131M	5.90E+00
I-133	7.02E-04
XE-133	5.49E+02
XE-133M	4.82E+00
XE-135	2.05E+01
XE-135M	2.11E+00
CS-137	2.24E-06
XE-138	2.47E-01
Unidentified	3.42E-05

Total Airborne Tritium Released 1.24E+02 Ci

Installation: R. E. Ginna
Unit No.(s): 1

Location: 16 Mi NE Rochester, NY

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-244
Thermal Power(MWH): 1.07E+07
Commercial Operation: 07/01/70
Cooling Water Source: Lake Ontario

Licensee: Rochester Gas & Electric
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.45E+06
Initial Criticality: 11/08/69

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CR-51	3.10E-03
MN-54	5.09E-04
FE-55	3.69E-03
CO-58	3.66E-03
FE-59	1.02E-04
CO-60	1.02E-02
SR-89	1.30E-04
SR-90	1.96E-04
ZR-NB-95	1.74E-03
MO-99	6.69E-06
RU-103	4.22E-05
RU-106	3.69E-04
AG-110M	4.93E-03
SB-122	3.35E-04
SB-124	2.19E-03
SB-125	6.14E-04
I-131	4.86E-02
TE-131M	8.98E-03
I-133	2.00E-02
XE-133	2.94E-01
CS-134	9.11E-03
I-135	7.46E-03
XE-135	3.76E-03
CS-136	2.35E-03
CS-137	2.18E-02
BA-LA-140	2.71E-04
CE-141	5.73E-06

Total Liquid Tritium Released	3.21E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.19E+08 liters
Volume of Dilution Water Used During Period	6.01E+11 liters

Installation: R. E. Ginna
Unit No.(s): 1

Location: 16 Mi NE Rochester, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-244
Thermal Power(MWH): 1.07E+07
Commercial Operation: 07/01/70
Cooling Water Source: Lake Ontario

Licensee: Rochester Gas & Electric
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.45E+06
Initial Criticality: 11/08/69

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
44	Highway Vehicle	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	6.80E+00	8.70E+00
CO-60	1.90E+01	2.40E+01
CS-134		6.90E+00
CS-137	8.70E+00	2.00E+01
FE-55	2.30E+01	1.74E+01
NI-63	1.80E+01	1.30E+01
SB-124		4.90E+00
SB-125	4.30E+00	

B

CO-58	1.90E+01	1.60E+01
CO-60	1.50E+01	1.40E+01
CS-137	2.30E+01	1.70E+01
FE-55	2.60E+01	2.30E+01
NI-63	7.90E+00	1.60E+01
SB-124		6.00E+00
SB-125	5.30E+00	4.80E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.04E+02	after
	Ci 2.27E+02	compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 9.43E+01	after
	Ci 5.65E+00	compaction
C. Irradiated Components, Control Rods, etc.	m3	
	Ci	
D. Other (describe)	m3	
	Ci	

Installation: Grand Gulf
Unit No.(s): 1

Location: 25 Mi Vicksburg, MS

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-416
Thermal Power(MWH): 2.43E+07
Commercial Operation: 07/01/85
Cooling Water Source: Mississippi River

Licensee: System Energy Resources, Inc.
Licensed Power(MWT): 3.83E+03
Net Electrical Power(MWH): 7.40E+06
Initial Criticality: 08/18/82

Airborne Effluents

Nuclide Released	Activity (Ci)
F-18	7.64E+00
NA-24	5.08E-05
AR-41	9.43E-02
CR-51	3.41E-04
MN-54	4.59E-05
CO-58	4.44E-06
FE-59	1.89E-06
CO-60	6.96E-05
AS-76	5.43E-06
KR-85M	6.93E-03
KR-89	3.17E+01
SR-89	4.38E-06
SR-90	1.11E-07
TC-99M	1.47E-03
I-131	5.22E-04
XE-131M	1.51E-02
I-133	2.72E-04
XE-133	4.54E+01
XE-133M	1.86E-01
CS-134	1.06E-07
XE-135	4.29E+01
XE-135M	7.75E+00
CS-137	6.30E-07
XE-138	4.64E-02
CE-144	8.56E-06

Total Airborne Tritium Released 3.32E+00 Ci

Installation: Grand Gulf
Unit No.(s): 1

Location: 25 Mi Vicksburg, MS

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-416
Thermal Power(MWH): 2.43E+07
Commercial Operation: 07/01/85
Cooling Water Source: Mississippi River

Licensee: System Energy Resources, Inc.
Licensed Power(MWT): 3.83E+03
Net Electrical Power(MWH): 7.40E+06
Initial Criticality: 08/18/82

Liquid Effluents

Nuclide Released	Activity (Ci)
F-18	4.95E-04
NA-24	3.22E-04
CR-51	2.24E-01
MN-54	4.66E-02
FE-55	2.77E-01
MN-56	2.39E-05
CO-58	5.65E-03
FE-59	8.66E-03
CO-60	7.51E-02
CU-64	2.18E-03
ZN-65	7.62E-05
AS-76	3.48E-03
SR-92	2.27E-06
ZR-NB-95	9.49E-05
MO-99	6.20E-05
TC-99M	1.50E-04
AG-110M	2.01E-04
SB-124	1.13E-04
I-131	2.59E-04
I-133	1.77E-05
XE-133	2.70E-03
CS-134	1.18E-04
XE-135	1.78E-03
CS-137	1.44E-04
BA-LA-140	1.30E-05

Total Liquid Tritium Released	1.89E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.89E+07 liters
Volume of Dilution Water Used During Period	2.66E+09 liters

Installation: Grand Gulf
Unit No.(s): 1

Location: 25 Mi Vicksburg, MS

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-416
Thermal Power(MWH): 2.43E+07
Commercial Operation: 07/01/85
Cooling Water Source: Mississippi River

Licensee: System Energy Resources, Inc.
Licensed Power(MWT): 3.83E+03
Net Electrical Power(MWH): 7.40E+06
Initial Criticality: 08/18/82

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
23	Truck	Barnwell, SC
18	Truck	Barnwell, SC via SEG

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	6.00E+00	
CO-60	2.50E+01	1.90E+01
CR-51	2.00E+00	
FE-55	1.50E+01	7.00E+01
MN-54	4.20E+01	9.00E+00
Others	1.00E+01	2.00E+00

B

CO-60	7.00E+00	7.20E+00
FE-55	7.80E+01	8.14E+01
FE-59	2.00E+00	1.10E+00
MN-54	1.10E+01	1.03E+01
Others	2.00E+00	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.28E+02 C1 1.35E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.21E+02 m3 3.41E+01 C1 2.14E+00	before compaction after compaction
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Haddam Neck
Unit No.(s): 1

Location: 9.5 Mi SE Middletown, CT

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-213
Thermal Power(MWH): 3.81E+06
Commercial Operation: 01/01/68
Cooling Water Source: Connecticut River

Licensee: Connecticut Yankee Atomic Power
Licensed Power(MWT): 1.82E+03
Net Electrical Power(MWH): 1.15E+06
Initial Criticality: 07/24/67

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.75E-02
MN-54	5.82E-05
CO-60	5.78E-05
KR-85	1.61E+01
KR-85M	6.79E-02
KR-87	1.99E-02
KR-88	7.57E-02
SR-89	6.79E-06
SR-90	2.55E-05
I-131	2.55E-03
XE-131M	7.91E+00
I-133	4.19E-04
XE-133	1.43E+03
XE-133M	4.62E+00
CS-134	5.34E-04
XE-135	3.92E+00
XE-135M	9.51E-03
CS-137	1.48E-03
XE-137	4.38E-02
XE-138	3.52E-02

Total Airborne Tritium Released 7.81E+01 Ci

Installation: Haddam Neck
Unit No.(s): 1

Location: 9.5 Mi SE Middletown, CT

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-213
Thermal Power(MWH): 3.81E+06
Commercial Operation: 01/01/68
Cooling Water Source: Connecticut River

Licensee: Connecticut Yankee Atomic Power
Licensed Power(MWT): 1.82E+03
Net Electrical Power(MWH): 1.15E+06
Initial Criticality: 07/24/67

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	1.69E-03
MN-54	1.49E-02
FE-55	5.43E-01
CO-58	9.16E-03
FE-59	3.52E-03
CO-60	9.33E-02
SR-89	2.17E-03
SR-90	2.26E-03
ZR-NB-95	9.90E-06
RU-103	2.91E-05
RU-106	4.11E-04
AG-110M	1.29E-03
SB-124	1.36E-05
SB-125	1.13E-04
I-131	6.76E-02
XE-131M	3.76E-02
I-132	3.89E-01
I-133	2.67E-01
XE-133	7.31E-01
XE-133M	1.01E-03
CS-134	9.70E-03
I-134	7.67E-01
I-135	4.85E-01
XE-135	1.43E-03
CS-136	1.32E-04
CS-137	2.83E-02
BA-LA-140	2.73E-03
CE-144	2.21E-04

Total Liquid Tritium Released	9.89E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	7.17E+07 liters
Volume of Dilution Water Used During Period	4.16E+11 liters

Installation: Haddam Neck
Unit No.(s): 1

Location: 9.5 Mi SE Middletown, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-213
Thermal Power(MWH): 3.81E+06
Commercial Operation: 01/01/68
Cooling Water Source: Connecticut River

Licensee: Connecticut Yankee Atomic Power
Licensed Power(MWT): 1.82E+03
Net Electrical Power(MWH): 1.15E+06
Initial Criticality: 07/24/67

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
31	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AM-241	3.65E-03	1.08E-03
C-14	7.50E-02	2.00E+00
CM-242	3.75E-03	3.71E-04
CM-243	1.97E-03	5.09E-04
CM-244	1.97E-03	5.09E-04
CO-57	5.50E-02	
CO-58	3.15E+00	1.97E+00
CO-60	3.78E+01	4.28E+01
CR-51	1.14E+00	1.77E+00
CS-134	3.81E+00	5.50E-01
CS-137	6.04E+00	2.56E+00
FE-55	4.04E+01	4.16E+01
FE-59	9.00E-02	1.50E-01
H-3	1.30E-01	1.60E-01
I-129	8.06E-05	4.36E-05
MN-54	2.50E+00	3.02E+00
NI-63	4.06E+00	5.25E+00
PU-238	6.28E-03	1.59E-03
PU-239	9.40E-04	2.60E-04
PU-240	9.40E-04	2.60E-04
PU-241	5.20E-02	5.00E-02
SR-90	7.55E-04	1.40E-02
TC-99	4.44E-05	5.06E-05

B

AM-241	1.92E-02	1.92E-02
C-14	2.47E-01	2.47E-01
CM-242	1.65E-02	1.65E-02
CM-243	1.12E-02	1.12E-02
CM-244	1.12E-02	1.12E-02
CO-58	2.98E+00	2.98E+00
CO-60	1.03E+01	1.03E+01
CS-134	1.41E+00	1.41E+00
CS-137	7.54E+00	7.54E+00
FE-55	6.18E+01	6.18E+01
H-3	4.57E-01	4.57E-01
I-129	1.51E-01	1.51E-01

Installation: Haddam Neck
Unit No.(s): 1

Location: 9.5 Mi SE Middletown, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

NI-63	5.87E+00	5.87E+00
PU-238	1.88E-01	1.88E-01
PU-239	2.23E-02	2.23E-02
PU-240	2.23E-02	2.23E-02
PU-241	8.85E+00	8.85E+00
SR-90	9.04E-02	9.04E-02
TC-99	2.86E-02	2.86E-02

C

AM-241	2.00E-14
C-14	4.61E-03
CM-242	1.88E-13
CM-243	1.11E-14
CM-244	1.11E-14
CO-58	2.15E+00
CO-60	4.58E+01
CR-51	2.03E+00
FE-55	4.27E+01
FE-59	1.70E-01
MN-54	3.38E+00
NB-95	8.75E-05
NI-59	3.00E-02
NI-63	3.65E+00
NP-237	1.67E-15
PU-238	2.84E-14
PU-239	5.00E-15
PU-240	5.00E-15
PU-241	6.97E-15
TC-99	4.13E-06

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.14E+01	after
	Ci 6.98E+02	compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.03E+02	after
	Ci 2.20E+01	compaction
C. Irradiated Components, Control Rods, etc.	m3 2.15E+01	after
	Ci 2.20E+05	compaction
D. Other (describe)	m3	
	Ci	

Installation: Harris
Unit No.(s): 1

Location: 20 Mi SW Raleigh, NC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-400
Thermal Power(MWH): 2.65E+07
Commercial Operation: 05/02/87
Cooling Water Source: Makeup Reservoir

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 6.34E+06
Initial Criticality: 01/03/87

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	6.08E-02
CO-60	7.72E-05
KR-85	1.22E-01
KR-85M	1.26E+01
KR-87	4.21E+00
KR-88	2.10E+01
XE-131M	9.64E-02
XE-133	5.15E+02
XE-133M	8.55E+00
XE-135	3.01E+01
XE-135M	2.81E-03
XE-138	4.20E+00

Total Airborne Tritium Released 1.56E+00 Ci

Installation: Harris
Unit No.(s): 1

Location: 20 Mi SW Raleigh, NC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-400
Thermal Power(MWH): 2.05E+07
Commercial Operation: 05/02/87
Cooling Water Source: Makeup Reservoir

Licensee: Carolina Power & Light
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 6.34E+06
Initial Criticality: 01/03/87

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

BE-7	1.22E-04
NA-24	7.23E-05
CR-51	2.49E-03
MN-54	3.61E-03
FE-55	3.69E-02
CO-57	1.50E-03
CO-58	5.03E-01
FE-59	5.89E-05
CO-60	1.36E-01
ZN-65	1.06E-04
KR-85M	8.13E-06
SR-89	1.62E-05
SR-90	2.41E-05
ZR/NB-95	1.63E-04
NB-97	1.45E-05
MO-99	5.19E-05
TC-99M	2.12E-04
RU-103	4.75E-05
AG-110M	8.56E-05
SN-113	4.88E-05
SB-122	1.41E-04
SB-125	3.46E-02
I-131	1.96E-03
TE-131	1.76E-04
XE-131M	3.60E-05
TE-132	1.20E-05
I-133	4.69E-05
XE-133	4.70E-03
XE-133M	2.41E-05
CS-134	2.55E-03
I-134	1.25E-05
XE-135	1.22E-04
CS-137	4.75E-03
BA-139	3.04E-05
CS-139	4.38E-04
CE-143	2.77E-05
PR-144	8.97E-04
HF-181	1.86E-05

Total Liquid Tritium Released	7.26E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.24E+07 liters
Volume of Dilution Water Used During Period	1.62E+10 liters

Installation: Harris
Unit No.(s): 1

Location: 20 Mi SW Raleigh, NC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR	Licensee: Carolina Power & Light
Docket Number: 50-400	Licensed Power(MWT): 2.77E+03
Thermal Power(MWH): 2.05E+07	Net Electrical Power(MWH): 6.34E+06
Commercial Operation: 05/02/87	Initial Criticality: 01/03/87
Cooling Water Source: Makeup Reservoir	

Solid Waste Disposition		Destination
Number of Shipments	Mode of Transportation	
4	Truck	Barnwell, SC
45	Truck	Barnwell, SC via SEG

Estimate of Major Nuclide Composition (by type of waste) % Jan-June		Jul-Dec
A		
AM-241		7.57E-06
C-14		9.84E-02
CM-243/244		5.23E-06
CO-58	3.94E+01	3.43E+00
CO-60	5.88E+00	1.94E+01
CS-137		5.25E-02
FE-55	4.33E+01	4.22E+01
H-3		3.11E-02
MN-54	2.55E+00	1.33E+01
NI-63	8.81E+00	2.11E+01
PU-238		1.40E-05
PU-239/240		3.54E-05
SB-125		2.33E-01
SR-90		2.13E-02
B		
C-14		2.90E-02
CO-58	3.69E+00	1.45E+00
CO-60	5.50E+00	6.53E+00
CR-51	1.12E+00	4.83E-02
CS-137	1.19E-01	4.45E-03
FE-55	8.61E+01	9.02E+01
H-3	4.70E-01	3.43E-01
MN-54	1.86E+00	1.09E-01
NB-95	4.18E-01	6.80E-03
NI-59		9.13E-02
NI-63	5.53E-01	1.03E+00
TH-234		3.84E-03
ZR-95		1.66E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.72E+01 Ci 5.37E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 4.34E+02 m3 6.01E+01 Ci 8.85E+00	before compaction after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Edwin I. Hatch
Unit No.(s): 1&2

Location: 11 Mi N Baxley, GA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-321
Thermal Power(MWH): 1.35E+07
Commercial Operation: 12/31/75
Cooling Water Source: Altamaha River

Licensee: Georgia Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.07E+06
Initial Criticality: 09/12/74

Unit Number: 2 Type: BWR
Docket Number: 50-366
Thermal Power(MWH): 2.08E+07
Commercial Operation: 09/05/79
Cooling Water Source: Altamaha River

Licensee: Georgia Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 6.53E+06
Initial Criticality: 07/04/78

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	2.87E-04
MN-54	3.39E-05
CO-58	1.10E-05
CO-60	2.30E-04
ZN-65	2.74E-04
KR-85M	2.88E+00
KR-87	6.73E+00
SR-89	1.77E-04
SR-90	1.62E-06
NB-95	9.28E-08
MO-99	2.77E-05
I-131	6.02E-03
I-133	1.88E-02
XE-133	7.93E+02
CS-134	3.09E-06
I-135	2.09E-02
XE-135	1.24E+02
XE-135M	5.05E+01
CS-137	2.92E-05
XE-138	1.27E+02
BA-140	5.74E-04
LA-140	9.05E-04
CE-141	2.64E-07

Total Airborne Tritium Released 3.99E+01 Ci

Installation: Edwin I. Hatch
Unit No.(s): 1&2

Location: 11 Mi N Baxley, GA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-321
Thermal Power(MWH): 1.35E+07
Commercial Operation: 12/31/75
Cooling Water Source: Altamaha River

Licensee: Georgia Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.07E+06
Initial Criticality: 09/12/74

Unit Number: 2 Type: BWR
Docket Number: 50-366
Thermal Power(MWH): 2.08E+07
Commercial Operation: 09/05/79
Cooling Water Source: Altamaha River

Licensee: Georgia Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 6.53E+06
Initial Criticality: 07/04/78

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	3.59E-03
AR-41	1.57E-05
CR-51	2.81E-02
MN-54	6.80E-03
MN-56	2.87E-05
CO-58	3.31E-03
FE-59	2.93E-04
CO-60	3.65E-02
NI-65	3.03E-06
ZN-65	8.76E-02
AS-76	2.23E-04
KR-85	4.47E-04
SR-89	5.86E-04
SR-91	5.89E-05
Y-91M	9.79E-05
SR-92	1.04E-05
NB-95	2.66E-04
ZR-95	2.01E-04
NB-97	1.23E-03
MO-99	4.16E-04
TC-99M	1.23E-03
SB-125	2.29E-04
I-131	7.40E-03
XE-131M	2.90E-04
I-132	7.32E-04
I-133	1.12E-02
XE-133	6.51E-03
XE-133M	3.47E-06
CS-134	2.37E-02
I-134	3.34E-04
I-135	5.75E-03
XE-135	2.72E-02
XE-135M	1.00E-02
CS-136	8.23E-05
CS-137	7.40E-02
CS-138	2.61E-04
BA-140	1.27E-04

Installation: Edwin I. Hatch
Unit No.(s): 1&2

Location: 11 Mi N Baxley, GA

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

LA-140	3.73E-04
CE-141	8.16E-05
CE-144	1.49E-04
NP-239	5.59E-03

Total Liquid Tritium Released	2.26E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.67E+07 liters
Volume of Dilution Water Used During Period	6.51E+09 liters

Installation: Edwin I. Hatch
Unit No.(s): 1&2

Location: 11 Mi N Baxley, GA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-321
Thermal Power(MWH): 1.35E+07
Commercial Operation: 12/31/75
Cooling Water Source: Altamaha River

Licensee: Georgia Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.07E+06
Initial Criticality: 09/12/74

Unit Number: 2 Type: BWR
Docket Number: 50-366
Thermal Power(MWH): 2.08E+07
Commercial Operation: 09/05/79
Cooling Water Source: Altamaha River

Licensee: Georgia Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 6.53E+06
Initial Criticality: 07/04/78

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
101	Tractor Trailer	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A			
	CO-60	1.77E+01	1.79E+01
	CS-137	2.03E+00	4.78E+00
	FE-55	1.06E+01	1.08E+01
	Others	2.00E+01	2.46E+01
	ZN-65	4.96E+01	4.21E+01
B			
	CO-60	2.68E+01	2.68E+01
	CS-137	6.70E+00	6.55E+00
	FE-55	4.20E+00	4.17E+00
	Others	1.15E+01	1.13E+01
	ZN-65	5.08E+01	5.12E+01
C			
	CO-60	1.57E+01	5.94E+01
	FE-55	4.20E+01	3.52E+01
	NI-63		5.41E+00
	Others	3.20E+01	1.00E-02
	ZN-65	1.03E+01	
D			
	CO-60		5.86E+01
	FE-55		2.93E+01
	MN-54		1.50E+00
	Others		4.50E+00
	ZN-65		6.11E+00

Installation: Edwin I. Hatch
Unit No.(s): 1&2

Location: 11 Mi N Baxley, GA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.35E+02 Ci 2.45E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.01E+03 Ci 7.84E+00	after compaction
C. Irradiated Components, Control Rods, etc.	m3 1.85E+01 Ci 2.60E+04	
D. Other (describe) Torus Filters	m3 1.72E+01 Ci 9.99E+00	

Installation: Hope Creek
Unit No.(s): 1

Location: 18 Mi SE Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-354
Thermal Power(MWH): 1.35E+07
Commercial Operation: 12/20/86
Cooling Water Source: Delaware River

Licensee: Public Serv Elec & Gas Co of NJ
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 4.07E+06
Initial Criticality: 06/28/86

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	8.81E-08
MN-54	3.17E-04
FE-59	5.16E-05
CO-60	1.66E-04
ZN-65	3.74E-03
KR-83M	3.95E+00
KR-85M	4.73E+01
KR-87	7.83E+01
KR-88	1.24E+02
KR-89	1.06E+02
I-131	1.20E-03
I-133	1.47E-04
XE-133	7.49E+01
XE-133M	3.37E+00
XE-135	1.65E+02
XE-135M	3.04E+01
XE-137	1.22E+02
CE-138	1.36E+01
XE-138	6.13E+01

Total Airborne Tritium Released 8.20E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	2.06E-05
CR-51	7.48E-02
MN-54	1.58E-01
FE-55	9.20E-01
CO-58	8.06E-03
FE-59	2.98E-02
CO-60	3.65E-02
ZN-65	2.64E-01
SR-92	5.57E-04
TC-99M	3.36E-05
AG-110M	1.52E-03
SB-124	1.49E-05
I-131	6.73E-06
XE-133	2.42E-03
XE-135	1.05E-03

Total Liquid Tritium Released	1.18E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	8.46E+06 liters
Volume of Dilution Water Used During Period	5.30E+10 liters

Installation: Hope Creek
Unit No.(s): 1

Location: 18 Mi SE Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-354
Thermal Power(MWH): 1.35E+07
Commercial Operation: 12/20/86
Cooling Water Source: Delaware River

Licensee: Public Serv Elec & Gas Co of NJ
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 4.07E+06
Initial Criticality: 06/28/86

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
62	Truck	Barnwell, SC
1	Truck	Oak Ridge, TN
1	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	4.00E-02	
CO-58		2.00E-01
CO-60	3.10E+00	1.30E+00
CR-51	2.75E+00	1.40E+00
FE-55	2.25E+01	1.80E+01
FE-59		1.00E-01
MN-54	5.13E+00	2.00E+00
NI-63		1.00E-01
ZN-65	6.52E+01	7.68E+01

B

C-14	1.30E-01	
CO-58	1.35E+00	2.00E-01
CO-60	2.17E+00	1.30E+00
CR-51	1.10E+01	1.40E+00
FE-50		1.00E-01
FE-55	2.72E+01	1.80E+01
FE-59	2.34E+00	
MN-54	5.77E+00	2.00E+00
NI-63	2.20E-01	1.00E-01
ZN-65	4.96E+01	7.68E+01

D

CE-144		5.00E-01
CO-58		6.00E-01
CO-60	5.66E+00	2.60E+00
CR-51		7.40E+00
FE-55	7.08E+01	3.41E+01
FE-59		9.00E-01
H-3		1.20E+00
MN-54	4.43E+00	7.10E+00
NI-63	5.90E-01	
ZN-65	1.83E+01	4.51E+01

Installation: Hope Creek
Unit No.(s): 1

Location: 18 Mi SE Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.39E+02	before
	Cl 2.20E+03	compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.61E+01	after
	Cl 6.20E+00	compaction
C. Irradiated Components, Control Rods, etc.	m3	
	Cl	
D. Other (describe)		
solidified oil	m3 1.15E+01	before
	Cl 9.78E-02	compaction
lubricating oil	m3 1.98E+01	before
	Cl 1.48E+00	compaction

Installation: Humboldt Bay
Unit No.(s): 3

Location: 4 Mi SW Eureka, CA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR	Licensee: Pacific Gas & Electric
Docket Number: 50-133	Licensed Power(MWT): 0.00E+00
Thermal Power(MWH):	Net Electrical Power(MWH):
Commercial Operation: 08/01/63	Initial Criticality: 02/16/63
Cooling Water Source: Humboldt Bay	

Airborne Effluents

Nuclide Released	Activity (Ci)
CO-60	2.27E-05
SR-90	7.82E-07
CS-137	1.50E-05

Liquid Effluents

Nuclide Released	Activity (Ci)
CO-60	1.44E-04
SR-90	2.40E-04
CS-134	1.89E-05
CS-137	5.37E-03

Total Liquid Tritium Released	3.48E-03 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.42E+05 liters
Volume of Dilution Water Used During Period	5.96E+10 liters

Installation: Humboldt Bay
Unit No.(s): 3

Location: 4 Mi SW Eureka, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-133
Thermal Power(MWH):
Commercial Operation: 08/01/63
Cooling Water Source: Humboldt Bay

Licensee: Pacific Gas & Electric
Licensed Power(MWT): 0.00E+00
Net Electrical Power(MWH):
Initial Criticality: 02/16/63

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
1	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

B

AM-241	2.40E-01
C-14	8.01E-02
CO-60	1.00E+00
CS-134	5.38E-02
CS-137	2.82E+01
FE-55	4.90E+01
NI-63	5.69E+00
PU-241	2.92E+00
SR-90	2.85E+00

D

AM-241	2.28E-01
CO-60	6.68E+00
CS-134	2.28E-01
CS-137	4.84E+01
FE-55	3.26E+01
NI-63	3.76E+00
PU-241	1.93E+00
SR-90	4.87E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 Ci	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.59E+01 Ci 8.36E-02	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) absorbed liquids	m3 3.40E+00 Ci 7.02E-03	non-compacted

Installation: Indian Point
Unit No.(s): 1&2

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-3
Thermal Power(MWH):
Commercial Operation:
Cooling Water Source: Hudson River

Licensee: Consolidated Edison
Licensed Power(MWT): 6.15E+02
Net Electrical Power(MWH):
Initial Criticality: 08/02/62

Unit Number: 2 Type: PWR
Docket Number: 50-247
Thermal Power(MWH): 1.66E+07
Commercial Operation: 08/01/74
Cooling Water Source: Hudson River

Licensee: Consolidated Edison
Licensed Power(MWT): 2.76E+03
Net Electrical Power(MWH): 5.21E+06
Initial Criticality: 05/22/73

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.55E+00
FE-55	2.09E-06
CO-58	2.57E-05
CO-60	5.59E-04
NI-63	1.29E-05
KR-85	1.20E-05
KR-85M	1.77E+00
KR-87	5.10E-01
KR-88	1.58E+00
TE-123M	9.08E-06
I-131	4.44E-03
XE-131M	1.83E+01
I-133	4.34E-03
XE-133	2.15E+03
XE-133M	1.82E+01
XE-135	3.00E+01
XE-135M	2.51E+00
CS-137	3.17E-04
XE-138	1.07E+00

Total Airborne Tritium Released 2.56E-01 Ci

Installation: Indian Point
Unit No.(s): 1&2

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-3
Thermal Power(MWH):
Commercial Operation:
Cooling Water Source: Hudson River

Licensee: Consolidated Edison
Licensed Power(MWT): 6.15E+02
Net Electrical Power(MWH):
Initial Criticality: 08/02/62

Unit Number: 2 Type: PWR
Docket Number: 50-247
Thermal Power(MWH): 1.66E+07
Commercial Operation: 08/01/74
Cooling Water Source: Hudson River

Licensee: Consolidated Edison
Licensed Power(MWT): 2.76E+03
Net Electrical Power(MWH): 5.21E+06
Initial Criticality: 05/22/73

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.19E-01
CR-51	5.89E-04
MN-54	3.17E-04
FE-55	4.72E-02
CO-58	2.05E-02
FE-59	1.63E-04
CO-60	3.09E-02
NI-63	7.57E-02
SR-89	3.14E-05
TC-99M	3.39E-07
RU-106	3.01E-07
AG-110M	4.04E-04
SB-122	1.78E-02
TE-123M	1.37E-03
SB-124	9.05E-02
SB-125	1.53E-04
I-131	1.52E-01
XE-131M	3.14E-03
I-132	9.19E-02
I-133	1.87E-01
XE-133	1.17E-01
I-134	8.48E-02
I-135	1.15E-01
XE-135	1.59E-02
XE-135M	3.78E-02
CS-137	1.67E-02
CS-138	9.32E-03
BA-139	3.25E-06
LA-140	3.62E-04

Total Liquid Tritium Released	6.44E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.59E+08 liters
Volume of Dilution Water Used During Period	1.07E+12 liters

Installation: Indian Point
Unit No.(s): 1&2

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-3
Thermal Power(MWH):
Commercial Operation:
Cooling Water Source: Hudson River

Licensee: Consolidated Edison
Licensed Power(MWT): 6.15E+02
Net Electrical Power(MWH):
Initial Criticality: 08/02/62

Unit Number: 2 Type: PWR
Docket Number: 50-247
Thermal Power(MWH): 1.66E+07
Commercial Operation: 08/01/74
Cooling Water Source: Hudson River

Licensee: Consolidated Edison
Licensed Power(MWT): 2.76E+03
Net Electrical Power(MWH): 5.21E+06
Initial Criticality: 05/22/73

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
36	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	1.00E-01	
CE-144		4.00E-01
CO-57		5.00E-01
CO-58	1.40E+01	1.10E+01
CO-60	3.48E+01	1.77E+01
CS-134	4.00E-01	3.00E-01
CS-137	4.60E+00	1.05E+01
FE-55	7.30E+00	1.62E+01
FE-59	1.00E-01	
H-3	7.00E-01	
MN-54	7.00E-01	7.25E-01
NI-59	1.00E-01	2.23E+00
NI-63	2.32E+01	2.99E+01
Others	2.70E+00	1.35E+00
PU-241		5.00E-01
SB-124	1.00E+00	7.60E+00
SB-125	1.00E+00	3.00E-01
SR-89		7.50E-01
SR-90	1.00E-01	
ZN-65	1.00E-01	
ZR-95	9.10E+00	

B

C-14	2.00E-01	6.00E-01
CE-144		1.00E+00
CO-58	7.80E+00	1.20E+00
CO-60	2.63E+01	2.65E+01
CS-134	1.60E+00	1.15E+01
CS-137	8.20E+00	3.10E+00
FE-55	3.32E+01	3.79E+01

Installation: Indian Point
Unit No.(s): 1&2

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

H-3		2.00E-01
MN-54		2.00E-01
NB-94		6.00E-01
NI-63	2.26E+01	1.52E+01
PU-239/240,AM-241	1.00E-01	
PU-241		1.00E-01
SB-124		1.00E-01
SB-125		9.00E-01
SR-89		4.00E-01
SR-90	1.00E-01	5.00E-01

C

CO-58	1.00E-01
CO-60	5.35E+01
FE-55	3.27E+01
H-3	1.00E-01
MN-54	6.00E-01
NI-59	1.00E-01
NI-63	1.29E+01
Others	1.00E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.89E+01	after
	Ci 1.57E+03	compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.00E+02	after
	Ci 2.54E+01	compaction
C. Irradiated Components, Control Rods, etc.	m3 4.13E-01	after
	Ci 4.91E+02	compaction
D. Other (describe)	m3	
	Ci	

Installation: Indian Point
Unit No.(s): 3

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-286
Thermal Power(MWH): 1.57E+07
Commercial Operation: 08/30/76
Cooling Water Source: Hudson River

Licensee: Power Authority of the State of NY
Licensed Power(MWT): 3.02E+03
Net Electrical Power(MWH): 5.03E+06
Initial Criticality: 04/06/76

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.23E-01
CO-58	2.68E-05
KR-85	8.61E+00
KR-85M	7.38E-01
KR-87	6.90E-04
KR-88	1.85E-02
I-131	1.37E-04
XE-131M	4.51E+00
XE-133	5.74E+02
XE-133M	2.79E+00
CS-134	5.91E-06
XE-135	3.61E+01
CS-137	1.12E-05

Total Airborne Tritium Released 2.87E+00 Ci

Installation: Indian Point
Unit No.(s): 3

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-286
Thermal Power(MWH): 1.57E+07
Commercial Operation: 08/30/76
Cooling Water Source: Hudson River

Licensee: Power Authority of the State of NY
Licensed Power(MWT): 3.02E+03
Net Electrical Power(MWH): 5.03E+06
Initial Criticality: 04/06/76

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	4.61E-04
NA-24	1.86E-04
AR-41	1.62E-05
CR-51	1.79E-02
MN-54	1.46E-03
FE-55	6.33E-02
CO-57	3.24E-05
CO-58	9.49E-02
FE-59	1.02E-03
CO-60	1.57E-02
NI-63	1.78E-02
KR-85	6.75E-02
KR-85M	4.94E-04
SR-85	2.96E-04
KR-88	5.70E-05
RB-88	7.61E-04
SR-89	2.56E-05
NB-95	2.20E-03
ZR-95	7.48E-04
TC-99M	1.34E-04
RU-103	2.59E-05
AG-110M	7.36E-03
SN-113	4.17E-04
SB-124	1.44E-02
SB-125	1.56E-02
I-131	3.28E-03
XE-131M	9.15E-02
I-133	7.63E-04
XE-133	4.16E+00
XE-133M	3.13E-02
CS-134	2.71E-02
XE-135	9.46E-03
CS-136	2.26E-04
CS-137	2.28E-02
CS-138	3.73E-05
LA-140	2.40E-04

Total Liquid Tritium Released	3.33E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	6.54E+06 liters
Volume of Dilution Water Used During Period	1.08E+12 liters

Installation: Indian Point
Unit No.(s): 3

Location: 3 Mi SW Peekskill, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-286
Thermal Power(MWH): 1.57E+07
Commercial Operation: 08/30/76
Cooling Water Source: Hudson River

Licensee: Power Authority of the State of NY
Licensed Power(MWT): 3.02E+03
Net Electrical Power(MWH): 5.03E+06
Initial Criticality: 04/06/76

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
13	Truck	Alaron, Wampum, PA
11	Truck	Barnwell, SC
1	Truck	Quadrex, Oak Ridge, TN
5	Truck	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A			
	CO-58	1.40E+01	7.55E+00
	CO-60	1.10E+01	2.12E+01
	CR-51	1.50E+00	9.19E-01
	CS-134	2.00E+01	2.12E+01
	CS-137	1.80E+01	1.80E+01
	FE-55	2.60E+01	1.96E+01
	MN-54	1.40E+00	8.84E-01
	NI-63	5.90E+00	9.19E+00
B			
	CO-58	5.00E+00	5.00E+00
	CO-60	2.80E+01	2.80E+01
	CS-137	2.00E+00	2.00E+00
	FE-55	5.90E+01	5.90E+01
	NI-63	5.00E+00	5.00E+00
D			
	CO-58	5.00E+00	5.00E+00
	CO-60	2.80E+01	2.80E+01
	CS-137	2.00E+00	2.00E+00
	FE-55	5.90E+01	5.90E+01
	NI-63	5.00E+00	5.00E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.51E+01 Ci 1.26E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.37E+01 Ci 9.81E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Dry compressible, contaminated equip.	m3 5.97E+02 Ci 1.36E+01	before volume reduction

Installation: Kewaunee
Unit No.(s): 1

Location: 27 Mi ESE Green Bay, WI

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-305
Thermal Power(MWH): 1.24E+07
Commercial Operation: 06/16/74
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Public Service
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.90E+06
Initial Criticality: 03/07/74

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	9.41E-01
CO-58	1.30E-06
CO-60	7.51E-06
KR-85	7.65E-02
RB-88	1.38E-07
NB-95	1.06E-06
SN-113	6.40E-08
I-131	1.15E-06
XE-131M	5.32E-01
I-132	3.29E-09
I-133	1.72E-09
XE-133	7.34E-01
XE-133M	4.88E-05
XE-135	2.84E-02
XE-135M	4.34E-06
CS-137	9.69E-07
Unidentified	3.23E-03

Total Airborne Tritium Released 5.98E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.53E-05
CR-51	2.02E-02
MN-54	3.01E-03
FE-55	1.61E-02
NI-56	2.56E-04
CO-57	1.17E-04
CO-58	9.01E-02
FE-59	3.05E-03
CO-60	3.47E-02
NB-95	5.75E-03
ZR-95	3.98E-03
ZR-97	1.17E-04
AG-110M	1.92E-02
SN-113	2.36E-03
SB-122	1.53E-05
SB-124	1.91E-03
SB-125	2.72E-03
I-133	3.24E-05
XE-133M	1.22E-04
CS-134	6.92E-04
CS-137	8.02E-04
W-187	6.87E-04

Total Liquid Tritium Released	3.79E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.21E+06 liters
Volume of Dilution Water Used During Period	3.57E+10 liters

Installation: Kewaunee
Unit No.(s): 1

Location: 27 Mi ESE Green Bay, WI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-305
Thermal Power(MWH): 1.24E+07
Commercial Operation: 06/16/74
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Public Service
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.90E+06
Initial Criticality: 03/07/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
5	CNSI 14-190H Cask	Barnwell, SC
2	CNSI Conventional Van	Barnwell, SC
2	Containers on Flatbed Trailers	Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	1.18E-01	2.64E-01
CO-57	1.88E-01	1.58E-01
CO-58	1.53E+01	9.79E+00
CO-60	4.59E+01	4.41E+01
CS-134	7.63E+00	8.96E+00
CS-137	5.78E+00	1.02E+01
FE-55	3.18E+00	3.86E+00
MN-54	2.16E+00	2.17E+00
NB-94	3.42E-02	2.48E-02
NI-63	1.86E+01	1.94E+01
PU-241	1.25E-02	8.49E-03
SB-125	7.91E-01	1.00E+00
TC-99	1.26E-04	8.54E-05
TRU	6.30E-03	4.31E-03

B

C-14		1.92E+00
CM-242	6.63E-04	
CO-57	9.64E-02	3.02E-01
CO-58	1.51E+01	5.46E+01
CO-60	2.15E+01	6.20E+00
CS-134	1.61E-01	
CS-137	1.71E-01	
FE-55	4.72E+01	1.89E+01
MN-54	9.29E-01	8.30E-01
NB-95	3.11E-01	4.31E+00
NI-63	1.19E+01	8.80E+00
PU-241	2.02E+00	
SB-125	2.90E-01	1.68E+00
SN-113	1.71E-01	4.50E-01
TRU	7.37E-03	4.05E-02
ZR-95	1.28E-01	1.89E+00

D

AG-110M	1.04E-01
C-14	1.39E-03

Installation: Kewaunee
Unit No.(s): 1

Location: 27 Mi ESE Green Bay, WI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec
D

CM-242	3.75E+01
CO-57	4.38E-02
CO-58	8.99E-01
CO-60	5.75E+01
CS-134	1.20E-01
CS-137	5.14E-01
FE-55	2.41E+00
MN-54	4.16E-01
NB-94	1.98E-01
NB-95	2.49E-02
PU-241	5.50E-02
SB-125	3.66E-01
SN-113	3.61E-02
SR-90	4.86E-03
TC-99	1.13E-03
TRU	1.76E-03
ZN-65	1.46E-03
ZR-95	2.54E-03

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.79E+01 Ci 3.31E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 4.67E+01 Ci 1.15E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)		
Contam.scrap,filter elements,sealand	m3 4.60E+01 Ci 2.18E+01	

Installation: LaCrosse
Unit No.(s): 1

Location: 19 Mi S LaCrosse, WI

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-409
Thermal Power(MWH):
Commercial Operation: 11/01/69
Cooling Water Source: Mississippi River

Licensee: Dairyland Power
Licensed Power(MWT): 1.65E+02
Net Electrical Power(MWH):
Initial Criticality: 07/11/67

Airborne Effluents

Nuclide Released	Activity (Ci)
MN-54	2.15E-08
CO-58	1.00E-08
CO-60	3.15E-06
ZN-65	1.73E-07
SR-89	1.75E-04
CS-137	1.60E-06

Total Airborne Tritium Released 4.91E-01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
MN-54	3.23E-03
FE-55	2.30E-02
CO-60	2.90E-02
SR-89	7.57E-04
SR-90	4.25E-04
CS-134	3.05E-05
CS-137	1.21E-02

Total Liquid Tritium Released	7.74E-01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.27E+05 liters
Volume of Dilution Water Used During Period	8.35E+09 liters

Installation: LaCrosse
Unit No.(s): 1

Location: 19 Mi S LaCrosse, WI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-409
Thermal Power(MWH):
Commercial Operation: 11/01/69
Cooling Water Source: Mississippi River

Licensee: Dairyland Power
Licensed Power(MWT): 1.65E+02
Net Electrical Power(MWH):
Initial Criticality: 07/11/67

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
7	Sole Use	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Annual

B	
CO-60	4.27E+01
CS-137	2.10E+00
FE-55	4.73E+01
MN-54	1.90E+00
NI-63	5.60E+00
PU-241	4.00E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 Ci	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.70E+01 m3 4.59E+00 Ci 7.44E-01	before processing burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: LaSalle
Unit No.(s): 1&2

Location: 11 Mi SE Ottawa, IL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-373
Thermal Power(MWH): 2.64E+07
Commercial Operation: 01/01/84
Cooling Water Source: Reservoir

Licensee: Commonwealth Edison Company
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 8.64E+06
Initial Criticality: 06/21/82

Unit Number: 2 Type: BWR
Docket Number: 50-374
Thermal Power(MWH): 1.91E+07
Commercial Operation: 10/19/84
Cooling Water Source: Reservoir

Licensee: Commonwealth Edison Company
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 6.18E+06
Initial Criticality: 03/10/84

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	8.41E+00
MN-54	7.15E-06
CO-60	1.22E-03
KR-85	6.68E+02
KR-85M	4.17E+00
AG-110M	4.47E-05
I-131	2.17E-03
I-132	2.02E-03
I-133	1.98E-02
XE-133	6.09E+00
I-134	2.03E-03
I-135	3.60E-03
XE-135	1.96E-02

Total Airborne Tritium Released 1.70E-01 Ci

Installation: LaSalle
Unit No.(s): 1

Location: 11 Mi SE Ottawa, IL

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-373

Thermal Power(MWH): 2.64E+07

Commercial Operation: 01/01/84

Cooling Water Source: Reservoir

Licensee: Commonwealth Edison Company

Licensed Power(MWT): 3.32E+03

Net Electrical Power(MWH): 8.64E+06

Initial Criticality: 06/21/82

Liquid Effluents

Nuclide Released	Activity (Ci)
MN-54	7.22E-04
FE-55	9.74E-04
CO-60	3.77E-03
SR-89	2.51E-06
SR-90	1.52E-07
CS-134	2.03E-04
CS-137	2.98E-04

Total Liquid Tritium Released	1.83E-01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.99E+05 liters
Volume of Dilution Water Used During Period	1.73E+08 liters

Installation: LaSalle
Unit No.(s): 2

Location: 11 Mi SE Ottawa, IL

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-374

Thermal Power(MWH): 1.91E+07

Commercial Operation: 10/19/84

Cooling Water Source: Reservoir

Licensee: Commonwealth Edison Company

Licensed Power(MWT): 3.32E+03

Net Electrical Power(MWH): 6.18E+06

Initial Criticality: 03/10/84

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

MN-54	1.22E-03
-------	----------

FE-55	1.14E-02
-------	----------

CO-58	1.85E-05
-------	----------

CO-60	5.33E-03
-------	----------

SR-89	1.96E-06
-------	----------

SR-90	1.54E-07
-------	----------

CS-134	2.56E-04
--------	----------

CS-137	3.97E-04
--------	----------

Total Liquid Tritium Released	1.91E-01 Ci
-------------------------------	-------------

Volume of Liquid Waste Released (Prior to Dilution)	2.08E+05 liters
---	-----------------

Volume of Dilution Water Used During Period	1.39E+08 liters
---	-----------------

Installation: LaSalle
Unit No.(s): 1&2

Location: 11 Mi SE Ottawa, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-373
Thermal Power(MWH): 2.64E+07
Commercial Operation: 01/01/84
Cooling Water Source: Reservoir

Licensee: Commonwealth Edison Company
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 8.64E+06
Initial Criticality: 06/21/82

Unit Number: 2 Type: BWR
Docket Number: 50-374
Thermal Power(MWH): 1.91E+07
Commercial Operation: 10/19/84
Cooling Water Source: Reservoir

Licensee: Commonwealth Edison Company
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 6.18E+06
Initial Criticality: 03/10/84

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
14	Truck	Barnwell, SC
37	Truck	Beatty, NV
1	Truck	Channahon, IL
38	Truck	Oak Ridge, TN
2	Truck	Waltz Mill, PA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-60	3.41E+01	2.61E+01
FE-55	4.82E+01	6.07E+01
MN-54	1.25E+01	9.92E+00
B		
CO-60	3.07E+01	
CR-51	2.59E+01	1.40E+01
FE-55		4.50E+01
FE-59		1.60E+01
MN-54	2.72E+01	1.50E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.90E+02 Ci 2.89E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 7.14E+02 Ci 5.66E+01	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Limerick
Unit No.(s): 1&2

Location: 21 Mi NW Philadelphia, PA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-352
Thermal Power(MWH): 1.82E+07
Commercial Operation: 02/01/86
Cooling Water Source: Schuylkill River

Licensee: Philadelphia Electric Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 5.62E+06
Initial Criticality: 12/22/84

Unit Number: 2 Type: BWR
Docket Number: 50-353
Thermal Power(MWH): 2.29E+07
Commercial Operation: 01/08/90
Cooling Water Source: Schuylkill River

Licensee: Philadelphia Electric Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 7.23E+06
Initial Criticality: 08/12/89

Airborne Effluents

Nuclide Released	Activity (Ci)
KR-85	1.54E-03
I-131	3.36E-05
I-133	1.47E-03
XE-133	1.57E+01
XE-135	1.34E+01

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	4.15E-05
CR-51	3.72E-02
MN-54	3.77E-02
FE-55	2.32E-01
CO-58	1.55E-03
FE-59	2.51E-04
CO-60	5.56E-03
ZN-65	2.38E-02
AS-76	3.00E-06
SR-90	2.57E-04
TC-99M	4.72E-05
XE-133	1.61E-02
CS-134	1.62E-03
XE-135	1.34E-02
CS-137	3.23E-03

Total Liquid Tritium Released	3.02E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.95E+07 liters
Volume of Dilution Water Used During Period	1.42E+10 liters

Installation: Limerick
Unit No.(s): 1

Location: 21 Mi NW Philadelphia, PA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-352
Thermal Power(MWH): 1.82E+07
Commercial Operation: 02/01/86
Cooling Water Source: Schuylkill River

Licensee: Philadelphia Electric Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 5.62E+06
Initial Criticality: 12/22,84

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.12E-04
CR-51	1.86E-04
XE-133	4.47E-01
XE-135	3.27E+00

Installation: Limerick
Unit No.(s): 2

Location: 21 Mi NW Philadelphia, PA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-353
Thermal Power(MWH): 2.29E+07
Commercial Operation: 01/08/90
Cooling Water Source: Schuylkill River

Licensee: Philadelphia Electric Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 7.23E+06
Initial Criticality: 08/12/89

Airborne Effluents

Nuclide Released	Activity (Ci)
MN-54	1.92E-04
CO-58	3.12E-05
FE-59	6.72E-05
CO-60	1.55E-04
ZN-65	9.86E-05
KR-85	7.34E-04
XE-133	3.58E-01
XE-135	1.09E+00

Installation: Limerick
Unit No.(s): 1&2

Location: 21 Mi NW Philidelphia, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-352
Thermal Power(MWH): 1.82E+07
Commercial Operation: 02/01/86
Cooling Water Source: Schuylkill River

Licensee: Philadelphia Electric Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 5.62E+06
Initial Criticality: 12/22/84

Unit Number: 2 Type: BWR
Docket Number: 50-353
Thermal Power(MWH): 2.29E+07
Commercial Operation: 01/08/90
Cooling Water Source: Schuylkill River

Licensee: Philadelphia Electric Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 7.23E+06
Initial Criticality: 08/12/89

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
99	Truck	Barnwell, SC
32	Truck	Quadrex, Barnwell, SC
49	Truck	SEG, Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	7.14E-02	7.41E-02
CO-58	3.53E+00	2.83E+00
CO-60	3.21E+00	3.48E+00
CR-51	5.25E+01	4.48E+01
CS-134	6.28E+00	5.35E+00
CS-137	9.36E+00	8.59E+00
FE-55	1.33E+00	1.70E+00
H-3	1.98E-02	2.07E-02
MN-54	7.99E-01	1.91E+00
NI-63	2.64E-02	1.11E-01
SR-90	1.76E-02	9.56E-03
ZN-65	2.28E+01	3.06E+01

B

AG-110M		2.00E-02
C-14	2.00E-01	3.10E-01
CE-141	8.00E-02	1.20E-01
CO-58	3.28E+00	1.74E+00
CO-60	7.48E+00	4.25E+00
CR-51	1.11E+01	6.30E+00
CS-134	9.19E+00	8.54E+00
CS-137	1.49E+01	1.42E+01
FE-55	2.76E+00	2.12E+00
H-3	4.00E-02	2.60E-01
MN-54	1.86E+00	9.50E-01
NB-95	5.00E-02	4.10E-01
NI-63	1.40E-01	2.30E-01
SR-89	4.40E-01	7.20E-01

Installation: Limerick
Unit No.(s): 1&2

Location: 21 Mi NW Phildelphia, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B			
	SR-90	4.00E-02	
	ZN-65	4.84E+01	6.03E+01
D			
	CO-60		5.32E+00
	CS-134		1.44E+01
	CS-137		3.13E+01
	MN-54		3.85E+00
	SR-90		3.00E-02
	ZN-65		4.51E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 6.11E+02 C1 1.23E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 7.30E+01 C1 6.70E+00	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe) CRD Filters & Trash	m3 2.10E+00 C1 2.35E+00	

Installation: Maine Yankee
Unit No.(s): 1

Location: 3.9 Mi S Wicasset, ME

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-309
Thermal Power(MWH): 1.50E+07
Commercial Operation: 12/28/72
Cooling Water Source: Back River

Licensee: Maine Yankee Atomic Power
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 4.86E+06
Initial Criticality: 10/23/72

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.50E-01
CR-51	2.80E-04
MN-54	3.45E-05
CO-57	1.14E-05
CO-58	6.65E-04
CO-60	1.09E-02
KR-85	1.50E-01
KR-85M	8.42E-01
KR-87	4.24E-01
KR-88	5.24E-01
NB-95	6.94E-07
CD-109	1.16E-05
AG-110M	3.07E-05
SB-125	1.60E-04
I-131	4.41E-03
XE-131M	7.20E+00
I-132	3.25E-03
I-133	1.03E-03
XE-133	9.15E+02
XE-133M	5.47E+00
CS-134	5.84E-04
I-134	3.02E-06
I-135	5.55E-03
XE-135	1.62E+01
XE-135M	3.04E-01
CS-137	1.00E-03
XE-138	1.72E-01
CE-144	3.01E-05

Total Airborne Tritium Released 3.74E+01 Ci

Installation: Maine Yankee
Unit No.(s): 1

Location: 3.9 Mi S Wicasset, ME

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-309
Thermal Power(MWH): 1.50E+07
Commercial Operation: 12/28/72
Cooling Water Source: Back River

Licensee: Maine Yankee Atomic Power
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 4.86E+06
Initial Criticality: 10/23/72

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CR-51	4.79E-03
MN-54	1.81E-04
FE-55	1.97E-02
CO-57	3.28E-05
CO-58	2.23E-02
CO-60	1.21E-02
ZN-65	2.66E-06
BR-84	3.35E-06
KR-85	7.10E-03
KR-85M	1.80E-04
SR-85	1.43E-05
KR-87	2.58E-05
KR-88	9.90E-05
SR-89	1.94E-03
NB-95	2.69E-04
ZR-NB-95	6.36E-05
TC-99M	1.23E-03
RU-103	9.44E-07
CD-109	2.50E-04
AG-110M	4.48E-03
SN-113	2.71E-05
SB-122	3.74E-04
SB-124	4.42E-02
SB-125	2.57E-02
I-131	2.79E-02
TE-131	9.17E-07
XE-131M	9.14E-02
I-132	1.65E-05
I-133	1.99E-03
XE-133	4.50E+00
XE-133M	2.08E-02
CS-134	2.03E-03
XE-135	4.74E-03
XE-135M	8.67E-05
CS-137	1.63E-02
BA-LA-140	6.59E-04
CE-141	5.52E-05
LA-142	2.31E-07
CE-144	2.46E-07
HG-203	9.11E-05
Unidentified	1.93E-04

Total Liquid Tritium Released	2.43E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	6.03E+07 liters
Volume of Dilution Water Used During Period	6.43E+11 liters

Installation: Maine Yankee
Unit No.(s): 1

Location: 3.9 Mi S Wicasset, ME

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-309
Thermal Power(MWH): 1.50E+07
Commercial Operation: 12/28/72
Cooling Water Source: Back River

Licensee: Maine Yankee Atomic Power
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 4.86E+06
Initial Criticality: 10/23/72

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
22	Trucking over highway	CNSI, Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14		9.50E-01
CD-109		1.43E+00
CO-58		5.55E+01
CO-60	1.53E+01	1.91E+01
CS-134	8.90E+00	3.26E+00
CS-137	6.15E+01	4.40E+00
FE-55	6.20E+00	7.96E+00
MN-54		1.02E+00
NI-63	1.40E+00	1.77E+00
SB-124		2.84E+00
SB-125	1.40E+00	
SR-90	1.70E+00	

B

AG-110M	1.20E+00	
CE-141	1.60E+00	
CO-58	1.13E+01	8.58E+00
CO-60	2.20E+01	2.18E+01
CR-51		3.09E+00
CS-134	2.50E+00	
CS-137	1.03E+01	1.11E+01
FE-55	2.53E+01	2.44E+01
NI-63	1.42E+01	2.19E+01
RU-106		4.36E+00
SB-125	1.90E+00	
ZR-95	5.10E+00	1.24E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.16E+01 Ci 1.72E+02	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.58E+02 Ci 1.26E+01	burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: McGuire
Unit No.(s): 1

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-369
Thermal Power(MWH): 1.48E+07
Commercial Operation: 12/01/81
Cooling Water Source: Lake Norman

Licensee: Duke Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.73E+06
Initial Criticality: 08/08/81

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	2.79E-09
CL-38	3.15E-08
K-40	2.08E-05
AR-41	1.90E+00
CR-51	4.02E-05
CO-58	1.15E-04
CO-60	1.79E-04
BR-82	4.51E-08
KR-85	2.94E+01
KR-85M	9.53E-01
KR-87	2.62E-01
KR-88	1.15E+00
RB-88	5.38E-05
RB-89	4.43E-07
SR-90	1.02E-06
SR-92	1.85E-09
MO-99	6.09E-09
TC-99M	4.42E-09
I-130	1.56E-08
I-131	6.57E-04
XE-131M	5.35E+00
I-132	9.15E-05
I-133	6.06E-04
XE-133	4.61E+02
XE-133M	4.29E+00
CS-134	7.47E-09
I-134	3.34E-06
I-135	1.28E-05
XE-135	1.40E+01
XE-135M	5.33E-02
CS-136	1.89E-09
CS-137	9.09E-06
CS-138	2.17E-06
XE-138	1.50E-02
BA-139	1.65E-07
PB-214	9.71E-07

Total Airborne Tritium Released 2.50E+01 Ci

Installation: McGuire
Unit No.(s): 1

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-369
Thermal Power(MWH): 1.48E+07
Commercial Operation: 12/01/81
Cooling Water Source: Lake Norman

Licensee: Duke Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.73E+06
Initial Criticality: 08/08/81

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	1.48E-03
K-40	2.99E-04
AR-41	8.09E-05
CR-51	1.11E-01
MN-54	7.05E-02
FE-55	5.41E-01
MN-56	2.95E-05
CO-57	3.25E-03
CO-58	5.23E-01
FE-59	6.51E-03
CO-60	4.48E-01
ZN-65	1.24E-03
BR-82	2.80E-04
BR-84	5.49E-06
KR-85	3.17E-04
KR-85M	2.13E-04
RB-86	1.26E-05
KR-87	6.89E-06
KR-88	4.58E-05
RB-88	8.50E-04
SR-89	1.23E-04
SR-90	1.03E-05
SR-91	1.64E-06
Y-91M	1.29E-06
SR-92	6.42E-04
Y-93	9.44E-05
NB-95	3.55E-02
ZR-95	1.77E-02
NB-97	1.25E-03
ZR-97	1.05E-04
MO-99	1.69E-04
TC-99M	9.09E-04
RU-103	1.38E-03
RU-106	9.60E-03
AG-110M	1.71E-02
SN-113	6.25E-03
CD-115	3.21E-05
IN-115M	1.48E-06
SB-122	5.60E-04
SB-124	4.27E-03
SB-125	1.02E-01
SB-126	3.42E-05
I-131	1.96E-02
XE-131M	2.48E-03

Installation: McGuire
Unit No.(s): 1

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
I-132	1.81E-03
TE-132	1.87E-04
I-133	2.40E-02
XE-133	8.85E-01
XE-133M	1.40E-02
CS-134	1.50E-02
I-134	1.33E-04
I-135	9.11E-03
XE-135	7.08E-02
XE-135M	1.68E-03
CS-136	5.17E-05
CS-137	2.18E-02
CS-138	2.88E-04
XE-138	5.13E-06
BA-140	8.87E-05
LA-140	1.32E-03
CE-141	1.49E-04
CE-143	3.16E-06
CE-144	4.78E-03
W-187	4.69E-05
NP-239	1.89E-05

Total Liquid Tritium Released	4.58E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	8.43E+06 liters *
Volume of Dilution Water Used During Period	3.05E+12 liters *

*These volumes represent the total dilution flow for both McGuire 1&2 since there is one primary release point for the site.

Installation: McGuire
Unit No.(s): 2

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-370
Thermal Power(MWH): 1.93E+07
Commercial Operation: 03/01/84
Cooling Water Source: Lake Norman

Licensee: Duke Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.46E+06
Initial Criticality: 05/08/83

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	2.79E-09
CL-38	3.15E-08
K-40	2.08E-05
AR-41	1.90E+00
CR-51	4.02E-05
CO-58	1.15E-04
CO-60	1.79E-04
BR-82	4.51E-08
KR-85	2.94E+01
KR-85M	9.53E-01
KR-87	2.62E-01
KR-88	1.15E+00
RB-88	5.38E-05
RB-89	4.43E-07
SR-90	1.02E-06
SR-92	1.85E-09
MO-99	6.09E-09
TC-99M	4.42E-09
I-130	1.56E-08
I-131	6.57E-04
XE-131M	5.35E+00
I-132	9.15E-05
I-133	6.06E-04
XE-133	4.61E+02
XE-133M	4.29E+00
CS-134	7.47E-09
I-134	3.34E-06
I-135	1.28E-05
XE-135	1.40E+01
XE-135M	5.33E-02
CS-136	1.89E-09
CS-137	9.09E-06
CS-138	2.17E-06
XE-138	1.50E-02
BA-139	1.65E-07
PB-214	9.71E-07

Total Airborne Tritium Released 2.50E+01 Ci

Installation: McGuire
Unit No.(s): 2

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-370
Thermal Power(MWH): 1.93E+07
Commercial Operation: 03/01/84
Cooling Water Source: Lake Norman

Licensee: Duke Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.46E+06
Initial Criticality: 05/08/83

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.48E-03
K-40	2.99E-04
AR-41	8.09E-05
CR-51	1.11E-01
MN-54	7.05E-02
FE-55	5.41E-01
MN-56	2.95E-05
CO-57	3.25E-03
CO-58	5.23E-01
FE-59	6.51E-03
CO-60	4.48E-01
ZN-65	1.24E-03
BR-82	2.80E-04
BR-84	5.49E-06
KR-85	3.17E-04
KR-85M	2.13E-04
RB-86	1.26E-05
KR-87	6.89E-06
KR-88	4.58E-05
RB-88	8.50E-04
SR-89	1.23E-04
SR-90	1.03E-05
SR-91	1.64E-06
Y-91M	1.29E-06
SR-92	6.42E-04
Y-93	9.44E-05
NB-95	3.55E-02
ZR-95	1.77E-02
NB-97	1.25E-03
ZR-97	1.05E-04
MO-99	1.69E-04
TC-99M	9.09E-04
RU-103	1.38E-03
RU-106	9.60E-03
AG-110M	1.71E-02
SN-113	6.25E-03
CD-115	3.21E-05
IN-115M	1.48E-06
SB-122	5.60E-04
SB-124	4.27E-03
SB-125	1.02E-01
SB-126	3.42E-05
I-131	1.96E-02
XE-131M	2.48E-03

Installation: McGuire
Unit No.(s): 2

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
I-132	1.81E-03
TE-132	1.87E-04
I-133	2.40E-02
XE-133	8.85E-01
XE-133M	1.40E-02
CS-134	1.50E-02
I-134	1.33E-04
I-135	9.11E-03
XE-135	7.08E-02
XE-135M	1.68E-03
CS-136	5.17E-05
CS-137	2.18E-02
CS-138	2.88E-04
XE-138	5.13E-06
BA-140	8.87E-05
LA-140	1.32E-03
CE-141	1.49E-04
CE-143	3.16E-06
CE-144	4.78E-03
W-187	4.69E-05
NP-239	1.89E-05

Total Liquid Tritium Released	4.58E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	8.43E+06 liters *
Volume of Dilution Water Used During Period	3.05E+12 liters *

*These volumes represent the total dilution flow for both McGuire 1&2 since there is one primary release point for the site.

Installation: McGuire
Unit No.(s): 1&2

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1980
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-369
Thermal Power(MWH): 1.48E+07
Commercial Operation: 12/01/81
Cooling Water Source: Lake Norman

Licensee: Duke Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.73E+06
Initial Criticality: 08/08/81

Unit Number: 2 Type: PWR
Docket Number: 50-370
Thermal Power(MWH): 1.93E+07
Commercial Operation: 03/01/84
Cooling Water Source: Lake Norman

Licensee: Duke Power Co.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.46E+06
Initial Criticality: 05/08/83

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
---------------------	------------------------	-------------

46

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec
A

AG-110M	1.13E-02	
BA-140		8.67E-07
C-14	1.94E-01	9.00E-02
CE-144	2.02E-04	7.81E-06
CM-242	3.75E-04	1.00E-03
CO-57	1.62E-01	1.00E-01
CO-58	4.13E+00	1.79E+01
CO-60	3.86E+01	1.82E+01
CR-51		1.79E-01
CS-134	6.92E+00	1.99E+01
CS-137	1.42E+01	2.45E+01
FE-55	1.15E+01	5.41E+00
FE-59		5.00E-03
H-3	3.49E-02	1.68E-03
I-131	1.81E-04	1.31E-06
MN-54	5.07E+00	4.07E+00
NB-95	3.83E-01	7.00E-02
NI-63	1.71E+01	8.08E+00
PB-212		2.62E-07
PB-214		3.75E-07
PU-241	9.40E-03	2.00E-02
RU-106	1.56E-04	6.94E-06
SB-125	1.19E+00	1.30E+00
SN-113	1.84E-05	8.67E-07
SR-90	4.71E-02	8.00E-02
TE-125M	3.91E-02	5.00E-02
TRU	9.40E-04	2.02E-03
ZN-65	2.77E-05	
ZR-95	2.62E-01	3.00E-02

Installation: McGuire
Unit No.(s): 1&2

Location: 17 Mi N of Charlotte, NC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

C-14	2.00E-02	2.00E-02
CM-242	1.00E-02	1.00E-02
CO-58	3.48E+01	3.48E+01
CO-60	3.20E+01	3.20E+01
CS-137	8.40E-01	8.40E-01
FE-55	2.33E+01	2.33E+01
MN-54	5.36E+00	5.36E+00
NI-63	3.36E+00	3.36E+00
PU-241	3.00E-01	3.00E-01
SR-90	3.00E-02	3.00E-02
TRU	1.00E-02	1.00E-02

D

AG-110M	1.36E+00
C-14	2.00E-02
CE-144	2.43E+00
CM-242	3.00E-02
CO-58	3.65E+00
CO-60	3.33E+01
CS-137	1.06E+00
FE-55	4.47E+01
MN-54	3.27E+00
NB-95	1.30E+00
NI-63	4.87E+00
PU-241	7.20E-01
RU-106	2.15E+00
SB-125	1.10E+00
SR-90	1.00E-02
TRU	1.00E-02

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.27E+02 Ci 9.19E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.25E+02 Ci 2.68E+01	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Dewatered Mechanical Filters	m3 1.10E+01 Ci 3.50E+01	

Installation: Millstone
Unit No.(s): 1

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-245
Thermal Power(MWH): 1.56E+07
Commercial Operation: 03/01/71
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 2.01E+03
Net Electrical Power(MWH): 5.09E+06
Initial Criticality: 10/26/70

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.64E+00
CR-51	1.74E-04
MN-54	2.73E-05
CO-58	2.54E-05
CO-60	2.51E-04
ZN-65	5.34E-04
KR-85M	1.79E+00
KR-87	9.15E+00
KR-88	5.60E+00
SR-89	3.51E-04
SR-90	1.38E-06
I-131	7.31E-04
I-133	1.69E-03
XE-133	4.29E+01
XE-135	1.29E+01
XE-135M	9.54E+00
CS-137	1.20E-04
XE-138	3.33E+01
BA-140	3.85E-04

Total Airborne Tritium Released 3.86E+01 Ci

Installation: Millstone
Unit No.(s): 1

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-245
Thermal Power(MWH): 1.56E+07
Commercial Operation: 03/01/71
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 2.01E+03
Net Electrical Power(MWH): 5.09E+06
Initial Criticality: 10/26/70

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	2.20E-03
MN-54	9.17E-03
FE-55	3.85E-02
CO-58	2.79E-04
FE-59	1.10E-04
CO-60	6.00E-02
ZN-65	1.15E-02
SR-89	2.03E-05
SR-90	7.86E-05
TC-99M	7.14E-05
SB-125	3.67E-06
I-131	2.01E-04
I-132	8.06E-06
I-133	1.66E-04
XE-133	9.15E-04
CS-134	1.57E-05
I-135	6.18E-05
XE-135	7.96E-04
XE-135M	9.54E-05
CS-137	1.64E-02

Total Liquid Tritium Released	2.02E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.20E+07 liters
Volume of Dilution Water Used During Period	8.14E+11 liters

Installation: Millstone
Unit No.(s): 1

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-245
Thermal Power(MWH): 1.56E+07
Commercial Operation: 03/01/71
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 2.01E+03
Net Electrical Power(MWH): 5.09E+06
Initial Criticality: 10/26/70

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
37	Truck	CNSI, Barnwell, SC
3	Truck	Quadrex, Oak Ridge, TN
1	Truck	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	8.00E-02	8.00E-02
AM-241	2.00E-02	
BA-140	4.10E-01	2.00E-02
C-14	2.40E-01	1.30E-01
CE-141	8.00E-02	
CM-244	1.00E-02	
CO-58	2.00E-02	1.20E-01
CO-60	1.28E+01	9.89E+00
CR-51		2.00E-02
CS-134	9.00E-02	2.00E-02
CS-137	1.10E+01	5.88E+00
FE-55	1.03E+01	3.48E+01
H-3	7.00E-01	2.00E-02
I-131	3.00E-02	2.00E-02
LA-140	7.00E-02	
MN-54	1.43E+00	5.56E+00
NI-59	3.00E-01	
NI-63	1.46E+00	5.10E-01
PU-241	9.90E-01	3.00E-02
SB-125		3.00E-02
SR-89	4.00E-02	5.00E-02
SR-90	2.00E-02	6.00E-02
ZN-65	6.00E+01	4.25E+01

B

AM-241	3.40E-01	
CO-58	1.00E-02	1.71E+00
CO-60	2.20E+01	1.88E+01
CS-134	1.10E-01	7.02E-03
CS-137	9.36E+00	1.64E+00
FE-55	5.31E+01	7.02E+01
H-3	7.00E-02	2.20E-01
MN-54	2.78E+00	2.45E+00
NI-63	4.36E+00	3.89E+00
PU-238	1.00E-02	

Installation: Millstone
Unit No.(s): 1

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

PU-241	3.00E-02	
SR-90	1.00E-02	
ZN-65	7.80E+00	1.13E+00

C

CO-58	5.70E-01	
CO-60	3.42E+01	
CR-51	7.00E-02	
FE-55	5.76E+01	
FE-59	2.00E-02	
HF-175	8.00E-01	
HF-181	1.26E+00	
MN-54	3.29E+00	
NI-59	2.00E-02	
NI-63	2.21E+00	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.84E+02	non-compacted
	Ci 6.35E+02	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.05E+02	compacted
	Ci 1.94E+01	burial volume
C. Irradiated Components, Control Rods, etc.	m3 4.63E+00	non-compacted
	Ci 3.34E+04	burial volume
D. Other (describe)	m3	
	Ci	

Installation: Millstone
Unit No.(s): 2

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-336
Thermal Power(MWH): 1.69E+07
Commercial Operation: 12/26/75
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 5.30E+06
Initial Criticality: 10/17/75

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.50E+00
CO-58	3.62E-06
KR-85	7.26E+01
KR-85M	3.10E+00
KR-88	2.86E+00
RB-88	2.39E-04
I-131	2.08E-02
XE-131M	4.54E+01
I-133	2.03E-02
XE-133	2.67E+03
XE-133M	1.41E+01
XE-135	8.52E+01

Total Airborne Tritium Released 1.00E+02 Ci

Installation: Millstone
Unit No.(s): 2

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-336
Thermal Power(MWH): 1.69E+07
Commercial Operation: 12/26/75
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 5.30E+06
Initial Criticality: 10/17/75

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	1.72E-03
CR-51	4.01E-02
MN-54	1.41E-02
FE-55	3.76E+00
CO-57	1.37E-03
CO-58	7.88E-01
CO-60	6.00E-01
KR-85	8.09E-01
KR-85M	7.11E-04
SR-87M	6.34E-05
KR-88	8.60E-04
SR-89	6.79E-01
SR-90	3.23E-01
SR-92	1.14E-02
Y-93	8.09E-05
NB-95	4.07E-03
NB-97	5.15E-02
MO-99	5.45E-04
TC-99M	1.10E-03
AG-110M	3.68E-02
SB-124	9.10E-02
SB-125	1.70E-01
I-131	1.02E-01
XE-131M	7.14E-01
I-132	1.82E-02
I-133	4.08E-02
XE-133	3.94E+01
XE-133M	6.61E-01
CS-134	4.31E-01
I-135	1.17E-02
XE-135	2.98E-01
XE-135M	1.11E-02
CS-136	8.69E-03
CS-137	1.57E+00
BA-139	8.86E-05
LA-140	3.05E-03
LA-141	2.73E-03
CE-143	1.05E-04
CE-144	4.24E-04

Total Liquid Tritium Released	5.28E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.49E+08 liters
Volume of Dilution Water Used During Period	9.82E+11 liters

Installation: Millstone
Unit No.(s): 2

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-336
Thermal Power(MWH): 1.69E+07
Commercial Operation: 12/26/75
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 5.30E+06
Initial Criticality: 10/17/75

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
11	Truck	CNSI, Barnwell, SC
9	Truck	Quadrex, Oak Ridge, TN
7	Truck	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M		9.00E-02
C-14		3.88E+00
CO-58		1.82E+00
CO-60		2.43E+02
CS-134		3.40E-01
CS-137		1.18E+00
FE-55		6.07E+01
H-3		2.00E-02
NI-63		7.55E+00
PU-241		1.20E-01
SR-89		1.00E-02
SR-90		1.00E-02

B

AM-241	2.94E-04	4.28E-04
C-14	8.81E-04	3.55E+00
CM-242	5.89E-04	8.55E-04
CM-244	2.94E-04	8.55E-05
CO-58	3.65E+01	2.68E+00
CO-60	1.76E+01	3.74E+01
CS-134	1.17E+00	2.82E+00
CS-137	2.10E+00	1.11E+01
FE-55	1.04E+01	2.36E+01
H-3	2.65E-03	6.17E-02
I-131		4.88E-03
MN-54	6.76E-03	4.97E-01
NI-63	3.22E+01	1.88E+01
ZN-65		2.59E-02

Installation: Millstone
Unit No.(s): 2

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.54E+00 C1 4.87E+00	compacted burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.57E+02 C1 4.47E+00	compacted burial volume
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Millstone
Unit No.(s): 3

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-423
Thermal Power(MWH): 2.52E+07
Commercial Operation: 04/23/86
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 8.22E+06
Initial Criticality: 01/23/86

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	1.09E-05
MN-54	7.59E-06
KR-85	5.53E+00
KR-85M	5.16E-01
KR-87	6.06E-02
SR-89	4.08E-08
SR-90	1.60E-08
SB-125	7.11E-06
I-131	2.38E-03
XE-131M	7.78E-02
I-133	2.38E-03
XE-133	1.84E+02
XE-133M	1.87E-02
XE-135	2.03E+01
CS-137	2.21E-06
CE-141	1.78E-08
ND-147	5.23E-05

Total Airborne Tritium Released 9.67E+00 Ci

Installation: Millstone
Unit No.(s): 3

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-423
Thermal Power(MWH): 2.52E+07
Commercial Operation: 04/23/86
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 8.22E+06
Initial Criticality: 01/23/86

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	5.66E-04
AR-41	1.28E-05
CR-51	7.51E-03
MN-54	1.99E-01
FE-55	7.18E-01
CO-57	1.55E-03
CO-58	1.16E-01
FE-59	2.33E-04
CO-60	4.03E-01
ZN-65	2.73E-03
KR-85	7.42E-04
KR-85M	1.32E-05
KR-87	3.23E-06
RB-88	1.07E-04
SR-89	1.76E-04
SR-92	4.15E-02
NB-95	3.10E-02
ZR-95	4.46E-03
NB-97	2.19E-01
MO-99	1.98E-04
TC-99M	5.48E-03
RU-106	2.15E-02
AG-110M	1.31E-01
SB-125	3.53E-02
SN-125	5.91E-04
I-131	3.02E-02
XE-131M	1.67E-05
I-132	5.14E-06
I-133	9.74E-03
XE-133	5.12E-02
XE-133M	6.87E-06
CS-134	2.31E-01
I-135	9.21E-05
XE-135	3.38E-02
XE-135M	2.66E-05
CS-136	1.04E-03
CS-137	2.47E-01
CE-141	2.40E-06
CE-144	1.23E-03
PR-144	7.20E-03
HF-181	6.19E-05

Total Liquid Tritium Released	7.74E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.81E+07 liters
Volume of Dilution Water Used During Period	1.70E+12 liters

Installation: Millstone
Unit No.(s): 3

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-423
Thermal Power(MWH): 2.52E+07
Commercial Operation: 04/23/86
Cooling Water Source: Niantic Bay

Licensee: Northeast Nuclear Energy
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 8.22E+06
Initial Criticality: 01/23/86

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
5	Truck	CNSI, Barnwell, SC
1	Truck	Quadrex, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M		6.00E-02
C-14		2.00E-02
CO-57		2.70E-01
CO-58		4.40E-01
CO-60		1.33E+01
CS-134		8.57E+00
CS-137		1.52E+01
FE-55		4.16E+01
H-3		1.00E-02
MN-54		4.43E+00
NI-63		1.61E+01
PU-241		1.00E-02
SR-89		2.00E-02
SR-90		2.00E-02

B

C-14		6.42E-03
CO-58	4.55E+01	9.96E+00
CO-60	4.69E+00	1.08E+01
CS-134		9.17E+00
CS-136		3.23E-01
CS-137	4.28E-03	1.20E+01
FE-55	3.52E+01	3.82E+01
H-3		4.03E+00
I-131		8.52E-01
MN-54	4.14E+00	2.19E+00
NI-63	1.05E+01	1.23E+01
ZN-65	8.00E-04	9.65E-02

Installation: Millstone
Unit No.(s): 3

Location: 3.2 Mi WSW of New London, CT

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 3 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.24E+01 Ci 1.72E+02	non-compacted burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.36E+01 Ci 4.09E+00	compacted burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Monticello
Unit No.(s): 1

Location: 23 Mi SE St. Cloud, MN

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-263
Thermal Power(MWH): 1.40E+07
Commercial Operation: 06/30/71
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.67E+03
Net Electrical Power(MWH): 4.51E+06
Initial Criticality: 12/10/70

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	7.81E-08
CR-51	4.47E-09
MN-54	1.09E-05
CO-58	7.10E-08
CO-60	3.70E-04
ZN-65	2.59E-04
KR-85	7.37E-08
KR-85M	7.02E+00
KR-87	2.60E+01
KR-88	1.78E+01
KR-89	8.91E+00
SR-89	1.23E-03
SR-90	3.98E-06
ZR-95	4.37E-07
I-131	3.74E-02
I-133	1.94E-01
XE-133	6.30E+02
XE-133M	1.23E+01
I-135	2.56E-01
XE-135	3.47E+02
XE-135M	6.18E+02
CS-137	1.76E-04
XE-137	8.50E+02
XE-138	4.40E+02
BA-140	3.84E-03
CE-141	8.77E-05

Total Airborne Tritium Released 8.54E+01 Ci

Installation: Monticello
Unit No.(s): 1

Location: 23 Mi SE St. Cloud, MN

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR	Licensee: Northern States Power
Docket Number: 50-263	Licensed Power(MWT): 1.67E+03
Thermal Power(MWH): 1.40E+07	Net Electrical Power(MWH): 4.51E+06
Commercial Operation: 06/30/71	Initial Criticality: 12/10/70
Cooling Water Source: Mississippi River	

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Railway	CNSI, Barnwell, SC
7	Truck	CNSI, Barnwell, SC
4	Railway	US Ecology, Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

BA-140	5.94E-01	3.97E-02
CE-141	1.27E-01	1.51E-02
CO-58	5.09E-01	2.27E-02
CO-60	3.65E+01	4.26E+01
CR-51	5.80E-01	
CS-134	6.07E-01	8.56E-01
CS-137	6.64E+00	2.89E+00
FE-55	4.12E+01	4.43E+01
FE-59	1.13E-01	
I-131	1.09E+00	7.85E-02
LA-140	2.54E-01	9.08E-03
MN-54	4.88E+00	3.25E+00
NI-63	1.44E+00	1.77E-01
SR-89	7.95E-01	8.64E-01
SR-90	2.91E-02	1.72E-01
ZN-65	3.97E+00	4.58E+00

B

BA-140	1.60E-01	3.82E-01
CE-141	4.10E-01	1.00E-01
CO-58		8.50E-01
CO-60	3.50E+01	3.69E+01
CR-51		4.06E+00
CS-134		1.82E+00
CS-137		3.67E+00
FE-55	3.96E+01	3.17E+01
FE-59		1.02E+00
I-131	6.80E-02	5.38E-01
LA-140		1.06E-01
MN-54	8.50E-02	6.74E+00
NI-63	1.63E+00	2.54E-01
RU-103	7.00E-02	
SR-89		1.54E+00
SR-90		1.06E-01
ZN-65	2.00E+01	3.02E+00

Installation: Monticello
Unit No.(s): 1

Location: 23 Mi SE St. Cloud, MN

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.93E+01 Ci 1.16E+03	after compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.47E+01 Ci 8.79E+00	after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Nine Mile Point
Unit No.(s): 1

Location: 8 Mi NE Oswego, NY

Effluent and Waste Disposal Annual Report for 1990

Type: BWR	Licensee: Niagara Mohawk Power
Docket Number: 50-220	Licensed Power(MWT): 1.85E+03
Thermal Power(MWH): 4.07E+06	Net Electrical Power(MWH): 1.28E+06
Commercial Operation: 12/01/69	Initial Criticality: 09/05/69
Cooling Water Source: Lake Ontario	

Airborne Effluents

Nuclide Released	Activity (Ci)
FE-55	2.95E-04
CO-60	8.89E-04
SR-89	3.07E-04
SR-90	8.14E-06
I-131	9.71E-04
I-133	1.79E-02
I-135	1.81E-02
CS-137	1.68E-04
BA-LA-140	8.28E-05

Total Airborne Tritium Released 1.86E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
FE-55	1.70E-03
CO-60	2.56E-04

Total Liquid Tritium Released	1.41E+00 Ci
Volume of Liquid Waste Released (Prior to Dilution)	8.35E+05 liters
Volume of Dilution Water Used During Period	4.30E+11 liters

Installation: Nine Mile Point
Unit No.(s): 1

Location: 8 Mi NE Oswego, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-220
Thermal Power(MWH): 4.07E+06
Commercial Operation: 12/01/69
Cooling Water Source: Lake Ontario

Licensee: Niagara Mohawk Power
Licensed Power(MWT): 1.85E+03
Net Electrical Power(MWH): 1.28E+06
Initial Criticality: 09/05/69

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
65		Barnwell, SC
15	Truck	CNSI, Barnwell, SC
9		Hanford, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-60	6.76E+01	2.42E+01
CS-137	1.86E+01	2.09E+01
FE-55	9.40E+00	5.26E+01
MN-54	1.69E+00	4.59E-01
NI-63	2.09E+00	1.01E+00
Others	6.20E-01	5.33E-01
SR-90		3.08E-01
B		
CO-60	3.32E+01	
CS-134	8.29E-01	
CS-137	5.94E+01	
H-3	5.33E+00	
MN-54	1.07E+00	
Others	1.71E-01	
D		
C-14	9.87E-01	1.15E+00
CO-60	3.86E+01	6.01E+01
CS-134	1.65E-01	
CS-137	4.82E+01	2.89E+01
FE-55	7.61E+00	6.34E+00
H-3	1.03E+00	2.03E+00
MN-54	1.05E+00	
NI-63	1.85E+00	1.01E+00
Others	5.08E-01	4.70E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 7.24E+01	non-compacted
	Ci 4.26E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 5.38E+00	before
		compaction
	Ci 1.41E+00	
C. Irradiated Components, Control Rods, etc.	m3	
	Ci	
D. Other (describe)		
DAW shipped offsite for proc. & burial	m3 1.68E+02	after
		compaction
	Ci 6.96E+00	

Installation: Nine Mile Point
Unit No.(s): 2

Location: 8 Mi NE Oswego, NY

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-410

Thermal Power(MWH): 1.34E+07

Commercial Operation: 04/05/88

Cooling Water Source: Lake Ontario

Licensee: Niagara Mohawk Power

Licensed Power(MWT): 3.32E+03

Net Electrical Power(MWH): 4.14E+06

Initial Criticality: 05/23/87

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

AR-41	1.30E+01
CR-51	2.30E-03
MN-54	1.86E-04
FE-55	2.43E-04
CO-57	3.00E-04
CO-58	4.28E-05
FE-59	5.13E-05
CO-60	3.48E-04
ZN-65	6.73E-04
SE-75	1.79E-04
KR-85	4.25E-04
KR-85M	4.78E+00
KR-87	2.08E+00
KR-88	7.24E+01
SR-89	1.54E-04
MO-99	2.72E-04
I-131	4.70E-04
I-133	4.98E-03
XE-133	1.25E-05
I-135	6.99E-04
XE-135	1.06E+00
XE-135M	4.13E+00
XE-137	4.20E+01
XE-138	2.40E+01
BA-LA-140	7.40E-06

Total Airborne Tritium Released 3.70E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CR-51	5.84E-03
MN-54	5.15E-03
FE-55	6.40E-03
CO-58	1.87E-03
FE-59	7.06E-04
CO-60	1.12E-02
ZN-65	3.23E-02
MO-99	1.01E-05
TC-99M	9.84E-06
XE-133	1.05E-04
XE-135	1.16E-04

Total Liquid Tritium Released

4.78E+00 Ci

Volume of Liquid Waste Released (Prior to Dilution)

6.75E+06 liters

Volume of Dilution Water Used During Period

5.37E+10 liters

Installation: Nine Mile Point
Unit No.(s): 2

Location: 8 Mi NE Oswego, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-410
Thermal Power(MWH): 1.34E+07
Commercial Operation: 04/05/88
Cooling Water Source: Lake Ontario

Licensee: Niagara Mohawk Power
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 4.14E+06
Initial Criticality: 05/23/87

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
48	Truck	Barnwell, SC
24	Truck	Barnwell, SC via vendor

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	1.89E+00	1.77E+00
CO-60	4.43E+00	1.38E+01
CR-51	6.81E+01	8.08E+00
FE-55	2.56E+00	4.23E+00
MN-54	2.24E+00	6.74E+00
Others	1.05E+00	1.76E+00
ZN-65	1.97E+01	6.37E+01

B

CO-58	1.73E+00	
CO-60	1.56E+01	4.12E+00
CR-51	2.78E+00	5.87E+01
FE-55	1.94E+00	1.31E+01
FE-59		1.46E+00
H-3		2.37E+00
MN-54	8.32E+00	2.22E+00
Others	2.73E+00	2.13E+00
ZN-65	6.69E+01	1.59E+01

D

CO-58		3.25E+01
CO-60		2.96E+01
CS-137		4.60E+00
FE-55		2.20E+00
MN-54		8.29E+00
ZN-65		2.28E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.68E+02 Ci 6.72E+02	non-compacted
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 5.86E+01 Ci 7.43E-01	before compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) DAW shipped offsite for proc. & burial	m3 1.38E+01 Ci 2.80E-01	after compaction

Installation: North Anna
Unit No.(s): 1&2

Location: 40 Mi NW Richmond, VA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-338
Thermal Power(MWH): 2.31E+07
Commercial Operation: 06/06/78
Cooling Water Source: Lake Anna

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 7.23E+06
Initial Criticality: 04/05/78

Unit Number: 2 Type: PWR
Docket Number: 50-339
Thermal Power(MWH): 1.91E+07
Commercial Operation: 12/14/80
Cooling Water Source: Lake Anna

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 5.98E+06
Initial Criticality: 06/12/80

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	4.31E-09
AR-41	2.54E+00
MN-54	2.78E-10
FE-55	1.36E-04
CO-58	3.05E-04
CO-60	1.66E-04
ZN-65	4.02E-08
BR-84	2.57E-09
KR-85	2.59E+01
KR-85M	1.77E-01
SR-85	3.56E-09
KR-87	1.87E-01
KR-88	2.61E-01
RU-106	7.27E-05
SB-122	3.77E-07
I-131	6.32E-03
XE-131M	9.84E+00
I-132	5.61E-05
I-133	1.77E-03
XE-133	8.94E+02
XE-133M	1.91E+00
CS-134	1.35E-05
I-134	4.63E-05
I-135	1.06E-04
XE-135	1.52E+01
XE-135M	1.22E+00
CS-136	2.84E-09
CS-137	3.97E-05
CS-138	1.76E-07
XE-138	3.49E-01
TM-170	7.88E-05

Total Airborne Tritium Released 3.11E+01 Ci

Installation: North Anna
Unit No.(s): 1&2

Location: 40 Mi NW Richmond, VA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-338
Thermal Power(MWH): 2.31E+07
Commercial Operation: 06/06/78
Cooling Water Source: Lake Anna

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 7.23E+06
Initial Criticality: 04/05/78

Unit Number: 2 Type: PWR
Docket Number: 50-339
Thermal Power(MWH): 1.91E+07
Commercial Operation: 12/14/80
Cooling Water Source: Lake Anna

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 5.98E+06
Initial Criticality: 06/12/80

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

AR-41	1.44E-04
CR-51	5.83E-03
MN-54	6.16E-03
CO-57	1.52E-04
CO-58	2.26E-01
FE-59	1.52E-03
CO-60	2.79E-01
ZN-65	9.20E-05
BR-84	1.59E-04
KR-85	2.80E-01
KR-85M	1.49E-04
SR-85	1.21E-03
RB-88	9.57E-05
NB-95	8.08E-03
ZR-95	1.04E-03
CD-109	6.98E-05
AG-110M	2.15E-02
SB-122	1.39E-06
SB-124	2.58E-03
SB-125	4.12E-02
I-131	1.56E-02
XE-131M	3.87E-01
I-132	4.91E-04
I-133	4.55E-02
XE-133	2.63E+01
XE-133M	1.45E-01
CS-134	2.54E-03
I-134	3.99E-05
I-135	3.40E-03
XE-135	1.08E-01
XE-135M	9.78E-04
CS-136	1.02E-04
CS-137	8.50E-03
CS-138	4.49E-05
BA-139	3.61E-03
BA-140	2.20E-04

Total Liquid Tritium Released	1.67E+03 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.62E+08 liters
Volume of Dilution Water Used During Period	2.72E+12 liters

Installation: North Anna
Unit No.(s): 1&2

Location: 40 Mi NW Richmond, VA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-338
Thermal Power(MWH): 2.31E+07
Commercial Operation: 06/06/78
Cooling Water Source: Lake Anna

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 7.23E+06
Initial Criticality: 04/05/78

Unit Number: 2 Type: PWR
Docket Number: 50-339
Thermal Power(MWH): 1.91E+07
Commercial Operation: 12/14/80
Cooling Water Source: Lake Anna

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 5.98E+06
Initial Criticality: 06/12/80

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
18	Truck	Barnwell, SC
1	Truck	Quadrex, Oak Ridge, TN
16	Truck	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CE-144	2.07E+00	
CO-58	2.62E+00	2.45E+01
CO-60	2.88E+01	2.06E+01
CS-134	1.25E+00	2.90E+00
CS-137	2.39E+00	4.90E+00
FE-55	1.51E+01	1.42E+01
MN-54		1.10E+00
NI-63	4.54E+01	2.81E+01

B

CO-58		3.15E+01
CO-60	3.34E+01	1.37E+01
CR-51		2.80E+00
CS-134	3.63E+00	1.60E+00
CS-137	1.14E+01	8.40E+00
FE-55	4.17E+01	2.62E+01
MN-54	1.39E+00	1.50E+00
NB-95		3.80E+00
NI-63	5.86E+00	3.40E+00
SB-125	1.31E+00	
ZR-95		5.20E+00

D

CO-58		3.50E+00
CO-60		2.58E+01
CS-134		1.88E+01
CS-137		5.18E+01

Installation: North Anna
Unit No.(s): 1&2

Location: 40 Mi NW Richmond, VA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 8.95E+01 Ci 7.10E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 6.89E+02 m3 1.23E+02 Ci 1.41E+01	before processing after processing
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Oil	m3 7.02E+00 m3 0.00E+00 Ci 6.54E-05	before incineration after incineration

Installation: Oconee
Unit No.(s): 1&2&3

Location: 30 Mi W Greenville, SC

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-269
Thermal Power(MWH): 1.96E+07
Commercial Operation: 07/15/73
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 6.45E+06
Initial Criticality: 04/19/73

Unit Number: 2 Type: PWR
Docket Number: 50-270
Thermal Power(MWH): 1.90E+07
Commercial Operation: 09/09/74
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 6.27E+06
Initial Criticality: 11/11/73

Unit Number: 3 Type: PWR
Docket Number: 50-287
Thermal Power(MWH): 2.23E+07
Commercial Operation: 12/16/74
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 7.43E+06
Initial Criticality: 09/05/74

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.30E+00
CO-57	6.44E-08
CO-58	1.70E-05
CO-60	1.67E-05
SE-75	5.40E-08
KR-85	2.10E+02
KR-85M	1.45E+01
KR-87	5.69E-01
KR-88	3.34E+00
RB-88	1.38E-02
SR-90	1.49E-07
SR-92	1.40E-06
NB-95	1.10E-07
ZR-95	4.51E-05
NB-97	1.01E-07
TC-99M	3.13E-06
RU-103	1.03E-06
RU-106	1.76E-06
SB-125	3.54E-04
I-131	7.62E-03
XE-131M	8.64E+01
I-132	9.70E-04
TE-132	2.07E-08
I-133	5.87E-03
XE-133	8.15E+03
XE-133M	3.09E+01
CS-134	5.60E-05
I-134	1.79E-04
I-135	2.21E-03
XE-135	3.19E+02
XE-135M	2.04E+01

Installation: Oconee
Unit No.(s): 1&2&3

Location: 30 Mi W Greenville, SC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2&3(continued)

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CS-136	1.64E-05
--------	----------

CS-137	8.28E-04
--------	----------

CS-138	7.38E-04
--------	----------

BA-140	5.97E-05
--------	----------

NP-239	1.46E-06
--------	----------

Total Airborne Tritium Released 1.01E+02 Ci

Installation: Oconee
Unit No.(s): 1&2&3

Location: 30 Mi W Greenville, SC

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-269
Thermal Power(MWH): 1.96E+07
Commercial Operation: 07/15/73
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 6.45E+06
Initial Criticality: 04/19/73

Unit Number: 2 Type: PWR
Docket Number: 50-270
Thermal Power(MWH): 1.90E+07
Commercial Operation: 09/09/74
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 6.27E+06
Initial Criticality: 11/11/73

Unit Number: 3 Type: PWR
Docket Number: 50-287
Thermal Power(MWH): 2.23E+07
Commercial Operation: 12/16/74
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 7.43E+06
Initial Criticality: 09/05/74

Liquid Effluents

Nuclide Released	Activity (Ci)
AR-41	1.19E-04
CR-51	7.12E-02
MN-54	1.06E-02
FE-55	1.51E+00
CO-57	4.66E-04
CO-58	3.60E-01
FE-59	5.49E-04
CO-60	1.46E-01
ZN-65	2.40E-04
KR-85M	1.75E-06
KR-87	1.39E-05
KR-88	9.11E-06
RB-88	2.97E-04
SR-89	2.28E-04
SR-90	3.59E-05
SR-92	1.82E-03
NB-95	3.07E-02
ZR-95	1.44E-02
NB-97	1.72E-02
TC-99M	7.85E-04
RU-103	5.10E-03
RU-106	6.37E-02
AG-110M	3.01E-01
SN-113	2.21E-03
SB-122	2.21E-04
SB-124	5.47E-03
SB-125	1.98E-01
I-131	2.04E-02
XE-131M	7.17E-03
I-132	1.68E-03
TE-132	2.12E-03

Installation: Oconee
Unit No.(s): 1&2&3

Location: 30 Mi W Greenville, SC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2&3(continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
I-133	5.36E-03
XE-133	1.10E+00
XE-133M	5.19E-03
CS-134	2.63E-02
I-135	1.07E-05
XE-135	5.79E-02
XE-135M	3.99E-06
CS-136	7.77E-05
CS-137	2.64E-01
CS-138	4.75E-03
BA-140	3.80E-03
LA-140	3.13E-02
CE-141	4.31E-04
CE-144	5.75E-03

Total Liquid Tritium Released	9.92E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.89E+09 liters
Volume of Dilution Water Used During Period	1.04E+12 liters

Installation: Oconee
Unit No.(s): 1&2&3

Location: 30 Mi W Greenville, SC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-269
Thermal Power(MWH): 1.96E+07
Commercial Operation: 07/15/73
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 6.45E+06
Initial Criticality: 04/19/73

Unit Number: 2 Type: PWR
Docket Number: 50-270
Thermal Power(MWH): 1.90E+07
Commercial Operation: 09/09/74
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 6.27E+06
Initial Criticality: 11/11/73

Unit Number: 3 Type: PWR
Docket Number: 50-287
Thermal Power(MWH): 2.23E+07
Commercial Operation: 12/16/74
Cooling Water Source: Lake Keowee

Licensee: Duke Power
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 7.43E+06
Initial Criticality: 09/05/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
20		Alaron, Barnwell, SC
28		Barnwell, SC
115		SEG, Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
AG-110M	1.95E-01	5.29E-01
C-14		1.16E-01
CE-144		8.54E-04
CO-57		5.00E-02
CO-58	1.11E+01	9.78E+00
CO-60	2.49E+00	2.29E+00
CR-51	9.77E-02	2.90E-02
CS-134	2.91E+01	3.02E+01
CS-137	4.79E+01	4.87E+01
FE-55	2.78E+00	2.62E+00
H-3		1.12E-01
I-131		1.71E-03
MN-54	1.00E+00	5.94E-01
NB-95	9.77E-02	5.12E-02
NI-63	4.27E+00	3.92E+00
PU-241		1.17E-01
RU-103		2.56E-03
RU-106		1.70E-03
SB-122	9.02E-01	
SB-125	9.77E-02	3.59E-01
SR-90		3.83E-01

Installation: Oconee
Unit No.(s): 1&2&3

Location: 30 Mi W Greenville, SC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2&3(continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

A

TE-125M		4.78E-02
TRU		4.12E-03
ZR-95		2.30E-02

B

CM-242	3.00E-02	3.00E-02
CO-60	1.59E+00	1.59E+00
CS-124		2.97E+01
CS-134	2.96E+01	
CS-137	5.43E+01	5.43E+01
FE-55	2.83E+00	2.83E+00
NI-63	1.08E+01	1.08E+00
PU-241	1.90E-01	1.90E-01
SR-90	6.00E-02	6.00E-02
TC-99	5.20E-01	5.20E-01
TRU	1.00E-02	1.00E-02

D

AG-110M	2.40E+01	1.14E+01
C-14		9.00E-01
CE-144	1.00E+00	2.84E+00
CO-57		2.04E-06
CO-58	2.00E+00	3.33E+01
CO-60	3.80E+01	9.41E+00
CS-134		1.00E+00
CS-137	1.50E-03	3.47E+00
FE-55	3.00E+00	6.10E-04
H-3	1.48E-01	7.04E+00
MN-54	2.00E+00	1.01E+00
NB-95		4.79E+00
NI-63	2.90E+01	7.59E+00
PU-241	1.00E+00	1.78E-01
RU-106		1.15E+01
SB-125		1.19E+00
SR-90		8.90E-01
TE-125		8.90E-02
TRU		3.31E-02
ZR-95		1.80E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.07E+02 Ci 1.70E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.15E+02 Ci 1.55E+01	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Dewatered mechanical filters	m3 1.76E+01 Ci 6.92E+01	

Installation: Oyster Creek
Unit No.(s): 1

Location: 9 Mi S Toms River, NJ

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-219
Thermal Power(MWH): 1.36E+07
Commercial Operation: 12/01/69
Cooling Water Source: Barnegat Bay

Licensee: GPU Nuclear Corporation
Licensed Power(MWT): 1.93E+03
Net Electrical Power(MWH): 4.31E+06
Initial Criticality: 05/03/69

Airborne Effluents

Nuclide Released	Activity (Ci)
KR-85M	3.05E+01
KR-87	1.19E+02
KR-88	1.18E+02
SR-89	7.89E-03
SR-90	3.22E-05
TC-99M	9.14E-03
I-131	2.30E-02
I-133	1.14E-01
XE-133	8.93E+01
I-135	4.04E-02
XE-135	3.78E+02
CS-137	4.56E-06
BA-140	4.10E-04

Total Airborne Tritium Released 1.15E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
MN-54	6.00E-07
CO-60	7.00E-07
CS-134	1.30E-05
CS-137	5.27E-05

Volume of Liquid Waste Released (Prior to Dilution)	3.78E+01 liters
Volume of Dilution Water Used During Period	4.16E+08 liters

Installation: Oyster Creek
Unit No.(s): 1

Location: 9 Mi S Toms River, NJ

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-219
Thermal Power(MWH): 1.36E+07
Commercial Operation: 12/01/69
Cooling Water Source: Barnegat Bay

Licensee: GPU Nuclear Corporation
Licensed Power(MWT): 1.93E+03
Net Electrical Power(MWH): 4.31E+06
Initial Criticality: 05/03/69

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
52	Truck	Barnwell, SC
6	Truck	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	7.00E-03	2.10E-02
CM-242	1.00E-03	1.00E-03
CO-58	1.00E+00	1.22E+00
CO-60	2.75E+01	3.68E+01
CR-51	1.40E+00	2.35E+00
CS-134	1.16E+01	3.07E+00
CS-137	3.19E+01	1.32E+01
FE-55	2.39E+01	3.53E+01
H-3	1.60E-02	1.50E-02
MN-54	2.46E+00	7.63E+00
NI-63	2.26E-01	3.38E-01
PU-241	4.00E-02	7.10E-02
SR-90	5.60E-02	6.20E-02

B

C-14	9.29E-04	1.05E-03
CE-141	1.39E-02	1.10E-02
CE-144	1.39E-02	4.41E-03
CO-58	5.58E-01	4.41E-01
CO-60	2.36E+01	2.93E+01
CR-51	1.03E+00	1.42E+00
CS-134	2.77E+00	2.28E+00
CS-137	8.38E+00	7.82E+00
FE-55	5.84E+01	5.31E+01
FE-59	8.37E-02	1.32E-01
H-3	5.58E-03	9.98E-03
LA-140	2.79E-01	4.41E-01
MN-54	4.30E+00	3.73E+00
NI-63	1.39E-01	2.20E-01
PU-241	6.97E-02	6.61E-02
SR-89	5.58E-01	1.10E-01
SR-90	7.60E-02	6.61E-02
ZN-65	9.76E-02	1.54E-01

C

C-14	6.40E-02
CO-60	3.88E+01

Installation: Oyster Creek
Unit No.(s): 1

Location: 9 Mi S Toms River, NJ

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

C

FE-55	3.76E+01
NB-94	2.00E-03
NI-3	4.44E+00
NI-59	2.90E-02
PU-241	2.00E-03
SB-125	1.90E+01

D

C-14	1.00E-03
CM-242	1.00E-03
CO-60	8.86E+01
CS-134	1.94E+00
CS-137	2.21E+00
FE-55	8.09E+01
H-3	5.10E-02
MN-54	5.63E+00
NI-63	8.27E-01
PU-241	1.69E-01
SR-90	2.00E-02

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.49E+02 Ci 9.14E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 6.60E+01 Ci 1.17E+01	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 2.20E+00 Ci 1.95E+02	
D. Other (describe) Other waste	m3 5.60E+00 Ci 1.01E+01	

Installation: Palisades
Unit No.(s): 1

Location: 5 Mi S South Haven, MI

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-255
Thermal Power(MWH): 1.01E+07
Commercial Operation: 12/31/71
Cooling Water Source: Lake Michigan

Licensee: Consumers Power
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 3.01E+06
Initial Criticality: 05/24/71

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.75E-01
CR-51	3.64E-06
CO-58	2.33E-05
CO-60	1.72E-05
SE-75	4.17E-05
KR-85	3.60E-01
KR-85M	4.31E-02
KR-87	9.92E-02
KR-88	1.20E-01
SR-89	4.68E-06
SR-90	2.88E-06
NB-95	4.84E-07
ZR-95	2.22E-06
AG-110M	4.85E-07
SB-125	2.82E-06
I-131	1.86E-03
XE-131M	1.73E-01
I-132	1.03E-03
I-133	1.12E-03
XE-133	1.18E+02
XE-133M	2.87E-01
CS-134	3.28E-05
I-135	8.82E-05
XE-135	1.22E+00
XE-135M	9.49E-01
CS-136	3.58E-07
CS-137	1.23E-04
XE-138	3.45E-01
CE-144	1.74E-06
Unidentified	2.07E-05

Total Airborne Tritium Released 5.58E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CO-58	4.01E-03
CO-60	1.78E-03
SR-89	4.74E-06
SR-90	5.99E-06
XE-133	6.67E-05
CS-134	1.11E-04
CS-137	1.10E-03
Unidentified	7.32E-04

Total Liquid Tritium Released	1.49E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.48E+06 liters
Volume of Dilution Water Used During Period	1.16E+11 liters

Installation: Palisades
Unit No.(s): 1

Location: 5 Mi S South Haven, MI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-255
Thermal Power(MWH): 1.01E+07
Commercial Operation: 12/31/71
Cooling Water Source: Lake Michigan

Licensee: Consumers Power
Licensed Power(MWT): 2.53E+03
Net Electrical Power(MWH): 3.01E+06
Initial Criticality: 05/24/71

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
5	Truck	Barnwell, SC
1	Truck	Richland, WA
1	Truck	SEG, Barnwell, SC
7	Truck	U.S. Ecol,WA & SEG,SC
1	Truck	U.S. Ecology, Richland, WA

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.34E+01 Ci 4.02E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.41E+02 Ci 2.07E+01	after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) filters	m3 1.02E+01 Ci 2.65E+01	

Installation: Palo Verde
Unit No.(s): 1

Location: 36 Mi W Phoenix, AZ

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-528
Thermal Power(MWH): 1.45E+07
Commercial Operation: 01/28/86
Cooling Water Source: Sewage Treatment

Licensee: Arizona Public Service Co.
Licensed Power(MWT): 3.80E+03
Net Electrical Power(MWH): 4.72E+06
Initial Criticality: 05/25/85

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.17E-01
CO-58	8.11E-10
CO-60	4.31E-04
BR-82	4.99E-05
KR-85	9.04E+01
KR-85M	4.57E-01
KR-87	3.22E-01
KR-88	4.37E-01
RB-88	1.26E-02
I-131	2.23E-03
XE-131M	3.12E+00
I-133	1.60E-04
XE-133	5.79E+02
XE-133M	3.00E+00
CS-134	1.24E-05
I-135	1.10E-05
XE-135	3.12E+01
CS-137	1.86E-05
CS-138	4.67E-05
LA-140	5.11E-07

Total Airborne Tritium Released 1.66E+02 Ci

Installation: Palo Verde
Unit No.(s): 2

Location: 36 Mi W Phoenix, AZ

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-529
Thermal Power(MWH): 1.91E+07
Commercial Operation: 09/19/86
Cooling Water Source: Sewage Treatment

Licensee: Arizona Public Service Co.
Licensed Power(MWT): 3.80E+03
Net Electrical Power(MWH): 6.24E+06
Initial Criticality: 04/18/86

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.89E+00
CR-51	3.54E-05
MN-54	4.40E-06
CO-58	7.43E-05
CO-60	5.40E-05
BR-82	2.04E-04
KR-85	7.88E+00
KR-85M	5.75E-03
KR-88	1.05E-01
RB-88	2.82E-03
NB-95	8.92E-06
ZR-95	4.25E-06
RU-103	2.05E-04
TE-123M	3.13E-06
SB-124	2.93E-04
I-131	1.99E-03
XE-131M	4.08E+00
I-133	1.12E-04
XE-133	6.48E+02
XE-133M	1.71E+00
XE-135	1.06E+01
CS-138	9.09E-07
XE-138	3.47E-04

Total Airborne Tritium Released 1.82E+02 Ci

Installation: Palo Verde
Unit No.(s): 3

Location: 36 Mi W Phoenix, AZ

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-530
Thermal Power(MWH): 2.92E+07
Commercial Operation: 01/08/88
Cooling Water Source: Sewage Treatment

Licensee: Arizona Public Service Co.
Licensed Power(MWT): 3.80E+03
Net Electrical Power(MWH): 9.64E+06
Initial Criticality: 10/25/87

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.74E+00
BR-82	2.78E-04
KR-85	2.53E+00
KR-85M	5.64E+00
KR-87	1.50E+00
KR-88	5.06E+00
RB-88	1.12E-02
I-131	1.13E-03
XE-131M	1.39E+00
I-133	3.45E-04
XE-133	1.08E+03
XE-133M	3.94E+00
XE-135	9.28E+01
XE-135M	1.90E-01
CS-137	5.90E-08
CS-138	1.17E-04

Total Airborne Tritium Released 4.05E+02 Ci

Installation: Palo Verde
Unit No.(s): 1&2&3

Location: 36 Mi W Phoenix, AZ

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-528
Thermal Power(MWH): 1.45E+07
Commercial Operation: 01/28/86
Cooling Water Source: Sewage Treatment

Licensee: Arizona Public Service Co.
Licensed Power(MWT): 3.80E+03
Net Electrical Power(MWH): 4.72E+06
Initial Criticality: 05/25/85

Unit Number: 2 Type: PWR
Docket Number: 50-529
Thermal Power(MWH): 1.91E+07
Commercial Operation: 09/19/86
Cooling Water Source: Sewage Treatment

Licensee: Arizona Public Service Co.
Licensed Power(MWT): 3.80E+03
Net Electrical Power(MWH): 6.24E+06
Initial Criticality: 04/18/86

Unit Number: 3 Type: PWR
Docket Number: 50-530
Thermal Power(MWH): 2.92E+07
Commercial Operation: 01/08/88
Cooling Water Source: Sewage Treatment

Licensee: Arizona Public Service Co.
Licensed Power(MWT): 3.80E+03
Net Electrical Power(MWH): 9.64E+06
Initial Criticality: 10/25/87

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
78	Truck	Hanford, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	5.04E-05	4.15E-01
AM-241	6.66E-06	4.29E-04
C-14	1.71E+00	3.08E+00
CE-144	7.13E-03	1.91E-01
CM-242	1.03E-08	
CM-243/244	5.74E-06	7.06E-04
CO-58	1.64E+01	1.47E+01
CO-60	1.62E+01	1.33E+01
CR-51	7.54E-01	7.99E-01
CS-134	4.70E+00	5.32E+00
CS-137	9.05E+00	1.04E+01
FE-55	3.80E+01	2.75E+01
FE-59	3.32E-01	
H-3	3.32E-01	
I-133	2.68E-04	
MN-54	1.66E+00	1.22E+00
NB-95	1.34E+00	5.16E-01
NI-63	2.10E+00	1.12E+01
PU-238	4.49E-04	1.75E-03
PU-239/240	4.92E-04	1.23E-03
PU-241	2.85E-02	1.41E-01
RU-106		7.47E-01
SB-124	4.70E+00	6.53E+00

Installation: Palo Verde
Unit No.(s): 1&2&3

Location: 36 Mi W Phoenix, AZ

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2&3(continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

A

SB-125	3.45E-01	1.61E+00
SN-113	1.55E-04	
SR-90	9.83E-03	8.97E-02
TC-99	7.79E-04	2.44E-03
ZN-65	3.16E-02	6.97E-02
ZR-95	7.35E-01	1.15E-01

B

AG-110M		7.85E-01
C-14	5.28E-01	6.77E-01
CE-144		3.36E-01
CO-58	5.65E+00	6.29E+00
CO-60	8.19E+00	9.85E+00
CR-51	3.86E+00	2.23E-01
CS-134	7.06E+00	9.03E+00
CS-137	1.57E+01	2.14E+01
FE-55	2.81E+01	2.68E+01
H-3	4.90E-01	7.13E-01
I-131	3.08E-01	3.84E-01
MN-54	1.25E+00	7.00E-02
NB-95	1.10E+00	4.42E-01
NI-63	9.67E+00	1.11E+01
RU-103	1.48E-01	
SB-124	1.74E+01	1.15E+01
SB-125	1.64E-01	
SR-90		3.80E-02
TC-99	3.64E-06	
ZR-95	3.10E-01	3.21E-01

D

C-14		9.86E+01
CE-144		1.42E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 5.65E+02 Ci 2.32E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.95E+02 Ci 8.32E+00	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) solidified oil	m3 5.65E+00 Ci 1.45E-04	

Installation: Peach Bottom
Unit No.(s): 2&3

Location: 17.9 Mi S Lancaster, PA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 2 Type: BWR
Docket Number: 50-277
Thermal Power(MWH): 2.11E+07
Commercial Operation: 07/05/74
Cooling Water Source: Susquehanna River

Licensee: Philadelphia Electric
Licensed Power(MWT): 3.44E+03
Net Electrical Power(MWH): 6.70E+06
Initial Criticality: 09/16/73

Unit Number: 3 Type: BWR
Docket Number: 50-278
Thermal Power(MWH): 2.37E+07
Commercial Operation: 12/23/74
Cooling Water Source: Susquehanna River

Licensee: Philadelphia Electric
Licensed Power(MWT): 3.44E+03
Net Electrical Power(MWH): 7.53E+06
Initial Criticality: 08/07/74

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	3.27E-05
CR-51	1.02E-04
CO-58	7.00E-07
CO-60	2.19E-06
KR-85M	5.57E+02
KR-87	3.65E+02
KR-88	5.21E+02
RB-88	1.14E-02
RB-89	1.17E-03
SR-89	2.34E-03
SR-90	8.27E-05
SR-91	2.05E-03
Y-91M	1.48E-02
MO-99	1.23E-04
TC-99M	1.67E-04
I-131	1.31E-02
XE-131M	8.22E+01
I-132	3.47E-05
TE-132	9.04E-06
I-133	4.07E-02
XE-133	6.97E+03
XE-133M	7.02E+01
I-135	1.68E-02
XE-135	1.75E+03
XE-135M	4.41E+02
CS-137	9.05E-05
CS-138	1.48E-01
XE-138	5.28E+01
BA-139	2.46E-02
BA-140	2.55E-03
LA-140	1.20E-03
Unidentified	4.20E+02

Total Airborne Tritium Released 3.11E+01 Ci

Installation: Peach Bottom
Unit No.(s): 2&3

Location: 17.9 Mi S Lancaster, PA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 2 Type: BWR
Docket Number: 50-277
Thermal Power(MWH): 2.11E+07
Commercial Operation: 07/05/74
Cooling Water Source: Susquehanna River

Licensee: Philadelphia Electric
Licensed Power(MWT): 3.44E+03
Net Electrical Power(MWH): 6.70E+06
Initial Criticality: 09/16/73

Unit Number: 3 Type: BWR
Docket Number: 50-278
Thermal Power(MWH): 2.37E+07
Commercial Operation: 12/23/74
Cooling Water Source: Susquehanna River

Licensee: Philadelphia Electric
Licensed Power(MWT): 3.44E+03
Net Electrical Power(MWH): 7.53E+06
Initial Criticality: 08/07/74

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

P-32	1.61E-03
CR-51	4.04E-03
MN-54	5.03E-05
FE-55	1.74E-03
CO-58	5.43E-05
CO-60	1.44E-03
ZN-65	5.00E-04
KR-85M	7.34E-05
KR-88	7.23E-05
SR-89	2.74E-04
SR-90	1.28E-04
SR-92	1.63E-05
NB-95	7.01E-05
MO-99	4.01E-06
TC-99M	4.51E-06
AG-110M	5.03E-04
I-131	2.34E-04
XE-131M	7.18E-04
XE-133	6.98E-02
XE-133M	1.17E-03
CS-134	4.30E-04
XE-135	5.00E-02
XE-135M	4.41E-05
CS-137	2.23E-03
LA-140	2.47E-04

Total Liquid Tritium Released	2.35E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.43E+07 liters
Volume of Dilution Water Used During Period	1.78E+11 liters

Installation: Peach Bottom
Unit No.(s): 2&3

Location: 17.9 Mi S Lancaster, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 2 Type: BWR
Docket Number: 50-277
Thermal Power(MWH): 2.11E+07
Commercial Operation: 07/05/74
Cooling Water Source: Susquehanna River

Licensee: Philadelphia Electric
Licensed Power(MWT): 3.44E+03
Net Electrical Power(MWH): 6.70E+06
Initial Criticality: 09/16/73

Unit Number: 3 Type: BWR
Docket Number: 50-278
Thermal Power(MWH): 2.37E+07
Commercial Operation: 12/23/74
Cooling Water Source: Susquehanna River

Licensee: Philadelphia Electric
Licensed Power(MWT): 3.44E+03
Net Electrical Power(MWH): 7.53E+06
Initial Criticality: 08/07/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
124		
82		Quadrex
10		SEG

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 6.28E+02 Ci 1.66E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.45E+02 Ci 3.58E+01	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 2.08E+01 Ci 2.85E+04	
D. Other (describe) Filters	m3 1.41E+01 Ci 3.14E+01	

Installation: Perry
Unit No.(s): 1

Location: 7 Mi NE Painesville, OH

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-440

Thermal Power(MWH): 2.00E+07

Commercial Operation: 11/18/87

Cooling Water Source: Lake Erie

Licensee: Cleveland Electric Illuminating Co

Licensed Power(MWT): 3.58E+03

Net Electrical Power(MWH): 6.59E+06

Initial Criticality: 06/06/86

Airborne Effluents

Nuclide Released	Activity (Ci)
KR-85M	6.27E-01
KR-87	6.16E-01
KR-88	5.35E-01
SR-89	1.36E-03
SR-90	6.75E-06
I-131	9.70E-03
I-132	9.68E-05
I-133	1.32E-02
XE-133	2.97E+01
XE-133M	2.84E-01
CS-134	1.76E-11
XE-135	3.86E+01
XE-135M	1.08E+01
CS-137	2.81E-11
XE-137	2.78E-01
XE-138	2.27E+00

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	2.39E-01
MN-54	4.20E-02
FE-55	2.26E-02
CO-58	1.22E-02
FE-59	4.51E-03
CO-60	1.46E-01
ZN-65	7.88E-02
SR-89	1.52E-03
SR-90	2.45E-05
SR-92	5.76E-04
NB-95	3.19E-04
ZR-95	1.38E-04
ZR-97	8.67E-05
TC-99M	9.75E-05
AG-110M	3.16E-02
SB-124	9.24E-05
I-131	7.47E-04
I-133	1.17E-04
XE-133	8.20E-03
CS-134	1.23E-02
XE-135	1.22E-03
CS-137	1.55E-02
LA-140	1.44E-03

Total Liquid Tritium Released

8.79E+00 Ci

Volume of Liquid Waste Released (Prior to Dilution)

2.85E+10 liters

Volume of Dilution Water Used During Period

1.62E+11 liters

Installation: Perry
Unit No.(s): 1

Location: 7 Mi NE Painesville, OH

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-440
Thermal Power(MWH): 2.00E+07
Commercial Operation: 11/18/87
Cooling Water Source: Lake Erie

Licensee: Cleveland Electric Illuminating Co
Licensed Power(MWT): 3.58E+03
Net Electrical Power(MWH): 6.59E+06
Initial Criticality: 06/06/86

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
17	Truck	Barnwell, SC
20	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M		6.63E-01
AM-241		2.89E-05
C-14	5.46E-01	3.75E-02
CE-141		3.64E-05
CE-144		1.39E-01
CM-242		1.58E-04
CO-57		1.80E-03
CO-58	3.78E+00	5.45E-01
CO-60	4.21E+01	1.18E+01
CR-51	8.76E+00	4.08E+00
CS-134	1.59E+00	3.19E-01
CS-137	2.44E+00	4.97E-01
FE-55	1.25E+01	7.04E+01
FE-59	1.85E+00	3.26E-01
H-3	6.15E+00	2.53E-01
I-129		1.08E-05
MN-54	1.52E+01	2.81E+00
NB-95		2.96E-02
NI-59		9.71E-03
NI-63	1.12E+00	2.64E-01
PU-238		7.09E-06
PU-239/240		4.09E-06
PU-241		8.26E-03
SB-124		6.63E-03
SR-90	5.10E-02	1.74E-02
TC-99		6.98E-05
ZN-65	3.50E+00	7.56E+00

B

AG-110M	1.76E+00	4.00E-01
C-14	1.00E-02	
CE-144		3.00E-02
CO-58	1.65E+01	3.64E+00
CO-60	1.97E+01	1.92E+01
CR-51	1.45E+01	1.00E-02
CS-137		2.60E-01

Installation: Perry
Unit No.(s): 1

Location: 7 Mi NE Painesville, OH

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

FE-55		6.11E+01
FE-59	3.78E+00	2.12E+00
H-3	3.00E-02	
MN-54	4.22E+01	1.24E+01
NB-95	1.59E+00	
NI-63		2.60E-01
SR-90		2.00E-02
ZN-65		6.00E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.61E+02 C1 1.91E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.10E+03 C1 3.00E+01	
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Pilgrim
Unit No.(s): 1

Location: 25 Mi SE Boston, MA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-293
Thermal Power(MWH): 1.29E+07
Commercial Operation: 12/01/72
Cooling Water Source: Cape Cod Bay

Licensee: Boston Edison
Licensed Power(MWT): 2.00E+03
Net Electrical Power(MWH): 4.24E+06
Initial Criticality: 06/16/72

Airborne Effluents

Nuclide Released	Activity (Ci)
MN-54	4.32E-06
CO-60	1.35E-05
KR-85M	2.12E+02
KR-87	5.50E+00
KR-88	1.70E+02
SR-89	6.18E-04
SR-90	6.67E-06
I-131	9.23E-03
I-133	3.81E-02
XE-133	4.56E+02
XE-135	3.00E+01
XE-135M	1.07E+01
CS-137	1.51E-07
XE-138	2.35E+01
BA/LA-140	3.41E-04

Total Airborne Tritium Released 1.59E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	6.22E-04
MN-54	3.87E-03
FE-55	5.03E-04
CO-58	2.52E-03
FE-59	8.07E-05
CO-60	5.91E-03
ZN-65	7.46E-06
SR-89	3.06E-05
SR-90	2.41E-05
AG-110M	5.58E-04
XE-133	1.63E-05
CS-134	1.73E-06
XE-135	1.59E-04
CS-137	1.23E-03
BA/LA-140	2.85E-04

Total Liquid Tritium Released	3.68E+00 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.66E+06 liters
Volume of Dilution Water Used During Period	4.41E+09 liters

Installation: Pilgrim
Unit No.(s): 1

Location: 25 Mi SE Boston, MA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-293
Thermal Power(MWH): 1.29E+07
Commercial Operation: 12/01/72
Cooling Water Source: Cape Cod Bay

Licensee: Boston Edison
Licensed Power(MWT): 2.00E+03
Net Electrical Power(MWH): 4.24E+06
Initial Criticality: 06/16/72

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Tractor-Trailer	Alaron, Wampum, PA/CNSI SC
30	Tractor-Trailer	CNSI, Barnwell, SC
7	Tractor-Trailer	Quadrex, Oak Ridge, TN/CNSI SC
23	Tractor-Trailer	SEG, Oak Ridge, TN/CNSI SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	2.64E-03	4.12E-01
BA-140	9.61E-02	9.90E-02
C-14	1.01E-02	5.00E-03
CE-141	1.93E-02	
CE-144	3.57E-02	1.80E-01
CM-242	3.45E-05	
CO-58	1.00E+01	1.39E+01
CO-60	3.41E+01	3.37E+01
CR-51	5.58E-01	2.08E+01
CS-134	5.77E-01	4.02E-01
CS-137	2.89E+01	2.15E+00
FE-55	6.78E+00	1.57E+01
FE-59	2.59E-01	7.65E-01
H-3	9.48E-03	2.00E-03
I-129	1.38E-03	
I-131	1.14E-02	2.10E-02
LA-140	1.08E-01	
MN-54	1.62E+01	8.02E+00
NI-63	2.15E+00	2.59E+00
PU-241	1.56E-02	7.00E-03
SR-89		4.00E-02
SR-90	7.24E-03	3.20E-02
TC-99	1.16E-03	
TRU	1.46E-03	
ZN-65	4.61E-02	1.26E+00

B

AM-241		9.99E-03
C-14	2.00E-03	9.99E-03
CE-144		1.40E-01
CM-242	8.00E-05	
CM-243/244		2.30E-01
CO-58	1.29E+00	2.48E+00
CO-60	3.19E+01	3.95E+01

Installation: Pilgrim
Unit No.(s): 1

Location: 25 Mi SE Boston, MA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

CR-51		2.69E+00
CS-134		1.10E-01
CS-137	6.06E+00	6.85E+00
FE-55	5.75E+01	4.11E+01
FE-59		4.49E-01
H-3	2.00E-02	3.99E-03
I-129	4.00E-03	9.99E-04
MN-54	1.46E+00	1.48E+00
NI-59		9.99E-03
NI-63	1.47E+00	3.91E+00
PU-238		4.99E-03
PU-239/240		6.99E-03
PU-241	1.90E-01	4.49E-01
SB-124		4.99E-02
SR-89		5.99E-02
SR-90	6.00E-02	3.99E-02
TC-99	4.00E-02	3.00E-02
TRU	1.00E-02	
ZN-65		3.00E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.58E+02 C1 6.53E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.13E+02 C1 9.40E+00	
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Point Beach
Unit No.(s): 1&2

Location: 15 Mi N Manitowoc, WI

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-266
Thermal Power(MWH): 1.09E+07
Commercial Operation: 12/21/70
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Electric Power Company
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.53E+06
Initial Criticality: 11/02/70

Unit Number: 2 Type: PWR
Docket Number: 50-301
Thermal Power(MWH): 1.16E+07
Commercial Operation: 10/01/72
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Electric Power Company
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.79E+06
Initial Criticality: 05/30/72

Airborne Effluents

Nuclide Released	Activity (Ci)
F-18	1.10E-05
AR-41	1.11E+00
CO-57	1.23E-06
CO-58	2.74E-05
CO-60	3.56E-06
KR-85	1.78E-01
KR-85M	1.85E-01
KR-87	4.05E-01
KR-88	4.49E-01
NB-95	9.56E-10
ZR-95	7.43E-10
I-131	7.85E-05
I-132	1.09E-05
I-133	1.13E-04
XE-133	1.96E+00
XE-133M	2.06E-02
I-135	3.15E-08
XE-135	1.09E+00
XE-135M	6.49E-01
CS-137	1.91E-04
XE-138	1.99E+00

Total Airborne Tritium Released 1.28E+02 Ci

Installation: Point Beach
Unit No.(s): 1&2

Location: 15 Mi N Manitowoc, WI

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-266
Thermal Power(MWH): 1.09E+07
Commercial Operation: 12/21/70
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Electric Power Company
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.53E+06
Initial Criticality: 11/02/70

Unit Number: 2 Type: PWR
Docket Number: 50-301
Thermal Power(MWH): 1.16E+07
Commercial Operation: 10/01/72
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Electric Power Company
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.79E+06
Initial Criticality: 05/30/72

Liquid Effluents

Nuclide Released	Activity (Ci)
F-18	2.26E-03
CR-51	8.71E-05
MN-54	3.10E-05
CO-57	4.08E-06
CO-58	3.25E-04
CO-60	1.41E-03
SR-89	1.55E-03
SR-90	4.32E-04
NB-95	8.68E-05
ZR-95	1.58E-05
NB-97	8.80E-06
AG-110M	1.71E-04
SB-125	1.28E-05
I-131	1.53E-04
I-132	4.45E-05
I-133	3.01E-03
CS-137	1.94E-03
CE-144	9.47E-06

Total Liquid Tritium Released	8.72E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.80E+08 liters
Volume of Dilution Water Used During Period	6.91E+11 liters

Installation: Point Beach
Unit No.(s): 1&2

Location: 15 Mi N Manitowoc, WI

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-266
Thermal Power(MWH): 1.09E+07
Commercial Operation: 12/21/70
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Electric Power Company
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.53E+06
Initial Criticality: 11/02/70

Unit Number: 2 Type: PWR
Docket Number: 50-301
Thermal Power(MWH): 1.16E+07
Commercial Operation: 10/01/72
Cooling Water Source: Lake Michigan

Licensee: Wisconsin Electric Power Company
Licensed Power(MWT): 1.52E+03
Net Electrical Power(MWH): 3.79E+06
Initial Criticality: 05/30/72

Solid Waste Disposition

Number of Shipments	Mode of Transportation
24	
2	

Destination
Barnwell, SC
Hanford, WA

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.43E+01 Ci 2.05E+02	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 8.58E+01 Ci 2.75E+00	burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Prairie Island
Unit No.(s): 1&2

Location: 26 Mi SE Minneapolis, MN

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-282
Thermal Power(MWH): 1.23E+07
Commercial Operation: 12/16/73
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.83E+06
Initial Criticality: 12/01/73

Unit Number: 2 Type: PWR
Docket Number: 50-306
Thermal Power(MWH): 1.22E+07
Commercial Operation: 12/21/74
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.80E+06
Initial Criticality: 12/17/74

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.17E+00
CO-58	1.95E-05
CO-60	5.01E-06
KR-85	2.57E+00
KR-85M	1.81E-02
KR-88	1.28E-04
SR-89	6.92E-07
CD-109	3.23E-05
SB-125	1.19E-06
I-131	1.43E-03
XE-131M	8.93E-01
I-133	5.16E-05
XE-133	7.68E+01
XE-133M	6.56E-01
CS-134	4.90E-06
XE-135	7.09E-01
CS-137	1.19E-05

Total Airborne Tritium Released 1.26E+02 Ci

Installation: Prairie Island
Unit No.(s): 1&2

Location: 26 Mi SE Minneapolis, MN

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-282
Thermal Power(MWH): 1.23E+07
Commercial Operation: 12/16/73
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.83E+06
Initial Criticality: 12/01/73

Unit Number: 2 Type: PWR
Docket Number: 50-306
Thermal Power(MWH): 1.22E+07
Commercial Operation: 12/21/74
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.80E+06
Initial Criticality: 12/17/74

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

BE-7	6.12E-04
AR-41	2.50E-05
SC-47	4.93E-04
CR-51	2.94E-03
MN-54	3.77E-04
FE-55	3.39E-02
CO-57	2.29E-05
CO-58	3.37E-02
FE-59	5.03E-03
CO-60	9.66E-03
ZN-65	3.34E-05
SR-89	1.31E-03
SR-92	8.20E-06
NB-97	1.37E-04
ZR-97	6.37E-05
TC-99M	9.32E-06
RH-105	4.78E-06
AG-110M	2.74E-02
SN-113	1.29E-03
SB-122	7.25E-04
SB-124	6.83E-03
SB-125	5.11E-03
SB-126	1.44E-05
I-131	2.75E-04
XE-131M	4.50E-04
XE-133	1.95E-02
XE-133M	8.91E-05
CS-134	1.47E-04
XE-135	4.55E-04
CS-136	2.77E-06
CS-137	2.18E-04
LA-140	2.39E-05
LA-142	3.60E-06
CE-144	4.65E-05
ND-147	7.12E-06

Total Liquid Tritium Released	3.98E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.73E+08 liters
Volume of Dilution Water Used During Period	5.92E+11 liters

Installation: Prairie Island
Unit No.(s): 1&2

Location: 26 Mi SE Minneapolis, MN

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-282
Thermal Power(MWH): 1.23E+07
Commercial Operation: 12/16/73
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.83E+06
Initial Criticality: 12/01/73

Unit Number: 2 Type: PWR
Docket Number: 50-306
Thermal Power(MWH): 1.22E+07
Commercial Operation: 12/21/74
Cooling Water Source: Mississippi River

Licensee: Northern States Power
Licensed Power(MWT): 1.65E+03
Net Electrical Power(MWH): 3.80E+06
Initial Criticality: 12/17/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Truck	Barnwell, SC
2	Truck	Oak Ridge, TN
4	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	1.00E-01	
CO-58		1.38E+01
CO-60	4.47E+01	3.80E+01
CS-134	3.10E+00	3.60E+00
CS-137	1.16E+01	8.00E+00
FE-55	1.27E+01	1.12E+01
H-3	1.10E+00	
MN-54		2.00E+00
NI-63	2.66E+01	2.19E+01

B

C-14		1.13E+01
CO-60		2.95E+01
FE-55		4.65E+01
H-3		1.60E+00
NI-63		1.11E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.19E+01	after
	Ci 3.23E+02	compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.35E+01	after
	Ci 2.32E-01	compaction
C. Irradiated Components, Control Rods, etc.	m3	
	Ci	
D. Other (describe)	m3	
	Ci	

Installation: Quad-Cities
Unit No.(s): 1&2

Location: 20 Mi NE Moline, IL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-265
Thermal Power(MWH): 1.70E+07
Commercial Operation: 02/18/73
Cooling Water Source: Mississippi River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 2.51E+03
Net Electrical Power(MWH): 5.33E+06
Initial Criticality: 10/18/71

Unit Number: 2 Type: BWR
Docket Number: 50-265
Thermal Power(MWH): 1.38E+07
Commercial Operation: 03/10/73
Cooling Water Source: Mississippi River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 2.51E+03
Net Electrical Power(MWH): 4.35E+06
Initial Criticality: 04/26/72

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

AR-41	1.10E+00
CR-51	1.07E-02
MN-54	4.61E-03
CO-58	6.41E-04
FE-59	4.32E-05
CO-60	1.01E-02
ZN-65	4.17E-05
KR-85M	9.88E-01
KR-87	1.93E+00
KR-88	1.56E+01
SR-89	1.59E-03
SR-90	1.40E-05
NB-95	1.54E-05
MO-99	4.39E-03
I-131	4.65E-03
I-133	1.06E-02
XE-133	4.48E+00
I-135	1.85E-02
XE-135	2.72E+00
XE-135M	1.04E+01
CS-137	2.73E-04
XE-138	4.25E+01
BA-140	7.51E-04
LA-140	3.27E-03
HF-181	2.03E-05

Total Airborne Tritium Released 1.16E+02 Ci

Installation: Quad-Cities
Unit No.(s): 1&2

Location: 20 Mi NE Moline, IL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: BWR
Docket Number: 50-265
Thermal Power(MWH): 1.70E+07
Commercial Operation: 02/18/73
Cooling Water Source: Mississippi River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 2.51E+03
Net Electrical Power(MWH): 5.33E+06
Initial Criticality: 10/18/71

Unit Number: 2 Type: BWR
Docket Number: 50-265
Thermal Power(MWH): 1.38E+07
Commercial Operation: 03/10/73
Cooling Water Source: Mississippi River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 2.51E+03
Net Electrical Power(MWH): 4.35E+06
Initial Criticality: 04/26/72

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CR-51	2.48E-02
MN-54	9.55E-03
FE-55	7.11E-03
CO-58	2.94E-03
FE-59	1.30E-03
CO-60	6.06E-02
ZN-65	7.88E-04
AS-76	1.72E-04
SR-89	5.47E-04
SR-90	7.24E-05
NB-95	4.70E-05
AG-110M	1.03E-03
SB-124	6.45E-05
XE-133	6.75E-04
XE-135	9.68E-04
CS-137	4.24E-03
LA-140	1.98E-05

Total Liquid Tritium Released	2.61E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	6.95E+06 liters
Volume of Dilution Water Used During Period	1.38E+12 liters

Installation: Quad-Cities
Unit No.(s): 1&2

Location: 20 Mi NE Moline, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-265
Thermal Power(MWH): 1.70E+07
Commercial Operation: 02/18/73
Cooling Water Source: Mississippi River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 2.51E+03
Net Electrical Power(MWH): 5.33E+06
Initial Criticality: 10/18/71

Unit Number: 2 Type: BWR
Docket Number: 50-265
Thermal Power(MWH): 1.38E+07
Commercial Operation: 03/10/73
Cooling Water Source: Mississippi River

Licensee: Commonwealth Edison Co.
Licensed Power(MWT): 2.51E+03
Net Electrical Power(MWH): 4.35E+06
Initial Criticality: 04/26/72

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
40		CNSI- Barnwell, SC
2		CNSI- Channanhan
8		CNSI- WA
11		Hittman- SEG
10		Kindrick- Quadrex
1		Raytech- CNSI
4		Raytech- CNSI, Channahan
1		Raytech- WA
6		USE- WA

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.21E+03 Ci 1.24E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 Ci	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Rancho Seco
Unit No.(s): 1

Location: 25 Mi SE Sacramento, CA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-312
Thermal Power(MWH): 0.00E+00
Commercial Operation: 04/17/75
Cooling Water Source: Folsom Canal

Licensee: Sacramento Municipal Utility
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 09/16/74

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

KR-85	2.20E-01
-------	----------

Total Airborne Tritium Released 2.92E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

FE-55	5.49E-06
CO-60	9.13E-05
CS-134	8.50E-06
CS-137	1.02E-04

Total Liquid Tritium Released	1.37E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.84E+07 liters
Volume of Dilution Water Used During Period	1.83E+10 liters

Installation: Rancho Seco
Unit No.(s): 1

Location: 25 Mi SE Sacramento, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-312
Thermal Power(MWH): 0.00E+00
Commercial Operation: 04/17/75
Cooling Water Source: Folsom Canal

Licensee: Sacramento Municipal Utility
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 0.00E+00
Initial Criticality: 09/16/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
5	Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	3.68E-01
C-14	1.73E-01
CD-109	1.08E+00
CO-58	1.02E+00
CO-60	2.44E+00
CS-134	1.94E+01
CS-137	6.79E+01
FE-55	2.24E+00
H-3	8.28E-01
MN-54	3.09E-01
NI-63	3.63E+00
SB-125	2.79E-01
SR-90	1.49E-01

B

AG-110M	1.13E-01
C-14	8.17E-01
CO-60	1.14E+01
CS-134	3.39E-01
CS-137	2.04E+00
FE-55	1.04E+01
H-3	5.69E+01
MN-54	1.46E-01
NI-63	1.71E+01
SB-125	2.25E-01

D

C-14	3.46E-01	
CO-60		1.47E+01
CS-134		8.36E+00
CS-137	1.91E-01	7.69E+01
FE-55	1.22E-01	
H-3	9.94E+01	

Installation: Rancho Seco
Unit No.(s): 1

Location: 25 Mi SE Sacramento, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.50E+01 Ci 3.69E+02	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 5.89E+00 Ci 1.26E-01	burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)		
Oil	m3 9.56E+00 m3 0.00E+00 Ci 6.91E-04	before incineration after incineration
Moisture Seperator Reheaters&Chevrans	m3 7.11E-01 Ci 5.50E-03	burial volume

Installation: River Bend
Unit No.(s): 1

Location: 24 Mi NNW Baton Rouge, LA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-458
Thermal Power(MWH): 1.78E+07
Commercial Operation: 06/16/86
Cooling Water Source: Mississippi River

Licensee: Gulf States Utilities Co
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 5.59E+06
Initial Criticality: 10/31/85

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	1.64E-05
MN-54	1.26E-05
CO-58	4.01E-05
CO-60	1.05E-04
KR-85M	7.49E+00
KR-87	2.54E+01
KR-88	7.36E+00
SR-89	5.89E-04
SR-90	2.66E-05
I-131	4.83E-02
I-133	2.47E-01
XE-133	4.34E+02
XE-133M	2.40E+00
XE-135	4.17E+02
XE-135M	6.71E+01
XE-137	9.36E+00
XE-138	6.14E+01
BA-140	2.57E-03
CE-141	8.91E-05

Total Airborne Tritium Released 4.52E+01 Ci

Installation: River Bend
Unit No.(s): 1

Location: 24 Mi NNW Baton Rouge, LA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-458
Thermal Power(MWH): 1.78E+07
Commercial Operation: 06/16/86
Cooling Water Source: Mississippi River

Licensee: Gulf States Utilities Co
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 5.59E+06
Initial Criticality: 10/31/85

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	7.83E-06
CR-51	3.66E-01
MN-54	4.65E-02
FE-55	6.98E-02
CO-57	1.75E-05
CO-58	2.35E-02
FE-59	2.00E-02
CO-60	1.14E-01
ZN-65	3.31E-03
AS-76	1.20E-03
SR-89	5.63E-04
SR-90	5.93E-04
Y-91M	1.12E-04
SR-92	5.07E-04
Y-92	7.50E-03
NB-95	3.22E-03
ZR-95	2.03E-03
NB-97	2.71E-03
MO-99	2.88E-03
TC-99M	2.53E-03
RU-103	1.88E-03
RU-105	6.93E-04
AG-110M	2.01E-03
SN-113	1.97E-04
SB-122	3.92E-04
SB-124	3.41E-03
I-131	4.50E-03
XE-131M	1.45E-04
TE-132	1.12E-03
I-133	9.14E-04
XE-133	1.87E-01
XE-133M	9.48E-03
CS-134	5.85E-04
XE-135	2.47E-01
CS-137	7.09E-04
BA-140	4.83E-04
LA-140	3.91E-02
CE-141	4.89E-03
CE-144	1.16E-03
W-187	2.27E-04
NP-239	8.67E-03

Total Liquid Tritium Released	8.35E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.67E+07 liters
Volume of Dilution Water Used During Period	5.04E+09 liters

Installation: River Bend
Unit No.(s): 1

Location: 24 Mi NNW Baton Rouge, LA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-458
Thermal Power(MWH): 1.78E+07
Commercial Operation: 06/16/86
Cooling Water Source: Mississippi River

Licensee: Gulf States Utilities Co
Licensed Power(MWT): 2.89E+03
Net Electrical Power(MWH): 5.59E+06
Initial Criticality: 10/31/85

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
38	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AM-241	2.56E-04	1.87E-04
BA-140		9.00E-02
C-14	2.03E-01	8.20E-02
CE-141		1.32E-02
CM-242	1.51E-04	1.09E-04
CM-244	3.09E-04	1.88E-04
CO-57	8.95E-01	4.18E-03
CO-58	1.43E+01	1.59E+00
CO-60	3.57E+01	3.44E+01
CR-51	7.94E+00	1.18E+00
CS-134		1.03E+00
CS-136		5.25E-04
CS-137		9.53E-01
FE-55	1.65E+01	5.03E+01
FE-59	1.22E+00	8.19E-02
H-3	2.34E+00	1.52E-01
I-129		5.08E-04
I-131	9.31E-05	2.49E-02
I-133		7.86E-17
LA-140		1.67E-06
MN-54	1.78E+01	8.38E+00
MO-99	7.09E-08	2.23E-06
NB-95	8.92E-02	1.47E-02
NI-63	1.17E+00	5.50E-01
NP-239		8.90E-06
PU-238	5.65E-04	3.48E-04
PU-239	4.14E-04	2.57E-04
PU-241	1.50E-02	9.29E-03
RU-103		3.06E-03
SB-122	1.98E-08	
SB-124	2.66E-01	1.17E-02
SN-113		5.25E-04
SR-90		5.81E-02
TC-99		1.44E-03
TE-132		5.12E-06
ZN-65	1.45E+00	1.02E+00

Installation: River Bend
Unit No.(s): 1

Location: 24 Mi NNW Baton Rouge, LA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

A			
	ZR-95	1.41E-01	3.23E-03
B			
	C-14	1.70E+00	2.78E+00
	CO-58		7.00E-01
	CO-60	6.23E+01	5.49E+01
	CR-51	1.00E+00	5.60E-01
	FE-55	2.18E+01	2.69E+01
	H-3		5.00E-02
	MN-54	9.00E+00	7.03E+00
	NI-63	1.30E+00	4.97E+00
	PU-241		5.60E-01
	ZN-65	2.90E+00	1.13E+00
	ZR-95		1.07E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.39E+02	after
	Ci 3.90E+02	compaction
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.06E+02	after
	Ci 1.23E+01	compaction
C. Irradiated Components, Control Rods, etc.	m3	
	Ci	
D. Other (describe)	m3	
	Ci	

Installation: H. B. Robinson
Unit No.(s): 2

Location: 4.5 Mi WNW Hartsville, SC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-261

Thermal Power(MWH): 1.08E+07

Commercial Operation: 03/07/71

Cooling Water Source: Robinson Impoundment

Licensee: Carolina Power & Light

Licensed Power(MWT): 2.30E+03

Net Electrical Power(MWH): 3.31E+06

Initial Criticality: 09/20/70

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.77E+00
CR-51	5.93E-06
MN-54	5.66E-08
CO-58	7.48E-06
CO-60	1.20E-04
KR-85	3.54E+00
KR-85M	2.76E-03
KR-87	2.43E-05
KR-88	1.29E-03
NB-95	2.34E-08
I-131	1.09E-07
XE-131M	1.11E-03
XE-133	7.74E-01
XE-133M	1.01E-02
XE-135	1.04E-01
CS-137	9.44E-08
CE-144	1.48E-07

Total Airborne Tritium Released 4.44E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.08E-05
CR-51	4.53E-03
MN-54	1.68E-03
FE-55	1.86E-01
CO-57	8.05E-06
CO-58	1.27E-02
FE-59	2.13E-04
CO-60	9.48E-02
ZN-65	5.57E-06
SR-90	3.87E-06
SR-92	8.43E-06
NB-95	1.68E-04
NB-97	7.16E-05
RU-103	4.65E-07
AG-110M	3.58E-03
SN-113	1.53E-05
SB-124	1.02E-02
SB-125	4.51E-02
XE-131M	3.58E-04
XE-133	1.40E-01
XE-133M	1.95E-03
CS-134	5.69E-05
XE-135	4.24E-04
CS-137	7.92E-04

Total Liquid Tritium Released

Volume of Liquid Waste Released (Prior to Dilution)

Volume of Dilution Water Used During Period

3.53E+02 Ci

4.61E+06 liters

7.63E+11 liters

Installation: H. B. Robinson
Unit No.(s): 2

Location: 4.5 Mi WNW Hartsville, SC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR	Licensee: Carolina Power & Light
Docket Number: 50-261	Licensed Power(MWT): 2.30E+03
Thermal Power(MWH): 1.08E+07	Net Electrical Power(MWH): 3.31E+06
Commercial Operation: 03/07/71	Initial Criticality: 09/20/70
Cooling Water Source: Robinson Impoundment	

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
61	Sole Use Vehicle	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	1.00E-01	
CO-58		5.43E+00
CO-60	3.17E+01	5.56E+01
CR-51		1.59E+00
CS-134	7.00E+00	
CS-137	1.57E+01	
FE-55	3.75E+01	3.11E+01
H-3, C-14		1.11E-01
MN-54	1.20E+00	3.10E+00
NI-63	5.50E+00	3.17E+00
SB-125	1.30E+00	

B

C-14	1.00E-02	
C-14, TC-99, I-129, CS-137		1.39E-02
CO-58	6.86E+00	3.20E+00
CO-60	1.16E+01	1.31E+01
CR-51	9.16E+00	5.38E+00
FE-55	6.02E+01	6.83E+01
NB-95	2.72E+00	1.77E+00
NI-63	7.43E+00	8.34E+00
ZR-95	2.06E+00	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 8.25E+00 Ci 7.74E+00	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 4.34E+02 m3 6.17E+01 Ci 6.70E+00	before compaction after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Salem
Unit No.(s): 1

Location: 20 Mi S Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Licensee: PSE&G

Docket Number: 50-272

Licensed Power(MWT): 3.41E+03

Thermal Power(MWH): 1.90E+07

Net Electrical Power(MWH): 5.96E+06

Commercial Operation: 06/30/77

Initial Criticality: 12/11/76

Cooling Water Source: Delaware River

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.10E-03
CO-58	1.77E-05
CO-60	1.53E-05
KR-85	2.27E+00
KR-85M	3.45E-02
KR-88	1.09E-02
I-131	1.17E-03
XE-131M	3.23E+00
XE-133	3.01E+02
XE-133M	2.68E+00
XE-135	3.87E+00

Total Airborne Tritium Released 8.58E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	1.87E-03
NA-24	2.15E-03
AR-41	1.26E-06
CR-51	1.16E-02
MN-54	1.52E-01
FE-55	5.77E-02
CO-57	7.54E-03
CO-58	1.98E+00
FE-59	1.15E-03
CO-60	2.39E-01
ZN-65	7.74E-03
BR-84	7.11E-05
KR-87	1.41E-05
KR-88	5.92E-05
SR-89	1.62E-03
SR-90	1.80E-04
NB-95	9.76E-03
ZR-95	4.53E-03
TC-99M	8.53E-04
TC-101	8.69E-05
RH-105	1.02E-04
CD-109	4.07E-04
AG-110M	8.40E-04
SN-113	3.57E-04
SB-122	1.65E-03
SB-124	1.94E-02
SB-125	6.09E-02
SB-126	6.38E-05
I-131	3.53E-02
XE-131M	5.46E-03
TE-132	5.64E-05
I-133	8.36E-03
XE-133	6.51E-01
XE-133M	3.72E-03
CS-134	1.91E-01
I-135	1.42E-04

Installation: Salem
Unit No.(s): 1

Location: 20 Mi S Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
XE-135	9.45E-03
CS-136	1.21E-03
CS-137	2.02E-01
CS-138	1.69E-04
BA-140	1.10E-04
LA-140	5.35E-04
LA-141	1.76E-03
CE-144	1.69E-04
PR-147	5.66E-04

Total Liquid Tritium Released	3.53E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.74E+06 liters
Volume of Dilution Water Used During Period	1.82E+12 liters

Installation: Salem
Unit No.(s): 2

Location: 20 Mi S Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-311

Thermal Power(MWH): 1.69E+07

Commercial Operation: 10/13/81

Cooling Water Source: Delaware River

Licensee: PSE&G

Licensed Power(MWT): 3.41E+03

Net Electrical Power(MWH): 5.41E+06

Initial Criticality: 08/02/80

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	9.44E-03
CO-58	1.93E-05
CO-60	8.56E-06
KR-85	7.15E-01
KR-85M	1.56E-02
KR-87	3.70E-04
KR-88	1.16E-02
I-131	1.78E-04
XE-131M	2.56E-01
XE-133	1.47E+02
XE-133M	1.79E-01
XE-135	5.39E-01
CS-137	9.06E-07

Total Airborne Tritium Released 6.84E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	4.82E-04
NA-24	2.28E-03
AR-41	2.75E-05
CR-51	1.48E-02
MN-54	1.52E-01
FE-55	1.52E-01
CO-57	7.92E-03
CO-58	2.01E+00
FE-59	1.09E-03
CO-60	2.36E-01
ZN-65	1.06E-02
ZN-69M	4.29E-05
KR-85M	1.52E-04
RB-88	3.32E-04
SR-89	1.64E-03
SR-90	8.64E-05
SR-92	4.41E-05
NB-95	1.03E-02
ZR-95	1.74E-03
TC-99M	8.67E-04
CD-109	1.76E-04
AG-110M	2.56E-03
SN-113	6.85E-04
SB-122	1.94E-03
SB-124	2.22E-02
SB-125	7.41E-02
SB-126	5.95E-05
I-131	3.83E-02
XE-131M	4.78E-03
TE-132	2.08E-05
I-133	1.07E-02
XE-133	9.02E-01
XE-133M	8.19E-03

Installation: Salem
Unit No.(s): 2

Location: 20 Mi S Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
CS-134	1.86E-01
I-135	7.09E-04
XE-135	3.08E-02
CS-136	1.32E-03
CS-137	1.95E-01
CS-138	2.10E-04
LA-140	6.23E-04
CE-141	4.24E-05
LA-141	1.06E-03
CE-144	7.67E-05

Total Liquid Tritium Released	3.03E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.09E+06 liters
Volume of Dilution Water Used During Period	1.41E+12 liters

Installation: Salem
Unit No.(s): 1&2

Location: 20 Mi S Wilmington, DE

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-272
Thermal Power(MWH): 1.90E+07
Commercial Operation: 06/30/77
Cooling Water Source: Delaware River

Licensee: PSE&G
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 5.96E+06
Initial Criticality: 12/11/76

Unit Number: 2 Type: PWR
Docket Number: 50-311
Thermal Power(MWH): 1.69E+07
Commercial Operation: 10/13/81
Cooling Water Source: Delaware River

Licensee: PSE&G
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 5.41E+06
Initial Criticality: 08/02/80

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
20	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58		5.64E+01
CO-60		8.30E+00
CS-134		1.40E+00
CS-137		1.50E+00
FE-55		2.16E+01
MN-54		5.00E+00
NI-63		5.80E+00
B		
CE-144	2.30E-01	2.00E-01
CO-58	5.66E+01	5.66E+01
CO-60	9.39E+00	9.40E+00
CS-134	2.13E+00	2.10E+00
CS-137	4.21E+00	4.20E+00
FE-55	1.57E+01	1.57E+01
H-3	1.00E-01	1.00E-01
MN-54	1.20E+00	1.20E+00
NI-63	9.11E+00	9.10E+00
PU-241	1.25E+00	1.20E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.26E+01 C1 1.43E+02	non-compacted
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 7.66E+01 C1 1.78E+00	after compaction
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: San Onofre
Unit No.(s): 1

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-206
Thermal Power(MWH): 5.04E+06
Commercial Operation: 01/01/68
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 1.35E+03
Net Electrical Power(MWH): 1.54E+06
Initial Criticality: 06/14/67

Airborne Effluents

Nuclide Released	Activity (Ci)
CR-51	3.55E-07
CO-58	9.49E-07
CO-60	2.33E-07
BR-82	8.19E-06
KR-85	6.33E+00
KR-85M	1.33E+01
KR-88	2.06E-03
RB-88	1.46E-04
I-131	7.22E-03
XE-131M	1.01E+01
I-132	2.09E-04
I-133	1.89E-03
XE-133	1.74E+03
XE-133M	6.65E+00
CS-134	1.82E-06
I-135	5.49E-05
XE-135	1.87E+01
XE-135M	4.77E+00
CS-137	2.43E-05
CS-138	2.34E-04
CE-143	7.07E-08

Total Airborne Tritium Released 9.13E+01 Ci

Installation: San Onofre
Unit No.(s): 1

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-206
Thermal Power(MWH): 5.04E+06
Commercial Operation: 01/01/68
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 1.35E+03
Net Electrical Power(MWH): 1.54E+06
Initial Criticality: 06/14/67

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	2.44E-05
CR-51	2.05E-03
MN-54	1.28E-03
FE-55	8.02E-03
CO-57	6.91E-05
CO-58	2.09E-02
FE-59	3.35E-04
CO-60	1.74E-02
ZN-65	4.73E-06
KR-85	1.98E-01
KR-85M	7.38E-03
KR-88	4.01E-03
SR-89	1.97E-04
SR-90	6.66E-04
SR-92	4.16E-03
NB-95	2.32E-04
ZR-95	1.16E-04
MO-99	5.00E-05
TC-99M	4.79E-05
RU-103	2.77E-04
AG-110M	2.53E-04
SB-124	1.62E-04
SB-125	1.61E-04
I-131	3.41E-02
XE-131M	1.41E-01
I-133	1.48E-03
XE-133	5.13E+00
XE-133M	4.90E-03
CS-134	1.22E-01
I-135	1.76E-05
XE-135	1.57E-04
CS-136	1.64E-03
CS-137	1.88E-01
BA-140	7.79E-05
LA-140	9.51E-05
CE-141	7.94E-05
CE-144	1.08E-04

Total Liquid Tritium Released	1.42E+03 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.78E+06 liters
Volume of Dilution Water Used During Period	3.57E+11 liters

Installation: San Onofre
Unit No.(s): 1

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-206
Thermal Power(MWH): 5.04E+06
Commercial Operation: 01/01/68
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 1.35E+03
Net Electrical Power(MWH): 1.54E+06
Initial Criticality: 06/14/67

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

B

AM-241		5.02E-02
C-14	1.48E-03	6.56E-02
CO-58	9.07E-01	5.70E-01
CO-60	4.42E+00	3.31E+01
CS-134	3.49E+00	2.71E+00
CS-137	9.58E+00	1.02E+01
CU-243/244		1.36E-01
EU-154		1.23E-01
EU-155		3.66E-02
FE-55	3.01E+00	2.24E+00
H-3	7.57E+01	2.62E+01
I-129	3.56E-01	5.98E-01
MN-54		2.87E-01
NI-63	2.48E+00	1.49E+01
PU-238		9.49E-02
PU-239/240		1.97E-02
PU-241		3.14E+00
SR-90		5.45E+00
TC-99	9.73E-02	7.21E-04

D

AM-241	4.98E-02
C-14	3.72E-05
CO-57	2.11E-02
CO-60	4.59E+01
CS-137	5.07E-02
CU-242	3.85E-04
CU-243/244	2.08E-02
FE-55	2.90E+01
H-3	1.31E+00
I-129	3.09E-04
MN-54	1.01E-01
NI-63	2.16E+01
PU-238	5.56E-02
PU-239/240	1.97E-02
PU-241	1.81E+00
SR-89	4.62E-04
SR-90	8.43E-02
TC-99	8.13E-04

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 Ci	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 5.81E+01 Ci 4.40E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Filters	m3 5.66E-02 Ci 8.34E+00	

Installation: San Onofre
Unit No.(s): 2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 2 Type: PWR
Docket Number: 50-361
Thermal Power(MWH): 2.55E+07
Commercial Operation: 08/08/83
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.31E+06
Initial Criticality: 07/26/82

Unit Number: 3 Type: PWR
Docket Number: 50-362
Thermal Power(MWH): 2.04E+07
Commercial Operation: 04/01/84
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 6.58E+06
Initial Criticality: 08/29/83

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

AR-41	1.49E+01
CR-51	1.39E-05
MN-54	2.60E-07
CO-57	9.55E-08
CO-58	4.93E-04
CO-60	7.17E-05
BR-82	4.12E-04
KR-85	3.12E+00
KR-85M	4.46E-01
KR-87	2.22E-04
RB-88	1.78E-03
SR-89	2.11E-09
NB-95	5.00E-08
MO-99	7.68E-07
TC-99M	7.88E-07
SN-113	1.36E-10
I-131	6.44E-03
XE-131M	6.49E-01
I-132	3.53E-04
TE-132	5.84E-11
I-133	5.72E-03
XE-133	1.10E+03
XE-133M	2.48E-01
CS-134	2.25E-07
I-135	4.39E-04
XE-135	4.50E+01
CS-137	3.48E-05
CS-138	3.09E-04
BA-139	1.78E-08
CE-143	1.24E-05
CE-144	2.29E-06

Total Airborne Tritium Released 3.27E+01 Ci

Installation: San Onofre
Unit No.(s): 2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 2 Type: PWR
Docket Number: 50-361
Thermal Power(MWH): 2.55E+07
Commercial Operation: 08/08/83
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.31E+06
Initial Criticality: 07/26/82

Unit Number: 3 Type: PWR
Docket Number: 50-362
Thermal Power(MWH): 2.04E+07
Commercial Operation: 04/01/84
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 6.58E+06
Initial Criticality: 08/29/83

Liquid Effluents

Nuclide Released	Activity (Ci)
AR-41	1.22E-06
CR-51	6.28E-03
MN-54	1.67E-03
FE-55	4.12E-02
CO-57	1.60E-04
CO-58	3.86E-02
FE-59	4.84E-04
CO-60	8.72E-03
ZN-65	3.33E-06
KR-85M	2.17E-05
KR-88	3.17E-02
Y-91M	3.55E-04
SR-92	2.62E-05
NB-95	4.83E-03
ZR-95	2.41E-03
NB-97	5.52E-05
MO-99	1.29E-05
TC-99M	1.31E-05
RU-103	1.28E-04
AG-110M	1.40E-03
SN-113	6.22E-04
SB-124	1.30E-03
SB-125	1.27E-02
I-131	3.96E-04
XE-131M	1.33E-02
I-132	6.29E-05
TE-132	6.70E-05
I-133	9.35E-06
XE-133	5.31E-01
XE-133M	2.35E-03
CS-134	2.84E-02
XE-135	1.89E-03
CS-137	5.18E-02
BA-139	8.35E-05

Installation: San Onofre
Unit No.(s): 2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 2&3 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

LA-140	2.20E-04
CE-141	1.42E-05
CE-144	2.26E-04

Total Liquid Tritium Released	9.27E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	3.62E+07 liters
Volume of Dilution Water Used During Period	2.60E+12 liters

Installation: San Onofre
Unit No.(s): 2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 2 Type: PWR
Docket Number: 50-361
Thermal Power(MWH): 2.55E+07
Commercial Operation: 08/08/83
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.31E+06
Initial Criticality: 07/26/82

Unit Number: 3 Type: PWR
Docket Number: 50-362
Thermal Power(MWH): 2.04E+07
Commercial Operation: 04/01/84
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 6.58E+06
Initial Criticality: 08/29/83

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

B

C-14	9.87E-03	1.65E-02
CM-242	3.52E-01	
CO-58	1.02E+00	1.85E+00
CO-60	8.08E+00	1.30E+01
CS-134	1.04E+01	7.59E+00
CS-137	1.70E+01	2.01E+01
FE-55	1.95E+01	2.61E+01
H-3	3.84E+01	2.49E+01
I-129	3.29E-02	3.61E-03
MN-54	5.36E-01	1.04E+00
NB-95	5.81E-01	8.92E-01
NI-63	2.68E+00	3.38E+00
PU-241	4.81E-01	
SB-125	4.87E-01	8.37E-01
SR-89		2.32E-02
TC-99	7.42E-02	1.30E-03
ZR-95	2.40E-01	2.99E-01

D

AG-110M	6.53E-02	2.60E-01
AM-241		2.21E-04
C-14	7.05E-03	1.76E-04
CE-141		4.56E-05
CE-144	1.56E-01	4.27E-01
CM-242	5.20E-03	
CO-57	7.80E-02	1.46E-01
CO-58	1.52E+01	4.97E+00
CO-60	8.27E+00	9.71E+00
CR-51	9.28E-01	7.99E-03
CS-134	1.51E+00	7.22E-01
CS-136		4.41E-05
CS-137	4.16E+00	2.46E+00
CU-242		1.17E-02
CU-243/244		6.14E-04
FE-55	3.90E+01	6.78E+01
FE-59	1.46E-01	1.04E-02
H-3	2.09E+01	8.37E-01
I-129	5.51E-04	1.24E-03
MN-54	1.28E+00	1.09E+00
NB-94		5.86E-03
NB-95	1.29E+00	2.47E-02
NI-63	5.64E+00	9.54E+00
PU-238		5.46E-04
PU-239/240		6.33E-04
PU-241	9.20E-02	1.54E-01
RU-103		8.44E-03

Installation: San Onofre
Unit No.(s): 2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 2&3 (continued)

Estimate of Major Nuclide Composition (by type of D	Jan-June	July-Dec
RU-106	1.28E-01	6.14E-01
SB-124	9.35E-02	2.93E-02
SB-125	3.20E-01	8.78E-01
SR-89	5.60E-03	7.07E-04
SR-90	3.77E-03	1.05E-02
TC-99	3.29E-04	4.47E-04
ZR-95	6.97E-01	2.58E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 Ci	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.74E+02 Ci 6.42E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Filters	m3 1.79E+00 Ci 2.70E+01	

Installation: San Onofre
Unit No.(s): 1&2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-206
Thermal Power(MWH): 5.04E+06
Commercial Operation: 01/01/68
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 1.35E+03
Net Electrical Power(MWH): 1.54E+06
Initial Criticality: 06/14/67

Unit Number: 2 Type: PWR
Docket Number: 50-361
Thermal Power(MWH): 2.55E+07
Commercial Operation: 08/08/83
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.31E+06
Initial Criticality: 07/26/82

Unit Number: 3 Type: PWR
Docket Number: 50-362
Thermal Power(MWH): 2.04E+07
Commercial Operation: 04/01/84
Cooling Water Source: Pacific Ocean

Licensee: So. California Edison Co.
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 6.58E+06
Initial Criticality: 08/29/83

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
7	Truck/Trailer	Barnwell, SC
1	Truck/Cask	Beatty, NV
11	Truck/Trailer	Beatty, NV
1	Truck/Cask	Richland, WA
2	Truck/Trailer	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

D

AG-110M	5.57E-02
AM-241	2.49E-03
C-14	6.18E-04
CE-144	1.98E-01
CO-57	1.31E-01
CO-58	2.23E+00
CO-60	2.15E+01
CR-51	1.06E-02
CS-134	4.26E-01
CS-137	9.81E-01
CU-242	1.12E-02
CU-243/244	2.81E-03
FE-55	5.54E+01
FE-59	1.04E-02
H-3	2.42E+00
I-129	1.07E-05
MN-54	1.98E+00
NB-95	2.73E-02
NI-63	1.42E+01

Installation: San Onofre
Unit No.(s): 1&2&3

Location: 2.5 Mi S San Clemente, CA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2&3(continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

D

PU-238	3.01E-03
PU-239/240	2.04E-03
PU-241	2.15E-01
SB-124	3.63E-03
SR-89	6.07E-04
SR-90	2.65E-02
TC-99	3.92E-04
ZR-95	1.55E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 Ci	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 Ci	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Filters	m3 2.12E-01 Ci 1.04E+00	

Installation: Seabrook
Unit No.(s): 1

Location: 13 Mi S Portsmouth, NH

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-443
Thermal Power(MWH): 1.26E+07
Commercial Operation: 08/19/90
Cooling Water Source: Atlantic Ocean

Licensee: North Atlantic
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 4.09E+06
Initial Criticality: 06/13/89

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.08E+01
KR-85M	3.56E+00
XE-133	3.68E+01
XE-135	5.59E+01

Total Airborne Tritium Released 2.52E-01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	2.32E-04
CO-58	1.16E-03
FE-59	1.43E-05
SB-124	8.02E-04

Total Liquid Tritium Released	1.13E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.03E+08 liters
Volume of Dilution Water Used During Period	7.58E+11 liters

Installation: Sequoyah
Unit No.(s): 1&2

Location: Daisy, TN

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-327
Thermal Power(MWH): 2.10E+07
Commercial Operation: 07/01/81
Cooling Water Source: Chickamauga Lake

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.82E+06
Initial Criticality: 07/05/80

Unit Number: 2 Type: PWR
Docket Number: 50-328
Thermal Power(MWH): 2.19E+07
Commercial Operation: 06/01/82
Cooling Water Source: Chickamauga Lake

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.18E+06
Initial Criticality: 11/05/81

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	9.75E+00
CR-51	9.97E-06
CO-57	1.58E-09
CO-58	5.28E-05
CO-60	5.23E-06
KR-85	1.34E+01
KR-85M	6.52E+00
KR-87	1.29E-01
KR-88	5.03E+00
MO-99	1.74E-07
TC-99M	1.74E-07
I-131	1.97E-04
XE-131M	5.00E+01
I-133	1.78E-05
XE-133	5.80E+03
XE-133M	7.55E+01
XE-135	1.08E+02
XE-135M	8.11E-02

Total Airborne Tritium Released 1.17E+01 Ci

Installation: Sequoyah
Unit No.(s): 1&2

Location: Daisy, TN

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-327
Thermal Power(MWH): 2.10E+07
Commercial Operation: 07/01/81
Cooling Water Source: Chickamauga Lake

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.82E+06
Initial Criticality: 07/05/80

Unit Number: 2 Type: PWR
Docket Number: 50-328
Thermal Power(MWH): 2.19E+07
Commercial Operation: 06/01/82
Cooling Water Source: Chickamauga Lake

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.18E+06
Initial Criticality: 11/05/81

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	3.76E-05
AR-41	2.23E-05
CR-51	4.62E-02
MN-54	7.39E-03
FE-55	1.87E-01
MN-56	7.67E-06
CO-57	3.26E-03
CO-58	7.10E-01
FE-59	4.88E-03
CO-60	7.94E-02
ZN-65	2.73E-04
ZN-69M	1.86E-05
BR-82	6.53E-06
BR-84	8.59E-05
KR-85M	2.09E-04
RB-86	9.97E-05
KR-87	3.64E-05
KR-88	9.80E-06
SR-91	2.20E-05
Y-91	4.17E-03
Y-91M	5.80E-05
SR-92	8.96E-06
Y-93	8.70E-05
NB-95	7.02E-03
ZR-95	2.90E-03
NB-97	8.01E-05
MO-99	3.58E-02
TC-99M	3.58E-02
RU-103	1.08E-03
SB-124	4.03E-03
SB-125	6.57E-02
SB-127	2.71E-05
TE-129M	2.77E-04
I-131	3.80E-03
XE-131M	1.98E-02
TE-132	3.55E-05
I-133	1.08E-04

Installation: Sequoyah
Unit No.(s): 1&2

Location: Daisy, TN

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
XE-133	1.68E+00
XE-133M	2.16E-02
CS-134	1.80E-03
I-135	1.49E-05
XE-135	3.04E-02
XE-135M	2.96E-05
CS-136	5.87E-05
CS-137	3.61E-03
CS-138	1.34E-05
BA-140	2.63E-03
LA-140	6.54E-03
CE-141	1.71E-03
CE-143	1.63E-04
CE-144	1.88E-03

Total Liquid Tritium Released	8.53E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.20E+07 liters
Volume of Dilution Water Used During Period	5.60E+09 liters

Installation: Sequoyah
Unit No.(s): 1&2

Location: Daisy, TN

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-327
Thermal Power(MWH): 2.10E+07
Commercial Operation: 07/01/81
Cooling Water Source: Chickamauga Lake

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.82E+06
Initial Criticality: 07/05/80

Unit Number: 2 Type: PWR
Docket Number: 50-328
Thermal Power(MWH): 2.19E+07
Commercial Operation: 06/01/82
Cooling Water Source: Chickamauga Lake

Licensee: Tennessee Valley Authority
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.18E+06
Initial Criticality: 11/05/81

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
208	Motor freight	Barnwell, SC
1	Motor freight	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58	2.99E+01	3.74E+01
CO-60	2.00E+01	1.64E+01
CS-134		7.79E+00
CS-137	4.44E+00	9.26E+00
FE-55	1.62E+01	1.81E+01
H-3	1.37E+00	
MN-54	6.56E+00	5.01E+00
NI-63	1.67E+01	5.67E+00
B		
CO-58	3.06E+00	2.62E+01
CO-60	1.68E+01	1.30E+01
CR-51		8.64E+00
FE-55	7.10E+01	4.21E+01
NB-95		2.23E+00
NI-63	7.62E+00	5.83E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.05E+01 C1 6.27E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.18E+02 C1 2.79E+02	
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Shoreham
Unit No.(s): 1

Location: Brookhaven, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Docket Number: 50-322
Thermal Power(MWH):
Commercial Operation:
Cooling Water Source: Long Island Sound

Licensee: Long Island Power Authority
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH):
Initial Criticality: 02/15/85

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AG-110M	3.58E+00	3.34E+00
CE-141	2.60E-02	2.30E-02
CE-144	1.27E+00	1.06E+00
CO-57	1.09E-01	1.02E-01
CO-58	1.26E+01	1.34E+01
CO-60	2.67E+01	2.51E+01
CR-51	1.72E+01	1.81E+01
CS-137	3.75E-01	3.41E-01
FE-55	2.19E+01	2.19E+01
FE-59	1.49E+00	1.68E+00
H-3	3.64E+00	3.26E+00
MN-54	1.34E+00	2.76E+00
NB-95		1.48E-01
NI-59	1.90E-02	1.80E-02
NI-63	1.03E+00	9.90E-01
PU-241	4.24E+00	3.33E+00
SB-124	1.34E-01	1.27E-01
SR-90	7.00E-03	7.00E-03
ZN-65	4.40E+00	4.17E+00

B

AG-110M	3.07E+00	3.07E+00
CO-57		7.00E-03
CO-58	1.08E+01	1.09E+01
CO-60	2.30E+01	2.29E+01
CR-51	1.48E+01	1.54E+01
CS-137		3.00E-03
FE-55	1.89E+01	1.86E+01
FE-59	1.28E+00	1.31E+00
H-3	3.08E-01	4.50E-02
MN-54	2.41E+01	2.39E+01
NI-59		1.00E-03
NI-63		6.00E-02
SB-124		8.00E-03
ZN-65	3.79E+00	3.76E+00
ZR-95		5.00E-03

Installation: Shoreham
Unit No.(s): 1

Location: Brookhaven, NY

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

C

C-14	3.00E-03
CO-60	2.94E+01
FE-55	6.64E+01
MN-54	1.89E+00
NI-59	1.50E-02
NI-63	2.24E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.58E+01 Ci 6.12E-03	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.18E+01 Ci 9.16E-02	burial volume
C. Irradiated Components, Control Rods, etc.	m3 2.80E+00 Ci 8.19E-01	burial volume
D. Other (describe)	m3 Ci	

Installation: South Texas
Unit No.(s): 1

Location: 12 Mi SSW Bay City, TX

Effluent and Waste Disposal Annual Report for 1990

Type: PWR	Licensee: Houston Lighting & Power
Docket Number: 50-498	Licensed Power(MWT): 3.80E+03
Thermal Power(MWH): 1.90E+07	Net Electrical Power(MWH): 6.00E+06
Commercial Operation: 08/25/88	Initial Criticality: 03/08/88
Cooling Water Source: Main Cooling Reservoir	

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.54E+00
CR-51	1.19E-04
MN-54	4.41E-06
CO-58	3.05E-04
FE-59	3.43E-06
CO-60	2.46E-05
KR-85M	8.12E-05
ZR-95	3.99E-06
SB-124	1.16E-07
I-131	3.45E-04
XE-131M	1.38E-03
I-133	1.41E-04
XE-133	1.65E+02
XE-133M	7.91E-04
CS-134	1.24E-06
XE-135	4.42E+00
CS-137	3.13E-04
Unidentified	2.61E-05

Total Airborne Tritium Released 2.23E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	9.77E-01
MN-54	1.18E-01
FE-55	1.19E+00
CO-58	4.16E+00
FE-59	1.01E-01
CO-60	3.48E-01
ZN-65	4.63E-03
SR-90	3.20E-05
SR-92	4.23E-07
NB-95	9.59E-02
ZR-95	5.09E-02
ZR-97	2.05E-04
MO-99	1.98E-05
TC-99M	2.01E-05
AG-110M	2.01E-02
TE-129M	1.75E-04
I-131	2.04E-03
I-133	1.61E-04
XE-133	1.17E+00
CS-134	9.75E-03
XE-135	4.23E-03
CS-137	1.45E-02
LA-140	1.38E-03
CE-144	5.86E-04

Total Liquid Tritium Released	3.45E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.45E+07 liters
Volume of Dilution Water Used During Period	7.40E+11 liters

Installation: South Texas
Unit No.(s): 2

Location: 12 Mi SSW Bay City, TX

Effluent and Waste Disposal Annual Report for 1990

Type: PWR	Licensee: Houston Lighting & Power
Docket Number: 50-499	Licensed Power(MWT): 3.80E+03
Thermal Power(MWH): 2.02E+07	Net Electrical Power(MWH): 6.43E+06
Commercial Operation: 06/19/89	Initial Criticality: 03/12/89
Cooling Water Source: Main Cooling Reservoir	

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	4.73E+00
CR-51	3.40E-05
MN-54	4.34E-06
CO-58	1.08E-04
FE-59	4.75E-06
CO-60	1.12E-05
KR-85M	6.13E-02
ZR-95	5.04E-06
I-131	1.73E-04
XE-131M	2.95E-02
I-133	2.86E-05
XE-133	1.00E+02
XE-133M	3.47E-02
XE-135	3.78E+00
CE-144	8.71E-06
Unidentified	2.26E-04

Total Airborne Tritium Released 1.90E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	6.22E-01
MN-54	1.09E-01
FE-55	2.61E+00
CO-58	1.46E+00
FE-59	1.07E-01
CO-60	4.10E-01
ZN-65	8.85E-03
NB-95	2.47E-01
ZR-95	1.37E-01
ZR-97	7.63E-07
MO-99	1.04E-05
TC-99M	1.05E-05
RU-103	2.50E-04
AG-110M	7.38E-04
TE-127	6.17E-04
I-131	3.35E-03
TE-132	1.18E-05
I-133	1.77E-05
XE-133	4.88E+00
CS-134	3.15E-04
XE-135	1.64E-02
CS-137	2.28E-03
BA-140	2.77E-06
LA-140	5.57E-05
CE-141	6.38E-06
CE-144	1.02E-04

Total Liquid Tritium Released	4.70E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.85E+07 liters
Volume of Dilution Water Used During Period	7.40E+11 liters

Installation: South Texas
Unit No.(s): 1&2

Location: 12 Mi SSW Bay City, TX

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR Licensee: Houston Lighting & Power
Docket Number: 50-498 Licensed Power(MWT): 3.80E+03
Thermal Power(MWH): 1.90E+07 Net Electrical Power(MWH): 6.00E+06
Commercial Operation: 08/25/88 Initial Criticality: 03/08/88
Cooling Water Source: Main Cooling Reservoir

Unit Number: 2 Type: PWR Licensee: Houston Lighting & Power
Docket Number: 50-499 Licensed Power(MWT): 3.80E+03
Thermal Power(MWH): 2.02E+07 Net Electrical Power(MWH): 6.43E+06
Commercial Operation: 06/19/89 Initial Criticality: 03/12/89
Cooling Water Source: Main Cooling Reservoir

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
2	Truck	CNSI, Barnwell, SC
9	Truck	SEG, Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58	8.28E+01	5.23E+01
CO-60	6.20E+00	1.89E+01
CR-51		2.60E+00
FE-55	1.80E+00	5.50E+00
H-3	1.60E+00	2.40E+00
MN-54	3.50E+00	6.20E+00
NB-95		2.00E+00
NI-63	2.60E+00	7.90E+00
ZR-95		1.10E+00
B		
CO-58	2.64E+01	7.10E+00
CR-51	3.94E+01	1.42E+01
FE-55	6.80E+00	2.50E+00
H-3	4.62E+01	7.12E+01
NB-95	3.80E+00	1.20E+00
ZR-95	3.40E+00	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.16E+01 C1 1.33E+01	non-compacted
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 4.60E+01 C1 5.88E-01	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: St. Lucie
Unit No.(s): 1

Location: 8 Mi S Ft. Pierce, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-335
Thermal Power(MWH): 1.43E+07
Commercial Operation: 12/21/76
Cooling Water Source: Atlantic Ocean

Licensee: Florida Power & Light
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 4.49E+06
Initial Criticality: 04/22/76

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.75E+00
CO-57	2.20E-06
CO-60	1.27E-05
KR-85M	4.96E+00
KR-88	1.88E+00
I-131	8.35E-03
XE-131M	3.50E-01
I-132	5.56E-02
TE-132	1.94E-05
I-133	5.50E-03
XE-133	5.17E+02
XE-133M	3.16E-01
XE-135	9.20E+01
CS-138	5.86E-02

Total Airborne Tritium Released 8.01E+01 Ci

Installation: St. Lucie
Unit No.(s): 1

Location: 8 Mi S Ft. Pierce, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-335

Thermal Power(MWH): 1.43E+07

Commercial Operation: 12/21/76

Cooling Water Source: Atlantic Ocean

Licensee: Florida Power & Light

Licensed Power(MWT): 2.70E+03

Net Electrical Power(MWH): 4.49E+06

Initial Criticality: 04/22/76

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	5.38E-04
CR-51	5.43E-02
MN-54	3.75E-03
FE-55	1.18E-01
FE-59	2.39E-04
CO-57	2.97E-04
CO-58	2.48E-01
FE-59	1.02E-03
CO-60	5.40E-02
KR-85M	4.76E-05
SR-89	2.19E-03
SR-90	4.82E-05
Y-90	4.82E-05
Y-92	2.30E-04
NB-95	1.74E-02
ZR-95	1.02E-02
NB-97	6.09E-03
TC-99M	7.75E-05
RU-103	8.00E-04
AG-110	4.72E-03
SN-113	1.70E-03
SB-122	3.21E-03
SB-124	4.14E-02
SB-125	1.21E-01
TE-129	8.07E-04
I-131	2.61E-02
XE-131M	3.34E-03
I-132	6.22E-05
TE-132	3.82E-05
I-133	1.38E-02
XE-133	6.02E-01
XE-133M	4.16E-03
CS-134	4.03E-02
I-135	1.04E-04
XE-135	3.16E-03
CS-136	1.84E-04
CS-137	5.46E-02
CS-138	9.76E-05
LA-140	1.76E-03
CE-141	1.99E-05

Total Liquid Tritium Released

2.84E+02 Ci

Volume of Liquid Waste Released (Prior to Dilution)

6.74E+07 liters

Volume of Dilution Water Used During Period

1.65E+12 liters

Installation: St. Lucie
Unit No.(s): 2

Location: 8 Mi S Ft. Pierce, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-389
Thermal Power(MWH): 1.70E+07
Commercial Operation: 08/08/83
Cooling Water Source: Atlantic Ocean

Licensee: Florida Power & Light
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 5.32E+06
Initial Criticality: 06/02/83

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.39E+00
CO-58	2.86E-05
KR-85	4.11E-01
KR-85M	2.31E+00
KR-87	1.58E-02
KR-88	6.52E+00
SR-89	3.06E-06
I-131	5.72E-03
XE-131M	1.77E+00
I-132	6.03E-03
I-133	2.11E-02
XE-133	4.76E+02
XE-133M	2.25E+00
XE-135	4.33E+01
CS-137	3.40E-05

Total Airborne Tritium Released 2.55E+01 Ci

Installation: St. Lucie
Unit No.(s): 2

Location: 8 Mi S Ft. Pierce, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-389
Thermal Power(MWH): 1.70E+07
Commercial Operation: 08/08/83
Cooling Water Source: Atlantic Ocean

Licensee: Florida Power & Light
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 5.32E+06
Initial Criticality: 06/02/83

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	5.38E-04
CR-51	5.43E-02
MN-54	3.75E-03
FE-55	9.82E-02
CO-57	2.97E-04
CO-58	2.48E-01
FE-59	1.26E-03
CO-60	5.40E-02
KR-85M	4.76E-05
SR-89	1.83E-03
SR-90	4.82E-05
Y-90	4.82E-05
Y-92	2.30E-04
NB-95	1.74E-02
ZR-95	1.02E-02
NB-97	6.09E-03
TC-99M	7.75E-05
RU-103	8.00E-04
AG-110	4.72E-03
SN-113	1.70E-03
SB-122	3.21E-03
SB-124	4.14E-02
SB-125	1.21E-01
TE-129	8.07E-04
I-131	6.19E-03
XE-131M	3.34E-03
I-132	6.22E-05
TE-132	3.82E-05
I-133	1.44E-03
XE-133	5.99E-01
XE-133M	4.16E-03
CS-134	3.73E-02
I-135	1.04E-04
XE-135	3.16E-03
CS-136	6.70E-05
CS-137	5.09E-02
CS-138	1.08E-04
LA-140	1.76E-03
CE-141	1.99E-05

Total Liquid Tritium Released	2.84E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	7.63E+06 liters
Volume of Dilution Water Used During Period	1.65E+12 liters

Installation: St. Lucie
Unit No.(s): 1&2

Location: 8 Mi S Ft. Pierce, FL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-335
Thermal Power(MWH): 1.43E+07
Commercial Operation: 12/21/76
Cooling Water Source: Atlantic Ocean

Licensee: Florida Power & Light
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 4.49E+06
Initial Criticality: 04/22/76

Unit Number: 2 Type: PWR
Docket Number: 50-389
Thermal Power(MWH): 1.70E+07
Commercial Operation: 08/08/83
Cooling Water Source: Atlantic Ocean

Licensee: Florida Power & Light
Licensed Power(MWT): 2.70E+03
Net Electrical Power(MWH): 5.32E+06
Initial Criticality: 06/02/83

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
59	Sole Use Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

BE-7	4.41E+00	
CO-58	1.44E+01	8.26E+00
CO-60	2.75E+01	1.39E+01
CR-51	4.93E+00	
CS-134	7.84E+00	2.43E+01
CS-137	1.19E+01	3.21E+01
FE-55	1.24E+01	3.39E+00
I-131	2.35E+00	
MN-54	3.51E+00	3.40E+00
NB-95	2.46E+00	
NI-63	4.82E+00	1.21E+01
ZR-95	1.42E+00	

B

CO-58	3.99E+00	7.76E+00
CO-60	1.15E+01	1.95E+01
CR-51		2.16E+00
CS-134	4.96E+00	8.06E+00
CS-137	1.50E+01	2.40E+01
FE-55	5.99E+01	2.58E+01
H-3		4.49E+00
NB-95	1.18E+00	9.80E-01
NI-63	1.26E+00	2.20E+00
SB-125	8.40E-01	3.83E+00

C

CO-58		6.00E-01
CO-60		3.86E+01
FE-55		5.31E+01
MN-54		4.90E+00
NI-63		2.80E+00

Installation: St. Lucie
Unit No.(s): 1&2

Location: 8 Mi S Ft. Pierce, FL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

D

CO-60	4.26E+01	1.94E+01
CS-134	1.92E+00	5.91E+00
CS-137	6.25E+00	2.16E+01
FE-55	3.57E+01	4.93E+01
MN-54	9.70E-01	
NI-63	9.56E+00	2.21E+00
SB-125	1.74E+00	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.57E+01 Ci 6.62E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.18E+02 Ci 8.16E+00	volume reduced
C. Irradiated Components, Control Rods, etc.	m3 1.63E+00 Ci 5.21E+03	
D. Other (describe)	m3 4.94E+01 m3 5.87E+00 m3 5.89E+00 Ci 6.24E+00	non-compressible metal solidified tank sludge solidified phosphoric acid

Installation: Summer
Unit No.(s): 1

Location: 26 Mi NW Columbia, SC

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-395
Thermal Power(MWH): 1.93E+07
Commercial Operation: 01/01/84
Cooling Water Source: Monticello Reservoir

Licensee: South Carolina Electric & Gas Co.
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 6.11E+06
Initial Criticality: 10/22/82

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	3.09E+00
CR-51	3.13E-05
CO-58	5.85E-05
CO-60	1.69E-05
KR-85	2.04E+00
KR-85M	1.38E+00
KR-87	6.73E-01
KR-88	1.36E+00
RB-88	1.77E-02
NB-95	3.94E-06
ZR-95	3.19E-06
TC-99M	7.86E-06
RU-103	3.77E-06
I-131	4.41E-04
XE-131M	1.19E+00
I-132	5.35E-04
I-133	2.60E-04
XE-133	7.02E+02
XE-133M	3.59E+00
CS-134	9.11E-07
I-134	1.75E-05
I-135	7.91E-05
XE-135	3.47E+01
XE-135M	7.24E-01
CS-137	1.95E-06
CS-138	1.22E-02
XE-138	1.13E-03

Total Airborne Tritium Released 2.28E+00 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
F-18	2.23E-03
NA-24	3.03E-04
CR-51	5.65E-03
MN-54	3.16E-02
FE-55	3.84E-02
NI-56	4.35E-07
CO-57	1.59E-04
CO-58	2.50E-02
FE-59	5.30E-05
CO-60	3.97E-02
ZN-65	1.24E-03
KR-85	7.16E-07
KR-85M	5.85E-07
KR-87	2.06E-06
SR-89	7.81E-04
SR-90	1.02E-03
ZR-NB-95	3.24E-03
ZR-97	4.74E-06
MO-99	9.70E-04
TC-99M	6.99E-04

Installation: Summer
Unit No.(s): 1

Location: 26 Mi NW Columbia, SC

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
RU-103	2.35E-04
RU-106	3.15E-03
AG-110M	5.84E-04
SN-113	1.95E-04
SB-122	5.20E-04
SB-124	1.40E-03
SB-125	1.60E-02
SB-126	6.54E-05
I-131	3.53E-02
XE-131M	2.82E-03
I-132	2.20E-02
TE-132	2.72E-04
I-133	3.34E-02
XE-133	3.36E-01
XE-133M	2.62E-03
CS-134	2.25E-02
I-134	1.15E-02
I-135	2.28E-02
XE-135	1.85E-03
CS-136	1.85E-04
CS-137	3.19E-02
CS-138	1.03E-03
BA-LA-140	1.59E-04
CE-141	3.11E-05
CE-144	1.57E-03
NP-239	4.53E-06

Total Liquid Tritium Released	4.22E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	2.06E+08 liters
Volume of Dilution Water Used During Period	1.47E+12 liters

Installation: Summer
Unit No.(s): 1

Location: 26 Mi NW Columbia, SC

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-395
Thermal Power(MWH): 1.93E+07
Commercial Operation: 01/01/84
Cooling Water Source: Monticello Reservoir

Licensee: South Carolina Electric & Gas Co.
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH): 6.11E+06
Initial Criticality: 10/22/82

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
64	Truck	Barnwell, SC

Irradiated Fuel Shipments (Disposition)

Number of Shipments	Mode of Transportation	Destination
1	Truck	Chalk River, Canada

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	2.40E+00	1.22E+01
CO-60	1.85E+01	2.13E+01
CS-134	9.82E+00	6.03E+00
CS-137	1.12E+01	8.43E+00
FE-55	4.35E+01	2.70E+01
MN-54		4.48E+00
NI-63	9.44E+00	2.16E+01
SB-125		1.01E+00

B

CO-58	2.23E+01	1.57E+00
CO-60	7.89E+00	1.99E+01
CR-51	3.80E+00	
CS-134	6.22E+00	8.29E+00
CS-137	5.33E+00	1.39E+01
FE-55	4.77E+01	4.12E+01
H-3		1.60E+00
MN-54		2.69E+00
NI-63		6.94E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.91E+01 Ci 2.07E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 7.67E+02 m3 8.13E+01 Ci 1.51E+01	before compaction after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Surry
Unit No.(s): 1&2

Location: 19 Mi NW Newport News, VA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-280
Thermal Power(MWH): 1.51E+07
Commercial Operation: 12/22/72
Cooling Water Source: James River

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.77E+06
Initial Criticality: 07/01/72

Unit Number: 2 Type: PWR
Docket Number: 50-281
Thermal Power(MWH): 1.85E+07
Commercial Operation: 05/01/73
Cooling Water Source: James River

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 5.84E+06
Initial Criticality: 03/07/73

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.25E-01
CR-51	2.89E-05
MN-54	1.17E-06
CO-58	8.43E-05
CO-60	4.92E-04
SE-75	1.05E-08
KR-85	5.81E+00
KR-85M	7.76E-02
KR-87	9.53E-02
KR-88	1.35E-01
RB-88	1.52E-04
NB-95	5.03E-06
AG-110M	3.08E-06
SB-125	6.17E-09
I-131	1.33E-03
XE-131M	2.55E+00
I-132	5.05E-03
I-133	8.32E-04
XE-133	4.33E+02
XE-133M	1.55E+00
CS-134	5.55E-05
I-135	2.96E-05
XE-135	6.80E+00
XE-135M	1.05E-01
CS-137	9.34E-04
CS-138	2.39E-04
XE-138	2.80E-01

Total Airborne Tritium Released 2.17E+01 Ci

Installation: Surry
Unit No.(s): 1&2

Location: 19 Mi NW Newport News, VA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-280
Thermal Power(MWH): 1.51E+07
Commercial Operation: 12/22/72
Cooling Water Source: James River

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.77E+06
Initial Criticality: 07/01/72

Unit Number: 2 Type: PWR
Docket Number: 50-281
Thermal Power(MWH): 1.85E+07
Commercial Operation: 05/01/73
Cooling Water Source: James River

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 5.84E+06
Initial Criticality: 03/07/73

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-22	1.91E-06
NA-24	2.08E-04
AR-41	8.93E-04
CR-51	2.37E-01
MN-54	1.11E-02
FE-55	1.83E+00
CO-57	6.23E-04
CO-58	3.42E-01
FE-59	1.84E-02
CO-60	4.44E-01
ZN-65	9.35E-05
KR-85M	3.76E-05
KR-87	4.17E-05
KR-88	6.07E-05
RB-88	2.60E-04
NB-95	2.31E-02
ZR-95	1.48E-02
MO-99	2.34E-05
TC-99M	9.12E-05
RU-103	6.78E-03
AG-110M	2.32E-02
SB-124	2.12E-02
SB-125	4.40E-01
I-131	3.60E-02
XE-131M	2.29E-02
I-132	2.57E-04
TE-132	5.54E-04
I-133	1.78E-04
XE-133	3.46E+00
XE-133M	3.17E-02
CS-134	1.96E-01
XE-135	8.64E-02
XE-135M	2.82E-03
CS-136	4.71E-06
CS-137	9.54E-01
BA-140	3.09E-05
LA-140	5.40E-04

Installation: Surry
Unit No.(s): 1&2

Location: 19 Mi NW Newport News, VA

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

CE-141	4.16E-04
--------	----------

CE-144	3.65E-04
--------	----------

ND-147	1.92E-05
--------	----------

Total Liquid Tritium Released	1.11E+03 Ci
-------------------------------	-------------

Volume of Liquid Waste Released (Prior to Dilution)	1.74E+08 liters
---	-----------------

Volume of Dilution Water Used During Period	2.40E+12 liters
---	-----------------

Installation: Surry
Unit No.(s): 1&2

Location: 19 Mi NW Newport News, VA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-280
Thermal Power(MWH): 1.51E+07
Commercial Operation: 12/22/72
Cooling Water Source: James River

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 4.77E+06
Initial Criticality: 07/01/72

Unit Number: 2 Type: PWR
Docket Number: 50-281
Thermal Power(MWH): 1.85E+07
Commercial Operation: 05/01/73
Cooling Water Source: James River

Licensee: Virginia Electric & Power
Licensed Power(MWT): 2.44E+03
Net Electrical Power(MWH): 5.84E+06
Initial Criticality: 03/07/73

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
12	Truck	Barnwell, SC
15	Truck	Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

BE-7		1.21E+00
CO-60	6.37E+01	3.08E+01
CS-134		7.14E+00
CS-137	1.39E+00	2.76E+01
FE-55	4.64E+00	1.21E+01
MN-54	1.19E+00	
NI-63	2.69E+01	1.83E+01

B

CO-58	1.18E+00	
CO-60	2.94E+01	3.02E+01
CR-51	1.48E+00	
CS-134	1.43E+00	1.40E+00
CS-137	1.73E+01	1.19E+01
FE-55	3.79E+01	3.05E+01
NI-63	1.13E+01	2.53E+01

D

CO-60	7.42E+01	
CS-134	1.79E+00	
CS-137	2.32E+01	

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.43E+01 Ci 1.13E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 6.55E+02 m3 1.01E+02 Ci 6.51E+00	before processing after processing
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Organic waste	m3 1.30E+01 Ci 4.17E-03	

Installation: Susquehanna
Unit No.(s): 1&2

Location: 7 Mi NE Berwick, PA

Effluent and Waste Disposal Annual Report for 1980

Unit Number: 1 Type: BWR
Docket Number: 50-387
Thermal Power(MWH): 2.05E+07
Commercial Operation: 06/08/83
Cooling Water Source: Susquehanna River

Licensee: Pennsylvania Power & Light Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 6.44E+06
Initial Criticality: 09/10/82

Unit Number: 2 Type: BWR
Docket Number: 50-388
Thermal Power(MWH): 2.63E+07
Commercial Operation: 02/12/85
Cooling Water Source: Susquehanna River

Licensee: Pennsylvania Power & Light Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 8.29E+06
Initial Criticality: 05/08/84

Airborne Effluents

Nuclide Released	Activity (Ci)
MN-54	3.28E-04
CO-58	7.42E-05
FE-59	5.27E-05
CO-60	1.55E-04
ZN-65	2.53E-04
XE-133	7.21E+01

Total Airborne Tritium Released 9.24E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
AR-41	4.24E-07
CR-51	3.28E-03
MN-54	2.20E-02
FE-55	9.20E-02
CO-58	1.19E-03
FE-59	2.00E-03
CO-60	1.32E-02
ZN-65	7.00E-04
AG-110M	1.03E-04
XE-133	5.11E-04
XE-135	3.39E-04

Total Liquid Tritium Released	5.80E+01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.56E+06 liters
Volume of Dilution Water Used During Period	1.50E+10 liters

Installation: Susquehanna
Unit No.(s): 1&2

Location: 7 Mi NE Berwick, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: BWR
Docket Number: 50-387
Thermal Power(MWH): 2.05E+07
Commercial Operation: 06/08/83
Cooling Water Source: Susquehanna River

Licensee: Pennsylvania Power & Light Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 6.44E+06
Initial Criticality: 09/10/82

Unit Number: 2 Type: BWR
Docket Number: 50-388
Thermal Power(MWH): 2.63E+07
Commercial Operation: 02/12/85
Cooling Water Source: Susquehanna River

Licensee: Pennsylvania Power & Light Company
Licensed Power(MWT): 3.29E+03
Net Electrical Power(MWH): 8.29E+06
Initial Criticality: 05/08/84

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
54	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	1.66E-01	3.40E-02
CO-58	5.56E-01	2.28E-01
CO-60	6.84E+00	1.10E+01
CR-51	5.79E+00	1.77E-01
CS-134	1.76E-02	7.61E-03
CS-137	1.61E-02	1.43E-02
FE-55	7.07E+01	7.39E+01
FE-59	1.79E+00	5.90E-02
H-3	3.95E-02	1.32E-02
I-129	4.47E-04	3.69E-04
I-131	8.08E-04	1.63E-03
MN-54	1.32E+01	1.31E+01
NI-63	7.44E-02	3.33E-01
PU-241		7.20E-04
SB-124	5.53E-02	1.03E-03
SR-90	2.12E-04	1.35E-04
TC-99	7.67E-04	3.88E-04
ZN-65	2.26E-01	1.49E+00

B

C-14	1.57E-02	
CO-58	3.81E-01	3.45E-01
CO-60	7.39E+00	7.60E+00
CR-51	6.37E-01	6.47E-01
FE-55	7.93E+01	8.06E+01
FE-59	9.93E-01	1.05E+00
H-3	1.72E-03	1.77E-02
I-129	3.59E-02	5.44E-02
MN-54	9.98E+00	7.71E+00
NI-63		1.03E-01

Installation: Susquehanna
Unit No.(s): 1&2

Location: 7 Mi NE Berwick, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1&2 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

B

PU-241		1.22E-02
TC-99	1.37E-01	8.11E-02
ZN-65	1.18E+00	1.40E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.85E+02 Ci 2.95E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.22E+02 Ci 8.19E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Three Mile Island
Unit No.(s): 1

Location: 10 Mi SE Harrisburg, PA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-289
Thermal Power(MWH): 1.69E+07
Commercial Operation: 09/02/74
Cooling Water Source: Susquehanna River

Licensee: GPU Nuclear Group
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 5.30E+06
Initial Criticality: 06/05/74

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	8.83E-01
CO-58	2.28E-08
KR-85	9.64E-01
KR-85M	7.87E-01
KR-87	1.75E-01
KR-88	7.37E-01
I-131	1.53E-03
XE-131M	4.50E+00
I-132	4.64E-05
I-133	7.96E-04
XE-133	6.36E+02
XE-133M	5.14E+00
CS-134	4.80E-08
I-135	2.21E-04
XE-135	1.49E+01
XE-135M	9.81E-01
CS-137	5.66E-08
XE-138	1.18E-01

Total Airborne Tritium Released 2.26E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	1.23E-04
MN-54	4.32E-05
FE-55	2.08E-03
CO-58	8.63E-03
FE-59	4.18E-05
CO-60	2.01E-04
KR-85	2.05E-03
SR-89	1.91E-05
NB-95	6.21E-05
ZR-95	9.00E-06
AG-110M	2.64E-04
SB-125	5.51E-04
I-131	1.51E-03
XE-133	5.88E-06
CS-134	3.91E-03
CS-137	6.12E-03
LA-140	7.14E-06

Total Liquid Tritium Released	2.10E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	5.19E+07 liters
Volume of Dilution Water Used During Period	2.59E+10 liters

Installation: Three Mile Island
Unit No.(s): 1

Location: 10 Mi SE Harrisburg, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-289
Thermal Power(MWH): 1.69E+07
Commercial Operation: 09/02/74
Cooling Water Source: Susquehanna River

Licensee: GPU Nuclear Group
Licensed Power(MWT): 2.57E+03
Net Electrical Power(MWH): 5.30E+06
Initial Criticality: 06/05/74

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
4	Tractor	CNSI, Barnwell, SC
1	Tractor-Closed Van	SEG, Oak Ridge, TN
16	Tractor-Flatbed	SEG, Oak Ridge, TN
8	Tractor-Flatbed	US Ecology, Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58	1.03E+01	1.20E+01
CS-134	2.94E+01	5.82E+00
CS-137	4.76E+01	8.90E+00
H-3		6.51E+01
NI-63	4.71E+00	
B		
CO-58	1.27E+01	1.30E+01
CS-137	1.30E+01	1.27E+01
FE-55	1.07E+01	1.07E+01
I-131	3.23E+01	3.27E+01
NI-63	1.39E+01	1.37E+01
D		
CO-60		3.14E+01
FE-55		2.77E+01
H-3		1.30E+01
NI-63		1.94E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.42E+02 Ci 6.47E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 4.40E+02 Ci 5.86E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Oil for incineration	m3 8.50E-01 Ci 1.83E-04	

Installation: Three Mile Island
Unit No.(s): 2

Location: 10 Mi SE Harrisburg, PA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-320
Thermal Power(MWH):
Commercial Operation: 12/30/78
Cooling Water Source: Susquehanna River

Licensee: Metro. ED & Jersey Central Power & Light
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH):
Initial Criticality: 03/28/78

Airborne Effluents

Nuclide Released	Activity (Ci)
CO-58	1.15E-07
SR-90	1.49E-07
CS-137	3.48E-06

Total Airborne Tritium Released 1.03E+01 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
SR-90	6.45E-05
CS-137	1.12E-04

Total Liquid Tritium Released	8.80E-04 Ci
Volume of Liquid Waste Released (Prior to Dilution)	4.22E+05 liters
Volume of Dilution Water Used During Period	4.80E+10 liters

Installation: Three Mile Island
Unit No.(s): 2

Location: 10 Mi SE Harrisburg, PA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-320
Thermal Power(MWH):
Commercial Operation: 12/30/78
Cooling Water Source: Susquehanna River

Licensee: Metro. ED & Jersey Central Power & Light
Licensed Power(MWT): 2.77E+03
Net Electrical Power(MWH):
Initial Criticality: 03/28/78

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
4	Tractor-cask	CNSI, Barnwell, SC
6	Tractor-flatbed	SEG, Oak Ridge, TN
2	Tractor-cask	US Ecology, Beatty, NV
1	Tractor-cask	US Ecology, Richland, WA
1	Tractor-flatbed	US Ecology, Richland, WA

Irradiated Fuel Shipments (Disposition)

Number of Shipments	Mode of Transportation	Destination
3	Rail Cask	INEL, Scoville, ID

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CS-137	6.38E+00	4.06E+01
FE-55	3.99E+00	
NI-63	9.12E+00	4.72E-01
PM-147		2.12E+00
SR-90	7.68E+01	5.58E+01
B		
CS-137		2.12E+01
PM-147		7.56E+00
PU-241		4.48E+00
SB-125		1.56E+00
SR-90		6.01E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.59E+01	before compaction
	ci 7.74E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 3.24E+02	before compaction
	ci 1.54E+00	
C. Irradiated Components, Control Rods, etc.	m3	
	ci	
D. Other (describe)	m3	
	ci	

Installation: Trojan
Unit No.(s): 1

Location: 43 Mi NW Portland, OR

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-344
Thermal Power(MWH): 1.90E+07
Commercial Operation: 05/20/76
Cooling Water Source: Columbia River

Licensee: Portland General Electric
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.07E+06
Initial Criticality: 12/15/75

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	5.16E-01
MN-54	1.32E-07
FE-55	5.59E-06
CO-58	9.47E-06
KR-85	1.99E+00
KR-85M	1.74E-02
KR-87	1.14E-02
KR-88	2.10E-02
SR-89	8.88E-05
SR-90	9.13E-07
MO-99	1.07E-05
I-131	1.51E-03
XE-131M	5.90E-01
I-132	2.87E-03
I-133	1.63E-03
XE-133	2.02E+02
XE-133M	3.00E-01
CS-134	7.86E-06
I-134	4.71E-03
I-135	2.74E-03
XE-135	4.05E-01
XE-135M	5.29E-02
CS-136	1.43E-06
CS-137	1.12E-05
XE-137	1.57E-02
XE-138	2.95E-02
BA-140	1.98E-06

Total Airborne Tritium Released 9.22E+01 Ci

Installation: Trojan
Unit No.(s): 1

Location: 43 Mi NW Portland, OR

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-344
Thermal Power(MWH): 1.90E+07
Commercial Operation: 05/20/76
Cooling Water Source: Columbia River

Licensee: Portland General Electric
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.07E+06
Initial Criticality: 12/15/75

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	4.95E-03
MN-54	8.71E-04
FE-55	6.33E-02
CO-57	4.71E-05
CO-58	1.21E-02
FE-59	9.74E-05
CO-60	1.93E-02
SR-89	3.75E-04
SR-90	7.04E-05
NB-95	4.96E-03
ZR-95	4.01E-03
MO-99	7.78E-06
TC-99M	7.92E-06
RU-103	7.41E-03
RU-106	1.47E-02
AG-110M	1.47E-03
SN-113	5.03E-05
SB-125	5.16E-03
I-131	2.09E-04
I-132	3.49E-05
TE-132	4.04E-05
XE-133	1.13E-03
CS-134	2.37E-04
XE-135	6.74E-05
CS-137	8.17E-04
BA-140	4.23E-05
LA-140	2.27E-04
CE-141	2.62E-04
CE-144	3.12E-03
Unidentified	4.98E-06

Total Liquid Tritium Released	2.19E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	7.12E+07 liters
Volume of Dilution Water Used During Period	6.27E+10 liters

Installation: Trojan
Unit No.(s): 1

Location: 43 Mi NW Portland, OR

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-344
Thermal Power(MWH): 1.90E+07
Commercial Operation: 05/20/76
Cooling Water Source: Columbia River

Licensee: Portland General Electric
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.07E+06
Initial Criticality: 12/15/75

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
8	Exclusive Truck	Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14		7.77E-02
CO-57		7.31E-02
CO-58	1.69E+00	3.15E-01
CO-60	1.69E+00	2.37E+01
CS-134	1.69E+00	1.09E+01
CS-137	1.69E+00	2.62E+01
FE-55	9.15E+01	4.68E+00
H-3		6.17E-02
MN-54		9.77E-01
NI-63		3.18E+01
PU-238		1.72E-03
PU-239/240		3.78E-03
PU-241		1.22E-01
RU-106	1.69E+00	
SB-125		2.28E-01
SR-90		9.02E-01

B

C-14	2.16E+01
CE-141	6.31E-02
CE-144	3.78E-01
CO-58	2.71E+00
CO-60	1.58E+00
CR-51	8.20E-01
CS-134	2.52E-01
CS-137	8.20E-01
FE-55	3.59E+00
H-3	6.46E+01
MN-54	6.31E-02
NB-95	8.20E-01
NI-63	6.94E-01
PU-238	6.31E-02
PU-239	6.31E-02
PU-241	5.04E-01
RU-103	3.15E-01
RU-106	4.41E-01
ZR-95	6.31E-01

Installation: Trojan
Unit No.(s): 1

Location: 43 Mi NW Portland, OR

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 1 (continued)

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.45E+01 Ci 5.82E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.56E+02 Ci 1.58E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Turkey Point
Unit No.(s): 3

Location: 10 Mi E Florida City, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-250
Thermal Power(MWH): 1.12E+07
Commercial Operation: 12/14/72
Cooling Water Source: Closed Cycle Canal

Licensee: Florida Power & Light
Licensed Power(MWT): 2.20E+03
Net Electrical Power(MWH): 3.36E+06
Initial Criticality: 10/20/72

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.18E+00
CO-58	9.66E-06
CO-60	4.40E-05
BR-82	9.77E-05
KR-85	5.47E+00
KR-85M	2.01E-02
KR-87	9.89E-04
RU-103	7.68E-07
I-131	4.52E-03
XE-131M	8.89E+00
I-133	4.10E-04
XE-133	6.62E+02
XE-133M	1.02E+00
CS-134	7.96E-06
XE-135	8.72E+00
XE-135M	3.54E-02
CS-136	1.92E-06
CS-137	1.63E-05
CS-138	3.41E-09

Total Airborne Tritium Released 4.59E+01 Ci

Installation: Turkey Point
Unit No.(s): 3

Location: 10 Mi E Florida City, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR

Docket Number: 50-250

Thermal Power(MWH): 1.12E+07

Commercial Operation: 12/14/72

Cooling Water Source: Closed Cycle Canal

Licensee: Florida Power & Light

Licensed Power(MWT): 2.20E+03

Net Electrical Power(MWH): 3.36E+06

Initial Criticality: 10/20/72

Liquid Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

NA-24	6.06E-06
CR-51	2.29E-03
MN-54	2.14E-02
FE-55	2.99E-02
CO-57	9.20E-06
CO-58	3.79E-02
FE-59	1.91E-04
CO-60	2.74E-02
KR-85	4.07E-03
NB-95	4.04E-04
ZR-95	2.86E-05
ZR-97	2.32E-05
MO-99	2.44E-04
RU-103	6.80E-05
AG-110	3.43E-03
SN-117M	2.40E-05
SB-124	1.13E-03
SB-125	8.53E-03
I-131	4.90E-04
XE-131M	6.44E-02
I-133	1.41E-04
XE-133	1.44E+00
XE-133M	3.60E-03
CS-134	1.38E-03
XE-135	2.68E-04
XE-135M	2.06E-06
CS-137	5.61E-03
LA-140	2.22E-05
CE-144	3.68E-06

Total Liquid Tritium Released

3.22E+02 Ci

Volume of Liquid Waste Released (Prior to Dilution)

8.53E+06 liters

Volume of Dilution Water Used During Period

2.44E+11 liters

Installation: Turkey Point
Unit No.(s): 4

Location: 10 Mi E Florida City, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-251
Thermal Power(MWH): 1.44E+07
Commercial Operation: 09/07/73
Cooling Water Source: Closed Cycle Canal

Licensee: Florida Power & Light
Licensed Power(MWT): 2.20E+03
Net Electrical Power(MWH): 4.38E+06
Initial Criticality: 06/11/73

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	1.19E+00
CO-58	9.21E-06
CO-60	4.40E-05
BR-82	9.77E-05
KR-85	3.10E+00
KR-85M	3.84E-02
KR-87	2.00E-03
RU-103	5.35E-07
I-131	1.79E-03
XE-131M	2.02E+00
I-133	3.96E-04
XE-133	5.76E+02
XE-133M	8.80E-01
CS-134	7.96E-06
XE-135	8.55E+00
XE-135M	3.30E-02
CS-136	1.92E-06
CS-137	1.64E-05

Total Airborne Tritium Released 3.35E+01 Ci

Installation: Turkey Point
Unit No.(s): 4

Location: 10 Mi E Florida City, FL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-251
Thermal Power(MWH): 1.44E+07
Commercial Operation: 09/07/73
Cooling Water Source: Closed Cycle Canal

Licensee: Florida Power & Light
Licensed Power(MWT): 2.20E+03
Net Electrical Power(MWH): 4.38E+06
Initial Criticality: 06/11/73

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	6.06E-06
CR-51	2.29E-03
MN-54	2.14E-02
FE-55	2.99E-02
CO-57	9.20E-06
CO-58	3.79E-02
FE-59	1.91E-04
CO-60	2.74E-02
KR-85	4.07E-03
NB-95	4.04E-04
ZR-95	2.86E-05
ZR-97	2.32E-05
MO-99	2.44E-04
RU-103	6.80E-05
AG-110	3.43E-03
SN-117M	2.40E-05
SB-124	1.13E-03
SB-125	8.53E-03
I-131	3.28E-04
XE-131M	6.44E-02
I-133	1.20E-05
XE-133	1.44E+00
XE-133M	3.60E-03
CS-134	1.38E-03
XE-135	2.68E-04
XE-135M	2.06E-06
CS-137	5.61E-03
LA-140	6.86E-05
CE-144	3.68E-06
NP-239	5.60E-05

Total Liquid Tritium Released	3.22E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	8.53E+06 liters
Volume of Dilution Water Used During Period	2.44E+11 liters

Installation: Turkey Point
Unit No.(s): 3&4

Location: 10 Mi E Florida City, FL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 3 Type: PWR
Docket Number: 50-250
Thermal Power(MWH): 1.12E+07
Commercial Operation: 12/14/72
Cooling Water Source: Closed Cycle Canal

Licensee: Florida Power & Light
Licensed Power(MWT): 2.20E+03
Net Electrical Power(MWH): 3.36E+06
Initial Criticality: 10/20/72

Unit Number: 4 Type: PWR
Docket Number: 50-251
Thermal Power(MWH): 1.44E+07
Commercial Operation: 09/07/73
Cooling Water Source: Closed Cycle Canal

Licensee: Florida Power & Light
Licensed Power(MWT): 2.20E+03
Net Electrical Power(MWH): 4.38E+06
Initial Criticality: 06/11/73

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
7	Truck	Barnwell, SC
22	Truck	Oak Ridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	2.00E+00	
CO-60	6.90E+01	6.90E+01
CS-134	1.00E+00	1.00E+00
CS-137	4.00E+00	6.00E+00
FE-55	3.00E+00	2.00E+00
MN-54		1.00E+00
NI-63	2.00E+01	2.00E+01
SB-125		1.00E+00

B

AG-110M		1.00E+00
CO-58	2.70E+01	2.00E+00
CO-60	4.40E+01	3.10E+01
CR-51	4.00E+00	1.00E+00
CS-134		2.00E+00
CS-137	2.00E+00	9.00E+00
FE-55	1.30E+01	3.70E+01
I-131	2.00E+00	
NB-95		1.00E+00
NI-63	8.00E+00	1.50E+01
SB-125		1.00E+00

D

AG-110M		1.00E+00
CO-58	1.00E+00	2.00E+00
CO-60	3.70E+01	3.10E+01
CR-51		1.00E+00
CS-134	1.00E+00	2.00E+00
CS-137	5.10E+01	9.00E+00
FE-55	4.00E+00	3.70E+01

Installation: Turkey Point
Unit No.(s): 3&4

Location: 10 Mi E Florida City, FL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit No.: 3&4 (continued)

Estimate of Major Nuclide Composition (by type of waste) % Jan-June July-Dec

D

NB-95		1.00E+00
NI-63	6.00E+00	1.50E+01
SB-125		1.00E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 2.87E+01 Ci 6.82E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.41E+03 m3 1.61E+02 Ci 1.15E+01	before volume reduction burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Non-compressible waste	m3 2.56E+01 Ci 2.77E-01	

Installation: Vermont Yankee
Unit No.(s): 1

Location: 5 Mi S Brattleboro, VT

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-271
Thermal Power(MWH): 1.13E+07
Commercial Operation: 11/30/72
Cooling Water Source: Connecticut River

Licensee: Vermont Yankee Nuclear Power
Licensed Power(MWT): 1.59E+03
Net Electrical Power(MWH): 3.62E+06
Initial Criticality: 03/24/72

Airborne Effluents

Nuclide Released	Activity (Ci)
MN-54	1.37E-04
CO-58	6.87E-06
FE-59	2.54E-05
CO-60	5.62E-04
ZN-65	6.41E-05
KR-85M	8.01E+01
KR-87	1.28E+02
KR-88	9.86E+01
SR-89	6.94E-03
SR-90	8.86E-05
I-131	5.51E-02
I-133	1.04E-01
XE-133	1.27E+03
XE-133M	3.78E+01
CS-134	3.58E-04
I-135	1.64E-01
XE-135	6.55E+02
XE-135M	8.11E+02
CS-137	4.66E-04
XE-138	1.99E+03
BA-LA-140	8.59E-03
CE-141	2.89E-06

Total Airborne Tritium Released 9.67E+01 Ci

Installation: Vogtle
Unit No.(s): 1&2

Location: 25 Mi SSE Augusta, GA

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-424
Thermal Power(MWH): 2.32E+07
Commercial Operation: 05/31/87
Cooling Water Source: Savannah River

Licensee: Georgia Power
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.34E+06
Initial Criticality: 03/09/87

Unit Number: 2 Type: PWR
Docket Number: 50-425
Thermal Power(MWH): 2.17E+07
Commercial Operation: 05/20/89
Cooling Water Source: Savannah River

Licensee: Georgia Power
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.85E+06
Initial Criticality: 03/28/89

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	7.17E+00
CR-51	7.06E-06
MN-54	8.38E-07
CO-57	2.35E-07
CO-58	4.20E-05
FE-59	3.74E-06
CO-60	2.86E-06
KR-85	4.06E-01
KR-85M	1.75E-01
KR-88	3.88E-03
SR-90	9.94E-08
I-131	2.80E-05
XE-131M	1.71E+00
I-133	5.23E-05
XE-133	1.72E+02
XE-133M	7.13E-01
XE-135	5.93E+00

Total Airborne Tritium Released 2.15E+02 Ci

Liquid Effluents

Nuclide Released	Activity (Ci)
BE-7	1.39E-03
NA-24	5.71E-04
AR-41	5.84E-05
CR-51	6.51E-02
MN-54	1.38E-02
FE-55	3.53E-01
CO-57	1.47E-03
CO-58	3.17E-01
FE-59	1.64E-02
CO-60	3.83E-02
ZN-65	1.19E-04
KR-85M	3.14E-06
KR-88	2.55E-05
SR-92	2.64E-05
Y-92	5.66E-05
NB-95	8.66E-03
ZR-95	3.11E-03
NB-97	4.24E-04
TC-99M	1.89E-04
AG-110M	3.16E-04
SN-113	6.04E-04
SB-122	6.89E-03
SB-124	3.00E-02

Installation: Vogtle
Unit No.(s): 1&2

Location: 25 Mi SSE Augusta, GA

Effluent and Waste Disposal Annual Report for 1990

Unit No.: 1&2 (continued)

Liquid Effluents

Nuclide Released	Activity (Ci)
SB-125	1.38E-01
TE-129M	7.38E-03
I-131	1.03E-02
XE-131M	1.53E-03
I-132	4.14E-04
TE-132	4.67E-04
I-133	4.44E-04
XE-133	2.00E-01
XE-133M	5.59E-04
CS-134	2.01E-05
XE-135	3.11E-03
CS-137	8.17E-05
BA-140	2.20E-05
LA-140	1.54E-04
CE-144	4.20E-05
HF-181	2.93E-04
W-187	3.05E-05

Total Liquid Tritium Released	1.17E+03 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.33E+07 liters
Volume of Dilution Water Used During Period	7.08E+09 liters

Installation: Vogtle
Unit No.(s): 1&2

Location: 25 Mi SSE Augusta, GA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-424
Thermal Power(MWH): 2.32E+07
Commercial Operation: 05/31/87
Cooling Water Source: Savannah River

Licensee: Georgia Power
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.34E+06
Initial Criticality: 03/09/87

Unit Number: 2 Type: PWR
Docket Number: 50-425
Thermal Power(MWH): 2.17E+07
Commercial Operation: 05/20/89
Cooling Water Source: Savannah River

Licensee: Georgia Power
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 6.85E+06
Initial Criticality: 03/28/89

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
8	Tractor and Shielded cask	CNSI, Barnwell, SC
10	Tractor-Trailer	SEG, Oakridge, TN

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A		
CO-58	2.62E+01	4.61E+01
CO-60	3.05E+01	3.22E+01
Others	4.33E+01	2.16E+01
B		
CO-58		3.58E+01
CO-60	4.34E+01	
FE-55	2.40E+01	2.46E+01
Others	3.27E+01	3.96E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 3.59E+01 Ci 1.63E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 5.70E+01 Ci 6.57E-01	after compaction
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Waterford
Unit No.(s): 3

Location: 20 Mi W New Orleans, LA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-382
Thermal Power(MWH): 2.69E+07
Commercial Operation: 09/24/85
Cooling Water Source: Mississippi River

Licensee: Louisiana Power & Light
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.60E+06
Initial Criticality: 03/04/85

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	4.37E-01
CO-58	1.12E-07
BR-82	4.56E-05
KR-85	1.98E-02
KR-85M	6.82E+00
KR-87	6.71E-02
KR-88	3.03E-01
I-131	5.99E-04
XE-131M	2.08E+00
I-133	4.66E-05
XE-133	5.58E+03
XE-133M	1.60E+00
XE-135	1.46E+02

Total Airborne Tritium Released 2.05E+02 Ci

Installation: Waterford
Unit No.(s): 3

Location: 20 Mi W New Orleans, LA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-382
Thermal Power(MWH): 2.69E+07
Commercial Operation: 09/24/85
Cooling Water Source: Mississippi River

Licensee: Louisiana Power & Light
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.60E+06
Initial Criticality: 03/04/85

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	1.09E-04
CR-51	1.43E-03
MN-54	1.60E-03
FE-55	3.50E-02
CO-57	2.55E-04
CO-58	1.63E-01
FE-59	1.59E-04
CO-60	1.60E-02
KR-85	1.70E-02
KR-85M	7.19E-03
KR-87	7.21E-05
KR-88	3.60E-03
RB-88	2.79E-01
SR-89	3.02E-05
SR-92	2.34E-04
NB-95	2.18E-03
ZR-95	7.74E-04
NB-97	6.99E-04
ZR-97	1.66E-04
TC-99M	1.73E-04
RU-106	5.75E-04
AG-110M	5.08E-03
SN-113	7.21E-04
SB-122	6.72E-04
SB-124	5.62E-03
SB-125	5.16E-02
SB-126	1.20E-04
I-131	9.11E-03
XE-131M	1.72E-01
I-133	9.10E-05
XE-133	2.46E+01
XE-133M	2.76E-01
CS-134	5.55E-02
XE-135	2.15E-01
CS-137	9.84E-02
BA-139	2.98E-04
BA-140	6.55E-04
LA-140	1.56E-03
W-187	6.81E-05

Total Liquid Tritium Released	7.12E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	9.49E+06 liters
Volume of Dilution Water Used During Period	1.77E+12 liters

Installation: Waterford
Unit No.(s): 3

Location: 20 Mi W New Orleans, LA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-382
Thermal Power(MWH): 2.69E+07
Commercial Operation: 09/24/85
Cooling Water Source: Mississippi River

Licensee: Louisiana Power & Light
Licensed Power(MWT): 3.39E+03
Net Electrical Power(MWH): 8.60E+06
Initial Criticality: 03/04/85

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
3	Truck	Barnwell, SC
5	Truck	Oak Ridge, TN
2	Truck	Wampum, PA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	3.05E+00
CO-60	3.95E+00
CS-134	2.58E+01
CS-137	5.14E+01
FE-55	1.09E-01
MN-54	1.38E+00
NI-63	1.43E+01

B

CO-58	9.26E+00	3.71E+01
CO-60	8.63E+00	5.37E+00
CS-134	1.10E+01	8.55E+00
CS-137	1.91E+01	1.35E+01
FE-55	3.32E+01	2.06E+01
MN-54	2.70E+00	4.18E+00
NI-63	1.46E+01	9.08E+00

D

CO-58	9.13E+00
CS-134	1.08E+01
CS-137	1.88E+01
FE-55	3.27E+01
MN-54	2.67E+00
NI-63	1.44E+01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.55E+01 Ci 5.90E+02	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 2.75E+02 m3 3.95E+01 Ci 9.98E-01	before volume reduction burial volume
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Waste Oil	m3 7.43E+00 m3 0.00E+00 Ci 9.40E-03	before incineration after incineration

Installation: WNP-2
Unit No.(s): 2

Location: 12 Mi NW Richland, WA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR

Docket Number: 50-397

Thermal Power(MWH): 1.80E+07

Commercial Operation: 12/13/84

Cooling Water Source: Columbia River

Licensee: Washington Public Pwr. Supply Sys.

Licensed Power(MWT): 3.32E+03

Net Electrical Power(MWH): 5.74E+06

Initial Criticality: 01/19/84

Airborne Effluents

Nuclide Released	Activity (Ci)
------------------	---------------

AR-41	1.77E+01
CR-51	1.09E-03
MN-54	9.60E-05
CO-58	4.30E-05
CO-60	1.35E-03
ZN-65	1.04E-03
KR-85M	4.22E+01
KR-87	4.33E+00
KR-88	2.91E+01
SR-89	1.34E-02
SR-90	7.91E-05
I-131	8.67E-02
I-132	4.51E-02
I-133	1.36E-01
XE-133	4.31E+02
XE-133M	6.53E+00
CS-134	7.60E-05
I-134	1.05E-02
I-135	9.49E-02
XE-135	1.09E+02
XE-135M	9.15E+01
CS-137	1.32E-04
XE-137M	3.82E+01
XE-138	1.20E+02
BA-LA-140	4.54E-02
CE-141	8.12E-05

Total Airborne Tritium Released 3.70E+01 Ci

Installation: WNP-2
Unit No.(s): 2

Location: 12 Mi NW Richland, WA

Effluent and Waste Disposal Annual Report for 1990

Type: BWR
Docket Number: 50-397
Thermal Power(MWH): 1.80E+07
Commercial Operation: 12/13/84
Cooling Water Source: Columbia River

Licensee: Washington Public Pwr. Supply Sys.
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 5.74E+06
Initial Criticality: 01/19/84

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	2.10E-03
MN-54	3.66E-04
FE-55	1.35E-04
CO-58	2.60E-04
FE-59	1.30E-04
CO-60	5.19E-03
ZN-65	3.00E-03
SR-89	1.30E-04
SR-90	5.85E-05
ZR-NB-95	1.10E-04
I-131	1.20E-03
XE-133	6.40E-03
CS-134	1.30E-03
XE-135	1.00E-03
CS-137	1.20E-03
CE-141	7.60E-05

Total Liquid Tritium Released	7.54E-01 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.57E+06 liters
Volume of Dilution Water Used During Period	1.06E+09 liters

Installation: WNP-2
Unit No.(s): 2

Location: 12 Mi NW Richland, WA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: BWR
Dock Number: 50-397
Thermal Power(MWH): 1.80E+07
Commercial Operation: 12/13/84
Cooling Water Source: Columbia River

Licensee: Washington Public Pwr. Supply Sys.
Licensed Power(MWT): 3.32E+03
Net Electrical Power(MWH): 5.74E+06
Initial Criticality: 01/19/84

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
34	Cask	U.S. Ecology, Richland, WA
6	Flatbed trailer	U.S. Ecology, Richland, WA

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

CO-58	2.70E+00	2.20E+00
CO-60	1.74E+01	2.68E+01
CR-51	3.23E+01	1.57E+01
CS-134	5.00E+00	8.20E+00
CS-137	5.20E+00	7.50E+00
FE-55	4.70E+00	7.10E+00
I-131	1.20E+00	
LA-140	6.00E-01	
MN-54	1.80E+00	1.80E+00
NB-95		1.00E+00
ZN-65	2.73E+01	2.74E+01
ZR-95		8.00E-01

B

CO-58		6.00E-01
CO-60		4.34E+01
CR-51		2.70E+00
FE-55		3.05E+01
MN-54		1.40E+00
NB-95		1.70E+00
NI-63		1.90E+00
SB-125		1.70E+00
ZN-65		1.42E+01
ZR-95		7.00E-01

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.51E+02 C1 1.23E+03	burial volume
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.83E+02 C1 5.97E+01	burial volume (compacted)
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Wolf Creek
Unit No.(s): 1

Location: 3.5 Mi NE Burlington, KS

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-482
Thermal Power(MWH): 2.36E+07
Commercial Operation: 09/03/85
Cooling Water Source: Cooling Lake

Licensee: Wolf Creek Nuclear Oper.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.87E+06
Initial Criticality: 05/22/85

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-41	2.72E+00
MN-54	4.50E-06
CO-58	6.52E-07
CO-60	7.53E-05
KR-85	1.89E-01
KR-85M	5.62E-01
KR-88	5.53E-02
I-131	8.48E-05
XE-131M	1.43E+01
XE-133	9.54E+02
XE-133M	1.15E+01
XE-135	1.53E+01

Total Airborne Tritium Released 1.87E+01 Ci

Installation: Wolf Creek
Unit No.(s): 1

Location: 3.5 Mi NE Burlington, KS

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-482
Thermal Power(MWH): 2.36E+07
Commercial Operation: 09/03/85
Cooling Water Source: Cooling Lake

Licensee: Wolf Creek Nuclear Oper.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.87E+06
Initial Criticality: 05/22/85

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	6.19E-06
AR-41	2.09E-04
CR-51	1.64E-02
MN-54	3.32E-03
FE-55	8.84E-02
CO-57	4.49E-04
CO-58	9.22E-02
FE-59	2.34E-03
CO-60	4.95E-02
KR-85	9.60E-02
KR-85M	4.16E-03
KR-87	1.43E-04
KR-88	2.96E-03
RB-88	2.85E-02
SR-92	5.57E-05
NB-95	3.67E-04
ZR-95	7.90E-05
NB-97	6.93E-05
AG-110M	1.81E-04
SN-113	2.32E-05
SN-117M	3.93E-04
SB-124	2.48E-03
SB-125	1.43E-02
SB-126	3.80E-05
I-131	1.79E-04
XE-131M	1.48E-01
XE-133	1.27E+01
XE-133M	1.20E-01
CS-134	7.07E-03
XE-135	5.68E-02
CS-137	8.89E-03
BA-139	1.74E-04
LA-140	2.23E-05
CE-141	7.08E-05

Total Liquid Tritium Released	5.90E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.84E+08 liters
Volume of Dilution Water Used During Period	1.14E+12 liters

Installation: Wolf Creek
Unit No.(s): 1

Location: 3.5 Mi NE Burlington, KS

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-482
Thermal Power(MWH): 2.36E+07
Commercial Operation: 09/03/85
Cooling Water Source: Cooling Lake

Licensee: Wolf Creek Nuclear Oper.
Licensed Power(MWT): 3.41E+03
Net Electrical Power(MWH): 7.87E+06
Initial Criticality: 05/22/85

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
6	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

AC-110M		1.24E+00
AM-241		1.10E-02
C-14	2.51E-01	3.50E-01
CE-144		9.20E-02
CM-243/244		7.00E-03
CO-58		1.99E+01
CO-60	8.91E+00	8.07E+00
CR-51		2.99E+00
CS-134		2.25E-01
CS-137		3.93E-01
FE-55	8.57E+01	4.75E+01
H-3	1.66E+00	2.29E+00
I-131		6.00E-02
MN-54	1.27E+00	1.16E+00
NB-95		1.07E+00
NI-63	2.23E+00	1.28E+01
PU-238		2.70E-02
PU-241		1.99E-01
ZR-95		1.57E+00

B

C-14	7.00E-03	2.30E-02
CO-58	3.60E+00	9.07E-01
CO-60	1.04E+01	1.23E+01
CR-51		3.70E-02
CS-137	1.37E+00	1.43E+00
FE-55	7.60E+01	7.65E+01
H-3		1.37E-01
MN-54	1.52E+00	1.38E+00
NI-63	7.11E+00	7.37E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.16E+01 Ci 2.70E+01	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 7.15E+01 Ci 4.70E+00	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe)	m3 Ci	

Installation: Yankee Rowe
Unit No.(s): 1

Location: 20 Mi NW Greenfield, MA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-029
Thermal Power(MWH): 2.94E+06
Commercial Operation: 07/01/61
Cooling Water Source: Deerfield River

Licensee: Yankee Atomic Electric
Licensed Power(MWT): 6.00E+02
Net Electrical Power(MWH): 8.26E+05
Initial Criticality: 08/19/60

Airborne Effluents

Nuclide Released	Activity (Ci)
AR-37	7.71E-02
AR-41	6.52E-01
CR-51	4.83E-07
MN-54	2.93E-06
CO-58	1.34E-06
FE-59	3.05E-07
CO-60	1.83E-05
KR-85	5.12E+00
KR-85M	1.00E+00
KR-87	1.22E+00
KR-88	2.12E+00
ZR-NB-95	1.90E-07
I-131	1.34E-04
XE-131M	2.89E-01
I-133	1.14E-05
XE-133	3.86E+01
XE-133M	4.20E-01
CS-134	3.75E-07
I-135	7.79E-07
XE-135	2.33E+01
XE-135M	3.88E+01
CS-137	1.94E-06
XE-138	1.28E+00
BA-LA-140	1.06E-06

Total Airborne Tritium Released 3.74E+00 Ci

Installation: Yankee Rowe
Unit No.(s): 1

Location: 20 Mi NW Greenfield, MA

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-029
Thermal Power(MWH): 2.94E+06
Commercial Operation: 07/01/61
Cooling Water Source: Deerfield River

Licensee: Yankee Atomic Electric
Licensed Power(MWT): 6.00E+02
Net Electrical Power(MWH): 8.26E+05
Initial Criticality: 08/19/60

Liquid Effluents

Nuclide Released	Activity (Ci)
CR-51	8.30E-07
MN-54	6.58E-06
FE-55	2.53E-03
CO-58	6.58E-07
FE-59	2.28E-06
CO-60	1.99E-04
KR-85	3.31E-02
SB-124	1.52E-06
I-131	2.50E-05
XE-131M	2.09E-03
TE-132	1.97E-07
I-133	3.26E-06
XE-133	1.42E-01
XE-133M	1.05E-03
CS-134	3.53E-04
XE-135	6.07E-04
CS-137	1.04E-03
CE-144	1.63E-06

Total Liquid Tritium Released	1.92E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.96E+07 liters
Volume of Dilution Water Used During Period	1.72E+11 liters

Installation: Yankee Rowe
Unit No.(s): 1

Location: 20 Mi NW Greenfield, MA

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Type: PWR
Docket Number: 50-029
Thermal Power(MWH): 2.94E+06
Commercial Operation: 07/01/61
Cooling Water Source: Deerfield River

Licensee: Yankee Atomic Electric
Licensed Power(MWT): 6.00E+02
Net Electrical Power(MWH): 8.26E+05
Initial Criticality: 08/19/60

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
11	Truck	Barnwell, SC

Estimate of Major Nuclide Composition (by type of waste) % Jan-June Jul-Dec

A

C-14	1.72E-01	1.51E-01
CO-60	5.40E+00	2.75E+00
CS-134	1.42E+01	1.60E+01
CS-137	6.27E+01	2.11E+01
FE-55	9.22E+00	2.35E+01
H-3		3.41E+01
NI-63	5.48E+00	1.71E+00
PU-241	1.99E-01	
SR-90	1.59E+00	

B

C-14		2.26E-01
CO-60		4.15E+00
CS-134		2.39E+01
CS-137		3.01E+01
FE-55		3.67E+01
H-3		5.00E-03
NB-95		1.92E+00
NI-63		2.54E+00

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 4.93E+01 C1 1.64E+02	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.33E+02 C1 5.73E+00	compacted & non-compacted
C. Irradiated Components, Control Rods, etc.	m3 C1	
D. Other (describe)	m3 C1	

Installation: Zion
Unit No.(s): 1&2

Location: 6 Mi N Waukegan, IL

Effluent and Waste Disposal Annual Report for 1990

Unit Number: 1 Type: PWR
Docket Number: 50-295
Thermal Power(MWH): 1.41E+07
Commercial Operation: 12/31/73
Cooling Water Source: Lake Michigan

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 4.45E+06
Initial Criticality: 06/19/73

Unit Number: 2 Type: PWR
Docket Number: 50-304
Thermal Power(MWH): 8.42E+06
Commercial Operation: 09/17/74
Cooling Water Source: Lake Michigan

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 2.65E+06
Initial Criticality: 12/24/73

Airborne Effluents

Nuclide Released	Activity (Ci)
NA-24	3.01E-05
AR-41	1.71E-01
MN-54	1.14E-07
CO-57	5.50E-09
CO-58	7.47E-06
CO-60	5.62E-05
SE-75	2.90E-08
BR-82	8.44E-06
KR-85	2.19E+00
KR-88	1.46E-01
RB-88	1.24E-04
NB-95	6.90E-09
MO-99	2.40E-07
AG-110M	3.90E-09
SN-113	2.20E-10
I-131	1.31E-03
XE-131M	3.19E-01
I-132	1.55E-05
I-133	1.29E-04
XE-133	1.07E+02
XE-133M	8.90E-03
CS-134	7.22E-06
I-135	3.52E-05
XE-135	7.73E-02
CS-136	1.20E-07
CS-137	1.72E-05
CS-138	3.48E-04
CE-143	7.40E-12
W-187	5.38E-07

Total Airborne Tritium Released 1.80E+01 Ci

Installation: Zion
Unit No.(s): 1

Location: 6 Mi N Waukegan, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-295
Thermal Power(MWH): 1.41E+07
Commercial Operation: 12/31/73
Cooling Water Source: Lake Michigan

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 4.45E+06
Initial Criticality: 06/19/73

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	3.76E-03
CR-51	3.48E-02
MN-54	4.98E-03
FE-55	9.00E-02
CO-57	1.88E-03
CO-58	1.02E+00
FE-59	1.44E-02
CO-60	4.66E-01
NI-65	2.70E-04
RB-88	9.10E-05
NB-95	6.32E-03
ZR-95	5.39E-03
MO-99	3.85E-04
TC-99M	2.90E-05
AG-110M	7.20E-02
SN-113	5.68E-04
SB-124	1.49E-01
SB-125	4.46E-01
SB-126	2.48E-03
I-131	6.94E-02
I-133	5.08E-02
XE-133	1.03E-01
XE-133M	1.00E-04
CS-134	8.78E-02
XE-135	1.25E-03
CS-136	4.60E-05
CS-137	1.19E-01
LA-140	7.10E-04

Total Liquid Tritium Released	2.90E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.43E+08 liters
Volume of Dilution Water Used During Period	1.04E+12 liters

Installation: Zion
Unit No.(s): 2

Location: 6 Mi N Waukegan, IL

Effluent and Waste Disposal Annual Report for 1990

Type: PWR
Docket Number: 50-304
Thermal Power(MWH): 8.42E+06
Commercial Operation: 09/17/74
Cooling Water Source: Lake Michigan

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 2.65E+06
Initial Criticality: 12/24/73

Liquid Effluents

Nuclide Released	Activity (Ci)
NA-24	4.58E-04
CR-51	2.56E-03
MN-54	4.41E-03
FE-55	2.80E-02
CO-57	4.57E-04
CO-58	1.91E-01
FE-59	2.40E-03
CO-60	2.72E-01
RB-88	7.70E-04
SR-90	4.89E-05
NB-95	3.59E-03
ZR-95	1.91E-03
MO-99	1.09E-03
AG-110M	3.33E-02
SN-113	2.20E-04
SB-124	1.93E-02
SB-125	1.31E-01
I-131	2.21E-02
I-132	4.10E-05
I-133	5.52E-03
XE-133	3.02E-01
XE-133M	6.70E-04
CS-134	5.47E-02
XE-135	2.06E-03
CS-136	3.20E-05
CS-137	1.51E-01
LA-140	5.28E-04

Total Liquid Tritium Released	3.91E+02 Ci
Volume of Liquid Waste Released (Prior to Dilution)	1.36E+08 liters
Volume of Dilution Water Used During Period	8.69E+11 liters

Installation: Zion
Unit No.(s): 1&2

Location: 6 Mi N Waukegan, IL

Effluent and Waste Disposal Annual Report for 1990
Solid Effluents

Unit Number: 1 Type: PWR
Docket Number: 50-295
Thermal Power(MWH): 1.41E+07
Commercial Operation: 12/31/73
Cooling Water Source: Lake Michigan

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 4.45E+06
Initial Criticality: 06/19/73

Unit Number: 2 Type: PWR
Docket Number: 50-304
Thermal Power(MWH): 8.42E+06
Commercial Operation: 09/17/74
Cooling Water Source: Lake Michigan

Licensee: Commonwealth Edison
Licensed Power(MWT): 3.25E+03
Net Electrical Power(MWH): 2.65E+06
Initial Criticality: 12/24/73

Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
27		Barnwell, SC
2		Richland, WA

Type of Waste	Unit	Description
A. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.	m3 1.09E+02 Ci 1.81E+03	
B. Dry Compressible Waste, Contaminated Equipment, etc.	m3 1.70E+01 Ci 2.15E+02	
C. Irradiated Components, Control Rods, etc.	m3 Ci	
D. Other (describe) Solidified ethylene glycol	m3 1.34E+01 Ci 2.83E-05	
Solidified oil	m3 5.10E+00 Ci 5.60E-04	

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC. Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG/CR-2907
BNL-NUREG-51581
Vol. 11

2. TITLE AND SUBTITLE

Radioactive Materials Released from Nuclear Power Plants
Annual Report 1990

3. DATE REPORT PUBLISHED

MONTH	YEAR
October	1993

4. FIN OR GRANT NUMBER
FIN B2234

5. AUTHOR(S)

J. Tichler, K. Doty, J. Congemi

6. TYPE OF REPORT

Annual Technical

7. PERIOD COVERED (Inclusive Dates)

1990

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Brookhaven National Laboratory
Upton, NY 11973

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Information Resources Management
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

Releases of radioactive materials in airborne and liquid effluents from commercial light water reactors during 1990 have been compiled and reported. Data on solid waste shipments as well as selected operating information have been included. This report supplements earlier annual reports issued by the former Atomic Energy Commission and the Nuclear Regulatory Commission. The 1990 release data are summarized in tabular form. Data covering specific radionuclides are summarized.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

radioactive materials
airborne effluents
solid waste disposal
nuclear power plants
liquid effluents

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE

END

DATE

FILMED

11/29/93