DOE/MC/26233--2935

DE91 002019

**Advanced Development of
the Nested Fiber Filter
Phase I -- Evaluation of
Cleaning Methods**

Final Report

**R.D. Litt
H.N. Conkle
R.C. Glover
H. Jordan**

August 1990

Work Performed Under Contract No.: DE-AC21-89MC26233

For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
Morgantown, West Virginia

By
Battelle
Columbus, Ohio

MASTER

40

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

**Advanced Development of
the Nested Fiber Filter
Phase I -- Evaluation of
Cleaning Methods**

Final Report

**R.D. Litt
H.N. Conkle
R.C. Glover
H. Jordan**

Work Performed Under Contract No.: DE-AC21-89MC26233

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880**

**By
Battelle
505 King Avenue
Columbus, Ohio 43201-2693**

August 1990

SUMMARY

Battelle has completed Phase I of the DOE program to evaluate cleaning methods for the Nested Fiber Filter (NFF). The results of the investigations into fly ash bonding mechanisms, and mechanical vibration and acoustic vibration techniques led to the conclusion that acoustic cleaning with a pulse combustor is the preferred integrated system for high-temperature, high-pressure applications.

Bonding Mechanisms

An evaluation of the bonding mechanisms was conducted to determine the nature of the bond of the fly ash particles to the metal fibers or to each other. Knowing the nature of the bond led to a better understanding of the other process parameters and a more effective design of the cleaning system.

Results of the evaluation of chemical bonds showed that they are not significant in holding fly ash to fibers or to the dendrite structure. Testing showed that electrostatic bonds are not significant in holding fly ash particles onto the fibers. These tests were not designed to investigate the influence of electrostatic forces on collecting particles. Electrostatic forces (from triboelectric charging) are expected to have a positive contribution to collecting particles.

Van der Waals forces are significant in holding collected fly ash particles onto the fibers or the dendrite structure. The close particle to particle distance between collected particles provide adequate force to withstand shear caused by gas flow past the particle. This evaluation is consistent with prior reported work.

The bonding mechanism evaluation did not indicate the presence of any limitations that should prevent effective cleaning using mechanical or acoustic cleaning techniques.

Vibration Cleaning

Previous work established that mechanical vibration was an effective technique for cleaning/regenerating the NFF. An accelerometer measured the instantaneous acceleration at several thousand times the force of gravity when a pneumatic impact wrench vibrated the NFF test module. Cleaning was essentially complete in less than 2 minutes with cumulative energy input of 4×10^8 joules (3800 Btu). This figure represents an energy input limit required for effective cleaning of a 6-inch diameter filter.

Acoustic Cleaning

Alternative cleaning methods were evaluated because of the difficulty of integrating mechanical vibration in a large-scale, high-temperature filter. Acoustic cleaning was found to be effective and could be easily integrated with the high-temperature, high-pressure applications. Low frequency acoustic drivers in the range of 100 to 400 Hz were found to be effective; higher frequency devices such as whistles (8 kHz to 16 kHz) were not effective.

A pulse combustor generating a sound pressure level of 130 to 150 db was able to clean the NFF in less than 1 minute. The pulse combustor fires natural gas to produce the acoustic energy (also thermal and kinetic) at combustion conditions compatible with 1600 to 2000 F. The energy input from the natural gas is a net gain to the system rather than the loss that characterizes pulse jet or reverse flow air cleaning systems. The pulse combustor is the preferred acoustic driver because of its simplicity, reliability, and ease of integration into a high-temperature, high-pressure application. Multiple cycles of filtering and cleaning showed the NFF performance was maintained at previously reported levels.

A sonic horn, such as the commercially available devices for baghouses or sootblowers, is a viable alternative to the pulse combustor. Tests established that a pneumatically actuated sonic horn that generates up to 160 db at a frequency of 180 Hz is effective in cleaning the NFF in less

than 1 minute. The sonic horn uses high-pressure air and must be cooled; thus, it is less compatible with the high-temperature environment, but represents an alternative.

Battelle recommends proceeding with the pilot plant tests to generate engineering design data at a meaningful scale. An existing fluidized bed combustor would produce representative flue gas and fly ash at 1600 to 1800 F for integrated testing of a 6-ft² NFF module with pulse combustor cleaning.

TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION	3
Background	1
Objective	2
Approach	3
TECHNICAL DISCUSSION	4
Bonding Mechanisms	4
Chemical Bonding	5
Electrostatic Bonding	9
Van Der Waals Bonding	13
Cleaning Techniques	14
Mechanical Impact	15
Acoustic Vibration	21
Pulse Jet Blowback	37
CONCLUSIONS	37
BIBLIOGRAPHY	39
APPENDIX A--SAMPLE CALCULATION OF ACOUSTIC ENERGY	

LIST OF TABLES

	<u>Page</u>
TABLE 1. PULSE COMBUSTOR CLEANING TESTS (METHANE FIRED)	28
TABLE 2. PULSE COMBUSTOR CLEANING TESTS (CARBON MONOXIDE FIRED)	31
TABLE 3. SONIC HORN CLEANING TESTS	36

LIST OF FIGURES

FIGURE 1. NFF PROGRAM SEQUENCE	3
FIGURE 2. PHOTOGRAPH 85329, 210X--NFF FIBER	7
FIGURE 3. PHOTOGRAPH 85337, 1650 F, 160X--NFF FIBER	8
FIGURE 4. PHOTOGRAPH 85338, FE OUTER CR INNER, 100X, 1650 F--SCALE SECTION	10
FIGURE 5. ACCELEROMETER ORIENTATION	16
FIGURE 6. VIBRATION TIME VERSUS RECOVERY	18
FIGURE 7. CUMULATIVE ENERGY VERSUS PERCENT RECOVERY	19
FIGURE 8. NESTED FIBER FILTER IMPACT TEST	20
FIGURE 9. PROTOTYPE SONIC HORN MOUNTED ON TEST BENCH FOR NFF CLEANING USING HIGH SOUND PRESSURE LEVELS	24
FIGURE 10. RESULTS OF ACOUSTIC HORN BENCH TESTS: SOUND PRESSURE LEVEL VERSUS FREQUENCY FOR HORN LOCATED 1 FOOT IN PIPE (TOP) AND BELOW 7-INCH FILTER BASKET (BOTTOM)	25
FIGURE 11. NESTED FIBER-FILTER TEST FACILITY	27
FIGURE 12. PHOTOGRAPH OF PULSE COMBUSTOR	29
FIGURE 13. SCHEMATIC OF PULSE COMBUSTOR	30
FIGURE 14. PULSE COMBUSTOR ACOUSTIC OUTPUT	32
FIGURE 15. CLEANING CYCLES, NFF PULSE COMBUSTOR	34

Advanced Development of the Nested Fiber Filter
Phase I: Evaluation of Cleaning Methods

Topical Report

to

U.S. Department of Energy
Morgantown Energy Technology Center

by

R. D. Litt, H. N. Conkle,
R. C. Glover, and H. Jordan

from

Battelle
Columbus Operations

August 1, 1990

INTRODUCTION

This topical report describes the filter cleaning/regeneration work conducted on the Nested Fiber Filter (NFF) for the U.S. Department of Energy (DOE) under contract number DE-AC21-89MC26233 for the period extending from August 1989 to May 1990. This study follows a previous investigation of the NFF for High-Temperature, High-Pressure Particulate Removal, DOE Contract No. DE-AC21-86MC23251.

Background

Battelle's work on the Nested Fiber Filter began in 1983 with internally funded bench-scale tests to prove the concept feasibility. The NFF concept is based on the following observed effect: randomly oriented metallic fibers of appropriate length-to-diameter ratio tend to form an interlocking nest with high voidage and, therefore, low gas pressure drop at face velocities of 200 feet per minute (fpm). The particulate collection

efficiency and pressure drop compares well with that for typical bag filters with face velocities of 2 to 4 fpm. The resulting benefit of the high throughput of the NFF is a significant reduction in the required equipment volume and the associated capital cost for particulate filters in many applications. Technical feasibility of the NFF has been proven in bench-scale and continuous mini-plant tests. Some promising applications of the NFF include pressurized fluidized bed combustion, integrated coal gasification combined cycle, and coal-fired gas turbines.

In 1986, Battelle entered into a contract with DOE to begin development of the NFF for high-temperature, high-pressure particulate control. The current program represents a focused effort to evaluate cleaning techniques for the NFF. The practical cleaning technique needs to be demonstrated at high temperature and integrated with the high-efficiency filter performance expected of the NFF. Finally, the integrated system needs to be optimized and evaluated under actual combustion gas conditions.

Objective

The overall objective of this program is to advance the development of the Nested Fiber Filter. Battelle's three-phase program (illustrated in Figure 1) is designed to meet this objective. Phase I covers the evaluation of three cleaning techniques (mechanical impact, acoustic vibration, and pulse jet blowback) to identify the most practical and effective method for the NFF concept. Phase II involves tests on the NFF on the pilot plant scale in an integrated system with an existing fluidized bed combustor. Phase III continues with development of a conceptual design and assessment of the economic and engineering aspects of the NFF, and includes a commercialization plan.

This topical report covers Phase I activities.

FIGURE 1. NFF PROGRAM SEQUENCE

Approach

Battelle's approach was based on a logical progression of tasks and subtasks that provide the information necessary to properly evaluate alternative cleaning methods. First, simple experiments were conducted to determine what type of bonding was involved in the observed dendritic particulate collection. Next, laboratory experiments were conducted to quantify the effects associated with successful cleaning. Finally, bench-scale and continuous mini-plant experiments were conducted to characterize the cleaning methods at the high temperatures (1650 F) expected under PFBC operating conditions. This sequential approach built on the data base for filtration performance that was developed earlier and provided the basis for system optimization.

TECHNICAL DISCUSSION

This section describes the activities conducted to date for the advanced development of the Nested Fiber Filter. These activities correspond to the Phase I tasks, which were designed to generate data and pertinent information as the basis for evaluation of the NFF cleaning methods.

Bonding Mechanisms

Battelle's Nested Fiber Filter draws its advantage from filtration within the high voidage fiber filter. The relatively low pressure drop is a direct consequence of the high porosity of the filter bed; the high efficiency is a direct consequence of the formation of fine, interlaced, dendrites of particulate that are deposited on the filter. These dendrites constitute the filtration medium. Regenerating the fiber filter medium requires removal of the dendritic deposits from a 4.75-inch diameter laboratory test filter. The metal fibers themselves are fabricated from Type 304 stainless steel (0.005-inch diameter by 0.5-inch long) by rapid solidification.

Before attempting to address the requirement of cleaning or regenerating the Nested Fiber Filter, it was important to understand the nature of the bond of the fly ash particles to each other and to the metal fibers of the NFF. Once the nature of the bond was known, a better estimate of other process parameters could be made, and a more effective cleaning technique devised. The particle-to-particle bonding mechanism was of special interest because of the dendritic structure of the collected particles.

Initial considerations indicated that chemical, electrostatic, or van der Waals forces might be significant in fly ash buildup. Two laboratory investigations were conducted using loaded ("dirty") filters to determine whether the bonding mechanism was chemical in nature or electrostatic in nature. The testing conducted was not extensive, and neither test showed strong results. This was interpreted as an indication that van der Waals forces were significant in holding particulate matter onto the fibers.

Chemical Bonding

These tests were conducted using the 4.75-inch diameter test apparatus that was used in the previous study conducted for the U.S. DOE Morgantown Energy Technology Center. The particulate used in the tests was a fly ash/limestone material obtained from the Grimethorpe PFBC in the United Kingdom; it had the following characteristics:

Maximum size	18 μm
Mean size	4.6 μm
Standard deviation	0.3 μm
% below 6 μm size	61.8%
Density	2.65 g/cm ³

Filter elements were exposed to a hot gas stream at a face velocity of 100 ft/min for 2 hours at the predetermined gas temperatures of 1400 and 1650 F. The particulate loading of the gas was 5,000 to 10,000 ppm. After exposure, the filter elements were removed from the test apparatus and the contents fixed by infiltrating them with epoxy resin to a depth of about 1.5 in. from the filter entry face. Samples were cut from the center region of the filter cross section and polished for micro examination. Next they were examined briefly by optical microscopy and then carbon coated for examination under the Scanning Electron Microscope (SEM). SEM procedures consisted of imaging, energy dispersive X-ray analysis, electron probe analysis, and X-ray mapping. Of these, X-ray mapping was most useful. Samples of the dendrites and particles were also collected for examination by standard techniques of metallography and scanning electron microscopy.

Test Results. X-ray mapping of the 1400 F sample showed a clear boundary between the iron in the fiber and its surroundings. Chromium, however, was present in an irregular pattern in regions 2-3 μm from the iron boundary, indicating scaling. The fly ash particles in the surrounding mounting medium showed the expected internal elemental associations, but there was no evidence of combination with the fiber. Calcium was associated with sulfur, probably as sulfate or sulfite. Silicon was associated with aluminum

and potassium, although potassium was fairly well dispersed. Discrete iron rich particles, possibly residuals from pyrite in the coal, were also found. Some ash particles appeared spherical, suggesting that they had at some time been molten (presumably in the FBC, since melting is unlikely at 1400 F).

The 1650 F sample showed essentially similar features, except that the chromium rich scale was thicker and generally separated from the fiber as shown in Figure 2. It appears to have been lifted by intrusion of the epoxy mounting medium but must have been detached prior to the mounting operation. The chromium rich scale is removed up to 0.25 mm from the fiber, but is nearly intact and reproduces the fiber outline. The space between the fiber and scale is virtually free of particulate material or metal oxides, suggesting that the scale separated after the filter test.

The fly ash particles in both samples were fairly densely packed in zones where several fibers were close together. They did not appear to be connected by sintering. Figure 3 shows areas of dense particle packing which can be distinguished from less concentrated areas (i.e. dendrites).

To explore the possibility that the metal scale had interacted chemically with the particulate, several sections of scale were examined at higher magnification (10,000 X). A series of microprobe analyses from the inner side to the outer side of the scale showed a progressive change in composition as follows:

Inner Edge of Scale:	Mostly Cr, with Mn and Fe
Center:	Cr, with more Mn and Fe
Outer Edge:	High Cr, Mn, Fe, Si, some Al
Fly Ash Particle:	High Si, Al.

These analyses provide clear evidence of interaction by solid state interdiffusion between the scale and the alumino-silicate fly ash particle which was in contact with it. We have no documentation of Cr-Si-Fe intermetallic compounds with low melting points, so it is very unlikely that this diffusion process would lead to sintering by surface softening. Similar

Photograph 85329

210X

FIGURE 2. NFF FIBER (MAGNIFIED 210 TIMES) WITH THICK CHROMIUM SCALE SEPARATED FROM THE FIBER

Photograph 85337
1650 F

160X

FIGURE 3. NFF FIBER (MAGNIFIED 160 TIMES) WITH AREAS OF DENSE PACKING DISTINGUISHABLE FROM LESS CONCENTRATED AREAS (DENDRITES)

gradations in composition were found in other scales. Characteristically, scales were richer in chromium on the inner side and had high contents of chromium, iron, and manganese on the outside, with significant penetration of silicon and aluminum. Figure 4 shows a cross section of the fiber and scale, which was typical of this analysis. No evidence was found of fusion or sintering between scale and the particulate material.

Electrostatic Bonding

In this test, a particulate laden NFF module was subjected to gas flow containing high concentrations of unipolarly charged ions. It was expected that the ions would adsorb to the primary fly ash particles of which the dendrites are formed and neutralize those of opposite charge, gradually inducing a net unipolar charge. Any cohesive bonds resulting primarily from electrostatic attractive forces would therefore be relaxed; if enough ions could be adsorbed, the fly ash particles would experience a repulsive force. If such primarily electrostatic bonds exist, neutralization and the flowing gas should lead to resuspension of primary particles or clusters of primary particles. The experiments were designed to check specifically for such resuspension.

To conduct this test, a vertical plexiglas tube of 6.25 in. inside diameter and 8 ft tall was used. The loaded filter was installed 1.5 ft above the bottom, conical inflow section. At the top, a platform served to hold the aerosol measuring and detection instruments and an electrometer. At the bottom, just ahead of the conically divergent entrance region, were a point-to-plane corona discharge couple and the required 10 kV power supply. With a point-to-plane separation of 3.2 mm, a negative corona was generated at 5 kV. A positive corona (with reversal of polarities) was achieved at a lesser potential difference, but this mode was unstable and required frequent readjustment.

Compressed air was passed through an absolute filter and a rotameter before flowing through the column. The flow rate was set at 12 SCFM providing turbulent flow (Reynolds number = 3028) for good mixing of both the

Photograph 85338   100X
Fe Outer   Cr Inner   1650 F

FIGURE 4. CROSS SECTION OF TYPICAL FIBER SCALE (MAGNIFIED 100 TIMES) WITH HIGHER CHROMIUM CONTENT ON THE INSIDE, IRON ON THE OUTSIDE

ions and any resuspended particles; the linear velocity is high enough (56 ft/min) to elutriate particles with diameters less than 30 μm . By orienting the column vertically, wall losses due to rapid settling of the larger particles were eliminated.

Aerosol was sampled from the centerline of the column, near the exit. This sampling point was more than 10 column diameters from the filter and thus representative for the entire cross section of the column. Two instruments were used: a TSI Condensation Nucleus Counter (Model 3020) and a TSI Aerodynamic Particle Sizer (Model 33). The former instrument measured particle concentrations for particles between 0.01 μm and 10 μm in diameter. The latter instrument measured particle concentrations between 0.5 μm and 30 μm and resolved the particle size distribution in this range. Placing the instruments as close as possible to the sampling location minimized sampling losses. However, it is generally well known that, even in this mode, the Aerodynamic Particle Sizer is inefficient for particles in excess of 15 μm (and less than about 1 μm).

Test Result. Tests were conducted to determine whether there was electrostatic bonding between the particulate and the fibers. Two filters were investigated, the one loaded with particulate at 1400 F; the other loaded at 1650 F. At this higher temperature, some plastic deformation of the primary particles was observed, but fusion did not occur. Each filter had a fiber depth of 1 inch and a diameter of 4.75 inches, and was heavily loaded. The interstices at the exit of the filter were visibly caked with deposits. In the tests, air, without corona charging, was blown through the plexiglas column until resuspension had settled to an apparently steady state minimum. The corona was then turned on and the exit aerosol was monitored. Any change in exit aerosol concentration was measured.

Both filters were heavily loaded with fine orange PFBC particulate that could be easily removed by incidental mechanical vibration that occurs when the filters are installed. On first insertion in the flow tube, it took the 1650 F filter about 2 hours to reach a minimum resuspension concentration about 1 particle/cm³ for particles with diameters in excess of 1 μm and about

2 particles/cm³ for particles with diameters smaller than 1 μ m. The 1400 F filter took more than 8 hours to reach minimum concentrations of 5 particles/cm³ for supermicron and 4.5/cm³ for submicron particles. Furthermore, while resuspension occurred at a steady rate for the 1650 F filter, it occurred in distinct bursts for the 1400 F filter. A concentration of 5 particles/cm³ represents an average over a long period of time; during the bursts, concentrations reaching more than 40 particles/cm³ could be observed. This finding suggests that primary particles or clusters of a few primary particles break off and resuspend in uncharged flow.

The corona at the column entrance was turned off until the concentration of resuspended particles had reached an apparent steady state level. In fact, the concentration reached the very low levels noted above. With the corona discharge on, the charge state of the filter bed (stainless steel fibers) was monitored, as was the concentration of fly ash particles exiting at the top of the column. The charge state of the filter bed could be reversed between $\pm 2 \times 10^{-6}$ Coulombs. No measurable change in particle concentration was observed for particles with diameters in excess of 1 μ m, even with repeated measurements for both negative and positive coronas. However, the repeated response of the Condensation Nucleus Counter did indicate the apparent release of submicron particles. This release occurred as a sharply defined pulse followed by subsidence to pre-corona levels, despite the continual operation of the corona.

In this test, some of the particles were resuspended by hydrodynamic flow, but nearly all were apparently bonded enough to be unaffected. This indicates that cohesion and adhesion are present in the filter, because otherwise all the particles would have been resuspended. The mass of the particles is too small for gravity to keep them in the filter. Results also indicated better adhesion/cohesion of the particles in the 1650 F filter than in the 1400 F filter. The evidence suggests that cohesion by van der Waals forces is the dominant bonding mechanism, although the results are not conclusive.

Van Der Waals Bonding

The tests described above were designed to be critical experiments to verify the presence of one bond mechanism. Currently there is no critical experiment to distinguish the action of van der Waals bonds. Only the absence of evidence for chemical and electrostatic bonding would imply dominance of van der Waals bonds, as turned out to be the case.

Clift⁽¹⁾ compared electrostatic forces to van der Waals forces for small particles in a gas-particle system. He reduced the force equation for a charged particle to a conducting surface to:

$$F_e = Q^2 / 16\pi\epsilon_0\delta^2 \quad (1)$$

where F_e = attractive force from electrostatic effects
 Q = charge on particle
 ϵ_0 = permittivity of free space and
 δ = distance between center of particle and surface.

For a 1 μm particle carrying a charge of -2.8×10^{-17} coulombs*, the electrostatic force is 1.3×10^{-14} newtons.⁽¹⁾ If the charge on the particle is generated by triboelectrification, then Q is dependent on the surface properties of the solid.

Van der Waals forces for the similar situation are estimated by:

$$F_v = Ad / 12\beta^2 \quad (2)$$

where F_v = adhesive force arising from van der Waals effects
 A = Hamaker constant (generally 10^{-20} joules)
 d = particle diameter and
 β = least distance between particles.

---

*This charge corresponds to approximately 175 excess electrons, a value that has been measured on resuspended fly ash.

Comparing the van der Waals forces to electrostatic forces results in the following equation, according to Clift:

$$\frac{F_v}{F_e} = 2 \times 10^9 \left[1 + \frac{d}{2\beta^2} \right]^2 d^{-1.05} \quad (3)$$

For a 1 μm particle then the ratio becomes

$$F_v = 2.4 \times 10^{11} F_e$$

or $F_v = 3.1 \times 10^{-3}$ newtons

Thus van der Waals forces dominate. They are essentially very short range forces and may be regarded as adhesive rather than attractive. These are the forces that must be broken to remove the collected particles from the NFF. The results of the bonding mechanism study did not identify any limitations that should prevent effective cleaning using mechanical or acoustic techniques.

Cleaning Techniques

The evaluation of bonding mechanisms confirmed that chemical and electrostatic bonds are not significant in cleaning the NFF.

The efforts to characterize the main bond mechanism provided a logical connection to the examination of techniques for cleaning or regenerating the Nested Fiber Filter. The problem of cleaning the filter has two distinct aspects:

1. Breaking the bonds of the particulate materials to each other and the metal fibers of the filter
2. Removing the particulate materials from the nested fibers.

The techniques that were examined were mechanical impact, acoustic vibration, and pulse blowback. By separating the two aspects of the cleaning problem, it was easier to quantify the effects of the different techniques and identify the most effective. The results would also prove valuable in defining the scale-up requirements needed for a full-scale system.

Mechanical Impact

Previous results indicated that repetitive impact was an effective method for cleaning the NFF, both in terms of breaking the particulate bonds and in removing the materials from the nested fibers. An impact vibrator could impart sufficient energy from high local acceleration to first break the bonds and then shake the particulate out of the filter. Bench-scale tests were conducted to quantify the effect of particle acceleration and imparted energy using mechanical vibration. The NFF modules were impacted in the axial and radial directions for tests using a pneumatic impact wrench. The "g" forces were measured with an accelerometer.

Test Results. Bench-scale, mechanical impact tests were conducted for the cold-vertical, cold-horizontal, hot-vertical, and hot-horizontal configurations. Results of these tests indicate that greater than 80 percent of the particulate is removed from the NFF with less than 2 minutes of vibration and less than 6×10^8 joules (5700 Btu) of energy input. The high-temperature (1500 F) tests required more energy to remove the particulate than the corresponding low temperature tests. This is consistent with previous observations that the particulate bonds are stronger at higher temperature. Horizontal impact (acceleration) significantly reduced the cleaning time to approximately 30 seconds compared to the 2 minutes required for comparable particulate removal with vertical impact.

The mechanical impact tests were conducted using a pneumatic impact wrench to establish a baseline for effective cleaning measurements. The tests were conducted with specially designed baskets (shown in Figure 5). The impact wrench struck the basket at a top face (vertical tests) and at a radial

FIGURE 5. BASKET DESIGN PROVIDED FOR IMPACT POINT AND ACCELEROMETER MOUNTING FOR BOTH VERTICAL AND HORIZONTAL TESTS

position (horizontal tests) while an accelerometer measured the instantaneous acceleration at an opposite position.

Cold-Vertical Impact. Air pressure to the pneumatic impact tool was regulated to 4 pressures producing varied levels of force and energy to the basket. Each air pressure provided a distinct impact frequency and rate at which particulate was removed (see Figure 6). The cleaning tests were conducted for 240 seconds. Data were collected after vibration durations of 5 seconds for the first 2 minutes, 15 seconds for the next minute, and 30 seconds for the final minute. The rate of particulate removal was then determined and integrated to calculate the percent particulate removed as a function of time. These data also show that air pressures greater than 22.5 psig provide adequate cleaning; improvements at even higher pressures occur in small increments. These data are representative of the other test sequences.

A representative time trace of the accelerometer measurements is shown in Figure 7. The acceleration starts very high (2500 g's) and is dampened within 4 milliseconds. The integrated average acceleration over the initial 1.5 milliseconds was used to calculate the impact force.

The curve shown in Figure 8 depicts the conversion of the acceleration data into energy. These data establish that the cumulative energy is essentially independent of air pressure and that 80 percent of the particulate are removed with a cumulative energy less than 4×10^6 Joules (3600 Btu) for all test conditions.

Cold-Horizontal Impact. Horizontal impact produced more rapid cleaning than the vertical impact, with essentially 90 percent removal in 20 seconds. At the highest air pressure level (62.5 psig), some fibers vibrated out of the NFF with the particulate. The accelerometer leads broke due to the extreme impact force. The collected data were generally consistent with the energy profile presented in Figure 8 although this represented the upper boundary condition.

FIGURE 6. PLOT OF VIBRATION TIME VERSUS RECOVERY INDICATES GOOD RESULTS AT AIR PRESSURES OF 22.5 psig AND GREATER

NESTED FIBER FILTER IMPACT TEST

Basket Acceleration Measurement

FIGURE 7. TIME TRACE OF ACCELEROMETER MEASUREMENTS SHOWS DAMPING WITHIN 4 MILLISECONDS IN THE COLD VERTICAL IMPACT TEST

FIGURE 8. PLOT OF CUMULATIVE ENERGY VERSUS PARTICULATE RECOVERY
INDICATES REMOVAL OF 80 PERCENT OF PARTICULATE WITH LESS THAN
4 MJ CUMULATIVE ENERGY IN THE COLD VERTICAL IMPACT TEST

Hot-Vertical Impact. Hot refers to the temperature (1500 F) at which the particulate was collected on the filter. One preliminary conclusion is that the particulate collected hot is more tightly bonded than the material collected cold. This is consistent with prior results and general softening of particulate constituents observed at elevated temperature. One to two minutes of vibration are required to remove 70 to 80 percent of the particulate. The cumulative energy required to remove 80 percent of the particulate is approximately 4×10^6 J (3800 Btu) for the 0.2 ft² basket, which is generally consistent with the cold tests.

Hot-Horizontal Impact. These final mechanical vibration tests were completed with horizontal impact on particulate collected at approximately 1600 F. The results are consistent with the earlier results. Horizontal vibration is more effective than vertical vibration in removing particulate from the NFF. The fibers can be cleaned in less than 1 minute at a cumulative energy input of less than 2×10^6 J (1895 Btu). Because of the unmeasured losses, this value represents a minimum design value for scale up.

Acoustic Vibration

Bench-Scale Tests. A bench-scale test apparatus was assembled to test the various acoustic methods before progressing to in-situ cleaning experiments. The acoustic source was mounted on the bench directed down into a section of pipe. The NFF test module was attached to the bottom of the pipe. The acoustic pressure wave propagated down the pipe as a plane wave and through the filter. A pan was placed under the NFF module to collect the particulate and determine percent recovery. A pressure transducer was mounted in the pipe wall approximately 1 foot below the acoustic source, and a microphone was placed under the NFF test module. The two transducers provided information on the sound pressure level produced by the acoustic drivers and the sound energy attenuation by the filter.

The acceleration levels imparted to the fibers using the mechanical impact method are relatively high. With acoustic vibration methods, however, a much lower energy level is imparted. This part of the investigation was

designed to determine whether the transmitted accelerations or peak forces would be sufficient to break the bonds and dissociate the particulate material. A sonic cleaning test stand was assembled for multiple acoustic drivers and NFF test modules (baskets) as illustrated in Figure 5. Devices that were tested included:

- JBL mid range driver (350 Hz to 15 kHz)
- Hartman whistle, furnished by DOE (12 kHz)
- Hartman whistle, furnished by Battelle (16 kHz and 4 kHz)
- Pulse combustor (140 to 150 Hz)
- Sonic horn (250 Hz).

Electro Acoustic Driver. The initial acoustic tests were conducted with a mid-range electro-acoustic driver (JBL Model 24B5J) capable of propagating acoustic pressure waves over a frequency range from 350 Hz to 15 kHz. This driver is typically used in high-output public address sound systems. The low frequencies were effective in removing the particulate from the NFF; the higher frequencies tested were not.

The JBL electro-acoustic driver operating at full power and low frequency produced approximately 150 db at 400 Hz (measured 1 foot from the driver) for less than 1 second before the diaphragm failed. This short burst removed approximately 30 percent of the particulate. A replacement diaphragm was progressively tested at increasing power levels until it also failed at full power with less than 30 percent particulate removal. These tests indicated that acoustic cleaning showed promise, but other drivers may be better suited.

Whistle. The Hartman whistle operating at 12 kHz removed only a few percent of particulate from the NFF basket and was considered ineffective compared to the lower frequency devices. The 4 kHz whistle was also ineffective in removing particulate. This conclusion drove the decision to dispense with tests on the higher frequency whistle furnished by Battelle.

Pulse Combustor. Preliminary tests with a pulse combustor showed outstanding results on the bench-scale tests. The pulse combustor provides an acoustic Sound Pressure Level (SPL = 140 db at 130 Hz) with reverse gas flow. For comparison, the SPL of a military jet at takeoff, fifty feet away, is approximately 130 db. This SPL could cause almost immediate hearing damage. The NFF filter housing contains the sound and dampens it to levels that are within acceptable limits. Less than 1 minute operation of the pulse combustor removed essentially all the particulate in the bench-scale tests.

Sonic Horn. An air-powered sonic horn was tested to evaluate this commercial device as the acoustic driver for cleaning the NFF. A high-temperature prototype model was purchased from BHA Consultants for testing with the NFF. This horn is typical of devices used in baghouse cleaning or sootblowing applications.

This air-powered sonic horn is capable of producing extremely high sound pressure levels (160 db in a plane wave tube). The type of horn chosen is typically used for bag houses to separate fly ash from the bag material. It featured a horn exit diameter of 4 inches, which is approximately the same diameter as our filter baskets, providing the best possible match with our test facility dimensions. Figure 9 shows the horn mounted on the same test bench facility that was used for the previous acoustic experiments using conventional acoustic drivers and air whistles.

After some fine adjustments were made, the maximum acoustic output of the horn was measured to be 160 db at a frequency of 181 Hz inside the test pipe at 1 foot from the horn outlet. The sound pressure level dropped approximately 30 db to 130 db on the outlet of the 7-inch filter basket (see Figure 10). The attenuation of 30 db means that 99.9 percent of the acoustic energy was dissipated in the NFF.

FIGURE 9. PROTOTYPE SONIC HORN MOUNTED ON TEST BENCH FOR NFF
CLEANING USING HIGH SOUND PRESSURE LEVELS

FIGURE 10. RESULTS OF ACOUSTIC HORN BENCH TESTS: SOUND PRESSURE LEVEL VERSUS FREQUENCY FOR HORN LOCATED 1 FOOT IN PIPE (TOP) AND BELOW 7-INCH FILTER BASKET (BOTTOM)

The cleaning results on the bench test showed that the sound pressure propagated through the filter and cleaned the filter moderately well. All of the remaining particulate in the filter was in the bottom 0.5 inch of the filter. In this region the particulate was caked together, which made it difficult to exit through the steel mesh on the bottom of the filter. This problem might be solved by light vibration of the filter or intermittent turbulent air flow directed up at the bottom of the filter.

In Situ Tests. The trends in the data gathered in the bench-scale tests indicated that satisfactory results could be expected from further tests on a pulse combustor and sonic horn. These tests were conducted "in situ" (in the existing 6-inch diameter NFF Test Facility, see Figure 11) to investigate cleaning techniques at operating temperatures.

Pulse Combustor. An existing natural-gas-fired pulse combustor was effective in removing particulate from the NFF, see Table 1. The pulse combustor used in these tests (see Figure 12) was designed by Battelle 10 years ago as an aerovalved-pulse combustor. The air inlet was modified, as illustrated in Figure 13, to introduce compressed air for the high-temperature, high-pressure application. Natural gas is the primary fuel for the pulse combustor, with a spark plug for initial operation. When the pulse combustor is hot, after 1 to 2 minutes of operation, the spark plug can be disconnected for sustained operation. Carbon monoxide (CO) was used as an alternate fuel in most of the tests, see Table 2. The CO-fired pulse combustor had the advantage of not creating water vapor which interfered with particulate collection calculations (i.e., there was no water to collect on the ultimate filter).

The initial operation of the pulse combustor was unstable with a dominant first harmonic at 125 to 150 Hertz and 135 to 140 decibels acoustic pressure. The pulse combustor acoustic output is represented in Figure 14 for this initial operation. After the pulse combustor heated up (approximately 1 minute), it stabilized with a dominant second harmonic at 286 Hz and 140 db. Cleaning was rapid and essentially complete within the 1 minute initial duration.

FIGURE 11. SCHEMATIC OF THE NESTED FIBER FILTER TEST FACILITY
(P and T indicate pressure and temperature instruments, respectively)

TABLE 1. PULSE COMBUSTOR CLEANING TESTS (METHANE FIRED)

Run No.	Face Velocity ft/min	Bed Depth in.	Filter Inlet Temp. F	Filter Outlet Temp. F	Inlet Loading ppm	Filter ΔP in. WC			No. Pulse Cycles	Average Duration min.
						Initial	Before Cleaning	Final After Cleaning		
239	247	7	1288	1581	11,214	1.8	6.0	0.6	6	0.3
240	251	7	1540	1602	36,041	1.5	6.2	2.2	12	0.3

FIGURE 12. AN EXISTING PULSE COMBUSTOR DESIGNED BY BATTELLE WAS MODIFIED FOR NFF TESTS

FIGURE 13. PULSE COMBUSTOR MODIFICATIONS ALLOWED FOR COMPRESSED AIR TO BE INTRODUCED IN HIGH-PRESSURE, HIGH-TEMPERATURE APPLICATIONS

TABLE 2. PULSE COMBUSTOR CLEANING TESTS (CARBON MONOXIDE FIRED)

Run No.	Face Velocity ft/min	Bed Depth in.	Filter Inlet Temp. F	Filter Outlet Temp. F	Inlet Loading ppm	Filter ΔP in. WC		Collection Efficiency, %(a)	No. Pulse Cycles	Average Duration min.
						Initial	Before Final Cleaning After Cleaning			
228	279	7	1569	1486	13,280	2.5	6.5	99.2	1	0.25
229	251	7	1603	1568	20,948	2.7	6.6	99.2	19	0.5
230	246	7	1604	1532	10,310	1.0	10.0	99.2	3	0.3
235(c)	255	7	1595	1600	19,904	1.0	8.0	-	7+	0.25
236	258	7	1558	1625	21,607	1.3	6.0	86.5	12	0.5
237	258	7 ^(b)	1112	1621	15,825	1.4	7.0	95.4	11	0.5
238	252	7 ^(b)	1063	1579	14,368	0.6	6.0	83.0	8	0.5
242	110	7	1494	1619	43,488	0.2	10.0	87.6	9	0.5

- (a) Collection efficiencies are low due to accelerated loading test with high face velocities, high particulate loadings, and shallow bed depths.
- (b) Distance from pulse combustor to top of NFF reduced from 40 inches to 20 inches.
- (c) Runs 231 through 234 conducted to prepare samples of bench-scale vibration tests.

FIGURE 14. PLOT OF ACOUSTIC OUTPUT DURING INITIAL OPERATION OF PULSE COMBUSTOR, WITH DOMINANT FIRST HARMONIC AND ACOUSTIC PRESSURE INDICATED

The measured sound pressure level (in decibels) can be converted to an energy value; a sample calculation is included in Appendix A. The 150 db acoustic pressure obtained from the pulse combustor is equivalent to 62 Btu/hr as the energy that is effective in cleaning the NFF.

An initial subset of tests investigated the NFF performance through multiple cycles of filtration with off-line cleaning. Figure 15 presents representative data for these tests. The NFF pressure differential increased from 1 inch H₂O at the clean condition to 10 inches H₂O before regeneration; this continued for several additional cycles over a range of filter operating temperatures from 400 to 1600 F. The particulate loading into the NFF exceeded 10,000 ppm to accelerate the tests with a 7-inch-deep bed of 0.5-inch fibers. The time duration to load the NFF at a lower particulate loading would be proportionately increased.

Operating the pulse combustor on natural gas complicates quantifying the NFF test performance because water condensation from the flue gas plugs the downstream unheated ultimate filter. The NFF test facility uses this ultimate filter to establish collection efficiency on a mass basis. Cleaning durations of approximately 1 minute are too short to get meaningful data from isokinetic sampling (EPA Method 5), which requires 1 to 3 hours to collect sufficient mass from the clean exit gas stream.

In one subset of tests, carbon monoxide served as the pulse combustor fuel in an effort to eliminate water condensation problems at the ultimate filter. The energy value of CO is significantly less than CH₄ (321 Btu/SCF versus 1010 Btu/SCF) so that the energy output from the pulse combustor was expected to be reduced by this ratio. NFF performance was expected to be better when firing natural gas, but CO was used to quantify performance in the existing test facility. Tests were conducted with on-line cleaning (i.e., dirty gas flow was continuous) by the pulse combustor to evaluate this most ambitious arrangement. Data from these tests are presented in Table 1.

FIGURE 15. PLOT OF PRESSURE DROP OVER TIME DURING MULTIPLE CLEANING CYCLES USING THE PULSE COMBUSTOR

The results are encouraging considering the extremely difficult test conditions, i.e., high face velocity, high particulate loading, and low fiber bed depth. Less difficult conditions and/or the use of natural gas as fuel to the pulse combustor are expected to meet the NFF target performance specifications. Off-line cleaning (dirty gas flow is stopped) is tentatively recommended based on the testing to date; however, provisions should be included for both on-line and off-line cleaning in the next phase of testing.

The distance from the pulse combustor outlet tube to the top of the NFF was reduced from 40 inches to 20 inches for Tests No. 237 and 238 (see Table 1 for data). At the close range, the NFF fibers were blown out of their "nest" creating a channel for particulate laden gas to bypass the fibers. This phenomenon could contribute to the decreased collection efficiency. The effect of physical arrangement will be investigated further during the pilot-scale tests.

Based on results of these investigations, several additional patent applications, including acoustic cleaning, are being prepared to expand the technical scope of the Nested Fiber Filter technology.

Sonic Horn. Two sonic horn cleaning cycles of an in-situ test were conducted for direct comparison with the pulse combustor method, see Table 3. The results were encouraging. The sound pressure level measured in the pressure vessel near the outlet of the horn was approximately 159 db. Fine adjustments were required to provide the air pressure to the horn diaphragm to keep the horn operating at maximum output. About 3 minutes of cleaning reduced the filter pressure drop from 5.1 to 0.2 inches H_2O after the second cycle. These test results are included in Table 3. The sonic horn is an effective acoustic driver, providing an alternative device to the pulse combustor.

Comparison of Acoustic Horn and Pulse Combustor. The maximum sound pressure level produced by the acoustic horn exceeds that from the pulse combustor by about 24 db. The difference in the fundamental frequency, 180 Hz for the horn and 151 Hz for the pulse combustor, is less important. Also, the

TABLE 3. SONIC HORN CLEANING TESTS

Run No.	Face Velocity ft/min	Bed Depth in.	Filter Inlet Temp. F	Filter Outlet Temp. F	Inlet Loading ppm	Filter ΔP in. WC		Collection Efficiency, %(a)	No. Pulse Cycles	Average Duration min.
						Initial	Final Before After Cleaning Cleaning			
241	252	7	1509	1517	17,703	1.0	20.0 -	93.3	1	3.6
243	111	7	1368	1568	48,956	0.3	5.1 0.2	94.7	2	3.0

(a) Collection efficiencies are low due to accelerated loading test with high face velocities, high particulate loadings, and shallow bed depths.

frequency will shift with changes in operating conditions. The pulse combustor may be optimized for increased acoustic output, the opposite of normal design goals of pulse combustors in other applications. The pulse combustor must be able to produce a similar acoustic output in much higher ambient pressures. This is being studied by other researchers and will be incorporated into our future work. The ambient pressure is less of a problem with the horn, since it only requires providing a small pressure differential on each side of the diaphragm. However, operating temperature could be a limitation for the horn diaphragm material.

Pulse Jet Blowback

The application of air or steam as either a jet or pulsed flow, as in a soot-blower, appeared to offer benefits of simplicity and reliability. This part of the investigation was designed to determine whether the lower separation forces of the viscous drag associated with the jet pulse blowback technique were sufficient to dissociate the particulate. Also of interest was the effect of the temperature difference between hot filter and the air or steam.

Based on the results of the tests described above, a separate pulse jet blowback technique did not appear to offer any distinct advantages. Consequently, evaluation of the pulse combustor was emphasized as the most significant cleaning technique.

CONCLUSIONS

Battelle concluded that van der Waals forces are the dominant adhesive force holding the fly ash particles to the fibers and dendrite structure. The close particle-to-particle distance between collected particles provides adequate force to withstand shear caused by gas flow past the particle. This force cannot be directly measured but is calculated to be 3.1×10^{-3} Newtons for a $1 \mu\text{m}$ particle. Chemical and electrostatic bonds are

not significant in holding the fly ash particles to the fibers. The bonding mechanisms do not limit mechanical or acoustic cleaning techniques.

Previous work established that mechanical vibration was an effective technique for cleaning/regenerating the NFF. An accelerometer was used to measure the instantaneous acceleration (up to several thousand times the force of gravity) when a pneumatic impact wrench was used to vibrate the NFF test module. The cleaning was essentially complete in less than 2 minutes with cumulative energy input of approximately 4×10^6 Joules (3600 Btu).

Alternative cleaning methods were evaluated because of the difficulty of integrating mechanical vibration in a large-scale, high-temperature filter. Acoustic cleaning was found to be effective and could be easily integrated with the high-temperature, high-pressure applications. Low frequency acoustic drivers in the range of 100 to 400 Hz were found to be effective; higher frequency devices such as whistles (8 kHz to 16 kHz) were not effective.

A pulse combustor generating a sound pressure level of 130 to 150 db was able to clean the NFF in less than 1 minute. The pulse combustor fires natural gas to produce the acoustic energy (also thermal and kinetic) at combustion conditions compatible with 1600 to 2000 F. The energy input from the natural gas is a net gain to the system rather than the loss that characterizes pulse jet or reverse flow air cleaning systems. The pulse combustor is the preferred acoustic driver because of its simplicity, reliability, and ease of integration into a high-temperature, high-pressure application. Multiple cycles of filtering and cleaning showed the NFF performance, as measured by the initial filter pressure drop, was maintained at previously reported levels.

A sonic horn, such as the commercially available devices for baghouses or sootblowers, is a viable alternative to the pulse combustor. Tests established that a pneumatically actuated sonic horn that generates up to 160 db at a frequency of 180 Hz is effective in cleaning the NFF in less than 1 minute. The sonic horn uses high-pressure air and must be cooled;

thus, it is less compatible with the high-temperature environment, but represents a viable alternative.

RECOMMENDATIONS

Battelle recommends proceeding with the pilot plant testing (Phase II of the contract). A pulse combustor would be integrated with a 6-ft² NFF test module to provide integrated testing at a meaningful scale to generate engineering design data. An existing atmospheric fluidized bed combustor would provide representative flue gas and fly ash at 1600 to 1800 F for testing the NFF. Initial tests would evaluate the pulse combustor for off-line cleaning (dirty gas flow would be stopped). Additional tests with on-line cleaning and with a sonic horn are recommended for comparison and further evaluation of the integrated system.

An engineering and economic evaluation is also recommended (Contract Phase III) to start after the pilot plant tests are in progress.

BIBLIOGRAPHY

- (1) Clift, Roland, "Particle-Particle Interactions in Gas-Particle Systems," I. Chem. E. Symposium Series No. 91, Powtech '85 (1986).
- (2) First, Melvin W., "High-Temperature Gas Filtration Research Needs," DOE Contract No. DE-AC01-83FE60365, 30 April 1984.
- (3) Payatakes, A. C. and Tien, C., "Particle Deposition in Fibrous Media with Dendrite-Like Pattern: A Preliminary Model," Journal of Aerosol Science, 7 (1976) 85-100.
- (4) Putnam, Abbott A., "Historical Overview of Pulse Combustion with Specific Comments Relative to Noise," ASME 84-WA/NCA-20, 1984.
- (5) Richard, George A. and Bedick, Robert C., "Applications of Acoustics in Advanced Energy Systems," ASME 89-WA/NCA-3, 1989.
- (6) Litt, Robert D., and Conkle, H. Nicholas, "Nested Fiber Filter for High-Temperature and High-Pressure Particulate Removal", DOE Contract No. DE-AC21-86MC23251, July 31, 1988.

APPENDIX A

SAMPLE CALCULATION OF ACOUSTIC ENERGY

Sound Pressure Level (measured)

Microphone measured pressure: P, Pascals (newtons/meter)

Logarithmic scale (db) decibels is

$$20 \text{ Log } (P/.00002 \text{ Pa})$$

0.00002 Pa is the reference pressure (threshold of audibility)

Pressure is related to intensity of (energy/meter²) by the following relation

$$I = \frac{p^2}{\rho c} \quad \begin{array}{l} \rho = \text{density of air} = 1.21 \text{ kg/m}^3 \\ c = \text{speed of sound} = 343 \text{ m/sec @ } 70^\circ\text{F} \end{array}$$

Now, to make the intensity decibel scale to correspond to the SPL scale, the reference becomes

$$\frac{(.00002)^2}{1.21 (343)} = \frac{4 \times 10^{-16}}{1.21(343)} = 1 \times 10^{-12} \text{ watts/m}^2$$

The decibel scale becomes (Sound Intensity Level) with I in watts/m²

$$\text{SIL} = 10 \log (I/1 \times 10^{-12})$$

So, 160 db sound pressure level (SPL) corresponds to 160 db sound intensity level (SIL = 160).

$$\begin{array}{rcl} 160 & = & 10 \log (I/1 \times 10^{-12}) \\ 16 & = & \log (I \times 10^{12}) \\ 10^{16} & = & I \times 10^{12} \\ I & = & 10^4 \text{ watts/m}^2 \end{array}$$

The total energy in acoustic watts requires the cross-sectional area of the pipe at the measurement location

$$\text{Energy (in watts)} = I \times A$$

$$A = 0.018 \text{ m}^2 \text{ for 6-inch diameter filter}$$

$$E = 10^4 \text{ watts/m}^2 \times 0.018 \text{ m}^2$$

$$E = 24 \text{ watts}$$

$$E = 24 \text{ watts} \times 1 \text{ Btu}/0.293 \text{ Whr}$$

$$E = 83 \text{ Btu/hr}$$

END

**DATE
FILMED**

12 / 8 / 92