**Analysis of Potential Implementation
Levels for Waste Heat Utilization
in the Nuclear Power Industry**

M. Olszewski
H. R. Bigelow

OAK RIDGE NATIONAL LABORATORY
OPERATED BY UNION CARBIDE CORPORATION · FOR THE DEPARTMENT OF ENERGY

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road, Springfield, Virginia 22161
Price: Printed Copy \$4.50 ; Microfiche \$3.00

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, contractors, subcontractors, or their employees, makes any warranty, express or implied, nor assumes any legal liability or responsibility for any third party's use or the results of such use of any information, apparatus, product or process disclosed in this report, nor represents that its use by such third party would not infringe privately owned rights.

Contract No. W-7405-eng-26

Engineering Technology Division

ANALYSIS OF POTENTIAL IMPLEMENTATION LEVELS FOR WASTE HEAT
UTILIZATION IN THE NUCLEAR POWER INDUSTRY

M. Olszewski

H. R. Bigelow

Date Published - October 1978

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
DEPARTMENT OF ENERGY

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

TABLE OF CONTENTS

	<u>Page No.</u>
FOREWORD.....	v
ABSTRACT.....	1
BACKGROUND.....	1
SITE INFORMATION.....	2
ANALYSIS OF LAND CONSTRAINTS.....	14
DISCUSSION OF RESULTS.....	23
CONCLUSIONS.....	27
REFERENCES.....	28

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

FOREWORD

It has been recognized that, because of power cycle operating conditions, nuclear power plants reject more waste heat per unit of electricity produced than comparable fossil stations. Because the waste heat problem is more severe for nuclear power stations, research in the area of beneficial uses of waste heat has been sponsored for a number of years by the Advanced Systems and Materials Production Division of DOE (formerly Nuclear Research and Applications Division of ERDA).

These studies have considered various uses for power plant reject heat and have centered on agricultural applications. Some of this agricultural work has been carried out in a cooperative program with the Tennessee Valley Authority (TVA). This work is continuing with an 0.5 acre demonstration greenhouse being constructed by TVA at the Browns Ferry Nuclear Station. This greenhouse is based on a DOE-supplied design, and a combined DOE-TVA report concerning this project will be issued after the greenhouse has been in operation for a growing season.

During the course of the beneficial uses investigations, it became evident that an assessment of the potential for implementation of these systems at nuclear power stations was needed. Therefore, this study was initiated to address this question.

ANALYSIS OF POTENTIAL IMPLEMENTATION LEVELS FOR WASTE HEAT UTILIZATION IN THE NUCLEAR POWER INDUSTRY

M. Olszewski
H. R. Bigelow

ABSTRACT

An assessment of land available at nuclear power stations was performed in an effort to determine the limitations land availability would impose on the implementation of reject heat utilization systems. A waste heat utilization factor was defined for all operating and planned nuclear power stations for which a Preliminary Safety Analysis Report has been filed. This factor is the percentage of the station's reject heat that could be utilized on the land available for such use at the site.

The results indicate that reject heat from 115,000 MW(e) of generating capacity could be utilized on the land which is available. The results further indicate that about half of this potential implementation is at stations that have enough land to accommodate waste heat utilization systems sized to use all of the reject heat of the station. Utilization of the remaining 50% is about equally distributed among sites capable of using between 10 and 90% of their reject heat. Further, it seems reasonable that for many applications, an integrated waste heat complex, using several waste heat technologies, will be required to avoid marketing problems. It also appears that single application systems will be important for the sites that can use only a small fraction of their total reject heat.

A preliminary estimate of the potential for implementation at fossil stations was also performed. Based on these estimates it appears that implementation of waste heat utilization systems in the power industry will be limited by economic and marketing constraints rather than power plant land availability considerations.

The sites were also examined to determine the relative importance of retrofit applications. Those stations having a starting date prior to 1981 for any unit were classed as retrofit applications. The results of this analysis indicated that about half the potential for waste heat utilization was in retrofit applications.

BACKGROUND

Utility statistics¹ indicate that thermal power stations generated about 1.6×10^{12} MW(e)-hr during 1975. Because of the second law of thermodynamics, this resulted in about 11.6×10^9 GJ (11×10^{15} Btu) of low

temperature heat being rejected to the atmosphere. This represents an energy resource equivalent to $4.4 \times 10^8 \text{ m}^3$ (2.8×10^9 bbl) of oil per year, if appropriate uses could be found for this low grade energy.

Various techniques have been proposed and studied to utilize this reject heat, which is contained in power plant condenser cooling streams. These applications have focused primarily on agricultural (greenhouse and livestock facility heating, open field underoil heating and spray irrigation) and aquacultural applications. Most of the efforts in these areas have been directed at developing the individual applications. To date, there has been little information available concerning possible implementation levels for these systems on a national scale.

A recent ORNL study² attempted to define implementation levels for the various waste heat utilization techniques by examining economic and market constraints from the waste heat user's perspective. The results of this study indicated that, for most of the systems studied, marketing factors were the key implementation constraints. This study, however, did not account for land availability constraints associated with the power plant sites. Since most of the reject heat uses currently being examined require relatively large [on the order of 400 ha for a 1000-MW(e) plant] land areas to utilize a significant portion of the station's reject heat, land availability at the power station may limit wide-scale implementation of such systems in the power industry.

The present study was initiated in an effort to determine if the implementation levels reported in the previous study would be achievable when power plant site considerations were included in the analysis. The assessment was performed by analyzing site sizes for operating and planned nuclear stations to determine if land availability constraints around these stations could limit implementation of waste heat use systems. Because relevant site information was readily available for nuclear power stations, the study was confined to this segment of the power industry.

SITE INFORMATION

Information concerning the power plant sites was taken from Refs. 3, 4, 5, and 6. Since these sources used Preliminary Safety Analysis Reports (PSARs) as their source, the sites under consideration were confined to

existing or planned nuclear power stations. Pertinent data concerning electrical output, type of cooling system, site size, startup date, exclusion distance, and utility ownership are presented in Table 1 for each station included in the study.

The portion of the site available for waste heat utilization facilities, presented in Table 1, was estimated at 75% of the total site size. Initially, this area was computed using the exclusion distance and the total site size. In this scheme, the exclusion distance radius was used to calculate a circular exclusion area. This exclusion area was then subtracted from the site size to give the area that could be used for waste heat utilization facilities. However, for some sites this method yielded exclusion areas that were greater than the total site size. This was typically true for sites that were located near bodies of water. When these sites were excluded, it was found that the exclusion area generally occupied 25% of the total site.

Additional data concerning land utilization of nuclear power stations from Ref. 7 indicated that the power station facilities (site structures, roadways, cooling systems, etc.) generally occupy 10% or less of the total site. A detailed breakdown of land use at five stations (Arkansas 1, Hatch 1 and 2, Farley 1 and 2, and Grand Gulf 1 and 2)⁷ showed that, on the average, 75% of the station site is left undisturbed. The land could, therefore, be used for waste heat utilization facilities unless other factors precluded the use of a portion of the land.

Since a detailed breakdown of land use at each nuclear station was well beyond the scope of this study, it was decided to uniformly use 75% of the total site size as the area available for reject heat facilities. From the data available this seemed to be a reasonable assumption for the overall industry. There are stations, such as Indian Point and Vermont Yankee, that deviate greatly from the 75% figure. These stations, however, generally occupy small sites [less than 100 ha (250 acres)]⁷ and represent only a small (~5%) fraction of the nuclear power station sites. Therefore, it was felt that significant deviation from the 75% assumption by these stations would not seriously affect the conclusions reached in this study.

Table 1.

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY (MWe)</u>	<u>COOLING SYSTEM</u>	<u>SITE SIZE (ha)</u>	<u>AVAILABLE AREA (ha)</u>	<u>WASTE HEAT UTILIZATION FACTOR (%)</u>
AGUIRRE	PRWR	P*	614	n. a.	127	95	39
ALLENS CREEK 1)	HL&P	P	1150	CL	4400	3300	359
2)			1150				
ARKANSAS 1)	APL	1974	850	OT	440	330	47
2)		1977	912	NO			
DUANE ARNOLD	IE&PCO	1974	538	MD	192	144	67
BAILLY	NIPS	1982	645	ND	140	105	41
ALAN R. BARTON 1)	APC	P	1159	ND	1120	840	91
2)		P	1159				
BEAVER VALLEY 1)	DLC	1976	852	ND	180	135	20
2)		1982	852				
BELL STATION	NYSE&G	P	866	OT	360	270	78
BELLEFONTAINE 1)	TVA	1980	1213	ND	600	450	46
2)		1980	1213				
BIG ROCK POINT	CPC	1962	75	OT	240	180	60
BLACK FOX 1)	PSO	1982	1150	MD	882	661	72
2)		1984	1150				
BLUE HILLS 1)	GSU	1989	918	MD	1216	912	124
2)		1981	918				
BRAIDWOOD 1)	CEC	1981	1120	CL	1742	1306	146
2)		1982	1120				
BROWNS FERRY 1)	TVA	1973	1065	MD	339	254	20
2)		1974	1065				
3)		1976	1065				
BRUNSWICK 1)	CP&L	1976	821	OT	484	363	55
2)		1975	821				

*Indicates future planned startup date has not been finalized.

Table 1. (continued)

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY (MWe)</u>	<u>COOLING SYSTEM</u>	<u>SITE SIZE (ha)</u>	<u>AVAILABLE AREA (ha)</u>	<u>WASTE HEAT UTILIZATION FACTOR (%)</u>
ENRICO							
FERMI 2)	DEC	1980	1093	MD	373	280	64
JOSEPH 1)	APC	1977	829	MD	323	242	26
M FARLEY 2)		1978	829				
FORKED RIVER	JCP&L	1982	1070	OT	575	431	98
FORT CALHOUN 1)	OPPD	1973	457	OT	467	350	55
2)		1982	1136				
FORT ST~ VRAIN	PSC	1974	330	MD	903	677	513
FULTON	PE	1981	1160	ND	145	109	23
ROBERT GINNA	RG&E	1969	490	OT	136	102	52
GRAND GULF 1)	MP&L	1980	1250	MD	887	665	67
2)		1983	1250				
GREENE COUNTY	PASNY	1984	1191	ND	114	86	18
GREENWOOD 2)	DEC	P	1200	SP	1460	1095	114
3)		P	1200				
HARTSVILLE A)	TVA	1983-84	2466	ND	782	587	30
B)			2466				
SHEARON CP&L HARRIS (1-4)		1984-90	3600	N.A.	7258	5143	378
EDWIN I. 1)	GPC	1974	786	MD	905	679	106
HATCH 2)		1978	795				
HOPE 1)	PSE&G	1985	1067	ND	282	212	25
CREEK 2)		1983	1067				
HUMBOLDT BAY 3)	PG&E	1963	70	OT	58	44	155
INDIAN 1)	CONED	1962	260	OT	96.4	72	9
POINT 2)		1973	880				
3)		1976	965				

Table 1. (continued)

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY</u> <u>(MWe)</u>	<u>COOLING</u> <u>SYSTEM</u>	<u>SITE</u> <u>SIZE</u> <u>(ha)</u>	<u>AVAILABLE</u> <u>AREA</u> <u>(ha)</u>	<u>WASTE</u> <u>HEAT</u> <u>UTILIZATION</u> <u>FACTOR (%)</u>
JAMESPORT							
1)	LILO	1983	1150	OT	224	168	18
2)		1985	1150				
KEWAUNEE	WP&L	1974	560	OT	364	273	122
KOSHKONONG							
1)	WEP	1984	900	ND	466	424	59
2)		1986	900				
LA CROSSE	DPC	1969	52.4	OT	40	30	150
LA SALLE							
1)	CEC	1979	1078	CL	2016	1512	145
2)		1979	1078				
LIMERICK							
1)	PE	1983	1065	MD	237	178	21
2)		1985	1065				
MAINE							
YANKEE	MYAPCO	1972	790	OT	298	224	71
MARBLE							
HILL 1)	PS1	1981	1130	MD	398	299	32
2)	(20%NLPS)	1983	1130				
MCGUIRE							
1)	DUKE	1979	1180	MD	12077	9073	945
2)		1980	1180				
MENDOCINO	PG&E	P	1168	OT	165	124	26
MIDLAND 1)	CPC	P	492	CL	149	112	21
2)			818				
MILLSTONE							
1)	HEL	1970	690	OT	202	152	14
2)		1975	828				
3)		1982	1156				
MONTAGUE							
1)	NEU	1986	1150	ND	766	575	62
2)		1987	1150				
MONTICELLO	NSP	1970	545	MD	534	400	182
NEW	1) NEPC	1983	1150	OT	221	166	18
ENGLAND 2)		1987	1150				

Table 1. (continued)

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY (MWe)</u>	<u>COOLING SYSTEM</u>	<u>SITE SIZE (ha)</u>	<u>AVAILABLE AREA (ha)</u>	<u>WASTE HEAT UTILIZATION FACTOR (%)</u>
NINE MILE POINT	1) NMPC 2)	1969 1982	610 1100	OT	605	454	67
NORTH ANNA	1) VEPCO 2) 3) 4)	1977 1978 1980 1981	898 898 907 907	OT	434	325	23
OCONEE	1) DUKE 2) 3)	1973 1973 1974	986 986 986	OT	203	152	13
OYSTER CREEK	JCP&L	1969	650	OT	571	428	165
PALISAIDES	1) CPC	1971	821	MD	196	147	45
PALO VERDE	1) APS 2) 3)	1981 1983 1983	1237 1237 1237				
PEACH BOTTOM	2) PE 3)	1973	1065 1065	OT&MD	250	188	22
PEBBLE SPRINGS	1) PORTGE 2)	1984 1988	1260 1260	CL	3387	2540	254
PERKINS	1) DUKE 2) 3)	1984 1986 1988	1280 1280 1280	MD	484	363	24
PERRY	1) CEI 2)	1981 1982	1205 1205	OT	429	322	34
PHIPPS BEND	1) TVA 2)	1983 1984	1233 1233	ND	512	384	38
PILGRIM	1) BEC 2) 3)	1972 1983	655 1180 1180	OT	208	156	13
POINT BEACH	1) WEP 2)	1970 1972	497 497	OT	508	381	95

Table 1. (continued)

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY</u> (MWe)	<u>COOLING</u> <u>SYSTEM</u>	<u>SITE</u> <u>SIZE</u> (ha)	<u>AVAILABLE</u> <u>AREA</u> (ha)	<u>WASTE</u> <u>HEAT</u> <u>UTILIZATION</u> <u>FACTOR (%)</u>
PRARIE 1)	NSP	1973	530	MD	226	170	40
ISLAND 2)		1974	530				
QUAD-CITIES 1)	CEC	1971	809	OT	163	122	19
2)		1972	809				
QUANICASSEE 1)	CEC	1980-81	1200	ND	429	322	67
2)							
RANCHO DECO 3MUD		1974	913	ND	1000	750	205
RIVER BEND 1)	GSU	1981	934	MD	1081	811	108
2)		1983	934				
H B ROBINSON 2)	CP&L	1970	707	OT	2016	1512	535
SALEM 1)	PSE&G	1976	1090	OT	232	212	24
2)		1979	1115				
SAN ONOFRE 1)	SCE	1967	450	OT	34	26	2
2)		1980	1100				
3)		1981	1100				
SEQUOYAH 1)	TVA	1977	1148	OT(LAG)	212	283	31
2)		1978	1148				
SHOREHAM	LILOU	1979	819	OT	181	136	41
SKAGIT 1)	PSP&L	1983	1277	ND	605	454	44
2)		1986	1277				
SOUTH TEXAS 1)	HL&D	1980	1250	CL	4980	3735	374
2)		1981	1250				
STERLING	RG&E	1983	1150	OT	1129	847	184
VIRGIL C							
SUMMER	SCE&G	1978	900	OT	4435	3326	924
SUMMIT	DF&L	1980	766	MD	726	544	177
SURRY 1)	VEPCO	1972	822	OT,SP	339	254	19
2)		1973	822				
3)		1986	859				
4)		1987	859				
SUSQUEHANA 1)	PP&L	1980	1050	ND	614	461	55
2)		1981	1050				

Table 1. (continued)

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY</u> <u>(MWe)</u>	<u>COOLING</u> <u>SYSTEM</u>	<u>SITE</u> <u>SIZE</u> <u>(ha)</u>	<u>AVAILABLE</u> <u>AREA</u> <u>(ha)</u>	<u>WASTE</u> <u>HEAT</u> <u>UTILIZATION</u> <u>FACTOR (%)</u>
THREE MILE	1) JCP&L 2)	1974 1977	792 906	MD	252	189	28
TROJAN	PORTGE	1975	1130	ND	251	188	42
TURKEY POINT	3) FPL 4)	1972 1973	745 745	OT	1331	998	148
TYRONE	NSP	1984	1150	MD	1855	1391	302
VERMONT YANKEE	VYP	1972	514	MD	50	38	18
VOGTLE	1) GPC 2)	1983 1984	1113 1113	ND	1290	968	107
WPPSS (Hanford)	1) WPPSS 2) 4)	1981 1982 1984	1218 1100 1218	MD	153,000	115,000	7900
WPPSS	3) WPPSS 5)	1981	1242 1242	ND	1024	768	77
WATERFORD	3) LL&P 4)	1980	1113 1113	OT	1452	1089	124
WATTS BAR	1) TVA 2)	1979 1979	1177 1177	ND	714	535.5	57
WOLF CREEK	KG&E	1981	1150	CL	444	333	72
YANKEE ATOMIC	YEPCO	1960	186	OT	806	605	795
YELLOW CREEK	1) TVA 2)	1984 1985	1285 1285	MD	468	351	34
ZIMMER	1) CG&E 2)	1978 P	810 1170	ND	198	149	19
ZION	1) CEC 2)	1973 1973	1050 1050	OT	101	76	9
SUNDESERT	1) SDG&E 2)	1984 1985	974 974	MD	2839	2129	273

Table 1. (continued)

<u>REACTOR</u>	<u>UTILITY</u>	<u>STARTUP</u>	<u>CAPACITY</u> <u>(MWe)</u>	<u>COOLING</u> <u>SYSTEM</u>	<u>SITE</u> <u>SIZE</u> <u>(ha)</u>	<u>AVAILABLE</u> <u>AREA</u> <u>(ha)</u>	<u>WASTE</u> <u>HEAT</u> <u>UTILIZATION</u> <u>FACTOR (%)</u>
ERIE 1)	DEC	1984	1260	ND	702	526	52
2)		1986	1260				
ST. LUCIE	1) FP&L	1976	825	OT	456	342	52
	2)	1982	825				

Table 2.

Key to Table 1.

A. Cooling System Codes -

OT	Once through
CL	Cooling lake or pond
MD	Mechanical draft cooling tower
ND	Natural draft cooling tower
SP	Spray pond or canal
LAG	Lagoon
n. a.	Information not available

B. Utility Names and Abbreviations -

APC	Alabama Power Company
APL	Arkansas Power and Light
APS	Arizona Public Service
BEC	Boston Edison Company
BG&E	Baltimore Gas & Electric Company
CEC	Commonwealth Edison Company
CEI	Cleveland Electric Illuminating Company
CG&E	Cincinnati Gas & Electric Company
CL&P	Connecticut Light & Power Company
CONED	Consolidated Edison Company
CPC	Consumers Power Company
CP&L	Carolina Power & Light Company
DEC	Detroit Edison Company
DLC	Duquesne Light Company
DPC	Dairyland Power Cooperative
DP&L	Delaware Power & Light Company
DUKE	Duke Power Company
DOE	Department of Energy
FPC	Florida Power Corporation
FP&L	Florida Power & Light Company
GPC	Georgia Power Company
GSU	Gulf States Utilities Company

Table 2. (continued)

Utility Names and Abbreviations - (cont'd)

HEL	Hartford Electric Light Company
HL&P	Houston Lighting & Power Company
IE&PCO	Iowa Electric & Power Company
IGEC	Illinois Gas & Electric Company
IMECO	Indiana & Michigan-Electric Company
IPC	Illinois Power Company
JCP&L	Jersey Central Power & Light Company
KCP&L	Kansas City Power & Light Company
KG&E	Kansas Gas & Electric Company
LILCO	Long Island Lighting Company
LL&P	Louisiana Light & Power Company
MP&L	Mississippi Power & Light Company
MYAPCO	Maine Yankee Atomic Power Company
NEPC	New England Power Company
NEU	Northeast Utilities
NIPS	Northern Indiana Public Service Company
NMPC	Niagara Mohawk Power Corporation
NPPD	Nebraska Public Power District
NSP	Northern States Power Company
NYSE&G	New York State Electric & Gas Corporation
OEC	Ohio Edison Company
OPPD	Omaha Public Power District
PacR&L	Pacific Power & Light Company
PASNY	Power Authority of the State of New York
PE	Philadelphia Electric Company
PEPCO	Potomac Electric Power Company
PG&E	Pacific Gas & Electric Company
PMC	Project Management Corporation
Port GE	Portland General Electric Company
PP&L	Pennsylvania Power & Light Company
PRWR	Puerto Rico Water Resources
PSC	Public Service Company of Colorado
PSE&G	Public Service Electric & Gas Company
PSI	Public Service Company of Indiana
PSNH	Public Service Company of New Hampshire

Table 2. (continued)

Utility Names and Abbreviations - (cont'd)

PSO	Public Service Company of Oklahoma
PSP&L	Puget Sound Power and Light Company
RG&E	Rochester Gas and Electric Company
SCE	Southern California Edison
SCE&G	South Carolina Electric & Gas Company
SDG&E	San Diego Gas & Electric Company
SMUD	Sacramento Municipal Utility District
TEC	Toledo Edison Company
TUS	Texas Utilities Services Incorporated
TVA	Tennessee Valley Authority
UEC	Union Electric Company
VEPCO	Virginia Electric Power Company
VYP	Vermont Yankee Power Corporation
WEP	Wisconsin Electric Power Company
WMP	Wisconsin-Michigan Power Company
WP&L	Wisconsin Power & Light Company
WPPSS	Washington Public Power Supply System
WPSC	Wisconsin Public Service Corporation
YEPCO	Yankee Electric Power Company

ANALYSIS OF LAND CONSTRAINTS

Data from Table 1 concerning the area available for waste heat utilization systems were used to determine what fraction of reject from the station could be utilized. To perform this analysis, however, it was necessary to estimate the area required by waste heat utilization systems to dissipate all of the reject heat from the power station. This area is a function of the waste heat utilization system being used and the site ambient weather conditions during the summer (high ambient temperatures during the summer result in minimum heat dissipation, hence, maximum system size). Such a detailed analysis, however, was beyond the scope of this report. Therefore, an average required waste heat utilization system size was used for the analysis.

This average system size was estimated using the results of a previous study² comparing various reject heat use alternatives. This study included greenhouse, animal shelter, and aquaculture applications and, thus, included the major waste heat use applications currently being examined. These systems were designed to accommodate, if possible, the yearly cooling needs of a 1000-MW(e) power station in Portland, Oregon. The results of this study indicated that an average area of 400 ha is required to utilize all of the reject heat from a 1000-MW(e) power station. Thus, for the purposes of this study, it was assumed that 0.4 ha/MW(e) of installed capacity was required to utilize all the reject heat from a power plant.

The area available at nuclear power stations and the average area required to utilize all of the reject heat from the station were then used to calculate a waste heat utilization factor (WHUF). The WHUF was calculated by dividing the area available for reject heat utilization, from Table 1, by the area required to utilize all of the station's reject heat. The latter figure was obtained by multiplying the average area requirement of 0.4 ha/MW(e) by the total installed capacity of the station.

The WHUF thus indicates the percentage of the total reject heat of the station that can be utilized if all of the area available at the station was dedicated to a waste heat utilization system. (This system could consist of a single application, such as greenhouses, or include a number of applications.) A site having a WHUF of 100%, or greater, has enough land

available to utilize all of its reject heat. Thus land availability will not constrain implementation of waste heat utilization systems at these sites. Sites having a WHUF less than 100% have only enough land to utilize a portion of their reject heat. Thus, for these sites, land availability will restrict the use of reject heat.

The WHUF data in Table 1 were then used to obtain the distribution of stations, with respect to their ability to use reject heat, by summing the number of stations in each 10% range (0-9, 10-19, etc.) and plotting them in Fig. 1. To obtain a better understanding of the relative importance of each WHUF range, the total installed capacity distribution, corresponding to the site distribution in Fig. 1, was plotted in Fig. 2.

The primary intent of this study was to determine the nuclear generating capacity from which waste heat could be utilized. The distribution of this capacity among the WHUF ranges is given in Fig. 3. These results were obtained by multiplying the installed capacity values in Fig. 2 by the mid-point WHUF for the range. The results in Fig. 3 thus indicate the generating capacity whose waste heat could be utilized for the various WHUF ranges. For example, at sites that can utilize 70 to 79% of their reject heat land availability, considerations would allow reject heat from 8500 MW(e) of installed capacity to be utilized (this is in contrast to the total installed capacity of 11,500 MW(e) for this range from Fig. 2).

The results in Fig. 3 were then used to develop cumulative plots with respect to the installed capacity whose reject heat could be utilized (Fig. 4) and on a percentage basis (Fig. 5).

In addition to analyzing site land constraints, the data in Table 1 were used to examine how important retrofitting existing stations will be in achieving significant waste heat implementation levels. It was assumed that stations having a startup data prior to 1981 for any unit would fall in the retrofit category, while those with projected startup of 1981, or beyond, would have the flexibility to accommodate taps for reject heat use purposes. The results of this analysis are presented in Figs. 6 and 7 in much the same manner as the waste heat utilization data in Figs. 1 and 2. The number of new and retrofit stations for each WHUF range is presented in Fig. 6, while the capacity of these stations is given in Fig. 7.

Fig. 1. Number of Nuclear Power Stations that can Utilize a Given Fraction of their Waste Heat

ORNL-DWG 78-12466R

Fig. 2. Total Installed Capacity of Nuclear Stations that can Utilize a Given Fraction of their Waste Heat

ORNL-DWG 78-12467R

Fig. 3. Installed Nuclear Capacity for which Reject Heat is Utilized

Fig. 4. Cumulative Installed Nuclear Capacity Utilizing Waste Heat Utilization

Fig. 5. Cumulative Percentage of Nuclear Capacity Utilizing Reject Heat

ORNL DWG 78-12470R

Fig. 6. Number of Nuclear Power Stations for New and Retrofit Applications

Fig. 7. Installed Capacity of Nuclear Power Stations in New and Retrofit Applications

DISCUSSION OF RESULTS

The results illustrated in Figs. 1 and 2 indicate that, in terms of both number of stations and generating capacity, sites that have enough land available to utilize all of their reject heat ($WHUF \geq 100\%$) provide the greatest potential for implementing reject heat use systems. These sites comprised 32% of the stations and 28% of the total generating capacity included in the study and thus represented a large fraction of the nuclear power generating capability.

The relative importance of these sites is further illustrated by considering the amount of generating capacity from which heat can be utilized (see Figs. 3-5). The results in Fig. 3 indicate that the waste heat from 53,000 MW(e) of generating capacity can be utilized at sites having a WHUF of 100% or greater. The cumulative results plotted in Figs. 4 and 5 indicate that these sites comprise about 50% of the total capacity that could utilize reject heat. Thus, if reject heat utilization is to be implemented at significant levels, much of this potential will have to be exploited.

From Fig. 2 it would seem that the next most important group would be those stations that have a WHUF in the range of 20-29% (i.e., could utilize between 20 and 29% of their reject heat). However, the results in Fig. 3 indicate that most of the remaining WHUF ranges are of about equal importance in terms of capacity from which reject heat could be utilized. This is due to the fact that, although the installed capacity represented by the power stations in the lower WHUF ranges is greater than those in the higher ranges, the fraction of this capacity which could utilize its reject heat is decreasing. Thus, the two trends offset each other and the capacity for which reject heat could be utilized remains about constant. Therefore, the results in Fig. 3 indicate that the sites in the WHUF ranges less than 100% are of about equal importance in terms of implementation significance.

The relative importance of the various WHUF ranges is significant when considering the type of waste heat utilization complex that would probably be required to utilize the reject heat. Since the sites whose WHUF is 100% or greater are about as important, in terms of implementation potential, as those having a WHUF less than 100%, discussion of the makeup of the reject heat complex will focus on these two applications. From Figs. 1 and 2 it

is apparent that the stations in the 100% or over WHUF groups are fairly large stations. Dividing the total capacity [56,200 MW(e)] by the total number of stations (36) yields an average station size of 1560 MW(e). A waste heat utilization complex sized to utilize all the reject heat from a station of this size would require about 600 ha. Since it is unlikely that local conditions would permit the marketing of only one type of product, the waste heat utilization system would be required to produce a number of products. The required diversity of production could be accomplished in one of two ways. One method could have the entire complex comprised of a single application, which would market a number of products. For example, the waste heat utilization system could be a large greenhouse complex producing tomatoes, cucumbers, lettuce, and various floral crops. A second, and more realistic, alternative would be an integrated system consisting of a variety of applications. For example, the complex could include greenhouses, animal shelter heating, aquaculture, and undersoil heating applications. Since each of these applications markets a different product, this type of system would offer greater design flexibility in sizing each individual application to meet local marketing constraints.

For sites that utilize only a fraction of their reject heat, design of the waste heat utilization system will depend upon specific site conditions. Since most of the WHUF ranges are of about equal importance, some of the systems will be large (for sites in the higher WHUF ranges) while others will be smaller. The larger systems will face the same marketing constraints mentioned above and will probably include several applications. The smaller systems, however, are not likely to face these constraints and could include only one application.

Therefore, it appears that if reject heat utilization is to be implemented at a significant level, integrated systems, involving several waste heat technologies, will play an important role. It further appears that systems comprised of only one application will also be utilized to a significant degree.

The results in Fig. 4, showing the cumulative capacity from which waste heat could be utilized, indicate that waste heat utilization systems could utilize all the reject heat from 111,500 MW(e) of generating capacity, if land availability at nuclear stations were the only criterion. If this

potential was achieved, 55% of the reject heat from the 202,000 MW(e) of installed nuclear capacity included in this study could be utilized.

A note of caution should be added when attempting to compare the results in this report for any particular station with actual site data. Since the land available at any given station will not necessarily be 75% of the site size, the results presented in this report for individual stations may differ from actual site conditions. However, as previously discussed, the 75% assumption appears to be valid on a industry-wide basis. Thus, while the WHUF values in Table 1 for individual stations may not exactly reflect actual site conditions, the WHUF range and industry totals shown in Figs. 1-5 are probably valid.

It should also be noted that the waste heat utilization implementation figures contained in this report represent an upper limit for the potential in the nuclear power industry. Site specific considerations not included in this analysis could diminish the estimates reported in this study. These factors could include: 1) site land use plans of the utility including installation of additional generating capacity or conversion to a closed-loop cooling system, 2) topographical features that would preclude construction of waste-heat utilization systems, 3) economic limitations on the distance that reject heat could be transported to the customer, and 4) water availability limitations. Inclusion of factors such as these would require an extensive examination of each site. However, even if these factors were to reduce the implementation potential by a factor of two, reject heat from 55,000 MW(e) of installed capacity could be utilized. This would still result in over 25% of the waste heat from nuclear power stations being utilized.

Previous analysis² of economic and marketing constraints indicated that reject heat from 180,000 MW(e) of generating capacity could be utilized. The present analysis has indicated that reject heat from 111,500 MW(e) of installed nuclear capacity could be utilized when power plant site size limitations are the only criterion. Therefore, about 60% of the potential implied by economic and marketing constraints could be achieved at nuclear power stations. Even if the nuclear potential is decreased by one-half, for reasons previously discussed, 30% of the maximum implementation potential could be achieved at nuclear stations.

To determine if the implementation potential associated with economic and marketing constraints would be further limited by power plant land availability considerations, it was necessary to make a preliminary assessment of the potential for implementation at fossil stations. Since site data is not as readily available for these stations as it was for nuclear plants, the implementation potential is more difficult to estimate.

A recent ERDA study⁸ concerning the potential for solar heating of boiler feed water at oil- and gas-fired power plants concluded that at least half of these plants had sufficient space available for 20 ha (50 acres) of heaters. The current installed capacity for these plants is about 213,000 MW(e)⁹ or about equal to the nuclear capacity included in this study. Therefore the potential implementation of waste heat utilization at these stations will be less than for the nuclear plants, but could be significant.

Coal plant sites typically total 200 to 400 ha (500 to 1000 acres)¹⁰ much like nuclear stations. However, land requirements for coal storage, rail yards and other facilities result in the coal plant using about 120 ha (300 acres) of the total site.¹¹ Therefore, the area available for waste heat utilization facilities is between 40 and 65% of the total site.

The current installed coal-fired capacity in the U.S. is about 207,000 MW(e).⁹ Estimates indicate that by 1995 an additional 148,000 MW(e) of capacity will be added.⁹ Thus, when compared to the nuclear stations the coal-fired plants have less land available at each station but have a larger total installed capacity. Therefore, the waste-heat utilization potential of the coal stations was estimated to be equal to or greater than the nuclear estimate.

Based on these estimates, it appears that implementation of waste heat utilization systems will be limited by economic and marketing constraints rather than power plant land availability considerations.

The results illustrated in Figs. 6 and 7 also indicate that, if power plant waste heat utilization is to achieve wide-scale implementation, retrofit of existing stations will be important. It is clear from Fig. 7 that about half the waste heat utilization at sites with a WHUF of 100% will involve retrofit applications. It is also clear from Figs. 6 and 7 that implementation for WHUF ranges less than 100% will involve a slightly larger percentage of retrofit cases. Since some of the sites have several units,

the results in Figs. 6 and 7 are conservative. As mentioned previously, a site was classed as retrofit if startup of any of the units was prior to 1981. Therefore, some sites may be classed as retrofit applications but have units that are scheduled to begin operation after 1981. This situation, however, does not introduce any serious error into the analysis because the number of such occurrences is small. Also, the utility will probably face many of the same problems if it is retrofitting one or several units. Therefore, from a utility perspective, the situation will be similar if one or several units must be retrofitted.

CONCLUSIONS

Analysis of power plant site size barriers to waste heat utilization has indicated that enough land is available at nuclear stations to utilize the reject heat from 111,500 MW(e) of generating capacity.

The results further indicated that sites that can utilize all of their reject heat make up approximately 50% of this capacity. The remaining capacity is distributed fairly uniformly among the WHUF ranges below 100%. This result indicates that integrated systems involving several waste heat utilization technologies will be important for over 50% of the possible implementation, while single application systems could be used for the sites that are constrained to use smaller systems.

The results also indicate that economic and marketing criteria will likely constrain waste heat utilization implementation more severely than power plant land availability considerations.

It is also clear that, if waste heat utilization is to achieve wide-scale implementation in the nuclear power industry, retrofit applications will play a major role.

REFERENCES

1. Edison Electric Institute, Statistical Yearbook of the Electric Utility Industry, Publications No. 75-39, November 1975.
2. M. Olszewski, "Power Plant Reject Heat Utilization: An Assessment of the Potential for Wide-Scale Implementation," ORNL/TM-5841, December 1977.
3. F. A. Heddleson, "Design Data and Safety Features of Commercial Nuclear Power Plants," ORNL/NSIC-96, June 1976.
4. F. A. Heddleson, "Design Data and Safety Features of Commercial Nuclear Power Plants," ORNL/NSIC-96, June 1976.
5. F. A. Heddleson, "Design Data and Safety Features of Commercial Nuclear Power Plants," ORNL/NUREG/NSIC-136, June 1977.
6. D. F. Cope and H. F. Bauman, "Expansion Potential for Existing Nuclear Power Station Sites," ORNL/TM-5927, November 1977.
7. W. Ramsay and P. R. Reid, "Land Use and Nuclear Power Plants Case Studies and Siting Problems," WASH-1319, 1974.
8. Technical and Economic Feasibility of Solar Augmentation for Boiler Feedwater Heating in Steam-Electric Power Plants, Franklin Institute Research Laboratories, COO-2864-1, November 1976.
9. Federal Energy Administration, Inventory of Power Plants in the United States, PB 269 867, June 1977.
10. M. Meyers, ORNL, personal communication, with M. Olszewski.
11. Capital Cost: Low and High Sulfur Coal Plants-800 MWE, United Engineers & Constructors, NUREG-0244, COO-2477-8 (no date).

Internal Distribution

1. T. D. Anderson	68. M. W. Rosenthal
2. S. Baron	69. M. R. Sheldon
3. S. E. Beall	70. M. J. Skinner
4. W. B. Cottrell	71. I. Spiewak
5. J. F. Harvey	72. H. E. Trammell
6. R. F. Hibbs	73. D. B. Trauger
7. H. W. Hoffman	74-75. Central Research Library
8. D. Jarred	76. Document Reference Section
9. M. Levenson	77-78. Laboratory Records Department
10-66. M. Olszewski	79. Laboratory Records, ORNL RC
67. H. Postma	

External Distribution

- 80-81. Director, Office of Fuel Cycle Evaluation, Nuclear Energy Programs, DOE, Washington, DC 20545
82. Director, Research and Technical Support Division, DOE, ORO
83. W. F. Savage, DOE, Advanced Systems and Materials Prod. Div., Washington, DC 20545
- 84-88. Ira Helms, DOE, Advanced Systems and Materials Prod. Div., Washington, DC 20545
89. Heyward D. Hamilton, Division of Biomedical and Environmental Research, DOE, Washington, DC 20545
90. William R. Cherry, Chief, Agriculture and Process Heat Branch, Division of Solar Energy, DOE, Washington, DC 20545
91. Richard H. Bleiden, Biomass, Ocean & Wind Systems, Division of Solar Energy, DOE, Washington, DC 20545
92. Edward Bryan, National Science Foundation, 1800 G St. NW, Washington, DC 20545
93. Edward Gaines, Vermont Yankee Nuclear Power Corp., 77 Grove St., Rutland, VT 05701
94. Gary Ashely, Northern States Power Company, 414 Nicollet Mall, Minneapolis, MN 55401
95. R. S. Pile, Agricultural Resources Development Branch, Tennessee Valley Authority, Muscle Shoals, AL 35660
96. F. Incropera, Department of Mechanical Engineering, Purdue University, West Lafayette, IN 47907
97. G. J. Trezek, Department of Mechanical Engineering, University of California, Berkeley, Berkeley, CA 94720
98. Bruce Godfriaux, Public Service Electric & Gas Company, Room 12329, Newark, NJ 07101
99. Marvin Gunn, Division of Power Systems, Energy Technology Group, DOE, Washington, DC 20545

- 100. Doug Harvey, Assistant Director for Industrial Systems,
Division of Industrial Energy Conservation, DOE, Washington, DC
20545
- 101-127. Technical Information Center, DOE, ORO