EGG-NRRI--10350

DE93 002038

PRELIMINARY DESIGN STUDIES ON THE
BROAD APPLICATION TEST REACTOR

Edited by W. J. Terry

W. K. Terry, J. M. Ryskamp, S. N. Jahshan,
C. D. Fletcher, R. L. Moore, C. F. Leyse,
E. H. Ottewitte, C. G. Motloch, and J. M. Lacy

Idaho National Engineering Laboratory

EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83415-1575

August 1992

Work performed under the auspices of the U.S. Department of Energy
Assistant Secretary for Nuclear Energy
Under Contract No. DE-AC07-76ID01570.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ACKNOWLEDGEMENT

The authors would like to acknowledge the contributions made by the Design Team and Cost Reduction Team members listed below.

Design Team: R. L. Drexler, C. D. Fletcher, S. N. Jahshan, S. T. Khericha,
J. M. Lacy, C. F. Leyse, R. L. Moore, J. M. Ryskamp, W. K. Terry,
G. L. Thinnes, and W. L. Weaver

Cost Reduction Team: D. I. Gertman, T. K. Larson, J. L. Liebenthal,
J. H. McDaniel, R. M. Pacetti, R. E. Polk, J. M. Ryskamp,
T. W. Smith, and K. L. Sorman

ABSTRACT

This report describes progress made at the Idaho National Engineering Laboratory during the first three quarters of Fiscal Year (FY) 1992 on the Laboratory-Directed Research and Development (LDRD) project to perform preliminary design studies on the Broad Application Test Reactor (BATR). This work builds on the FY-92 BATR studies,^a which identified anticipated mission and safety requirements for BATR and assessed a variety of reactor concepts for their potential capability to meet those requirements.

The main accomplishment of the FY-92 BATR program is the development of baseline reactor configurations for the two conventional conceptual test reactors recommended in the FY-91 report. Much of the present report consists of descriptions and neutronics and thermohydraulics analyses of these baseline configurations. In addition, we considered reactor safety issues, compared the consequences of steam explosions for alternative conventional fuel types, explored a Molten Chloride Fast Reactor concept as an alternate BATR design, and examined strategies for the reduction of operating costs. Work planned for the last quarter of FY-92 is discussed, and recommendations for future work are also presented.

^aJ. M. Ryskamp, et al., "Safety Requirements, Facility User Needs, and Reactor Concepts for a New Broad Application Test Reactor," EGG-NRRT-10332, Idaho National Engineering Laboratory (1992).

CONTENTS

ACKNOWLEDGEMENT	ii
ABSTRACT	iii
1.0 INTRODUCTION	1
2.0 DESCRIPTION OF CONVENTIONAL BATR DESIGN CANDIDATES	6
2.1 Basic Features of the Baseline Configurations	6
2.2 Selection of the Fuel Assembly Types.	8
2.3 Test Loop and Fuel Assembly Baseline Configurations	11
2.4 Cooling System and Vessel Layout.	14
3.0 CORE NEUTRONICS STUDIES.	19
3.1 DIF3D Models.	20
3.2 MCNP Models	26
3.3 Discussion of Results	32
4.0 THERMOHYDRAULICS STUDIES	38
4.1 Core Region	38
4.2 Coolant Loops	40
5.0 SAFETY CONSIDERATIONS.	45
6.0 POTENTIAL FOR STEAM EXPLOSIONS	47
6.1 Description of the Thermodynamic Model.	47
6.2 Results of Calculations	51
6.3 Summary of Findings	55
7.0 THE MOLTEN CHLORIDE REACTOR - AN ALTERNATE CONCEPT	56
8.0 COST REDUCTION STRATEGIES.	59
8.1 Naval Reactors Program.	59
8.1.1 Reactor Operations	59
8.1.2 ATR Experiments.	60
8.1.3 Site Office.	60
8.1.4 Engineering Support.	61
8.1.5 Reactor Maintenance.	61
8.1.6 Reactor Safety	62
8.1.7 Reactor Training	62
8.1.8 Waste Management	62
8.1.9 Compliance	62
8.1.10 Security	63

CONTENTS (CONTINUED)

8.2 Shutdown Time	63
8.3 NPR Experiments	63
9.0 RECOMMENDATIONS FOR FURTHER STUDY.	64
10.0 REFERENCES	67

TABLES

1. Test Loop Specifications	13
2. Fuel Assembly Characteristics.	15
3. Isotope Concentrations in DIF3D Nodes.	22
4. DIF3D Multiplication Factors	23
5. DIF3D Fluxes	24
6. MCNP Multiplication Factors for BATR and ATR	33
7. Peak MCNP Group Fluxes in Selected Locations	36
8. Comparison of Core Thermohydraulic Parameters for Two BATR Configurations and ATR.	39
9. Properties of Cladding Materials Considered for Conventional BATR Designs	54

FIGURES

1. Core Layout for Multiple Annular Reactor. The lower Portion of the Figure is an Expanded View of Part of the Core for Clarity in Showing Dimensions	9
2. Core Layout for Modular-Hexagonal Reactor. The lower Portion of the Figure is an Expanded View of Part of the Core for Clarity in Showing Dimensions	10
3. Schematic Illustration of Multiple-Annular Core with Mixed Fuel Types	12
4. Schematic Illustration of Pressure Vessel and Piping for Modular-Hexagonal Reactor.	17
5. Nodalization in DIF3D Models	25

FIGURES (CONTINUED)

6.	Sixth-Core Three Dimensional MCNP Model of the Multiple-Annular Reactor (a) Plan View, (b) Elevation View.	28
7.	Sixth-Core Three-Dimensional MCNP Model of the Modular-Hexagonal Reactor (a) Plan View, (b) Elevation View.	30
8.	Axial Profile of the Four Group Flux Values in the Multiple-Annular Reactor Central Loop.	34
9.	Axial Profile of the Four Group Flux Values in the Modular-Hexagonal Reactor Central Loop	35
10.	One Independent Coolant Loop in the Conventional BATR Design	42
11.	Processes for Hicks-Menzies FCI Model Pressure Volume Diagram.	50
12.	Work Per Unit Fuel Volume Function of Coolant to Fuel Volume Ratio	52
13.	Work Per Unit Fuel Volume Function of Coolant to Fuel Volume Ratio	53

1.0 INTRODUCTION

Nuclear reactors for testing of fuels and materials and for production of isotopes provide important support for several industries and institutions, including the medical-care system, the space program, the nuclear power industry, the electronics industry, and the nuclear Navy. The need for such reactors will continue for the foreseeable future as new applications develop and as increasingly stringent requirements continue to be imposed on old applications.

In the United States, the Department of Energy (DOE) administers most of the national programs related to nuclear energy. The DOE operates five reactors that collectively perform a broad range of testing and isotope production missions: the Advanced Test Reactor¹ (ATR) at the Idaho National Engineering Laboratory (INEL), the Fast Flux Test Facility² (FFTF) at Hanford, the High Flux Beam Reactor³ (HFBR) at Brookhaven, the High Flux Isotope Reactor⁴ (HFIR) at Oak Ridge, and the Experimental Breeder Reactor-II (EBR-II) at Argonne National Laboratory-West (ANL-W) in Idaho. The FFTF and EBR-II are fast reactors that do not provide high thermal neutron fluxes. The FFTF facility may be closed very soon; HFBR and HFIR are scheduled to shut down around the year 2000. The ATR and EBR-II have been operating for more than 25 years. The existing reactors at the Savannah River Site and the proposed New Production Reactor have tritium and plutonium production as their only missions and are not suitable for materials testing and other broad applications. Aside from design work on a new research reactor, the Advanced Neutron Source⁵ (ANS), which is primarily intended for neutron scattering experiments, no new reactor construction is planned that could provide DOE with sufficient testing and isotope production capabilities to replace the existing facilities that will be closed in the next 20 years.

Under the current DOE project management system (DOE Order 4700.1), major construction projects need at least fifteen years of lead time. This requirement may increase in the future. Therefore, it is prudent to begin planning now to ensure that DOE is not left without testing and isotope

production facilities when the existing facilities close. Furthermore, the need for new capabilities that cannot be provided by existing test reactors, such as space reactor fuel assembly testing, is likely to develop before a new test reactor can be built. To meet these needs, the INEL has begun preliminary planning and preconceptual design of a new-generation test reactor, the Broad Application Test Reactor (BATR).

Initial planning for BATR was begun in late 1990 by an interdisciplinary team of senior INEL engineers and scientists.⁶ The initial efforts emphasized determining the needs of potential users and ensuring safety.

The team judged the following user needs to be most important:

- o Irradiation testing of fuels and materials for terrestrial nuclear power
- o Isotope production, especially for the medical industry and for national defense
- o Irradiation testing of fuels and materials for space nuclear power and propulsion
- o Medical and neutron scattering research using beam tubes
- o Fusion materials testing
- o Intense positron facility
- o Silicon doping for the electronics industry.

The balance among these needs will certainly vary with time. A testing and production capability is needed that can respond flexibly and economically to changing mission requirements while maintaining a high level of safety. To provide such flexibility with a single reactor will require a new approach to both reactor design and reactor operation.

The initial studies reported in Reference 6 determined some of the basic design features that a multimission reactor will need to have. For many applications, a thermal neutron flux of at least $10^{15} \text{ cm}^{-2}\text{s}^{-1}$ will be required in a test volume larger than 50 liters. Such applications include materials and fuels testing, space power fuel assembly testing, isotope production, a positron facility, and some neutron beam research. Some potential applications, such as experiments with magnetism, will require a cold (i.e., very subthermal) neutron spectrum, so that the reactor will need to accommodate a cold neutron source. Other applications exist for epithermal and fast spectra. Devices such as "rabbits" will be needed to allow insertion and withdrawal of test articles during reactor operation. Neutron beams will be required for neutron scattering experiments.

A set of top-level goals has been established to guide the selection of a reactor type and the optimization of the reactor design. These goals are

- o A flexible high-neutron-flux facility for future-generation experiments and testing
- o A reactor design that emphasizes
 - Environment, safety, and health
 - Performance optimization
 - Risk and cost minimization
 - Responsiveness to broad and changing user needs
 - Safe routine maintenance over its lifetime.

Because of the variety of missions BATR will be called on to perform, several diverse reactor concepts were considered as candidates for the BATR design. These concepts were

- o Conventional test reactor with metal-plate fuel (using aluminum, zirconium, or stainless steel cladding), light-water cooling, and light-water or heavy-water moderation

- o Particle-bed reactor
- o Rotating-ring reactor
- o Cermet-fueled, liquid-metal-cooled reactor
- o Accelerator-driven spallation neutron source
- o TRIGA reactor
- o Pebble-bed reactor
- o Molten chloride fast reactor.

In the Fiscal Year (FY) 1991 studies, the conventional type of reactor was tentatively identified as the concept with the best chance of successfully meeting the goals identified for BATR. The molten chloride fast reactor is regarded as an alternative possibility. Other concepts could be added to the list of possibilities if their merits warrant inclusion in view of insights acquired in the future.

Two versions of the conventional concept were developed in FY 1991: the Multiple-Annular reactor and the Modular-Hexagonal reactor. Both of these versions feature independently cooled test loops, highly enriched aluminum plate fuel cooled by light water, and heavy-water neutron reflectors. However, because of differences in their core arrangements, the two versions will differ in their degrees of neutronic coupling.

The primary accomplishment of the work reported in this document is the development of baseline configurations for these two conventional reactor concepts. These baseline configurations will be used in the second half of FY 1992 as the reference cases for trade-off and optimization studies.

In the next section, the baseline designs are described and their development is discussed. Section 3.0 presents two sets of complementary neutronics

models for these designs. Section 4.0 summarizes thermohydraulics studies for the baseline concepts. The remaining sections discuss some studies that were not specifically connected with the two conventional reactor concepts: safety considerations (Section 5.0), the potential for steam explosions (Section 6.0), the Molten Chloride Fast Reactor (Section 7.0), and cost reduction strategies (Section 8.0). Section 9.0 presents recommendations for further study.

2.0 DESCRIPTION OF CONVENTIONAL BATR DESIGN CANDIDATES

As recounted in Section 1.0, the FY 1991 BATR development project⁶ studied a variety of possible reactor types for their potential ability to meet the anticipated BATR mission requirements. Of the various candidate concepts, two fundamentally conventional ones were chosen as the first to be developed further. This section describes the baseline configurations established for these two conventional reactor concepts, and explains how some aspects of these baseline configurations were selected. In future work, the baseline designs will be used as the bases for trade-off studies; some issues to be explored in the trade-off studies are mentioned where features of the baseline configurations are discussed.

2.1 Basic Features of the Baseline Configurations

The conventional concepts chosen for design studies are the Multiple-Annular concept and the Modular-Hexagonal concept. Both concepts feature metal-plate fuel cooled by light water, and both use heavy water for neutron reflection.

In the Multiple-Annular reactor, each test loop is closely surrounded by fuel assemblies, and each annular group of fuel assemblies is enclosed by its own pressure vessel. The pressure vessels pass vertically through a tank of heavy water that serves to moderate and reflect neutrons.

In the Modular-Hexagonal reactor, the fuel assembly locations define the corners of a hexagonal array, and the test loops are located at the centers of the hexagons. Most of the fuel assemblies are equidistant from the centers of two or even three test loops. A single pressure vessel encloses all the test loops and fuel assemblies, and a heavy water tank around the pressure vessel serves as a secondary reflector. Primary reflection is provided by a material inside the pressure vessel but outside the test loops and fuel assemblies; this material was tentatively assumed to be beryllium for calculations performed for this report. Inclusion of beryllium primary reflectors inside the pressure vessels in the Multiple-Annular reactor will be one of the

options examined in the trade-off studies that will be performed in the second half of FY 1992.

Heavy water was chosen as the material for the secondary reflector partly for the enhanced neutron efficiency it offers compared with light water (because thermal neutron absorption is substantially less in heavy water). Other reasons for the choice of heavy water for the secondary reflector are the improved accessibility of components (such as beam tubes) that are immersed in a liquid reflector instead of being imbedded in a solid reflector, and the greater flexibility of a structureless reflector for making adjustments in the reactor configuration from one operating cycle to another.

It was desired to configure the two conventional BATR designs with sufficient similarity that meaningful comparisons of their merits could be made. Accordingly, both concepts have the same number of test loops, with the same dimensions and the same spacing. Nevertheless, because of the more dispersed arrangement of the fuel in the Modular-Hexagonal reactor, and because of the large region of beryllium in its core, it is expected that the Modular-Hexagonal reactor will be more tightly coupled neutronically than the Multiple-Annular reactor.

To facilitate analyses, especially the trade-off studies that will require numerous repetitious calculations with incremental differences, a geometric arrangement was selected for both designs that permits representation by a hexagonal nodal model for the DIF3D neutron diffusion code⁷: each design has one central test loop and six outer test loops evenly spaced on a circle around the central one. To the greatest extent that is compatible with the accomplishment of BATR's operational mission, ease of analysis should be included among the design goals for BATR. The ability to perform analyses easily and accurately would be a very great advantage to the people who will operate the reactor; also, accurate analyses would enhance the interpretation of experimental results. One feature that makes analyses easier is geometric symmetry, as provided by these baseline designs.

Figure 1 shows the layout of the Multiple-Annular reactor in the horizontal plane. Figure 2 is an analogous depiction of the Modular-Hexagonal reactor.

2.2 Selection of the Fuel Assembly Types

In Reference 6, three alternative conventional fuel types are advanced. These are arcuate fuel as used in the ATR, concentric fuel (nested concentric cylinders) as used in reactors at the Savannah River Site, and involute fuel as used in HFIR and proposed for the Advanced Neutron Source.

Involute fuel is an annular form with curved plates extending between the inner and outer radii of the annulus. The radius of curvature of a fuel plate varies along the plate in such a way that the distance between adjacent plates remains constant. Involute fuel offers hydrodynamic advantages, which are very important for the ANS because of the high flow velocity required for adequate cooling in that high-flux reactor. However, it would be difficult to install a full annular assembly of involute fuel plates around the test loops in the Multiple-Annular reactor; multiple involute fuel assemblies may be structurally weak and introduce difficulties in positioning and reloading. Concentric fuel assemblies would be simpler in the Modular-Hexagonal reactor. Involute fuel will only be reconsidered if detailed thermohydraulic calculations or tests show the other fuel forms to have serious shortcomings.

Concentric fuel is simple and rigid. It was judged to be a natural choice for the Modular-Hexagonal reactor. For the Multiple-Annular reactor, installation of single concentric fuel assemblies around the test loops would be just as awkward as the use of one-piece involute assemblies. However, it would be possible to encircle each Multiple-Annular test loop by a group of concentric fuel assemblies evenly spaced around the circumference of the loop (see Figure 3).

Arcuate fuel assemblies would be convenient to install around the test loops in the Multiple-Annular reactor. Also, they would provide more symmetrical irradiation of the test spaces than a group of concentric assemblies would.

H105-WKT-0592-01

Figure 1. Core layout for multiple annular reactor. The lower portion of the figure is an expanded view of part of the core for clarity in showing dimensions.

H105-WKT-0592-03

Figure 2. Core layout for modular-hexagonal reactor. The lower portion of the figure is an expanded view of part of the core for clarity in showing dimensions.

Therefore, arcuate fuel assemblies were tentatively chosen for the Multiple-annular concept.

The use of clustered concentric fuel assemblies around the test loops in the Multiple-Annular reactor is being retained as an option. To meet several different simultaneous missions optimally, it might be desirable to mix fuel forms. Figure 3 is a computer-generated illustration of a core layout for the Multiple-Annular concept that combines the arcuate and concentric fuel forms simultaneously.

2.3 Test Loop and Fuel Assembly Baseline Configurations

A key requirement for BATR is to provide a thermal neutron flux of at least $10^{15} \text{ cm}^{-2}\text{s}^{-1}$ over a volume of at least 50 liters. This is a higher thermal neutron flux over a larger test volume than in the Advanced Test Reactor (ATR). However, because the ATR is a test reactor with a very successful operating history, we decided to set several basic parameters of the baseline BATR designs equal to or near the corresponding values in the ATR. Not only did this approach increase the likelihood of starting with a viable design configuration, but it facilitated a comparison with ATR, to help ensure that BATR will be a step forward in the state of the art in test reactor design rather than a regression. These basic parameters are total reactor power, fuel volume, core height, and fuel plate and coolant channel dimensions.

To meet the requirement for irradiation test volume that was established for BATR in FY 1991, the baseline configurations provide substantially larger irradiation spaces in the test loops than ATR offers. Because of the flux trap effect of light-water-cooled test loops, it should be expected that restrictions will be imposed on the allowable water volume in the loops. However, for preliminary design purposes, the test spaces were arbitrarily assumed to be composed of 50% light water and 50% Al-1100 aluminum alloy. The ATR test loops served as guides for the selection of BATR test loop components and materials. Table 1 shows the dimensions and materials used for the central and outer test loops. The central loop was given a larger test space

Figure 3. Schematic illustration of Multiple-Annular Core with mixed fuel types.

Table 1. Test Loop Specifications

Region	Composition	Dimensions (cm)			
		R_{outer}	Central Loop Width	R_{outer}	Outer Loop Width
Test space	50% Al-1100, 50% H ₂ O	7.5	7.5	4.0	4.0
Flow tube	S.S. 304	7.665	0.165	4.165	0.165
Flow return channel	H ₂ O	7.985	0.32	4.485	0.32
Pressure tube	S.S. 304	9.715	1.73	5.8	1.315
Helium annulus	Al-1100 (to represent (void)	9.865	0.15	5.95	0.15
Insulation jacket	S.S. 304	10.165	0.3	6.25	0.3
Water gap	H ₂ O	10.815	0.65	6.9	0.65
Baffle	Al-6061	11.5	0.685	7.5	0.6
Loop test space volume (L)			17.7		5.03
Total test space volume (L)					47.8

than the outer loops; accordingly, the pressure tube wall thickness was made greater to provide the same hoop strength.

Since the preliminary design configurations were constrained to use the same fuel plate component and coolant channel thicknesses as in the fuel used in ATR, the fuel assembly design process was reduced to the calculation of the integer number of fuel plates for which the fuel volume is as close as possible to that of ATR. Although the radii of curvature of the fuel plates in the inner-loop fuel assemblies of the Multiple-Annular reactor are different from the radii of curvature of the fuel plates in the outer-loop fuel assemblies, both kinds of fuel assemblies use the same number of fuel plates. Of course, this number is different from that used in the concentric fuel assemblies of the Modular-Hexagonal reactor.

Table 2 describes the fuel assemblies in the two reactor designs; the fuel loading values and fuel constituent concentrations are taken from the DIF3D neutronics models discussed in Section 3.1. Fuel loading will be varied as a parameter in the optimization studies.

2.4 Cooling System and Vessel Layout

Figure 4 is a computer-generated illustration of the piping system in the vicinity of the reactor vessel for the Modular-Hexagonal concept. Except for minor details, the corresponding illustration of the Multiple-Annular reactor is similar. Three cold legs supply light-water coolant to a common lower plenum. The three flows are mixed in the plenum before entering the core, and then flow upward through the fuel assemblies. Upon leaving the core, the coolant collects in the upper plenum and then flows to separate cooling loops through the three hot legs. The piping system for the Multiple-Annular reactor is similar. To avoid clutter in the illustration, only two of the cold legs and one of the hot legs are shown.

Safety considerations were given high priority in the establishment of pipe routing. For example, no opportunity was provided for molten core material to slump down into the piping beneath the core vessels. Concern over the

Table 2. Fuel Assembly Characteristics

	Multiple-Annular	Modular-Hexagonal
Active Fuel Height (cm)	100	100
Type	Arcuate in 45° sectors with side plates	Concentric
Location	Around test loops	At corners of hexagonal array
Number of fuel assemblies	7	24
Number of plates per assembly	16	13
Total U^{235} in core (kg)	51.03	47.8
ID of innermost coolant channel (cm)	15.0 (central assemblies) 8.0 (outer assemblies)	2.0
OD of outermost coolant channel (cm)	33.8 (central assemblies) 25.8 (outer assemblies)	10.85
Side plate width (cm)	0.475	---
Coolant channel width (cm)	0.2	0.2
Fuel plate thickness (cm)	0.125	0.125
Fuel meat thickness (cm)	0.05	0.05
Cladding composition	Al-6061	Al-6061

Table 2. (Continued)

Fuel composition	UA1 _x :	UA1 _x :
U-238	2.63102 x 10 ⁻⁴ a/b-cm	2.63102 x 10 ⁻⁴ a/b-cm
U-235	3.88806 x 10 ⁻³ a/b-cm	3.88806 x 10 ⁻³ a/b-cm
B-10	0.0 (for baseline designs)	0.0 (for baseline designs)
U-234	2.63102 x 10 ⁻⁵ a/b-cm	2.63102 x 10 ⁻⁵ a/b-cm
U-236	1.25290 x 10 ⁻⁵ a/b-cm	1.25290 x 10 ⁻⁵ a/b-cm
A1-1100	8.34181 x 10 ⁻¹ (volume fraction)	8.34181 x 10 ⁻¹ (volume fraction)

Figure 4. Schematic illustration of pressure vessel and piping for Modular-Hexagonal Reactor.

possibility of such slumping is the reason that the inlet pipes, which supply coolant from the bottom, are goosenecked down to the bottom of the reactor vessels from above. The inlet pipes come in from the sides to reduce the likelihood that they could be blocked by molten core material. On the bottom of the inlet plenum, a conical floor, with the point upward, is provided for the purpose of spreading out molten core material and further reducing the chance of collecting an ex-core critical configuration.

Although Figure 4 shows cold-leg pipes connecting to the lower plenum, a downcomer arrangement is probably a superior means of supplying coolant to the lower plenum, because a break in the illustrated inlet pipes below the core level could cause draining of the core. Downcomers are commonly used in commercial lightwater power reactors. If the illustrated piping were retained, the vessels and inlet pipes below the level of the outlet plenum would be immersed in a large tank of light water.

In both concepts, the temperature of the heavy-water reflector is maintained by a separate reflector cooling system. Twelve rabbit tubes allow insertion and removal of test samples during reactor operation. Three beam tubes facilitate neutron scattering research or other applications requiring monodirectional neutrons. The six control drives regulate the position of the scram blades or rods.

Further discussion of the cooling system is provided in Section 4.

3.0 CORE NEUTRONICS STUDIES

Two complementary sets of neutronics models were developed. The first set comprises two-dimensional models using hexagonal geometry for the Argonne National Laboratory (ANL) deterministic neutron diffusion code DIF3D.^{7,8} (Three-dimensional hexagonal-z DIF3D models will be developed in the future.) The second set comprises very detailed three-dimensional models using the Los Alamos National Laboratory (LANL) Monte Carlo (statistical) transport code MCNP.⁹

The DIF3D code can be run in either a finite-difference⁸ or a nodal⁷ formulation. In its finite-difference form, it tends to run more slowly for thermal reactor problems than some other diffusion codes such as PDQ.¹⁰ However, in its nodal form, it obtains node-averaged fluxes and global parameters such as k-effective (the effective core multiplication factor) very rapidly. Our nodal DIF3D models are intended to facilitate trade-off and optimization studies to assess the effects of some parameter variations on such global characteristics as k-effective and node-averaged neutron fluxes. Parameters to be varied in these studies include such quantities as test-loop spacing and fuel loading.

To assess the errors introduced by using the nodal option with the very coarse nodalization in our BATR models, we also constructed finite-difference DIF3D models. In the finite-difference models, each hexagonal node was divided into 700 mesh triangles. Each node was still represented as compositionally homogeneous, and the results are still given as node-averaged quantities. Introducing the very fine mesh enables the code to account more accurately for differences in composition across the boundaries of the large hexagonal nodes and for the effects of the external boundary conditions. Intranodal structure is still ignored.

For accurate computation of neutron fluxes averaged over specified regions that can be much smaller than the nodes in the DIF3D nodal models, the MCNP models must be used. The MCNP models can also obtain global parameters like

k-effective more accurately than the DIF3D nodal models. MCNP is a three-dimensional, continuous-energy, coupled neutron-photon Monte Carlo transport code. In the MCNP models, the reactor is represented by combinatorial geometry in arbitrarily fine detail. Also, the cross sections are provided in a continuous-energy format, so that a multigroup treatment is not necessary. In the preliminary studies reported in Reference 6, MCNP was used to resolve fundamental questions about the neutronics implications of different fuel cladding materials, primary reflector materials, and fuel assembly spacings. It was shown in a study of a single module that stainless steel cladding imposes a severe reactivity penalty. However, safety considerations may justify further consideration of stainless steel (see Section 6). A single-module study of reflector materials showed that heavy water or beryllium reflectors would provide a substantial benefit in k-effective.

Although it was desired to develop models based on fuel plates with the same characteristics as in the ATR, there was no obvious choice for the fuel plate composition, because not all fuel plates in ATR are the same even in the same fuel assembly. The composition of the inner boron-free fuel plates in an existing ATR SCRABL¹¹ model¹² was used for all the fuel plates in the BATR diffusion models, and the composition of the fuel assemblies in an existing ATR MCNP model was used in the BATR Monte Carlo models. The ATR SCRABL model represents the fuel "meat" layers explicitly, whereas the ATR MCNP model represents the fuel, cladding, and coolant as a homogenized mixture. Because of their different origins, the BATR models that were developed from these two ATR models are not consistent with respect to the total U-235 masses in the reactors. Therefore, the U-235 concentrations were varied in both models to facilitate comparison of results.

3.1 DIF3D MODELS

Development of DIF3D neutron diffusion models for the two competing conventional reactor design configurations proceeded in two major phases: calculation of appropriate microscopic cross sections and establishment of node dimensions and isotope concentrations.

Generally, our procedure for the calculation of microscopic cross sections for a new reactor design begins with the use of the COMBINE code¹³ to reduce a 166-group cross section library based on the ENDF/B-5 data library¹⁴ down to a group structure suitable for use by a transport code such as SCRABL¹¹ in supercell calculations. In the supercell calculations, the cross section set is further reduced to a few-group structure appropriate for a diffusion code, and the cross sections can also be coalesced over specified spatial regions.

The usual procedure was followed for the heavy water in the BATR designs. The other materials in the BATR models were assumed to be identical to materials in the ATR. The cross sections were coalesced into a four-energy-group structure identical to that used for ATR analysis by the PDQ neutron diffusion code, and they were spatially coalesced over the individual nodes. The LIBTRAN utility code was used to transform the cross sections produced by SCRABL into the ISOTXS format required by DIF3D.

In the Modular-Hexagonal reactor, the corners of the DIF3D hexagonal nodes were located on the centerlines of the concentric fuel assemblies, and the centers of the nodes were located on the test loop centerlines. In the Multiple-Annular reactor, the same node dimensions were appropriate, because the loop designs and spacings were the same. However, in the Multiple-Annular design, the fuel assemblies do not lie on the corners of the hexagonal nodes.

The hexagonal nodes in the DIF3D models are assumed to be homogeneous. Therefore, material concentrations were found by computing the average number density or volume fraction (as appropriate for different materials) over the nodes, based on the concentrations used in the data from the ATR. Table 3 gives the concentrations for each of the DIF3D nodes.

Because the full-core models have hexagonal symmetry about the z-axis, sixth-core models (60-degree sectors) were used in DIF3D.

Table 3. Isotope Concentrations in DIF3D Nodes

Isotope	Multiple-Annular Nodes			Modular Hexagonal Nodes			Second Reflector Ring	First Reflector Ring	Second Reflector Ring
	Inner Core	Outer Core	First Reflector Ring	Inner Core	Middle Core	Outer Core			
U238 (a/b-cm)	1.08290E-05	7.49470E-06	--	4.35172E-06	4.35172E-06	1.81324E-06	--	--	--
U235 (a/b-cm)	1.60030E-04	1.10760E-06	--	6.43086E-05	6.43086E-05	2.67955E-05	--	--	--
B10 (a/b-cm)	0.0	0.0	--	0.0	0.0	0.0	--	--	--
U234 (a/b-cm)	1.08290E-06	7.49470E-07	--	4.35172E-07	4.35172E-07	1.81324E-07	--	--	--
U236 (a/b-cm)	5.15700E-07	3.56900E-07	--	2.07230E-07	2.07230E-07	8.63459E-07	--	--	--
H ₂ O (mol./b-cm)	8.79430E-03	5.23670E-03	--	6.74260E-03	5.26810E-03	2.14380E-03	--	--	--
A1-1100 (vf)	0.095846	0.043095	--	0.0772853	0.0351102	6.57410E-03	--	--	--
A1-6061 (vf)	0.11788	0.085708	--	0.0550807	0.0419196	0.0103377	--	--	--
SS-304 (vf)	0.14641	0.089771	--	0.0774940	0.0368244	0.0282523	--	--	--
D ₂ O (mol./b-cm)	1.20137E-02	2.02936E-02	3.28700E-02	0.0	0.0	1.22978E-02	3.28700E-02	3.28700E-02	3.28700E-02
Be9 (a/b-cm)	0.0	0.0	--	7.19910E-02	8.94250E-02	6.36210E-02	--	--	--

Note:

- 1) alloy concentrations are given in terms of volume fraction (vf); other constituent concentrations are given in atoms/barn-cm or molecules/barn-cm
- 2) cross sections were determined separately for each core node type. Reflector nodes use D₂O cross sections from outer core nodes.

Results from the DIF3D models are presented in Tables 4 and 5. Also, a footnote in Table 5 describes the energy group structure in the DIF3D models. The core nodalization patterns are shown in Figure 5. In the Multiple-Annular model, the inner core node contains the central loop and the fuel assemblies around it, while the outer core nodes contain the outer loops and the fuel assemblies around them. In the Modular-Hexagonal model, the fuel assemblies are located at the corners of the hexagonal nodes, so each fuel assembly is divided among three nodes. The inner core node includes the central test loop and the inner portions of the first ring of fuel assemblies. The middle core nodes include the outer test loops, the outer portions of the first ring of fuel assemblies, and the inner portions of the outer ring of fuel assemblies. The outer core nodes include the outer portions of the outer ring of fuel assemblies.

Discussion of the results is deferred to Section 3.3, along with a discussion of the results of the MCNP Monte Carlo code analysis.

For trade studies to be performed in the next phase of the BATR program, data-processing codes were written to automate the calculation of region-averaged material densities for input into SCRABL and DIF3D.

Table 4. DIF3D Multiplication Factors

<u>U-235 Loading (kg)</u>	<u>Multiple-Annular</u>	<u>Modular-Hexagonal</u>
42.4	--	1.1929 (nodal)
42.8	0.9678 (nodal)	--
47.8	--	1.2484 (nodal) 1.2470 (finite-difference)
51.1	1.0424 (nodal) 1.0430 (finite-difference)	1.2800 (nodal)

Table 5. DIF3D Fluxes

Flux Location and Group	Multiple-Annular	Modular-Hexagonal
inner core node	3.672×10^{14}	5.681×10^{14}
thermal flux	3.792×10^{14}	5.888×10^{14}
middle core node	--	5.344×10^{14}
thermal flux		5.316×10^{14}
outer core node	4.176×10^{14}	1.655×10^{14}
thermal flux	4.148×10^{14}	1.643×10^{14}
inner core node	5.550×10^{14}	3.424×10^{14}
epithermal flux	5.497×10^{14}	3.476×10^{14}
middle core node	--	2.544×10^{14}
epithermal flux		2.540×10^{14}
outer core node	3.343×10^{14}	7.433×10^{13}
epithermal flux	3.265×10^{14}	7.295×10^{13}
inner core node	4.998×10^{14}	2.908×10^{14}
suprathemal flux	4.885×10^{14}	2.950×10^{14}
middle core node	--	2.132×10^{14}
suprathemal flux		2.117×10^{14}
outer core node	2.543×10^{14}	4.993×10^{13}
suprathemal flux	2.481×10^{14}	4.979×10^{13}
inner core node	4.018×10^{14}	2.058×10^{14}
fast flux	3.921×10^{14}	2.089×10^{14}
middle core node	--	1.479×10^{14}
fast flux		1.462×10^{14}
outer core node	1.875×10^{14}	2.657×10^{13}
fast flux	1.829×10^{14}	2.688×10^{13}

Notes:

- 1) all fluxes are in units of $\text{cm}^{-2} \text{ s}^{-1}$
- 2) Thermal flux energy range: $0 < E_n < 0.532 \text{ eV}$
 Epithermal flux energy range: $0.532 \text{ eV} < E_n < 5.53 \text{ keV}$
 Suprathemal flux energy range: $5.53 \text{ keV} < E_n < 0.821 \text{ MeV}$
 Fast flux energy range: $0.821 \text{ MeV} < E_n < 16.9 \text{ MeV}$
- 3) Upper values are nodal results; lower values are finite-difference results
- 4) Total core power = 250 MW

Multiple-Annular

Modular-Hexagonal

Stainless steel pressure vessel
171.2 cm O.D.

H105-WKT-0592-04

Figure 5. Core nodalization in DIF3D models.

3.2 MCNP Models

The MCNP code uses a very general combinatorial geometry technique to permit the representation of complicated reactor systems in great detail. MCNP evaluates the neutron multiplication factor (k -effective) by following neutron life histories one at a time. Events in the life history of a neutron (birth, scattering, absorption, etc.) are randomly selected according to the appropriate probability distribution functions (e.g., the cross sections) for the events. A life history is followed until the neutron is absorbed or enters a region of zero importance (corresponding, for example, to leakage from a non-reentrant surface). The successive histories are bunched into "cycles" in which an attribute, such as track length between collisions, is compared with the same attribute from the preceding cycle. The ratio of the number of neutrons in successive cycles is the multiplication factor. To obtain good statistics, the total number of neutron histories has to be large enough to satisfy the law of large numbers, and the number of histories per cycle has to be large enough to permit a representative sampling of the whole reactor in each cycle.

The inclusion of great geometric detail can impose the need to track excessively large numbers of particle histories. Initially, three-dimensional full-core MCNP models of the Multiple-Annular and Modular-Hexagonal conventional reactor concepts were developed. A search on the MCNP statistics for the full-core Multiple-Annular model yielded optimal statistics for about 5000 neutron histories per cycle, with a minimum of 30 cycles. The optimum was determined from the statistical error size in the multiplication factor. Because the models have hexagonal symmetry about the z -axis, 60-degree sectors of the full-core models were adopted, just as for the DIF3D models. The same number of histories was used for the sixth-core models as for the full-core models. Thus, the sampling density in the sixth-core models is six times as great. In effect, the increase in sampling density is equivalent to repeating identically the first sampling of the full-core models five more times. Because of the identical repetition of the original sampling, the optimum found in the sampling of the full core does not apply, and the statistics in the sixth-core models are much better than in the full-core models for the

number of histories actually used. The resulting statistical errors in the sixth-core models are less than 0.2% in k-effective and less than 5% in the neutron fluxes, except for odd instances of errors up to 20% in the fluxes.

Material compositions were obtained from a previously existing MCNP full-core model of the ATR. Some additional compositions were introduced, such as heavy water at 300 K.

The hardware regions around the test loops, consisting of water, aluminum, stainless steel, and helium, are homogenized. In the beryllium reflector in the Modular-Hexagonal model, light water channels are homogenized with the beryllium in the same mix as in the ATR MCNP model. No control elements, followers, or specific targets are modelled.

The MCNP code uses continuous-energy cross sections from ENDF/B-V. In the BATR models, the cross sections are evaluated at 300 K. For some elements that occur in nature as mixtures of isotopes, the MCNP library material comprises the natural mixture. For elements or molecules of low atomic weight, such as beryllium or the hydrogen in water, a thermal scattering library is used at energies below approximately 4 eV. However, the fluxes are lumped into four energy groups in the results presented below.

Figures 6 and 7 give the midplane and elevation views of the MCNP models of the Multiple-Annular and Modular-Hexagonal reactors, respectively.

Table 6 gives the values of the multiplication factor for the sixth-core three-dimensional MCNP models of both designs for both of the U-235 fuel loading values that were considered. The multiplication factor varies less than 4% for a 20% change in U-235 loading. Therefore, k-effective is not very sensitive to the fuel loading for a fresh core. However, it is to be expected that the cycle length and the flux distribution during the cycle will be dependent on the total fuel loading and the spatial distribution of the fuel.

Because the models assume that all the fuel is fresh, the flux magnitudes are largely dependent on the power level instead of the uranium loading. Thus,

Figure 6a. Sixth-Core Three-Dimensional MCNP Model of the Multiple-Annular Reactor (Plan View).

Figure 6b. Sixth-core Three-Dimensional MCNP Model of the Multiple-Annular Reactor (Elevation View).

Figure 7a. Sixth-core three-dimensional MCNP model of the modular-hexagonal reactor (plan view).

Figure 7b. Sixth-core three-dimensional MCNP model of the modular-hexagonal reactor (elevation view).

Figures 8 and 9 show fluxes in four energy groups for only one fuel loading (42.805 kg U-235). The group structure in the MCNP models was taken from the MCNP ANS model¹⁵ and differs slightly from the DIF3D model; the differences have no practical significance. The energy group limits are identified in Table 7. Figure 8 displays the group fluxes in the central loop as functions of distance from the core midplane in the Multiple-Annular reactor, and Figure 9 shows the analogous results for the Modular-Hexagonal reactor. Table 7 presents some selected peak fluxes for both models.

Further discussion of the results is provided in Section 3.3 below, along with a discussion of the DIF3D results.

3.3 Discussion of Results

The values of k-effective predicted by the nodal and finite-difference versions of DIF3D are in very good agreement, as shown in Table 4. The DIF3D and MCNP values differ by amounts ranging from 3.5% to 7.6%. The DIF3D values of k-effective are about twice as sensitive to U-235 concentration as the MCNP values. The reasons for this difference in sensitivity are not understood.

Both the DIF3D and MCNP models show an adequate margin of excess reactivity to achieve criticality at startup. However, such features as beam tubes and cold neutron sources, which the actual reactor must have, will pull this margin down. Furthermore, it has not been shown that the current configurations can achieve an adequate cycle length (about 30 days).

The finite-difference and nodal DIF3D flux solutions in the core regions, shown in Table 5, agree within 2.5%, and often differ by less than 1%. The agreement in the outer reflector regions is not nearly as good. In fact, the nodal solution gives negative values for the two fastest neutron groups in the outermost reflector node in both models. However, in this node, the flux magnitudes are more than three orders of magnitude below their values in the central node, and the failure of the nodal solution in the outer node is of little consequence.

Table 6. MCNP Multiplication Factors for BATR and ATR

<u>Reactor</u>	<u>k-effective</u>	<u>U-235 loading (kg)</u>
ATR, Cycle 73 (with control)	1.0140	42.920
Multiple-Annular (no control)	1.1021	51.111
	1.0641	42.805
Modular-Hexagonal (no control)	1.1532	42.805
	1.1900	51.111

Except for the central test loop peak flux from MCNP, the flux values shown in Tables 5 and 7 do not satisfy the requirements established in Reference 6. Since the power densities in the fuel regions are comparable to those in the ATR, it is not surprising that the test loop fluxes are in the ATR regime and not substantially higher. However, one of the goals of the optimization studies must be to raise the fluxes. The DIF3D models will be used to search for ways to increase the average fluxes, and the MCNP models will be used to find ways to put the flux peaks where they are needed.

Because the MCNP flux values shown in Table 7 apply to local regions, it is hard to compare them with the DIF3D fluxes of Table 5 in a meaningful way.

H113-SNJ-0592-01

Figure 8. Axial profile of the four group flux values in the multiple-annular reactor central loop.

H113-SNJ-0592-02

Figure 9. Axial profile of the four group flux values in the modular-hexagonal reactor central loop.

Table 7. Peak MCNP Group Fluxes in Selected Locations

	$\frac{\phi_1}{(n/cm^2-s)}$	$\frac{\phi_2}{(n/cm^2-s)}$	$\frac{\phi_3}{(n/cm^2-s)}$	$\frac{\phi_4}{(n/cm^2-s)}$	Comments
Multiple-Annular				9.73×10^{14}	Peak thermal flux at core midplane outside central hole between 240 and 268 mm radius.
Modular-Hexagonal				NA	Blocked by primary reflector.
Multiple-Annular	2.44×10^{14}	3.83×10^{14}	4.62×10^{14}	6.65×10^{14}	Peak flux tallies in outer loops at core midplane, and in cylinder of 100 mm height and 20 mm diameter.
Modular-Hexagonal	2.84×10^{12}	7.10×10^{13}	1.51×10^{14}	2.76×10^{14}	Peak thermal flux outside outer modules/loops
Modular-Annular				2.23×10^{14}	
Modular-Hexagonal				1.44×10^{14}	Peak thermal flux in secondary reflector
Modular-Hexagonal		4.45×10^{14}			Peak group-2 flux in center of fueled hex modules: (inner modules)
		5.57×10^{14}			(middle modules)

Table 7. (Continued)

	$\frac{\phi_1}{(n/cm^2-s)}$	$\frac{\phi_2}{(n/cm^2-s)}$	$\frac{\phi_3}{(n/cm^2-s)}$	$\frac{\phi_4}{(n/cm^2-s)}$	Comments
Multiple-Annular	2.18×10^{14}	3.30×10^{14}	4.83×10^{14}	1.60×10^{15}	Peak fluxes in central test module
Modular-Hexagonal	3.87×10^{13}	7.40×10^{13}	1.20×10^{14}	3.98×10^{14}	
Neutron Group Energy Ranges:					
Group 1: 0.821 MeV - 17.0 MeV					
Group 2: 5.531 keV - 0.821 MeV					
Group 3: 0.625 eV - 5.531 keV					
Group 4: 0 - 0.625 eV					

4.0 THERMOHYDRAULICS STUDIES

4.1 Core Region

Table 8 presents a preliminary assessment of the BATR core cooling requirements. For purposes of comparison, a set of common core conditions was specified for ATR and the Multiple-Annular and Modular-Hexagonal BATR configurations. The common conditions shown in the table include core thermal power, inlet pressure, inlet fluid temperature, and the active-core light-water flow rate. The assumption of common mass flow rate was made to simplify the comparison process, since it results in the same core outlet fluid temperature for the three designs. In a more detailed trade-off study, variations in the core mass flow rate (and hence core flow velocity) would also be considered.

Geometrical data for ATR and the two proposed conventional BATR configurations are shown in Table 8. Fuel plate and coolant gap widths for all three designs are comparable, while the core heights for the BATR designs are only 82% of the ATR core height. The core flow area for the BATR Multiple-Annular configuration is 128% of the ATR core flow area and for the BATR Modular-Hexagonal configuration it is 119% of the ATR core flow area. As a result of the larger flow areas in BATR, the core coolant velocity decreases from 14.33 m/s in ATR to 11.19 m/s and 12.01 m/s, respectively, for the Multiple-Annular and Modular-Hexagonal BATR configurations. Fuel plate structural stability is therefore enhanced in BATR over that in ATR because of these decreased coolant velocities.

The core outlet pressure is defined by the core inlet pressure and the core differential pressure. The core differential pressure is proportional to core length, proportional to the 1.8th power of velocity, and inversely proportional to coolant channel fluid gap. These effects combine to determine the core outlet pressures shown in Table 8 for the BATR configurations. Core cooling during normal operation is dependent on avoiding steam production between the fuel plates that leads to a flow excursion, a phenomenon that becomes more likely as the fluid pressure and saturation temperature are

Table 8. Comparison of Core Thermohydraulic Parameters for Two BATR Configurations and ATR

<u>Parameter (Units)</u>	<u>ATR</u>	<u>BATR</u>	
		<u>Multiple Annular</u>	<u>Modular Hexagonal</u>
<u>Common Conditions:</u>			
Thermal Power (MW)	250	250	250
Core Inlet Pressure (MPa)	2.55	2.55	2.55
Inlet Fluid Temperature (K)	325	325	325
Core Mass Flow Rate (kg/s)	1614	1614	1614
Outlet Fluid Temperature (K)	362	362	362
<u>Geometrical Data:</u>			
Core Height (cm)	121.9	100.0	100.0
Coolant Gap (cm)	0.198	0.200	0.200
Plate Thickness (cm)	0.127	0.125	0.125
Core Flow Area (m ²)	0.114	0.146	0.136
Core Heat Transfer Area (m ²)	125.6	122.1	125.9
<u>Derived Conditions:</u>			
Core Flow Velocity, (m/s)	14.33	11.19	12.01
Core Outlet Pressure (MPa)	1.86	2.19	2.14
Outlet Saturation Temperature (K)	482	490	489
Outlet Fluid Subcooling (K)	120	128	127
Core Average Heat Flux (MW/m ²)	1.99	2.05	1.99
Core Power Density (MW/liter)	0.949	0.977	1.166

lowered. This discussion is based on an assumption that flow excursion phenomena will determine the minimum safety margins; however, phenomena involving departure from nucleate boiling (DNB) will also need to be considered in future work. Since the pressure is lowest at the core outlet, and since common core outlet fluid temperatures are assumed, comparisons of core outlet fluid subcooling provide one indication of the relative thermal safety margins for the three core designs. The average thermal margins of the two BATR configurations are therefore moderately higher than for ATR, primarily as a result of decreased BATR core differential pressures caused by lower coolant velocities and shorter cores.

Further work is also recommended to evaluate the possible use of fuel

nucleation enhancers to promote rapid negative reactivity insertion during reactivity-driven accidents. In this evaluation, the effects of such enhancers on flow-excursion safety margins must be considered. In general, further BATR studies are needed for flow excursion and DNB phenomena.

Through preferential fuel loading, the maximum-to-average heat flux ratio can be minimized for the ATR-type fuel element construction proposed for the Multiple-Annular BATR configuration. However, this minimization is not feasible for the concentric cylinder fuel elements proposed for the Modular-Hexagonal BATR configuration. This effect therefore provides an additional safety margin advantage to the Multiple-Annular configuration over the Modular-Hexagonal configuration (beyond the small one shown in Table 8). Further studies are needed on local thermohydraulic effects on BATR fuel. These studies should also consider the need for and the feasibility of symmetric delivery of emergency core coolant to the fuel channels during accidents.

The average core heat fluxes for the three designs are comparable; the difference between the two BATR configurations is caused primarily by the presence of side plates in the Multiple-Annular configuration but not in the Modular-Hexagonal configuration. The average core power densities for the three designs also are comparable.

Both BATR configurations feature upward flow of coolant through the core as opposed to the downward flow in ATR. The upward flow option has a safety advantage for events where pumping power is lost because a core flow stagnation is avoided during transition from forced to natural circulation cooling. As noted in Section 2.4, an inlet-side downcomer/lower-plenum arrangement should also be considered for its safety advantages.

4.2 Coolant Loops

A proposed coolant loop layout, appropriate for either BATR configuration, is shown in Figure 10. The layout shows one of three similar and independent coolant loops capable of delivering water from a common core outlet plenum to

a common core inlet plenum. A coolant loop piping diameter of about 0.5 m (20 in.) is envisioned, based on current ATR design. Additional study is needed to evaluate whether safety could be improved by limiting water-hammer potential through the use of larger-diameter pipes. The coolant loop design can greatly affect the overall safety of BATR. Accordingly, reliable delivery of flow through the core and minimized depressurization of the fluid within the core are key objectives of the design. Employing multiple loops provides redundancy and reduces the sizes of pipes, whose rupture must be planned for and accommodated.

Large-volume core inlet and outlet plena appear to be advantageous for safety because they buffer the core region fluid from depressurization events initiated in external piping. This buffering approach is carried further with gas-charged accumulators connected to the plena, and flow limiting devices (such as orifices, flow diodes, or venturis) at the loop/plenum connections. The accumulators add compressibility to the fluid system that lowers the system depressurization rate during accidents. Locating the accumulators on the core plena assures availability of that compressibility for limiting depressurization of the fluid within the core, regardless of the location of a rupture in the system boundary. An accumulator design is anticipated where the gas bubble expansion is planned for in such a way that gas flow into the primary coolant cannot occur. Primary system pressure control will be accomplished via the accumulator gas pressure control systems. Further study is needed on the operational and safety aspects of gas control systems. From the perspective of the coolant within the core, the flow limiting devices effectively reduce the apparent size of ruptures occurring in external piping. However including these devices in the design increases the coolant loop pumping power requirements.

Each coolant loop (one is shown in Figure 10) consists of loop isolation valves, a main heat exchanger, an emergency heat exchanger, a main coolant pump, and associated piping.

The isolation valves allow removal of one loop from service for maintenance, and have the potential to terminate accidents (in the long term), for

H104-CDF-0492-01

Figure 10. One independent coolant loop in the conventional BATR designs.

situations where the source of a coolant loss can be identified. Furthermore, a means of preventing or limiting backflow through a loop with a disabled pump will be needed. This backflow would occur at the expense of flow delivered through the core. Figure 10 shows flow limiters providing this function; however, further study is needed to determine if check valves are a better choice. The reliability implications of the isolation valves are being considered in the Probabilistic Risk Assessment (PRA).

The main and emergency heat exchangers will be elevated, relative to the core, to ensure an adequate core flow during natural circulation. The main heat exchangers are of shell-and-tube design; the secondary systems feature AC-motor powered pumps and a cooling tower. The emergency heat exchangers also are of shell-and-tube design; however, their secondary systems feature an open-loop natural circulation heat removal to a water pool whose inventory may be replenished. Water from the bottom of this pool is drawn into the emergency heat exchanger where it is heated and returned through a tall chimney to the top of the pool. The secondary flow is driven by buoyancy forces created by the density difference between fluid in the water pool and that in the chimney. This system is advantageous in that long-term decay heat removal is assured with no active components.

The main coolant pumps will be powered by AC motors during normal operation. DC pony motors powered by station batteries, on the same shaft as the AC motors, will be employed to provide a source of forced circulation through the core that is independent of AC power. Core flow requirements are met by the AC motors during normal operation, by the coastdown of the AC motors during the process of tripping the reactors, by the DC motors for perhaps an hour following scram, and by loop natural circulation thereafter.

A preliminary layout of a core coolant cleanup system is shown in Figure 10. Fluid is withdrawn via a letdown valve from one or more hot legs, processed through the cleanup system, and returned via a makeup pump to the core inlet plenum. Provision is made to use the makeup pump for emergency core coolant injection during loss-of-coolant accidents. Where feasible, coolant loop piping will be immersed in a light water pool or in compartments that would

rapidly flood should a pipe rupture occur there. This arrangement would minimize the volume requirements for external core coolant tanks. The combination of elevated water pools and external tanks (that may be drained by gravity) will be sufficient to assure complete coverage of both the core and the heat exchanger regions. Thus, for a break at any location in the coolant system, the loop would remain liquid-filled and natural circulation would not be interrupted.

A heavy-water moderator tank cooling system will be needed to remove the high heat load from the fluid and structures in the tank. Figure 10 shows an external coolant loop, heat exchanger, and pump for this function. However, simpler and safer in-tank heat exchangers may be feasible. In either case, a tritium cleanup system will be needed for the moderator tank coolant.

5.0 SAFETY CONSIDERATIONS

The safety requirements applicable to the design studies for the BATR project are outlined in Reference 6. In this year's design studies of the Multiple-Annular and Modular-Hexagonal concepts selected for development as baseline designs, safety considerations were given major importance. Safety played a central role in the preliminary selection of key features of the reactor cooling system and in comparisons of the principal candidate fuel element cladding materials. A Probabilistic Risk Assessment (PRA) effort on BATR design is being undertaken in the second half of FY 1992.

Features of the baseline reactor cooling systems that were strongly influenced by safety considerations are identified below. Further discussions on these features appear in Section 4.

- a. Upward flow through the reactor core.
- b. Main and emergency heat exchangers elevated above the core to promote natural convection core cooling.
- c. Multiple coolant loops and pipes.
- d. Large-volume core inlet and outlet plena.
- e. Gas-charged accumulators.
- f. Flow-limiting devices at inlet plenum inlet and outlet plenum outlet.
- g. Location of reactor pressure vessel(s) and D₂O moderator tank in a light water pool.

Selection of fuel cladding material has very important impacts on safety. For the Multiple-Annular and Modular-Hexagonal concepts, the applicable choices are aluminum, zirconium, and stainless steel. Reference 6 provides analytical

results indicating that the time required for fuel plate melting in the event of cooling loss is significantly longer (e.g., more than twice as long at power densities in the range of 1-2 MW/L) for zirconium or stainless steel cladding than for aluminum. However, results summarized in Section 6 indicate that the severity of potential steam explosions in events with molten fuel in water may be significantly less when the fuel is clad with aluminum than when it is clad with zirconium or stainless steel. Because of the importance of these issues to safety, studies of cladding material selection will continue; such studies will be included in the PRA.

6.0 POTENTIAL FOR STEAM EXPLOSIONS

When contact occurs between a hot liquid (usually a molten material) and a cooler volatile liquid (usually a coolant), the energy transfer between the molten material and the coolant may suddenly become so rapid and coherent that an explosion results. Such an explosion is called a vapor explosion, or a steam explosion when water is used as the coolant. The terms steam and vapor will be used interchangeably in this discussion.

The phenomenon of vapor explosion in conjunction with nuclear reactors has been studied for the past three decades. During that period, most of the effort was focused on vapor explosions in liquid metal fast breeder reactors and light water commercial reactors. However, after the Chernobyl accident much of the vapor explosion research effort was redirected at evaluating vapor explosion potential in reactors that use metal fuels, such as the ATR. One reason for this shift is that most of the vapor explosion events that have occurred in nuclear reactors have occurred in reactors fueled with metal fuel, such as SL-1¹⁶ and SPERT.¹⁷ Since BATR may use metal fuel, the potential for an energetic steam explosion must be considered.

This discussion presents the results of a study conducted to evaluate the differences in steam explosion energetics for the conventional plate-fueled BATR concepts. This preliminary evaluation of steam explosion energetics will be used as part of the data base to help make the fuel plate selection for the BATR design. Three fuel plate compositions were advanced for BATR in Reference 6: uranium aluminide particles dispersed in aluminum surrounded by aluminum cladding, UO₂ dispersed in austenitic stainless steel surrounded by a compatible stainless steel cladding, and a zirconium-clad fuel plate. The fuel form of the zirconium-clad plate was not specified.

6.1 Description of the Thermodynamic Model

By means of experimental observations it has been determined over the years that a well-defined sequence of events is required before a vapor explosion

can occur. These events have been defined as premixing, triggering, propagation, and expansion.

During the premixing stage, the molten material and coolant must become coarsely mixed because of density and velocity differences between the two materials. The molten material initially consists of millimeter-sized particles surrounded by thin layers of steam. That is, the particles are in film boiling, which yields little heat transfer between the hot particles and the coolant. This slow heat transfer provides sufficient time for a significant amount of the hot material to contact the liquid coolant before the initiation of an explosion; thus, a large-scale energetic event can occur instead of many small-scale incoherent explosions.

During the triggering phase, destabilization of the vapor film occurs, resulting in fuel fragmentation into micron-sized particles. Fragmentation causes the surface area of the fuel to increase by several orders of magnitude, producing rapid heat transfer to the coolant. The rapid heat transfer causes explosive vapor formation and generation of locally high pressures. A pressure pulse then propagates through the mixing zone, causing additional fragmentation to occur.

As more and more energy is added to the coolant, the pressure pulse steepens to form a shock wave, which is then propagated throughout the reactor system, causing structural damage to the reactor. The high pressure vapor can also expand against the surrounding liquid coolant. This expansion imparts kinetic energy to the surrounding coolant, which in turn can also cause structural damage to the reactor.

At the present time there are two basic approaches used to model vapor explosions. The first approach is a mechanistic one, in which the various events described above are modeled in detail.¹⁸ This method is expensive in both model development time and computer requirements. The second approach applies a thermodynamic model that was first proposed by Hicks and Menzies¹⁹. The advantage of this model is that a detailed description of the vapor

explosion process does not have to be specified. Although the model does not provide a detailed pressure history for the vessel wall, which would be needed to determine whether the vessel would fail, it does yield an upper bound on the theoretical work that can be generated from a vapor explosion. The value of the work calculated from this model is usually much higher than any value measured from the many experiments that have been run to date. However, this approach does provide a means of comparing the severity of vapor explosions produced by the melting of different fuel plate materials. The Hicks-Menzies model was used to evaluate the explosion potential of the three plate materials being considered for BATR.

Two processes are included in the thermodynamic model. These processes are depicted in the P-V diagram presented in Figure 11. In the first process, x kg of molten fuel and y kg of coolant are mixed adiabatically at constant volume and allowed to come to thermodynamic equilibrium. For this process, a simple energy balance results in an equilibrium temperature for the closed system. Using this equilibrium temperature in conjunction with the steam tables, we calculate a corresponding maximum system pressure. The second process is an isentropic expansion from the maximum system pressure to a final system pressure. The work done during this expansion process is determined using the first law of thermodynamics.

When a metallic fuel interacts with water, chemical energy can be released to the system. Past vapor explosion studies have neglected the energy contributed by a chemical reaction between the metallic fuel and the water because this energy was thought to be small compared to the thermal energy released from the fuel. Recent undocumented experimental studies performed at Sandia National Laboratory on aluminum-water steam explosions have indicated that ignition of the molten metallic fuel may have occurred in some of the experiments at some yet-unknown critical fuel temperature. For this reason, results are presented below for the case without fuel ignition and for the case with the ignition of some percentage of the fuel.

The fuel plates considered in this analysis are composed of a central "meat" layer sandwiched by metal cladding. A large percentage of the central meat

PROCESSES FOR HICKS-MENZIES FCI MODEL PRESSURE VOLUME DIAGRAM

Figure 11.

section is also composed of the same material used for the cladding. Thus, for this study, we assume that the entire fuel plate is composed of cladding material and neglect the effects that the uranium or UO_2 in the meat may have on the maximum work generated in the vapor explosion. We believe that the effect of neglecting the uranium will be small; however, experiments have not been performed to confirm this assumption.

The three cladding materials considered in this study are aluminum, stainless steel, and zirconium. Table 9 contains the important thermodynamic properties used for these materials.

6.2 Results of Calculations

Results obtained by applying the thermodynamic model are presented in Figure 12 for the case with no fuel ignition. Analogous results are presented in Figure 13 for the case with 20% fuel ignition.

First we will consider the no-ignition case presented in Figure 12. For this case it was assumed that the aluminum, stainless steel, and zirconium cladding were each 200 K above their respective melting temperatures (see Table 9) when they contacted the coolant. The choice of 200 K is strictly arbitrary since there are presently no severe accident analyses for the BATR design. However, preliminary molten fuel analyses for the ATR, which uses aluminum-clad fuel, indicate that the maximum temperature of the fuel as it leaves the core and first contacts the coolant will be approximately 200 K above the melting temperature. This does not mean that the fuel will not be hotter than 200 K above melting at some later time in the accident sequence. Since we are interested in differences in the vapor explosion work generated by the three cladding materials, and not in absolute values, a choice of 200 K fuel superheat is acceptable for making comparisons. Furthermore, we have assumed that the coolant temperature is 323 K (subcooled by 50 K, based on the saturation temperature at an initial system pressure of 0.101 MPa), and we

Work Per Unit Fuel Volume

Function of Coolant to Fuel Volume Ratio

Figure 12.

Work Per Unit Fuel Volume Function of Coolant to Fuel Volume Ratio

Figure 13.

Table 9. Properties of Cladding Materials Considered for Conventional BATR Designs

<u>Material</u>	<u>Melting Temperature (K)</u>	<u>Density (kg/m³)</u>	<u>Specific Heat (K/kg-K)</u>	<u>Chemical Energy of Oxidation (J/kg)</u>
Aluminum	933	2700	1090	17481
Stainless Steel	1700	7055	558	595
Zirconium	2123	6184	356	6513

have also assumed that the initial coolant void fraction is zero. Varying these parameters will only affect the absolute magnitude of the results and not their relative position.

Figure 12 displays the work per unit volume of fuel as a function of the volume ratio of coolant to molten fuel for the three candidate cladding materials. The coolant-to-fuel volume ratio is one of the more important parameters associated with vapor explosion energetics. It is also one of the least measurable or calculable parameters; thus, we have computed energy release as a function of this variable. Aluminum cladding clearly has an advantage from a maximum-work standpoint over the entire range of coolant-to-fuel volume ratio considered. Stainless steel appears to be the least desirable material from an energetic standpoint for the case with no ignition.

Next we consider the case in which 20% of the cladding material is oxidized: chemical energy from oxidizing 20% of the fuel is added to the thermal energy initially contained in the fuel. Stainless steel now yields the lowest calculated work and aluminum yields the highest work, as shown in Figure 13. The reason for the reversal is the high chemical energy release per unit volume for aluminum (47200 MJ/m³) compared to stainless steel (4200 MJ/m³). For oxidation fractions larger than 20%, the values of the work generated by the three materials will retain the same order. As oxidation fraction

increases from zero, the order will change from that shown in Figure 12 to that shown in Figure 13; the crossover points have not been found.

6.3 Summary of Findings

This study has focused on the energetics of vapor explosions. If a vapor explosion occurs, the energy release depends on whether or not the explosion involves the ignition of a substantial portion of the cladding. If substantial cladding ignition occurs, the least energy is released when the fuel is clad by stainless steel. On the other hand, if little cladding ignition occurs, the least energy is released when the fuel is aluminum-clad. These results are based on the assumption that the cladding temperature in each case reaches 200 K above the melting point at the moment of dispersion in the coolant.

However, total risk depends on the product of event probability and event consequence. This study has not addressed the relative probability of fuel melting for the three different cladding materials. Such issues will be confronted in a Probabilistic Risk Assessment planned for future work.

Research on ignition of aluminum material in conjunction with vapor explosions is now in progress at several universities and national laboratories in this country. No definitive results have yet been published. Preliminary results indicate that a critical aluminum temperature of 1373 K or greater is needed before ignition of the molten aluminum material will occur. If aluminum cladding is chosen for BATR because of considerations other than steam explosion energetics, the design should include features that eliminate the possibility of fuel temperatures above the critical value in severe accident sequences.

7.0 THE MOLTEN CHLORIDE REACTOR - AN ALTERNATE CONCEPT

Although conventional metal-plate-fueled, water-cooled reactor concepts were selected for the baseline design configurations, other reactor concepts have features that make them worth considering for a new test reactor. One concept that has some very appealing advantages for application to a BATR design is the Molten Chloride Fast Reactor (MCFR); the MCFR concept is described in this section, and its advantages and disadvantages are noted. Chief among its liabilities is the very large amount of development work that would be required before an MCFR could be built for use as a workhorse test reactor.

The central unique feature of an MCFR is its use of molten fuel in the form of a peritectic mixture of fuel and carrier salts. Peritectic mixtures melt at a much lower temperature than either of the pure constituents. A combination of UCl_3 or PuCl_3 fuel and NaCl carrier salt could have a melting point below 1000 K, so that a temperature rise on the order of 300 K could be allowed in the core without reaching excessive temperatures. The fuel would flow into the core region, where it would enter a critical configuration, and flow out after heating up during its transit time through the core. While out of the core, it would not be in a geometric arrangement that could permit criticality. The fuel would in effect act as its own cooling fluid, passing through a heat exchanger for heat removal.

Waste removal and fuel replenishment would be part of the fuel circulation loop, so that these processes would take place continuously, while the reactor operates. This feature would permit very long operating cycles and minimize downtime. Also, continuous refueling would allow the reactor to compensate for burnup by operating with relatively low excess reactivity.

Molten fuel obviates the need for complicated fuel assemblies and associated structures. The absence of fuel cladding would improve the neutron economy. Control can be achieved without control rods by varying the flow rate and salt composition. Thus, the MCFR is a structurally very simple and uncluttered reactor.

A very strong negative temperature coefficient provides a high level of operational safety. The fuel is already molten, so that meltdowns are meaningless; boiling can be avoided by simple design features, such as draining fuel to a tank in which criticality could not occur, and in which natural convection could cool the fuel adequately.

Use of chlorides would lead to a very fast neutron spectrum, which would allow higher neutron fluxes than a thermal reactor at the same power, because the fission cross section at high energies is lower than at thermal energy. Neutron flux traps (consisting of appropriate moderators) could be placed around test loops to tailor the spectra in the loops to meet changing experimental needs.

Molten salts would not require high-pressure containment, so that the structural demands on the containment system would be greatly reduced.

Against the attractive qualities discussed above, the MCFR has several significant disadvantages.

Because the fuel itself flows from the core into the coolant loop and fuel processing system, there is a substantial fuel inventory in the plant but outside of the core. This fuel contains fission products, so it is highly radioactive and must be contained in the piping, heat exchangers, and processing system with a very high standard of leak tightness. Radiation shielding will have to be provided in many areas where conventional plants experience negligible radiation. Also, maintenance workers will be exposed to more radiation than in a conventional plant. However, continuous reprocessing of the fuel is expected to reduce the fission product inventory in the fuel by two orders of magnitude relative to conventional solid-fuel reactors.

Molten salt has poor heat transfer characteristics compared with water or liquid sodium. To keep it in the molten state, some portions of the flow path outside the primary loop may need to be heated externally (for example, on the downstream side of the reprocessing system).

Corrosion from radiolytic decomposition of chlorides, from free chlorine generation caused by the breakup of fuel molecules during fission, and from various chemical reactions, limits the choice of structural materials and imposes a substantial development need. The fuel processing plant also requires much development. Only a few molten salt reactors have ever been built, so many unknown problems may arise in the development of a large operational MCFR.

The development needs are the principal factor in the decision to keep the MCFR in its status as an alternate concept. The MCFR will be reconsidered if the conventional designs fail to evolve to a stage where they can confidently be expected to meet the design goals for BATR in a cost-effective way.

8.0 COST REDUCTION STRATEGIES

This section presents the findings and recommendations of a search for ways to reduce the operating costs of BATR. Information about the Advanced Test Reactor (ATR) was used to define a baseline for the costs of test reactor operations. Organizational structures, functional relationships, and interactions were studied. Costs were examined for three aspects of ATR operations: the Naval Reactors program, New Production Reactor (NPR) experiments, and reactor shutdown. Findings are presented first for cost elements associated with the Naval Reactors program, in descending order of their costs. Findings for reactor shutdown and NPR experiments follow.

The FY-90 Naval Reactors operations budget for ATR was assessed to identify areas of potential operational cost savings for BATR. The functional areas of Operations, Experiments, Site Office, Engineering, Maintenance, Safety, and Training were considered. Although no separate cost accounting for Waste Management, Compliance, or Security was available, these topics are discussed briefly. Importantly, the cost assessment below does not include the significant escalation in costs in the last two years resulting from compliance-related activities. These activities are becoming a major cost driver and should be thoroughly examined for possible efficiency improvements.

8.1 Naval Reactors Program

8.1.1 Reactor Operations

The cost of ATR operations for crew and support was 29% of the FY-90 Naval Reactors portion of the budget. The general category of operational costs includes specific elements for reactor operations, as well as reactor staff support, water and chemical analysis, reactor fuel burnup, ATR special process spares, and performance oversight.

ATR operates with five crews to support continuous operation over cycles that typically last three to six weeks. ATR previously operated with 4 crews, but a fifth crew was added to cover training time. Each crew consists of 14

people, so the total number of crew members is 70, out of a total ATR staff of 420. Thus, one out of every six ATR staff members is an operating crew member.

The number of required reactor operators for BATR could be reduced by having one common control room for the reactor and loops and by automating as much of the facility as possible. Reducing the number of operators would directly reduce the number of people required to support them with training, compliance, and administrative services.

Minimizing outage time and operating in longer cycles would result in an overall higher availability. Automatic refueling schemes could reduce labor requirements. On-line experiment changes and on-line refueling would help reduce outage time. Serving multiple customers, however, may lead to longer outages, because outage time is primarily controlled by experiment changes.

Integrated control room duties could reduce personnel requirements. Surveillance could be done by remote sensing using computers and robots. An electronic checklist for startup items could speed up the process. The use of fast-response fuel would allow quicker start-ups. If BATR can avoid the need for pre-filming fuel elements, the costs of this procedure can be eliminated.

8.1.2 ATR Experiments

The cost of ATR experiments was 20% of the Naval Reactors budget. This general cost element includes specific support for the experiments, as well as for loop safety and data, administration, and loop engineering. Costs for BATR could be reduced by locating hot cells and experiment setup facilities together on one site, which would improve handling of the experiments and reduce the number of moves required.

8.1.3 Site Office

The cost to operate the ATR site director's office was 19% of the Naval Reactors budget. This cost element includes plant support, document control,

probabilistic risk assessment, Reactivity Insertion Accident (RIA) analysis, safety reviews and response, code development, safety issue resolution, symptom-based procedures, and document process upgrades. A reduction in the number of operations personnel through automating and streamlining functions may have a multiplicative effect on reduction of required support personnel.

8.1.4 Engineering Support

Engineering support costs at ATR were 11% of the Naval Reactors budget. This cost element includes mechanical and I&E (Instrumentation and Electrical) reactor modifications, upgrades, systems support, capital projects, and fuel support. The number of compliance-related upgrades can be minimized by designing and building the safest reactor possible. This should have a direct bearing on reducing the number of support staff.

8.1.5 Reactor Maintenance

Reactor maintenance costs at ATR were 9% of the Naval Reactors budget. This cost element includes preventive, corrective, and operational maintenance for ATR and also for ATRC (the ATR critical facility). As many maintenance items as practicable, such as recalibration of instruments, should be automated. Reliability-centered maintenance, signature analysis, automated predictive maintenance, and on-line expert diagnostics should be used. An extensive spare parts system should be implemented and standard off-the-shelf items should be used where possible. The number of pumps and valves should be minimized, and they should be located in areas accessible for reactor-on-line maintenance. Extra room for robot operation, especially in hot cell areas, should be provided. Robots should be used wherever practicable.

Advances in numerical simulation capabilities over the next 15 years should allow inexpensive and accurate predictions of reactor performance and behavioral parameters for proposed test configurations, and thus may eliminate the need for a critical facility.

8.1.6 Reactor Safety

Safety operations costs at ATR were 7% of the Naval Reactors budget. This cost element includes the core safety assurance program, probabilistic risk assessment, RIA analysis, nuclear performance improvement, thermohydraulic code development and validation, symptom-based procedures, and document and process upgrades. Significant duplication of functions appears to exist between this cost element and the site office. Reducing the required number of operations and support personnel should result in a lower required safety budget without any reduction in the level of safety.

8.1.7 Reactor Training

Reactor training costs at ATR were 5% of the Naval Reactors budget. This item does not include the costs of training for support personnel. Reducing the required number of operations and support personnel should directly reduce the training costs.

8.1.8 Waste Management

No ATR cost data for waste management were available. However, reducing the number of penetrations into the BATR heavy water tank will reduce the potential for accidental spillage of tritium and result in cost avoidance.

8.1.9 Compliance

No ATR cost data for compliance activities were available. However, automation should aid in minimizing compliance-related costs. Experience at CANDU reactors shows that automation improves safety and reduces compliance costs. Configuration management needs to be implemented and maintained throughout the life of the reactor. Compliance-associated costs are believed to be a significant portion of cost of operations. Every effort should be made to address these requirements effectively and efficiently.

8.1.10 Security

No separate ATR cost data for security were available. However, security costs could be reduced by minimizing the number of customers, especially foreign customers, that must be located on site. Costs associated with guarding fuel can be reduced by using low-enrichment fuel; however, low-enrichment fuel would seriously degrade reactor performance. Building support facilities outside the reactor-site fence will have to be balanced with the needs of fuel/experiment transfers and close communications.

8.2 Shutdown Time

The current prorated cost of shutdown time for ATR is about 23% of the ATR budget. Clearly, reducing this time will increase utilization and drive down operating costs.

8.3 NPR Experiments

The recent budget for New Production Reactor experiments was about 20% of the overall ATR budget. The NPR Department covered a portion of the experiment-related shutdown costs. In the absence of this program, portions of this cost would have been absorbed in the overall cost of ATR operations.

9.0 RECOMMENDATIONS FOR FURTHER STUDY

Work to be performed in the remainder of FY 1992 has been planned and funded. This work includes the tasks summarized below.

1. Neutronics - preliminary trade-off and proof-of-principle studies. The Multiple-Annular and Modular-Hexagonal designs will be refined to obtain configurations that meet the goals for neutron flux and irradiation volume.
2. Thermohydraulics - companion studies to those in the neutronics area. Topics to be assessed include core length, pressure drop, flow distribution, and thermal margins.
3. Probabilistic Risk Assessment (PRA) - compilation of insights from DOE reactor PRAs, definition of preliminary risk allocation scheme, identification of PRA developmental areas, and design assistance.
4. Full-Core Neutronics Models - extension of MCNP models of the Multiple-Annular and Modular-Hexagonal reactors to the full reactor cores instead of the sixth-core sector.
5. Utility Code for Isotope Production - development of a code to automate data transfer between MCNP and ORIGEN, the code that will be used to compute the changing isotope concentrations during BATR operation. The capability provided by this utility code can be used to analyze both isotope production in targets and fuel isotope depletion during operating cycles.
6. Isotope Production Studies - assessment of the capability of the Multiple-Annular and Modular-Hexagonal reactors to produce isotopes such as plutonium-238, using the utility code discussed above.

Work performed in the near-term future after FY 1992, and especially in FY 1993, should be focused on seeking ways to expand the capability of BATR to

meet potential users' needs, including the anticipated requirements established as goals in the FY 1991 study (cf. Reference 6). This objective can best be fulfilled by adopting the tactics discussed in the following paragraphs.

Potential users should be surveyed for their perspective on the capabilities BATR should offer them. Where appropriate, design goals for BATR should be modified to incorporate new features recommended by these potential users.

The neutronics models of the Multiple-Annular and Modular-Hexagonal conventional BATR concepts should be refined to incorporate such features as beam tubes and cold sources, which offer the kind of flexible use that BATR was conceived to provide. Studies should be performed to clarify the capabilities and limitations of these conventional concepts, and to increase the variety of the options that can be made available in them. For example, studies should be made to assess the feasibility of on-line refueling and experiment changes. Zirconium and stainless steel should be studied further as alternative cladding materials. Steady-state thermohydraulics studies should be performed to complement these neutronics studies.

Isotope production studies should be continued beyond what is planned for FY 1992, in order to determine the capability of BATR to produce isotopes for a variety of customers, including the medical industry. Additional capability to model isotope production should be developed where needed.

Innovative advanced concepts, such as the Molten Chloride Fast Reactor and gas-cooled reactors, should be examined for their potential to offer reactors that could perform better than the conventional concepts. An accelerator-driven spallation neutron source should be assessed for its suitability for the BATR missions.

Studies should be performed to seek ways to minimize waste production and other environmental impacts, and to improve safety. The PRA work should be extended to Level 2 and 3 issues (e.g., molten fuel interactions with coolant, steam explosion potential, hydrogen generation, and containment/confinement

design and performance). It should be noted that the desired neutron flux levels sought for the BATR, in excess of 10^{15} neutrons/cm²-s, impose very severe demands on safety systems. Passive safety, which is considered to be imperative for any new utility-owned nuclear power reactor, is probably impossible to achieve with a reactor operating at the fluxes desired for BATR; therefore, extremely reliable active safety features must be included in the BATR design. Design features should be developed to limit depressurization and maintain core coolant flow during accident scenarios, and to preclude pressure vessel drainage in a cold-leg break.

Further efforts should be made to find ways to reduce costs, especially operating costs. One option that should be considered is to generate electric power during BATR operation. If on-line refueling and experiment changes are practical for some sequences of experiments, BATR may be available with sufficient continuity to interest utilities in buying power from it.

A preliminary balance-of-plant/facility layout should be created, reflecting such possible options as electric power generation.

A program should be undertaken to acquire or develop analytical techniques that could contribute to the BATR design. One such technique that is already being developed is the utility code for data transfer between MCNP and ORIGEN. Another need is to obtain flux reconstruction methods for the calculation of local fluxes and reaction rates from DIF3D nodal solutions. Such methods were being developed for the New Production Reactor before NPR funding was reduced.

10.0 REFERENCES

1. U. S. Department of Energy, Advanced Test Reactor, BL-297-0987-R1-.5M-T, undated.
2. "FFTF Final Safety Analysis Report," HEDL-TI-75001, Hanford Engineering Development Laboratory, December 1975.
3. S. Shapiro, D. C. Rorer, and H. Kuper, HFBR Handbook, BNL-24182, Brookhaven National Laboratory, August 1983.
4. F. T. Binford and E. N. Cramer, The High-Flux Isotope Reactor, A Functional Description, Volumes 1 & 2, ORNL-3572, Oak Ridge National Laboratory, May 1964.
5. J. M. Ryskamp, D. L. Selby, and R. T. Primm III, "Reactor Design of the Advanced Neutron Source," Nucl. Tech. 93, 1991, pp 330-349.
6. J. M. Ryskamp, et al., "Safety Requirements, Facility User Needs, and Reactor Concepts for a New Broad Application Test Reactor," EGG-NRRT-10332, Idaho National Engineering Laboratory, 1992.
7. R. D. Lawrence, "The DIF3D Nodal Neutronics Option for Two- and Three-Dimensional Diffusion Theory Calculations in Hexagonal Geometry," ANL-83-1, Argonne National Laboratory, March 1983.
8. K. L. Derstine, "DIF3D: A Code to Solve One-, Two-, and Three-Dimensional Finite-Difference Diffusion Theory Problems," ANL-82-64, Argonne National Laboratory, April 1984.
9. Judith F. Briesmeister, et al., "MCNP - A General Monte Carlo Code for Neutron and Photon Transport," LA-7396-M, Rev. 2, Los Alamos National Laboratory, September 1986.
10. C. J. Pfeifer, "PDQ-7 Reference Manual II," WAPD-TM-947(L), Bettis Atomic Power Laboratory, February 1971.
11. J. L. Judd, "SCRABL-5 - An ENDF/B Version 5 Computer Code for Cross Section Collapsing," EGG-NE-9904, Idaho National Engineering Laboratory, September 1991.
12. J. L. Judd and W. K. Terry, "RELAP5 Kinetics Model Development for the Advanced Test Reactor," Proc. Intl. Topical Meeting on Advances in Mathematics, Computations, and Reactor Physics, Vol. 4, pp. 18.2 1-1 to 18.2 1-20, April 28 - May 2, 1991, Pittsburgh, PA, American Nuclear Society (April 1991).

13. Robert A. Grimesey, David W. Nigg, and Richard L. Curtis, "COMBINE/PC - A Portable ENDF/B Version 5 Neutron Spectrum and Cross-Section Generation Program," EGG-2589, Idaho National Engineering Laboratory, April 1990.
14. R. Kinsey, "Data Formats and Procedures for the Evaluated Nuclear Data File ENDF," BNL-NCS-50496, Brookhaven National Laboratory, 1979.
15. E. L. Redmond and J. M. Ryskamp, "Monte Carlo Methods, Models, and Applications to the Advanced Neutron Source," Nucl. Tech. 95, pp. 272-286, 1991.
16. SL-1 Project, "Final Report of SL-1 Recovery Operation," TM62-7-704, IDO-19311, July 1962.
17. R. W. Miller, A. Sola, and R. K. McCardell, "Report of the SPERT-1 Destructive Test Program on an Aluminum, Plate-Type Water-Moderated Reactor," IDO-16883, Phillips Petroleum Co., Atomic Energy Division, Idaho Falls, ID, June 1964.
18. R. L. Moore, ATR RIA Hypothetical Vapor Explosion Assessment (Demonstration Calculation)," EGG-NE-9098, Idaho National Engineering Laboratory, December 1990.
19. E. P. Hicks and D. C. Menzies, "Theoretical Study on the Fast Reactor Maximum Accidents," Proc. Conf. on Safety, Fuels, and Core Design in Large Fast Power Reactors, ANL-7120, Argonne National Laboratory, October 1965.

END

**DATE
FILMED**

1 / 11 / 93