Index to
NUCLEAR SAFETY
A Technical Progress Review
by
Chronology, Permuted Title, and Author
Vol. 11 (1) through Vol. 18 (6)

Prepared for the U.S. Nuclear Regulatory Commission
Office of Nuclear Regulatory Research
Under Interagency Agreements DOE 40-551-75 and 40-552-75

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

NUCLEAR SAFETY INFORMATION CENTER

NSIC

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ORNL/NUREG/NSIC-147
(Revision to ORNL/NUREG/NSIC-133)
Dist. Category R1

Contract No. W-7405-eng-26

Nuclear Safety Information Center

INDEX TO
NUCLEAR SAFETY
A TECHNICAL PROGRESS REVIEW
BY
CHRONOLOGY, PERMUTED TITLE, AND AUTHOR
VOL. 11(1) THROUGH VOL. 18(6)

Wm. B. Cottrell
Engineering Technology Division
Ann Klein
Information Division

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Manuscript Completed - April 11, 1978
Date Published - May 1978

Prepared for the
U.S. Nuclear Regulatory Commission
Office of Nuclear Regulatory Research
Under Interagency Agreements DOE 40-551-75 and 40-552-75

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
DEPARTMENT OF ENERGY

**Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road, Springfield, Virginia 22161
Price: Printed Copy \$7.25; Microfiche \$3.00**

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, contractors, subcontractors, or their employees, makes any warranty, express or implied, nor assumes any legal liability or responsibility for any third party's use or the results of such use of any information, apparatus, product or process disclosed in this report, nor represents that its use by such third party would not infringe privately owned rights.

CONTENTS

	<u>Page</u>
FOREWORD.....	v
ABSTRACT.....	vii
INTRODUCTION.....	ix
SECTION 1. CHRONOLOGICAL MAIN INDEX.....	1
SECTION 2. PERMUTED-TITLE (KWIC) INDEX.....	79
SECTION 3. AUTHOR INDEX.....	105

FOREWORD

The Nuclear Safety Information Center (NSIC), which was established in March 1963 at Oak Ridge National Laboratory, is principally supported by the U.S. Nuclear Regulatory Commission's Office of Nuclear Regulatory Research. Support is also provided by the Division of Reactor Development and Demonstration of the Department of Energy. NSIC is a focal point for the collection, storage, evaluation, and dissemination of safety information to aid those concerned with the analysis, design, and operation of nuclear facilities. Although the most widely known product of NSIC is the technical progress review *Nuclear Safety*, the Center prepares reports and bibliographies as listed on the inside covers of this document. The Center has also developed a system of key words to index the information which it catalogs. The title, author, installation, abstract, and key words for each document reviewed are recorded at the central computing facility in Oak Ridge. The references are cataloged according to the following categories:

1. General Safety Criteria
2. Siting of Nuclear Facilities
3. Transportation and Handling of Radioactive Materials
4. Aerospace Safety (inactive 1970)
5. Heat Transfer and Thermal Hydraulics
6. Reactor Transients, Kinetics, and Stability
7. Fission Product Release, Transport, and Removal
8. Sources of Energy Release under Accident Conditions
9. Nuclear Instrumentation, Control, and Safety Systems
10. Electrical Power Systems
11. Containment of Nuclear Facilities
12. Plant Safety Features - Reactor
13. Plant Safety Features - Nonreactor
14. Radionuclide Release, Disposal, Treatment, and Management (inactive September 1973)
15. Environmental Surveys, Monitoring, and Radiation Dose Measurements (inactive September 1973)
16. Meteorological Considerations

BLANK PAGE

17. Operational Safety and Experience
18. Design, Construction and Licensing
19. Internal Exposure Effects on Humans Due to Radioactivity
in the Environment (inactive September 1973)
20. Effects of Thermal Modifications on Ecological Systems
(inactive September 1973)
21. Radiation Effects on Ecological Systems (inactive September 1973)
22. Safeguards of Nuclear Materials

Computer programs have been developed that enable NSIC to (1) operate a program of selective dissemination of information (SDI) to individuals according to their particular profile of interest, (2) make retrospective searches of the stored references, and (3) produce topical indexed bibliographies. In addition, the Center Staff is available for consultation, and the document literature at NSIC offices is available for examination. NSIC reports (i.e., those with the ORNL/NSIC and ORNL/NUREG/NSIC numbers) may be purchased from the National Technical Information Service (see inside front cover). All of the above services are free to NRC and DOE personnel as well as their direct contractors. They are available to all others at a nominal cost as determined by the DOE Cost Recovery Policy. Persons interested in any of the services offered by NSIC should address inquiries to:

J. R. Buchanan, Assistant Director
Nuclear Safety Information Center
P.O. Box Y
Oak Ridge National Laboratory
Oak Ridge, Tennessee 37830

Telephone 615-483-8611, Ext. 3-7253
FTS number is 850-7253

ABSTRACT

This index to *Nuclear Safety* covers articles published in *Nuclear Safety*, Vol. 11, No. 1 (January-February 1970), through Vol. 18, No. 6 (November-December 1977). It is divided into three sections: a chronological list of articles (including abstracts) followed by a permuted-title (KWIC) index and an author index. *Nuclear Safety*, a bimonthly technical progress review prepared by the Nuclear Safety Information Center (NSIC), covers all safety aspects of nuclear power reactors and associated facilities. Over 450 technical articles published in *Nuclear Safety* in the last eight years are listed in this index.

INTRODUCTION

Nuclear Safety, a bimonthly technical progress review, is prepared by the Oak Ridge National Laboratory for the Nuclear Regulatory Commission. The technical articles (i.e., excluding special reviews and features) are refereed and cover all topics relevant to the safe design, construction, and operation of nuclear facilities. In addition to that primary emphasis on power reactors, safety considerations in reactor fuel fabrication, spent-fuel processing, nuclear waste disposal, handling of radioactive materials, and the environmental effects of these operations are also treated.

Cumulative indexes of *Nuclear Safety* have been prepared annually since 1967. However, starting in 1974, the issues covered extended back only through Volume 11. This issue of the *Index to Nuclear Safety* covers articles included in *Nuclear Safety*, Vol. 11, No. 1, through Vol. 18, No. 6. Persons interested in an index to earlier *Nuclear Safety* volumes should purchase ORNL-NSIC-107 (see inside front cover).

This index is presented in three sections as follows:

Section 1 (orange) - Chronological List of Articles by Volume

Section 2 (white) - Permuted-Title (KWIC) Index

Section 3 (green) - Author Index

A KWIC (KeyWord In Context) index is one in which article titles are permuted around the various significant words contained therein. For example, the title, "Design Basis for Nuclear Power Plant Protection Systems," is indexed under the words Design, Nuclear, Power, Plant, and Protection. As may be seen by reference to Section 2 (white) of this report, the index words are arranged alphabetically in a column in the center of the page, with the titles permuted around them. In some cases, additional significant words in parentheses have been added to the title by the editors to allow more precise indexing. The location of the indexed articles in *Nuclear Safety* is indicated by the seven-digit numbers in the column to the right of the page, as described below. The KWIC code was developed by IBM and has proved to be a useful tool for the preparation of indexes for many different purposes.

BLANK PAGE

Early issues of the index were used primarily for the benefit of the *Nuclear Safety* editors. However, it has been so helpful that it is now prepared and distributed as an NSIC report. The index is published annually following the close of each *Nuclear Safety* volume year and replaces the index that was previously included in the last issue of the volume year.

The seven-digit index number given in all three sections is divided into four parts (00-3-0-000) which stand, respectively, for volume-number-section-page. It provides ready entry from the permuted-title (KWIC) index (white) and author index (green) to the main index (orange), which gives title, author, and abstract when available. Corporate affiliation is given in the orange section for all authors. Abstracts are also included for those articles that contained one. Volume 11 corresponds to 1970; Volume 12, 1971; Volume 13, 1972; Volume 14, 1973; Volume 15, 1974; Volume 16, 1975; Volume 17, 1976; and Volume 18, 1977.

Wm. B. Cottrell, Editor
 W. H. Jordan, Advisory Editor
 M. R. Sheldon and A. L. Ragan,
 Editorial Reviewers
 Section Editors:

1. General Safety Considerations
 J. R. Buchanan
2. Accident Analysis
 P. M. Haas
3. Control and Instrumentation
 E. W. Hagen
4. Plant Safety Features
 F. N. Browder
5. Environmental Effects
 R. O. Chester and F. O. Hoffman
6. Operating Experiences
 W. R. Casto
7. Current Events
 Wm. B. Cottrell

Section 1

CHRONOLOGICAL MAIN INDEX

Nuclear Safety articles are indexed in this section by volume in the chronological order of their appearance in the Journal. Titles (white section) and authors (green section) are keyed to this main index by means of a seven-digit number in the left-hand column; the number is divided into four parts (00-0-0-000), which stand for volume-number-section-page, respectively. Following the index number are the appropriate article title and author. For example, Vol. 11, No. 1, Sect. 3, p. 20 (11-1-3-020) contained the article, "The Design Basis for Nuclear Power Plant Protection Systems," by R. S. Stone (see index). The dates pertinent to each volume are listed in the introduction. Abstracts are included in this section for all articles that had one.

BIBLIOGRAPHY

- 11-1-1-001 THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM
BAKER, L. JR. + ROSE, D. + MILLER, C. E., JR.
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
THE GENERAL AIM OF THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM IS THE IMPROVEMENT OF THE TECHNOLOGICAL BASE NEEDED TO UNDERSTAND ACCIDENT SITUATIONS, TO DEVELOP SAFETY SYSTEMS, AND TO DEVELOP STANDARDS AND CODES FOR SAFE DESIGN, SITING, CONSTRUCTION, AND OPERATION OF AEC TEST FACILITIES AND COMMERCIAL LIQUID METAL FAST BREEDERS. IN ITS SCOPE THE PROGRAM INCLUDES STUDIES OF THE PHENOMENA ASSOCIATED WITH ABNORMAL OPERATION, POTENTIAL ACCIDENTS, AND SAFETY SYSTEMS DESIGNED TO PREVENT ACCIDENTS OR TO LIMIT THEIR CONSEQUENCES. EMPHASIS IS PLACED ON PREVENTION, EARLY DETECTION, AND CONTROL OF POTENTIAL ACCIDENTS.
- 11-1-2-012 ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY RAPID HEATING
UCHIDA, N. + YAMURA, T.
UNIVERSITY OF TOKYO, TOKYO, JAPAN
A BASIC INVESTIGATION WAS MADE OF THE POWERFUL PULSELIKE PRESSURE INCREASES THAT OCCUR IN A NARROW WATER CHANNEL WHEN THE WATER IS BEING HEATED RAPIDLY. IN THE EXPERIMENTS A VERTICAL WATER COLUMN WAS HEATED AT THE BOTTOM, AND THE TOP OF THE WATER WAS A FREE SURFACE. TEMPERATURE CHANGE RATES ON THE WATER SURFACE WERE VARIED FROM 3000 TO 25,000C/SEC. THE INVESTIGATION INDICATED THAT THE PRESSURE CHANGE, IN A CHANNEL UNDERGOING RAPID HEATING EXHIBIT TWO KINDS OF PATTERNS, NAMELY, AN INITIAL INCREASE TO A PEAK PRESSURE THAT IS INFLUENCED BY THE HEATING RATE AND THEN A SERIES OF PRESSURE PULSES THAT CAN BE EXPLAINED ANALYTICALLY AS A DYNAMICS PROBLEM SIMILAR TO THAT ASSOCIATED WITH A WATER HAMMER. IN THIS SECOND STAGE THE MAXIMUM PRESSURE IS GREATER THAN THE PEAK PRESSURE IN THE FIRST STAGE. THESE PRESSURE CHANGES ARE SIMILAR TO PRESSURE CHANGES OBSERVED IN BORAX AND SPERT EXPERIMENTS.
- 11-1-3-020 THE DESIGN BASIS FOR NUCLEAR POWER PLANT PROTECTION SYSTEMS
STONE, R. S.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE DESIGN BASIS FOR A NUCLEAR PLANT PROTECTION SYSTEM GIVES FUNCTIONAL REQUIREMENTS AND ESTABLISHES THE CIRCUMSTANCES UNDER WHICH THE SYSTEM MUST BE CAPABLE OF OPERATING. IT TAKES INTO ACCOUNT BOTH THE SYSTEM'S CHARACTERISTICS AND THOSE OF THE ENTIRE COMPLEX OF PROTECTIVE FEATURES. THESE LATTER CHARACTERISTICS CONSIST IN THOSE ASPECTS OF PLANT DESIGN THAT FORESTALL, AVOID, OR MITIGATE HAZARDOUS OCCURRENCES IN THE POWER-GENERATING CHAIN. THE BASIC REQUIREMENTS ARE TO ENSURE PUBLIC SAFETY AND, IF POSSIBLE, TO PREVENT DAMAGE TO THE PLANT. A PROPER DESIGN BASIS TIES TOGETHER ALL THE INFORMATION NECESSARY FOR THE DEVELOPMENT OF A COMPETENT PLANT PROTECTION SYSTEM. WITHOUT SUCH A DESIGN BASIS, THE SYSTEM WILL BE HAPHAZARD AND INCOMPLETE.
- 11-1-4-025 A REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESSURE VESSELS
TAN, C. P.
FRANKLIN INSTITUTE RESEARCH LABORATORIES, PHILADELPHIA, PENNSYLVANIA
PRESTRESSED CONCRETE REACTOR VESSELS (PCRV'S) ARE ADAPTABLE TO LARGE NUCLEAR CORES AND THE HIGH PRESSURES NEEDED FOR THE SAFE AND ECONOMICAL PRODUCTION OF NUCLEAR POWER WITH GAS-COOLED REACTORS. THERE ARE AT PRESENT 18 PCRV'S, MOST OF WHICH ARE IN GREAT BRITAIN AND FRANCE. IN THE UNITED STATES A PCRV FOR THE FORT ST. VRAIN HIGH TEMPERATURE GAS-COOLED REACTOR IS UNDER CONSTRUCTION. THE BASIC PROBLEMS FACING THE DESIGNER AND CONSTRUCTOR OF PCRV'S WERE (1) LACK OF APPLICABLE CODES, (2) LITTLE KNOWLEDGE OF LONG TERM BEHAVIOR OF CONCRETE UNDER MULTIAXIAL STRESSES AT HIGH TEMPERATURE, (3) LITTLE INFORMATION ON STRESS CONCENTRATIONS IN CONCRETE DUE TO PENETRATIONS OF VARIOUS SIZES AND TO THE ANCHORAGES, (4) POROSITY OF CONCRETE, AND (5) LIMITED CAPACITY OF COMMERCIALLY AVAILABLE PRESTRESSING SYSTEMS. MOST OF THESE PROBLEMS HAVE BEEN RESOLVED THROUGH ENGINEERING INGENUITY COMPLEMENTED WITH EXTENSIVE RESEARCH AND DEVELOPMENT. SATISFACTORY DESIGNS OF PCRV'S HAVE BEEN ACCOMPLISHED BY DEVELOPING SOPHISTICATED ANALYTICAL METHODS AND TESTING STRUCTURAL MODELS. PCRV'S APPEAR TO BE FAVORED FOR ADVANCED REACTORS BECAUSE OF ADAPTABILITY WITH RESPECT TO SIZE AND PRESSURE.
- 11-1-5-034 VARIABILITY OF WIND DIRECTION WITHIN THE UNITED STATES
SINGER, I. A. + MUGLE, C. M.
BROOKHAVEN NATIONAL LABORATORY, UPTON, L.I., NEW YORK
INCREASING INTEREST IN ATMOSPHERIC DIFFUSION PROBLEMS (PARTICULARLY FOR NUCLEAR SAFETY REACTORS, AS RELATED TO THE SITING OF NUCLEAR POWER REACTORS) HAS CREATED NEED FOR A QUANTITATIVE MEASURE OF THE VARIABILITY OF THE MEAN WIND DIRECTION WITH TIME. IT HAS BEEN PROPOSED THAT THE CONSTANCY OF THE WIND, DEFINED AS THE MEAN VECTOR WIND DIVIDED BY THE MEAN SCALAR WIND (V/V), BE USED FOR SIMPLE CLASSIFICATION PURPOSES. A TRIGONOMETRIC TRANSFORMATION IS USED TO LINEARIZE THE VARIATION OF CONSTANCY WITH THE MEAN ANGULAR RANGE OF DIRECTION. THIS FUNCTION, CALLED THE STEADINESS, S , IS THEN

BLANK PAGE

COMPUTED FOR VARIOUS TIME PERIODS, AND BY USE OF EXTREME-VALUE THEORY THE RECURRENCE INTERVALS OF VARIOUS MEAN WIND DIRECTION RANGES CAN BE PREDICTED. THIS HAS BEEN DONE FOR 34 STATIONS IN THE UNITED STATES. RECURRENCE INTERVAL MAPS OF THE STEADINESS OF WIND DIRECTION WITHIN THE UNITED STATES FOR VARIOUS TIME PERIODS ARE PRESENTED THAT SHOW THE INTERRELATION OF GEOGRAPHICAL LOCATION AND SYNOPTIC METEOROLOGY WITH WIND DIRECTION PERSISTENCE. THE MOST PERSISTENT WIND DIRECTIONS APPEAR AT COASTAL STATIONS, AND THE LEAST PERSISTENT OCCUR IN MOUNTAINOUS REGIONS.

11-1-5-039 U.S.A. STANDARD N13.2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION MONITORING (A GUIDE FOR MANAGEMENT)

WART, J. C. + MOELLER, D. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE - HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASSACHUSETTS
RADIATION PROTECTION IN ANY NUCLEAR-BASED OPERATION IS A RESPONSIBILITY OF MANAGEMENT. THE USA STANDARD N13.2 IS DESIGNED TO PROVIDE A GENERAL REVIEW OF THE TYPE AND EXTENT OF MONITORING NEEDED FOR THE SAFE USE AND APPLICATION OF RADIATION SOURCES. THIS STANDARD MAY BE USED DURING THE PLANNING STAGES OF AN OPERATION AS A GUIDE TO AN EFFECTIVE MONITORING PROGRAM.

11-1-5-043 TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN FOOD CHAINS

REICHME, D. E. + DUNAWAY, P. B. + NELSON, D. J.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
PROLIFERATION OF NUCLEAR TECHNOLOGY AND CONCERN FOR RADIOACTIVITY IN THE BIOSPHERE DEMAND MORE SOPHISTICATED EVALUATIONS OF FUTURE NUCLEAR INSTALLATIONS AND PROCEDURES. ADEQUATE ANALYSES OF RADIONUCLIDE DISPERSION IN THE ENVIRONMENT WILL REQUIRE MORE SUBSTANTIAL BIOENVIRONMENTAL INFORMATION THAN IS PRESENTLY AVAILABLE. FREQUENTLY INFORMATION KNOWN FOR ONE ECOLOGICAL SYSTEM (E.G., ARCTIC TUNDRA) WILL NOT BE APPLICABLE TO OTHER ECOSYSTEMS (E.G., TEMPERATE OR TROPICAL FORESTS). ONLY WITH SUFFICIENT ECOLOGICAL DATA CAN PREDICTIVE MODELS BE DEVELOPED THAT WILL ENABLE ASSESSMENT OF THE ENVIRONMENTAL CONSEQUENCES OF RADIOACTIVE CONTAMINATION. A SIMPLE SOURCE PATHWAY RECEPTOR MODEL, ANALOGOUS TO THE ECOLOGICAL FOOD CHAIN, REQUIRES PATHWAY IDENTIFICATION, DATA ON ASSIMILATION BY EACH LINK (ORGANISM) IN THE PATHWAY, AND DETERMINATION OF THE BIOLOGICAL TURNOVER OF EACH RADIONUCLIDE. FOR ACUTE RELEASES OF RADIOACTIVITY TO THE ENVIRONMENT, EVALUATION OF THESE VARIABLES IS NEEDED TO PREDICT TIME DEPENDENT CONCENTRATIONS OF RADIOACTIVITY IN ORGANISMS. FOR CHRONIC RELEASES, CONCENTRATION FACTORS ALONE WILL OFTEN SUFFICE. THE BIOLOGICAL CONCENTRATION AND TURNOVER OF RADIONUCLIDES BY ANIMALS ARE SUMMARIZED IN THIS PAPER. DATA ARE PRESENTED FOR USE IN ENVIRONMENTAL MODELS AND CORRELATION WITH SPECIES CHARACTERISTICS (E.G., BODY SIZE) THAT ALLOW ESTIMATION OF ABSOLUTE VALUES FOR MANY DIFFERENT ANIMAL GROUPS BASED ON EXISTING EXPERIMENTAL DATA.

11-2-1-107

INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS

TURNER, S. E. + MCCULLOUGH, C. R. + LYTLEY, R. L.
SOUTHERN NUCLEAR ENGINEERING, INC., DUNEDIN, FLORIDA
THE CONSEQUENCES OF INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS HAVE BEEN STUDIED FROM THE STANDPOINT OF THE POTENTIAL HAZARD TO THE HEALTH AND SAFETY OF THE PUBLIC. THIS EVALUATION OF THE POTENTIAL THREAT OF SABOTAGE CONSIDERED (1) HISTORICAL PRECEDENTS, (2) THE OPINIONS OF EXPERIENCED AND KNOWLEDGEABLE INDIVIDUALS, (3) MOTIVATION AND LIKELY EXTENT OF KNOWLEDGE OF VARIOUS TYPES OF SABOTEURS, AND (4) AN ASSESSMENT OF THE PROBABILITY AND POSSIBLE CONSEQUENCES OF A NUMBER OF POSTULATED SABOTAGE ACTS. AS WELL AS THE LEVEL OF DAMAGE NECESSARY TO CREATE A PUBLIC HAZARD. ON THE BASIS OF THE STUDY, IT IS CONCLUDED THAT, ALTHOUGH SABOTAGE WITH SERIOUS CONSEQUENCES TO THE PUBLIC IS POSSIBLE IN THEORY, THE PROBABILITY IS SUFFICIENTLY LOW THAT NO UNIQUE RISK TO THE HEALTH AND SAFETY OF THE PUBLIC EXISTS.

11-2-3-115

AUTOMATION OF REACTOR CONTROL AND SAFETY SYSTEMS AT ORNL
OAKES, L. C.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
REACTOR SAFETY FUNCTIONS REQUIRING FAST RESPONSE ARE AUTOMATED, BUT OBJECTIONS ARISE WHEN SOME TRADITIONALLY MANUAL OPERATIONS ARE PROPOSED FOR AUTOMATION. IN A REACTOR CONTROL SYSTEM, PERHAPS MORE THAN IN ANY OTHER, THE OPERATOR IS DEPENDENT ON SENSORY INSTRUMENTATION FOR DETERMINING THE OPERATING STATE. COMPARISONS OF RELIABILITY, OPERABILITY, ECONOMICS, AND SAFETY FOR AUTOMATIC VS. MANUAL CONTROL ARE ABOUT THE SAME IF SIMILAR PERFORMANCE IS EXPECTED. THESE ARE EXEMPLIFIED BY DISCUSSIONS OF AUTOMATIC STARTUPS AND SHUTTING. OPERATOR JUSTIFICATION IS EVEN NOW SOMEWHAT PHILOSOPHICAL, AND RESULTS OF CURRENT RESEARCH AND DEVELOPMENT IN COMPUTER CONTROL AND DIAGNOSTIC TECHNIQUES WILL FURTHER TEND TO REDUCE HIS ROLE. A GREATER AMOUNT OF AUTOMATION THAN NOW USED WOULD LEAD TO IMPROVED SAFETY AND OPERABILITY.

11-2-4-119

CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL
REEDY, R. F. + SINS, J. E.
CHICAGO BRIDGE AND IRON COMPANY, OAK BROOK, ILLINOIS - CHICAGO BRIDGE AND IRON COMPANY, MEMPHIS, TENNESSEE
THE MONTICELLO NUCLEAR GENERATING PLANT IN MINNESOTA, OWNED BY NORTHERN STATES POWER COMPANY, IS UNIQUE IN THAT IT HAS THE

FIRST FIELD FABRICATED NUCLEAR REACTOR PRESSURE VESSEL BUILT IN THE UNITED STATES. THE MATERIALS FOR THIS VESSEL WERE FABRICATED IN THE NORMAL MANNER AND SHIPPED TO THE SITE FOR FINAL ASSEMBLY INTO A COMPLETED VESSEL. SPECIAL TRAINING FOR FIELD MACHINING, WELDING, AND QUALITY CONTROL WAS REQUIRED. THE COMPLETION OF THE PRESSURE VESSEL AHEAD OF SCHEDULE SHOWED THAT THE FIELD FABRICATION OF NUCLEAR PRESSURE VESSELS IS BOTH FEASIBLE AND ECONOMICAL.

- 11-2-5-130 STATUS OF INVESTIGATIONS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WASTES
MCLAM, H. C. + GARDSMAN, R. L.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

A COMMITTEE OF THE NATIONAL ACADEMY OF SCIENCES FIRST SUGGESTED THE USE OF SALT FORMATIONS FOR THE DISPOSAL OF RADIOACTIVE WASTES IN 1955, AND FEASIBILITY STUDIES BEGAN AT OAK RIDGE NATIONAL LABORATORY AND ELSEWHERE AS EARLY AS 1957. BY THE EARLY 1960'S, EMPHASIS HAD SHIFTED FROM DIRECT DISPOSAL OF LIQUID WASTES TO SOLIDIFICATION AND DISPOSAL OF THE RESULTING SOLIDS. A CONCEPT FOR DISPOSAL OF SUCH SOLIDS IN A SALT MINE WAS DEVELOPED, AND PREPARATIONS FOR A DEMONSTRATION EXPERIMENT BEGAN IN 1963. THE RADIOACTIVE PHASE OF THIS DEMONSTRATION BEGAN IN NOVEMBER 1965 AND SUCCESSFULLY DEMONSTRATED THE FEASIBILITY AND SAFETY OF HANDLING HIGHLY RADIOACTIVE MATERIALS IN AN UNDERGROUND ENVIRONMENT. THIS EXPERIMENT ALSO DEMONSTRATED THE STABILITY OF SALT UNDER THE EFFECTS OF HEAT AND RADIATION. DATA OBTAINED ON THE CREEP AND PLASTIC FLOW CHARACTERISTICS OF SALT HAVE MADE IT POSSIBLE TO ARRIVE AT A SUITABLE MINE DESIGN FOR A DISPOSAL FACILITY. A STUDY OF THE ECONOMICS OF DISPOSAL IN SALT MINES INDICATES THAT THIS METHOD WILL BE COMPATIBLE WITH COMPETITIVE NUCLEAR POWER. AN ANALYSIS OF THE PROJECTED POWER REACTOR WASTES AND THE SAFETY CONSIDERATIONS INVOLVED POINTS TO THE NEED FOR A GOVERNMENT OWNED WASTE REPOSITORY TO BE IN OPERATION BEFORE 1980.

- 11-2-6-142 SAN ONOFRE EXPERIENCE WITH APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE ANOMALIES
ORTEGA, D. J. + JOHNSON, C. G. + BASKIN, R. P.
SOUTHERN CALIFORNIA EDISON COMPANY, LOS ANGELES, CALIFORNIA

IN JANUARY 1960 THE UPPER LIMIT FOR OPERATION AT THE SAN ONOFRE NUCLEAR GENERATING STATION WAS SET AT 90 PERCENT POWER, 405 MWIE). BECAUSE DISCREPANCIES HAD BEEN NOTED IN REACTOR THERMAL POWER AS reckoned BY DIFFERENT METHODS, CALCULATIONS BASED ON THE TEMPERATURE DIFFERENTIALS ACROSS THE STEAM GENERATOR IN THE PRIMARY LOOPS GAVE ONE VALUE, AND CALORIMETRICS IN THE SECONDARY SYSTEM GAVE ANOTHER. IT APPEARED THAT COOLANT FLOW WAS LESS THAN THE DESIGN VALUE. EXTENSIVE TESTING DURING MARCH, SEPTEMBER, AND OCTOBER 1960 REVEALED THAT TEMPERATURE SENSORS GAVE MISLEADING INDICATIONS BECAUSE OF THEIR LOCATIONS. ACCORDINGLY, ADDITIONAL DIRECT IMMERSION RESISTANCE TEMPERATURE DETECTORS (RTD'S) WERE INSTALLED DOWNSTREAM OF EACH COOLANT PUMP TO GIVE ACCURATE COLD-LEG MIXED-MEAN TEMPERATURES. ACCURATE CORE OUTLET TEMPERATURES WERE ALREADY BEING PROVIDED BY CORE THERMOCOUPLES. THE DATA FROM THE NEW RTD'S PROVED THAT COOLANT FLOW ACTUALLY WAS EQUAL TO OR GREATER THAN DESIGN FLOW. ON THE STRENGTH OF THIS KNOWLEDGE, OPERATION AT 100 PERCENT POWER RATING, 450 MWIE), WAS BEGUN IN DECEMBER 1960 AFTER AN 18-MONTH INVESTIGATION OF THE ANOMALY. THE PROBLEM DEMONSTRATED THE GREAT NEED FOR INSTRUMENTATION TO ACCURATELY READ TWO PERFORMANCE PARAMETERS IN LARGE PWR'S (1) MIXED-MEAN HOT- AND COLD-LEG TEMPERATURES AND (2) FLOW OF PRIMARY COOLANT.

- 11-3-1-105 THE UTILITY'S ROLE IN NUCLEAR SAFETY RESEARCH AND DEVELOPMENT
MOORE, J. B.

SOUTHERN CALIFORNIA EDISON COMPANY, LOS ANGELES, CALIFORNIA
PLANNING FOR NEW ELECTRICITY GENERATING UNITS IN LARGE UTILITIES IS CHARACTERIZED BY CONTRACTING FOR A SERIES OF SIMILAR UNITS TO BE OPERATIONAL OVER A SPAN OF YEARS BEFORE CHANGING TO A DIFFERENT DESIGN. DELAYS, CAUSED BY DESIGN CHANGES MADE NECESSARY BECAUSE OF EQUIPMENT PROBLEMS AND BY CHANGING REQUIREMENTS IN REACTOR LICENSING, UPSET THIS ORDERLY GROWTH AND HAVE A CASCADING EFFECT SO THAT A SERIOUS RISK OF ELECTRICAL BLACKOUTS ENSUES DURING THE TRANSITION FROM FOSSIL FUELED TO NUCLEAR FUELED ELECTRICITY GENERATION. THE UTILITY'S ROLE IS TO ASSURE FEEDBACK OF OPERATING EXPERIENCE AND PROPER EVALUATION OF THE FEED-FORWARD TO STANDARDS AND CRITERIA THAT OCCURS PRIOR TO ACTUAL OPERATING EXPERIENCE.

- 11-3-2-195 STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS
DICKERMAN, C. E.

ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS ARE INCLUDED IN THE COMPREHENSIVE USAEC SAFETY PROGRAM. INFORMATION IS NOW BECOMING AVAILABLE ON VAPORIZATION, PRESSURE GENERATION, AND VOIDING OF SODIUM COOLANT UNDER TRANSIENT HEATING. SEMIEMPIRICAL MODELS OF OXIDE FUEL FAILURE ARE BEING DEVELOPED FROM TRANSIENT EXPERIMENT DATA. THE COMPLEX RELATIONS BETWEEN FUEL FAILURE, MELTDOWN, AND SECONDARY MOVEMENTS OF FUEL AND COOLANT ARE BEING STUDIED IN SODIUM FILLED CAPSULES, AUTOCLAVES, AND LOOPS. DATA NOW AVAILABLE INDICATE THAT, IN SOME CASES AT LEAST, THE REAL PHENOMENA ARE SIGNIFICANTLY LESS HAZARDOUS THAN PREDICTIONS BASED ON LIMITING CASE MODELS REQUIRED IN THE ABSENCE OF ACTUAL DATA.

- 11-3-3-296 PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER-COOLED POWER REACTOR PLANTS
O'Brien, M. G. + Walker, C. S.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
CURRENT PRACTICES IN PROTECTION SYSTEM DESIGNS VARY WIDELY, INDICATING DIFFERENCES IN DESIGN CRITERIA, AS WELL AS THE LACK OF COMMONLY RECOGNIZED 'BEST WAYS' IN DESIGN APPROACHES FOR CARRYING OUT SIMILAR FUNCTIONS. THE DESIGN OF THE INSTRUMENTATION SYSTEMS FOR THE ENGINEERED SAFETY FEATURES PRESENTS A CONSIDERABLY MORE COMPLEX PROBLEM THAN THE DESIGN OF THE REACTOR SHUTDOWN SYSTEM. EXAMINATIONS OF THE DESIGNS OF FOUR TYPICAL PROTECTION INSTRUMENTATION SYSTEMS FOR BOILING AND PRESSURIZED WATER POWER REACTORS INDICATED THAT (1) DESIGNS SHOULD BE EFFECTIVELY DOCUMENTED, (2) LOGICAL AND APPROPRIATE REQUIREMENTS FOR PERFORMANCE AND RELIABILITY SHOULD BE ESTABLISHED, AND (3) DETAILED CRITERIA ARE NEEDED FOR INSTRUMENTATION SYSTEM DESIGN.
- 11-3-4-215 THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM
Heems, S. J. + Lyman, M. G. + Naga, P. B.
MPR ASSOCIATES, INC., WASHINGTON, D.C. - WESTINGHOUSE PWR SYSTEMS DIVISION, PITTSBURGH, PENNSYLVANIA
THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM, WHICH WAS DESIGNED AND DEVELOPED AT WESTINGHOUSE ELECTRIC CORPORATION, EMPLOYS BORATED ICE AS A STATIC HEAT SINK FOR RAPID ABSORPTION OF ENERGY THAT MIGHT BE RELEASED THROUGH RUPTURE OF REACTOR COOLANT PIPING. THE CONCEPT IS ADAPTABLE TO ALL CURRENT TYPES OF COMMERCIAL NUCLEAR POWER PLANTS. THE BASIC DESIGN PHILOSOPHY, SYSTEM PARAMETERS, AND FULL SCALE SECTION PROOFTESTING CONDUCTED TO ESTABLISH THE SOUNDNESS AND PRACTICALITY OF THE CONCEPT ARE DESCRIBED, AS WELL AS THE FIRST PLANT APPLICATIONS - THE DONALD C. COOK NUCLEAR PLANT FOR THE AMERICAN ELECTRIC POWER SYSTEM AND THE SEQUOYAH NUCLEAR PLANT FOR THE TENNESSEE VALLEY AUTHORITY.
- 11-3-4-223 RESEARCH ON THE USE OF CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER REACTORS
Roh, T. H.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
MANY OF THE PRESSURIZED WATER REACTORS OPERATING OR UNDER CONSTRUCTION INCLUDE CONTAINMENT BUILDING PRESSURE REDUCTION SPRAY SYSTEMS DESIGNED TO INCORPORATE A FISSION PRODUCT SEQUESTERING AUDITIVE. A PROGRAM TO EVALUATE ALL ASPECTS OF THE USE OF A SPRAY SYSTEM AS AN ENGINEERED SAFETY FEATURE HAS BEEN COORDINATED BY OAK RIDGE NATIONAL LABORATORY FOR THE AEC SINCE MARCH 1957. THE MAJOR RESEARCH EFFORT HAS BEEN CENTERED AT OAK RIDGE NATIONAL LABORATORY, WITH ADDITIONAL WORK BEING DONE AT BATTELLE-NORTHWEST AND THROUGH PRIVATELY SPONSORED RESEARCH BY THE NUCLEAR INDUSTRY. CURRENT EVALUATIONS INDICATE THAT SPRAY SYSTEMS WILL RAPIDLY REMOVE MOLECULAR IODINE AND THAT METHYL IODIDE AND PARTICULATE REMOVAL ARE SIGNIFICANTLY SLOWER PROCESSES. RADIOLYTIC HYDROGEN GENERATION BY POSTACCIDENT COOLING OF THE REACTOR CORE INTRODUCES A SIGNIFICANT DESIGN CONSIDERATION.
- 11-3-4-235 RADON CONCENTRATION IN REACTOR CONTAINMENT BUILDINGS MASQUERADES AS IODINE-131 RELEASE
Clack, R. M. + Eckhoff, N. D.
KANSAS STATE UNIVERSITY, MANHATTAN, KANSAS
THE CONTAINMENT BUILDING AIR AT THE KANSAS STATE UNIVERSITY TRIGA MARK II REACTOR BECAME CONTAMINATED WITH RADON, WHICH PRESUMABLY CAME FROM THE THAWING GROUND JUST OUTSIDE THE VENTILATION INTAKE. GAMMA-RAY SPECTRUM ANALYSIS IDENTIFIED THE CONTAMINATION AS RADON AND ITS PROGENY INSTEAD OF IODINE-131, WITH WHICH IT CAN BE CONFUSED. A SIMILAR INCIDENT OCCURRED IN 1962 AT THE UNION CARBIDE REACTOR IN STERLING FOREST, NEW YORK.
- 11-3-4-237 A COMPARISON OF TWO NITROGEN-16 RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF RESEARCH REACTOR FUEL
CASHMELL, R. J.
UNIVERSITY OF WISCONSIN, MADISON, WISCONSIN
PERSONNEL AT THE UNIVERSITY OF WISCONSIN NUCLEAR REACTOR HAVE MADE DETAILED RADIATION MEASUREMENTS FOR COMPARING THE EFFICIENCY OF A PLEXIGLAS PLATE TYPE NITROGEN-16 DIFFUSER WITH AN 80 GAL/MIN JET-TYPE DIFFUSER, ALTHOUGH MUCH LESS EFFECTIVE THAN THE JET-TYPE DIFFUSER, THE PLATE TYPE DIFFUSER OFFERS GREATER SIMPLICITY AND RELIABILITY AND WITH NO REACTIVITY DISTURBANCES.
- 11-4-1-203 SAFETY ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE UNITED KINGDOM
FARMER, F. R.
UKAEA HEALTH AND SAFETY BRANCH, RISLEY, MARRINGTON, ENGLAND
THE BUILDING OF ANY REACTOR INTRODUCES SOME RISK TO THE PUBLIC, BUT IT APPEARS THAT THE FAST REACTOR MAY PRESENT LESS RISK THAN CURRENT REACTORS BECAUSE IT CAN BE DESIGNED SO AS NOT TO REQUIRE A FUEL SOURCE WHEN SHUT DOWN. SINCE IT IS UNLIKELY THAT IT CAN EVER BE POSITIVELY ESTABLISHED THAT EVERY ENERGY RELEASE CAN ALWAYS BE CONTAINED, RELIANCE MUST BE PLACED IN THE GREATER LIKELIHOOD OF IDENTIFYING THE FAULT AND SHUTTING DOWN THE REACTOR. THE OBJECTIVE OF CURRENT SAFETY RESEARCH IS TO PROVIDE TWO INDEPENDENT MECHANICAL SHUTDOWN SYSTEMS ACTIVATED BY INDEPENDENT SIGNALS. MEANS ARE BEING DEVELOPED FOR DETECTION OF FUEL SUBASSEMBLY FAILURES THROUGH DELAYED NEUTRONS, FISSION PRODUCTS, ACOUSTICS, AND POSSIBLY THE SHOCK OF SUBASSEMBLY COLLAPSE.

- 11-4-2-209 RECENT DEVELOPMENTS IN FAST REACTOR KINETICS
 BUTLER, D. K. + KEMLEY, D. A.
 ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
 ANALYSIS OF THE SAFETY OF A FAST BREEDER REACTOR REQUIRES CALCULATION OF THE TIME DEPENDENT NEUTRON FLUX AND FISSION POWER DENSITIES. METHODS FOR THESE CALCULATIONS WHICH ARE REVIEWED ARE THOSE BASED ON NEUTRON DIFFUSION THEORY - POINT KINETIC, ADIABATIC, QUASI-STATIC, AND EXACT SOLUTIONS. THE METHODS ARE USED IN DIGITAL COMPUTER PROGRAMS IN COMBINATION WITH THOSE CALCULATIONS OF MECHANICAL CHANGES, FLUID FLOW, AND HEAT TRANSFER WHICH ARE REQUIRED FOR THE ANALYSIS OF STABILITY AND ACCIDENTS. LIMITATIONS OF COMPUTER CAPABILITY REQUIRE THE USE OF APPROXIMATE METHODS WHERE APPLICABLE. COMPARISON OF RESULTS OBTAINED WITH EACH METHOD SHOWS THAT THE QUASI-STATIC OR EXACT SOLUTION IS REQUIRED TO OBTAIN ACCURATE VALUES FOR POWER GENERATION DURING SEVERE TRANSIENTS. INCORPORATING THESE MORE ACCURATE RESULTS INTO COMPUTER PROGRAMS WHICH INCLUDE EQUALLY ACCURATE CALCULATIONS OF THE THERMAL AND MECHANICAL EFFECTS WILL BE IMPORTANT IN DEVELOPING COMPUTER CODES FOR ACCIDENT ANALYSIS.
- 11-4-2-210 TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT STRUCTURES
 BOAH, P. L.
 UNITED ENGINEERS AND CONSTRUCTORS, INC., PHILADELPHIA, PENNSYLVANIA
 DESCRIPTIONS OF THE CHARACTERISTICS OF TORNADOS ARE PRESENTED THAT ARE BASED ON DOCUMENTED INFORMATION. THE NUCLEAR PLANT LIFETIME TORNADO RISK IS ASSESSED, AND MECHANISTIC CALCULATIONAL TECHNIQUES ARE PRESENTED TO DETERMINE THE EFFECTS ON PLANT STRUCTURES OF DYNAMIC WIND FORCES, STATIC PRESSURE DIFFERENTIALS, AND TORNADO GENERATED MISSILES. PARTICULAR ATTENTION IS GIVEN TO THE EFFECTS OF THE DESIGN TORNADO ON THE SPENT FUEL STORAGE POOL. POTENTIAL LOSS OF WATER BY ENTRAINMENT, SUCTION, EVAPORATION, AND RADIAL PRESSURE DIFFERENTIALS IS ASSESSED. ON THE BASIS OF HIGHLY CONSERVATIVE ASSUMPTIONS, IT IS SHOWN THAT THE SPENT FUEL STORAGE POOLS OF EXISTING LIGHT WATER REACTORS ARE QUITE ADEQUATELY DESIGNED TO ENSURE SAFE CONTAINMENT OF FISSION PRODUCTS IN THE EVENT THE DESIGN TORNADO OCCURS.
- 11-4-3-309 THE THIRD RELIABILITY MEETING AT RISO
 LEONARDINI, L.
 EUROPEAN NUCLEAR ENERGY AGENCY, PARIS, FRANCE
 AN INTERNATIONAL MEETING ON RELIABILITY PROBLEMS RELATED TO THE SAFETY OF THE MECHANICAL COMPONENTS AND SYSTEMS IN NUCLEAR REACTORS WAS HELD IN DENMARK DURING SEPTEMBER 1969. TWENTY-EIGHT PAPERS WERE PRESENTED BY REPRESENTATIVES FROM NINE COUNTRIES. RELIABILITY ENGINEERING TECHNIQUES WERE DESCRIBED, AND THE NEED FOR FAILURE DATA COLLECTION SYSTEMS AND BANKS WAS DISCUSSED. MUCH REMAINS TO BE DONE WITH RESPECT TO APPLICATION OF THE DATA.
- 11-4-4-315 INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS
 ROW, T. M. + DAVIS, R. J.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
 AN INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS SPONSORED BY THE FRENCH SOCIETY FOR RADIOPROTECTION WAS HELD AT SACLAY, FRANCE, NOV. 4-6, 1969. THE MEETING WAS ATTENDED BY 214 DELEGATES REPRESENTING 16 COUNTRIES AND 3 INTERNATIONAL AGENCIES. PRESENTED WERE 30 PAPERS AND 4 SUMMARY REPORTS. THE SCOPE OF THE CONGRESS WAS SUFFICIENTLY BROAD THAT ESSENTIALLY ALL PHASES OF FISSION PRODUCT RELEASE AND TRANSPORT WERE INCLUDED. APPROXIMATELY TWO-THIRDS OF THE PAPERS PRESENTED AT THE CONGRESS WERE DEVOTED TO FISSION PRODUCT RELEASE BEHAVIOR AND REMOVAL UNDER WATER-COOLED AND GAS-COOLED REACTOR CONDITIONS. THE REMAINING PAPERS WERE ADDRESSED TO LMFBR (LIQUID METAL COOLED FAST BREEDER REACTOR) CONDITIONS.
- 11-4-4-323 THE ORR EMERGENCY COOLING FAILURE
 EPLER, E. P.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
 THREE IDENTICAL UNITS THAT SUPPLY EMERGENCY POWER FOR AFTERHEAT PROTECTION OF THE OAK RIDGE RESEARCH REACTOR FAILED SIMULTANEOUSLY, AND THE REACTOR WAS OPERATED WITHOUT EMERGENCY POWER FOR THE AFTERHEAT REMOVAL SYSTEM FOR 5 HR BEFORE THE CONDITION WAS DISCOVERED. THE INCIDENT WAS CAUSED BY SEVEN COMMON MODE FAILURES OR ERRORS IN THREE IDENTICAL CHANNELS - A TOTAL OF 21 FAILURES. HAD ANY ONE OF THESE NOT HAPPENED, THE REACTOR WOULD NOT HAVE BEEN STARTED UP WITHOUT THE AVAILABILITY OF EMERGENCY COOLING FROM THE THREE INOPERATIVE UNITS. THE REACTOR WAS NOT ENDANGERED BECAUSE A DISSIMILAR UNIT OF LOW RELIABILITY WAS ACTIVATED. IT IS NOTeworthy THAT THIS PROBLEM OCCURRED IN A PLANT WITH AN OUTSTANDING SAFETY AND AVAILABILITY RECORD.
- 11-5-1-245 ABC GOES PUBLIC - A CASE HISTORY
 BROWN, M. C., JR.
 U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.
 IN THE SPRING OF 1969, THE U.S. ATOMIC ENERGY COMMISSION DECIDED TO TAKE THE CASE FOR NUCLEAR POWER DIRECTLY TO THE PUBLIC BY WAY OF THE TOWN HALL AND THE VILLAGE SQUARE, THE UNIVERSITY SYMPOSIUM, AND THE SPEAKER CIRCUIT, A PACTUAL

APPROACH HAS BEEN USEFUL IN COUNTERING MISINFORMATION AND IN ALLAYING UNFOUNDED FEARS. BUT THE INITIAL OUTINGS ALSO DEMONSTRATED THAT THE FACTS DO NOT ALWAYS SPEAK FOR THEMSELVES BECAUSE THEY ARE HIGHLY COMPLEX AND OCCASIONALLY CHALLENGED BY SMALL SEGMENTS OF THE SCIENTIFIC FRATERNITY. IT HAS BEEN NECESSARY TO TRANSLATE TECHNICAL JARGON INTO EVERYDAY LANGUAGE AND TO LEARN TO COMPETE WITH THE SHOWMANSHIP OF CRITICS. THE NEED FOR NUCLEAR ELECTRIC POWER IS INCREASINGLY RECOGNIZED, BUT NO SUBSTANTIAL ABATEMENT IN PUBLIC CONCERN FOR THE ENVIRONMENT IS IN SIGHT. LARGER SEGMENTS OF THE PUBLIC RECOGNIZE THAT THE SOLUTION TO THE ENVIRONMENTAL PROBLEM IS NEITHER TO TURN THE CLOCK BACK NOR THE LIGHT SWITCH OFF, AND THEY ARE PREPARED TO PAY A LITTLE MORE FOR A CLEAN ENVIRONMENT.

11-5-1-349

THE WATER REACTOR SAFETY PROGRAM PLAN

BRADBURN, M. F. + COOPER, C. M. + GILMORE, C. E.

IDAMO NUCLEAR CORPORATION, IDAMO FALLS, IDAMO

A USAEC REPORT DESIGNATED WASH-1146 HAS BEEN ISSUED TO SET FORTH A COMPREHENSIVE PLAN FOR USE BY THE DIVISION OF REACTOR DEVELOPMENT AND TECHNOLOGY IN ITS ADMINISTRATION OF WATER-REACTOR SAFETY PROGRAM AND FOR INFORMING THE NUCLEAR INDUSTRY CONCERNING THE SCOPE AND OBJECTIVES OF THE SPECIFIC PROJECTS THAT COMPOSE THE PROGRAM. THE REPORT COMPILES AND CORRELATES THE PROBLEMS AND INFORMATION NEEDS OF REACTOR SAFETY AND ASSIGNS PRIORITIES TO THE VARIOUS FACETS OF THE OVERALL PROBLEM. THE VIEWS EXPRESSED, ALTHOUGH NOT HELD UNIVERSALLY THROUGHOUT THE INDUSTRY, DO GENERALLY REPRESENT A CONSENSUS DETERMINED FROM COMMENTS SOLICITED FROM ALL MAJOR USERS OF SAFETY-RELATED INFORMATION, AND THE DOCUMENT THEREFORE FORMS AN AGREED-UPON BASIS UPON WHICH FUTURE CONSIDERATION AND DISCUSSION OF THE WATER-REACTOR SAFETY PROGRAM CAN BE FOUNDED. IT IS EXPECTED THAT THE PLAN WILL BE USED TO ASSURE THAT THE RESOURCES AVAILABLE TO THE SAFETY PROGRAM ARE APPLIED WHERE MOST NEEDED.

11-5-2-375

CRITERIA AND REQUIREMENTS FOR ROT PLANT PROTECTION SYSTEMS

WALKER, L. S.

TENNESSEE VALLEY AUTHORITY, KNOXVILLE, TENNESSEE

A SET OF GENERAL DESIGN CRITERIA AND REQUIREMENTS FOR REACTOR PROTECTION SYSTEMS HAS BEEN ISSUED AS A TENTATIVE STANDARD FOR APPLICATION TO REACTORS AND CRITICAL ASSEMBLIES UNDER THE JURISDICTION OF THE USAEC DIVISION OF REACTOR DEVELOPMENT AND TECHNOLOGY. THIS STANDARD, C 16-17, INCLUDES WITHIN ITS SCOPE ALL THE ACTIVE DEVICES, SUCH AS INSTRUMENTS, ACTUATORS, AND ELECTRIC POWER SUPPLIES, NECESSARY TO PREVENT UNACCEPTABLE RELEASE OF RADIOACTIVE MATERIALS OR UNACCEPTABLE PLANT DAMAGE. THIS STANDARD APPLIES TO THE OVERALL BEHAVIOR OF THE PROTECTION SYSTEM, RATHER THAN TO THE DESIGN OF INDIVIDUAL EQUIPMENT ITEMS. THE MAJOR SECTIONS ARE DESIGN BASIS, CRITERIA AND REQUIREMENTS, AND QUALITY ASSURANCE. EMPHASIS IS GIVEN THE DESIGN BASIS SECTION, WHICH PRESCRIBES THE INTERDISCIPLINARY INFORMATION AND ANALYSES FOR SPECIFYING THE NECESSARY PROTECTIVE FUNCTIONS, TOGETHER WITH THE SYSTEM-RELIABILITY REQUIREMENTS. CRITERIA ARE THEN GIVEN FOR PROVIDING DEFENSES AGAINST VARIOUS KINDS OF FAILURES AND FOR ACCOMMODATING THE SYSTEMS AND PROCEDURES REQUIRED TO OPERATE THE PLANT NORMALLY.

11-5-3-379

LMFOR SAFETY I. FISSION PRODUCT BEHAVIOR IN SODIUM

CASTLERMAN, A. M., JR.

BROOKHAVEN NATIONAL LABORATORY, LPTON, L.I., NEW YORK

THE POTENTIAL HAZARD PRESENTED BY THE POSSIBILITY OF FISSION-PRODUCT AND PLUTONIUM TRANSPORT FROM LIQUID METAL COOLED REACTORS INTO THE ENVIRONMENT IS A MAJOR FACTOR IN REACTOR SITING, DESIGN, AND OPERATION. FORTUNATELY CONSIDERABLE INFORMATION ON THE BEHAVIOR OF FISSION PRODUCTS IN SODIUM SYSTEMS IS AVAILABLE WITH WHICH TO ASSESS THEIR FATE UNDER CONDITIONS LIKELY TO EXIST BOTH DURING REACTOR OPERATION AND IN THE EVENT OF AN ACCIDENT. XENON AND KRYPTON ARE THE ONLY FISSION PRODUCTS THAT EXERT LARGE PARTIAL PRESSURES AND ARE THE ONLY ONES LIKELY TO BE SIGNIFICANTLY RELEASED IN THE ABSENCE OF EXTENSIVE SODIUM VAPORIZATION. UNDER INERT CONDITIONS FISSION-PRODUCT IODINE REACTS WITH SODIUM AND, EXCEPT POSSIBLY AT HIGH CONCENTRATIONS WITHIN THE SODIUM THERMAL BOND OF A FUEL ELEMENT, WILL PROBABLY BE RETAINED IN THE LIQUID SODIUM. THE ALKALINE METALS WILL DISTRIBUTE BETWEEN THE COOLANT AND THE SURFACES EXPOSED TO SODIUM, ALTHOUGH LARGE FRACTIONS WILL VAPORIZE IN THE EVENT OF SIGNIFICANT SODIUM VAPORIZATION. ANALYSIS OF THE BEHAVIOR OF BARIUM AND STRONTIUM REQUIRES FURTHER STUDY. HOWEVER, IT IS KNOWN THAT THEIR VOLATILITY IS LOW, AND THEY WILL PROBABLY INTERACT WITH THE OXYGEN DISSOLVED IN REACTOR-GRADE SODIUM AND DEPOSIT ON THE PRIMARY-SYSTEM PIPING. CALCULATIONAL METHODS ARE AVAILABLE FOR PREDICTING THE MAXIMUM EXTENT OF VAPORIZATION OF CS, RB, SA, I (AS NAH), BA, TE, AND SB AS A FUNCTION OF SODIUM VAPORIZATION.

11-5-4-391

RADIOACTIVE WASTE DISPOSAL BY HYDRAULIC FRACTURING

DE LAGUNA, W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

THE PETROLEUM INDUSTRY HAS DEVELOPED, LARGELY SINCE WORLD WAR II, THE TECHNIQUE OF HYDRAULIC FRACTURING TO INCREASE OIL RECOVERY THAT IS TODAY ALMOST UNIVERSALLY USED IN RESERVOIR

ROCKS OF LOW PERMEABILITY. SINGLE INJECTIONS OF 100,000 GAL OF OIL CONTAINING 250,000 LB OF SAND ARE NOT UNUSUAL. MUCH THE SAME EQUIPMENT AND PROCEDURE MAY BE USED FOR WASTE DISPOSAL. ALTHOUGH THERE ARE CERTAIN SIGNIFICANT DIFFERENCES. THE DISPOSAL WELL AT OAK RIDGE WAS DRILLED AND Cased TO A DEPTH OF 1000 FT IN SHALE BY USING STANDARD OIL-FIELD METHODS. THE CASING IS SLOTTED NEAR THE BOTTOM, AND FOR WASTE DISPOSAL A SELF-HARDENING MIXTURE OF WASTE, PORTLAND CEMENT, AND CLAY IS PUMPED DOWN UNDER HIGH PRESSURE TO FORM A WIDESPREAD, THIN, HORIZONTAL FRACTURE IN THE SHALE IN WHICH THE WASTE SETS UP SOLID. AFTER FOUR INJECTIONS INTO THE SAME SLOT, TOTALING ROUGHLY 500,000 GAL. THE BOTTOM OF THE WELL IS PLUGGED AND A NEW SLOT CUT SOME 10 FT HIGHER UP THE WELL. PROBLEMS THAT HAD TO BE SOLVED AT OAK RIDGE TO MAKE POSSIBLE THE OPERATIONAL DISPOSAL OF MEDIUM-LEVEL RADIOACTIVE WASTE WERE (1) DETERMINING THE GEOMETRY OF THE FRACTURES FORMED IN THE SHALE, (2) ESTABLISHING THE FORMULA FOR A SATISFACTORY WASTE-CEMENT-CLAY MIX, (3) DESIGNING AND CONSTRUCTING THE SURFACE PLANT, AND (4) FORMULATING METHODS OF MONITORING THE OPERATION.

11-6-1-435 BEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACCELERATOR CENTER
JENKINS, T. R.

STANFORD LINEAR ACCELERATOR CENTER, PALO ALTO, CALIFORNIA
THE HEALTH PHYSICS DEPARTMENT AT THE STANFORD LINEAR ACCELERATOR CENTER (SLAC) ACTIVELY PARTICIPATES WITH THE RESEARCH AREA DEPARTMENT IN PROBLEMS RELATED TO SAFE BEAM TRANSPORT AND SHIELDING. THE RESULT OF SUCH PLANNING AND DESIGN IS SET FORTH IN AN OPERATIONAL DOCUMENT KNOWN AS THE BEAM AUTHORIZATION SHEET, WHICH, ALONG WITH THE RADIATION RULE BOOK, PROVIDES THE GUIDELINES THROUGH WHICH THE ACCELERATOR, BEAM SWITCHYARD, AND RESEARCH AREA ARE OPERATED SAFELY. PLANNING AND OPERATIONAL PHASES OF RADIATION PROTECTION AT SLAC INCLUDE (1) PRIMARY ELECTRON- AND POSITION-BEAM CONTAINMENT, (2) CONTROL OF DANGEROUS SECONDARY-BEAM AREAS AND ANY THAT ARE POTENTIALLY DANGEROUS, (3) RADIATION AND SHIELDING CALCULATIONS, (4) BEAM CHECK-OUT PROCEDURES AND MEASUREMENTS, AND (5) ROUTINE MONITORING. SEVERAL CLASSIC EXAMPLES ILLUSTRATE THE INGENUITY REQUIRED TO SATISFY THE SAFETY CRITERIA ESTABLISHED AT SLAC, AND THE INFORMATION PRESENTED SHOULD BE OF PARTICULAR INTEREST TO THOSE WHO ARE PLANNING NEW ACCELERATORS.

11-6-1-445 A SYSTEMS APPROACH TO NUCLEAR PLANT SAFETY

SWEDEKER, J. T.
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
THE COMPLEXITY AND ADVANCED TECHNOLOGY OF TODAY'S NUCLEAR PLANTS WARRANT A NEW LOOK AT NUCLEAR PLANT SAFETY. THE EVALUATION TECHNIQUE ADVANCED IS BASED ON DEFINING THE EVENTS FOR WHICH A NUCLEAR PLANT MUST BE DESIGNED AND THEN SPECIFYING THE UNACCEPTABLE CONSEQUENCES OF THOSE EVENTS. IT IS THEN POSSIBLE TO SYSTEMATICALLY ANALYZE THE PLANT TO IDENTIFY THE ACTIONS, SYSTEMS, AND COMPONENTS ESSENTIAL TO ACCOMMODATING THE SPECIFIED EVENTS SO THAT UNACCEPTABLE RESULTS ARE NOT OBTAINED. THE ACTIONS, SYSTEMS, AND COMPONENTS IDENTIFIED AS ESSENTIAL MUST THEN BE DESIGNED AND OPERATED IN SUCH A WAY THAT SPECIFIED STANDARDS OF REDUNDANCY AND QUALITY ARE MAINTAINED. IN THIS WAY PLANT DESIGN AND OPERATION REFLECT A COMPREHENSIVE AND CONSISTENT BALANCE WITH RESPECT TO NUCLEAR SAFETY.

11-6-2-450 EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS
MILLER, D.

ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
THE EQUATION OF STATE IS IMPORTANT IN FAST REACTOR SAFETY STUDIES BECAUSE IT COUPLES THE RATE OF ENERGY DEPOSITION WITH THE DEFORMATIONS AND DAMAGE THAT CAN BE PRODUCED IN AN ACCIDENT. THIS FIRST PART OF A TWO-PART REVIEW DISCUSSES THE APPLICATION OF THE EQUATION OF STATE TO REACTOR PROBLEMS AND INDICATES IMPORTANT PROPERTIES AND PROCESSES, ALONG WITH LIMITATIONS ON THEIR APPLICABILITY. THE EQUATION OF STATE IS A COMPLEX ENTITY, WITH BOTH THERMAL AND MECHANICAL DEPENDENCIES. BECAUSE OF THE WIDE RANGE OF CONDITIONS THAT MIGHT BE IMPORTANT IN ACCIDENT ANALYSES, CONSIDERATION MUST BE GIVEN TO A WIDE VARIATION OF PROPERTIES. MATERIALS OF PRINCIPAL INTEREST ARE THE FUEL AND FERTILE MATERIALS (METALLIC OR CERAMIC), CLADDING AND STRUCTURAL MATERIALS (GENERALLY IRON ALLOYS), AND THE SODIUM COOLANT. EACH HAS SPECIAL CHARACTERISTICS. ALTHOUGH EXPERIMENTAL DATA ARE AVAILABLE FOR MANY OF THESE MATERIALS, THEORY AND EMPIRICISM MUST BE USED TO EXTEND AND APPLY THE DATA. PART 2 OF THIS REVIEW, SCHEDULED FOR AN EARLY ISSUE OF NUCLEAR SAFETY, WILL EMPHASIZE SOME METHODS OF MEASUREMENT AT EXTREME CONDITIONS, INCLUDING THE POSSIBLE USE OF REACTORS, AND THE STATUS OF KNOWLEDGE ABOUT SPECIFIC REACTOR MATERIALS.

11-6-2-463 FIFTH GERMAN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER PLANTS
NEPHEW, F. A.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE FIFTH GERMAN SYMPOSIUM ON PROGRESS IN THE DEVELOPMENT OF NEW METHODS FOR SAFETY ANALYSIS OF NUCLEAR POWER PLANTS WAS SPONSORED BY THE INSTITUTE FOR REACTOR SAFETY AND WAS HELD IN MANNING, GERMANY, OCT. 27-28, 1969. TEN PAPERS WERE PRESENTED IN THREE DIFFERENT SESSIONS, AND AMPLE TIME WAS PROVIDED FOR DETAILED DISCUSSION OF THE TOPICS, COVERED AND EXTENSIVELY

DISCUSSED WERE THE RELIABILITY ANALYSES OF COMPONENTS AND SYSTEMS, AS WELL AS THE ACQUISITION AND USE OF FAILURE DATA, IN THE DESIGN OF REACTOR PLANTS. IT HAS GENERALLY CONCLUDED THAT EXISTING FAILURE DATA ARE INADEQUATE FOR ABSOLUTE RISK ASSESSMENTS BUT CAN BE VERY USEFUL FOR IMPROVING PLANT AVAILABILITY AND COMPARING THE CONSEQUENCES OF ACCIDENTS. ACCORDINGLY, COLLECTION OF FAILURE DATA SHOULD BE ENCOURAGED, BUT THE USE OF THESE DATA IN RELIABILITY ANALYSES CANNOT NOW REPLACE THE MAXIMUM CREDIBLE ACCIDENT CONCEPT AS A BASIS FOR SAFETY ASSESSMENT.

11-6-3-448 INSTRUMENTATION FOR MONITORING THE HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER REACTORS

ROBINSON, T. G. + DUGGINS, B. C.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
VARIOUS ENGINEERED SAFETY FEATURES AVAILABLE IN NUCLEAR FUELED COMMERCIAL POWER STATIONS WOULD BE CALLED UPON TO COPE WITH THE CONSEQUENCES OF A LOSS-OF-COOLANT ACCIDENT. THESE SAFETY FEATURES ARE PROVIDED WITH INSTRUMENTS TO INITIATE OPERATION AND TO MONITOR CONTINUED OPERATION. WHEN THE SAFETY FEATURES WERE CALLED UPON, THE PLANT OPERATOR WOULD NEED INFORMATION REGARDING BOTH THE OPERATION OF THESE EMERGENCY SYSTEMS AND EQUIPMENT AND THE CONTINUING SUCCESS OF THEIR MISSION. A BRIEF STUDY WAS CONDUCTED TO DETERMINE THE TYPES AND EXTENT OF INSTRUMENTATION AVAILABLE IN THE DESIGNS OF REPRESENTATIVE NUCLEAR POWER PLANTS OF THE LATEST GENERATION FOR MONITORING THE COURSE OF A LOSS-OF-COOLANT ACCIDENT. THE FOUR PLANTS SURVEYED APPEARED TO HAVE ADEQUATE AND SUFFICIENT INSTRUMENTATION FOR MONITORING THE OPERATION OF THE EQUIPMENT IN THE ENGINEERED SAFETY SYSTEM FOR THE CASE OF A SUCCESSFULLY CONTAINED LOSS-OF-COOLANT ACCIDENT. HOWEVER, INSTRUMENTS FOR DIRECTLY DETECTING UNEXPECTED DAMAGE TO THE REACTOR CORE APPEAR TO BE LACKING.

11-6-4-475 SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFECTS

CLOUTIER, R. J.
OAK RIDGE ASSOCIATED UNIVERSITIES, OAK RIDGE, TENNESSEE
THE DIVISION OF BIOLOGY AND MEDICINE OF THE U.S. ATOMIC ENERGY COMMISSION AND THE ENVIRONMENTAL CONTROL ADMINISTRATION OF THE U.S. PUBLIC HEALTH SERVICE WERE THE SPONSORS OF THE SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFECTS, HELD IN OAK RIDGE, TENN., DEC. 8-11, 1969. THIS SYMPOSIUM WAS ONE OF A SERIES ON MEDICAL USES OF RADIONUCLIDES CONDUCTED BY THE MEDICAL DIVISION OF THE OAK RIDGE ASSOCIATED UNIVERSITIES. THE TOPICS OF THE 32 INVITED PAPERS MAY BE GROUPED INTO THREE GENERAL CATEGORIES - (1) MATHEMATICS FOR CALCULATING RADIATION DOSE TO A PATIENT FROM INTERNALLY ADMINISTERED RADIONUCLIDES, (2) DISTRIBUTION AND RETENTION OF RADIONUCLIDES IN PATIENTS, AND (3) BIOLOGIC EFFECTS OF RADIONUCLIDES.

11-6-4-482 LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE LATE MORTALITY RISKS FROM REACTOR ACCIDENTS

OTWAY, H. J. + EROPAKA, R. C.
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO - UCLA, LOS ANGELES, CALIFORNIA
THE LITERATURE REGARDING THE LATE SOMATIC EFFECTS OF IONIZING RADIATION WAS REVIEWED AND ESTIMATES WERE MADE OF THE MORTALITY RISK FOR LEUKEMIA AND THYROID CARCINOMA BASED ON A LINEAR THEORY OF CARCINOGENESIS. THE ESTIMATES WERE ONE DEATH PER MILLION PERSONS PER RAD OF IODINE-131 THYROID IRRADIATION AND 30 DEATHS PER MILLION PERSONS PER RAD FROM LEUKEMIA DUE TO WHOLE-BODY IRRADIATION. THESE NUMBERS ARE APPLIED TO THE DOSE-DISTANCE RELATIONS FOR HYPOTHETICAL DESIGN ACCIDENTS CALCULATED FOR PRESSURIZED-WATER AND FAST BREEDER REACTORS. IT IS CONCLUDED THAT FOR THESE POSTULATED ACCIDENTS AND REACTOR TYPES THE LONG-TERM RISK OF DEATH FROM LEUKEMIA MAY BE COMPARABLE TO OR GREATER THAN THAT FROM THYROID CARCINOMA.

11-6-5-493 REPORT ON SEMINAR OF TRIGA OWNERS

KRAKER, P.
U.S. DEPARTMENT OF THE INTERIOR, DENVER, COLORADO
A SEMINAR OF TRIGA RESEARCH-REACTOR OWNERS WAS HELD IN DENVER, COLO., IN FEBRUARY 1970. SOME OF THE REMARKS, OPINIONS, AND INFORMATION FROM THE SESSIONS ARE ASSEMBLED AND PUBLISHED IN THIS ARTICLE UNDER THE FOLLOWING HEADINGS - REACTOR FUNDING, TECHNICAL SPECIFICATIONS AND REACTOR LICENSING, TRIGA FUEL ELEMENTS, TRIGA REACTOR DESIGN IMPROVEMENTS, TRIGA EXPERIENCES, HEALTH-PHYSICS CONSIDERATIONS, AND TRIGAS AND USAEC COMPLIANCE.

12-1-1-001 RADIATION STANDARDS AND PUBLIC HEALTH

EISENHUT, R.
NEW YORK UNIVERSITY MEDICAL CENTER, NEW YORK, NEW YORK
THE RADIATION SAFETY RECORD OF THE AEC HAS BEEN GOOD, BUT CHANGES IN THE PRESENT REGULATORY SYSTEM ARE NEEDED TO RECONCILE DIFFERENCES BETWEEN PUBLIC ATTITUDES AND THE AEC. AEC REGULATIONS ARE BASED ON THE RECOMMENDATIONS OF THE ICRP AND THE NCRP, AND THE STANDARDS CONTAIN EXTENSIVE BUILT-IN CONSERVATISM. HOWEVER, THE EMPHASIS ON THE MAXIMUM PERMISSIBLE CONCENTRATIONS OF RADIONUCLIDES IN AIR AND DRINKING WATER SHOULD BE CHANGED TO SPECIFY THE MAXIMUM PERMISSIBLE DAILY INTAKE FROM ALL SOURCES TO TAKE INTO CONSIDERATION MULTIPLE SOURCES AND ECOLOGICAL FACTORS. FURTHER, THE DUAL RESPONSIBILITY OF THE AEC FOR THE

DEVELOPMENT OF NUCLEAR POWER AND THE PROTECTION OF THE PUBLIC HAS CONTRIBUTED TO LACK OF PUBLIC CONFIDENCE IN THE AEC. ACCORDINGLY IT IS RECOMMENDED THAT RESPONSIBILITIES FOR SETTING RADIATION LIMITS BE SHIFTED TO ANOTHER AGENCY OF THE FEDERAL GOVERNMENT. THE SAME AGENCY, IN COOPERATION WITH THE STATES, SHOULD ASSUME RESPONSIBILITY FOR ENVIRONMENTAL MONITORING IN THE VICINITY OF AEC-LICENSED FACILITIES.

12-1-2-000 OFFSHORE SITING OF NUCLEAR ENERGY STATIONS

ANDERSON, T. G.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

QUESTIONS INVOLVING ENVIRONMENTAL QUALITY, PRIORITY OF LAND USES, AND PUBLIC SAFETY HAVE CREATED AND WILL CONTINUE TO CREATE DIFFICULTIES IN FINDING ACCEPTABLE SITES FOR NUCLEAR POWER PLANTS. INTEREST IS INCREASING IN OFFSHORE STATIONS AS ONE SOLUTION TO THE SITING PROBLEM. INVESTIGATIONS OF OFFSHORE STATIONS HAVE INCLUDED BOTH ARTIFICIAL ISLANDS AND FLOATING PLATFORMS AND HAVE TOUCHED ON ENVIRONMENTAL EFFECTS, ECONOMICS, AND SAFETY. INDICATIONS ARE THAT MANY OF THE PROBLEMS ASSOCIATED WITH SITING NUCLEAR POWER PLANTS COULD BE ALLEVIATED BY OFFSHORE STATIONS. THE FLOATING-STATION CONCEPT, IN PARTICULAR, SEEMS TO HAVE SIGNIFICANT POTENTIAL FOR THE FUTURE. BEFORE THIS POTENTIAL CAN BE REALIZED, HOWEVER, CONSIDERABLE DEVELOPMENT OF THE CONCEPT WILL BE NEEDED.

12-1-3-005 PLUME RISE - A RECENT CRITICAL REVIEW

BRIGGS, G. A.

NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION, OAK RIDGE TENNESSEE

COMPARISONS OF A LARGE NUMBER OF PLUME-RISE OBSERVATIONS AND FORMULAS INDICATED THAT A RELATIVELY SIMPLE MODEL PROVIDED THE BEST PREDICTIONS OF PLUME RISE IN A VARIETY OF METEOROLOGICAL CONDITIONS. THE MODEL PREDICTS THAT NEAR THE STACK THE RISE OF A HOT, BUOYANT PLUME IS PROPORTIONAL TO THE RECIPROCAL OF THE WIND SPEED, TO THE ONE-THIRD POWER OF THE HEAT EMISSION, AND TO THE TWO-THIRDS POWER OF THE DISTANCE DOWNWIND. THIS "2/3 LAW" OF RISE FITS THE BULK OF PUBLISHED OBSERVATIONS. DEPENDENCE ON DISTANCE DOWNWIND GRADUALLY DIMINISHES IN NEUTRAL ATMOSPHERIC CONDITIONS BEYOND THE DISTANCE RELATED TO THE HEAT EMISSION AND THE STACK HEIGHT. IN STABLE CONDITIONS, RATHER ABRUPT LEVELING OF PLUMES OCCURS AT A "DISTANCE DEPENDENT ON THE WIND SPEED AND THE ATMOSPHERIC VERTICAL TEMPERATURE GRADIENT. THE MODEL WAS ALSO APPLIED TO THE PREDICTION OF WHETHER A HOT PLUME WILL PENETRATE AN ELEVATED INVERSION AND WAS FOUND TO AGREE WITH OBSERVATIONS.

12-1-3-025 ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM

AMERBACH, S. I.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

ONE OF THE CURRENT CONCERNS OVER THE INCREASING INSTALLATION OF NUCLEAR POWER STATIONS IS THE POTENTIAL IMPACT OF RADIOACTIVE WASTE RELEASES ON LOCAL ECOSYSTEMS. IN PARTICULAR, THE QUESTION HAS BEEN RAISED WHETHER WASTE RELEASES AT MAXIMUM PERMISSIBLE CONCENTRATION (MPC) LEVELS WOULD CAUSE ECOLOGICAL PROBLEMS DUE TO THE RADIOACTIVITY. HYPOTHETICAL ANNUAL SUBMERSION DOSE RATES FROM WATER ASSUMED TO BE MAINTAINED AT THE OCCUPATIONAL MPC X 1/30 WERE CALCULATED FOR ORGANISMS LIVING CONTINUOUSLY IN THESE WATERS. THESE HYPOTHETICAL DOSES ARE USED AS A BASIS FOR COMPARISONS IN A VARIETY OF ECOLOGICAL STUDIES OF LOW DOSES OF IONIZING RADIATION AND ARE ANALYZED AND EVALUATED IN TERMS OF DETECTABILITY OF BIOLOGICAL EFFECTS AT MPC LEVELS. PRESENT KNOWLEDGE BASED ON THESE AND SIMILAR STUDIES OF THE ECOLOGICAL EFFECTS OF LOW-LEVEL CHRONIC DOSES, SUCH AS COULD RESULT FROM ROUTINE REACTOR RELEASES UNDER CURRENT STANDARDS, GUIDELINES, AND OPERATIONAL EXPERIENCE, INDICATES THAT ANY POSSIBLE BIOLOGICAL EFFECTS WOULD BE UNDETECTABLE. ALTHOUGH THE DATA IN SUPPORT OF THIS CONTENTION ARE LIMITED, THEY CONSISTENTLY POINT TO THIS CONCLUSION.

12-1-4-035 FUEL MELTDOWN AT ST. LAURENT I

CORDETT, B. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

THE ST. LAURENT I PLANT, ELECTRICITE DE FRANCE'S NEW 500-MW(1) GAS-COOLED NUCLEAR GENERATING FACILITY, SUFFERED A FUEL MELTDOWN ON OCT. 17, 1969. DURING A ROUTINE REFUELING OPERATION, GRAPHITE ADSORBERS, INCLUDING A GRAPHITE FLOW RESTRICTOR, WERE MISTAKENLY LOADED AT THE TOP OF A FUEL ELEMENT CHANNEL. THE COOLANT-FLOW REDUCTION DAMAGED 6 OF THE 10 FUEL ELEMENTS IN THIS CHANNEL, AND THERE WAS SOME EVIDENCE THAT UP TO 10 KG OF URANIUM (EQUIVALENT TO A COMPLETE FUEL ELEMENT) COMPLETELY MELTED. SUBSEQUENT CLEANUP AND PLANT MODIFICATIONS WERE EXPECTED TO REQUIRE ABOUT 1 YEAR OF REACTOR DOWNTIME.

- 12-2-1-75 THE IAEA-AEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR POWER
GIFFORD, F. A., JR.
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK
RIDGE, TENNESSEE
A SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR POWER STATIONS
WAS HELD IN NEW YORK CITY, AUG. 10-14, 1970. THE PRINCIPAL TOPICS
CONSIDERED WERE: NUCLEAR POWER AS AN ENERGY SOURCE, STANDARDS
FOR THE CONTROL OF EFFLUENTS, EFFLUENT CONTROL AND MONITORING,
CONSIDERATIONS AFFECTING STEAM POWER-STATION SITE SELECTION,
AND BENEFIT VS. RISK ASSESSMENT.
- 12-2-1-83 AN APPRECIATION OF FAST REACTOR SAFETY-1970
RASSMUSSEN, N. C.
MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASSACHUSETTS
THIS IAEA REPORT CONCISELY SUMMARIZES CURRENT THINKING IN THE
UNITED KINGDOM WITH REGARD TO FAST REACTOR SAFETY -
SPECIFICALLY, SODIUM-COOLED FAST REACTOR SAFETY. THE PRINCIPAL
PURPOSE OF THE REPORT IS STATED, AS FOLLOWS, BY P. R. FARMER IN
THE FOREWORD - IT IS IMPORTANT FOR ALL COUNTRIES THAT FAST
REACTORS SHOULD BE SAFE AND THAT SAFETY SHOULD NOT BE A MATTER
OF COMMERCIAL BARGAINING. THE IMMEDIATE NEED NOW IS TO DEVELOP
A COMMON INSIGHT INTO THE TECHNICAL UNCERTAINTIES OF FAST
REACTORS, FROM WHICH MAY EVOLVE A SAFETY PHILOSOPHY WHICH CAN
BE MEANINGFULLY PURSUED BY ALL COUNTRIES. THERE IS STILL A LOT
FOR MORE WORK AND IN THE BELIEF THAT PROBLEMS OF ALL MAJOR
SYSTEMS REQUIRE INTERNATIONAL RECOGNITION AND JOINT EFFORT IN
THEIR SOLUTION, THIS APPENDIX IS OFFERED IN THE HOPE THAT THE
COMMENT AND CRITICISM IT MIGHT EVOKE COULD LEAD TO A SECOND
IMPROVED VERSION WITH CONTRIBUTIONS FROM OTHER NATIONS.
- 12-2-2-85 RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONAL DATA
MINT, D. C.
DOW CHEMICAL COMPANY, GOLDEN, COLORADO
A STUDY WAS MADE OF THE POSSIBLE HAZARD OUTSIDE AN ENCLOSURE
DUE TO INCIDENTAL RELEASE FROM THE ENCLOSURE FOLLOWING THE
UNCONTROLLED RELEASE OF PLUTONIUM WITHIN THE ENCLOSURE BY
REVIEWING THE EXISTING OBSERVATIONAL DATA ON SUCH RESTRICTED
PLUTONIUM RELEASES. OBSERVATIONS BASED ON BOTH ACCIDENT
EXPERIENCE AND EXPERIMENTS DESIGNED TO STUDY THE RESTRICTED
RELEASE WERE CONSIDERED. THE CONCLUSION BASED ON THE
OBSERVATIONAL DATA IS THAT RESTRICTED RELEASE IS UNLIKELY TO
LEAD TO DANGEROUS FREE RELEASE OF A PLUTONIUM AEROSOL. A
REMARKABLE EXAMPLE OF THIS WAS THE FIRE AT THE ROCKY FLATS
PLANT ON MAY 11, 1969. ONLY A MINUTE AMOUNT OF THE PLUTONIUM
INVOLVED IN THE FIRE ESCAPED FROM THE BUILDING IN WHICH THE
FIRE OCCURRED, AND NO PLUTONIUM WAS DETECTED BEYOND THE PLANT
BOUNDARIES.
- 12-2-3-90 FISSION PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED REACTORS
BAURMAN, C. D.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
AN APPLICATIONS STUDY IS MADE OF RADIATION MEASURING
INSTRUMENTS AND SYSTEMS THAT MIGHT BE SUITABLE FOR DEVELOPMENT
AS MONITORS OF THE FISSION PRODUCT ACTIVITY OF THE PRIMARY
GAS-COOLANT STREAM IN HIGH TEMPERATURE GAS-COOLED REACTORS.
PARTICULAR ATTENTION IS GIVEN TO THE PLATEOUT IN LOOP
COMPONENTS, PRIMARILY THE HEAT EXCHANGERS. THE DETECTORS
REVIEWED ARE IONIZATION CHAMBERS, BETA AND GAMMA SPECTROMETERS,
CHARGED-WIRE PRECIPITATORS, Cerenkov DETECTORS, FILTERS,
DIFFUSION TUBES, THERMAL-GRADIENT TUBES, DEPOSITION TUBES, AND
IMPACTORS. THE PRINCIPLE OF OPERATION OF EACH IN A SYSTEM IS
DESCRIBED, AND THE ADVANTAGES AND DISADVANTAGES IN APPLICATION
TO THE PROBLEM ARE EVALUATED. ON THE BASIS OF LITERATURE
REQUIREMENTS, GAS STREAM SAMPLING TECHNIQUES, CONCURRENCY OF
READOUT, AND THE CHARACTERISTIC MERITS OF THE INDIVIDUAL
SYSTEMS, IT APPEARS THAT THE DEPOSITION TUBE AND GAMMA
SPECTROMETER SYSTEMS CAN BE FURTHER DEVELOPED AS COMPETENT
PLATEOUT MONITORS FOR HIGH TEMPERATURE GAS LOOPS IN NUCLEAR
REACTOR SERVICE.
- 12-2-4-100 THE ELEVENTH AEC AIR CLEANING CONFERENCE
MOELLER, D. W.
HARVARD UNIVERSITY, BOSTON, MASSACHUSETTS
THE ELEVENTH AEC AIR-CLEANING CONFERENCE WAS HELD
AUG. 31-SEPT. 3, 1970, IN RICHMOND, VA. THE SUBJECTS DISCUSSED
WERE (1) SODIUM AEROSOLS FROM LIQUID METAL-COOLED FAST BREEDER
REACTORS (2) WATER-REACTOR FISSION PRODUCT RELEASE ESTIMATIONS
(3) REMOVAL AND BEHAVIOR OF FISSION PRODUCT GASES (4) IODINE
CHARACTERIZATION AND REMOVAL (5) OTHER FILTRATION STUDIES (6)
INSTRUMENT DEVELOPMENT AND EVALUATION (7) EFFECTS OF AIRBORNE
RADIOACTIVE MATERIALS (8) FIRE SAFETY AND (9) STANDARDS
DEVELOPMENT. THE PROCEEDINGS OF THE CONFERENCE WERE PUBLISHED
IN JANUARY 1971.
- 12-2-5-110 PREDICTING SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTAL LOCATIONS
COLLINS, J. P.
THE RESEARCH CORPORATION OF NEW ENGLAND, HARTFORD, CONNECTICUT
A METHOD OF PREDICTING THE TRANSPORT DISTANCE REQUIRED TO
COMPLETE THE TRANSITION FROM OVERWATER TO OVERLAND DIFFUSION AS
A FUNCTION OF PLUME HEIGHT, WIND SPEED, AND VERTICAL
TEMPERATURE PROFILE WAS SUGGESTED BY ISAAC VAN DER MOVEN IN

NUCLEAR SAFETY FOR SEPT.-OCT. 1967. THIS ARTICLE DESCRIBES FIELD STUDIES CONDUCTED ON THE SHORES OF CAPE COD BAY DURING THE SUMMER OF 1967 TO TEST THE ACCURACY OF VAN DER HOVEN'S TECHNIQUE AND ITS APPLICABILITY TO IRREGULAR TERRAIN. THE RESULTS OF THE STUDY SHOW THAT THE METHOD OFFERS A PRACTICAL TOOL FOR COMPILING A SEA-BREEZE FUMIGATION CLIMATOLOGY.

12-2-5-114

METEOROLOGICAL EFFECTS OF THE HEAT AND MOISTURE PRODUCED BY MAN
MARRA, S. R. + SHISLER, S. D.
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK RIDGE, TENNESSEE
INTERACTIONS AMONG THE HEAT AND MOISTURE PRODUCED BY MAN AND ALL SCALES OF ATMOSPHERIC PHENOMENA ARE BEING STUDIED IN LIGHT OF CURRENT OBSERVATIONS AND FUTURE PROJECTIONS OF ENERGY CONSUMPTION. ATMOSPHERIC PROCESSES ARE BEING SIGNIFICANTLY INFLUENCED ON LENGTH SCALES UP TO ABOUT 20 KM. A FIGURE THAT IS LIKELY TO INCREASE AS ENERGY PRODUCTION INCREASES. PRESENT RESEARCH EFFORTS ON THESE ATMOSPHERIC INTERACTIONS ARE INSUFFICIENT AND PROGRAMS TO SUPPLEMENT THESE ARE NEEDED.

12-2-6-123

FUEL MELTING INCIDENT AT THE FERMI REACTOR ON OCT. 5, 1966
SCOTT, R. L., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
ON OCT. 5, 1966, THE ENRICO FERMI 1 NUCLEAR REACTOR SUSTAINED THE PARTIAL MELTING OF TWO FUEL SUBASSEMBLIES AS THE RESULT OF COOLANT FLOW BLOCKAGE. IT HAS DETERMINED THAT A COMPONENT WITHIN THE REACTOR VESSEL HAD VIBRATED LOOSE AND CAUSED FLOW BLOCKAGE WHEN HYDRODYNAMIC FORCES CARRIED IT UP TO THE INLET NOZZLE OF THE FUEL SUBASSEMBLIES. RECOVERY OPERATIONS WERE SUCCESSFUL AND WERE CLIMAXED BY FULL POWER OPERATION AT 200 MW(1) (45 MW(E)) ON OCT. 16, 1976. MANY REPORTS AND ARTICLES HAVE BEEN WRITTEN ABOUT THE INCIDENT DURING THE PAST 4 YEARS, BUT MOST OF THESE WERE FRAGMENTARY BECAUSE THE INVESTIGATIONS AND ANALYSES HAD NOT BEEN COMPLETED. THIS REVIEW WAS PREPARED TO PRESENT A CONCISE DESCRIPTION OF THE INCIDENT AND SUMMARY OF THE RESULTS OF THE INVESTIGATIONS. THE SEQUENCE OF EVENTS LEADING UP TO THE INCIDENT AND DURING THE INCIDENT IS REVIEWED. THE CONSIDERATIONS THAT LED TO UNDERSTANDING WHAT HAD TRANSPIRED ARE PRESENTED, AND THE LESSONS DERIVED FROM THE INCIDENT ARE DISCUSSED.

12-2-6-134

REPORT ON THE 1970 AAS CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENTS
SCOTT, R. L., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
FIFTY-THREE PAPERS WERE PRESENTED AT THE AMERICAN NUCLEAR SOCIETY'S 1970 CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENTS. THE PAPERS COVERED THE MAIN SUBJECT AREAS OF QUALITY ASSURANCE, SAFETY AND INSTRUMENTATION SYSTEMS, COMMERCIAL REACTORS, AND ADVANCED REACTORS. SOME OF THE MORE INTERESTING AND INFORMATIVE ASPECTS OF THE PAPERS INCLUDED STARTUP EXPERIENCES AT A COMMERCIAL NUCLEAR POWER PLANT, REVIEWS OF THE NUCLEAR STANDARDS PROGRAMS IN THE UNITED STATES, RESULTS OF LOSS-OF-COOLANT ACCIDENT STUDIES, AND RESULTS OF A SIMULATED ACCIDENT IN AN ACTUAL CONTAINMENT STRUCTURE.

12-3-1-105

RADIATION IN PERSPECTIVE - SOME COMPARISONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS
MILL, A. P.
BROOKHAVEN NATIONAL LABORATORY, UPTON, L.I., NEW YORK
FOSSIL AND NUCLEAR FUELED STEAM PLANTS SEEM THE PRACTICAL MEANS FOR MEETING IMMEDIATE POWER NEEDS. THE USE OF NUCLEAR FUELED PLANTS IS BEING RESTRICTED BY SEVERAL INSTANCES BECAUSE REACTOR RELATED HAZARDS HAVE BEEN EXAGGERATED. NINETY POWER REACTORS, IN THE UNITED STATES AND ABROAD, HAVE GENERATED 2.5×10^{16} KWH OVER 450 REACTOR YEARS WITHOUT SERIOUS INCIDENTS. COMPARISON OF ROUTINE DISCHARGES OF HAZARDOUS AGENTS FROM DIFFERENT TYPES OF STEAM POWER PLANTS SHOWS THAT NUCLEAR FUELED PLANTS PRODUCE THE LOWEST CONCENTRATIONS OF SUCH AGENTS RELATIVE TO PROTECTION STANDARDS. RADIOACTIVE RELEASES ASSOCIATED WITH THE BROOKHAVEN GRAPHITE RESEARCH REACTOR ARE COMPARABLE TO THE UPPER AMOUNTS ANTICIPATED FROM 1000-MW(E) REACTORS, AND THE MEASURED BROOKHAVEN EXTERNAL RADIATION LEVELS, DEPOSITION, AND AQUATIC CONCENTRATIONS SUGGEST THAT THE RADIATION LEVEL IN THE VICINITY OF LARGE POWER REACTORS SHOULD BE INSIGNIFICANT. THE CALCULATED RISK (ABOUT 10^{-6} P-71/YEAR) OF FATAL INJURY FROM THE ANTICIPATED MAXIMUM EXPOSURES OF A FEW MILLIREMS PER YEAR ABOVE NATURAL BACKGROUND IS SMALL COMPARED WITH THAT OF OTHER ACCEPTED HAZARDS OF EVERYDAY LIVING.

12-3-1-196

CREST SUMMARY - WATER-COOLED REACTOR SAFETY
COTTRELL, M. B.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE COMMITTEE ON REACTOR SAFETY TECHNOLOGY OF THE ORGANIZATION FOR ECONOMIC COOPERATION AND DEVELOPMENT HAS PUBLISHED AN ASSESSMENT OF WATER-COOLED REACTOR SAFETY. THIS ASSESSMENT SUMMARIZES OVER 3 YEARS OF EFFORT BY A WORKING GROUP OF SOME OF THE MOST QUALIFIED EUROPEAN NUCLEAR SAFETY EXPERTS. FOR THE PURPOSES OF THIS REPORT, THE SCOPE OF WORK IS DIVIDED INTO EIGHT AREAS, AND IN EACH AREA, TO THE EXTENT PRACTICAL, THE PROBLEM IS DEFINED, ANALYTICAL METHODS ARE SURVEYED, AVAILABLE EXPERIMENTAL AND THEORETICAL PROGRAMS ARE EVALUATED, AND THE

EFFECTS ON ACCIDENT ANALYSIS ARE NOTED. THE EIGHT AREAS SO COVERED INCLUDE (1) THERMODYNAMIC EFFECTS OF BLOWDOWN (2) EMERGENCY CORE COOLING (3) BEHAVIOR OF MOLTEN CORE MATERIALS (4) MISSILE EFFECTS ON CONTAINMENT, PIPES, AND COMPONENTS (5) CONTAINMENT SYSTEM RESPONSE (6) FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL (7) RELIABILITY ANALYSIS IN REACTOR DESIGN AND SAFETY ASSESSMENT AND (8) POWER TRANSIENTS CAUSED BY REACTIVITY ADDITION.

- 12-3-2-203 RESTRICTED RELEASE OF PLUTONIUM II. THEORY
MINT. D. C.
THE OOW CHEMICAL COMPANY, GOLDEN, COLORADO
A STUDY WAS MADE OF THE POSSIBLE HAZARD OUTSIDE AN ENCLOSURE DUE TO UNCONTROLLED RELEASE OF PLUTONIUM WITHIN THE ENCLOSURE. IN PART I OF THIS STUDY, WHICH WAS PUBLISHED IN NUCLEAR SAFETY, VOL. 12, NO. 2, A REVIEW WAS MADE OF EXISTING OBSERVATIONAL DATA ON SUCH RESTRICTED PLUTONIUM RELEASES. IN THIS SECOND AND LAST PART OF THE STUDY, A MODEL OF RESTRICTED RELEASE IS DEVELOPED. THE MODEL PREDICTS 'FREE-RELEASE' SOURCE STRENGTHS AS A FUNCTION OF THE VARIABLES ASSUMED TO DESCRIBE THE RELEASE. AN ILLUSTRATION OF THE USE OF THE THEORETICAL METHODS IS GIVEN BY APPLYING THEM TO THE ROCKY PLATS CRITICAL MASS FACILITY TEST CELL. THESE PARTICULAR CALCULATIONS SHOW THAT THE ACTUAL RELEASE WOULD BE SIGNIFICANTLY LESS THAN THE ALLOWABLE PLUTONIUM-239 MPC VALUE FOR INSOLUBLE MATERIAL IN CONTROLLED AREAS IF NOMINAL VALUES ARE ASSUMED FOR ALL RELEASE PARAMETERS. A PARAMETRIC STUDY INDICATED THAT THE CALCULATED RESULTS ARE MOST SENSITIVE TO THE RATE OF RELEASE OF PLUTONIUM WITHIN THE ENCLOSURE AND TO THE ASSUMED THERMAL EQUILIBRIUM CONDITIONS WITHIN THE ENCLOSURE.
- 12-3-3-217 REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS
JOSLIN, W. M. + MOORE, J. S. + RUSS, J. C.
AMERICAN NATIONAL STANDARDS INSTITUTE, OAK PARK, ILLINOIS -
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA -
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
THE EFFORTS BEING MADE BY THE AMERICAN NATIONAL STANDARDS INSTITUTE, INC., THE AMERICAN NUCLEAR SOCIETY, AND THE INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS IN PROMOTING ENGINEERING STANDARDS DEVELOPMENT PROGRAMS FOR NUCLEAR POWER SYSTEMS ARE DISCUSSED BY THREE LEADERS IN THE FIELD. SOME EXAMPLES ARE GIVEN OF THE DIFFICULTIES AND THE SATISFACTIONS, AND SOME SUGGESTIONS ARE MADE FOR SOLVING THE PROBLEMS. THE REVIEWERS PRESENT A GENERAL CONCLUSION THAT THE TIME ELAPSE FROM INCEPTION TO ADOPTION NEEDS TO BE SHORTENED AND THAT MORE PARTICIPATION AND CLOSER COORDINATION ARE NEEDED AMONG GROUPS HAVING OVERLAPPING INTERESTS.
- 12-3-3-226 THE USE OF ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL SAFE DESIGN
EPLER, E. P. + DITTO, S. J.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
SOME OF THE PRINCIPLES GOVERNING CURRENT DESIGNS OF ELECTRICAL OR ELECTRONIC VOTING LOGIC SYSTEMS CAN BE APPLIED TO THE DESIGN OF CONTROL AND PROTECTION SYSTEMS WHERE THE VOTING LOGIC IS AT THE LEVEL OF THE LARGE ELECTROMECHANICAL DEVICES THAT ACT DIRECTLY TO CONTROL A PROCESS. THIS APPLICATION IS OF PARTICULAR BENEFIT IN SYSTEMS FOR WHICH THERE MAY BE A SIGNIFICANT PENALTY FOR FAILURE IN THE SO-CALLED SAFE MODE AS WELL AS IN THE UNSAFE MODE. SUCH SYSTEMS HAVE FREQUENTLY MADE USE OF 'FAILURE-TO-DANGER' TECHNIQUES, WHICH IN SOME AREAS MIGHT LEAD TO A COMPROMISE OF SAFETY OBJECTIVES. THE USE OF ACTUATORS AS LOGIC ELEMENTS ALLOWS THE DESIGN OF SIMPLER SYSTEMS, WITH MORE COMPLETE TESTABILITY, AND CAN PROVIDE AN ULTIMATE GAIN IN SAFETY.
- 12-3-4-234 NUCLEAR SAFETY IN AMERICAN RADIOCHEMICAL PROCESSING PLANTS
UNGER, W. E. + BRONDER, P. W. + MANN, S.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
WITH THE PROJECTED RAPID GROWTH OF NUCLEAR ELECTRIC POWER GENERATION AND THE ACCOMPANYING GROWTH IN REPROCESSING OF SPENT NUCLEAR FUEL, THE WHOLE AREA OF NUCLEAR AND RADIOCHEMICAL SAFETY BECOMES INCREASINGLY IMPORTANT. THERE IS AN INDICATED WORLDWIDE NEED FOR INFORMATION ON ACCEPTED PRACTICES, RECOMMENDED METHODS, AND REGULATIONS FOR SAFE OPERATION IN RADIOCHEMICAL PROCESSING PLANTS. EXPERIENCE AND DEVELOPMENTS IN THE UNITED STATES ARE DESCRIBED TO ILLUSTRATE SAFETY CONSIDERATIONS IN ALL STAGES FROM SITE SELECTION AND LICENSING THROUGH DESIGN, CONSTRUCTION, AND OPERATION AND MAINTENANCE OF PROCESSING PLANTS.
- 12-4-1-283 NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE DENIGN GIANT
HES., D. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
PREMISED ON THE ASSUMPTION THAT THE PUBLIC PRESS IS BOTH A HOLDER OF OPINION AND A REFLECTOR OF PUBLIC INTEREST AND CRITIQUE, NEARLY 800 ITEMS IN THE DAILY AND PERIODICAL PRESS PERTAINING TO THE NUCLEAR INDUSTRY AND COVERING A PERIOD OF ABOUT 1 YEAR WERE EXAMINED FOR THEIR PHILOSOPHICAL AND PSYCHOLOGICAL IMPACT ON THE READER. ACCORDINGLY THIS SURVEY IS A RETROSPECTIVE ASSESSMENT IN ORDER OF PRIORITY OF THE PRINCIPAL CONTROVERSIAL ISSUES CONFRONTING THE NUCLEAR COMMUNITY. THE HOPE IS THAT, FROM THIS WORK, NUCLEAR ADVOCATES

AND ALLIED INTERESTS MAY FIND A FIRMER SENSE OF DIRECTION AND SIGNIFICANT AREAS WHERE SPECIAL ATTENTION CAN BE MOST PROFITABLY DEVOTED TO AFFORD THE PUBLIC THE REASSURANCES IT NEEDS TO FEEL AT EASE IN THE PRESENCE OF THE ENERGY GIANT.

12-4-1-298 NUCLEAR LIABILITY INSURANCE - A BRIEF HISTORY REFLECTING THE SUCCESS OF NUCLEAR SAFETY
MORRONE, J.

NUCLEAR ENGINEERING LIABILITY INSURANCE AGENCY, NEW YORK, NEW YORK
NUCLEAR LIABILITY INSURANCE HAS BEEN MADE AVAILABLE TO THE NUCLEAR INDUSTRY BY AMERICAN INSURERS THROUGH POOLING ARRANGEMENTS THAT DISTRIBUTE THE RISK AMONG MANY PARTICIPATING INSURERS. THE LIABILITY INSURANCE AFFORDED BY THE POOLS HAS TUNIS FAR BEEN THE ONLY MEANS EMPLOYED TO SATISFY THE FINANCIAL PROTECTION REQUIREMENTS IMPOSED BY THE AEC ON SOME OF ITS LICENSEES. THE EXTRAORDINARY SAFETY RECORD OF THE NUCLEAR INDUSTRY IS QUITE VISIBLE IN THE POOLS' LIABILITY CLAIMS EXPERIENCE. THE MOST SIGNIFICANT FACT ISSUING FROM 14 YEARS OF OPERATION IS THAT THE NUCLEAR LIABILITY POOLS HAVE NEVER RECEIVED A CLAIM FOR BODILY INJURY OR PROPERTY DAMAGE CAUSED DURING THE OPERATION OF A LICENSED NUCLEAR REACTOR - THIS INCLUDES ALL TYPES OF LICENSED REACTORS. CRITICS OF NUCLEAR SAFETY HAVE PLAYED A ROLE IN ACHIEVING THIS RECORD. THE LIABILITY LOSS EXPERIENCE OF THE NUCLEAR INDUSTRY SUGGESTS THAT A POSITIVE IMAGE OF SAFETY IN THE NUCLEAR INDUSTRY COULD BE PROMOTED BY PRESENTING IT AS AN EXAMPLE, WARRANTING EVALUATION, OF EFFECTIVE CONTROL OF A RELATIVELY NEW AND SERIOUS HAZARD. THAT OVER 1 MILLION PERSONS HAVE BEEN KILLED IN CONVENTIONAL ACCIDENTS IN THE UNITED STATES IN THE 10-YEAR PERIOD 1960 TO 1969 STRONGLY SUGGESTS THAT MUCH COULD BE LEARNED FROM THE NUCLEAR SAFETY PROGRAM BY THOSE WHO ARE CONCERNED ABOUT SAFETY IN THE NONNUCLEAR AREA.

12-4-2-297 FISSION GAS EFFECTS IN REACTOR FUELS 1. BASIC STUDIES
CARROLL, R. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE LITERATURE DEALING WITH THE BASIC PROCESSES OF FISSION-GAS BEHAVIOR IN REACTOR FUEL MATERIALS WHICH HAS PUBLISHED BETWEEN 1960 AND THE FALL OF 1970 IS REVIEWED. PARTICULAR ATTENTION IS CALLED TO THE 85 PUBLICATIONS CITED, AND NO ATTEMPT IS MADE TO PROVIDE A COMPREHENSIVE SUMMARY OF THEM. A CONSISTENT PATTERN IS SHOWN FOR ALL THE FUELS STUDIED. FISSION GAS WITHIN THE FUEL MATRIX DIFFUSES RAPIDLY EVEN AT COMPARATIVELY LOW TEMPERATURES. HOWEVER, THE GAS IS ATTACHED TO TRAPPING SITES WITH A FORCE THAT DEPENDS ON THE NATURE OF THE SITE AND THE NUMBER OF GAS ATOMS COLLECTED AT THE SITE. VARIOUS DRIVING FORCES CAN DISLODGE THE GAS ATOMS FROM THE SITE, AND NEW SITES CAN BE CREATED BY IRRADIATION, THUS GAS BEHAVIOR DURING FISSIONING DEPENDS ON VARIOUS TRAPPING AND DRIVING FORCES.

12-4-2-305 RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUCTION
RIVERO, J. S.

SANDIA LABORATORIES, ALBUQUERQUE, NEW MEXICO
A QUANTITATIVE APPROACH TO SYSTEM SAFETY HAS BEEN DEVELOPED. THE RISKS FROM COMPONENT ACTIVITIES ARE EXPRESSED AS EXPLICIT FUNCTIONS OF THE RESOURCES AVAILABLE FOR THEIR REDUCTION, AND THE MINIMUM SYSTEM RISK IS THEN FOUND BY DYNAMIC PROGRAMMING. NUMERICAL EXAMPLES OF THE METHOD ARE GIVEN.

12-4-3-310 JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR SCIENCE GROUPS - 1970
MAGEN, E. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE SECOND JOINT SYMPOSIUM BY THE IEEE POWER AND NUCLEAR SCIENCE GROUPS ON THE GENERAL TOPIC OF NUCLEAR POWER, CONTROL, AND INSTRUMENTATION WAS HELD IN NEW YORK CITY, NOV. 3-6, 1970. THE TALKS AND PAPERS PRESENTED TOTALLED 121 AT 15 SESSIONS, OF WHICH TWO WERE TUTORIAL. ENVIRONMENTAL CONSIDERATIONS WERE THE SUBJECT OF THE GENERAL MEETING, AND THE LUNCHEON SPEAKER DEFENDED TECHNOLOGY. THE TECHNICAL SESSIONS COVERED SOME OPERATING EXPERIENCES, RELIABILITY ANALYSES, AND STANDARDS FOR NUCLEAR POWER STATIONS. THERE WERE ALSO PAPERS ON NUCLEAR INSTRUMENTATION FOR RESEARCH AND DEVELOPMENT IN NUCLEAR PHYSICS, BIOMEDICINE, SPACE EXPLORATION, AND DATA COLLECTING.

12-4-4-320 ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE ENVIRONMENT
BLWOOD, J. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
A RAPIDLY EXPANDING NUCLEAR POWER ECONOMY HAS RESULTED IN INCREASED PUBLIC CONCERN OVER RELEASES OF RADIONUCLIDES TO THE ENVIRONMENT. REVIEW OF AVAILABLE LITERATURE ON TRITIUM, ONE OF THE RADIONUCLIDES RELEASED TO THE ENVIRONMENT AT NUCLEAR POWER REACTORS AND FUEL REPROCESSING PLANTS, INDICATES THAT TRITIUM CAN BE TAKEN IN BY PLANTS AND ANIMALS AND ORGANICALLY BOUND, REGARDLESS OF THE MEANS OF EXPOSURE. HOWEVER, THERE APPEARS TO BE NO CONCENTRATION FACTOR RELATIVE TO HYDROGEN AT ANY LEVEL OF FOOD CHAINS ANALYZED TO DATE. ISOTOPE EFFECTS APPARENTLY DO NOT SIGNIFICANTLY ALTER TRITIUM BEHAVIOR COMPARED WITH THAT OF STABLE HYDROGEN (HYDROGEN-1) IN NATURAL ECOSYSTEMS. TURNOVER TIMES OF TRITIUM IN COUPLED ECOSYSTEM COMPARTMENTS ARE DEPENDENT ON CLIMATIC, HYDROLOGICAL, AND METEOROLOGICAL FACTORS AND THUS ARE SITE SPECIFIC FOR EACH ECOSYSTEM. HALF-TIMES ARE MUCH LONGER IN A DESERT ECOSYSTEM COMPARED WITH THOSE IN A TROPICAL RAIN FOREST. THE TOTAL ECOSYSTEM WILL HAVE A

HALF-TIME OF RETENTION AT LEAST AS LONG AS THE COMPARTMENT WITH THE LONGEST HALF-TIME. TRITIUM BODY BURDEN IS DEPENDENT ON THE PATHWAYS OF EXPOSURE. TISSUE-BOUND FRACTIONS ARISE PRIMARILY FROM ORGANICALLY BOUND TRITIUM IN FOOD. BIOLOGICAL HALF-LIVES OF TISSUE-BOUND FRACTIONS ARE LONGER THAN THE HALF-LIFE OF THE BODY-WATER COMPONENT AND MAY BE AS LONG AS ONE-THIRD OF THE ORGANISM'S LIFE-SPAN. TRITIUM IN ALL COMPARTMENTS IN A CHRONICALLY CONTAMINATED ECOSYSTEM WOULD BE EXPECTED TO BE UNIFORMLY LABELED WITH HYDROGEN-3, WITH THE TRITIUM RATIO BEING DEPENDENT ON RELEASE LEVELS.

12-4-5-338

IAEA - WHO SYMPOSIUM ON HANDLING OF RADIATION ACCIDENTS

ROMNER, P. S.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

A SYMPOSIUM ENTITLED "HANDLING OF RADIATION ACCIDENTS" WAS HELD IN VIENNA ON MAY 19-23, 1969. IT WAS ORGANIZED BY THE INTERNATIONAL ATOMIC ENERGY AGENCY (IAEA) AND THE WORLD HEALTH ORGANIZATION (WHO) TO ENABLE RADIATION MONITORING AND DOSIMETRY SPECIALISTS, MEDICAL DOCTORS EXPERIENCED IN DIAGNOSING AND TREATING RADIATION INJURY, NUCLEAR SAFETY AND WASTE MANAGEMENT SPECIALISTS, PUBLIC RELATIONS OFFICERS, AND MANY OTHERS TO DISCUSS RADIATION ACCIDENTS ON A VERY BROAD BASIS. THE LIST OF SESSION TOPICS INDICATES THE SCOPE OF THE SYMPOSIUM - ORGANIZATION AND PLANNING, EARLY ACCIDENT CONTROL MEASURES, MONITORING AND DOSIMETRY, DECONTAMINATION AND PROTECTIVE MEASURES, MEDICAL MANAGEMENT OF EXPOSED OR CONTAMINATED PERSONS, FUTURE EMPLOYMENT OF OVEREXPOSED PERSONS, AND REVIEW OF SELECTED ACCIDENTS. THE AGENDA INCLUDED 54 PAPERS AND A PANEL DISCUSSION ON SYMPOSIUM PROGRAM HIGHLIGHTS AND RECOMMENDATIONS FOR FURTHER WORK RELATIVE TO RADIATION ACCIDENTS. TWO HUNDRED AND TWELVE PARTICIPANTS FROM 34 COUNTRIES AND 9 INTERNATIONAL ORGANIZATIONS PARTICIPATED IN THE SYMPOSIUM. THE PROCEEDINGS OF THE SYMPOSIUM HAVE BEEN PUBLISHED BY THE IAEA AS REPORT STI/PLB/229.

12-5-1-421

LMFBR SAFETY

ROSE, U.

ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS

THIS REVIEW OF LIQUID METAL COOLED FAST BREEDER REACTOR SAFETY EMPHASIZES THE RESEARCH EFFORT AND RECENT RESULTS OF THE MAJOR RESEARCH AND DEVELOPMENT PROGRAMS OF THE U.S. ATOMIC ENERGY COMMISSION AND OF U.S. INDUSTRY. THE SAFETY PROGRAM FOR THE LIQUID METAL COOLED FAST BREEDER REACTOR STRESSES ACCIDENT PREVENTION AND THE EARLY DETECTION AND CONTROL OF POTENTIAL ACCIDENTS. THE MAIN AREAS OF INTEREST INCLUDE THE INVESTIGATION OF FUEL BEHAVIOR AND OF FUEL FAILURE PROPAGATION, THE UNDERSTANDING OF THE PHENOMENA INVOLVED IN REACTIVITY ACCIDENTS AND THE DEVELOPMENT OF TECHNIQUES TO ASSESS THEIR EFFECTS, THE MECHANICAL RESPONSES OF REACTOR SYSTEMS TO ACCIDENTS, AND THE CONTAINMENT OF THE CONSEQUENCES OF POSTULATED ACCIDENTS.

12-5-1-433

LIGHT WATER REACTOR SAFETY

BRIGHT, G. O.

AERJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO

LIGHT WATER REACTOR SAFETY PROBLEMS ARE PRIMARILY ASSOCIATED WITH THE LARGE POWER REACTORS NOW BEING CONSTRUCTED. CONSIDERATION OF THESE COMPLEX SYSTEMS HAS RESULTED IN THE DEVELOPMENT OF A WATER REACTOR SAFETY PROGRAM PLAN, WHICH REPRESENTS AN INDUSTRY WIDE CONSENSUS ON ISSUES, NEEDS, AND PRIORITIES. THE PRINCIPAL ISSUES ARE IDENTIFIED AS DEVELOPMENT AND CONFIRMATION OF ANALYTICAL TECHNIQUES FOR DESIGN AND SAFETY EVALUATION. SPECIFIC AREAS OF GREATEST IMPORTANCE ARE EMERGENCY CORE COOLING CAPABILITY, FUEL FAILURE PHENOMENA UNDER ABNORMAL CONDITIONS, AND DEVELOPMENT OF NEEDED STANDARDS AND QUALITY ASSURANCE PROCEDURES. CURRENT AND PLANNED FUTURE PROGRAMS SHOULD PROVIDE ADEQUATE CAPABILITY FOR SOLUTION OF PROBLEMS THAT CAN BE IDENTIFIED AT PRESENT. BUT SAFETY IS A MOVING TARGET AND, AS REACTOR DESIGN ADVANCES, A CONTINUING PROGRAM IS FORESEEN.

12-5-1-438

HTGR SAFETY

KAPLAN, S. I.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

FOR A HIGH TEMPERATURE GAS COOLED REACTOR (HTGR), THE POSTULATED ACCIDENT MECHANISMS THAT CARRY POPULATION SAFETY SIGNIFICANCE ARE THOSE WHICH EITHER INCREASE THE RELEASABLE FISSION PRODUCT INVENTORY OF THE PRIMARY SYSTEM OR THOSE WHICH RELEASE THE PRIMARY SYSTEM CONTENTS TO THE ENVIRONMENT. NOMINALLY THESE MECHANISMS COMPRISE LOSS OF COOLANT, GRAPHITE OXIDATION, LOSS OF FORCED CIRCULATION OF COOLANT, REACTIVITY EXCURSIONS, AND CORE BLOCKAGE. HOWEVER, THE SPECIFIC MULTIPLE LINES FOR SAFEGUARDING AGAINST ALL THESE ACCIDENT MECHANISMS WHICH ARE POSTULATED FOR A LARGE HTGR RENDER THE PROBABILITY OF THEIR OCCURRENCE EXTREMELY LOW. SAFETY DIRECTED RESEARCH HAS PROVIDED A GOOD GENERAL UNDERSTANDING OF THE MAJOR FISSION PRODUCT ESCAPE AND TRANSPORT MECHANISMS, CORE PHYSICS, AND GRAPHITE OXIDATION PHENOMENA. ALTHOUGH MUCH DETAILED EXPERIMENTAL INFORMATION IS STILL NEEDED BEFORE RIGOROUS PREDICTIONS OF COOLANT CHEMISTRY AND FISSION PRODUCT BEHAVIOR FOR NEW DESIGNS BECOME FEASIBLE, FUTURE RESEARCH MUST BE INFLUENCED BY THE SHIFTS IN RELATIVE IMPORTANCE OF CERTAIN ACCIDENT MECHANISMS AS REACTOR SIZE INCREASES, BY INCREASED

PUBLIC PRESSURE TO MINIMIZE ALL RADIOACTIVE RELEASES, AND BY NEW DEVELOPMENTS IN FUEL AND COMPONENT DESIGN.

12-5-2-448

PUBLIC OPPOSITION TO NUCLEAR POWER - AN INDUSTRY OVERVIEW
SLATER, M. G.

NIAGARA MOHAWK POWER CORPORATION, SYRACUSE, NEW YORK
THE RECENT HISTORY OF PUBLIC AND PRESS ATTITUDES TOWARD NUCLEAR POWER AND ITS EFFECT ON THE ENVIRONMENT CAN BE TRACED IN THE RESULTS OF POLLS, PANEL MEETINGS, DEBATES, ETC. ALTHOUGH OPPOSITION IS NOT THE RULE, THE QUICK RESPONSE BY THE NUCLEAR INDUSTRY TO THE ENVIRONMENTALISTS' POSITIONS HAS HELPED TO IMPROVE PUBLIC RELATIONS. SINCE NUCLEAR TECHNOLOGY IS INVOLVED IN THESE COMPLEX PROBLEMS, ITS LEADERS MUST DO ALL THEY CAN TO INFORM THE PUBLIC AND TO RESPOND WITH CANDOR TO IMPORTANT QUESTIONS SO THAT MUTUAL TRUST AND UNDERSTANDING MAY PREVAIL. SUCH OPENNESS MAY AT FIRST SEEM SELF-DEFEATING, BUT IN THE LONG RUN IT WILL SUCCEED.

12-5-2-456

THE OUTCRY OVER EXPOSURE GUIDELINES

AUBIER, J. A.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THERE HAS BEEN A GROWING PUBLIC CONCERN ABOUT RADIATION POLLUTION OF THE ENVIRONMENT OVER THE PAST FEW YEARS. ALSO, THE PUBLIC NEWS MEDIA HAVE GIVEN INCREASED COVERAGE TO INDIVIDUALS CRITICAL OF THE RADIATION EXPOSURE GUIDES AND STANDARDS RECOMMENDED BY THE FEDERAL RADIATION COUNCIL AND OTHER NATIONAL AND INTERNATIONAL COMMITTEES AND COUNCILS. THE RECOMMENDATIONS OF THE FEDERAL RADIATION COUNCIL ARE THOSE WITH WHICH THE ATOMIC ENERGY COMMISSION AND OTHER FEDERAL AGENCIES MUST COMPLY. THIS ARTICLE IS INTENDED TO GIVE AN OBJECTIVE VIEW OF SOME OF THE MANY PROBLEMS, HYPOTHESES, AND ASSUMPTIONS THAT UNDERLIE THE POSITIONS OF THOSE CRITICAL OF THE RADIATION EXPOSURE STANDARDS AND GUIDELINES, AS WELL AS THOSE WHO MAINTAIN STAINCHLY THAT THE RECOMMENDED DOSE LEVELS ARE ADEQUATELY LOW. IT IS CONCLUDED HERE, AS HAS BEEN DONE BY THE NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS, THAT THERE IS NO NEED TO ADJUST THE GUIDELINES AT PRESENT. CURRENT CONTAMINATION LEVELS ARE SO LOW, RELATIVE TO THE GUIDELINES, THAT EXPOSURE LEVELS WILL NOT REACH 10 PERCENT OF THE RECOMMENDED GUIDELINE LIMITS DURING THE NEXT FEW DECADES. CONSEQUENTLY, EVEN IF FUTURE RESEARCH INDICATED A NEED FOR THE FULL 10-FOLD REDUCTION RECOMMENDED BY THE CRITICS, THE AVERAGE POPULATION DOSE WOULD STILL BE BELOW REDUCED GUIDELINES.

12-5-3-461

COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS
MINTON, M. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
MANY COMPUTER PROGRAMS HAVE BEEN DEVELOPED FOR USE IN VARIOUS ASPECTS OF NUCLEAR ACCIDENT ANALYSIS. THE NUCLEAR SAFETY INFORMATION CENTER HAS SEPARATED OVER 200 OF THESE CODES INTO 15 GROUPS AND TABULATED THEM. THE RESULTING TABLE GIVES NAME OF CODE, MACHINE ON WHICH IT IS OPERABLE, ITS LANGUAGE, CORPORATE AUTHOR, A STATEMENT OF WHAT THE CODE DOES, A REFERENCE CITATION, AND DATE OF THE REFERENCE. AN OUTLINE OF THE ANALYSIS OF A LOSS OF COOLANT ACCIDENT IS GIVEN, AND CODES THAT MIGHT BE USED IN THE ANALYSIS ARE BRIEFLY DISCUSSED. SEVERAL COMPARISONS OF SIMILAR CODES ARE CITED, AND SOME OF THE RESULTS ARE DISCUSSED. IN ADDITION, THERE IS NOTATION OF THOSE CODES ON WHICH INFORMATION MAY BE OBTAINED FROM THE ARGONNE CODE CENTER, THE EUROPEAN NUCLEAR ENERGY AGENCY (ENEA) LIBRARY AT ISPRA, AND THE RADIATION SHIELDING INFORMATION CENTER.

12-5-3-487

FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR ACCIDENTS
RITTENHOUSE, P. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE STATUS OF RESEARCH AND TESTING FOR IDENTIFYING THE MODES OF FUEL ROD FAILURE THAT MAY RESULT FROM A LOSS OF COOLANT ACCIDENT IN A LIGHT WATER COOLED REACTOR AND THE INFLUENCE OF SUCH FAILURES ON THE EFFICIENCY AND EFFECTIVENESS OF EMERGENCY COOLING ARE REVIEWED. SUBJECTS COVERED INCLUDE DEFORMATION AND RUPTURE OF ZIRCALOY CLADDING OF FUEL RODS, COOLANT CHANNEL BLOCKAGE RESULTING FROM THIS MODE OF FUEL ROD FAILURE, AND EMBRITTLEMENT OF CLADDING BY REACTION WITH STEAM. THE EFFECTS OF ALL THESE FACTORS ON THE INTEGRITY OF THE REACTOR CORE AND ON THE ABILITY TO COOL THE CORE ARE DISCUSSED.

12-5-4-496

RELIABILITY ENGINEERING METHODS IN REACTOR SAFETY TECHNOLOGY
RUBEL, P.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
RELIABILITY ENGINEERING SEEKS DELIBERATELY TO INCREASE THE LIKELIHOOD THAT DEVICES OR SYSTEMS WILL FUNCTION AS INTENDED. TO THIS END, ANALYTICAL TECHNIQUES ARE ROUTINELY APPLIED IN FIELDS SUCH AS AEROSPACE IN WAYS THAT GIVE RATIONAL DIRECTION TO THE VARIOUS QUALITY ASSURANCE ACTIVITIES. A RECENT SURVEY OF SIMILAR APPLICATIONS TO ENHANCE REACTOR SAFETY REVEALED THAT, ALTHOUGH QUALITATIVE ANALYSIS METHODS HAVE BEEN ADOPTED WIDELY, PROBABILISTIC MODELING AND RISK FORECASTING HAVE BEEN SOMEWHAT RESTRICTED BY LACK OF ADEQUATE SUPPORTING INFORMATION. PROBABILISTIC ANALYSIS USE IS EXPANDING, HOWEVER, AS CURRENT EFFORTS GRADUALLY OVERCOME THE INFORMATION PROBLEM. MEANWHILE, QUALITY ASSURANCE HAS BENEFITED FROM THE INSIGHT PROVIDED BY THE PRELIMINARY RISK EVALUATION STUDIES.

- 12-5-4-496 REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINUITY OF SERVICE
HAGEN, F. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE AVERAGE AVAILABILITY OF FIRST-GENERATION NUCLEAR POWER REACTORS TO PRODUCE UNINTERRUPTEDLY A SUPPLY OF THERMAL ENERGY WAS DETERMINED TO BE 83.4 PERCENT FOR SEVEN COMMERCIAL OPERATED ELECTRICITY-GENERATING STATIONS BY REVIEWING THE STATION OPERATING REPORTS FOR A 3-YEAR PERIOD. THE SAFEST NUCLEAR POWER REACTOR IS ONE THAT IS IN NORMAL STEADY-STATE OPERATION, AND THEREFORE IT WAS PERTINENT TO DETERMINE THE CAUSES OF ABNORMAL OPERATION OR UNSCHEDULED SHUTDOWNS. OPERATIONAL DEVIATIONS AND UNPLANNED STATION SHUTDOWNS WERE ANALYZED AND CATEGORIZED INTO THOSE RELATED TO HEAT TRANSFER SYSTEMS, INSTRUMENTATION AND CONTROLS, AND THE ELECTRIC TURBINE GENERATOR POWER SYSTEM. THE CENTRAL PROBLEM AREAS WERE FOUND TO BE LEAKS IN THE HEAT TRANSFER SYSTEM, DIFFICULTIES WITH THE CONTROL ROD DRIVES IN THE PRIMARY SYSTEM, AND BOTH LEAKS AND TURBINE CONTROLS IN THE SECONDARY PLANT. FROM THE DATA AVAILABLE A FIGURE OF MERIT WAS PRODUCED TO EVALUATE THE UNSCHEDULED SHUTDOWNS AND ALSO TO GIVE A COMPARATIVE EVALUATION OF STATION SERVICE RELIABILITY FOR USE OF UTILITY OPERATORS.
- 12-5-5-516 REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR FISSION PRODUCT REMOVAL
ROWE, T. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
CONTAINMENT BUILDING SPRAY SYSTEMS AS FISSION PRODUCT REMOVAL DEVICES ARE BECOMING WIDESPREAD IN PRESSURIZED WATER REACTOR DESIGN, AND THE AEC HAS BEEN SPONSORING A RESEARCH PROGRAM TO INVESTIGATE THE APPLICABILITY OF THESE SYSTEMS AS ENGINEERED SAFETY FEATURES. THE OAK RIDGE NATIONAL LABORATORY HAS COORDINATED THE PROGRAM FOR THE AEC AND MAINTAINED LIAISON BETWEEN COMMISSION SPONSORED LABORATORIES AND NUCLEAR INDUSTRY. THREE SPRAY SOLUTIONS ARE PRESENTLY IN USE OR BEING SERIOUSLY CONSIDERED BY PLANT DESIGNERS. MOLECULAR IODINE REMOVAL BY THESE SPRAYS IS VERY EFFECTIVE, AND DECONTAMINATION FACTORS RANGING FROM 20 AND 1000 MAY BE OBTAINED, DEPENDING ON THE SOLUTION SELECTED. THE EXPLOSION HAZARD FROM GENERATION OF RADIOLYTIC HYDROGEN, FIRST IDENTIFIED IN THIS PROGRAM IN 1967, CONTINUES TO REQUIRE SERIOUS CONSIDERATION IN PLANT DESIGN.
- 12-5-5-523 FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM
WITT, F. J. + WHITMAN, G. D.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM IS ONE OF THE MAJOR NUCLEAR PRESSURE VESSEL SAFETY RESEARCH EFFORTS SPONSORED BY THE U.S. ATOMIC ENERGY COMMISSION. THE SCOPE OF THIS INVESTIGATION COVERS METALLURGY, CHEMISTRY, MATERIAL PROPERTIES, INSPECTION, ANALYTICAL AND EXPERIMENTAL STRESS AND STRAIN ANALYSES, ENVIRONMENTAL EFFECTS, FRACTURE MECHANICS, AND THE GENERAL AREA OF FRACTURE BEHAVIOR. IN THIS ARTICLE, HOWEVER, THE DISCUSSION IS LIMITED MAINLY TO CONSIDERATIONS OF HOW THICKNESS AFFECTS THE FRACTURE BEHAVIOR OF STEELS AS MANIFESTED IN DYNAMIC TEAR TEST SPECIMENS, MIL-DUCTILITY TRANSITION DROPWEIGHT SPECIMENS, COMPACT TENSION SPECIMENS, AND FLAMED TENSILE SPECIMENS. TEST RESULTS HAVE DEMONSTRATED A SIGNIFICANT INCREASE IN TOUGHNESS LEVELS AS A FUNCTION OF TEMPERATURE. SIMILAR BEHAVIOR IS INDICATED TO OCCUR AFTER THE STEEL IS SUBJECTED TO HIGH FAST NEUTRON FLUENCES, ALTHOUGH THERE IS A SIGNIFICANT INCREASE IN THE TEMPERATURE AT WHICH THE MAJOR PORTION OF THE CHANGE OCCURS. IN ADDITION, A PROPOSED METHOD OF RELATING FLAW SIZE AND NOMINAL STRESS (LOAD) AS A FUNCTION OF TEMPERATURE FOR FRAGILE, TRANSITIONAL, AND TOUGH BEHAVIORS HAS BEEN SHOWN TO HAVE A POTENTIAL FOR CALCULATING QUANTITATIVE SAFETY MARGINS IN REACTOR PRESSURE VESSELS.
- 12-5-6-530 SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITING
PELLETIER, C. A.
HEALTH SERVICES LABORATORY, IDAHO FALLS, IDAHO
THE FIFTH ANNUAL MIDYEAR SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY WAS HELD IN IDAHO FALLS, IDAHO, ON NOV. 3-6, 1970. FORTY-TWO PAPERS ON HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITING WERE GIVEN IN SESSIONS DEALING WITH GENERAL SITE-SELECTION CRITERIA FOR NUCLEAR POWER REACTORS, SITING EVALUATIONS FOR LARGE ACCELERATORS, FUEL, COOLANT, AND FISSION PRODUCT INTERACTIONS, EVALUATION OF ENVIRONMENTAL CONTAMINATION AROUND NUCLEAR FACILITIES, BEHAVIOR OF AIRBORNE RADIOACTIVITY, RADIONUCLIDES IN BIOLOGICAL SYSTEMS, COMPARISON OF HAZARDS FROM INTERNAL CONTAMINATION, RADIATION STANDARDS, AND PUBLIC RELATIONS. (APPORTEUR SESSIONS WERE HELD ON THE ENVIRONMENTAL IMPACT OF OPERATING POWER PLANTS AND FUEL REPROCESSING PLANTS AND ON DIRECT RADIATION FROM CLOUDS.
- 12-5-7-538 DRESDEN 2 INCIDENT OF JUNE-5, 1970
WITT, F. J. + G. D.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
ON JUNE 5, 1970, WHILE DRESDEN UNIT 2 (A SECOND GENERATION BOILING WATER REACTOR) WAS UNDERGOING POWER TESTING AND WAS OPERATING AT APPROXIMATELY 75 PERCENT POWER (1875 MWTH), 623 MW(E)), A SPURIOUS SIGNAL IN THE REACTOR PRESSURE CONTROL SYSTEM ALTERED THE STEAM FLOW TO THE TURBINE AND CAUSED A TURBINE TRIP FOLLOWED BY A REACTOR SCRAM. SUBSEQUENT ERRATIC WATER LEVEL AND PRESSURE CONTROL IN THE REACTOR VESSEL.

COMPOUNDED BY A STUCK INDICATOR PEN ON A WATER LEVEL MONITOR - RECORDER AND INABILITY OF THE ISOLATION CONDENSER TO FUNCTION AS NEEDED, LED TO DISCHARGE OF STEAM AND WATER THROUGH SAFETY VALVES INTO THE REACTOR DRY WELL. ELECTRIC CABLES WERE DAMAGED, AND ELECTRIC MOTORS DEVELOPED LOW RESISTANCE PROBLEMS. NO SIGNIFICANT AMOUNT OF RADIOACTIVE CONTAMINATION WAS DISCHARGED TO THE ENVIRONMENT. THERE WAS NO PRESSURE DAMAGE OF THE REACTOR VESSEL OR THE DRY WELL CONTAINMENT WALLS. RECOVERY INCLUDED REPLACING SOME ELECTRIC CABLES WITH IMPROVED CABLES HAVING HIGHER TEMPERATURE RATINGS, REROUTING OTHER ELECTRIC CABLES, DRYING ELECTRIC MOTORS, REORIENTING THE DISCHARGE DIRECTION OF SAFETY VALVES, REVISING THE REACTOR PRESSURE CONTROL SYSTEM, IMPROVING THE CAPABILITY OF THE ISOLATION CONDENSER, AND REVISING OPERATING AND EMERGENCY PROCEDURES. THE REACTOR REMAINED SHUT DOWN UNTIL AUG. 8, 1970. TWO TO 3 WEEKS OF THIS DOWNTIME WAS ASCRIBED TO REFUELING.

12-6-1-549

QUALITY ASSURANCE STANDARDS AND PRACTICES

LANGSTON, R. E.

U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.

THE U. S. ATOMIC ENERGY COMMISSION HAS BEEN TAKING MANY POSITIVE STRENGTHENING ACTIONS TO ESTABLISH AND ENFORCE A SYSTEMATIC, DISCIPLINED APPROACH TO THE ASSURANCE OF QUALITY IN ADVANCED REACTORS AND TEST FACILITIES TO PROVIDE FOR SAFE, RELIABLE, AND ECONOMIC OPERATION IN A TIMELY AND PREDICTABLE MANNER. THIS ARTICLE DESCRIBES SOME OF THESE STRENGTHENING ACTIONS DIRECTED TOWARD THE DEVELOPMENT AND APPLICATION OF QUALITY ASSURANCE STANDARDS AND PRACTICES FOR ADVANCED REACTOR DEVELOPMENT AND TECHNOLOGY PROGRAMS. THIS ARTICLE ALSO DESCRIBES THE ASSISTANCE RENDERED TO THE ANSI SUBCOMMITTEE N45-3 IN THE PREPARATION OF INDUSTRY STANDARDS.

12-6-1-553

CASKS FOR IRRADIATED FUEL - A LOOK AT THE CASK DESIGNERS GUIDE

LANGHAAR, J. W.

E. I. DU PONT DE NEMOURS AND COMPANY, WILMINGTON, DELAWARE
SHIPPING CONTAINERS FOR RADIOACTIVE MATERIALS IN QUANTITIES AND CONCENTRATIONS ABOVE SOME RATHER LOW LIMITS ARE REQUIRED BY FEDERAL REGULATION TO MEET CERTAIN PERFORMANCE CRITERIA UNDER SPECIFIED ENVIRONMENTAL CONDITIONS, INCLUDING A HYPOTHETICAL ACCIDENT. THE THICKLY SHIELDED CONTAINERS FOR IRRADIATED FUEL AND OTHER STRONG GAMMA EMITTERS REQUIRE RIGOROUS DESIGN AND ANALYSIS TO ASSURE RETENTION OF SHIELDING AND ADEQUATE HEAT REMOVAL. MUCH EFFORT HAS BEEN DEVOTED DURING THE PAST 10 YEARS TO DESIGNING CASKS TO MEET THESE REQUIREMENTS AND TO DEVELOPING PROCEDURES TO DEMONSTRATE COMPLIANCE WITH THE REGULATIONS. THE EMPHASIS HAS BEEN PRIMARILY ON LEAD SHIELDED CASKS, WHICH HAVE BEEN COMMONLY USED IN THE UNITED STATES BECAUSE OF A FAVORABLE BALANCE BETWEEN INVESTMENT AND OPERATING COST. UNDER SOME CONDITIONS, THE GREATER PAYLOAD OR SMALLER SIZE OF A URANIUM SHIELDED CASK JUSTIFIES THE GREATER INVESTMENT. AMONG THE DESIGN CONSIDERATIONS ARE HEAT REMOVAL, CRITICALITY, SHIELDING, STRUCTURAL INTEGRITY UNDER IMPACT AND FIRE CONDITIONS, THERMAL BEHAVIOR IN A FIRE, RESISTANCE TO FRACTURE AT VERY LOW TEMPERATURES, AND ASSURANCE OF PROPER FABRICATION. THESE DESIGN CONSIDERATIONS ARE DISCUSSED IN DETAIL IN THE CASK DESIGNERS GUIDE, USAEC REPORT ORNL-ASIC-68, WHICH ALSO DESCRIBES THE METHODS OF ANALYSIS, FABRICATION TECHNIQUES, AND TESTING PROCEDURES FOUND ACCEPTABLE.

12-6-2-562

FISSION GAS EFFECTS IN REACTOR FUELS II. ENGINEERING APPLICATIONS

CARROLL, R. M.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

THE LITERATURE DEALING WITH THE ENGINEERING EFFECTS OF FISSION GAS BEHAVIOR IN REACTOR FUEL MATERIAL IS QUITE EXTENSIVE. THIS REVIEW COVERS THE PAPERS PUBLISHED FROM 1968 TO 1970. THE 73 PUBLICATIONS CITED AND BRIEFLY SUMMARIZED DEAL PRIMARILY WITH FUEL SWELLING MODELS, HIGH TEMPERATURE EFFECTS, NEW EXPERIMENTAL TECHNIQUES, AND ENGINEERING FOR FISSION GAS RELEASE.

12-6-2-569

A SURVEY OF HEAT CONDUCTION COMPUTER PROGRAMS

SHUKER, W. A.

BETTS ATOMIC POWER LABORATORY, WEST HIFFLIN, PENNSYLVANIA

MANY PROBLEMS IN REACTOR ANALYSIS REQUIRE KNOWLEDGE OF THE TEMPERATURE VARIATIONS DURING NORMAL REACTOR TRANSIENTS AND IN ACCIDENT SITUATIONS. IN SOLID BODIES THE HEAT CONDUCTION EQUATION DESCRIBES THERMAL BEHAVIOR. MOST OFTEN A CLOSED-FORM SOLUTION CANNOT BE OBTAINED BECAUSE OF COMPLEX GEOMETRIES AND BOUNDARY CONDITIONS, BUT THESE PROBLEMS MAY BE CONVENIENTLY APPROXIMATED BY NUMERICAL SOLUTIONS OBTAINED ON HIGH-SPEED COMPUTERS. ELEVEN HEAT CONDUCTION PROGRAMS REPORTED IN THE LITERATURE ARE REVIEWED. ALL THESE PROGRAMS APPROXIMATE THE HEAT CONDUCTION EQUATION IN AT LEAST TWO DIMENSIONS UNDER TRANSIENT AND STEADY-STATE CONDITIONS FOR GENERAL TYPES OF BOUNDARY CONDITIONS. THE COMPARISON OF PROGRAMS INCLUDES CONSIDERATION OF THE METHOD USED TO DESCRIBE GEOMETRY, THE NUMERICAL DIFFERENCING METHOD, THE MAXIMUM ALLOWABLE NUMBER OF NODES, AND THE MANNER OF SPECIFICATION OF BOUNDARY CONDITIONS, MATERIAL PROPERTIES, AND HEAT-GENERATION RATE.

- 12-6-3-583 SUBCRITICALITY MEASUREMENT IN AN LMFBR
ACKEFMAN, N. J., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
RELIABLE KNOWLEDGE OF THE SUBCRITICALITY STATE OF A NUCLEAR REACTOR AT ALL TIMES DURING SHUTDOWN, COUPLED WITH PROPER ADMINISTRATIVE CONTROL, SHOULD PRECLUDE THE POSSIBILITY OF THAT REACTOR ACCIDENTALLY BECOMING CRITICAL OR SUPERCRITICAL. THIS REVIEW OF THE STATE OF THE ART OF SUBCRITICALITY MEASUREMENT IN THE LMFBR GIVES PARTICULAR ATTENTION TO FOUR MEASUREMENT TECHNIQUES - NEUTRON SOURCE MULTIPLICATION, NEUTRON NOISE ANALYSIS, INVERSE KINETICS, AND PULSED NEUTRONS. IT IS CONCLUDED THAT THE NEUTRON SOURCE MULTIPLICATION TECHNIQUE IS THE ONLY METHOD APPLICABLE FOR MEASURING THE SUBCRITICALITY IN AN LMFBR OVER THE FULL RANGE OF SHUTDOWN. PRESENT SUBCRITICALITY MEASUREMENT DEVELOPMENT PROGRAMS ARE REVIEWED, AND FUTURE APPLICATIONS ARE DISCUSSED.
- 12-6-4-591 KRYPTON - XENON REMOVAL SYSTEMS
KEILHOLTZ, G. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE NEED FOR MORE ELECTRIC POWER AND THE CORRESPONDING INCREASE IN THE NUMBER OF NUCLEAR POWER REACTORS AND FUEL RECOVERY PLANTS MAKE IT DESIRABLE TO HAVE NEAR ZERO RELEASE OF FISSION PRODUCT GASES TO THE ATMOSPHERE. SYSTEMS FOR RETAINING AND STORING RADIOACTIVE XENON AND KRYPTON HAVE BEEN DEVELOPED, AND FOUR OF THE MOST PROMISING METHODS CAPABLE OF FULL SCALE APPLICATION ARE DESCRIBED. CURRENT SYSTEMS INVOLVE ONE OR MORE OF THE FOLLOWING PROCESSES (1) ADSORPTION ON CHARCOAL AT AMBIENT OR LOWER TEMPERATURES, (2) CRYOGENIC DISTILLATION WITHOUT CHARCOAL, (3) SEPARATION BY PERMEATIVE MEMBRANES, AND (4) SELECTIVE ABSORPTION OF KRYPTON AND XENON IN FLUOROCARBON SOLVENTS.
- 12-6-5-600 EFFECTS ON ORGANISMS OF ENTRAINMENT IN COOLING WATER - STEPS TOWARD PREDICTABILITY
COUTANT, C. C.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
MODELS ARE BEING DEVELOPED AT OAK RIDGE NATIONAL LABORATORY AND ELSEWHERE FOR PREDICTING ECOLOGICAL EFFECTS OF THERMAL SHOCKS RECEIVED BY ORGANISMS PASSING THROUGH THERMAL POWER PLANT COOLING SYSTEMS. THE MODELS WERE DEVELOPED INITIALLY FOR STUDYING DIRECTLY LETHAL EFFECTS, BUT THEY ARE APPLICABLE TO SUCH SUBLETHAL EFFECTS AS EQUILIBRIUM LOSS AND INCREASED SUSCEPTIBILITY TO PREGATIGN. THESE PREDICTIVE MODELS AND THE BASIC BIOLOGICAL DATA REQUIRED FOR USE OF THEM PROVIDE FOR SELECTION OF LIMITS OF TEMPERATURE ELEVATIONS AND DURATIONS OF EXPOSURE TO WARMED WATER AT POWER PLANTS WHICH WILL PREVENT DETRIMENTAL EFFECTS.
- 12-6-6-608 FAILURE OF N REACTOR PRIMARY SCRAM SYSTEM
GALLAGHER, G. R.
U.S. ATOMIC ENERGY COMMISSION, RICHLAND, WASHINGTON
THE N REACTOR AT MANFRO SCRAPPED FROM AN OPERATING LEVEL OF APPROXIMATELY 450 MW AT 0525 HR, SEP. 30, 1970. THE REACTOR WAS IN A POWER HOLDING MODE WITH THE PRIMARY LOOP AT EQUILIBRIUM FLOW AND TEMPERATURE. THE SCRAM SIGNAL WAS INITIATED BY SIMULTANEOUS LOW FLOW TRIPS ON SEVERAL PROCESS TUBES. DUE TO A UNIQUE MALFUNCTION, THE ROD SAFETY SYSTEM DID NOT RESPOND TO THE SCRAM SIGNAL. OTHER SCRAM TRIP INSTRUMENTATION RESPONDED AS DESIGNED, AND THE REACTOR WAS SHUT DOWN AND MAINTAINED IN A SAFE CONDITION BY THE BALL SAFETY SYSTEM. NO OVERHEATING OF REACTOR COMPONENTS OCCURRED, AND NO RADIATION WAS RELEASED. THE SHUTDOWN TRANSIENT WAS NORMAL IN ALL RESPECTS. THE LOW FLOW WAS CAUSED BY A PRIMARY PUMP TRIPPING FROM STEAM TURBINE DRIVE SPEED DOWN TO PCV MOTOR ELECTRIC DRIVE SPEED. THE TURBINE TRIP WAS PRECIPITATED BY ONE OF THE TURBINE CONDENSER CONDENSATE PUMPS LOSING SUCTION BECAUSE OF A PLUGGED SCREEN. THE SAFETY RODS FAILED TO SCRAM DUE TO A COMBINATION OF CIRCUMSTANCES INVOLVING THE NO. 59 ROD ASSIGNMENT SWITCH BEING IN THE OFF POSITION AND THERE BEING FOUR FAILED (SHORTED) DIODES IN THE NO. 59 ROD SCRAM CIRCUIT. THIS COMBINATION OF EVENTS AND THE PARALLEL WIRING CHARACTERISTICS OF THE ROD SAFETY CIRCUIT ALLOWED POWER FROM AN AUXILIARY ELECTRICAL CIRCUIT TO FEED ALL THE ROD SCRAM SOLENOIDS AND THUS KEEP THEM ENERGIZED AFTER THE MAIN SCRAM RELAYS HAD TRIPPED.
- 12-6-6-61 SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PERSONNEL
MCCORD, R. V.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
TWENTY-TWO PAPERS AND A PANEL DISCUSSION WERE PRESENTED AT THE SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PERSONNEL. THE PAPERS COVERED ALL FACETS OF NUCLEAR REACTOR OPERATOR TRAINING FROM PHILOSOPHY AND OBJECTIVES TO DETAILED TRAINING METHODS. TWO PAPERS WERE PRESENTED ON THE TRAINING AND LICENSING OF RADIOCHEMICAL PROCESSING PLANT PERSONNEL. SEVERAL PAPERS DISCUSSED PUBLIC RELATIONS AND THE EDUCATION OF THE PUBLIC FOR THE ACCEPTANCE OF NUCLEAR POWER.

- 13-1-1-001 THE ROLE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE REACTOR LICENSING PROCESS
BUSH, S. W.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
THE ROLE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) IN THE REACTOR LICENSING PROCESS IS REVIEWED IN THE CONTEXT OF ITS ORIGINAL CHARTER ESTABLISHED BY CONGRESS. SPECIFICALLY, MEMBERSHIP AND OPERATIONAL PROCEDURES ARE REVIEWED WITH RESPECT TO SPECIFIC PROJECTS. AN IMPORTANT ACTIVITY OF THE ACRS IS REVIEW OF GENERIC SAFETY ITEMS AND CODES, STANDARDS, AND CRITERIA. RECOMMENDATIONS AND COMMENTS ARE MADE CONCERNING AREAS WHERE CONTINUING IMPROVEMENTS ARE POSSIBLE IN THE REGULATORY WORK LOAD, EVALUATION OF DESIGN CONCEPTS, AND OPERATION OF THE ACRS.
- 13-1-1-013 SOME EFFECTS OF PUBLIC INTERVENTION ON THE REACTOR LICENSING PROCESS
BRIGHT, G. O.
AEROJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO
THE ENVIRONMENTAL PROTECTION MOVEMENT, WHICH HAS GROWN SO STRONG OVER THE LAST 2 TO 3 YEARS, HAS GREATLY AFFECTED THE CIVILIAN POWER REACTOR LICENSING PROCESS. INTERVENTION IN PUBLIC LICENSING HEARINGS AND COURT ACTION HAVE BOTH BEEN WIDELY EMPLOYED, WITH A NET RESULT, IN MANY CASES, OF SIGNIFICANTLY INCREASING THE TIME REQUIRED TO OBTAIN BOTH CONSTRUCTION AND OPERATING LICENSES. IT IS CONCLUDED THAT A STRONG EFFORT MUST BE MADE BY INDUSTRY IF PROTRACTED DELAYS ARE TO BE AVOIDED.
- 13-1-2-022 THE DEVELOPMENT OF REACTOR SITING CRITERIA BASED UPON RISK PROBABILITY
NELIS, M. + FIDMAN, R. C.
UNIVERSITY OF CALIFORNIA AT LOS ANGELES, LOS ANGELES, CALIFORNIA
EXAMINATION OF THE ORIGINALLY PROPOSED FARMER LIMIT LINE CRITERION FOR NUCLEAR PLANTS LED TO A TOTAL INDIVIDUAL MORTALITY RISK THAT IS FAIRLY HIGH WITH RESPECT TO OTHER RECORDED RISKS. FOR EXAMPLE, IN THE CASE OF AN EQUAL WIND DIRECTION PROBABILITY OF 1/12 (ANY 30 DEGREE VECTOR OVER A 360 DEGREE CIRCLE), THE TOTAL RISK FROM AN ACCIDENTAL RELEASE AT THE PLANT WAS ONLY $3.4 \times 10^{(-6)}$ BUT WAS STILL 34 TIMES THAT CAUSED BY LIGHTNING. A NEW LOCATION FOR THE LIMIT LINE WAS THEREFORE DEDUCED THAT WOULD SATISFY BOTH FARMER'S PROBABILISTIC SAFETY ANALYSIS PHILOSOPHY AND AT THE SAME TIME LIMIT THE ADDED RISK TO THE INDIVIDUALS LIVING AT THE EXCLUSION RADIUS TO A VERY LOW VALUE. FINALLY, THE PROBABILISTIC SAFETY ANALYSES OF THREE EXISTING NUCLEAR PLANTS ARE COMPARED WITH THE ORIGINAL AND MODIFIED LIMIT LINES. HENCE ONE CAN OBSERVE A CORRESPONDENCE BETWEEN CALCULATED PLANT RELEASE DATA AND THE LIMIT LINE CONCEPT. WE THUS CONCLUDE THAT AN INTEGRATED SAFETY ANALYSIS BASED ON THE LIMIT LINE CONCEPT COULD PROVIDE THE NUCLEAR INDUSTRY WITH AN ADEQUATE REACTOR SITING TECHNIQUE.
- 13-1-3-029 THE FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCIETY OF AMERICA
HAGEN, E. W. + RHODE, G. K. + BASSETT, T. G.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE - NIAGARA MOHAWK POWER CORPORATION, SYRACUSE, NEW YORK
THE ELECTRIC POWER GENERATION SEGMENT OF THE NUCLEAR FIELD IS INCREASING IN SIZE AND IN IMPORTANCE AND, THEREFORE, IN ITS RESPONSIBILITIES AND NEED TO BE HEARD. SOME OF THIS INDUSTRY'S CONCERNS ABOUT STANDARDS, RELIABILITY, COMMUNICATIONS, AND INSTRUMENTATION AND CONTROL NEEDS WERE EXPRESSED AT THE INSTRUMENT SOCIETY OF AMERICA'S 14TH POWER INSTRUMENTATION SYMPOSIUM. MORE STANDARDS ARE STILL NEEDED, AND TO RESOLVE SOME OF THE MAJOR SAFETY PROBLEMS NOW BEFORE THE INDUSTRY, SEVERAL IMPORTANT INSTRUMENTATION AND CONTROL OBJECTIVES MUST BE MET. ALSO COMMUNICATION BETWEEN THE ENGINEERING DESIGN AND THE OPERATING GROUPS COULD BE IMPROVED.
- 13-1-4-037 CONTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER REACTORS
FIRST, M. W.
HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASSACHUSETTS
ALTHOUGH LIQUID METAL COOLED FAST BREEDER REACTORS ARE DESIGNED TO AVOID SODIUM RELEASES, SOUND PUBLIC HEALTH PRACTICE DEMANDS THAT THE NATURE AND POTENTIAL CONSEQUENCES OF EVERY CONCEIVABLE TYPE OF RELEASE BE EVALUATED. IN THIS ARTICLE A TYPICAL REACTOR HANDLING LARGE VOLUMES OF HOT SODIUM IS ANALYZED CAREFULLY TO DETERMINE WHERE ACCIDENTAL LEAKS AND SPILLS MAY OCCUR. STANDBY CONTROL METHODS ARE RECOMMENDED TO PREVENT SPREAD OF AIRBORNE SODIUM AND ITS REACTION PRODUCTS, TO REDUCE REACTOR SHUTDOWN TIME, AND TO MINIMIZE CLEANUP COSTS. CRITICAL FACTORS AFFECTING THE DESIGN OF ENGINEERED CONTROLS FOR THE CONTAINMENT OF ACCIDENTAL SODIUM RELEASES WERE TEMPERATURE OF THE METAL, OXYGEN CONCENTRATION AND SIZE OF THE SPACE INTO WHICH THE SPILL OR LEAK OCCURS, RATE OF SODIUM ESCAPE, AND THE AMOUNT OF SODIUM LIKELY TO BE RELEASED BEFORE REMEDIAL MEASURES CAN BE TAKEN TO STOP IT.
- 13-1-5-047 FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR FACILITIES
SCOTT, A. L. + HARLEY, P. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THIRTY-THREE INCIDENTS ARE TABULATED CONCERNING PROBLEMS ENCOUNTERED WITH BOLTS, SCREWS, NUTS, AND THREADED FITTINGS. ALL OF WHICH SHOULD BE OF INTEREST TO BOTH DESIGNERS AND

OPERATORS. THESE INCIDENTS HAVE REQUIRED APPROXIMATELY 70 MONTHS OF ADDITIONAL REACTOR DOWNTIME. AT ONE FACILITY AN ESTIMATED EXPENDITURE OF \$10,000 WAS CAUSED BY THE FAILURE OF A 1-IN. THREADED STRAINER PLUG. THE THREE MAJOR TYPES OF FAILURES - CORROSION, FATIGUE, AND GALLING - ARE DISCUSSED.

- 13-1-5-054 ON ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOURCE STRENGTH
CLACK, R. W. + ECKHOFF, R. C.

KANSAS STATE UNIVERSITY, MANHATTAN, KANSAS
ASSUMING EXTENDED STEADY-STATE REACTOR OPERATION, USEFUL APPROXIMATIONS OF FISSION PRODUCT SOURCE STRENGTH (IN CUATERS) CAN BE MADE BY MULTIPLYING THE THERMAL-ENERGY RELEASE (IN MW) BY 100 AND DIVIDING BY THE TIME INTERVAL FROM SHUTDOWN (IN YEARS).

- 13-2-1-099 THE ASME CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR REACTORS
MCGUFFEY, J. R.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
TO ENHANCE THE SAFETY AND RELIABILITY OF VESSELS, PUMPS, VALVES, AND PIPING USED IN NUCLEAR POWER SYSTEMS, THE ASME BOILER AND PRESSURE VESSEL CODE HAS SET FORTH SPECIFIC QUALITY-ASSURANCE (QA) RESPONSIBILITIES FOR THE OWNER, THE MANUFACTURERS, THE INSTALLERS, THE ASME, AND AUTHORIZED INSPECTION AGENCIES. IN PARTICULAR, THE MANUFACTURERS AND THE INSTALLERS OF SUCH COMPONENTS MUST OPERATE UNDER A CONTROLLED MANUFACTURING SYSTEM AND UNDER DETAILED QA PROGRAMS. THIS APPROACH TO CONTROLLING THE DESIGN, FABRICATION, AND INSTALLATION OF NUCLEAR COMPONENTS DURING THE PAST 3 YEARS HAS MATERIALLY IMPROVED THE INTEGRITY OF NUCLEAR PRESSURE BOUNDARY AND PRESSURE-CONTAINING SYSTEMS.

- 13-2-1-103 THE IMPACT OF THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIVE MATERIALS
SEAGREN, R. D.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
AN EFFORT IS UNDER WAY TO REVISE AND UPDATE THE IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIVE MATERIALS. UNDER THE NEW REGULATIONS THE PRESENT SYSTEM OF CLASSIFYING RADIOACTIVE MATERIAL INTO GROUPS ACCORDING TO THE RADIOTOXICITY OF THE RADIOISOTOPE CONCERNED WILL BE DISCONTINUED. INSTEAD, ASSESSMENTS OF THE LIKELY INTAKE OF RADIOACTIVE MATERIAL AFTER SERIOUS DAMAGE TO PACKAGING ARE COMBINED WITH CALCULATED RADIATION DOSES FOR UNIT INTAKE OF SOME 200 RADIOISOTOPES TO DERIVE A THEORETICAL SAFE LIMIT FOR THE RADIOACTIVE CONTENT OF TRANSPORT PACKAGES. ACTIVITY RELEASE RATES FOR PACKAGING UNDER NORMAL CONDITIONS OF TRANSPORT AS WELL AS UNDER ACCIDENT CONDITIONS ARE TO BE BASED ON THESE SAFE LIMITS.

- 13-2-2-107 STRUCTURAL EFFECTS OF CONFINED DYNAMIC LOADS

MATIP, L. R.
FORD RESEARCH AND ENGINEERING CENTER, DEARBORN, MICHIGAN
THIS REVIEW OF MODERN METHODS OF DESIGN AND ANALYSIS IN THE FIELD OF STRUCTURAL EFFECTS OF DYNAMIC LOADS STEMS FROM CURRENT NEEDS TO ENSURE THE CONTAINMENT OF CHEMICAL REACTIONS THAT MAY ACCIDENTALLY OCCUR IN LIQUID METAL HEATED STEAM GENERATORS ASSOCIATED WITH CERTAIN NUCLEAR POWER PLANTS. IT IS RECOMMENDED THAT THE DESIGN OF CYLINDRICAL VESSELS SUBJECTED TO TRANSIENT INTERNAL PRESSURES BE BASED ON THE AMPLITUDE - IMPULSE PLANE REPRESENTATION OF THE DYNAMIC BURSTING CRITERION. METHODS AVAILABLE FOR APPLICATION TO THE PROBLEM UNDER CONSIDERATION ARE DYNAMIC LIMIT ANALYSIS AND FINITE DIFFERENCE ANALYSIS, WITH BRIEF MENTION OF RECENT DEVELOPMENTS IN FINITE ELEMENT METHODS.

- 13-2-2-114 SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER PLANTS
SMITH, C. B. + MATTHIESSEN, R. B.

UNIVERSITY OF CALIFORNIA, LOS ANGELES, CALIFORNIA
RESEARCH BEING CONDUCTED TO DETERMINE THE EFFECTS OF EARTHQUAKES ON NUCLEAR POWER PLANTS INCLUDES DYNAMIC TESTS OF FULL-SCALE NUCLEAR POWER PLANTS AND THE DEVELOPMENT OF MATHEMATICAL MODELS OF THE SYSTEM BASED ON EXPERIMENTAL RESULTS. THESE TESTS HAVE BEEN CONDUCTED AT THE UCLA RESEARCH REACTOR, THE EXPERIMENTAL GAS-COOLED REACTOR (EGCR), THE CAROLINAS-VIRGINIA TUBE REACTOR (CVTR), THE FERMILAB BREEDER REACTOR, AND THE SAN DOMINGUE NUCLEAR GENERATING STATION. EXPERIMENTAL INVESTIGATIONS INCLUDE THE RESPONSE DUE TO AMBIENT EXCITATION (WIND AND NATURAL GROUND VIBRATIONS), FORCED VIBRATIONS USING STRUCTURAL VIBRATORS, FORCED VIBRATIONS USING IMPULSES, FREE VIBRATIONS FROM A LARGE INITIAL DISPLACEMENT ('SHAKEDOWN' TESTS), AND FORCED VIBRATIONS CAUSED BY EXPLOSIVE BLASTS. THE MAJOR EMPHASIS OF THE WORK IS ON DEVELOPING METHODS FOR EXCITING FULL-SCALE STRUCTURES AT LEVELS COMPARABLE WITH STRONG MOTION EARTHQUAKES AND USING THESE TESTS TO DEVELOP MATHEMATICAL MODELS FOR REACTOR SYSTEMS. CURRENT EFFORT IS CONCENTRATED ON ANALYZING THE RESULTS OF BLAST TESTS. ANALYSIS TO DATE HAS PROVED THE FEASIBILITY OF THE BLAST TECHNIQUES AND IS GIVING INSIGHT INTO THE NONLINEARITIES ASSOCIATED WITH HIGH LEVEL RESPONSE. EXCELLENT AGREEMENT WAS OBTAINED IN COMPARISONS OF FORCED VIBRATION TEST DATA AND BLAST DATA. NEVERTHELESS, NONLINEAR BEHAVIOR OF NUCLEAR PLANT COMPONENTS IS STILL NOT WELL UNDERSTOOD, AND ADDITIONAL WORK IS REQUIRED TO DEFINE THE MECHANISMS THAT GIVE RISE TO NONLINEARITIES.

- 13-2-4-122 **PIPE RUPTURE STUDY - 1971**
 VANDENBERG, S. R.
 GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
 THE PIPE RUPTURE STUDY IS CONCERNED WITH EXTENDING THE UNDERSTANDING OF FAILURE CAUSING MECHANISMS AND IMPROVING THE CAPABILITY FOR EVALUATING REACTOR PIPING SYSTEMS TO MINIMIZE THE PROBABILITY OF FAILURES. FOLLOWING A DETAILED REVIEW TO DETERMINE THE EFFORT MOST NEEDED TO IMPROVE NUCLEAR SYSTEM PIPING (PHASE I), ANALYTICAL AND EXPERIMENTAL EFFORTS (PHASE II) WERE STARTED IN 1969. THIS STATUS REPORT SUMMARIZES THE ACCOMPLISHMENTS OF A BROAD PROGRAM IN (1) AT-REACTOR TESTS OF THE EFFECT OF PRIMARY COOLANT ENVIRONMENT ON THE FATIGUE BEHAVIOR OF PIPING STEELS, (2) FATIGUE STUDIES THROUGH BOTH BENCH-SCALE AND LARGE COMPONENT TESTS, (3) FRACTURE MECHANICS, (4) SOLUTION OF PROBLEMS IN STRESS ANALYSIS, AND (5) FAILURE PROBABILITY STUDY OF ACTUAL REACTOR PIPING SYSTEMS. BROADLY, THE RESULTS OBTAINED SHOW THAT PRIMARY PIPING SYSTEMS ARE VERY SAFE, THAT SUCH PIPING IS CONSERVATIVELY DESIGNED (TO BS1.7 'NUCLEAR PIPING CODE'), AND THAT THE MATERIALS, PARTICULARLY IN LOW CYCLE FATIGUE, ARE SUCH THAT CONSIDERABLE LEEWAY EXISTS ON THE SIDE OF SAFETY. I.E., THE NUMBER OF STRESS CYCLES TO INITIATE AND GROW CRACKS THROUGH PIPE WALLS ARE AT LEAST AN ORDER OF MAGNITUDE GREATER THAN THE NUMBER OF CYCLES IN PLANT SERVICE LIFETIMES OF 40 YEARS.
- 13-2-5-130 **ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT**
 KNOX, J. R. + PETERSON, K. R.
 LAWRENCE RADIATION LABORATORY, LIVERMORE, CALIFORNIA
 THE RADIOACTIVE DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A TYPICAL NUCLEAR FUEL REPROCESSING PLANT IS ESTIMATED FOR VARIOUS DISTANCES AND TIMES, INCLUDING THE GLOBAL EQUILIBRIUM POPULATION DOSE RESULTING FROM A CONSTANT RATE OF EMISSION. THE TOTAL POPULATION DOSE AT ANY LOCATION DEPENDS ON BOTH THE PROXIMITY TO THE PLANT AND THE POPULATION OF THE AREA AFFECTED. THE LARGEST POPULATION DOSE OCCURS IN ASIA, PRINCIPALLY BECAUSE OF ITS DENSE POPULATION, BUT THIS IS A SMALL FRACTION OF THAT RECEIVED FROM NATURAL RADIOACTIVITY. THE NEXT LARGEST DOSE IS WITHIN 1000 KM OF THE SOURCE, AND THE SMALLEST DOSES ARE IN POLAR AND EQUATORIAL LATITUDES.
- 13-3-0-108 **NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOURTH GENEVA CONFERENCE**
 NUCLEAR SAFETY EDITORIAL STAFF
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
 THE NUCLEAR SAFETY ASPECTS OF THE FOURTH INTERNATIONAL CONFERENCE ON THE PEACEFUL USES OF ATOMIC ENERGY, HELD AT GENEVA IN SEPTEMBER 1971, DEALT WITH ENVIRONMENTAL ASPECTS AND PUBLIC ACCEPTANCE, INSURANCE AND REGULATION, POWER PLANT SAFETY, WASTE MANAGEMENT, HEALTH PHYSICS AND RADIATION PROTECTION, AND NUCLEAR PLANT PERFORMANCE. THE AUTHORS OF THE MORE THAN 100 PAPERS GIVEN AT THESE SESSIONS, REPRESENTING MOST OF THE WORLD'S NATIONS WITH NUCLEAR POWER CAPABILITY, WERE GENERALLY SANGUINE IN THEIR PRESENTATIONS AND SEEMED TO FEEL THAT CONTINUED EXPERIENCE AND ADVANCING TECHNOLOGY WOULD EVENTUALLY SOLVE MOST IF NOT ALL THE PROBLEMS CURRENTLY ASSOCIATED WITH NUCLEAR POWER. RESEARCH AND DEVELOPMENT MUST CONTINUE, HOWEVER, IN ORDER TO MAKE POSSIBLE THE PROMISE OF ABUNDANT POWER TO THE NEXT CENTURY'S TEENING MILLIONS WHO WOULD OTHERWISE FACE ENERGY STARVATION.
- 13-3-1-209 **BALANCING ENVIRONMENTAL IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE COURTS**
 NICHOLS, B. L.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
 ALTHOUGH ENVIRONMENTAL LEGISLATION RESULTING FROM PUBLIC CONCERN DATES BACK TO THE RIVERS AND HARBORS ACT OF 1899, ONLY RECENTLY HAS THE MOMENTUM OF CONCERN RESULTED IN FEDERAL LEGISLATION THAT FORMALLY WEIGHS THE COSTS OF ENVIRONMENTAL IMPACT AGAINST THE ECONOMIC AND TECHNICAL BENEFITS TO BE GAINED. THE NATIONAL ENVIRONMENTAL POLICY ACT OF 1969 (NEPA) NOT ONLY STRENGTHENS PREVIOUS LEGISLATION BUT, IN ADDITION, REQUIRES A BALANCING OF THE ENVIRONMENTAL IMPACT AND THE TECHNICAL AND ECONOMIC BENEFITS TO THE PUBLIC AS A WHOLE. THE INTERPRETATION OF NEPA BY THE U.S. COURT OF APPEALS FOR THE DISTRICT OF COLUMBIA CIRCUIT IN THE CALVERT CLIFFS CASE HAS HAD CONSIDERABLE IMPACT ON BOTH THE U.S. ATOMIC ENERGY COMMISSION (AEC) AND THE ELECTRIC-POWER INDUSTRY. ALTHOUGH THE BURDEN ON THE COMMISSION AND INDUSTRY MAY SEEM CUMBERSOME, IT IS CONCEIVABLE THAT THE THOROUGH REVIEW OF ALL ASPECTS OF PLANNED PROJECTS REQUIRED BY NEPA MAY RESULT IN A THOUGHTFUL BENEFIT - THE REDUCTION OF BOTH ENVIRONMENTAL IMPACT AND ECONOMIC OUTLAY AT FUTURE NUCLEAR POWER PLANTS. THIS ARTICLE DISCUSSES THE IMPLICATIONS FOR THE NUCLEAR POWER INDUSTRY OF ENVIRONMENTAL LEGISLATION AND THE DECISION OF THE COURT IN THE CALVERT CLIFFS CASE.
- 13-3-1-216 **NATIONAL CONFERENCE ON WASTE HEAT UTILIZATION**
 MORGAN, J. G.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
 THE CONFERENCE ON WASTE HEAT UTILIZATION WAS HELD IN GATLINBURG, TENN., OCT. 27-29, 1971. AMONG THE TOPICS CONSIDERED WERE TECHNICAL STATUS FOR HEAT UTILIZATION.

DEMONSTRATION PROJECTS, MARKETING AND ECONOMICS, PROJECTED APPLICATIONS, SITE SELECTION, AND WATER LAW AND WATER REGULATIONS. ALTHOUGH AT PRESENT THE FRACTION OF WASTE HEAT EFFECTIVELY USED MAY BE SMALL, THE CONFERENCE PROJECTED A SENSE OF URGENCY FOR PROMPT PLANNING AND ACTION. HOWEVER, IT WAS ALSO POINTED OUT THAT REGULATION CONSTRAINTS AND UNCERTAINTIES ACT AS DETERRENTS TO FINANCIAL INVESTMENT FROM PRIVATE SECTORS.

13-3-3-220 DETECTION OF FAILED FUEL ELEMENTS

GROSS, E.

COMMISSION OF THE EUROPEAN COMMUNITIES, KERNFORSCHUNGSANLAGE, JULICH, GERMANY

SAFETY, VERSATILITY, AND ECONOMY OF A HIGH TEMPERATURE PEBBLE-BED REACTOR COULD BE IMPROVED IF FUEL ELEMENTS WITH UNDESIRABLE HIGH FISSION PRODUCT RELEASE WERE REMOVED FROM THE CORE LOADING. HOWEVER, MEASUREMENTS FOR DETECTING THESE LEAKY ELEMENTS CAN ONLY BE PERFORMED DURING THE INTERCYCLING PERIODS WHEN A FUEL ELEMENT IS OUT OF THE CORE. THE COMMON DIFFICULTY ENCOUNTERED IN THE THREE DETECTION METHODS INVESTIGATED WAS THE SHORT TIME AVAILABLE FOR MEASUREMENTS, 7 TO 24 SEC, DEPENDING ON THE RATE OF CIRCULATION OF THE FUEL ELEMENTS. A FISSION GAS ANNEALING METHOD HAS PROVED APPLICABLE, AND A TECHNIQUE USING A LASER BEAM FOR REMOVING SMALL AMOUNTS OF GRAPHITE FOR BETA COUNTING IS STILL BEING EXAMINED.

13-3-5-225 THE 1971 TRITIUM SYMPOSIUM AT LAS VEGAS

BARTON, C. J. + BUTLER, M. M. + CUPPING, R. B.
RODNER, P. S.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

A "TRITIUM SYMPOSIUM" SPONSORED BY THE WESTERN ENVIRONMENTAL RESEARCH LABORATORY OF THE ENVIRONMENTAL PROTECTION AGENCY AND THE UNIVERSITY OF NEVADA AT LAS VEGAS WAS HELD IN LAS VEGAS AUG. 30 TO SEPT. 2, 1971. APPROXIMATELY 100 PAPERS WERE PRESENTED COVERING A BROAD RANGE OF TOPICS, INCLUDING TRITIUM PRODUCTION, ITS MOVEMENT IN THE ENVIRONMENT, ENVIRONMENTAL RELEASE AND MONITORING, DETECTION AND MEASUREMENT, BIOLOGICAL EFFECTS, BIONINETICS, APPLICATIONS IN BIOLOGY AND MEDICINE, AND HEALTH PHYSICS. SOME SPEAKERS REVIEWED PUBLISHED INFORMATION, BUT MANY NEW DATA WERE DISCUSSED BY OTHERS. THE SYMPOSIUM SERVED A USEFUL PURPOSE IN GATHERING TOGETHER SCIENTISTS CONCERNED WITH DIVERSE ASPECTS OF THIS IMPORTANT HYDROGEN ISOTOPE. MOST OF THE PAPERS FROM THE SYMPOSIUM, ALONG WITH SOME THAT WERE NOT PRESENTED, WILL BE PUBLISHED IN THE PROCEEDINGS DURING THE SUMMER OF 1972. THIS ARTICLE TOUCHES ON ALL ASPECTS OF THE MEETING, BUT PAPERS OF PARTICULAR INTEREST IN THE FIELD OF NUCLEAR SAFETY ARE EMPHASIZED.

13-4-1-275 NATURAL RADIATION IN THE URBAN ENVIRONMENT

YEATES, D. B. + GOLYIN, A. S. + MOELLER, D. W.
HARVARD UNIVERSITY, BOSTON, MASS.

NATURAL RADIATION IS THE LARGEST SOURCE OF POPULATION DOSE AND IS IMPORTANT AS A BASE LINE WITH WHICH RADIATION PROTECTION STANDARDS MAY BE COMPARED. IN THIS ARTICLE PREVIOUS WORK ON NATURAL BACKGROUND RADIATION LEVELS IS SUMMARIZED, AND SOME NEW DATA FROM BOSTON, MASS., ARE REPORTED. GAMMA DOSE RATES, CORRECTED FOR COSMIC RADIATION, WERE MEASURED WITH LARGE IONIZATION CHAMBERS - DOSE RATES INSIDE WOODEN SINGLE FAMILY DWELLINGS WERE 25 TO 50 PERCENT LOWER THAN THOSE OUTSIDE. IN MASONRY MULTIPLE FAMILY DWELLINGS, THEY WERE ABOUT 10 PERCENT LOWER. CONCENTRATIONS OF RADON DAUGHTERS IN THE AIR WERE MEASURED BY PREDECAY AND POSTDECAY ALPHA SPECTROMETRY - CONCENTRATIONS IN DWELLINGS WERE COMPARABLE WITH OUTDOOR CONCENTRATIONS, BUT CONCENTRATIONS IN BASEMENTS WERE HIGHER BY A FACTOR OF ABOUT 5. CONCENTRATIONS IN OFFICE BUILDINGS WERE QUITE LOW, THE RADON DAUGHTERS BEING REMOVED BY THE VENTILATION SYSTEM. EFFECTS OF BUILDING TYPE, CONSTRUCTION MATERIALS, AND VENTILATION ON HUMAN DOSE ARE DISCUSSED, AS ARE POSSIBLE WAYS OF REDUCING POPULATION DOSE.

13-4-2-287 SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS

SMETS, M. B.

EUROPEAN NUCLEAR ENERGY AGENCY, PARIS, FRANCE

THE FIRST EUROPEAN CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS WAS HELD AT ISPPA, ITALY, ON OCT. 27-30, 1970. FORTY-FIVE REPRESENTATIVES OF 14 COUNTRIES AND INTERNATIONAL ORGANIZATIONS MET TO CONSTITUTE A WORLDWIDE FORUM ON MATHEMATICAL MODELS AND PRACTICAL CONSEQUENCES OF SPACE-TIME CALCULATIONS. THEY REPORTED THAT SEVERAL COMPUTER PROGRAMS HAD BEEN DEVELOPED FOR THE SOLUTION OF SPACE-TIME PROBLEMS. AS THE MODELS BECAME MORE COMPLEX, HOWEVER, A BALANCE MUST BE STRUCK BETWEEN THE DESCRIPTION OF NEUTRON BEHAVIOR AND THAT OF FEEDBACK EFFECTS SO THAT COMPUTATIONAL IMPROVEMENTS TRULY RESULT IN IMPROVED UNDERSTANDING OF REACTOR BEHAVIOR.

13-4-3-295 A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS

FRY, D. M.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

A METHOD IS PRESENTED FOR ON-LINE MONITORING OF THE REACTIVITY FEEDBACK TIME CONSTANTS FOR DETERMINING THE OPERATING STABILITY OF LARGE FAST BREEDER REACTORS. IN THIS METHOD, MONITORING CAN BE PERFORMED WITHOUT INTERFERING WITH NORMAL REACTOR OPERATION.

WITH NEGLIGIBLE REACTOR POWER DISTURBANCE, AND WITHOUT THE NEED FOR SPECIAL IN-CORE REACTIVITY OSCILLATORS. THE METHOD ALSO IS CONDUCTIVE TO THE DETECTION OF PARTIAL FLOW BLOCKAGES IN COOLANT CHANNELS IN REACTOR CORE SUBASSEMBLIES.

- 13-4-4-304 ACCIDENTAL COBALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY
MADE, L. JR.
UT-AEC AGRICULTURAL RESEARCH LABORATORY, OAK RIDGE, TENN.
A RESEARCH TECHNICIAN ENTERED A COBALT-60 IRRADIATION FACILITY AT THE UNIVERSITY OF TENNESSEE-ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY IN OAK RIDGE, TENN., AND RECEIVED A TOTAL BODY EXPOSURE OF 260 R. CONTRIBUTING FACTORS IN THE INCIDENT WERE MALFUNCTIONING INTERLOCK SYSTEMS, FAILURE TO OBSERVE WARNING DEVICES, AND FAILURE TO FOLLOW ESTABLISHED PROCEDURES. SEVERAL PHYSICAL AND ADMINISTRATIVE CONTROLS HAVE BEEN ADDED TO PREVENT SUCH AN INCIDENT.
- 13-5-1-353 PRELIMINARY OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER
STEINER, D. + FRAAS, A. P.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER ARE CONSIDERED WITH REFERENCE TO A CONCEPTUAL FUSION REACTOR BASED ON THE DEUTERIUM - TRITIUM FUEL CYCLE. THIS ANALYSIS LEADS TO THE FOLLOWING OBSERVATIONS (1) THE ENGINEERED FEATURES NECESSARY TO LIMIT BIOLOGICAL IMPACT IN THE EVENT OF AN ACCIDENT MAY HAVE TO SATISFY LESS STRINGENT REQUIREMENTS IN FUSION REACTOR DESIGN THAN IN FISSION-REACTOR DESIGN. (2) DURING NORMAL OPERATION, TRITIUM WILL PRESENT THE PRIMARY SOURCE OF RADIOACTIVITY IN EFFLUENTS ASSOCIATED WITH FUSION POWER. THE MONITORING OF TRITIUM IN EFFLUENTS WILL BE REQUIRED ONLY AT THE REACTOR SITE SINCE THE FUEL REPROCESSING SYSTEM OF A FUSION REACTOR IS AN INTEGRAL PART OF THE REACTOR. ECONOMIC CONTAINMENT OF TRITIUM MUST BE A MAJOR OBJECTIVE OF FUSION REACTOR TECHNOLOGY. (3) LONG LIVED RADIONUCLIDES WILL BE PRODUCED IN THE STRUCTURAL COMPONENTS OF FUSION REACTORS. IF NIOBIUM IS EMPLOYED AS THE STRUCTURAL MATERIAL, DISPOSAL SCHEMES SIMILAR TO THOSE CURRENTLY PROPOSED FOR FISSION REACTOR WASTES MAY BE REQUIRED. IF VANADIUM IS EMPLOYED, RECYCLE OF THE STRUCTURAL MATERIAL APPEARS POSSIBLE. (4) ALTHOUGH AFTERHEAT REMOVAL WILL BE QUANTITATIVELY LESS OF A PROBLEM WITH FUSION POWER THAN WITH FISSION POWER, IT MUST BE CONSIDERED IN THE ENGINEERING DESIGN OF FUSION REACTORS.
- 13-5-3-364 INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA CONFERENCE AND EXHIBIT
LISSER, C. S. + EADS, B. G. + EUGGINS, S. C.
HAGEN, E. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
THE 26TH INSTRUMENT SOCIETY OF AMERICA CONFERENCE AND EXHIBIT PRESENTED A REVIEW OF THE STATE OF THE TECHNOLOGY OF THE INDUSTRY AND A SUGGESTION OF THINGS TO COME. A BROAD RANGE OF TOPICS CONCERNING INSTRUMENTATION THEORY AND APPLICATION WAS CONSIDERED IN THE 72 TECHNICAL SESSIONS COMPRISING THE CONFERENCE PROGRAM. AN INNOVATION THIS YEAR WAS A SERIES OF DISTINGUISHED LECTURES ON SPECIAL AREAS OF INSTRUMENTATION. CONCERN ABOUT INTERNATIONAL STANDARDS HIGHLIGHTED THE ECONOMIC ASPECT, AND MORE RESEARCH AND DEVELOPMENT WERE ACKNOWLEDGED TO BE NEEDED IN THE ENVIRONMENTAL FIELD. SOME NEW WORK WAS REPORTED ON THE STUDY OF VIBRATION AND ITS EFFECTS IN AND ON NUCLEAR PLANTS. SELECTED PAPERS OF PARTICULAR SAFETY SIGNIFICANCE ARE REVIEWED.
- 13-5-4-373 GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT INTERIOR STRUCTURES
SINHEIL, I. S.
ARCHTEL CORPORATION, GAITHERSBURG, MARYLAND
THE CONTAINMENT INTERIOR STRUCTURES OF PRESSURIZED WATER REACTORS HAVE SEVERAL SAFETY FUNCTIONS FOR WHICH THEIR STRUCTURAL INTEGRITY IS OF UTMOST IMPORTANCE. BY PROVIDING SUPPORT DURING PLANT OPERATION AND POSTULATED EARTHQUAKES, THEY HELP PREVENT THE OCCURRENCE OF A LOSS OF COOLANT ACCIDENT. FURTHERMORE, IF AN ACCIDENT DOES OCCUR, THEY HELP MITIGATE ITS CONSEQUENCES BY PROTECTING THE CONTAINMENT AND ALL THE PROVIDED ENGINEERED SAFETY FEATURES FROM JET FORCES, WHIPPING PIPES, DIFFERENTIAL PRESSURES, AND MISSILES. THE PROBLEMS AND COMPLEXITY OF COMBINING SYSTEM AND STRUCTURAL REQUIREMENTS IN ARRIVING AT A CONSERVATIVE AND YET ECONOMICAL DESIGN WARRANT A GENERAL DISCUSSION OF THE CRITERIA INVOLVED AND OF THE SPECIAL DYNAMIC STRUCTURAL PROBLEMS ENCOUNTERED.
- 13-5-5-386 SYMPOSIUM ON RADIOECOLOGY APPLIED TO THE PROTECTION OF MAN AND HIS ENVIRONMENT
SHEETS, J. G. P. R. + BERLIN, A. + ARAVIS, R. J.
COMMISSION OF EUROPEAN COMMUNITIES, LUXEMBOURG
THIS SYMPOSIUM, ORGANIZED BY THE COMMISSION OF THE EUROPEAN COMMUNITIES, WAS DEVOTED TO THE ASSESSMENT OF THE ACHIEVEMENTS OF RADIOECOLOGY IN THE PROTECTION OF MAN AGAINST RADIOACTIVE POLLUTANTS (AREAS STILL IN NEED OF RESEARCH WERE DEFINED) AND TO THE DETERMINATION OF THE EXTENT TO WHICH THE KNOWLEDGE GAINED IN RADIOECOLOGY CAN BE APPLIED TO THE FIGHT AGAINST NONRADIOACTIVE POLLUTANTS. ONE OF THE CONCLUSIONS WAS THAT THE CONCEPT OF "RADIOECOLOGICAL FORECASTING" SHOULD BE INTRODUCED, ALLOWING FOR LONG TERM PLANNING IN THE SETTING UP OF NEW NUCLEAR INSTALLATIONS. MANY OF THE CONCEPTS DEVELOPED IN

RADIOECOLOGY FIND THEIR PLACE IN THE FIGHT AGAINST NONRADIOACTIVE POLLUTANTS. THE NOTION OF 'ENGAGED DAMAGE' CAN BE USED FOR THE DEVELOPMENT OF 'CRITERIA' AND 'GUIDE LEVELS' IN THE ESTABLISHMENT OF REGULATIONS.

- 13-5-9-391 ATMOSPHERIC TRANSPORT AND DISPERSION OVER CITIES
GIFFORD, F. A., JR.
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK RIDGE, TENNESSEE
IN CITIES, ATMOSPHERIC DISPERSION AND TRANSPORT OF POLLUTANTS ARE AFFECTED BY SEVERAL FACTORS THAT ARE NOT PRESENT IN THE NONURBAN ENVIRONMENT, PRINCIPALLY THE ENHANCED SURFACE ROUGHNESS AND HEAT CAPACITY. THE EFFECTS OF THESE ON THE MICROMETEOROLOGY OF THE URBAN ATMOSPHERIC BOUNDARY LAYER ARE BRIEFLY SUMMARIZED, AND DIFFUSION MODELS FOR URBAN SOURCES ARE REVIEWED. THE BOUNDARY LAYER OVER A CITY IS USUALLY NEARLY ADIABATIC. DISPERSION IS ENHANCED BY THE INCREASED URBAN ROUGHNESS, ALTHOUGH TRANSPORT BY THE MEAN WIND IS SLIGHTLY DECREASED BY THE AERODYNAMIC CRAG. SUCH REMOVAL PROCESSES AS FALLOUT AND PRECIPITATION SCAVENGING, AS WELL AS CHEMICAL REACTIONS, ARE BRIEFLY DISCUSSED.
- 13-6-1-451 ISPRAS CONTRIBUTION TO REACTOR SAFETY
RANDELS, J.
JOINT CENTRE FOR NUCLEAR RESEARCH, ISPRAS (VARESE), ITALY
EURATOMS JOINT RESEARCH CENTRE AT ISPRAS HAS HAD FOR SEVERAL YEARS AN EXTENSIVE PROGRAM IN REACTOR SAFETY RESEARCH AND DEVELOPMENT. IN THE FAST REACTOR SAFETY FIELD, IT INCLUDED WORK ON THE INTERACTION BETWEEN URANIUM DIOXIDE AND SODIUM AND ON THE DYNAMIC LOADING OF LIQUID METAL COOLED FAST BREEDER REACTOR CONTAINMENT. RESEARCH IN SUPPORT OF WATER REACTOR SAFETY COVERS DEPRESSURIZATION AND EMERGENCY CORE COOLING SYSTEM STUDIES. A MORE GENERALIZED RESEARCH EFFORT IS UNDER WAY IN THE AREAS OF REACTOR DYNAMICS, RELIABILITY THEORY, EARLY FAILURE DETECTION, AND FRACTURE MECHANICS AND PIPE RUPTURE.
- 13-6-2-459 RADIOLYTIC HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER REACTORS
ZITTEL, H. E.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE RADIOLYTIC GENERATION OF HYDROGEN FROM THE PRESSURE SUPPRESSION COOLANT LIQUID FOLLOWING A LOSS OF COOLANT ACCIDENT IN LIGHT WATER COOLED POWER REACTORS IS AN IMPORTANT CONSIDERATION SINCE IT COULD CONCEIVABLY RESULT IN A HAZARDOUS CONDITION. STUDIES CARRIED OUT IN THIS LABORATORY ON THE PROBABLE RADIOLYTIC HYDROGEN GENERATION IN BOTH THE PWR AND BWR ACCIDENT CASES HAVE BEEN INSTRUMENTAL IN ESTABLISHING A BASE FROM WHICH TO CONSIDER THIS POINT. A REVIEW OF THE EXPERIMENTAL WORK AND THE CONCLUSIONS ARISING FROM THE WORK ARE GIVEN.
- 13-6-2-467 SOME PRELIMINARY CONSIDERATIONS RELATING TO AN EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL
BROOK, A. J.
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY, WARRINGTON, LANCES
THE CALCULATION OF ENERGY RELEASE RESULTING FROM SEVERE EXCURSIONS IN FAST REACTORS DEPENDS A KNOWLEDGE OF THE EQUATION OF STATE OF REACTOR FUEL. THIS ARTICLE DISCUSSES THE MODIFYING EFFECTS THAT FISSION PRODUCTS MAY PRODUCE ON PRESSURE TEMPERATURE RELATIONS AND OUTLINES SOME OF THE MAJOR UNCERTAINTIES IN THE PHYSICAL AND CHEMICAL BEHAVIOR OF THE FISSION PRODUCTS. ATTENTION IS DRAWN TO THE IMPORTANCE OF REACTOR CONDITIONS AT THE INITIATION OF THE SUPERPROMPT EXCURSION, AND AN INDICATION IS GIVEN OF THE EFFECTS OF FISSION PRODUCT PRESSURES ON NUCLEAR EXCURSION YIELDS AND CONTAINMENT REQUIREMENTS.
- 13-6-4-478 EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION BED
UNDERHILL, D. W.
HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASS.
THEORETICAL AND EXPERIMENTAL STUDIES SHOW THAT, IN THE EVENT OF AN ACCIDENTAL RUPTURE OF A PRESSURIZED NOBLE GAS ADSORPTION BED, (1) THE PRACTICAL RELEASE OF ADSORBED FISSION GASES CAN BE SMALLER THAN THE RATIO OF THE INITIAL-TO-FINAL BED PRESSURES, (2) FOR A GIVEN SET OF CONDITIONS, THE FRACTION OF KRYPTON RELEASED WILL BE GREATER THAN THAT OF XENON, AND (3) WHERE THE LEAK IS RELATIVELY SLOW AND THE CARRIER GAS IS ARGON, AS IN THE PROPOSED FAST FLUX TEST FACILITY DESIGN, THE FRACTION OF FISSION GASES ESCAPING CAN BE SIGNIFICANTLY SMALLER THAN THAT OF THE CARRIER GAS.
- 13-6-5-482 THE EMERGING ROLE OF THE CAMPUS RADIATION SAFETY OFFICER
ZIEMER, P. L.
PURDUE UNIVERSITY, LAFAYETTE, INDIANA
UNIVERSITY RADIATION SAFETY OFFICERS (RSOS) FROM THROUGHOUT THE UNITED STATES AND CANADA MET AT PURDUE UNIVERSITY IN SEPTEMBER 1971 TO EXAMINE THEIR ROLE ON THE CAMPUS AND HOW THIS ROLE IS CHANGING. THE CONFERENCE FOCUSED PRIMARILY ON ADMINISTRATIVE ASPECTS OF CAMPUS RADIATION SAFETY PROGRAMS BUT ALSO INCLUDED DISCUSSIONS OF PRACTICAL HEALTH PHYSICS PROBLEMS COMMON TO THE CAMPUSES. A WIDE DIVERSITY WAS SEEN IN THE ORGANIZATIONAL STRUCTURES AND RESPONSIBILITIES OF THE MANY UNIVERSITIES REPRESENTED. THE CAMPUS RSO PARTICIPATES IN HEALTH PHYSICS ADMINISTRATION, TEACHING, AND RESEARCH, FINDING THE PROPER BALANCE OF THESE FUNCTIONS IN AN ORGANIZATIONALLY SOUND

FRAMEWORK WILL PERMIT HIM TO FILL HIS ROLE IN MEETING THE GROWING HEALTH PHYSICS NEEDS OF HIS CAMPUS IN THE FUTURE.

- 14-1-1-001 EARTHQUAKE RESISTANT DESIGN OF ENGINEERING STRUCTURES
 BELL, C. G.
 UNIVERSITY OF NORTH CAROLINA, CHARLOTTE, NORTH CAROLINA
 A 2-WEEK MEETING ON EARTHQUAKE-RESISTANT DESIGN OF ENGINEERING STRUCTURES, HELD AT THE UNIVERSITY OF CALIFORNIA, BERKELEY, JUNE 19-30, 1972, IS SUMMARIZED. THE PRINCIPAL TOPICS COVERED INCLUDE SEISMOLOGY AND STRONG-MOTION RECORDS, RESPONSE OF SOILS AND DAMS, FINITE ELEMENT APPLICATIONS IN STRUCTURES AND FOUNDATIONS, A NEW LARGE SHAKER, AND PROBABILISTIC DESIGN. CONSIDERABLE INFORMATION WAS PRESENTED THAT WILL BE USEFUL AS BACKGROUND IN SITING AND EARTHQUAKE-RESPONSE CONSIDERATIONS FOR NUCLEAR REACTORS.
- 14-1-1-006 THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS
 DAVIS, J. P.
 CONSOLIDATED Edison COMPANY, NEW YORK, N. Y.
 THIS IS THE FIRST OF A SERIES OF TWO ARTICLES, AND IT PRESENTS A SURVEY OF THE REGULATION OF ENVIRONMENTAL FEATURES OF NUCLEAR POWER PLANTS. RECEIVING PARTICULAR ATTENTION IS THE JURISDICTION OF THE ATOMIC ENERGY COMMISSION UNDER THE ATOMIC ENERGY ACT OF 1954, AND ITS EXPANSION UNDER THE NATIONAL ENVIRONMENTAL POLICY ACT OF 1969. SEVERAL OTHER FEDERAL AGENCIES, INCLUDING THE FEDERAL POWER COMMISSION, THE CORPS OF ENGINEERS, AND THE ENVIRONMENTAL PROTECTION AGENCY, ALSO PLAY IMPORTANT ROLES IN THIS AREA. IN ADDITION, THERE HAVE BEEN INTERESTING RECENT DEVELOPMENTS IN THE STATE REGULATORY PICTURE IN THE FIELD OF POWER PLANT SITING.
- 14-1-2-004 PROBABILITY ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF COOLANT ACCIDENTS
 LINGGACKERS, K-H + STOEDEL, H.
 TECHNICAL SURVEILLANCE ORGANIZATION, RHEINLAND, FEDERAL REPUBLIC OF GERMANY
 IN THE PAST, IT HAS BEEN THE PRACTICE IN THE FEDERAL REPUBLIC OF GERMANY TO BASE SITE SELECTION AND ENGINEERING SAFEGUARDS FOR NUCLEAR POWER PLANTS ON THE SO-CALLED MAXIMUM CREDIBLE ACCIDENT CONCEPT (MCA CONCEPT). IN THE OPINION OF THE AUTHORS, IT WILL NOW BE NECESSARY TO USE A MORE QUANTITATIVE APPROACH, AS DEVELOPED BY THE UNITED KINGDOM ATOMIC ENERGY AUTHORITY, BECAUSE NUCLEAR POWER PLANTS MUST BE CONSTRUCTED IN MORE DENSELY POPULATED AREAS. WITH RESPECT TO LIGHT WATER REACTORS, LOSS OF COOLANT ACCIDENTS COULD LEAD TO A RELATIVELY HIGH RELEASE OF FISSION PRODUCTS. IN THIS ARTICLE THE PROBABILITY ANALYSIS IS APPLIED TO LOSS OF COOLANT ACCIDENTS IN THE NUCLEAR POWER PLANTS OF MURGASSEN (DDR) AND STADE (FRG), WHICH ARE NOW UNDER CONSTRUCTION. THE INFLUENCE OF UNCERTAINTIES IN THE MAIN FACTORS OF THIS ANALYSIS (E.G., PROBABILITY OF FAILURES IN PIPING AND CONTAINMENT) IS DISCUSSED.
- 14-1-3-021 HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS
 RAUDEMUSH, H. H.
 GULF GENERAL ATOMIC, INC., SAN DIEGO, CALIFORNIA
 CONTROL BOARD LAYOUT DESIGN TRENDS IN THE NUCLEAR POWER INDUSTRY ARE EXAMINED AND EVALUATED FROM A HUMAN ENGINEERING ASPECT. EXTENSIVE REVIEW OF EXISTING LITERATURE AND STUDY OF PRESENT CONTROL BOARD LAYOUT PHILOSOPHY SUBSTANTIATE THE SUGGESTION THAT A GREAT NEED EXISTS WITHIN THE NUCLEAR POWER INDUSTRY FOR CONTROL BOARD LAYOUT STANDARDS BASED ON FORMAL HUMAN ENGINEERING STUDIES. RESULTS OF A DETAILED HUMAN ENGINEERING EVALUATION OF A MINIATURIZED CONTROL BOARD ARE PRESENTED TO DEMONSTRATE BOTH THE ADVANTAGES AND DISADVANTAGES OF SIZE REDUCTION. FINALLY, A SUBJECTIVE DISCUSSION OF OPERATOR-AUTOMATION INTERFACES SUGGESTS THE DIRECTION FUTURE CONTROL BOARD DESIGN SHOULD TAKE TO ASSURE OPTIMUM OPERATOR CONTROL AND SAFETY.
- 14-1-4-027 SAFETY EXPERIENCE GAINED FROM RAPSODIE OPERATION
 APCOUS, J. P. + CHANTOT, H. + PETIT, J. + STACHURA, S. J.
 COMMISSARIAT A L'ENERGIE ATOMIQUE, SAINT PAUL, LEZ, FRANCE + ATOMICS INTERNATIONAL, CINDOGA PARK, CALIF.
 THIS ARTICLE BRIEFLY DESCRIBES AND ANALYZES THREE OPERATIONAL INCIDENTS AT THE FRENCH EXPERIMENTAL FAST REACTOR RAPSODIE. THESE EVENTS SERVED TO IDENTIFY VARIOUS DESIGN INADEQUACIES TO BE AVOIDED IN FUTURE PLANTS AND ALSO DEMONSTRATED SEVERAL POSITIVE SAFETY ASPECTS OF THE DESIGN. THE INCIDENTS INVOLVED (1) SODIUM OVERFLOW THROUGH PENETRATIONS IN A SMALL ROTATING PLUG AS A RESULT OF INADEQUATE REACTOR COVER-GAS OVERPRESSURE, (2) A FUEL-HANDLING INCIDENT THAT RESULTED IN DEFORMATION OF HANDLING MECHANISMS AND CORE ASSEMBLIES, AND (3) OVERFLOW OF A FUSIBLE METAL SEAL IN A SMALL ROTATING PLUG DUE TO A PRESSURIZATION ANOMALY. THE INCIDENTS GENERALLY INVOLVED COMBINATIONS OF DESIGN, EQUIPMENT, PROCEDURAL, OR OPERATIONAL ERRORS.
- 14-2-1-079 SAFETY ASSESSMENT PHILOSOPHY OF THE FAST FLUX TEST FACILITY
 FFTF PROJECT PERSONNEL
 HANFORD ENGINEERING DEVELOPMENT LABORATORY, RICHLAND, WASH.
 THIS REPORT EXPLAINS HOW SAFETY HAS BEEN EMPHASIZED THROUGHOUT THE FAST FLUX TEST FACILITY (FFTF) PROJECT AS AN INTEGRAL PART

OF THE TOTAL PROJECT EFFORT FROM THE INCEPTION OF DESIGN THROUGHOUT ALL ASPECTS OF THE ENGINEERING, CONSTRUCTION, TESTING, OPERATION, AND MAINTENANCE OF THE PLANT. THIS OVERALL CONCEPT IS EXPRESSED IN TERMS OF THREE LEVELS OF SAFETY. THE FIRST LEVEL ADDRESSES THE PREVENTION OF ACCIDENTS THROUGH THE INTRINSIC FEATURES OF THE DESIGN OF THE PLANT AND THE QUALITY, REDUNDANCY, TESTABILITY, INSPECTABILITY, AND FAIL SAFE FEATURES OF THE COMPONENTS OF THE REACTOR AND PLANT. THE SECOND LEVEL CONCERNS PROVIDING PROTECTION AGAINST SUCH INCIDENTS AS REACTIVITY INSERTIONS OR FAILURES OF PARTS OF THE CONTROL SYSTEM WHICH MIGHT OCCUR IN SPITE OF THE CARE TAKEN IN DESIGN, CONSTRUCTION, AND OPERATION TO PREVENT THEM. THE THIRD LEVEL OF SAFETY SUPPLEMENTS THE FIRST TWO THROUGH FEATURES THAT ADD MARGIN IN THE PLANT DESIGN AS ADDITIONAL ASSURANCE THAT PROTECTION TO THE PUBLIC IS PROVIDED EVEN IN THE EVENT OF THE OCCURRENCE OF EXTREMELY UNLIKELY AND UNFORESEEN CIRCUMSTANCES. ALSO INCLUDED IN THE DISCUSSION ARE THE PRINCIPAL FFTF DESIGN PARAMETERS AND THE REACTOR'S INHERENT SAFETY FEATURES, THE PROGRAMS OF TESTING AND DEVELOPMENT TO SUPPORT THE DESIGN, AND THE CARE USED IN CONSTRUCTION AND TESTING.

14-2-2-091

COUPLED NEUTRONICS HYDRODYNAMICS METHODS

TODIAS, M.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE PRINCIPAL FEATURES OF COMPUTER CODES AND METHODS FOR REACTOR DISASSEMBLY ANALYSIS ARE BRIEFLY SURVEYED. FROM THE BASICALLY HAND CALCULATED METHOD OF BETHE AND TAIT, THESE METHODS HAVE PROGRESSED TO FAIRLY ELABORATE PROGRAMS DESIGNED TO ESTIMATE THE CONSEQUENCES OF A HYPOTHETICAL FAST REACTOR CORE DISASSEMBLY. SUCCESSIVE DEVELOPMENTS HAVE INCLUDED SUCH FEATURES AS DOPPLER FEEDBACK, DELAYED NEUTRONS, IMPROVED EQUATIONS OF STATE, AND MORE ELABORATE GEOMETRIES.

14-2-3-095

OBSTACLES TO COMPLETE AUTOMATION OF REACTOR CONTROL

EPFLER, E. P. & DAKES, L. C.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

ANOMALOUS REACTIVITY CHANGES RESULTING FROM CONDITIONS OTHER THAN ANTICIPATED CONTROL ACTION OCCURRED IN EARLY EXPERIMENTAL REACTORS AND LED TO LOCAL MELTING. DOUBT HAS BEEN EXPRESSED, HOWEVER, THAT SUCH CHANGES COULD OCCUR IN COMMERCIAL POWER REACTORS. DEFENSES AGAINST THE REACTIVITY ANOMALY HAVE SINCE BEEN DEVELOPED FOR TEST AND PRODUCTION REACTORS WHICH HAVE PERMITTED AN INCREASED DEGREE OF AUTOMATION TO BE SAFELY APPLIED. THE PRINCIPLES SO DEVELOPED, WHICH RELY ON DIGITAL TECHNIQUES, ARE EQUALLY APPLICABLE TO POWER REACTORS. ACCEPTED CRITERIA FOR THE APPLICATION OF DIGITAL TECHNIQUES TO CONTROL AND PROTECTION SYSTEMS HAVE NOT YET BEEN DEVELOPED, HOWEVER, AN EXTENSION OF EXISTING PRACTICES AND PRECEDENTS SHOULD BE ADEQUATE UNTIL SUCH CRITERIA ARE AVAILABLE.

14-2-3-105

LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSIS

THIE, J. A.

CONSULTANT, BARRINGTON, ILL.

A MEANS IS DESCRIBED FOR SEPARATING A REACTOR PLANT'S VARIABLE RADIATION FROM A LARGER AND ALSO VARYING BACKGROUND UTILIZING THE DIFFERING CHARACTER OF FLUCTUATIONS PRESENT. IT IS SHOWN THAT AN ACCURACY OF PLUS OR MINUS 0.9 HR PER YEAR IN THE FENCE LINE DOSE RATE FROM A BOILING WATER REACTOR (BWR) PLUME IS OBTAINABLE FROM RANDOM FLUCTUATION ANALYSIS, IN WHICH THE STANDARD DEVIATION IS THE BASIC MEASUREMENT TOOL. OTHER SPECIFIC APPLICATIONS OF AUTOCORRELATION, CROSS CORRELATION, AND SPECTRAL ANALYSIS TO THE GENERAL PROBLEM OF SIGNAL EXTRACTION IN LOW LEVEL ENVIRONMENTAL MONITORING ARE DISCUSSED.

14-2-4-111

THE TWELFTH AEC AIR-CLEANING CONFERENCE

MOELLER, U. M. & FIRST, M. W.

HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASS.

THE TWELFTH AEC AIR-CLEANING CONFERENCE WAS HELD AUGUST 28-31, 1972, IN OAK RIDGE, TENN. REGISTRATION TOTALED A RECORD 340 PEOPLE, INCLUDING PERSONNEL FROM ESSENTIALLY ALL FACETS OF GOVERNMENT, INDUSTRY, AND EDUCATIONAL INSTITUTIONS, PLUS REPRESENTATIVES FROM SEVEN FOREIGN COUNTRIES. MAJOR TOPICS WERE CURRENT RESEARCH ON AIR AND GAS CLEANING SYSTEMS OF INTEREST TO THE NUCLEAR COMMUNITY AND MORE RECENT CONSIDERATIONS IN THE DESIGN OF SYSTEMS TO RESIST THE EFFECTS OF FIRE, EARTHQUAKES, AND OTHER MECHANICAL STRESSES. ALSO DISCUSSED WERE AIR CLEANING PROBLEMS ASSOCIATED WITH URANIUM MINING, HIGH TEMPERATURE GAS COOLED REACTORS, AND CHEMICAL PROCESSING PLANTS. CLEAR-CUT BENEFITS RESULTING FROM THE CONFERENCE WERE BETTER DEFINITION OF THE MAJOR PROBLEMS CONFRONTING THE PROFESSION AND PROVISION OF AN OPPORTUNITY FOR GROUPS DEALING ON SIMILAR PROBLEMS TO SHARE THEIR MOST RECENT DATA. PROCEEDINGS OF THE CONFERENCE WERE PUBLISHED IN JANUARY 1973.

14-3-1-165

THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS

DAVIS, J. P.

CONSOLIDATED Edison COMPANY, NEW YORK, N.Y.

PART ONE OF THIS TWO-PART ARTICLE (SEE NUCLEAR SAFETY FOR JANUARY-FEBRUARY 1973) DISCUSSED U. S. NEEDS FOR ELECTRIC POWER AND THE ROLE OF NUCLEAR ENERGY IN MEETING THESE NEEDS. THE MAJOR PORTION OF THE ARTICLE REVIEWED THE REGULATORY PROCESS THAT IS CURRENTLY REQUIRED FOR NUCLEAR POWER PLANTS. PART TWO

DISCUSSES THE RADIOLOGICAL AND NONRADIOLOGICAL EFFECTS OF NUCLEAR POWER GENERATION ON THE ENVIRONMENT AND THE MEANS FOR THEIR REGULATION ALONG WITH SOME RELATED CASES AND CONTROVERSIES. PROPOSALS FOR IMPROVEMENTS THROUGH CHANGES IN PROCEDURES AND NEW LEGISLATION ARE ALSO EXAMINED.

- 14-3-1-181 ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY
NEIDER, R. J. A.
FEDERAL INSTITUTE OF MATERIALS TESTING, FEDERAL REPUBLIC OF GERMANY
THE INCREASING DEMAND FOR NUCLEAR STANDARDS TO FACILITATE THE SITING, DESIGN, AND LICENSING OF NUCLEAR POWER PLANTS IS EVIDENT IN GERMANY AS IN MOST OTHER COUNTRIES WITH A VIABLE NUCLEAR CAPABILITY. AS A RESULT, THE GERMAN STANDARDS INSTITUTE'S NUCLEAR TECHNOLOGY COMMITTEE HAS RECENTLY INTENSIFIED ITS EFFORT. IN ADDITION, SEVERAL GERMAN TECHNICAL SOCIETIES ARE INVOLVED IN THE STANDARDIZATION EFFORT, AND GERMANY COOPERATES IN THE INTERNATIONAL STANDARDS ORGANIZATION ACTIVITIES.
- 14-3-2-187 PROBABILITY OF DAMAGE TO NUCLEAR COMPONENTS DUE TO TURBINE FAILURE
RUSH, S. M.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
THE PROBABILITY OF SIGNIFICANT DAMAGE TO CRITICAL COMPONENTS OF A NUCLEAR REACTOR SYSTEM DUE TO TURBINE FAILURE HAS BEEN ASSESSED BY DETERMINING THE COMBINED PROBABILITIES OF TURBINE FAILURE AND EJECTION OF AN ENERGETIC MISSILE (P1), ON THE BASIS OF 70,000 TURBINE YEARS OF OPERATION, A MISSILE FROM THE TURBINE STRIKING A CRITICAL COMPONENT (P2), AND SIGNIFICANT DAMAGE OCCURRING TO THE COMPONENT (P3). THE OVERALL PROBABILITY (P4) IS AN INDICATION OF HOW MUCH THE NUCLEAR PLANT DESIGNER NEEDS TO BE CONCERNED WITH THE TURBINE MISSILE PROBLEM. TURBINE FAILURES WERE REVIEWED TO ESTABLISH RELEVANCE WITH REGARD TO CURRENT PRACTICE IN DESIGN, FABRICATION, AND OPERATION OF NUCLEAR STEAM TURBINES. IF P1 IS 10⁻⁴ PER YEAR, P2 IS 10⁻³ FOR STRIKE ON A 1200 SQUARE FT. AREA, AND P3 APPROACHES 1, THEN P4 IS APPROXIMATELY 10⁻⁷ IF P2 INCREASES. EVALUATION OF P3 BECOMES NECESSARY.
- 14-3-2-201 FACTORS LIMITING PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST REACTOR CORE.
TEAGUE, M. J. + MATHER, D. J.
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CULCHETH, WA. WARRINGTON, LANC.
PRELIMINARY CALCULATIONS ARE REPORTED WHICH ILLUSTRATE HOW PRESSURES FROM FISSION PRODUCTS IN IRRADIATED FUEL WOULD DRASTICALLY REDUCE THE EXPLOSIVE ENERGY RELEASE IN A FAST REACTOR SUBJECTED TO A FAST REACTIVITY RAMP. ADDITIONAL EMPHASIS IS PUT ON THE REDUCTION OF DAMAGING EFFECTS DUE TO RAPID GENERATION OF SODIUM VAPOR FOR THREE REASONS - LOWER FUEL TEMPERATURES AT CORE DISASSEMBLY, LESS VIOLENT INTERNAL DISASSEMBLY PROCESSES, AND GAS BLANKETING OF FUEL PARTICLES.
- 14-3-3-206 STANDBY EMERGENCY POWER SYSTEMS I. THE EARLY PLANTS
MAGER, E. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
AVAILABILITY OF RELIABLE STANDBY OR EMERGENCY POWER SYSTEMS HAS ALWAYS BEEN A PRIME CONSIDERATION IN STATION DESIGN, BEGINNING WITH THE EARLY NUCLEAR REACTOR POWER PLANTS. THE DOCUMENTED OPERATING EXPERIENCES WERE REVIEWED FOR THE STATIC OFF-SITE AND ON-SITE STANDBY, EMERGENCY A-C POWER SOURCES, AND THE BATTERY SYSTEMS. PART 1 DISCUSSES THESE SYSTEMS FOR THE GENERATING REACTORS COMMISSIONED ABOUT 1959-1967. THE ABILITY OF THESE SYSTEMS TO PERFORM SATISFACTORILY WHEN NEEDED HAS BEEN VERY GOOD FOR THE EARLY PLANTS, BUT THE ABILITY TO PERFORM SATISFACTORILY AT ANY GIVEN TIME WAS SOMETHING LESS. HOWEVER, WITH THE ADVANCEMENT OF REGULATORY DESIGN GUIDES AND INDUSTRY STANDARDS, THE RELIABILITY IS EXPECTED TO CONTINUE TO BE GOOD AND THE AVAILABILITY TO BE IMPROVED. IN THE LATER PLANTS, TO BE DISCUSSED IN PART 2, WITH STANDARDIZED AND MODULARIZED DESIGNS, THESE EFFORTS AND EFFECTS WILL BECOME APPARENT THROUGH BETTER USE, TESTING, AND DOCUMENTATION.
- 14-3-3-220 SHOULD MEDICAL RADIATION EXPOSURE BE RECORDED FOR RADIATION WORKERS
EASON, C. F. + BROOKS, B. G.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
IT HAS BEEN STATED THAT THE AVERAGE YEARLY OCCUPATIONAL RADIATION EXPOSURE OF A RADIATION WORKER IS COMPARABLE TO THAT OF NATURAL BACKGROUND (THAT IS, 120 TO 150 MREMS), THUS THERE IS NO NEED TO ASSESS THE WORKER'S MEDICAL RADIATION EXPOSURE TO ENSURE HIS ON THE JOB HEALTH AND SAFETY. ON THE OTHER HAND, THERE ARE THOSE WHO BELIEVE THAT, IF A WORKER HAS UNDERGONE A LARGE THERAPEUTIC EXPOSURE, IT MAY BE DESIRABLE TO RESTRICT FUTURE OCCUPATIONAL EXPOSURE WHERE THE RISK OF A LARGE ACCIDENTAL EXPOSURE MAY BE UNUSUALLY HIGH. IT HAS ALSO BEEN STATED THAT, ALTHOUGH THE RADIATION DOSE RESULTING FROM MEDICAL EXPOSURE SHOULD NOT, IN GENERAL, BE INCLUDED IN DOSE LIMITATIONS, IT WOULD NEED TO BE TAKEN INTO ACCOUNT IN ANY ASSESSMENT OF THE TOTAL RISK TO THE INDIVIDUAL FROM RADIATION EXPOSURE. IN VIEW OF THE APPARENT DIFFERENCES OF OPINION ON THE VALUE OF NOTING MEDICAL RADIATION EXPOSURES, IS THERE A NEED FOR A RECORD-KEEPING SYSTEM THAT WILL PROVIDE MANAGEMENT, LABOR, AND THE MEDICAL PROFESSION WITH THE INFORMATION

NECESSARY TO WEIGH THE TOTAL RISK OF A WORKER EXPOSED TO A SOURCE OF IONIZING RADIATION. THIS ARTICLE REVIEWS VARIOUS ASPECTS RELATING TO THIS QUESTION.

- 14-4-1-267 PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS
STARR, C. + GREENFIELD, M. A.
UNIVERSITY OF CALIFORNIA AT LOS ANGELES, LOS ANGELES, CALIF.
THE RESULTS OF A STUDY COMPARING NUCLEAR POWER PLANTS WITH OIL FIRED PLANTS ARE REVIEWED AND ASSESSED IN TERMS OF PUBLIC HEALTH RISKS. THE STUDY WAS UNDERTAKEN AS A BASIC CONTRIBUTION TO THE STATE OF CALIFORNIA'S LONG RANGE PLANNING ON HOW BEST TO MEET THE POWER NEEDS OF ITS GROWING POPULATION. BASED ON AN 8-MONTH EVALUATION OF OIL FIRED AND NUCLEAR PLANTS IN URBAN SETTINGS, THE AUTHORS CONCLUDE THAT THE PUBLIC HEALTH RISK FROM EITHER TYPE OF PLANT IS ROUGHLY COMPARABLE TO THE HAZARDS TO WHICH THE PUBLIC IS EXPOSED BY UNCONTROLLABLE NATURAL EVENTS - LIGHTNING, INSECT OR SNAKE BITES, ETC. SUCH DEATHS OCCUR AT AN ANNUAL RATE OF APPROXIMATELY ONE PER MILLION OF POPULATION. A COMPARISON OF THE RISK FACTORS IN ROUTINE OPERATION OF DIFFERENT TYPES OF POWER PLANTS SHOWED THAT PUBLIC HEALTH RISKS FROM NUCLEAR PLANTS AVERAGED LESS THAN ONE-TENTH OF THE RISKS FROM OIL FIRED PLANTS.
- 14-4-1-274 THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF RADIOACTIVE MATERIALS
PRYOR, W. A.
USAEC OAK RIDGE OPERATIONS, OAK RIDGE, TENN.
THE THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF RADIOACTIVE MATERIALS WAS HELD IN RICHMOND, WASH., AUG. 14-20, 1971. ALL PHASES OF TRANSPORTATION WERE COVERED IN THE 95 PAPERS PRESENTED, AND THERE WERE OVER 450 REGISTRANTS REPRESENTING 17 NATIONS. HIGHLIGHTS OF THE MANY TOPICS DISCUSSED IN BOTH THE FORMAL AND INFORMAL SESSIONS ARE REVIEWED IN THIS ARTICLE.
- 14-4-2-291 PRESSURIZED WATER REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE
DOAN, P. L. + LANNING, D. D. + RASMUSSEN, M. C.
UNITED ENGINEERS AND CONSTRUCTORS, PHILADELPHIA, PA. + MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASS.
THE UNLIKELY LOSS OF COOLANT BY SOME TYPES OF POSTULATED PRESSURE VESSEL RUPTURES IN A LARGE, FOUR-LOOP 2750-MW(t) PRESSURIZED WATER REACTOR HAS BEEN STUDIED TO ASSESS THE RELATIVE IMPORTANCE AND CONSEQUENCES OF PRINCIPAL BLOWDOWN PROCESSES. THE COMPUTER CODES WHAM AND RELAP3 HAVE BEEN EMPLOYED AS THE PRINCIPAL TOOLS OF ANALYSIS. A LARGE NUMBER OF COMPUTER RUNS HAVE BEEN MADE WITH VARYING PARAMETERS SUCH AS BREAK TIME, BREAK LOCATION, BREAK SIZE, FUEL CLADDING GAP CONDUCTANCE, EMERGENCY CORE COOLING INJECTION MODES, VOID COEFFICIENTS, AND PHASE SEPARATION MODELS. CLEAR PATTERNS ARE OBSERVED ON THE ASYMPTOTIC BEHAVIOR OF MANY BLOWDOWN PARAMETERS.
- 14-4-2-304 PHENOMENOLOGICAL RESEARCH IN LMFBR ACCIDENT ANALYSIS
KELBER, C. M.
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
CURRENT NEEDS FOR AND PROGRAMS OF, PHENOMENOLOGICAL RESEARCH APPLIED TO PROBLEMS IN ACCIDENT ANALYSIS OF LIQUID METAL COOLED FAST BREEDER REACTORS ARE REPORTED. THIS SURVEY IS RESTRICTED TO PHENOMENA INVOLVED IN ANALYSIS OF HYPOTHETICAL ACCIDENTS - SODIUM VOIDING - COOLANT DYNAMICS, FUEL DYNAMICS, FUEL FAILURE PROPAGATION, FUEL COOLANT INTERACTION, POSTACCIDENT HEAT REMOVAL, VESSEL AND PLUG RESPONSE, SODIUM FIRES AND AEROSOLS, AND FISSION PRODUCT TRANSPORT. REPORTED FOR EACH CASE ARE THE CURRENT NEED, THE STATUS, THE CURRENT PROGRAM, AND THE ULTIMATE OBJECTIVE OF THE APPLICABLE RESEARCH. THE SURVEY INDICATES THAT IN THE RELATIVELY NEAR TERM AN IMPROVED BASIS FOR DESCRIBING AND PREDICTING THE COURSE OF AN ACCIDENT WILL PROBABLY BE DEVELOPED. IT IS MUCH LESS CERTAIN TO WHAT EXTENT IT WILL BE POSSIBLE TO FACTOR THIS UNDERSTANDING INTO PLANT DESIGN IN SUCH A WAY AS TO DECREASE THE NEED FOR STRONG CONTAINMENTS. AN ADVANCED TESTING PROGRAM REQUIRING MUCH LARGER SCALE TESTS MAY BE NEEDED.
- 14-4-3-315 AN ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER REACTORS
DUMA, D. W. + SAXE, R. F.
NORTH CAROLINA STATE UNIVERSITY, RALEIGH, N. C.
CONTROL ROD SYSTEM FAILURES AND MALFUNCTIONS ARE REVIEWED FOR ALL OF THE NUCLEAR POWER REACTORS FROM INCEPTION TO COMMERCIAL OPERATION THROUGH 1971. FAILURE RATES ARE CALCULATED AND TYPES OF FAULTS ANALYZED FOR COMMON CAUSES. SYSTEM PERFORMANCES ARE COMPARED FOR THE MAJOR VENDORS OF PRESSURIZED AND BOILING WATER REACTORS AS WELL AS OTHERS. RESULTS INDICATE THAT OVERALL FAILURE RATES FOR THE REACTORS CONSIDERED ARE NOT WIDELY VARIANT.
- 14-4-3-325 CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE ENVIRONMENT FROM AN LMFBR
TADMOR, J.
SOREF NUCLEAR RESEARCH CENTRE, YAVNE, ISRAEL
A THEORETICAL EVALUATION HAS BEEN MADE OF THE CONSEQUENCES OF AN ENVIRONMENTAL RELEASE OF SODIUM IN THE FORM OF AN AIRBORNE CLOUD RESULTING FROM A SODIUM FIRE IN A LIQUID METAL COOLED FAST BREEDER REACTOR. THE EVALUATION TAKES INTO CONSIDERATION

ONLY THE HAZARDS OF THE RADIONUCLIDES OF THE SODIUM. PROBLEMS ASSOCIATED WITH ACCOMPANYING FISSION PRODUCTS WERE NOT INCLUDED. ON THE BASIS OF CONSERVATIVE ASSUMPTIONS, THE DATA SHOW THAT THE MOST SIGNIFICANT EXPOSURE WOULD BE TO A CHILD THROUGH THE FORAGE - COW - MILK FOOD CHAIN PATHWAY. THE WHOLE BODY DOSE FOR AN INSTANTANEOUS DIRECT ENVIRONMENTAL RELEASE OF 1 G OF SODIUM (CONTAINING 0.31 CURIES OF SODIUM-24 AND 1.8 X 10¹-41 CURIES OF SODIUM-22) WOULD BE ABOUT 0.2 REM. THE CORRESPONDING DOSE RESULTING FROM A RELEASE OF 1000G OF SODIUM WITHIN THE REACTOR CONTAINMENT VESSEL, FOLLOWED BY A SUBSEQUENT CONTAINMENT VESSEL LEAKAGE RATE OF 0.1 PERCENT PER DAY, WOULD BE ABOUT 13 REMS. RESTRICTIONS ON THE USE OF MILK AND MILK PRODUCTS WOULD CONSIDERABLY REDUCE THESE VALUES. OTHER POSSIBLE COUNTERMEASURES THAT MIGHT BE TAKEN TO COPE WITH THE ENVIRONMENTAL HAZARDS ARE ALSO DISCUSSED.

14-4-5-340

SYMPOSIUM ON HEALTH PHYSICS IN THE HEALING ARTS

HART, J. C. + POSTON, J. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE SEVENTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY, HELD IN SAN JUAN, PUERTO RICO, DECEMBER 11-14, 1972, DEALT WITH HEALTH PHYSICS IN THE HEALING ARTS. THE SYMPOSIUM, WHICH INCLUDED OVER 100 TECHNICAL PAPERS, WAS ORGANIZED INTO NINE SESSIONS (INCLUDING TWO PANEL DISCUSSIONS). TOPICS INCLUDED - WHAT DO WE KNOW ABOUT (RADIATION) EFFECTS, RADIATION EXPOSURES IN THE HEALING ARTS, OPERATIONAL HEALTH PHYSICS AND QUALITY CONTROL, TRAINING, THE STATUS AND FUTURE TRENDS OF HEALTH PHYSICS TRAINING, TECHNOLOGICAL ASPECTS, GENERAL, EXPOSURE REDUCTION METHODOLOGY, REGULATION VS STANDARDIZATION, AND QUE PASA. HIGHLIGHTS OF THE TECHNICAL SESSIONS, INCLUDING REFRESHER COURSES AND PANEL DISCUSSIONS, ARE REVIEWED, AND THE COMPLETE SYMPOSIUM AGENDA IS INCLUDED.

14-4-6-356

DENSIFICATION OF REACTOR FUELS

CULBERT, W. H.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE MOVEMENT OF FUEL AS A CONSEQUENCE OF DENSIFICATION WAS DETERMINED TO BE THE CAUSE FOR COLLAPSE OF THE FUEL CLADDING IN A NUMBER OF PRESSURIZED WATER REACTORS. CLADDING COLLAPSE PRESENTED AN UNEVALUATED CONFIGURATION FOR HEAT REMOVAL IN BOTH NORMAL AND ACCIDENT SITUATIONS. ON NOV. 14, 1972, THE REGULATORY STAFF OF THE U.S. ATOMIC ENERGY COMMISSION ISSUED ITS TECHNICAL REPORT ON DENSIFICATION OF LIGHT WATER REACTOR FUELS. THEN ON FEB. 2, 1973, THE STAFF ISSUED THE REPORT ENTITLED ADDITIONAL TESTIMONY ON POINT BEACH 2 NUCLEAR PLANT IN REGARD TO FUEL DENSIFICATION AND ITS EFFECTS. BECAUSE OF THE INTEREST IN THIS SUBJECT, SUMMARIES OF BOTH OF THESE AEC REPORTS ARE PRESENTED HERE, ALONG WITH THE BIBLIOGRAPHY INCLUDED WITH THE NOVEMBER 14 REPORT.

14-4-6-362

ACTIVITY CONFINEMENT AND DECONTAMINATION AFTER FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE ROD

JOSEPH, J. W., JR. + LITTLE, J. W., JR.

E. I. DU PONT DE MEMOURS AND COMPANY, AIKEN, S. C.

ANTIMONY IN AN IRRADIATED SOLAR ROD MELTED WHILE THE ROD WAS SUSPENDED IN AIR IN THE K REACTOR ROOM AT THE SAVANNAH RIVER PLANT. THE FAILURE RELEASED ABOUT 85,000 CURIES OF ACTIVITY, WHICH WAS DISTRIBUTED IN THE REACTOR ROOM AND THE CONFINEMENT FILTERS IN THE VENTILATION EXHAUST SYSTEM. THE CONFINEMENT FILTERS PREVENTED A SIGNIFICANT ACTIVITY RELEASE, ONLY 3 MILLICURIES ESCAPED TO THE ENVIRONS, AND NO DECONTAMINATION WAS REQUIRED OUTSIDE THE REACTOR BUILDING. DECONTAMINATION OF THE REACTOR ROOM AND REPLACEMENT OF THE CONTAMINATED FILTER COMPARTMENTS REQUIRED ABOUT 3 1/2 MONTHS BEFORE THE REACTOR WAS RETURNED TO NORMAL OPERATION.

14-5-1-409

HEALTH EFFECTS OF ELECTRICITY GENERATION FROM COAL, OIL, AND NUCLEAR FUEL

LAVE, L. B. + FREEBURG, L. C.

CARNEGIE-MELLON UNIVERSITY, PITTSBURGH, PA.

OCCUPATIONAL AND PUBLIC HEALTH EFFECTS OF GENERATING ELECTRICITY FROM COAL, URANIUM, AND OIL ARE COMPARED, WITH PARTICULAR ATTENTION GIVEN TO ACCIDENT AND CHRONIC-DISEASE RATES FOR FUEL EXTRACTION AND AIRBORNE EMISSIONS FROM POWER AND REPROCESSING PLANTS. IT IS CONCLUDED THAT URANIUM OFFERS LESS OF A HEALTH HAZARD AS A FUEL THAN COAL. THE ANALYSIS IS BASED ON CURRENT OPERATING PRACTICE, HOWEVER, ADVANCES IN TECHNOLOGY CAN BE EXPECTED TO REDUCE BOTH THE OCCUPATIONAL AND PUBLIC HEALTH RISKS FROM THESE FUELS.

14-5-1-428

INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF REACTOR SAFETY

PALMER, J. F.

ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO

AN IAEA SYMPOSIUM ON PRINCIPLES AND STANDARDS OF REACTOR SAFETY WAS HELD FEB. 5-9, 1973, AT THE NUCLEAR RESEARCH CENTER, JÜLICH, FEDERAL REPUBLIC OF GERMANY. THE MEETING WAS ATTENDED BY APPROXIMATELY 250 PARTICIPANTS FROM 30 COUNTRIES, AND 40 PAPERS WERE PRESENTED. THE PAPERS ARE REVIEWED AND THE PANEL DISCUSSION IS SUMMARIZED TO GIVE SOME INSIGHT INTO INTERNATIONAL VIEWS ON THE PROBLEMS RELATED TO REACTOR SAFETY.

- 14-5-1-439 ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY
COTTRELL, W. B.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
A TOPICAL MEETING ON WATER REACTOR SAFETY SPONSORED BY THE AMERICAN NUCLEAR SOCIETY, THE ATOMIC INDUSTRIAL FORUM, THE OAK RIDGE NATIONAL LABORATORY, AND THE UNIVERSITY OF UTAH WAS HELD AT SALT LAKE CITY, MAR. 26 TO 28, 1973. THE MEETING WAS ATTENDED BY MORE THAN 360 TECHNICAL SPECIALISTS, WHO HEARD A TOTAL OF 44 PAPERS IN THE FOLLOWING TECHNICAL SESSIONS - ACCIDENT ANALYSIS AND PROBABILITY, FLUID FLOW DURING LOCA, MECHANICAL BEHAVIOR OF MATERIALS, HEAT TRANSFER DURING LOCA, STANDARDS AND SURVEILLANCE, COMPUTER CODES AND APPLICATIONS, PROTECTION FROM NATURAL AND MAN-MADE PHENOMENA, AND COMPARATIVE ANALYSES OF LOCA. OVER HALF OF THE PAPERS AND SESSIONS WERE CONCERNED WITH THE LOSS-OF-COOLANT ACCIDENT. A PANEL DISCUSSION ON REACTOR SAFETY RESEARCH - WHAT, WHY, HOW - PRESENTED A PLETHORA OF VIEWS ON THE SUBJECT.
- 14-5-2-446 OZONE FORMATION BY THE RADIOLYSIS OF LIQUID NITROGEN - CALCULATION AND MEASUREMENT
GAUT, J. D. * LOGAN, K. W. * CANNER, M. A.
FEDERAL UNIVERSITY OF SANTA CATARINA, FLORIANOPOLIS, BRAZIL * UNIVERSITY OF MISSOURI, COLUMBIA, MO.
A SIMPLE EXPERIMENTAL METHOD IS PRESENTED WHICH ALLOWS AN ESTIMATE OF THE AMOUNT OF OZONE PRESENT WHEN OXYGEN CONTAMINATED LIQUID NITROGEN IS EXPOSED TO A RADIATION FIELD. ALSO, IF THE RADIATION LEVEL AND THE OXYGEN CONCENTRATION ARE KNOWN, THE AMOUNT OF OZONE FORMED CAN BE CALCULATED. IN OUR CASE, THERE IS GOOD AGREEMENT. THE RESULTS INDICATE THAT THE CONCENTRATION OF THE OXYGEN IMPURITY IS MUCH LESS SIGNIFICANT THAN PREVIOUSLY SUPPOSED. INSTEAD, THE AMOUNT OF LIQUID NITROGEN REMAINING WHEN THE CRYOSTAT IS REFILLED IS THE PRIMARY FACTOR IN DETERMINING THE MAXIMUM AMOUNT OF OZONE THAT WILL BE PRESENT AT ANY TIME.
- 14-5-2-452 U.S. STUDIES ON LMFBR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS
UCKERMAN, C. E.
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
THIS ARTICLE PRESENTS A BRIEF REVIEW OF THE U. S. EFFORT, BETWEEN FALL 1969 AND SPRING 1972, RELATING TO EVALUATION OF THE BEHAVIOR OF THE FUEL AND COOLANT IN LIQUID METAL COOLED FAST BREEDER REACTORS UNDER ACCIDENT CONDITIONS. THE EXPERIMENTAL WORK IS CENTERED LARGELY AROUND THE TRANSIENT REACTOR TEST FACILITY. INVESTIGATIONS OF STEADY-STATE POWER OPERATION SUGGEST THAT SAFETY AND RELIABILITY CAN BE ATTAINED EVEN WITH PARTIAL BLOCKAGES OF COOLANT FLOW. RESULTS OF TRANSIENT TESTS ARE LESS SEVERE THAN PREDICTIONS BASED ON PESSIMISTIC ASSUMPTIONS, AND ADDITIONAL EFFORT IS REQUIRED TO PERMIT ACCURATE MODELING OF DETAILED BEHAVIOR.
- 14-5-3-461 SNEAK-CIRCUIT ANALYSIS
RANKIN, J. P.
THE BOEING COMPANY, HOLSTON, TEXAS
BEGINNING IN LATE 1967, THE BOEING COMPANY IN HOLSTON, TEX., DEVELOPED A COMPUTER AIDED ELECTRICAL SYSTEMS ANALYSIS TECHNIQUE TO HELP ASSURE TROUBLEFREE OPERATION OF NASA'S APOLLO AND SKYLAB HARDWARE. THE TECHNIQUE, CALLED SNEAK-CIRCUIT ANALYSIS, IS BASED ON THE DISCOVERY THAT THERE ARE TOPOLOGICAL CRITERIA THAT ENABLE PRERECOGNITION OF A CIRCUIT TO EXHIBIT UNPLANNED MODES OF OPERATION. THE RESULTS OF SNEAK-CIRCUIT ANALYSIS OVER THE LAST 5 YEARS HAVE SHOWN THAT IT IS NO LONGER NECESSARY TO ACCEPT THE SUPPOSITION THAT A FEW OPERATIONAL SURPRISES ARE INEVITABLE IN COMPLEX ELECTRICAL SYSTEMS. ELECTRICAL SYSTEMS CAN BE MADE FOOLPROOF FROM THE OPERATIONAL POINT OF VIEW. SPECIFICALLY, SNEAK-CIRCUIT ANALYSIS WILL DISCLOSE ALL LATENT CURRENT PATHS, INADVERTENT INHIBITS OR ACTIVATIONS, AMBIGUOUS SYSTEM INDICATIONS, AND MISLEADING CONSOLE LABELS. RELAY RACES, SNEAK GROUNDS, AND POWER SUPPLY CROSSTIES ARE INCLUDED. THIS ARTICLE PRESENTS AN OVERVIEW OF THESE PROBLEMS AND OTHER PRODUCTS OF THE ANALYSIS AS FOUND IN AEROSPACE, COMMERCIAL, AND NUCLEAR SYSTEMS.
- 14-5-4-470 DESIGN AND EVALUATION OF FFTF CONTAINMENT
SIMPSON, D. E.
WESTINGHOUSE HANFORD COMPANY, RICHLAND, WASH.
THE FAST FLUX TEST FACILITY HAS BEEN THE SUBJECT OF AN EXTENSIVE REGULATORY REVIEW SIMILAR TO THAT FOR POWER REACTOR CONSTRUCTION PERMITS. THE REVIEW EXTENDED FROM SEPTEMBER 1970 TO EARLY 1973, BUT INTERIM AGREEMENTS ALLOWED CONSTRUCTION TO PROCEED WITHOUT DELAY. A MAJOR PART OF THE REVIEW WAS DIRECTED TO THE CONTAINMENT DESIGN AND THE DEFINITION OF APPROPRIATE BASES FOR EVALUATING THE CONTAINMENT FOR THE LIQUID METAL COOLED FAST BREEDER REACTOR SYSTEM. STUDIES OF HYPOTHETICAL ACCIDENTS WERE CARRIED OUT FOR OVERPOWER AND LOSS OF COOLING CIRCUMSTANCES, ARBITRARILY NEGLECTING REACTOR SCRAM, INITIAL STUDIES INDICATED AN ACCIDENT ENERGY OF 150 MW-SEC OF THEORETICALLY AVAILABLE POWER TO BE REASONABLY CONSERVATIVE. MORE RECENT STUDIES, INCORPORATING PRELIMINARY RESULTS OF RESEARCH AND DEVELOPMENT BASED ON THE EARLIER STUDIES, INDICATE THAT A MUCH LOWER ENERGY IS MORE REALISTIC. ANALYSES AND SCALE MODEL TESTS SHOW THAT THE DESIGN CAN CONTAIN THE ENERGY AT 150 MW-SEC AND MAINTAIN MECHANICAL INTEGRITY, NOT ONLY OF THE CONTAINMENT STRUCTURE BUT ALSO OF THE REACTOR VESSEL AND THE HEAT TRANSPORT SYSTEM.

- 14-5-5-482 MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL REPROCESSING OPERATIONS
LEWISMAN, W. L.
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.
SINCE 1964 THE U. S. ATOMIC ENERGY COMMISSION (AND ITS PREDECESSOR, THE MANHATTAN DISTRICT) HAS BEEN OVERSEEING THE MANAGEMENT OF RADIOACTIVE WASTES FROM ITS FUEL REPROCESSING PLANTS WHICH ARE CONTRACTOR OPERATED. EXPERIENCE DURING THE YEARS HAS INDICATED THAT MANAGEMENT OF THESE RADIOACTIVE WASTES REQUIRES UNRELENTING EVALUATION AND APPRAISAL BY HIGHER MANAGEMENT AND MANAGEMENT GROUPS. EXPERIENCE WITH LEAKING WASTE TANKS AT MANFORD, SAVANNAH RIVER, AND THE NATIONAL REACTOR TESTING STATION TO 1972 IS SUMMARIZED. IMPORTANT RELATED ACTIVITIES ARE PERIODIC REVIEWS, FREQUENT ANALYSES, AND CONTINUOUS PLANNING. GUIDANCE IS PROVIDED FOR DESIGNERS OF FUEL REPROCESSING WASTE MANAGEMENT SYSTEMS INCLUDING SUCH FEATURES AS ACID WASTE STORAGE, DOUBLE CONTAINMENT, PROTECTION AGAINST CREDIBLE FORCES OF NATURE, FACILITIES FOR EMPTYING WASTE STORAGE TANKS, SPACE AND ACCESS FOR INSPECTION, ADEQUATE RADIATION MONITORING DEVICES CONNECTED TO A CENTRAL RECORDING STATION, AND SEGREGATION AND DIVERSION CAPABILITY FOR DISCHARGED EFFLUENT AQUEOUS STREAMS.
- 14-5-6-507 MATERIALS PERFORMANCE AT NUCLEAR POWER PLANTS
SCOTT, R. L., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
SAFETY RELATED OCCURRENCES - FAILURES, INCIDENTS, AND DEFICIENCIES - REPORTED BY LIGHT WATER REACTOR NUCLEAR POWER PLANTS ARE REVIEWED FOR THE PERIOD 1967-1972. THE OCCURRENCES ARE LIMITED, HOWEVER, TO THOSE IN WHICH A MATERIAL FAILURE WAS INVOLVED. TABLES ARE GIVEN FOR EACH YEAR, INDICATING THE FACILITY AND COMPONENTS INVOLVED, THE CAUSE OF FAILURE, AND THE AREA IN WHICH THE DEFICIENCY ORIGINATED (I.E., MATERIAL SELECTION, DESIGN, FABRICATION, INSTALLATION, OPERATION, OR MAINTENANCE). EACH INCIDENT IS DISCUSSED, AND AREAS IN WHICH MATERIALS PERFORMANCE CAN BE IMPROVED ARE INDICATED.
- 14-6-1-563 NUCLEAR EMERGENCY PLANNING IN THE STATE OF NEW JERSEY
ARATO, C. G.
STATE OF NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION, TRENTON, N. J.
TO MEET THE NECESSITY FOR A PUBLIC EMERGENCY PLAN FOR LARGE SCALE RADIATION INCIDENTS, THE STATE GOVERNMENT OF NEW JERSEY HAS DEVELOPED PIPAG, PROCEDURES FOR IMPLEMENTING PROTECTIVE ACTION GUIDES. PIPAG IS A CONTINGENCY PLAN BASED ON COOPERATIVE, PRUDENT PREPARING AIMED TOWARD MAINTAINING PUBLIC CONFIDENCE AND CONTROLLING DOSE AND DOSE COMMITMENTS. THE PLAN IS BASED ON THE LAW, GEOGRAPHY, RESOURCES, AND POLICIES OF NEW JERSEY. IT MAXIMIZES THE USE OF EXISTING RESOURCES AND RELIES ON THE CONCEPT OF CIVIL DEFENSE ORGANIZATIONS AS LOCAL GOVERNMENTS IN AN EMERGENCY. BOTH THE TECHNOLOGY AND SOCIOLOGY ASPECTS OF A REACTOR ACCIDENT ARE CONSIDERED SINCE PIPAG, IF EVER IMPLEMENTED, WILL DEAL WITH COMMUNITIES OF PEOPLE. THE SOCIAL CONCEPTS OF DISASTER AND REACTOR ACCIDENTS ARE INTRODUCED, AND THE FACTORS AFFECTING DISASTERS, AS WELL AS PROTECTIVE ACTION LEVELS, ARE DISCUSSED.
- 14-6-1-574 STATE RESPONSIBILITIES FOR NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION
NUCLEAR SAFETY EDITORIAL STAFF AT OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
FOLLOWING THE BELATED PUBLIC AND STATE AWARENESS OF TWO INCIDENTS THAT OCCURRED AT THE CRESGEN NUCLEAR POWER STATION IN 1970 AND 1971, THE STATE OF ILLINOIS UNDERTOOK A SEPARATE INVESTIGATION TO ASSURE THAT THE PUBLIC HEALTH AND SAFETY OF THE PEOPLE OF ILLINOIS ARE ADEQUATELY SAFEGUARDED. THIS INVESTIGATION WAS CONDUCTED IN PART BY DR. RALPH LAPP, A PRIVATE NUCLEAR CONSULTANT. HIS REPORT, SUBMITTED TO THE ILLINOIS COMMERCE COMMISSION ON DEC. 7, 1972, EXAMINES THE INCIDENTS AND SUBSEQUENT REVIEWS IN DETAIL AND MAKES CONCLUSIONS AND RECOMMENDATIONS RELEVANT TO A STATES RESPONSIBILITY TO ITS PUBLIC. TO THE EXTENT THAT THIS INFORMATION WOULD BE PERTINENT TO THE INTERACTION WHICH MAY BE EXPECTED BETWEEN ANY UTILITY AND ITS STATE GOVERNMENT, THE RELEVANT CONCLUSIONS ARE PRESENTED AS TAKEN FROM THE LAPP REPORT.
- 14-6-1-576 SITING PRACTICE AND ITS RELATION TO POPULATION
PIPER, W. B. & MEDOFFSON, F. A.
PROJECT MANAGEMENT CORPORATION, CHICAGO, ILL. AND OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
A STUDY WAS MADE TO DETERMINE THE RELATION BETWEEN POWER REACTOR SITES AND THE SURROUNDING POPULATION IN THE UNITED STATES AND IN SOME FOREIGN COUNTRIES. RESULTS SHOW THAT THE POPULATION VS. DISTANCE ENVELOPE REPRESENTED BY A COMBINATION OF THE INDIAN POINT AND ZION SITES HAS SERVED AS AN UPPER BOUNDARY IN CURRENT SITING PRACTICE. IT IS ALSO SHOWN THAT THE APPLICATION OF ENGINEERED SAFETY FEATURES HAS HAD NO DISCERNIBLE EFFECT ON THE SELECTION OF SITES.

- 14-6-2-596 POWER PLANT SAFETY AND EARTHQUAKES
SMITH, C. B.
APPLIED NUCLEONICS COMPANY, LOS ANGELES, CALIF.
THIS ARTICLE STRESSES THE IMPORTANCE OF CONSIDERING SEISMIC EFFECTS IN THE DESIGN OF POWER PLANTS FOR ELECTRICITY GENERATION, WITH EMPHASIS ON NUCLEAR POWER PLANTS. THE POTENTIAL EFFECTS ON PLANT PERFORMANCE ARE DESCRIBED, METHODS FOR SEISMIC ANALYSIS ARE REVIEWED, AND THE NEED FOR SEISMIC INSTRUMENTATION AND TESTING ARE DISCUSSED.
- 14-6-2-597 PROBABILITY AND CONSEQUENCES OF TRANSPORTATION ACCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL CYCLE
SHAPPERT, L. B. + BROST, W. A. + LANGHAM, J. W.
SISLER, J. A.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN. + U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C. + E. I. DU PONT DE NEMOURS AND COMPANY, WILMINGTON, DEL. + U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
FOR 1980 THE PROJECTED ELECTRICAL GENERATING CAPACITY OF NUCLEAR POWER PLANTS IN THE UNITED STATES IS ABOUT 130 MW(E), THIS, IN TURN, WILL GENERATE THOUSANDS OF SHIPMENTS OF RADIOACTIVE MATERIALS ANNUALLY. THE PROBABILITY OF ACCIDENTS INVOLVING THESE SHIPMENTS WITHIN THE PUBLIC DOMAIN HAS BEEN ESTIMATED AND BROKEN DOWN INTO FIVE SEVERITY CATEGORIES. IT IS ESTIMATED THAT IN 1980 THE SHIPMENTS CONSIDERED WOULD BE INVOLVED IN LESS THAN 20 ACCIDENTS, MOST OF WHICH WOULD RESULT IN ONLY MODERATE DAMAGE TO THE SHIPPING SYSTEM AND NO SIGNIFICANT NUCLEAR RELATED HAZARD. AN ESTIMATE WAS MADE OF THE EFFECT OF AN EXTREMELY SEVERE ACCIDENT INVOLVING LOSS OF CONTAMINATED COOLANT FROM A SPENT FUEL SHIPPING CASK AND THE POSSIBLE EXPOSURE TO THE PUBLIC, AS A RESULT OF THE ESTIMATES, IT IS CONCLUDED THAT THE LIKELIHOOD OF ANY SERIOUS RADIOLOGICAL INJURY IS VERY SMALL AND THE TRANSPORTATION OF NUCLEAR MATERIALS IN THE FUEL CYCLE HAS A HIGH DEGREE OF SAFETY.
- 14-6-2-605 COMPARATIVE RELIABILITY ANALYSES OF REACTOR SAFETY SYSTEMS
MURRAY, R. S. + SCHULTZ, M. A.
PENNSYLVANIA STATE UNIVERSITY, UNIVERSITY PARK, PENN.
FIVE REACTOR PROTECTION SYSTEMS HAVE BEEN ANALYZED USING A MONTE CARLO SIMULATION TECHNIQUE TO SOLVE FOR SYSTEM RELIABILITY AS A FUNCTION OF TEST AND REPAIR INTERVAL. THE SYSTEMS WERE EVALUATED FOR BOTH SAFETY RELIABILITY AND PROTECTION AGAINST FALSE SCRAMS. THE ANALYSIS TECHNIQUE IS DESCRIBED IN DETAIL, WITH EMPHASIS ON THE ASSUMPTIONS MADE AND THE VALIDITY OF THE RESULTS. A METHOD OF SCALING THE INPUT FOR THE MONTE CARLO PROGRAM BY VARYING THE REPAIR INTERVAL IS DEVELOPED. THE SYSTEMS ANALYZED INCLUDE FOUR COMMERCIAL REACTOR PROTECTION SYSTEMS, EACH DESIGNED BY A DIFFERENT MANUFACTURER, AND A PROPOSED SYSTEM, SUGGESTED AT PENNSYLVANIA STATE UNIVERSITY. THE RELIABILITIES OF THE SYSTEMS ARE COMPARED BY EXAMINING SYSTEM FAILURE PROBABILITIES. CONSIDERABLE DIFFERENCES IN PERFORMANCE WERE FOUND IN THE VARIOUS SYSTEMS, SUGGESTING THAT STILL BETTER CONFIGURATIONS MAY YET BE OBTAINED.
- 14-6-4-618 SAFETY DESIGN BASES OF THE HTGR
WESSMAN, G. L. + MCFFETTE, T. R.
GULF GENERAL ATOMIC COMPANY, SAN DIEGO, CALIF.
THE HIGH TEMPERATURE GAS-COOLED REACTOR (HTGR) HAS INHERENT AND DESIGN SAFETY FEATURES THAT ARE SIGNIFICANT AND UNIQUE, REQUIRING A NUMBER OF SAFETY CRITERIA AND APPROACHES THAT DIFFER MARKEDLY FROM OTHER REACTOR TYPES. FIRST, THIS ARTICLE BRIEFLY REVIEWS THE DESIGN OF HTGR PLANTS THAT HAVE BEEN BUILT AND ARE BEING OFFERED IN THE UNITED STATES. IT THEN REVIEWS THE SAFETY CONSIDERATIONS IN THE DESIGN OF THE PLANTS NOW BEING OFFERED. THE UNIQUE FEATURES, THEIR DEVELOPMENT, AND THEIR EFFECTS ON SAFETY CRITERIA ARE DESCRIBED, WITH PARTICULAR EMPHASIS ON THE DESIGN BASES OF THE PRESTRESSED CONCRETE REACTOR VESSEL.
- 14-6-4-634 SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPACES
ESTREICH, P. J.
EHSACI SERVICES INCORPORATED, NEW YORK, N. Y.
A MATHEMATICAL BASIS IS DEVELOPED TO PROVIDE THE PRACTICING ENGINEER WITH A METHOD FOR SIZING AIR CLEANING SYSTEMS FOR NUCLEAR FACILITIES. IN PARTICULAR, GENERAL FORMULAS ARE PROVIDED TO RELATE CLEANING AND CONTAMINATION DYNAMICS OF AN ENCLOSURE SUCH THAT SAFE CONDITIONS ARE OBTAINED WHEN WORKING CREWS ENTER. INCLUDED IN THESE CONSIDERATIONS IS THE SIZING OF AN AIR CLEANING SYSTEM TO PROVIDE RAPID DECONTAMINATION OF AIRBORNE RADIOACTIVITY. MULTIPLE NUCLIDE CONTAMINATION SOURCES, LEAK RATE, DIRECT RADIATION, CONTAMINANT MIXING EFFICIENCY, FILTER EFFICIENCIES, AIR CLEANING SYSTEM OPERATIONAL MODES, AND CRITERIA FOR MAXIMUM PERMISSIBLE CONCENTRATIONS ARE INTEGRATED INTO THE PROCEDURE.
- 14-6-5-643 PROBLEMS AND TECHNIQUES FOR REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM MINE ATMOSPHERES
GOODWIN, A.
U.S. DEPARTMENT OF THE INTERIOR, WASHINGTON, D.C.
VENTILATION WITH FRESH AIR HAS BEEN, AND WILL CONTINUE TO BE, THE PRIMARY SOLUTION FOR CONTROLLING RADON AND RADON DAUGHTER ACTIVITY IN MINES. HOWEVER, PROCEDURES TO MAKE THE VENTILATION

PROCESS MORE EFFECTIVE AND TO REDUCE CONTAMINATION HAVE BEEN PROPOSED. SUCH AS SEALING OFF OF OLD WORKINGS, THE USE OF COATINGS TO REDUCE RADON INFLOW, AND MINE PRESSURIZATION. AIR CLEANING TECHNIQUES HAVE PROVED SUCCESSFUL IN CERTAIN APPLICATIONS. FOR EXAMPLE, RADON DAUGHTERS CAN BE REMOVED BY MECHANICAL FILTERING AND BY ELECTROSTATIC PRECIPITATION METHODS, BOTH OF WHICH REMOVE CONDENSATION NUCLEI TO WHICH RADON DAUGHTERS BECOME ATTACHED. THE RADON GAS THAT PASSES THROUGH CONTINUES TO DECAY. BUT, IN THE ABSENCE OF CONDENSATION NUCLEI, THE DAUGHTERS HAVE LARGE DIFFUSION LENGTHS AND ARE TRAPPED ON THE WALLS OF AIR CIRCLES, THUS INHIBITING THEIR GROWTH. RADON GAS HAS BEEN SUCCESSFULLY REMOVED FROM AIR, ALTHOUGH THERE ARE NO KNOWN REPORTS OF THIS HAVING BEEN DONE IN OPERATING MINES. IT HAS BEEN CAPTURED ON ACTIVATED CHARCOAL AND SILICA GEL AND CHEMICALLY REMOVED BY REACTING WITH A HALOGEN FLUORIDE AND A METAL FLUORIDE.

- 14-6-5-651 THE ORIGIN AND FINDINGS OF THE ATOMIC BOMB CASUALTY COMMISSION JABLON, S.
NATIONAL ACADEMY OF SCIENCES, WASHINGTON, D.C.
THE ATOMIC BOMB CASUALTY COMMISSION (ABCC) WAS AUTHORIZED IN NOVEMBER 1947, WHEN IT BECAME APPARENT TO THE EARLIER INVESTIGATION TEAM THAT LONG TERM STUDIES OF THE SURVIVORS WERE REQUIRED. THE ABCC WAS ESTABLISHED UNDER THE NATIONAL RESEARCH COUNCIL OF THE NATIONAL ACADEMY OF SCIENCES AND HAS SINCE, IN COOPERATION WITH THE JAPANESE INSTITUTE OF HEALTH, MAINTAINED A MEDICAL SURVEILLANCE OF MORE THAN 100,000 INDIVIDUALS. THE EXAMINATIONS REVEALED NO SIGNIFICANT CHANGE IN GENETIC EFFECTS, ALTHOUGH EFFECTS ON GROWTH, MENTAL RETARDATION, AND LENTICULAR OPACITIES WERE OBSERVED. THE MAJOR EFFORT OF THE STUDY HAS BEEN CONCERNED WITH MORTALITY STUDIES, WHEREIN THE RADIATION EFFECTS ARE MANIFESTED CHIEFLY THROUGH CHANGES IN THE OCCURRENCE OF CANCER. THE INCIDENCE OF LEUKEMIA AS A FUNCTION OF DOSE, AGE, AND TIME HAS BEEN OBTAINED. FOR SURVIVORS WHO HAD THE LARGEST DOSE, OVER 200 RADS, CANCER DEATHS HAVE BEEN ABOUT 60 PERCENT HIGHER THAN EXPECTATION. NO NOTICEABLE DIFFERENCE IN DEATH RATES WAS OBSERVED FOR ANY CAUSE EXCEPT CANCER. THE STUDIES ARE CONTINUING, AS THEY SHOULD, AT LEAST THROUGHOUT THE LIFETIME OF THE EXPOSED SURVIVORS.
- 14-6-6-660 SWITCH FAILURES AT NUCLEAR FACILITIES CALBERT, W. H.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
SWITCH FAILURES IN NUCLEAR POWER PLANTS ARE REVIEWED FOR THE PERIOD 1964 TO MARCH 1973. THE TYPES OF FAILURES, SYSTEMS AFFECTED, AND THE NUMBER OF FAILURES ARE TABULATED, AND TECHNIQUES FOR MINIMIZING FAILURES ARE DISCUSSED.
- 15-1-1-001 REGULATION OF NUCLEAR POWER REACTORS AND RELATED FACILITIES NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE U.S. ATOMIC ENERGY COMMISSION (AEC) HAS THE RESPONSIBILITY TO PROTECT THE HEALTH AND SAFETY OF THE PUBLIC BY ASSURING THAT AN OWNER/OPERATOR DESIGNS, BUILDS, AND OPERATES, AND MAINTAINS THE INTEGRITY OF, A NUCLEAR FACILITY OVER ITS LIFETIME IN ACCORDANCE WITH THE CRITERIA, CODES, STANDARDS, AND REGULATORY JUDGMENTS DIRECTED TOWARD THAT END. THIS ARTICLE DISCUSSES THE PHILOSOPHY AND MEANS FOR PROTECTING THE PUBLIC HEALTH, THE RELEVANT AEC RULES AND REGULATIONS, AS WELL AS THE DETAILS OF THE LICENSING PROCESS AND THE AEC INSPECTION PROGRAM, ARE SUMMARIZED.
- 15-1-3-015 IAEA INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT CONTROL AND INSTRUMENTATION MAGEN, E. J. & KERLIN, T. H.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
IN RECOGNITION OF THE SIGNIFICANT ADVANCES BEING MADE IN THE FIELD OF NUCLEAR POWER PLANT CONTROL AND INSTRUMENTATION, THE INTERNATIONAL ATOMIC ENERGY AGENCY ORGANIZED A SERIES OF BIENNIAL SYMPOSIUMS ON THE SUBJECT. THESE MEETINGS PROVIDED SPECIALISTS FROM THE MEMBER STATES WITH AN OPPORTUNITY FOR A COMPREHENSIVE EXCHANGE OF INFORMATION ON THE CURRENT INTERNATIONAL STATUS OF THIS IMPORTANT FIELD. IN THIS ARTICLE THE DISCOURSE FROM THE FIRST MEETING (VIENNA, 1969) IS SUMMARIZED. THE PROCEEDINGS FROM THE SECOND MEETING (VIENNA, 1971) ARE REVIEWED, AND SOME OF THE PRESENTATIONS MADE AT THE THIRD MEETING (PRAGUE, 1973) ARE DISCUSSED.
- 15-1-4-030 THE ECCS RULE-MAKING HEARING COTTRELL, W. H.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE GENESIS, EXPOSITION, AND SOME OF THE RAMIFICATIONS OF THE ECCS RULE-MAKING HEARING, DOCKET RM-50-1, ARE REVIEWED. WHEN THE AEC PROMULGATED THE INTERIM ACCEPTANCE CRITERIA (IAC) IN JUNE OF 1971, A SERIES OF EVENTS WAS INITIATED WHICH IS STILL BEING FELT BY THE NUCLEAR COMMUNITY. THIS ARTICLE EXAMINES BRIEFLY WHAT THE EMERGENCY CORE COOLING SYSTEM (ECCS) IS AND HOW IT PERFORMS IN BOTH PWRs AND BWRs, AS WELL AS THE RESULTS OF THE VARIOUS STUDIES AND RESEARCH AND DEVELOPMENT (R&D) PROGRAMS THAT WERE EXTANT AT THAT TIME. THE RESULTING CONTROVERSIES FOLLOWING PUBLICATION OF THE IAC PRECIPITATED THE HEARING, WHICH BEGAN JAN. 27, 1972, AND ENDED JULY 25, 1973. THE COURSE OF THE HEARING AND THE AEC CONCLUDING STATEMENT - IN

EFFECT. PROPOSED REVISED CRITERIA - ARE SUMMARIZED. ALTHOUGH THE PROPOSED CRITERIA HAV NOT YET BEEN ADOPTED, THE RAMIFICATIONS OF THE HEARING INCLUDE A REVIEW AND REDIRECTION OF R&D PROGRAMS, CONTEMPLATED CERRATING OF SOME EXISTING PLANTS, AND NEW REACTOR DESIGNS BY THE VFNCOMS. THE AUTHCR CONCLUDES THAT THE HEARING WAS A NECESSARY AND CONSTRUCTIVE, IF TRAUMATIC, EXPERIENCE.

- 15-1-5-056 POPULATION DOSES FROM THE NUCLEAR INDUSTRY TO 2000 A.C.
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
DURING THE NEXT FEW DECADES, IT IS ANTICIPATED THAT THE NUCLEAR POWER INDUSTRY IN THE UNITED STATES WILL UNDERGO A REMARKABLE GROWTH. TO PROJECT THE EFFECT OF THIS GROWTH ON THE RADIATION DOSES OF THE GENERAL PUBLIC, THE U.S. ATOMIC ENERGY COMMISSION MADE A REVIEW OF CURRENT REACTOR OPERATING EXPERIENCES. FROM THIS REVIEW A DETAILED ANALYSIS OF THE RADIATION DOSE TO A MAJOR SECTION OF THE COUNTRY DUE TO EFFLUENTS FROM NUCLEAR FACILITIES FOR CONDITIONS PROJECTED FOR THE YEAR 2000 WAS UNDERTAKEN. THE STUDY INDICATES THAT THE AVERAGE DOSE TO THE U.S. POPULATION FROM NUCLEAR POWER WILL INCREASE FROM AN ESTIMATED 3,003 MREM PER PERSON IN 1970 TO AS MUCH AS 0.2 MREM IN THE YEAR 2000. THIS CONTRIBUTION REMAINS A SMALL FRACTION OF THE RADIATION DOSE FROM EITHER NATURAL OR MAN-MADE SOURCES OF IONIZING RADIATION.
- 15-1-6-067 SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1972
SCOTT, R. L.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
SUMMARIZED AND EVALUATED ARE 244 REPORTS OF INCIDENTS, FAILURES, AND DESIGN OR CONSTRUCTION DEFICIENCIES AT LIGHT WATER REACTOR CENTRAL POWER STATIONS DURING 1972. THE MATERIAL IS PRESENTED IN TABLES THAT INCLUDE THE FREQUENCY OF ITEMS REPORTED WITH REGARD TO COMPONENTS, SYSTEMS, CAUSES, SPECIFIC DEFICIENCIES, AND TIME OF OCCURRENCE. SELECTED FOR DISCUSSION ARE INCIDENTS THAT OCCURRED DURING CONSTRUCTION AND OCCURRENCES AT BOILING WATER AND PRESSURIZED WATER REACTORS.
- 15-1-6-076 EVALUATION OF INCIDENTS OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE REPORT EVOLVING FROM A REVIEW OF EIGHT INCIDENTS OF PRIMARY COOLANT RELEASES FROM EIGHT OPERATING BOILING WATER REACTORS BY A SEVEN MEMBER GROUP FROM THE AEC DIRECTORATE OF LICENSING AND DIRECTORATE OF REGULATORY OPERATIONS IS DESCRIBED. INCLUDED ARE SOURCES FOR OBTAINING THE REPORT AND THE COMPLETE SECTION ON CONCLUSIONS AND RECOMMENDATIONS.
- 15-2-1-127 AECS NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, AND SCHEDULES
KOUTS, M. J. C.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
THE RESEARCH OBJECTIVES AND PROGRAM PLANS OF THE AECS RECENTLY ESTABLISHED DIVISION OF REACTOR SAFETY RESEARCH ARE DISCUSSED. THE PRIMARY OBJECTIVE OF THE DIVISION IS TO PROVIDE INFORMATION NEEDED BY THE ACRS AND THE REGULATORY STAFF SO AS TO AVOID UNNECESSARILY STRICT LIMITATIONS ON THE OPERATION OF NUCLEAR POWER PLANTS. THE MEANS FOR SATISFYING PUBLIC CONCERN RELATED TO THE SAFETY OF NUCLEAR PLANTS AND THE CONSERVATISM IMPOSED BY LACK OF KNOWLEDGE, AS BEING DEVELOPED BY THE SAFETY PROGRAM, ARE DISCUSSED. THE SAFETY PROJECTS CURRENTLY SPONSORED ARE ALL RELATED TO WATER REACTOR SAFETY. ALTHOUGH SAFETY STUDIES RELATING TO THE HTGR AND THE LMFBR ARE PLANNED, IN ADDITION TO THE LOFT AND THE PBF - TWO LARGE PROGRAMS WHICH HAVE BEEN UNDER WAY FOR SOME TIME - A NUMBER OF SMALLER, MORE BASIC PROJECTS ARE ALSO UNDER WAY IN THE AREAS OF BLOWDOWN HEAT TRANSFER, TWO-PHASE PUMP CHARACTERISTICS, STEAM WATER MIXING, AND PRIMARY SYSTEM INTEGRITY. SEVERAL ADDITIONAL WATER REACTOR SAFETY PROJECTS, SOME BEING INITIATED AND OTHERS BEING PLANNED, ARE IDENTIFIED AND DISCUSSED.
- 15-2-1-132 AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON REACTOR SAFETY
COTTRELL, M. B.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
IN PHASE IIA OF THE JOINT COMMITTEE ON ATOMIC ENERGYS HEARINGS ON REACTOR SAFETY, HELD SEPT. 25-27 AND OCT. 1, 1973, THE 5 AEC COMMISSIONERS AND 12 OF THEIR STAFF PRESENTED TESTIMONY. THIS TESTIMONY, WHICH IS REVIEWED HERE AS REPORTED IN THE HEARING RECORD, WAS CONCERNED WITH ALL ASPECTS OF COMMISSION ACTIVITIES RELATED TO THE NUCLEAR POWER-REACTOR PROGRAM, INCLUDING (1) REACTOR SAFETY RESEARCH AND DEVELOPMENT, (2) WASTE-MANAGEMENT INVESTIGATIONS, (3) THE PROTECTION OF MATERIALS AND FACILITIES, AND (4) THE AECS REGULATORY ACTIVITIES AS WELL AS THOSE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS AND THE ATOMIC SAFETY AND LICENSING BOARD PANEL. THE PRESENTATIONS AS A WHOLE REFLECT TREMENDOUS ACTIVITY ON THE PART OF THE AEC TO PROVIDE FOR THE SAFE UTILIZATION OF THIS ENERGY RESOURCE. THE PRESENTATION DISCUSSED IN DETAIL MANY ACTUAL AND POTENTIAL PROBLEMS, INCLUDING NEEDED SAFETY RESEARCH, THE ACCIDENT RISK STUDY, WASTE MANAGEMENT EXPERIENCE, SABOTAGE, DIVERSION, REACTOR LICENSING, INSPECTION, OPERATING EXPERIENCE, AND STANDARDS DEVELOPMENT.

- 15-2-2-144 IAEA-INGFR MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHMENT
WILLIARD, R. E.
MANFORD ENGINEERING DEVELOPMENT LABORATORY, RICHMOND, WASH.
SPECIALISTS FROM SIX NATIONS PARTICIPATED IN A WORKING-GROUP MEETING ON THE TECHNIQUES AND TECHNOLOGY OF SODIUM COMBUSTION AND ITS EXTINGUISHMENT. THE MEETING WAS HELD IN RICHMOND, WASH., ON MAY 22-25, 1972. THE PRINCIPAL TOPICS CONSIDERED WERE DETECTION OF SODIUM LEAKS AND FIRES, EXTINGUISHMENT OF SODIUM FIRES, AND CONTROL OF COMBUSTION PRODUCTS. ALTHOUGH MUCH INFORMATION ON THESE TOPICS IS NOW AVAILABLE, THE LMFBR INDUSTRY WILL REQUIRE ADDITIONAL DEVELOPMENT IN ALL AREAS.
- 15-2-3-151 ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER REACTORS
AEC REGULATORY STAFF
AEC
THE ANTICIPATED TRANSIENTS WITHOUT SCRAM (ATWS) REPORT FOR WATER COOLED NUCLEAR POWER PLANTS PROVIDES A GENERAL EXPLANATION OF THE POSSIBILITY OF OCCURRENCE OF AN ATWS EVENT AND OF THE NATURE OF THE RESULTANT CONSEQUENCES. THE RELIABILITY REQUIRED OF THE PROTECTION OR SHUTDOWN SYSTEM TO REDUCE THE ATWS TO AN ACCEPTABLE RISK IS DETERMINED, AND DESIGN ASPECTS AND FAILURE ANALYSES OF THE PROTECTION SYSTEM ARE DISCUSSED. THE REGULATORY STAFFS CONCLUSIONS ARE GIVEN, AND, WITH THE OBJECTIVE OF IMPROVING REACTOR PLANT SAFETY AND PROTECTION SYSTEM RELIABILITY, AN IMPLEMENTATION PROGRAM INCLUDING BACKFITTING IS PRESENTED.
- 15-2-3-154 SAFETY ASSESSMENT OF REACTOR SYSTEMS
GREEN, A. E.
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY, LANCASHIRE, ENGLAND
THE PRACTICE IN THE UNITED KINGDOM ATOMIC ENERGY AUTHORITY IS TO CARRY OUT INDEPENDENT RELIABILITY AND SAFETY ASSESSMENTS OF THOSE REACTOR SYSTEMS ON WHICH SAFETY IS DEPENDENT. THE INDEPENDENT ASSESSMENT IS COMPLEMENTARY TO THE DESIGN PROCESS, AND, WHEN THE RESULTS ARE IN AGREEMENT, GREATER CONFIDENCE IS PLACED IN PROCEEDING WITH THE DEVELOPMENT OF THE SYSTEM OR PROJECT. PRESENTED ARE VIEWPOINTS IN THE UNITED KINGDOM ON HOW SAFETY OF SYSTEMS SHOULD BE PREDICTED, EMPLOYING COMPONENT FAILURE PROBABILITIES INTERPRETED IN THE LIGHT OF "REAL-WORLD" CONSIDERATIONS. THE TYPE OF SAFETY ASSESSMENT DESCRIBED HAS BEEN SUCCESSFUL IN A NUMBER OF APPLICATIONS, AND THESE BENEFITS ARE REVIEWED.
- 15-2-4-163 EVOLUTION AND CURRENT STATUS OF THE BWR CONTAINMENT SYSTEM
MADE, G. E.
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.
THE CONTAINMENT SYSTEM FOR BOILING-WATER REACTORS HAS EVOLVED FROM THE DRY SPHERICAL TYPE USED ON DRESDEN I THROUGH FOUR GENERATIONS OF PRESSURE SUPPRESSION TYPES. THE MARK I, II, AND III PRESSURE SUPPRESSION CONTAINMENT SIZES AND ARRANGEMENTS ARE PRESENTED, AND THE REASONS FOR THE DESIGN EVOLUTION ARE DISCUSSED. THE FIVE BASIC MODES IN THE PRESSURE SUPPRESSION ANALYTICAL MODEL AND A TYPICAL RESPONSE TO A LOSS OF COOLANT ACCIDENT ARE DESCRIBED. THE TEST PROGRAM BEING CONDUCTED TO VERIFY THE NEW PRESSURE SUPPRESSION HORIZONTAL VENT DESIGN IS BRIEFLY DESCRIBED. OVERALL DESIGN CHARACTERISTICS OF THE EMERGENCY CORE COOLING SYSTEM NETWORK, WHICH IS ESSENTIAL IN MAINTAINING THE INTEGRITY OF THE CONTAINMENT, ARE OUTLINED. THE NEW MARK III CONTAINMENT DESIGN ELIMINATES THE NEED FOR INERTING. THE DESIGN OBJECTIVES ARE OUTLINED FOR THE SYSTEM THAT HANDLES THE HYDROGEN GENERATED BY THE INITIAL METAL WATER REACTION OF THE ZIRCONIUM.
- 15-2-4-173 NEW ACCEPTANCE CRITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
IN A 140-PAGE REPORT ISSUED DEC. 28, 1973, THE ATOMIC ENERGY COMMISSION ESTABLISHED REVISED ECCS DESIGN CRITERIA, GAVE THE SCHEDULE FOR THEIR IMPLEMENTATION, AND PRESENTED A DETAILED TECHNICAL JUSTIFICATION FOR THE REVISIONS. BECAUSE OF THE INTEREST IN THIS MATTER, WE ARE PRESENTING HERE THE NEW CRITERIA AND THE INTRODUCTION TO THE AFOREMENTIONED REPORT WHICH SUMMARIZES THE COMMISSION'S POSITION. THESE SECTIONS ARE PRESENTED BELOW AS THEY APPEAR IN THE COMMISSION DOCUMENT EXCEPT THAT REFERENCED MATERIAL HAS BEEN EXPANDED AND PLACED AT THE END OF THE ARTICLE AND FOOTNOTES HAVE BEEN INCORPORATED INTO THE TEXT. THE LENGTH OF THE REPORT PRECLUDED PUBLICATION HERE OF THE DETAILED TECHNICAL RATIONALE, BUT THAT MAY BE FOUND IN THE DECEMBER 1973 ISSUE OF REGULATORY ADJUDICATION ISSUANCES (RAI-73-12), PAGES 1085-1138. THE ECCS RULE-MAKING MEETING, DOCKET RM-90-1, WHICH LED TO THIS COMMISSION REPORT, WAS SUMMARIZED IN NUCLEAR SAFETY, VOL. 15, NO. 1, PAGES 30-55.
- 15-2-5-185 RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF RADIOLOGICAL HEALTH
DEVORE, R. T.
U.S. DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE, WASHINGTON, D.C.
THE BUREAU OF RADIOLOGICAL HEALTH OF THE DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE HAS NUMEROUS RESPONSIBILITIES REGARDING THE LIMITATION OF HUMAN EXPOSURE TO IONIZING AND NONIONIZING RADIATIONS. THIS ARTICLE SUMMARIZES MANY OF THE BUREAU'S

ACTIVITIES IN 1972 IN DISCHARGING THESE RESPONSIBILITIES. INCLUDED HEREIN ARE BRIEF REPORTS ON THE BUREAU WORK IN THE FOLLOWING AREAS. (1) STUDIES OF DIAGNOSTIC X-RAY EXPOSURES, (2) DEVELOPMENT OF X-RAY-MACHINE SAFETY STANDARDS, (3) X-RAY-USER TRAINING AND EDUCATION, (4) DEVELOPMENT OF LASER AND INDUSTRIAL X-RAY STANDARDS, (5) DEVELOPMENT OF MICROWAVE-OVEN STANDARDS, (6) ENFORCEMENT ACTIVITIES, (7) IMPROVED PROTECTION IN THE HANDLING OF RADIOACTIVE MATERIALS, AND (8) RESEARCH ON BIOLOGICAL EFFECTS.

- 15-2-5-196 FOG AND DRIFT DEPOSITION FROM EVAPORATIVE COOLING TOWERS
MARRA, S. R.
AEP RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK
RIDGE, TENN.
METHODS OF DETERMINING FOG AND DRIFT DEPOSITION DUE TO EMISSIONS FROM EVAPORATIVE COOLING TOWERS ARE REVIEWED AND FORMULAS SUGGESTED THAT CAN BE USED AS A BASIS FOR CALCULATIONS. THE GAUSSIAN PLUME FORMULA IS RECOMMENDED FOR CALCULATING FOG CONCENTRATIONS FROM WHICH VISIBILITY CAN BE ESTIMATED. FOR DRIFT, DROPLETS WITH DIAMETERS GREATER THAN 200 MICROMETERS, DEPOSITION IS CALCULATED BY BALLISTICS METHODS. KNOWING THE ENVIRONMENTAL WIND SPEED AND RELATIVE HUMIDITY AND THE VERTICAL VELOCITY OF THE PLUME AND THE DROPLET, EVAPORATION OF THE DROPLETS IS ACCOUNTED FOR. DRIFT DROPLETS WITH DIAMETERS LESS THAN 200 MICROMETERS ARE ASSUMED TO BE DISPERSED ACCORDING TO THE GAUSSIAN PLUME FORMULA, WITH THE PLUME TILTED DOWNWARD TO ACCOUNT FOR THE SETTLING SPEED OF THE DROPLET.
- 15-2-6-198 SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER REACTOR FACILITIES
THOMPSON, G.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
THE EDITORS OF NUCLEAR SAFETY HAVE PREVIOUSLY BEEN EXTRACTING INFORMATION ON RECENT OCCURRENCES FROM THE MORE COMPREHENSIVE FILES OF THE NUCLEAR SAFETY INFORMATION CENTER. WE ARE PLEASED TO INITIATE IN THIS ISSUE A SUMMARY USING PRINTOUT FROM THE RECENTLY ESTABLISHED FILE ON ABNORMAL OCCURRENCE REPORTS WHICH HAS BEEN DEVELOPED BY THE OFFICE OF OPERATIONS EVALUATION, AEC DIRECTORATE OF REGULATORY OPERATIONS.
- 15-3-1-241 WATER REACTOR SAFETY RESEARCH INFORMATION MEETING
COTTRELL, M. B.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE IS A REVIEW OF THE WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE AEC DIVISION OF REACTOR SAFETY RESEARCH, HELD AT AEC HEADQUARTERS, WASHINGTON, D.C., DEC. 4-6, 1973. OVER 150 PEOPLE ATTENDED THE MEETING, BUT NO PROCEEDINGS ARE PLANNED. THE MEETING INCLUDED 37 PRESENTATIONS GROUPED INTO THE FOLLOWING SESSIONS (I) SEPARATE-EFFECTS PROGRAM, (II) LOSS-OF-FLUID TEST (LOFT) PROGRAM, (III) POWER BURST FACILITY (PBF) PROGRAM, (IV) LOSS-OF-COOLANT (LOCA) ANALYSIS PROGRAMS, (V) REACTOR SAFETY STUDIES, (VI) REGULATORY TECHNICAL ASSISTANCE PROGRAMS, (VII) HEAVY SECTION STEEL TECHNOLOGY PROGRAM, (VIII) REACTOR PRIMARY COOLANT SYSTEM PIPE RUPTURE STUDIES, AND (IX) VENDOR REACTOR SAFETY PROGRAMS. IT IS APPARENT FROM THESE PRESENTATIONS THAT THE AEC IS SPONSORING EXTENSIVE PROGRAMS IN THE AREAS OF BOTH LOCA AND PRIMARY SYSTEM INTEGRITY, BUT MUCH WORK REMAINS TO BE DONE. BRIEF SUMMARIES OF ALL PRESENTATIONS ARE INCLUDED.
- 15-3-1-242 THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION OF THE FWPCA AND RELATED LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS
DAVIS, J. P.
CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
THIS TWO PART ARTICLE PRESENTS A GENERAL OVERVIEW OF THE NEW FEDERAL WATER POLLUTION CONTROL ACT (ENACTED IN OCTOBER 1972) AND DISCUSSES ITS IMPACT ON THE REGULATION OF NUCLEAR POWER FACILITIES. PART I, INCLUDED HERE, DESCRIBES THE PERMIT PROGRAM FOR THE NATIONAL POLLUTION DISCHARGE ELIMINATION SYSTEM, WHICH REPLACES THE REFUSE ACT PERMIT PROGRAM AND REQUIRES A PERMIT FOR THE DISCHARGE OF ANY SUBSTANCE TO THE WATERWAYS OF THE UNITED STATES.
- 15-3-2-276 PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PLANTS
HALL, I. B.
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.
THE RISK TO THE PUBLIC FROM AN AIRCRAFT STRIKING A NUCLEAR POWER PLANT HAS BEEN EVALUATED IN A QUANTIFIED MANNER. AIRCRAFT ACCIDENT DATA HAVE BEEN ANALYZED TO ESTIMATE THE PROBABILITY OF AN AIRCRAFT STRIKING A TYPICAL NUCLEAR POWER PLANT AT SITES ADJACENT TO AND REMOTE FROM AN AIRPORT. IN THE EVENT THAT AN AIRCRAFT STRIKES A BUILDING, THE REGION OF IMPACT IS GENERALLY RESTRICTED TO A LOCAL COMPONENT. TWO MODES OF SIGNIFICANT DAMAGE ARE DELINEATED (1) PERFORATION AND (2) LOCAL COLLAPSE. METHODS HAVE BEEN DEVELOPED TO ESTIMATE THE CONDITIONAL PROBABILITIES OF SUCH STRUCTURAL DAMAGE GIVEN AN AIRCRAFT STRIKE AND PROBABILITY VALUES CALCULATED FOR A REPRESENTATIVE STRUCTURE. ACTUAL RISK TO THE PUBLIC (PROBABILITY VS. RADIOACTIVE-RELEASE MAGNITUDE) MAY BE ESTIMATED FROM A CLASSIFICATION OF CRITICAL SAFETY COMPONENTS BY THEIR STRUCTURAL PROTECTION AND THE LIKELY RELEASE MAGNITUDE IN THE EVENT OF THEIR DAMAGE. ALL FORESEEABLE RELEASES EITHER CAUSE INSIGNIFICANT OFF-SITE DOSE OR, FOR MOST SITES, ARE ASSOCIATED

WITH VERY LOW PROBABILITIES. A BRIEF EVALUATION SHOWS THAT FIRE UPON IMPACT IS NOT A SIGNIFICANT INCREMENT OF RISK. COMPARISON OF THESE RISKS TO SOCIALLY ACCEPTABLE RISK LEVELS SHOWS THAT REACTOR SITES BEYOND 5 MILES FROM AN AIRPORT OR AWAY FROM A BUSY AIR CORRIDOR SHOULD BE ACCEPTABLE. OTHER POTENTIAL SITES NEED INDIVIDUAL EXAMINATION, AND, IN SOME CASES, HARDENING OF THE STRUCTURE MAY BE NECESSARY.

- 15-3-2-285 ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING CASE. E. C.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.
IN AN ARTICLE DERIVED FROM TESTIMONY AT A RECENT PUBLIC HEARING ON AN OPERATING LICENSE FOR PRAIRIE ISLAND 1 AND 2, AEC TESTIMONY AS TO THE PROBABILITY OF A SPECIFIC CLASS 5 ACCIDENT-A SUDDEN LOSS-OF-COOLANT ACCIDENT (LOCA) ACCOMPANIED BY A SERIOUS FAILURE OF EMERGENCY CORE COOLING WAS PRESENTED. IN ARRIVING AT THE CONCLUSION THAT THE PROBABILITY FOR SUCH AN EVENT WOULD BE LESS THAN 10^{-7} PER REACTOR YEAR AND THAT THE ENVIRONMENTAL RISK OF SUCH AN ACCIDENT WAS NEGLIGIBLE, FAILURE PROBABILITIES WERE ASSIGNED TO THREE STEPS IN THE ACCIDENT SEQUENCE. THE LIKELIHOOD OF A SUDDEN MAJOR LOCA WAS IN THE RANGE 10^{-5} TO 10^{-3} PER REACTOR YEAR, THE LIKELIHOOD OF SERIOUS EMERGENCY CORE COOLING SYSTEM FAILURE WAS IN THE RANGE 10^{-2} TO 10^{-4} PER REACTOR YEAR, AND THE LIKELIHOOD OF CONTAINMENT BREACH WAS IN THE RANGE 10^{-3} TO 10^{-4} . THIS ARTICLE SUMMARIZES THE COMMISSIONS RATIONALE FOR ITS PROBABILITY ESTIMATES.
- 15-3-3-292 INS STANDARD NIA-8 ON DESIGN BASES FOR PROTECTIVE SYSTEMS FERGUSON, R. L.
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.
THE STANDARDS COMMITTEE OF THE AMERICAN NUCLEAR SOCIETY HAS DEVELOPED CRITERIA RELATED TO ESTABLISHING THE DESIGN BASES FOR THE INTEGRATED RESPONSE OF THE ACTUATOR SYSTEMS, THE PROTECTION SYSTEMS, AND THEIR SUPPORTING SYSTEMS TO THE POSTULATED ACCIDENTAL EVENTS THAT MIGHT OCCUR DURING THE LIFE OF NUCLEAR POWER STATIONS. THESE CRITERIA REPRESENT THE FIRST ATTEMPT TO DEVELOP CRITERIA FOR THE INTEGRATED RESPONSE OF THE SEVERAL SYSTEMS THAT PROTECT THE STATION AND THE PUBLIC.
- 15-3-4-295 THE SAFETY AND CONTROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FIXED NEUTRON ABSORBER ROTH, R. E. + ALVAREZ, D. L.
DOW CHEMICAL COMPANY, ROCKY FLATS, COLO.
RASCHIG RINGS HAVE BEEN USED FOR CRITICALITY PREVENTION IN THE STORAGE OF ENRICHED URANIUM-235 SOLUTION FOR OVER 8 YEARS AT THE DOW CHEMICAL COMPANY'S NUCLEAR SAFETY LABORATORY AT ROCKY FLATS, CO. UNDER NEARLY IDEAL STORAGE CONDITIONS, THE RELATIVELY PURE, LOW ACID SOLUTION HAS CAUSED NO CORROSION. PRODUCTION PLANTS HANDLING INDUSTRIAL GRADE SOLUTIONS EXPERIENCE GREATER CORROSION, REQUIRING OCCASIONAL RING REPLACEMENT. MATERIAL ACCOUNTABILITY PROCEDURES ALLOW MASS BASED INVENTORY MEASUREMENTS TO ± 1 PERCENT. A NEUTRON FLUX CALIBRATION TECHNIQUE ENHANCES THE ACCURACY AND HEALTH PHYSICS SAFETY OF GOOD MATERIAL CONTROL, WHICH IN TURN CONTRIBUTE TO NUCLEAR SAFETY. THE MORE AN INDUSTRIAL LIQUID DIFFERS FROM THE PRESENT SOLUTION, THE LESS APPLICABLE ARE THE CONCLUSIONS REPORTED HERE.
- 15-3-4-302 SEPARATION AND CONTAINMENT OF NOBLE GASES I A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I BARTON, C. J.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE NOBLE GASES SYMPOSIUM HELD IN LAS VEGAS, NEV., SEPT. 24-28, 1973, COVERED ALL IMPORTANT ASPECTS OF THIS TOPIC, INCLUDING SEPARATION AND CONTAINMENT CONSIDERED HERE. CHEMICAL BEDS, AT AMBIENT OR LOWER TEMPERATURES, PROVIDE A WIDE RANGE OF DELAY TIMES TO PERMIT DECAY OF THE SHORT LIVED RARE GASES. MORE SOPHISTICATED TECHNIQUES, SUCH AS CRYOGENIC SYSTEMS AND ADSORPTION IN LIQUID FLUOROCARBONS, CAN MINIMIZE THE VOLUME OF LONG LIVED SEPARATED RARE GAS, PRINCIPALLY KRYPTON-85, FOR LONG TERM STORAGE. CONTAINMENT OF KRYPTON-85 IN PRESSURIZED STEEL CYLINDERS STORED IN WELL ENGINEERED FACILITIES IS THE PREFERRED METHOD AT PRESENT.
- 15-3-5-306 IAEA-WHO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN THE ATMOSPHERE MOSKOW, R. P., JR.
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION OAK RIDGE, TENN.
THIS ARTICLE IS A REVIEW OF A SYMPOSIUM ON THE BEHAVIOR OF RADIOACTIVE ATMOSPHERIC CONTAMINANTS. THE SYMPOSIUM WAS HELD IN VIENNA, 10/12-16, 1973. THEORETICAL AND EXPERIMENTAL REPORTS ON LOCAL, REGIONAL, AND GLOBAL DISPERSION OF EFFLUENTS ARE DISCUSSED, AS ARE THE PRODUCTION AND ENVIRONMENTAL IMPACT OF THE EFFLUENTS.
- 15-3-6-311 RELEASES OF RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972 NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
PRESENTED IN THIS ARTICLE IS A TABULATION OF RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS FOR CALENDAR YEAR 1972. THE DATA INCLUDED ARE THOSE REPORTED BY THE LICENSEE EXCEPT FOR CERTAIN CALCULATIONS MADE BY THE AEC REGULATORY STAFF. A SIMILAR REPORT WAS MADE FOR 1971. IT IS

ALSO SHOWN IN THIS ARTICLE THAT THE RADIOACTIVITY IN EFFLUENTS FROM LICENSED NUCLEAR POWER PLANTS HAS GENERALLY BEEN LOW IN COMPARISON WITH THE LIMITS SET FORTH IN THE U.S. ATOMIC ENERGY COMMISSIONS TO CFR, PART 20, STANDARDS FOR PROTECTION AGAINST RADIATION.

15-4-1-316 VALVE MALFUNCTIONS IN NUCLEAR POWER PLANTS
NUCLEAR SAFETY STAFF

ORNL RICE NATIONAL LABORATORY, CAR RICE, TENN.

THIS ARTICLE PRESENTS THE RESULTS OF THREE INDEPENDENT SURVEYS OF DATA DESCRIBING MALFUNCTIONS OF VALVES USED IN REACTOR FACILITIES DURING THREE SEPARATE BUT OVERLAPPING TIME INTERVALS AND A FOURTH SURVEY OF EXPERIENCE CONCERNING THE STRUCTURAL INTEGRITY OF VALVES. NONE OF THE VALVE PROBLEMS COVERED BY THE REVIEWS HAVE POSED A THREAT TO THE HEALTH AND SAFETY OF THE OFF-SITE PUBLIC. HOWEVER, IN A FEW CASES, VALVE MALFUNCTIONS HAVE LED TO RADIOLOGICAL INJURIES TO PLANT PERSONNEL. THE APPARENT RATES OF MALFUNCTION OF VALVES RANGED FROM 2.5 TO 8.1 PER PLANT PER YEAR, ALTHOUGH THE HIGHER NUMBER IS BELIEVED BIASED BY A LARGE AMOUNT OF PREOPERATIONAL TEST DATA. THE FOURTH SURVEY INDICATED THAT 15 PERCENT OF THE VALVES DID NOT MEET WALL THICKNESS SPECIFICATIONS.

15-4-1-375 THE AEC STUDY ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS
RASMUSSEN, R. C.

MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASS.

THE U.S. ATOMIC ENERGY COMMISSION INITIATED A REACTOR SAFETY STUDY IN SEPTEMBER 1972 TO ESTIMATE THE PROBABILITY OF OCCURRENCE OF VARIOUS POTENTIAL ACCIDENTS IN LIGHT WATER NUCLEAR POWER PLANTS AND OF THEIR CONSEQUENCES. THE STUDY IS DIVIDED INTO SEVERAL TASKS, INCLUDING SUCH TOPICS AS THE IDENTIFICATION OF ACCIDENT SEQUENCES, THE ASSIGNMENT OF PROBABILITIES, FISSION PRODUCT TRANSPORT IN EACH ACCIDENT SEQUENCE, FISSION PRODUCT DISTRIBUTION IN THE ENVIRONMENT, HEALTH EFFECTS AND PROPERTY DAMAGE, NONNUCLEAR RISKS, AND INTERPRETATION AND COMMUNICATION OF THE MEANING OF LOW PROBABILITY EVENTS TO NONTECHNICAL READERS. A FINAL REPORT IS EXPECTED IN THE SUMMER OF 1974.

15-4-1-382 THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL
GOODRICH, R. P.

U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.

EDITOR'S NOTE - THIS ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY STAFF FROM THE TESTIMONY OF THE ATOMIC SAFETY AND LICENSING BOARD (ASLB) PANEL CHAIRMAN, RATHMEL M. GOODRICH, BEFORE THE JOINT COMMITTEE ON ATOMIC ENERGY OF THE U.S. CONGRESS ON SEPT. 27, 1973. CHAIRMAN GOODRICH OUTLINES THE ASLB WORK LOAD AND EXPLAINS HOW BOARDS ARE APPOINTED. VARIOUS FACETS OF THE HEARING PROCESS ARE DISCUSSED, INCLUDING SPECIFICALLY THE LEGAL BASIS, CONDUCT, ASSETS AND CONTRIBUTIONS, AND OPTIMIZATION. SOME RECENT EXPERIENCES ARE ALSO MENTIONED. THE FUNCTION OF THE ATOMIC SAFETY AND LICENSING BOARD (ASLB) IS TO CONDUCT HEARINGS, AS NEEDED, PURSUANT TO SEC. 191 OF THE ATOMIC ENERGY ACT. HEARINGS ARE CONDUCTED IN EACH INSTANCE BY THREE MEMBER BOARDS APPOINTED FROM THE MEMBERSHIP OF THE ASLB PANEL, WHICH WAS RECONSTITUTED FOR THIS SOLE PURPOSE IN NOVEMBER 1971. PRIOR TO THAT TIME, PANEL OFFICIALS ALSO WERE RESPONSIBLE FOR APPEAL REVIEW OF HEARING BOARD DECISIONS. THE APPEAL FUNCTION IS NOW CONDUCTED SEPARATELY BY BOARDS APPOINTED FROM AN ATOMIC SAFETY AND LICENSING APPEAL PANEL, WHICH OPERATES INDEPENDENTLY OF THE ASLB PANEL.

15-4-2-387 PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES
ADVISORY COMMITTEE REACTOR SAFEGUARDS, U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.

EDITOR'S NOTE - THIS ARTICLE WAS ADAPTED FROM SECTION 5 OF "REPORT ON THE INTEGRITY OF REACTOR VESSELS FOR LIGHT WATER POWER REACTORS," WASH-1285, PUBLISHED BY THE AEC ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN JANUARY 1974. THE EDITORS FELT THAT THE STATISTICAL DATA ON PRESSURE VESSEL FAILURES PRESENTED WERE WOULD BE OF PARTICULAR INTEREST TO THE READERS OF NUCLEAR SAFETY. THOSE INTERESTED IN THE BACKGROUND AND SUPPORTING MATERIAL PRESENTED IN THE REMAINDER OF THE REPORT MAY OBTAIN A COMPLETE COPY FROM THE SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE, WASHINGTON, FOR \$1.20.) OPERATING EXPERIENCE WITH NUCLEAR REACTOR PRESSURE VESSELS IS INADEQUATE, BOTH WITH RESPECT TO THE NUMBER OF VESSEL YEARS OF SERVICE AND THE NUMBER OF KNOWN DEFECTS, TO PERMIT A DIRECT STATISTICAL DETERMINATION OF THE PROBABILITY OF FAILURE. THUS AN ALTERNATE APPROACH HAS BEEN TAKEN WHICH INVOLVES THE FOLLOWING STEPS, 1. CONSIDERATION OF OPERATIONAL AND FAILURE DATA FOR NONNUCLEAR TYPES OF PRESSURIZED COMPONENTS, SUCH AS BOILER DRUMS AND UNFIRED PRESSURE VESSELS. 2. CLASSIFICATION OF THESE NONNUCLEAR VESSEL FAILURES INTO THREE CATEGORIES ADOPTED FOR THIS ARTICLE. 3. COMPARISON OF THE DESIGN, CONSTRUCTION, INSPECTION, AND OPERATING PROCEDURES USED FOR BOILER DRUMS AND UNFIRED PRESSURE VESSELS WITH THOSE USED FOR NUCLEAR REACTOR VESSELS, AND ESTIMATION OF THE EFFECTS OF ANY DIFFERENCES ON THE RELATIVE PROBABILITY OF FAILURE OF THE TWO TYPES OF VESSELS. 4. UTILIZATION OF THE INFORMATION FROM THE ABOVE STEPS TO APPRAISE THE PROBABILITY OF DISRUPTIVE REACTOR VESSEL FAILURE.

- 15-6-2-399 PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER PLANTS
WILL. I. B.
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.
A METHOD IS DESCRIBED FOR ESTIMATING THE POTENTIAL HAZARD TO A NUCLEAR POWER STATION FROM MAJOR FLOODING OF A NEARBY RIVER. THE METHOD, APPLIED TO THE MORTICELLO REACTOR SITE FOR ILLUSTRATION, USES HISTORICAL DATA TO ESTIMATE BOTH THE PROBABLE MAGNITUDES AND THE PROBABILITIES OF OCCURRENCE OF FLOODS DURING THE 50-YEAR LIFE OF THE PLANT. THIS APPROACH AVOIDS THE LONG EXTRAPOLATIONS FROM LIMITED DATA ASSOCIATED WITH ATTEMPTS TO ESTIMATE THE MAGNITUDE OF THE PROBABLE MAXIMUM FLOOD, WHICH MAY HAVE A RETURN PERIOD OF 10,000 YEARS, AND PERMITS THE CALCULATION OF CONFIDENCE LIMITS ASSOCIATED WITH DEVIATION FROM THE EXPECTED BEHAVIOR. ON THE BASIS OF ESTIMATES OF POTENTIAL EFFECTS, IT IS CONCLUDED THAT A REASONABLE NUCLEAR PLANT DESIGN BASIS WOULD BE THE "FLOOD MAGNITUDE WITH AN OCCURRENCE PROBABILITY OF 10E-4) TO 10E-5) DURING THE NEXT 50-YEAR PERIOD.
- 15-6-3-400 PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE FEDERAL REPUBLIC OF GERMANY
SCHMALLOPP, B.
BUND SCHMALLOPP FÜR KERNREAKTOR-INSTRUMENTIERUNG, BERLIN, FEDERAL REPUBLIC OF GERMANY
THIS ARTICLE REVIEWS SOME OF THE BASIC IDEAS AND PHILOSOPHIES APPLIED TO REACTOR PROTECTION SYSTEMS IN THE FEDERAL REPUBLIC OF GERMANY FROM THE SPECIAL POINT OF VIEW OF THE AUTHOR. REVIEWED ARE THE IMPLEMENTATION AND APPLICATION OF DESIGNS FOR THE SELF-MONITORING OF ELECTRONIC SYSTEMS AND FOR THE USE OF COMPUTERS IN THE PROTECTION SYSTEMS OF EXISTING NUCLEAR POWER STATIONS.
- 15-6-3-417 THE 16TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION
SILVERMAN, R. D. + HAGEN, E. W.
NUCLEAR PENNSYLVANIA POWER AND LIGHT COMPANY, ALLENTOWN, PA. / OAK RIDGE NATIONAL LABORATORY, CAR RIDGE, TENN.
THE 16TH ANNUAL INSTRUMENT SOCIETY OF AMERICA POWER INSTRUMENTATION SYMPOSIUM, GEARED TO THE THEME "CHALLENGES FOR POWER INSTRUMENTATION," IS REVIEWED. THE SYMPOSIUM PRESENTED NEW CONCEPTS IN USING EXISTING PROCESS CONTROL INSTRUMENTATION, A DISCUSSION OF AEC REGULATORY GLIDES AFFECTING INSTRUMENTATION FOR ENVIRONMENTAL MONITORING OF POWER PLANTS, AND THE NEED FOR INDUSTRY STANDARDS. NEW APPROACHES WERE PRESENTED RELATIVE TO CONTROL ROOM DESIGN, SEISMIC QUALIFICATION OF INSTRUMENTATION, DIRECT DIGITAL CONTROL DESIGNS, AND NITROUS OXIDE ABATEMENT.
- 15-6-4-423 PENETRATION TESTING FOR THE DETERMINATION OF PROPERTIES OF SOILS
ROBINSON, G. C., JR.
OAK RIDGE NATIONAL LABORATORY, CAR RIDGE, TENN.
SAFE PERFORMANCE OF MANY NUCLEAR POWER PLANTS IS INHERENTLY RELATED TO SOIL BEHAVIOR, PARTICULARLY AS AFFECTED BY THE LOADINGS THAT EARTH QUAKES MAY IMPOSE. SITES WITH COMPETENT ROCK FOUNDATIONS WILL BE INCREASINGLY DIFFICULT TO ACQUIRE BECAUSE OF INTERRELATIONS WITH ENVIRONMENT, LOAD LOCATION, AND ECONOMIC FACTORS. CONSEQUENTLY THE TECHNIQUES USED FOR ASSESSING SOIL PROPERTIES CONSTITUTE AN INTEGRAL PART OF THE INTERDISCIPLINARY REVIEW OF SUCH FACILITIES. ALTHOUGH STANDARD PENETRATION TESTING IS ONE OF THE MOST WIDELY USED TECHNIQUES FOR ASSESSING SOIL PROPERTIES, ITS LIMITATIONS ARE NOT WELL UNDERSTOOD. THIS ARTICLE REVIEWS THESE LIMITATIONS AND SUGGESTS RECOMMENDATIONS WHEREBY MORE QUANTIFIABLE SOIL TESTS MAY BE POSSIBLE.
- 15-6-4-432 TORNADO RESISTANT DESIGN OF NUCLEAR POWER PLANT STRUCTURES
MCDONALD, J. B. + MENTA, R. C. + MINOR, J. E.
TEXAS TECH UNIVERSITY, LUBBOCK, TEXAS
THIS ARTICLE REVIEWS THE VARIOUS FACTORS INVOLVED IN TORNADO RESISTANT DESIGN AND EVALUATES THEIR RELEVANCE IN LIGHT OF CURRENT DESIGN CRITERIA. THE FPP SCALE RATINGS OF STORMS AND THE RECORD KEEPING EFFORTS OF THE NATIONAL SEVERE STORMS FORECAST CENTER IN KANSAS CITY, MO., HAVE GENERATED DATA THAT PROVIDE A MORE CONCISE UNDERSTANDING OF THE GEOGRAPHICAL DISTRIBUTIONS OF TORNADOES AND THEIR INTENSITY. SUCH DATA HAVE RESULTED IN USEFUL REGION CRITERIA FOR THE DESIGN OF TORNADO RESISTANT NUCLEAR PLANTS. THE AEC DESIGN BASIS TORNADO AND ITS IMPLICATIONS ARE DISCUSSED, WITH SPECIFIC REFERENCE TO OCCURRENCE AND INTENSITY DATA, TORNADO - WIND MODELS, TORNADO STRUCTURE INTERACTION, AND TORNADO GENERATED MISSILES. THE USE OF TORNADO - WIND MODELS REPRESENTS A RATIONAL APPROACH TO DETERMINING THE FORCES ON STRUCTURES AND ALSO PROVIDES DATA FOR EVALUATING THE FLIGHT POTENTIAL OF MISSILES. TORNADO STRUCTURE INTERACTION, THE PHENOMENON WHEREBY THE METEOROLOGICAL EFFECTS ARE TRANSLATED INTO LOADS ON THE STRUCTURE, IS DISCUSSED AT LENGTH. A CLEAR UNDERSTANDING OF THESE LOADS CAN LEAD TO ECONOMY OF CONSTRUCTION WITHOUT COMPROMISING SAFETY. CURRENTLY THERE ARE MANY QUESTIONS RELATING TO DESIGN FOR TORNADO GENERATED MISSILES. HOPEFULLY FUTURE RESEARCH IN THIS AREA WILL LEAD TO AN UNDERSTANDING OF THE PHENOMENON AND ALLOW A RELAXING OF THE MISSILE CRITERIA.

- 15-4-5-440 REVIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE HEARING
 SHYDER, W. S.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
 EDITOR'S NOTE - AT THE REQUEST OF THE NUCLEAR SAFETY EDITORS, W. S. SHYDER HAS PREPARED THE FOLLOWING REVIEW OF THE FINAL ENVIRONMENTAL STATEMENT (FES) IN THE "AS LOW AS PRACTICABLE" HEARING. SHYDER MAKES NO ATTEMPT TO COMMENT ON EXTERNAL EVENTS THAT OCCURRED EITHER BEFORE OR SINCE THE HEARING OR ON INFORMATION INCLUDED IN THE HEARING BUT NOT IN THE FES. HOWEVER, IN THIS REVIEW HE HAS REACHED A COMPROMISE ON THE VARIOUS QUESTIONS AT ISSUE, A COMPROMISE THAT IS COMMENSURATE WITH HIS RESPONSIBILITY IN ACCEPTING THIS TASK.)
- 15-4-5-443 CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE HEARING
 EDITOR'S NOTE - THE CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE "AS LOW AS PRACTICABLE" HEARING, Docket No. AN-50-2, WAS ISSUED ON FEB. 20, 1976. IN ADDITION TO THE 145-PAGE STATEMENT, THE REGULATORY STAFF SIMULTANEOUSLY RELEASED A 450-PAGE ATTACHMENT CONTAINING THE TEXT OF FIVE DRAFT REGULATORY GUIDES THAT PROVIDE MODELS AND PARAMETERS FOR CALCULATING 1-PAGE EXPECTED RELEASES. THE "AS LOW AS PRACTICABLE" HEARING, WHICH BEGAN IN JANUARY 1972, IS NOW HEARING COMPLETION, BUT IT WILL BE SEVERAL MONTHS BEFORE THE PROPOSED RULES OR SOME VARIATION OF THEM ARE PUBLISHED IN THE FEDERAL REGISTER WITH AN EFFECTIVE DATE. IN THE MEANTIME, THE REGULATORY STAFF'S CONCLUDING STATEMENT PROVIDES THE BEST INTERIM GUIDANCE AVAILABLE. ALTHOUGH THE LENGTH OF THIS STATEMENT, COMPLETE WITH THE REGULATORY STAFF'S DISCUSSION OF ITS RECOMMENDATIONS AND COST-BENEFIT CONSIDERATIONS PRECLUDES PUBLICATION HERE, WE ARE REPRODUCING THE INTRODUCTION TO THE STATEMENT (INCLUDING THE REGULATORY STAFF'S CONCLUSIONS AND RECOMMENDATIONS) AND THE PROPOSED RULE ITSELF. PERSONS INTERESTED IN MORE DETAILS SHOULD EXAMINE THE FULL REPORT, WHICH IS A PART OF THE HEARING RECORD. IN ADDITION, THE FINAL ENVIRONMENTAL STATEMENT IS REVIEWED IN THE PRECEDING ARTICLE OF THIS ISSUE OF NUCLEAR SAFETY. THE TWO SECTIONS OF THE CONCLUDING STATEMENT ARE PRESENTED HERE VERBATIM, INCLUDING THE STAFF'S USE OF FOOTNOTES AND REFERENCES.)
- 15-4-5-443 POPULATION EXPOSURE TO X-RAYS - U.S. 1970
 EDITOR'S NOTE - WHILE THE NUCLEAR INDUSTRY IS BEING REQUESTED TO REDUCE EXPOSURE LEVELS TO "AS LOW AS PRACTICABLE," THE MEDICAL PROGRESSION CONTINUES TO BE THE DOMINANT SOURCE OF BACKGROUND RADIATION EXPOSURE TO THE POPULATION. THE ENTIRE SUMMARY SECTION OF THE PUBLIC HEALTH SERVICE REPORT ON "POPULATION EXPOSURE TO X-RAYS - U.S. 1970," (DHEW (FOS) PUBLICATION 73-6047, IS QUOTED BELOW. ALTHOUGH THE REPORT DOES NOT PRESENT A CONCLUSION AS TO THE AVERAGE POPULATION EXPOSURE FROM MEDICAL RADIATION, SUCH A NUMBER MAY BE CALCULATED FROM THE DATA GIVEN. THE 137-PAGE REPORT INCLUDES A COMPREHENSIVE ASSESSMENT OF MEDICAL EXPOSURES IN THE UNITED STATES BY REGION, TYPE OF EXAMINATION, AGE OF EQUIPMENT, ETC., WITH THE DETAILED DATA IN APPENDICES. THE REPORT CARRIES A DATE OF NOVEMBER 1973, ALTHOUGH IT WAS DISTRIBUTED IN APRIL 1974, AND MAY BE PURCHASED FROM THE SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE, WASHINGTON, D.C.)
- 15-4-5-455 UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM CERMET CORES DURING OUTGASSING
 GRAY, L. W.
 SAVANNAH RIVER LABORATORY, Aiken, SOUTH CAROLINA
 DURING ROUTINE OUTGASSING OF SCRAP URANIUM - ALUMINUM CERMET CORES, UNEXPECTED EXOTHERMIC REACTIONS RELEASED SUFFICIENT ENERGY TO MELT NINE CORES. IN THE SUBSEQUENT INVESTIGATION, COMPOUNDS IN THE SCRAP URANIUM WERE IDENTIFIED, AND THE HISTORY OF THE MATERIAL WAS DEFINED. THE INCIDENT WAS INITIATED BY REACTIONS AT ABOUT 350C BETWEEN POWDERED ALUMINUM METAL AND MIXED URANATE SALTS, WHICH RELEASED SUFFICIENT ENERGY TO INITIATE OTHER ALUMINOTHERMIC REACTIONS. A PLAUSIBLE REACTION SEQUENCE IS POSTULATED TO ACCOUNT FOR THE ENERGY RELEASED IN THE INCIDENT.
- 15-4-5-460 THE LEAK OF TANK 100-T AT WAFORD
 ROBINSON, R. A.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
 THIS ARTICLE REVIEWS AN INCIDENT IN WHICH APPROXIMATELY 115,000 GAL OF RADIOACTIVE LIQUID WASTE LEAKED FROM A 533,000-GAL UNDERGROUND STORAGE TANK AT THE WAFORD PLANT OF THE U.S. ATOMIC ENERGY COMMISSION IN 1973. THE ENSUING INVESTIGATION INDICATED THAT THE LEAKED MATERIAL WAS RETAINED IN THE SOIL IN THE VICINITY OF THE WASTE TANKS AND POSED NO THREAT TO THE WORKERS AND THE NEARBY COLUMBIA RIVER. HOWEVER, THE INVESTIGATION DID POINT OUT THE NEED FOR IMPROVED MONITORING PROCEDURES, WHICH ARE PRESENTLY BEING IMPLEMENTED.
- 15-5-1-513 SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF NUCLEAR MATERIALS
 NUCLEAR SAFETY STAFF
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
 DIVERSION OF SPECIAL NUCLEAR MATERIAL PRESENTS A THREAT AS AN EXPLOSIVE WEAPON, AS A BIOLOGICAL POISON, OR AS A RADIATION SOURCE. HOWEVER, THERE ARE ONLY A FEW STEPS IN THE NUCLEAR FUEL CYCLE WHICH ARE VULNERABLE TO DIVERSION OR SABOTAGE. THESE

STEPS ARE IDENTIFIED. THE PROTECTIVE MEASURES REQUIRED BY THE COMMISSION BOTH ON SITE AND IN TRANSIT ARE DESCRIBED. AS ARE THE RESEARCH AND DEVELOPMENT THAT ARE UNDER WAY TO IMPROVE THE CAPABILITY OF THE U.S. SAFEGUARDS.

15-5-1-519

UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND SAFETY ASSESSMENT
CONLEY, J. M. + OGDEN, P. L. + MCCREATH, J. R.
UNITED ENGINEERS AND CONSTRUCTORS, INC., PHILADELPHIA, PA.
THE SITING OF NUCLEAR PLANTS UNDERGROUND IS EXAMINED BASEDLY ON THE BASIS OF TECHNICAL FEASIBILITY, DESIGN, SAFETY, AND ECONOMICS. DISCUSSION IS GENERAL FOR ALL REACTOR TYPES AND UNDERGROUND SITING ALTERNATIVES, BUT SPECIFIC DETAILS ARE MAINLY REFERRED TO A 1000-MW PRESSURIZED WATER REACTOR LOCATED IN A DEEP ROCK CAVERN. CONCLUSIONS ARE THAT CURRENT TECHNOLOGY IS ENTIRELY ADEQUATE AND THAT THE ENHANCED SAFETY POSTURE OF AN UNDERGROUND SITE MAY FACILITATE CLOSE-IN SITING AND WITH NO GREATER RISK OR POSSIBLY LESS THAN THAT OF A SURFACE SITE. ECONOMIC TRADE-OFFS ARE IDENTIFIED, AND IT HAS NOT BEEN CLEARLY ESTABLISHED THAT UNDERGROUND SITING WOULD RESULT IN AN ECONOMIC PENALTY.

15-5-2-595

COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS

WATSON, R. L.

ORNL KIDNEY NATIONAL LABORATORY, CARLISLE, TENN.

MANY COMPUTER CODES HAVE BEEN DEVELOPED FOR USE IN VARIOUS ASPECTS OF NUCLEAR ACCIDENT ANALYSIS. THE NUCLEAR SAFETY INFORMATION CENTER HAS SEPARATED OVER 100 OF THESE CODES INTO 13 GROUPS AND TABULATED THEM. THE RESULTING TABLE GIVES NAME OF CODE, MACHINE ON WHICH IT IS OPERABLE, ITS LANGUAGE, COMPILANT AUTHOR, A STATEMENT OF WHAT THE CODE DOES, A REFERENCE CITATION, AND DATE OF THE REFERENCE.

15-5-3-556

A PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION TO DETECT INCIPENT FAILURE IN NUCLEAR PRESSURE VESSELS

BELL, R. L.

CELESCO, CANOGA PARK, CALIF.

SIGNIFICANT ADVANCES IN THE TECHNOLOGY AND APPLICATION OF THE ACOUSTIC EMISSION MONITORING TO DETECTION, LOCATION, AND CHARACTERIZATION OF INCIPENT FAILURE MECHANISMS IN PRESSURE VESSELS HAVE BEEN MADE OVER THE LAST SEVERAL YEARS. IN ADDITION TO PROGRAMS CARRIED OUT BY DEVELOPMENT LABORATORIES AND PRIVATE RESEARCH FACILITIES, THE GOVERNMENT AND THE UTILITY INDUSTRY HAVE ALSO SPONSORED PROGRAMS THAT HAVE GREATLY INCREASED THE SCOPE AND APPLICABILITY OF THE TECHNIQUE TO NUCLEAR PRESSURE VESSEL INSPECTION. BOTH PERIODIC HYDROTEST MONITORING WITH ACOUSTIC EMISSION AND CONTINUOUS ACOUSTIC EMISSION SURVEILLANCE ARE FEASIBLE FOR APPLICATION TO BOILING WATER REACTOR AND PRESSURIZED WATER REACTOR PRESSURE VESSELS. BOTH APPROACHES HAVE THEIR LIMITATIONS AND ADVANTAGES BUT, IN GENERAL, APPEAR TO PROVIDE MORE INFORMATION ON THE INTEGRITY OF THE NUCLEAR PRESSURE VESSEL THAN ANY OTHER NONDESTRUCTIVE TESTING TECHNIQUE PRESENTLY USED. ALTHOUGH RESEARCH AND DEVELOPMENT WORK IS CONTINUING WITH REGARD TO BETTER DETERMINING THE SEVERITY OF THE ACOUSTIC EMISSION SOURCES, CONSIDERABLE FIELD APPLICATION IS ALREADY PROVIDING USEFUL BASE-LINE AND OPERATING INFORMATION.

15-5-4-572

THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FLATS PLANT I.

SCHUSKE, C. L. + MCCARTHY, J. D.

THE DOW CHEMICAL COMPANY, GOLDEN, COLO.

THE NUCLEAR SAFETY PROGRAM FOR THE COM-AEC PRODUCTION AND RESEARCH COMPLEX AT ROCKY FLATS BEGAN IN 1952. SINCE THEN, CONSIDERABLE CHANGES HAVE BEEN MADE IN THE RESPONSIBILITIES OF THE NUCLEAR SAFETY AND OPERATING GROUPS. THESE RESPONSIBILITIES INCLUDE THE TRAINING OF PERSONNEL, THE AUDITING OF OPERATIONS, AND THE PERFORMING OF MAXIMUM CREDIBLE ACCIDENT REVIEWS OF PLANT FACILITIES. SIGNIFICANT CHANGES IN ADMINISTRATIVE POLICIES AND DOCUMENTATION OF THESE POLICIES WERE BROUGHT ABOUT DURING THE INFLUENCE OF THE COMPANY MANAGEMENT COMMITTEES AND THE AEC ALBUQUERQUE OPERATIONS OFFICE. THESE CHANGES ARE DISCUSSED HERE. PART II, TO APPEAR IN THE NEXT ISSUE OF NUCLEAR SAFETY, DISCUSSES THE IMPACT OF OUR EXPERIMENTAL AND COMPUTATIONAL PROGRAMS ON PLANT OPERATIONS.

15-5-5-505

THE LAW AND LOW LEVEL RADIATION

EASON, C. F. + ST. DENIS, R. V.

U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.

ONE OF THE RESPONSIBILITIES OF THE HEALTH PHYSICIST IS TO RECOMMEND AND ENFORCE RADIATION PROTECTION STANDARDS BASED UPON RECOGNIZED OCCUPATIONAL RADIATION EXPOSURE GUIDES. IT FOLLOWS, THEREFORE, THAT THE HEALTH PHYSICIST, BECAUSE OF HIS BACKGROUND AND TECHNICAL KNOWLEDGE, WILL PLAY A KEY ROLE IN EVALUATING A CLAIM ALLEGEDLY ARISING OUT OF EXPOSURE TO IONIZING RADIATION. THIS ARTICLE EXAMINES A NUMBER OF LATENT RADIATION INJURY CASES WITH PARTICULAR EMPHASIS ON THE KILOS OF RADIATION RECORDS OFFERED IN EVIDENCE, THE NATURE OF THE EXPERT TESTIMONY BY BOTH THE HEALTH PHYSICIST AND THE MEDICAL EXPERT, AND THE CONCLUSIONS OF THE COURT OR BOARD IN THE FINAL ADJUDICATION OF THE CLAIM. THE ARTICLE ALSO EXPLORES THE VIEWS OF THOSE WHO HOLD THAT THE PRESENT LEGAL SYSTEM IN THE UNITED STATES IS NOT APPROPRIATE FOR THE HANDLING OF LATENT INJURY CLAIMS.

- 15-5-5-592 SYMPOSIUM ON COOLING-TOWER ENVIRONMENT - 1974
TAYLOR, F. G., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
A SYMPOSIUM CONCERNING THE ENVIRONMENTAL ASPECTS OF COOLING TOWERS WAS HELD AT THE UNIVERSITY OF MARYLAND, COLLEGE PARK, MD., MAR. 4-6, 1974. THE MEETING, SPONSORED BY THE U.S. ATOMIC ENERGY COMMISSION AND THE STATE OF MARYLAND POWER PLANT SITING PROGRAM, CONSISTED OF SIX TECHNICAL SESSIONS WITH INVITED SPEAKERS FROM UNIVERSITY, GOVERNMENT, INDUSTRY, AND UTILITY SPECIALISTS PRESENTING A STATE OF THE ART SURVEY. ATTENDANCE WAS LIMITED BY INVITATION TO THOSE ACTIVELY INVOLVED IN COOLING TOWER RESEARCH IN ORDER TO ENHANCE THE FREE EXCHANGE OF IDEAS IN DISCUSSION FOLLOWING THE PRESENTATIONS. ONE HUNDRED AND FIFTY ATTENDEES, INCLUDING REPRESENTATIVES FROM FOUR FOREIGN COUNTRIES, EXCHANGED VIEWS TO FORM THE VARIOUS TECHNICAL SESSIONS INTO A COMPREHENSIVE SYMPOSIUM.
- 15-5-6-599 EVALUATION OF NUCLEAR POWER PLANT AVAILABILITY
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
A STUDY WAS MADE OF NUCLEAR AND FOSSIL POWER PLANT OPERATING EXPERIENCE TO COMPARE PLANT AVAILABILITY AND TO DETERMINE THE CAUSE AND SAFETY SIGNIFICANCE OF PLANT OUTAGES FOR NUCLEAR PLANTS. RESULTS SHOWED THAT THE AVAILABILITY OF THE NUCLEAR POWER PLANTS IS LOWER THAN THE GENERAL DESIGN OBJECTIVE DURING THE FIRST 1 TO 3 YEARS OF COMMERCIAL SERVICE. FOLLOWING THIS PERIOD OF OPERATION, HOWEVER, AVERAGE AVAILABILITY HAS APPROACHED OR EXCEEDED 80 PERCENT. THE AVERAGE AVAILABILITY OF NUCLEAR PLANTS HAS BEEN NEARLY THE SAME AS THAT OF FOSSIL PLANTS OF APPROXIMATELY THE SAME SIZE DURING THE 12 YEAR PERIOD 1960 TO 1971. APPROXIMATELY HALF OF THE FORCED OUTAGES OF NUCLEAR PLANTS RESULTED FROM EVENTS THAT ARE CONSIDERED TO HAVE SAFETY SIGNIFICANCE. IN NO CASE, HOWEVER, WAS THERE INJURY TO THE PUBLIC OR A RELEASE OF RADIOACTIVE MATERIALS IN EXCESS OF PERMISSIBLE LEVELS.
- 15-6-1-651 NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS
YADIGAROGLU, G. + ANDERSEN, S. C.
UNIVERSITY OF CALIFORNIA, BERKELEY, CALIF.
THIS ARTICLE IS A REVIEW OF THE CONFERENCE ON NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS, HELD IN SAN FRANCISCO, CALIF., NOV. 8-9, 1973. THE STATE OF THE ART OF MAJOR TECHNOLOGIES FOR OFFSHORE AND UNDERGROUND SITING IS REVIEWED BOTH IN TERMS OF DECOUPLING THE LICENSING OF REACTORS FROM SITE RELATED ENVIRONMENTAL FACTORS AND ENGINEERING, FINANCIAL, AND REGULATORY UNCERTAINTIES. PROBLEMS OF COMPREHENSIVE SITE EVALUATION AND TECHNOLOGY ASSESSMENT ASSOCIATED WITH THESE INNOVATIVE CONCEPTS ARE ALSO DISCUSSED. THE CONFERENCE PARTICIPANTS AGREED THAT MAJOR NEW TECHNOLOGIES FOR EXTENDING SITING OPTIONS ARE AVAILABLE. OFFSHORE BREAKWATER PROTECTED POWER PLANTS SEEM TO ENJOY ALMOST UNIVERSAL ACCEPTANCE AMONG ARCHITECT ENGINEER AND UTILITY PLANNERS, BUT OPINIONS WERE STRONGLY DIVIDED ON THE SAFETY AND ECONOMICS OF OTHER NOVEL CONCEPTS.
- 15-6-1-665 BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR POWER REACTORS
HILL, R. M. + BRYAN, R. M. + NICHOLS, B. L.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE DESCRIBES THE EVOLUTION OF A METHOD USED TO DEVELOP BENEFIT COST ANALYSES FOR INCLUSION IN ENVIRONMENTAL STATEMENTS PREPARED FOR THE AEC DIRECTORATE OF LICENSING. THE ARTICLE DISCUSSES (1) THE HISTORY OF THE FEDERAL GOVERNMENT'S DEVELOPMENT OF BENEFIT COST ANALYSES FOR WATER RESOURCES PROJECTS, (2) THE EFFECT OF THE CALVERT CLIFFS CASE ON AEC LICENSING ACTIVITIES, (3) THE DEVELOPMENT OF AEC GUIDES FOR PREPARATION OF ENVIRONMENTAL REPORTS AND BENEFIT COST ANALYSES AND THEIR EFFECT ON OTHER ACTIVITIES, AND (4) SOME POSSIBLE TRENDS IN THE DEVELOPMENT AND USE OF BENEFIT COST ANALYSES DEVELOPED FOR ENVIRONMENTAL REPORTS AND STATEMENTS.
- 15-6-1-673 AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE AEC HAS SPONSORED THIS STUDY, ALSO KNOWN AS THE REACTOR SAFETY STUDY, TO MAKE A QUANTITATIVE ASSESSMENT OF THE POTENTIAL RISKS INVOLVED IN NUCLEAR POWER PLANT ACCIDENTS. THE STUDY GROUP, WHICH WAS DIRECTED BY DR. NORMAN C. WASHNUSSEN, HAS COMPLETED 2 YEARS OF WORK AND PREPARED A DRAFT REPORT ENTITLED AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS. THIS PRODIGIOUS REPORT CONSISTS OF OVER 3000 PAGES BUT FOR CONVENIENCE IS DIVIDED INTO 14 SEPARATE VOLUMES. THE SUMMARY REPORT CONSISTS OF 29 PAGES, AND THE MAIN REPORT HAS 248 PAGES. THE REMAINDER OF THE REPORT CONSISTS OF APPENDICES. REPRINTED BELOW IS THE SECTION ENTITLED INTRODUCTION AND RESULTS FROM THE DRAFT SUMMARY REPORT. WHILE THE STUDY HAS PRESENTED THE ESTIMATED RISKS FROM NUCLEAR POWER PLANT ACCIDENTS AND COMPARED THEM WITH OTHER RISKS THAT EXIST IN OUR SOCIETY, IT HAS MADE NO JUDGMENT ON THE ACCEPTABILITY OF NUCLEAR RISKS. ALTHOUGH THE STUDY BELIEVES NUCLEAR ACCIDENT RISKS ARE VERY SMALL, THE JUDGMENT AS TO WHAT LEVEL OF RISK SOCIETY SHOULD ACCEPT IS A BROADER ONE THAN CAN BE MADE HERE.

- 15-6-2-676 LOSS OF FLUID TEST INTEGRAL TEST FACILITY AND PROGRAM
COPIEN, M. L. + YEARRONDO, L. J.
AEROJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO
THE LOSS OF FLUID TEST INTEGRAL TEST FACILITY WAS DESIGNED TO SIMULATE, AS NEARLY AS POSSIBLE, ALL THE IMPORTANT EFFECTS THAT ARE ANTICIPATED TO OCCUR DURING A LOSS OF COOLANT ACCIDENT IN A LARGE PRESSURIZED WATER REACTOR TYPE NUCLEAR STEAM SUPPLY SYSTEM. INTEGRAL, AS USED HERE, DEFINES AN EXPERIMENT COMBINING THE NUCLEAR, THERMAL, HYDRAULIC, AND STRUCTURAL PROCESSES OCCURRING DURING A LOSS OF COOLANT ACCIDENT AS OPPOSED TO THE SINGLE AND DUAL EFFECT, NON NUCLEAR, SMALL SCALE. THERMOHYDRAULIC EXPERIMENTS CONDUCTED TO DATE. A MINIMUM OF 19 LOSS OF COOLANT EXPERIMENTS IS PLANNED IN THE LOSS OF FLUID TEST WITH VARIOUS SIMULATED LINE BREAK LOCATIONS AND SIZES, INCLUDING SOME INITIAL ISOTHERMAL TESTS USING A CORE SIMULATOR RATHER THAN THE ACTUAL FUEL ASSEMBLIES.
- 15-6-3-691 COMPUTER CONTROL AT BRUCE NUCLEAR GENERATING STATION
MORRIS, D. I.
ATOMIC ENERGY OF CANADA LIMITED, SHERIDAN PARK, ONTARIO, CAN.
THE 3000-MW(e) BRUCE NUCLEAR GENERATING STATION, SCHEDULED TO GO CRITICAL IN SEPTEMBER 1975, UTILIZES DIRECT DIGITAL CONTROL FOR REACTOR REGULATION AND ELECTRIC POWER OUTPUT IN A REACTOR FOLLOWING TURBINE MODE. THE DESIGN AND OPERATING PHILOSOPHIES HAVE BEEN IMPLEMENTED SUCCESSFULLY AT OTHER NUCLEAR STATIONS WHICH ARE PRESENTLY PRODUCING POWER. THE COMPUTERS, PERIPHERALS, AND SOFTWARE OPERATING SYSTEM ARE DESIGNED TO PROVIDE A VARIETY OF HARDWARE AND SOFTWARE SELF-CHECKING FUNCTIONS SO THAT TRANSFER OF CONTROL TO THE STANDBY SYSTEM CAN BE CARRIED OUT AUTOMATICALLY AND CAN BE EITHER PARTIAL OR TOTAL, DEPENDING ON WHICH THE PARTICULAR FAILURE MODE WARRANTS. THE MAIN TASK OF THE DUAL DIGITAL COMPUTERS IS TO PROVIDE UNIT REACTOR POWER REGULATION TO CONTROL THE GENERATION OF ELECTRIC POWER TO AN OPERATOR ENTERED VALUE. A NUMBER OF FUNCTIONALLY INDEPENDENT PROGRAMS PROVIDE DIRECT DIGITAL CONTROL IN THE FORM OF ANALOG OR DIGITAL OUTPUTS TO DEVICES IN THE FIELD, SO THAT THE ENTIRE OPERATION FROM REACTOR WARMUP TO 100 PERCENT ELECTRIC POWER OUTPUT IS DONE WITHOUT OPERATOR INTERVENTION. THE MAJORITY OF THE ALARM ANNUNCIATION REQUIREMENTS FOR THE GENERATING UNIT ARE HANDLED BY THE CONTROL COMPUTERS UTILIZING HIGH-SPEED PRINTERS AND CATHODE-RAY TUBE DISPLAYS. AN EXTENSIVE OPERATOR INTERACTIVE GRAPHICAL DISPLAY SYSTEM, WHICH HAS REDUCED THE CONGESTION OF CONTROL-PANEL INSTRUMENTATION, HAS BEEN INCORPORATED IN THE UNIT'S DIGITAL CONTROL COMPUTER SYSTEM.
- 15-6-3-702 A SURVEY OF APPLIED INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER REACTOR CONTAINMENTS
TUXEN-MEYER, P.
AB ATOMENERGI, SWEDISH ATOMIC ENERGY ESTABLISHMENT
THIS ARTICLE SUMMARIZES DATA RELATED TO THE INSTRUMENTATION, TESTING PRACTICES, AND MONITORING PROCEDURES FOR BOILING AND PRESSURIZED WATER REACTOR CONTAINMENT ATMOSPHERES. QUESTIONNAIRES WERE SENT TO A REPRESENTATIVE SELECTION OF REACTOR INSTALLATIONS IN THE UNITED STATES, WEST GERMANY, AND SWEDEN WHICH HAD EITHER RECENTLY STARTED OPERATION OR WERE STILL UNDER CONSTRUCTION. COMPILATION OF THE ANSWERS IN TABULAR FORM REVEALED SURPRISING DIFFERENCES BETWEEN THE DIFFERENT INSTRUMENT ARRAYS IN REGARD TO THE DESIGN CRITERIA EMPLOYED. THE SURVEY INDICATES THAT FURTHER INFORMATION REGARDING INSTRUMENTATION PHILOSOPHY IS NEEDED.
- 15-6-4-711 ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT LOW CONCENTRATIONS
BELLAMY, R. R.
U. S. ATOMIC ENERGY COMMISSION.
THE CAPABILITY OF ACTIVATED CHARCOAL TO ADSORB ELEMENTAL IODINE AND METHYL IODIDE AT LOW CONCENTRATIONS HAS BEEN EXPERIMENTALLY EVALUATED TO OBSERVE THE EFFECT OF THE VARIATION OF CERTAIN OPERATING PARAMETERS WITHIN SPECIFIED LIMITS. THE OPERATING PARAMETERS INCLUDE INLET CONCENTRATION, SUPERFICIAL VELOCITY, RELATIVE HUMIDITY, TYPE OF CHARCOAL AND IMPREGNANT, CHARCOAL MESH SIZE, DURATION OF TEST, AND BED DEPTH. THE DATA OBTAINED IN AN INTENSIVE STUDY OF THESE PARAMETERS HAVE BEEN CORRELATED ASSUMING A TWO-STEP ADSORPTION MECHANISM FOR RADIOIODINE ON ACTIVATED CHARCOAL. THE CORRELATION IS PRESENTED TO AID THE NUCLEAR INDUSTRY IN DESIGNING CHARCOAL ADSORBER SYSTEMS FOR RADIOIODINE RETENTION.
- 15-6-4-723 THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY FLATS PLANT II.
SCHUSKE, C. L. + MCCARTHY, J. O.
DOW CHEMICAL COMPANY, GOLDEN, COLO.
THIS IS THE SECOND PART OF A TWO PART ARTICLE ON THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S PRODUCTION AND RESEARCH COMPLEX AT ROCKY FLATS, GOLDEN, COLO. PART I (NUCL. SAFETY, 15(5)) DESCRIBED THE ADMINISTRATIVE AND CONTROL ASPECTS OF THE PROGRAM. PART II DISCUSSES THE EXPERIMENTAL AND COMPUTATIONAL PROGRAMS. THESE PROGRAMS HAVE CONTRIBUTED DATA ON THE CRITICALITY PARAMETERS NEEDED IN THE DESIGN OF NEW EQUIPMENT AND FACILITIES, AS WELL AS THE EVALUATION OF EXISTING FACILITIES. THESE DATA HAVE RESULTED IN UNIQUE EQUIPMENT DESIGNS, SUCH AS METAL MELTING CRUCIBLES AND STORAGE FACILITIES IN WHICH DOUBLING AND TRIPLING OF PROCESS BATCHES NOT PREVIOUSLY PERMITTED HAVE BEEN SAFELY ACCOMPLISHED. THESE

INNOVATIONS HAVE CONSEQUENTLY LED TO MONETARY SAVINGS IN HANDLING OF FISSIONABLE MATERIALS.

15-6-5-732 BIOLOGICAL EFFECTS OF NOBLE GASES (A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS)

ROWNER, P. S. + BARTON, C. J.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE NOBLE GASES SYMPOSIUM HELD IN LAS VEGAS, NEV., SEPT. 24 TO 28, 1973, COVERED ALL IMPORTANT ASPECTS OF THIS TOPIC, INCLUDING THE BIOLOGICAL EFFECTS CONSIDERED HERE. SEPARATE SESSIONS WERE DEVOTED TO THE BIOLOGICAL EFFECTS OF RADON AND OF THE OTHER NOBLE GASES, BUT SPECIAL ATTENTION WAS FOCUSED ON KRYPTON-85, THE LONGEST-LIVED NOBLE GAS RELEASED FROM NUCLEAR FACILITIES, PRINCIPALLY FUEL REPROCESSING PLANTS. THE COST BENEFIT ASPECT OF LIMITING EXPOSURE OF THE WORLD POPULATION TO LOW CONCENTRATIONS OF THIS RADIOISOTOPE WAS DISCUSSED EXTENSIVELY DURING THE SYMPOSIUM. THE MAJORITY OF THE PARTICIPANTS FELT THAT EFFECTIVE CONTROLS ON LARGE SCALE EMISSIONS OF KRYPTON-85, SUCH AS THOSE FROM FUEL REPROCESSING PLANTS, SHOULD BE INSTITUTED AS SOON AS PRACTICABLE SO AS TO MINIMIZE POSSIBLE GENETIC EFFECTS FROM THIS MAN MADE RADIOACTIVITY.

15-6-6-738 U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

STATISTICAL INFORMATION CONCERNING NUCLEAR POWER PLANT AVAILABILITY, PLANT CAPACITY, AND REACTOR AVAILABILITY FACTORS FOR 1973 WAS COMPILED FROM SEMIANNUAL REPORTS SUBMITTED TO THE U.S. ATOMIC ENERGY COMMISSION (AEC). STATISTICS SHOWED THAT PLANT AVAILABILITY DURING 1973 WAS SLIGHTLY LOWER THAN THAT REPORTED FOR 1972. A PREVIOUS OBSERVATION CONCERNING ATTAINMENT OF, AND CONTINUED PERFORMANCE AT, 80 PERCENT AVAILABILITY AFTER 3 TO 4 YEARS' OPERATION WAS NOT SUBSTANTIATED BY EXPERIENCE DURING 1973 BECAUSE OF EXTENSIVE OUTAGES AT A FEW PLANTS THAT STRONGLY INFLUENCED THE AVERAGES FOR THE SMALL NUMBER OF PLANTS THAT HAVE BEEN IN OPERATION FOR 3 YEARS OR MORE. HOWEVER, PLANT AVAILABILITY AND CAPACITY FACTORS FOR NUCLEAR POWER PLANTS ARE COMPARABLE TO THOSE REPORTED ELSEWHERE FOR FOSSIL FUELED POWER PLANTS OF COMPARABLE SIZES AND AGES.

16-1-1-1 AEC WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER PLANT SITES
BUCHANAN, J. R.

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE REVIEWS A PROPOSED REGULATORY GUIDE, POPULATION DISTRIBUTION AROUND NUCLEAR POWER PLANTS, WHICH THE AEC CONSIDERED ISSUING TO PROVIDE GUIDANCE ON ACCEPTABLE POPULATION CHARACTERISTICS FOR A NUCLEAR REACTOR SITE. THE PROPOSED AEC GUIDE INVOLVED CUMULATIVE POPULATION PROJECTIONS WITHIN 5, 20, AND 40 MILES OF THE SITE. TWO TECHNIQUES FOR EVALUATING POPULATION DISTRIBUTIONS AROUND SITES ARE ALSO DISCUSSED. THE FIRST TECHNIQUE IS THE USE OF AN UNWEIGHTED CUMULATIVE POPULATION VS. DISTANCE. THE SECOND TECHNIQUE IS CALLED A SITE POPULATION FACTOR FOR THE PURPOSE OF COMPARING SITES, AND THIS TECHNIQUE WEIGHS POPULATION AT LONGER DISTANCES LESS THAN THE POPULATION ADJACENT TO A SITE. THE AEC IS CONTINUING WORK ON THESE POTENTIAL TOOLS. ALL PRESENTLY APPROVED SITES HAVE BEEN FOUND TO BE ACCEPTABLE IN TERMS OF POPULATION DENSITY AS WELL AS BY OTHER CONSIDERATIONS.

16-1-1-8 WATER REACTOR SAFETY RESEARCH INFORMATION MEETING
COTTRELL, W. B. + HOBSON, D. O. + WHITMAN, G. D.

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE IS A REVIEW OF THE SECOND WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE AEC DIVISION OF REACTOR SAFETY RESEARCH, HELD AT AEC HEADQUARTERS, GERMANTOWN, MD., SEPT. 19-20, 1974. THIS MEETING, ALTHOUGH SIMILAR IN SCOPE TO THE FIRST MEETING, WAS ORGANIZED SOMEWHAT DIFFERENTLY IN THAT THERE WERE ONLY FOUR TECHNICAL SESSIONS, WITH PARALLEL SESSIONS ON BOTH DAYS. THE TECHNICAL SESSIONS WERE (1) LOSS OF COOLANT ACCIDENT (LOCA) TEST PROGRAM, (2) FUEL BEHAVIOR PROGRAM, (3) PRIMARY SYSTEM INTEGRITY PROGRAM, AND (4) CODE DEVELOPMENT PROGRAM. OVER 275 PERSONS, INCLUDING SEVERAL FOREIGN REPRESENTATIVES, ATTENDED THE MEETING, BUT NO PROCEEDINGS ARE PLANNED. IT IS APPARENT FROM THE QUANTITY AND QUALITY OF THE TECHNICAL ACHIEVEMENTS REPORTED AT THE MEETING THAT THE CHANGES IN EXPERIMENTAL PROGRAMS, INCLUDING CONSTRUCTION AND/OR MODIFICATIONS OF FACILITIES WHICH SO DOMINATED THE TALKS AT THE FIRST MEETING, ARE BEGINNING TO PRODUCE RESULTS. BRIEF SUMMARIES OF MANY PRESENTATIONS ARE INCLUDED.

16-1-2-29 BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILING SYSTEMS

BERGLES, A. E.

IOWA STATE UNIVERSITY, IOWA CITY, IA.

RECENT EXPERIMENTAL AND ANALYTICAL DEVELOPMENTS IN POOL BOILING BURNOUT ARE REVIEWED, AND RESULTS ARE SUMMARIZED THAT CLARIFY THE DEPENDENCE OF CRITICAL HEAT FLUX ON HEATER GEOMETRY AND FLUID PROPERTIES. NEW ANALYTICAL INTERPRETATIONS OF BURNOUT ARE DISCUSSED, AND THE EFFECTS OF SURFACE CONDITION, AGING, ACCELERATION, AND TRANSIENT HEATING (OR COOLING) ARE DESCRIBED. AUGMENTATION OF CRITICAL HEAT FLUX, THE RELATION OF SOUND TO

BURNOUT, AND NEW TECHNIQUES FOR STABILIZING ELECTRIC HEATERS AT BURNOUT ARE ALSO CONSIDERED.

- 16-1-4-43 **RADIOISOTOPE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTIONS I. PRODUCTION**
 ERDMAN, C. A. + REYNOLDS, A. B.
 UNIVERSITY OF VIRGINIA, CHARLOTTESVILLE, VA.
 THIS ARTICLE, PRESENTED IN TWO PARTS, REVIEWS THE BEHAVIOR OF RADIOISOTOPES PRODUCED DURING THE NORMAL OPERATION OF A LIQUID METAL COOLED FAST BREEDER REACTOR (LMFBR). THE RESULTS GIVEN ARE PRIMARILY FROM THE LITERATURE, BUT SEVERAL INDEPENDENT CALCULATIONS ARE INCLUDED. NUMERICAL RESULTS ARE NORMALIZED TO A 1000-MW(E) LMFBR AND ARE COMPARED WITH A SIMILAR SIZE LIGHT WATER REACTOR. SOURCES OF RADIOACTIVITY STUDIED INCLUDE PLUTONIUM AND OTHER TRANSURANIC ELEMENTS, FISSION PRODUCTS, TRITIUM, CORROSION PRODUCTS, ACTIVATION PRODUCTS, AND TRAMP FUEL. THE REVIEW ALSO INCLUDES DATA ON RADIOACTIVITY TAKEN FROM THE OPERATING EXPERIENCES OF LMFBRs. DATA ARE INCLUDED FOR THE FAST REACTORS EBR-II, FERM1, SEFOR, DOWNEY, RAPSCOE, AND BR-5, WITH LIMITED DATA FOR THE THERMAL REACTORS SRE, SREB, AND MALLAM. THIS ARTICLE (PART I) DISCUSSES THE PRODUCTION OF RADIOACTIVITY, PART 2, SCHEDULED FOR NUCLEAR SAFETY, 1613), WILL DISCUSS THE TRANSPORT OF RADIOACTIVITY.
- 16-1-5-60 **THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS I. AEC OWNED FACILITIES**
 BILES, M. B. + COFFMAN, F. E.
 ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D. C.
 PROGRAMS FOR MONITORING AND REPORTING OF RADIOACTIVITY IN EFFLUENTS ARE MAINTAINED AT ALL U.S. ATOMIC ENERGY COMMISSION (AEC) FACILITIES DISCHARGING CONCENTRATIONS OF RADIOACTIVITY THAT HAVE POTENTIAL HEALTH AND SAFETY OR ENVIRONMENTAL SIGNIFICANCE. TO ENSURE THE EFFECTIVE MANAGEMENT AND CONTROL OF EFFLUENTS IS THE OBJECTIVE OF THESE PROGRAMS. THE NATURE AND QUANTITIES OF RADIOACTIVITY DISCHARGED TO THE ENVIRONMENT VARY WIDELY FROM SITE TO SITE, PRIMARILY OWING TO THE WIDE VARIETY OF OPERATIONS AND FACILITIES. EFFLUENT CONTROL PROGRAMS AT AEC SITES ARE PRIMARILY BASED ON GUIDANCE PROMULGATED BY THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION, THE NATIONAL COUNCIL ON RADIATION PROTECTION, AND THE FEDERAL RADIATION COUNCIL. TO MAINTAIN AN OVERVIEW OF ITS EFFLUENT CONTROL PRACTICES, THE AEC HAS DEVELOPED AND INSTITUTED A COMPUTER BASED ANNUAL EFFLUENT DATA REPORTING SYSTEM TO ENSURE THAT EFFLUENT CONTROL PROGRAMS ARE PROPERLY MAINTAINED. THIS SYSTEM HAS PROVED TO BE A VERY USEFUL INTERNAL MANAGEMENT TOOL FOR EVALUATING THE EFFECTIVENESS OF EFFLUENT CONTROL PROGRAMS AND FOR IDENTIFYING POTENTIAL PROBLEM AREAS. AN EFFLUENT REDUCTION PROGRAM THAT FOCUSES ON THE REDUCTION OF QUANTITIES RATHER THAN CONCENTRATIONS OF RADIOACTIVITY HAS RESULTED IN SUBSTANTIAL REDUCTIONS IN QUANTITIES OF RADIOACTIVITY RELEASED FROM SELECTED FACILITIES.
- 16-1-5-71 **THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. AEC LICENSED FACILITIES**
 HIGGINBOTHAM, L. B. + COLLINS, J. T.
 NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C. AND ENVIRONMENTAL CONSULTANTS, INC., DALLAS, TEX.
 PROGRAMS FOR CONTROL AND MONITORING OF RADIOACTIVE EFFLUENTS ARE REQUIRED AT ALL FACILITIES REGULATED BY THE U.S. ATOMIC ENERGY COMMISSION (AEC). LIMITATIONS AND REQUIREMENTS FOR CONTROL AND MONITORING OF RADIOACTIVE EFFLUENTS ARE EXPRESSED IN AEC REGULATIONS ISSUED UNDER TITLE 10, CODE OF FEDERAL REGULATIONS. AEC REGULATIONS AND POLICIES FOR CONTROL OF EXPOSURES FROM RADIATION AND RADIOACTIVE MATERIALS ARE BASED PRIMARILY ON GUIDANCE PROMULGATED BY THE INTERNATIONAL COMMISSION ON RADIATION PROTECTION, THE NATIONAL COUNCIL ON RADIATION PROTECTION, AND THE FEDERAL RADIATION COUNCIL. CONDITIONS IN OPERATING LICENSES ISSUED BY THE AEC REQUIRE APPROPRIATE SURVEILLANCE AND MONITORING PROGRAMS AS A BASIS FOR DEMONSTRATING COMPLIANCE WITH AEC REGULATORY LIMITS FOR THE RELEASE OF RADIOACTIVE EFFLUENTS.
- 16-1-6-76 **INCIDENT AT THE LUCENS REACTOR**
 MILLER, J. M.
 MOLLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.
 THE LUCENS 0.3-MW(E) EXPERIMENTAL NUCLEAR POWER STATION SUFFERED A LOSS OF CARBON DIOXIDE COOLANT AND DEUTERIUM OXIDE MODERATOR, AS WELL AS DAMAGE TO ONE OF ITS FUEL ELEMENTS, ON JAN. 21, 1969. THIS ARTICLE PRESENTS SOME OF THE PRELIMINARY RESULTS OF THE INVESTIGATION AS TO THE CAUSE OF THE INCIDENT. THE FINAL RESULTS HAVE NOT BEEN PUBLISHED.
- 16-1-6-79 **IAEA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS**
 PRYOR, W. A.
 ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, OAK RIDGE, TENN.
 A SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS WAS HELD OCT. 8-12, 1973, AT THE INTERNATIONAL ATOMIC ENERGY AGENCY IN VIENNA. THERE WERE 140 PARTICIPANTS FROM 35 COUNTRIES AND 4 INTERNATIONAL ORGANIZATIONS, AND 45 PAPERS WERE PRESENTED. IN ADDITION TO THE FOUR SESSIONS DEVOTED TO REVIEWS OF GENERAL OPERATING EXPERIENCE, THE MEETING INCLUDED SESSIONS ON BEHAVIOR OF MAJOR COMPONENTS, WASTE MANAGEMENT SYSTEMS, FUELING EXPERIENCE, TESTING, AND PERSONNEL TRAINING. THIS ARTICLE REVIEWS THE EXPERIENCES DESCRIBED IN THE FORMAL PAPERS AND IN THE PANEL DISCUSSION.

- 16-2-1-127 QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER PLANTS
BERNSEN, S. A.
BECHTEL POWER CORPORATION, SAN FRANCISCO, CALIF.
THIS ARTICLE IS A GENERAL SURVEY OF QUALITY ASSURANCE (QA) PRACTICES AS THEY RELATE TO THE CONSTRUCTION PHASE OF NUCLEAR POWER PLANTS. THE ARTICLE BRIEFLY OUTLINES THE EVOLUTION OF CONSTRUCTION QA REQUIREMENTS, DESCRIBES CONSTRUCTION PRACTICES AND ORGANIZATIONAL RELATIONS THAT HELP IDENTIFY THE UNIQUE CONSTRUCTION PHASE FEATURES THAT AFFECT QA PRACTICES, IDENTIFIES SOME OF THE PRINCIPAL REQUIREMENTS AND PROGRAMMATIC PROBLEMS INVOLVING CONSTRUCTION, AND DISCUSSES POTENTIAL TRENDS AND SUGGESTED GUIDELINES FOR THE IMPLEMENTATION OF PARTICULAR PRACTICES.
- 16-2-1-141 1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY
FONTANA, M. H.
MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE IS A BRIEF REVIEW OF THE AMERICAN NUCLEAR SOCIETY TOPICAL MEETING ON FAST REACTOR SAFETY, HELD AT BEVERLY HILLS, CALIF., APR. 2-4, 1974, SPONSORED BY THE TECHNICAL GROUP ON REACTOR SAFETY AND THE LOS ANGELES SECTION OF THE AMERICAN NUCLEAR SOCIETY. PRESENTATIONS AND DISCUSSIONS ON SAFETY PHILOSOPHY, RESEARCH NEEDS, AND SAFETY PHENOMENOLOGY INDICATE STEADY PROGRESS TOWARD UNDERSTANDING THE TECHNICAL BASES OF FAST REACTOR SAFETY, ALTHOUGH DIFFERENCES OF OPINION APPEAR TO EXIST WITH RESPECT TO PHILOSOPHY OF APPLICATION TO REACTOR DESIGNS.
- 16-2-3-150 GBR-4 PROTECTION SYSTEMS - FAILURES AND THEIR CONSEQUENCES
BURGMULLER, P. + DERAIS, J. J. + KRAHE, A.
PIGNATELLI, A. + VIEIDER, G.
GAS BREEDER REACTOR ASSOCIATION, BRUSSELS, BELGIUM
IN THE GBR-4 DESIGN OF A GAS COOLED FAST BREEDER REACTOR, EMPHASIS IS PLACED ON USING TO ADVANTAGE THE SINGLE PHASE CHARACTER OF THE COOLANT. SPECIFIC FEATURES OF THE PROTECTIVE SYSTEMS ARE FAIL-SAFE NEUTRON ADSORPTION, PERMANENTLY OPERATING AUXILIARY SUPPLIES, AND ATMOSPHERIC PRESSURE COOLING. A COMPUTER PROGRAM THAT USES A POINT REACTOR MODEL FOR HEAT TRANSFER AND NEUTRON KINETICS IS USED FOR TRANSIENT ANALYSIS, AND A STEAM GENERATOR DYNAMICS CODE IS USED TO DESCRIBE SECONDARY SIDE EFFECTS. ANTICIPATED DISTURBANCES IN OPERATION ARE REACTIVITY INSERTION, LOSS OF SUPPLIES, AND LOSS OF COOLANT PRESSURE. FAILURES IN REACTOR PROTECTION SYSTEMS ARE POSTULATED FOR THESE DISTURBANCES IN DECREASING ORDER OF PROBABILITY, AND THE CONSEQUENCES ARE ANALYZED AND DISCUSSED. THE RESULTS LEAD TO THE CONCLUSION THAT, DUE TO THE INHERENT CHARACTERISTICS OF THE SYSTEM AND TO THE SPECIFIC DESIGN, OCCURRENCES ARE WELL WITHIN THE LIMITS OF A TYPICAL PROBABILITY RELEASE CRITERION.
- 16-2-3-162 STANDBY EMERGENCY POWER SYSTEMS. II. THE LATER PLANTS
HAGEN, E. W.
MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS IS THE SECOND PART OF A TWO-PART ARTICLE THAT REVIEWS THE STANDBY EMERGENCY ELECTRIC POWER SYSTEMS FOR COMMERCIAL NUCLEAR POWER PLANTS. PART I APPEARED IN THE 14(3) ISSUE OF NUCLEAR SAFETY AND DISCUSSED THESE SYSTEMS AS THEY APPLIED TO THE EARLY PLANTS. PART 2, THE LATER PLANTS, UPDATES THE DESIGN CRITERIA AND CONSIDERATIONS SET FORTH IN PART I AND OFFERS SOME SUGGESTIONS FOR IMPROVING RELIABILITY AND AVAILABILITY FOR THESE SYSTEMS. TODAY, EVEN WITHIN THE CONFINES OF A SINGLE LARGE UTILITY, THE SYSTEM DESIGNS VARY BECAUSE OF THE DIFFERENT ARCHITECT ENGINEERS INVOLVED WITH THE VARIOUS PLANTS. PLANT CHARACTERISTICS VARY FROM SITE TO SITE, AND EVEN CONCEPTS CHANGE WITH TIME WITHIN A GIVEN DESIGN GROUP. SOME OF THE DESIGN PROBLEMS AND OPERATING EXPERIENCES FOR THE FOLLOW-ON PLANTS ARE EXEMPLIFIED, QUALITY ASSURANCE PROCEDURES ARE MENTIONED, AND SOME CONSIDERATIONS CONCERNING RELIABILITY, WHICH HAS NOT CHANGED SIGNIFICANTLY FOR THE LATER PLANTS, ARE DISCUSSED. SINCE HIGH AVAILABILITY OF THE STANDBY EMERGENCY ELECTRIC POWER SYSTEMS APPEARS TO BE THE MORE ATTAINABLE CHARACTERISTIC TO STRIVE FOR, SOME METHODS FOR ACHIEVING THIS ARE PROFFERED.
- 16-2-4-180 RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WASTE
MANSTRA, J.
REACTOR CENTRUM NEDERLAND, THE HAGUE, NETHERLANDS
THIS ARTICLE REVIEWS THE RADIOTOXIC HAZARDS RESULTING FROM THE DISPOSAL OF HIGH LEVEL REPROCESSING WASTES INTO A DEEP GEOLOGICAL FORMATION. THE TERM RADIOTOXIC HAZARD MEASURE (RHM), USED TO MEASURE THE HAZARD FROM BURIED RADIOACTIVE WASTES, IS BASED ON THE MAXIMUM RADIONUCLIDE CONCENTRATION PERMISSIBLE IN WATER. CALCULATIONS ARE MADE OF THE RHM LEVELS FOR THE HIGH LEVEL REPROCESSING WASTES OF BOTH LIGHT WATER REACTOR AND FAST BREEDER REACTOR FUELS. IN COMPARING THESE RHM LEVELS WITH THAT FOR THE NATURAL ACTIVITY OF AN EQUIVALENT AMOUNT OF URANIUM ORE AND ITS MILL TAILINGS, IT IS CONCLUDED THAT AN ACTUAL ADDITIONAL RADIOTOXIC HAZARD FOR BURIED HIGH LEVEL REPROCESSING WASTE ONLY EXISTS FOR THE FIRST 300 TO 500 YEARS AFTER BURIAL.

16-2-4-190

THE THIRTEENTH AEC AIR CLEANING CONFERENCE

MOELLER, D. W. * UNDERHILL, D. W. * FIRST, M. W.
HARVARD UNIVERSITY, CAMBRIDGE, MASS.

THE THIRTEENTH AEC AIR CLEANING CONFERENCE WAS HELD AUG. 12-15, 1975, IN SAN FRANCISCO, CALIF. A TOTAL OF 374 PEOPLE REGISTERED, INCLUDING PERSONNEL FROM ESSENTIALLY ALL FACETS OF INDUSTRY, GOVERNMENTAL AGENCIES, AND EDUCATIONAL INSTITUTIONS, PLUS REPRESENTATIVES FROM NINE FOREIGN COUNTRIES. MAJOR TOPICS WERE 1) PERFORMANCE AND RELIABILITY OF AIR CLEANING SYSTEMS 2) ADSORPTION, CONCENTRATION, AND STORAGE OF RADIOACTIVE NOBLE GASES 3) DESIGN, CONSTRUCTION, AND OPERATION OF REACTOR OFF-GAS TREATMENT SYSTEMS 4) DESIGN, TESTING, AND OPERATION OF VENTILATION SYSTEMS FOR REACTORS 5) PLUTONIUM HANDLING FACILITIES, AND FUEL REPROCESSING OPERATIONS 6) SAMPLING AND MONITORING OF AIRBORNE RELEASES, AND 7) CONTROL OF FIRES AND EXPLOSIONS. SUPPLEMENTARY SESSIONS COVERED SPECIAL PROBLEMS ASSOCIATED WITH MANAGING RADIOIODINE AND TRITIUM. A MAJOR DEFICIENCY BROUGHT OUT AT THE CONFERENCE WAS THE CONTINUED LACK OF ATTENTION BEING GIVEN TO AIR CLEANING SYSTEMS, PARTICULARLY IN THE PLANNING STAGES OF NUCLEAR FACILITIES. THERE IS A SIMILAR LACK OF ATTENTION TO THE NEEDS OF THOSE RESPONSIBLE FOR PREOPERATIONAL AND POSTOPERATIONAL TESTING OF SUCH SYSTEMS AFTER INSTALLATION. ON THE POSITIVE SIDE, THE CONFERENCE REVEALED THAT PROGRESS IS BEING MADE ON DEVELOPING PROCESSES FOR TRITIUM REMOVAL, ON CONCENTRATION AND STORAGE PROCEDURES FOR THE NOBLE GASES, AND ON METHODS FOR HANDLING AIR CLEANING PROBLEMS OF HIGH TEMPERATURE GAS COOLED REACTORS AND LIQUID METAL COOLED FAST BREEDER REACTORS. A MAJOR EFFORT IS ALSO BEING DIRECTED TO THE POTENTIAL AIR CLEANING PROBLEMS ASSOCIATED WITH NUCLEAR FUSION.

16-2-5-204

ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACILITIES IN NEW YORK STATE

TERPILAK, M. S. * JORGENSEN, B. L.

ENVIRONMENTAL PROTECTION AGENCY, NEW YORK CITY, N. Y.

THE ANNUAL QUANTITIES AND TYPES OF RADIOACTIVE MATERIALS RELEASED FROM THREE OPERATING NUCLEAR ELECTRIC GENERATING FACILITIES AND A NUCLEAR FUELS REPROCESSING FACILITY ARE PRESENTED AND DISCUSSED. THE PERIOD OF INTEREST SPANS THE YEARS 1969 TO 1972 WITH SOME ADDITIONAL DATA FOR THOSE FACILITIES OPERATING BEFORE 1969. RELEASE QUANTITIES HAVE BEEN WELL CONTROLLED, CONSIDERING THE NATURE AND VINTAGE OF THE OPERATIONS. PRESENTED ARE THE RESULTS OF ENVIRONMENTAL SURVEILLANCE RELYING MOST HEAVILY ON THE ACTIVITIES OF THE NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION. OBSERVATIONS AT INDIAN POINT 1 AND AT NUCLEAR FUEL SERVICES, INC., HAVE LED TO THE DISCOVERY OF SEVERAL FACILITY RELATED RADIOISOTOPES IN ENVIRONMENTAL MEDIA. THESE TWO FACILITIES ARE OF COMPARATIVELY EARLY VINTAGE, HAVE PRODUCED SLIGHTLY LARGER AMOUNTS OF WASTE MATERIALS, AND HAVE BEEN THE SUBJECT OF MORE COMPREHENSIVE STUDIES THAN OTHERS IN THE STATE. DOSE CONSEQUENCES TO HYPOTHETICAL PERSONS AND TO POPULATIONS WITHIN 50 MILES OF THE FACILITIES ARE ADDRESSED. IT SHOULD BE STRESSED THAT ALL INDIVIDUAL DOSES PRESENTED ARE HYPOTHETICAL. DOSES VIA THE DRINKING WATER AND COWS MILK PATHWAYS ARE PARTICULARLY CONSERVATIVE. IN EACH CASE THESE HYPOTHETICAL DOSES ARE AT LEAST AN ORDER OF MAGNITUDE OR MORE GREATER THAN THE KNOWN WORST CASE. NO EXCESSIVE EXPOSURE LEVELS ARE KNOWN TO HAVE EXISTED. ALL OPERATIONS HAVE RESULTED IN POSTULATED EXPOSURE LEVELS WELL WITHIN APPLICABLE REGULATIONS OR GUIDELINES, GENERALLY BEING A SMALL PERCENTAGE OF THESE VALUES. POPULATION DOSES HAVE BEEN SURPRISINGLY CONSISTENT THROUGH THE PERIOD OF INTEREST. THEY ARE INSIGNIFICANT IN COMPARISON TO THE DOSE TO THE POPULATION OF THE STATE FROM NATURAL OR MEDICAL SOURCES.

16-2-6-223

SET-POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RELATED INSTRUMENTATION

NUCLEAR SAFETY STAFF

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

FROM JAN. 1972, TO JUNE 30, 1973, 222 INSTANCES OF SET-POINT DRIFT IN NUCLEAR POWER PLANT PROTECTIVE INSTRUMENTATION DEVICES WERE REPORTED AS ABNORMAL OCCURRENCES BY NUCLEAR POWER PLANT LICENSEES. THIS ARTICLE PRESENTS THE RESULTS OF A STUDY PERFORMED TO ASSESS THE CAUSES AND SIGNIFICANCE OF THESE INCIDENTS.

16-2-6-224

DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER PLANTS

CROOKS, J. L. * VISSING, G. S.

U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.

AVAILABLE TEST AND OPERATING EXPERIENCE DATA ARE PROVIDED FOR DIESEL GENERATOR UNITS INSTALLED AS STANDBY ELECTRIC POWER SUPPLIES IN OPERATING NUCLEAR POWER PLANTS. THE DATA INCLUDE FAILURES EXPERIENCED DURING PERIODIC SURVEILLANCE TESTS AND DURING ABNORMAL EVENTS IN WHICH THE STANDBY POWER SYSTEM WAS REQUIRED TO OPERATE AUTOMATICALLY. THE DIESEL GENERATOR FAILURES EXPERIENCED DURING SURVEILLANCE TESTING OF THE UNITS ARE TABULATED FOR EACH OPERATING NUCLEAR PLANT AND ARE CLASSIFIED BY MANUFACTURER, BY THE ELECTRICAL CAPACITY OR SIZE OF THE DIESEL-GENERATOR UNIT, AND BY THE COMPONENT OR SUBSYSTEM INITIATING THE FAILURE. THE PROBABILITY OF SUCCESSFUL PERFORMANCE COMPUTED FROM THESE SURVEILLANCE TEST DATA IS LESS THAN 0.95 AT A CONFIDENCE LEVEL OF 90 PERCENT FOR MOST UNITS.

- 16-3-1-273 REVIEW OF AHS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING
PERLLE, E. + BAUMAN, H.
MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.
THE AMERICAN NUCLEAR SOCIETY TOPICAL MEETING ON NUCLEAR POWER PLANT SITING, HELD IN PORTLAND, OREG., AUG. 25-28, 1974, INCLUDED SESSIONS DEVOTED TO THE GOVERNMENT AND SITING, METHODOLOGIES OF SITE SELECTION, SPECIAL AND TECHNICAL ISSUES, UTILITY SITING EXPERIENCE, AND SOCIAL AND PUBLIC ACCEPTANCE ISSUES. HIGHLIGHTS OF THE MEETING INCLUDED SPEECHES BY AEC CHAIRMAN DIXY LEE RAY, MICHAEL MCCLOSKEY OF THE SIERRA CLUB, AND SAM LEVINE OF THE AEC PROBABILISTIC RISK STUDY TEAM. UTILITIES' PROBLEMS AND PRACTICES IN SITING NUCLEAR POWER PLANTS WERE DISCUSSED BY FOUR AMERICANS, AS WELL AS REPRESENTATIVES OF FRENCH AND SWISS UTILITIES. THE LACK OF WHOLLY SUITABLE SITES AND CONCERN WITH PUBLIC ACCEPTANCE WERE COMMON THEMES ADDRESSED IN WIDELY DIFFERENT MANNERS. INSTITUTIONAL CHANGES IN SITING PROCEDURES AND APPROACHES WERE SUGGESTED IN BOTH THE FIRST SESSION ON GOVERNMENTAL ROLES AND THE FINAL SESSION ON SOCIAL ISSUES.
- 16-3-1-282 NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITING
COPE, D. F.
MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN. + FEDERAL ENERGY ADMINISTRATION, WASHINGTON, D. C.
MEETING THE NATION'S FUTURE ENERGY REQUIREMENTS PORTENDS A MAJOR ROLE FOR NUCLEAR POWER. THIS COULD RESULT IN HUNDREDS OF RELATIVELY SMALL, DISPERSED NUCLEAR SITES THROUGHOUT THE COUNTRY BY THE YEAR 2000 IF PRESENT SITING TRENDS WERE TO CONTINUE. THE SITING OF SEVERAL NUCLEAR REACTORS AND THEIR ASSOCIATED FACILITIES IN A SMALL NUMBER OF CONCENTRATED NUCLEAR ENERGY CENTERS IS AN ALTERNATIVE HAVING MANY ADVANTAGES. THIS ARTICLE DESCRIBES THE BACKGROUND OF THE IDEA AND DISCUSSES SOME OF THE ADVANTAGES AND PROBLEMS IN CLUSTERING NUCLEAR REACTORS INTO NUCLEAR ENERGY CENTERS. IT CONCLUDES THAT THERE ARE COMPELLING ARGUMENTS FOR THE NATIONAL DEPLOYMENT OF NUCLEAR ENERGY, PARTICULARLY BREEDER REACTORS, INTO SUCH CENTERS BUT NOTES THAT THERE ARE MANY UNRESOLVED ISSUES ON WHICH MUCH WORK MUST BE DONE BEFORE FINAL ANSWERS ARE AVAILABLE AS TO THE SIZE, COMPOSITION, AND EXTENT TO WHICH THE ENERGY CENTER CONCEPT CAN BE APPLIED.
- 16-3-2-291 PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL COOLED FAST BREEDER REACTOR FUEL SUBASSEMBLIES
VAN ERF, J. B. + CHAMLA, T. C. + WILSON, R. E.
FAUSKE, M. K.
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
THIS ARTICLE IS A REVIEW OF RECENT EXPERIMENTAL AND ANALYTICAL WORK PERFORMED WITH THE OBJECTIVE OF EVALUATING THE POTENTIAL FOR PIN-TO-PIN FAILURE PROPAGATION WITHIN FUEL SUBASSEMBLIES OF LIQUID METAL COOLED FAST BREEDER REACTORS (LMFBR) OF CURRENT DESIGN. IT IS CONCLUDED THAT (1) PIN-TO-PIN FUEL-FAILURE PROPAGATION FOR CURRENT LMFBR DESIGNS IS UNLIKELY, AND (2) IF FAILURE PROPAGATION OCCURS AT ALL, IT WILL BE SELF-LIMITING OR ITS PROGRESSION WILL BE SLOW, THUS ALLOWING AMPLE TIME FOR DETECTION AND CORRECTIVE ACTION IF APPROPRIATE INSTRUMENT SYSTEMS ARE PROVIDED.
- 16-3-3-308 THE 1974 SPECIALISTS MEETING ON REACTOR NOISE
THIE, J. A.
CONSULTANT, BARRINGTON, ILL.
AN INTERNATIONAL MEETING OF SPECIALISTS ON REACTOR NOISE WAS HELD IN ROME, ITALY, OCT. 21-25, 1974. THEORETICAL AND EXPERIMENTAL PAPERS TREATED BOTH ZERO POWER AND POWER REACTORS FOR ALL MAJOR REACTOR TYPES. SIXTEEN DIFFERENT CATEGORIES OF NOISE-ANALYSIS PRACTICAL APPLICATIONS, MOSTLY IN POWER REACTORS, WERE IDENTIFIED FROM THE 46 PAPERS PRESENTED. ABOUT A THIRD OF THESE CATEGORIES ARE NEW SINCE THE LAST INTERNATIONAL CONFERENCE ON NOISE WAS HELD IN 1968. A DEPTH OF UNDERSTANDING OF ZERO POWER NOISE WAS EXHIBITED, AND IN A FEW OF THE MANY CATEGORIES OF POWER REACTOR NOISE, GOOD EXPERIMENTAL AND THEORETICAL UNDERSTANDINGS WERE PROJECTED.
- 16-3-3-316 QUANTIFICATION OF MAN - MACHINE SYSTEM RELIABILITY IN PROCESS CONTROL
FRANK P. LEES
LOUGHBOROUGH UNIVERSITY OF TECHNOLOGY, ENGLAND
AUTHORITATIVE DISCOURSES ON THE SUBJECT OF HUMAN RELIABILITY IN CONTROL SYSTEMS ARE AVAILABLE IN JOURNALS DEVOTED TO ERGONOMICS, CYBERNETICS, AND HUMAN FACTORS. HOWEVER, THE SUBJECT IS ALSO OF PRIME INTEREST TO OPERATION IN THE NUCLEAR INDUSTRY THEREFORE AN OVERVIEW OF THE SUBJECT OF OPERATOR RELIABILITY IS PRESENTED BY BOTH A DIGEST OF A PREVIOUSLY PUBLISHED PAPER AND AN ADDED SHORT BIBLIOGRAPHY.
- 16-3-4-318 RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPORT
ERDMAN, C. A. + KELLY, J. L. + REYNOLDS, A. B.
UNIVERSITY OF VIRGINIA, CHARLOTTESVILLE, VA.
THIS IS THE SECOND PART OF A TWO PART ARTICLE ON RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF A LIQUID-METAL-COOLED FAST BREEDER REACTOR (LMFBR). PART 1, INCLUDED IN NUCLEAR SAFETY 16(1), DISCUSSED THE PRODUCTION OF RADIOACTIVITY. PART 2 REVIEWS THE TRANSPORT OF THE VARIOUS RADIONUCLIDES. ALTHOUGH RELIANCE WAS PLACED ON PUBLISHED RESULTS FOR BOTH PARTS, SOME

NEW CALCULATIONS WERE MADE WHERE NEEDED. RESULTS WERE NORMALIZED TO A 1000-MW(e) LWR AND COMPARED WITH VALUES FOR A LIGHT WATER REACTOR (LWR). THIS REVIEW INCLUDES THE TRANSPORT OF TRITIUM AND CORROSION PRODUCTS, TRANSPORT OF FISSION PRODUCTS FROM FAILED FUEL, BEHAVIOR OF RADIOACTIVITY IN SODIUM AND COLD TRAPS, AND OPERATION OF GASEOUS RADWASTE SYSTEMS. OPERATING EXPERIENCES ARE REVIEWED FOR THE FAST REACTORS EBR-II, FERMI, SEFOR, OCEANWAY, RAPISOGIE, AND BR-5. LIMITED DATA ARE GIVEN FOR THE THERMAL REACTORS SRE, SBER, AND MALLAM.

- 16-3-5-337 KINETICS EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMENA
SKRABAL, K. + FRENCH, C. + CHABOT, G. + MAJON, A.
WRO, K.

LOWELL TECHNOLOGICAL INSTITUTE, LOWELL, MASS.

THIS ARTICLE DESCRIBES A GENERAL EQUATION FOR THE KINETICS OF SERIALY RELATED QUANTITIES LINKED BY LINEAR FIRST-ORDER PRODUCTION AND DESTRUCTION PHENOMENA. THE EQUATION IS APPLICABLE TO SYSTEMS OF CONCERN IN NUCLEAR AND RADIOLOGICAL SCIENCES AND HEALTH PHYSICS. SUGGESTED APPLICATIONS INCLUDE (1) THE SERIAL TRANSFORMATION OF RADIONUCLIDES, (2) THE COLLECTION AND ANALYSIS OF SERIALY RELATED AIRBORNE RADIOACTIVE PARTICULATES, (3) THE INVENTORY OF QUANTITIES IN THE CORE OF A NUCLEAR REACTOR, SUCH AS FISSION PRODUCTS, POISONS, FISSION ELEMENTS, AND TRANSURANUM ELEMENTS, (4) INTERNAL DOSIMETRY, SUCH AS THE BURDEN OF RADIONUCLIDES IN THE VARIOUS SEGMENTS OF THE GASTROINTESTINAL TRACT AND RESULTING DOSES FOR SINGLE OR CONTINUOUS INTAKES OF PARENT AS WELL AS DAUGHTER RADIONUCLIDES, (5) THE QUANTITY OF AIRBORNE RADIOACTIVE AEROSOLS GENERATED IN A VENTILATED SPACE THROUGH THE DECAY OF PARENT INERT RADIOACTIVE GASES, SUCH AS RADON, THORON, XENON, AND KRYPTON, AND (6) THE CALCULATION OF ROUTINE AND ACCIDENTAL RELEASES FROM NUCLEAR PLANTS.

- 16-3-5-345 THE ERDA RADIOLOGICAL ASSISTANCE PROGRAM
SMALLEY, W. L.

ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, CAR RIDGE, TENN.
THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION (ERDA) RADIOLOGICAL ASSISTANCE PROGRAM PROVIDES ADVICE AND ASSISTANCE AT THE SCENE OF A RADIOLOGICAL INCIDENT WHEN ERDA BELIEVES THAT SUCH ACTION IS NECESSARY OR ON REQUEST FROM OTHER AGENCIES OR INDIVIDUALS. THIS ARTICLE DISCUSSES THE TYPES OF ASSISTANCE AVAILABLE AND MEANS OF OBTAINING THAT ASSISTANCE AND PROVIDES STATISTICS SUMMARIZING THE EXPERIENCE WITH THE PROGRAM ALONG WITH GUIDELINES FOR HANDLING RADIOLOGICAL EMERGENCIES.

- 16-3-6-354 STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972
STEVENS-GUILLE, P. D.

ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, CANADA
DURING 1972, APPROXIMATELY ONE IN THREE OPERATING REACTORS WITH STEAM GENERATORS INCURRED TUBE FAILURES, PREDOMINANTLY NEAR THE TUBE SHEET AND IN THE BEND REGION. VARIOUS FORMS OF CORROSION WERE THE MOST FREQUENT CAUSE OF FAILURE. EDDY-CURRENT INSPECTION WAS THE PREFERRED METHOD FOR LOCATING AND INVESTIGATING THE CAUSE OF FAILURE. EXTENSIVE USE WAS MADE OF BOTH MECHANICAL AND EXPLOSIVE PLUGS FOR REPAIR. AS A CLASS, STEAM GENERATORS WITH MONEL 400 TUBES HAD THE LOWEST FAILURE RATES, AND THOSE WITH INCONEL 600 TUBES HAD THE HIGHEST.

- 16-4-1-415 THE ANSI-NSAB NUCLEAR STANDARDS PROGRAM
SAVOLAINEN, A. W.

AMERICAN NATIONAL STANDARDS INSTITUTE, NEW YORK, N.Y.
THE AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)-NUCLEAR STANDARDS MEASUREMENT BOARD (NSMB) NUCLEAR STANDARDS PROGRAM HAS, SINCE ITS INFANCY, PROCEEDED ON A BASE OF LONG TERM PLANS AND BROAD GOALS BEYOND THOSE OF THE INDIVIDUAL STANDARD PROJECTS UNDERTAKEN. THE EFFORT IN THE DEVELOPMENT OF NUCLEAR STANDARDS HAS FOCUSED ON MANY OBJECTIVES, INCLUDING: (1) THE EXPEDITIOUS DEVELOPMENT OF HIGH QUALITY STANDARDS IN AREAS OF NEED, (2) MAXIMUM COORDINATION OF THE PROGRAM TO PROMOTE A DISCIPLINED ENGINEERING APPROACH TO DESIGN AND CONSTRUCTION OF NUCLEAR FACILITIES, TO ENSURE ADEQUATE AND SAFE PLANTS, AND TO PROVIDE UTILITY AND SAFETY IN THE USE OF RADIOACTIVE MATERIALS, (3) PARTICIPATION IN THE PROGRAM BY THOSE WHO WILL ULTIMATELY USE THE STANDARDS, (4) RELIEF OF VOLUNTEER PROFESSIONALS FROM ADMINISTRATIVE BURDENS THAT DO NOT UTILIZE THEIR TIME EFFECTIVELY, (5) INCREASED PARTICIPATION BY PROFESSIONAL STANDARDS WRITING ORGANIZATIONS. THE INFORMATIONAL TOOLS ARE NOW IN PLACE TO ASSIST STANDARDS WRITING GROUPS IN ORGANIZING AND COMPLETING THEIR TASKS, TO PROVIDE STANDARDS MANAGEMENT GROUPS WITH A BASIS FOR EVALUATING PROGRESS, AND TO AID PROGRAM PLANNERS IN ASSURING ACHIEVEMENT OF THEIR GOALS WITH A MINIMUM OF OVERLAP AND DUPLICATION. AS OF JANUARY 1975, APPROXIMATELY 1500 STANDARDS HAD BEEN IDENTIFIED AS HAVING NUCLEAR APPLICATION, AND THERE WERE 551 ACTIVE PROJECTS UNDER THE COGNIZANCE OF NSMB.

- 16-4-1-421 THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPCA ON NRC LICENSING JURISDICTION AND PROCEDURES
DAVIS, J. P.

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC., N.Y.
PART II OF THIS ARTICLE COVERS THE INTERRELATIONSHIP OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA) AND THE U.S. NUCLEAR

REGULATORY COMMISSION (NRC) ENVIRONMENTAL REVIEWS UNDER THE FEDERAL WATER POLLUTION CONTROL ACT (FWPCA) AND OTHER STATUTES. THE SCOPE OF EPA'S AUTHORITY TO REGULATE RADIOACTIVE MATERIALS DISCHARGE UNDER FWPCA AND THE IMPACT ON NRC REGULATION UNDER THE ATOMIC ENERGY ACT ARE DISCUSSED, AND THE EFFECT OF FWPCA ON NRC ENVIRONMENTAL JURISDICTION UNDER NEPA IS CONSIDERED. IN ADDITION, THE PROBLEMS INVOLVED IN POSSIBLE OVERLAPPING AGENCY JURISDICTIONS AND THE EPA-AEC MEMORANDUM OF UNDERSTANDING ARE ANALYZED. THIS ARTICLE ALSO BRIEFLY SUMMARIZES EVENTS THAT HAVE OCCURRED SINCE THE PUBLICATION OF PART I. FINALLY, THE PROSPECTS FOR A WORKABLE DISCHARGE PERMIT SYSTEM UNDER THE FWPCA ARE DISCUSSED.

16-4-2-436

CSNI MEETING ON FUEL - COOLANT INTERACTIONS

FAUSKE, M. K.

ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.

THIS ARTICLE IS A BRIEF REVIEW OF THE SECOND SPECIALIST MEETING ON FUEL-COOLANT INTERACTIONS IN FAST REACTORS. THE MEETING, SPONSORED BY THE COMMITTEE ON THE SAFETY OF NUCLEAR INSTALLATIONS (CSNI), WAS HELD IN ISPR, ITALY, NOV. 21-23, 1973. EXPERIMENTAL DATA PRESENTED AT THE MEETING INCLUDED TESTS WITH BOTH SIMULANTS AND LIQUID METAL-COOLED FAST BREEDER REACTOR (LMBFR) MATERIALS. IN THE LATTER CATEGORY, OVER 100 INTERACTION TESTS WERE DISCUSSED, INCLUDING APPROXIMATELY 30 PROTOTYPIC REACTOR TESTS. ALL THE TESTS INVOLVING LMBFR MATERIALS RESULTED IN VERY RARE INTERACTIONS, EXCEPT FOR A FEW CASES WHERE SMALL QUANTITIES OF LIQUID SODIUM WERE INJECTED INTO MOLTEN URANIUM DIOXIDE (LABORATORY TESTS). THE ENERGETIC INTERACTIONS WERE GENERALLY EXPLAINED BY ENTRAPMENT AND OVERHEATING OF THE LIQUID SODIUM, ALTHOUGH SIGNIFICANT DIFFERENCES IN DETAILS OF THE PROPOSED MECHANISMS EXISTED. SEVERAL VARIATIONS OF THE ORIGINAL LHO-PADILLA ACCIDENT ANALYSIS MODEL OF FUEL-COOLANT INTERACTION WERE ALSO PRESENTED. HOWEVER, LACK OF UNDERSTANDING OF FRAGMENTATION, MIXING, AND HEAT TRANSFER PROCESSES HAS PREVENTED SUBSTANTIAL IMPROVEMENT OF THE MODEL AS ORIGINALLY PROPOSED. (FUEL-COOLANT INTERACTIONS REFERRED TO IN THIS ARTICLE ARE PHYSICAL, NOT CHEMICAL.)

16-4-2-443

A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PROBABILITIES

SWAN, S. W. + MELEIS, M.

BECHTEL POWER CORPORATION, SAN FRANCISCO, CALIF.

THE SIMPLE INEXPENSIVE COMPUTER CODE DESCRIBED IS USED FOR CALCULATING THE PROBABILITY OF TURBINE MISSILE DAMAGE TO SYSTEMS REQUIRED FOR SAFE SHUTDOWN OF A NUCLEAR PLANT FOLLOWING A STRUCTURAL FAILURE IN THE TURBINE GENERATOR SYSTEM. THE CODE CALCULATES THE PROBABILITY THAT A TURBINE MISSILE WILL STRIKE THE CONCRETE STRUCTURE SURROUNDING A PLANT SYSTEM AND THE PROBABILITY OF DAMAGE TO THE SYSTEM. EXAMPLE CALCULATIONS ARE PRESENTED ILLUSTRATE THE VARIATION IN THE CALCULATED PROBABILITIES AT DIFFERENT PLANT ARRANGEMENTS AND DIFFERENT TARGET WALL THICKNESSES.

16-4-3-452

SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY INSTRUMENTS

SOMMERS, J. F.

IDAH0 NATIONAL ENGINEERING LABORATORY, IDAH0 FALLS, IDAH0

DEVELOPMENT OF A NEW GENERATION OF PORTABLE RADIATION SURVEY INSTRUMENTS AND APPLICATION OF THE 'AS LOW AS PRACTICABLE' (ALAP) PHILOSOPHY HAVE PRESENTED A PROBLEM OF COMPLIANCE WITH GUIDES FOR RADIOACTIVE CONTAMINATION CONTROL. ISOLATED, LOW-LEVEL, DISCRETE PARTICLE BETA-GAMMA CONTAMINATION IS BEING DETECTED WITH THE NEW INSTRUMENTS. TO DETERMINE THE LIMITS OF PRACTICABILITY REQUIRES, IN TURN, THE DETERMINATION OF THE LIMITS OF DETECTION OF THESE SURFACE CONTAMINANTS. THE DATA AND CALCULATIONS INCLUDED IN THIS ARTICLE INDICATE THE SOURCE DETECTION FREQUENCIES THAT CAN BE EXPECTED USING THE NEW GENERATION OF SURVEY INSTRUMENTS. THE AUTHOR CONCLUDES THAT, IN LOW POPULATION GROUPS OF DISCRETE PARTICLES, ABOUT 5000 DIS/MIN OF BETA ACTIVITY PER PARTICLE IS THE MINIMUM LEVEL OF ACTIVITY PER PARTICLE WHICH IS APPLICABLE FOR CONFIDENT COMPLIANCE WITH SURFACE CONTAMINATION CONTROL GUIDES. LOWER CONTROL LEVELS ARE POSSIBLE WITH ADDITIONAL DEVELOPMENT OF INSTRUMENTS OR THROUGH HIGH COST CHANGES IN RADIATION SURVEY AND CONTAMINATION-CONTROL METHODS. ADDITIONAL ANALYSES ARE REQUIRED FOR ASSESSMENT OF THE HAZARD CAUSED BY WIDELY DISPERSED DISCRETE PARTICLE CONTAMINANTS.

16-4-4-458

APPLICATION OF EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE NUCLEAR INDUSTRY

GOODEE, M. W. + KIRBEY, A. M.

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

A SURVEY OF EVAPORATION AS APPLIED TO RADIOACTIVE-WASTE SOLUTIONS SHOWED THAT SYSTEM DECONTAMINATION FACTORS (DFS) OF 10³ TO 10⁴ CAN BE EXPECTED FOR NONVOLATILE RADIOACTIVE CONTAMINANTS TREATED IN SINGLE STAGE EVAPORATORS. THE DFS FOR IODINE CAN BE EXPECTED TO BE A FACTOR OF 10 TO 100 LOWER THAN THOSE EXPECTED FOR NONVOLATILE SPECIES UNDER ALKALINE, BUT NOT OXIDIZING OR ACIDIC, CONDITIONS. THE DFS IS REDUCED BY A FACTOR OF ABOUT 10 IF ORGANIC MATERIALS ARE MIXED WITH AQUEOUS WASTES. THESE VALUES CONSIDER THAT THE EVAPORATOR IS WELL DESIGNED, ADEQUATELY SIZED, AND OPERATED WITH REASONABLE SKILL.

- 16-4-4-449 **PROBLEMS IN NUCLEAR AIR CLEANING SYSTEMS**
 MOELLER, D. M.
 HARVARD UNIVERSITY, BOSTON, MASS.
 THIS ARTICLE IS A REVIEW OF PUBLISHED REPORTS OF FAILURES IN AIR CLEANING AND AIRBORNE WASTE MANAGEMENT SYSTEMS AT NUCLEAR INSTALLATIONS FROM 1964 TO 1974. THE REVIEW INDICATES INSTANCES OF DISRUPTION OF NOBLE GAS ADSORPTION SYSTEMS DUE TO HYDROGEN EXPLOSIONS, DECREASED PERFORMANCE OF PARTICULATE FILTERS DUE TO THE PRESENCE OF CONTAMINANTS OR THE FAILURE OF SEALS, DAMPERS, AND VALVES, AND IMPROPER EVALUATION OF THE EFFICIENCY OF AIR CLEANING SYSTEMS DUE TO SAMPLING AND OTHER PROCEDURAL ERRORS. ALTHOUGH A PORTION OF THE REPORTED FAILURES CAN BE ATTRIBUTED TO MANUFACTURING AND DESIGN DEFECTS, A MAJOR SHARE (ABOUT 65 PERCENT) APPEARS TO BE DUE TO ERRORS BY THOSE RESPONSIBLE FOR THE OPERATION AND MAINTENANCE OF AIR CLEANING EQUIPMENT.
- 16-4-5-482 **REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT SIMULATORS**
 COLLINS, P. F.
 U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
 THE NUCLEAR REGULATORY COMMISSION (NRC) REQUIRES THAT ALL OPERATORS OF THE CONTROLS OF NUCLEAR FACILITIES BE LICENSED. APPLICANTS FOR LICENSES MUST PASS WRITTEN EXAMINATIONS AND OPERATING TESTS ADMINISTERED BY NRC. SOME INDIVIDUALS MUST BE EXAMINED PRIOR TO INITIAL CRITICALITY AT A FACILITY, WHEREAS OTHERS MUST HAVE HAD EXTENSIVE ACTUAL OPERATING EXPERIENCE AT A COMPARABLE REACTOR TO SIT FOR THESE EXAMINATIONS. OPERATING EXPERIENCE MAY BE OBTAINED THROUGH APPROVED TRAINING PROGRAMS THAT UTILIZE NUCLEAR POWER PLANT SIMULATORS. SINCE 1969, NRC'S PREDECESSOR, THE USAEC, HAS ACCEPTED FOUR SUCH TRAINING PROGRAMS THAT ARE ADMINISTERED BY THE VENDORS OF NUCLEAR POWER PLANT SYSTEMS. THE PROGRAMS CONSIST OF (1) NUCLEAR FUNDAMENTALS COURSES, (2) RESEARCH-REACTOR OPERATION, (3) LECTURES ON NUCLEAR POWER-PLANT DESIGN, (4) OBSERVATION AT OPERATING NUCLEAR POWER PLANTS, AND (5) SIMULATOR OPERATIONS. INDIVIDUALS SEEKING LICENSES AFTER PLANTS BECOME OPERATIONAL MUST DEMONSTRATE THEIR PROFICIENCY AT REACTOR CONTROLS DURING EXAMINATIONS. IN 1971, THE USAEC APPROVED THE USE OF SIMULATORS IN TRAINING PROGRAMS AND DURING THE EXAMINATIONS. THESE PROGRAMS ARE LIMITED TO PERSONNEL FROM FACILITIES HAVING CONTROL ROOMS WHICH ARE CLOSELY PARALLEL TO THAT OF THE SIMULATOR. THE NRC ALSO REQUIRES LICENSED INDIVIDUALS TO PARTICIPATE IN REQUALIFICATION PROGRAMS THAT REQUIRE LICENSEES TO MANIPULATE REACTOR CONTROLS THROUGH A SPECIFIED NUMBER OF EVOLUTIONS DURING THEIR LICENSE TENURES. IF THE SIMULATOR'S OPERATING CHARACTERISTICS AND CONTROL ROOM ARE SIMILAR TO THOSE OF THE FACILITY INVOLVED, MANIPULATION OF SIMULATOR CONTROLS IS PERMITTED SO THAT THE NUMBER OF PLANT EVOLUTIONS SOLELY FOR REQUALIFICATION CAN BE MINIMIZED. FINAL EVALUATION OF THE MERITS OF USING SIMULATORS RATHER THAN OPERATING PLANTS IS BASED ON THE KNOWLEDGE AND UNDERSTANDING EXHIBITED BY TRAINEES DURING THE ADMINISTRATION OF EXAMINATIONS. THE NRC EXAMINERS HAVE FOUND THAT INDIVIDUALS TRAINED USING SIMULATORS HAVE A BETTER UNDERSTANDING OF PLANT RESPONSES TO TRANSIENT CONDITIONS AND ABNORMAL SITUATIONS AND ALSO ARE MORE CONFIDENT IN ANSWERING QUESTIONS THAT REQUIRE PREDICTION OF PLANT RESPONSES TO POSTULATED SITUATIONS. ALSO, SIMULATORS ARE EXTREMELY EFFECTIVE FOR EXAMINING AND EVALUATING INDIVIDUALS. THE NRC BELIEVES THAT SIMULATORS, USED IN CONJUNCTION WITH COMPREHENSIVE TRAINING PROGRAMS, ARE EFFECTIVE TRAINING DEVICES AND INTENDS TO ENCOURAGE THEIR USE IN FUTURE TRAINING PROGRAMS.
- 16-5-1-537 **NUCLEAR LIABILITY INSURANCE - A RESUME OF RECENT YEARS**
 HARRONE, J.
 NUCLEAR ENERGY LIABILITY-PROPERTY INSURANCE ASSOCIATION, FARMINGTON, CONN.
 THE NUCLEAR LIABILITY INSURANCE POOLS HAVE STEADILY INCREASED NUCLEAR LIABILITY INSURANCE AVAILABLE TO THE NUCLEAR INDUSTRY TO ITS PRESENT \$125 MILLION, WHICH IS MORE THAN DOUBLE THE \$40 MILLION FIRST PROVIDED IN 1957. THE INSURANCE POOLS ALSO PROVIDE AN ADDITIONAL \$175 MILLION OF ALL-RISK PROPERTY INSURANCE TO PROTECT AGAINST LOSS OF PROPERTY AT A NUCLEAR FACILITY, FOR A TOTAL OF \$300 MILLION. THIS AMOUNT OF LIABILITY AND PROPERTY INSURANCE AVAILABLE FOR NUCLEAR RISKS EXCEEDS THE COVERAGE THE INSURANCE INDUSTRY HAS AT RISK ANYWHERE ON A SINGLE UNIT OF RISK, THUS ATTESTING TO THE CONFIDENCE IN NUCLEAR SAFETY. THE EXTRAORDINARY SAFETY ACHIEVED AND RECORDED BY THE LOSS EXPERIENCE OF THE NUCLEAR POOLS IS DESCRIBED. THE INSURANCE POOLS HAVE PROPOSED A CHANGE IN THE PRICE-ANDERSON ACT WHICH WOULD PROVIDE SUBSTANTIAL ADDITIONAL SUMS OF NUCLEAR LIABILITY INSURANCE TO PROTECT THE PUBLIC AND WHICH IS LIKELY TO BE THE SUBJECT OF EXAMINATION BY CONGRESS DURING 1975. THE PROPOSAL, IF IMPLEMENTED, WILL GRADUALLY INCREASE THE PROTECTION AFFORDED TO THE PUBLIC AND VIRTUALLY ELIMINATE THE ROLE OF GOVERNMENT INDEMNITY.
- 16-5-1-542 **AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR SAFETY**
 (EDITORS NOTE - IN AUGUST 1974 THE U.S. ATOMIC ENERGY COMMISSION RELEASED FOR REVIEW AND COMMENT A DRAFT OF WASH-1400, 'REACTOR SAFETY STUDY-AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS.' SEE NUCLEAR SAFETY, VOL. 19, NO. 6, PAGES 473-475 FOR A BRIEF SUMMARY OF

THAT REPORT. THAT STUDY BY THE AEC IS THE MOST COMPREHENSIVE OF ITS KIND EVER UNDERTAKEN AND HAS SINCE BEEN EXTENSIVELY REVIEWED BY MANY INTERESTED PARTIES. THEIR COMMENTS ARE AVAILABLE AT THE NRC PUBLIC DOCUMENT ROOM. CONCURRENT WITH THE AEC REACTOR SAFETY STUDY, THE AMERICAN PHYSICAL SOCIETY (APS) DECIDED TO SPONSOR A STUDY OF REACTOR SAFETY BECAUSE IT WAS AN IMPORTANT AND CONTROVERSIAL SUBJECT WITH SUBSTANTIAL SCIENTIFIC AND TECHNOLOGICAL CONTENT. TOWARD THAT END THE APS STUDY WAS SUPPORTED BY THE NATIONAL SCIENCE FOUNDATION AND THE AEC. THE APS STUDY WAS UNDERTAKEN IN 1974-1975 BY A STUDY GROUP CONSISTING OF 12 PART-TIME PARTICIPANTS WITH VARIOUS LEVELS OF PRIOR EXPERIENCE IN THE REACTOR FIELD. ITS PURPOSE WAS TO MAKE A QUANTITATIVE ESTIMATE OF THE LIKELIHOOD OF ACCIDENT CONSEQUENCES OF A GIVEN SEVERITY. ALTHOUGH THE APS STUDY GROUP DID NOT UNDERTAKE TO REVIEW THE AEC REACTOR SAFETY STUDY, THERE IS MUCH COMMON GROUND BETWEEN THE TWO, AND THE AEC STUDY IS MENTIONED FREQUENTLY IN THE APS REPORT. THE DRAFT OF THE APS REPORT, ENTITLED "REPORT TO THE AMERICAN PHYSICAL SOCIETY BY THE STUDY GROUP ON LIGHT WATER-REACTOR SAFETY," WAS RELEASED IN APRIL 1975, AND THE FINAL VERSION WILL BE PUBLISHED IN THE REVIEWS OF MODERN PHYSICS. BECAUSE OF THE IMPORTANCE OF THE SUBJECT AND BECAUSE OF THE TECHNICAL COMPETENCE AND OBJECTIVITY OF THE APS STUDY GROUP, THE EDITORS OF NUCLEAR SAFETY ARE HERE REPRINTING THE FIRST CHAPTER, "SUMMARY OF CONCLUSIONS AND MAJOR RECOMMENDATIONS," OF THE DRAFT OF THE APS REPORT.)

16-5-2-546 POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRONIC ACCIDENTS IN HTGRS
TODIAS, M.

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

STUDIES OF POSTULATED NEUTRONIC EVENTS OF MAJOR CONCERN IN HIGH TEMPERATURE GAS COOLED REACTORS (HTGRS) ARE REVIEWED. THE LITERATURE COVERED INCLUDES LICENSING REVIEWS, SAFETY ANALYSIS REPORTS, AND TOPICAL REPORTS PREPARED DURING THE DESIGN AND DEVELOPMENT OF THE MAJOR REACTORS OF THE GENERAL ATOMIC COMPANY. INCIDENTS CONSIDERED ARE LOSS OF FISSION PRODUCTS, CORE COMPRESSION DUE TO EARTHQUAKE, FUEL INSERTION DURING RELOADING, AND STEAM INTRODUCTION INTO THE CORE, ALL OF WHICH ARE JUDGED TO BE OF LESS IMPORTANCE THAN THE WITHDRAWAL OF A SINGLE ROD PAIR. INCIDENTS SUCH AS MULTIPLE ROD WITHDRAWAL OR ROD EJECTION HAVE BEEN DISMISSED AS PHYSICALLY IMPOSSIBLE. ANALYSES OF REACTIVITY CHANGES FOLLOWING A LOSS OF COOLANT ACCIDENT INDICATE THAT HTGRS WILL REMAIN SUBCRITICAL. OTHER ITEMS THAT CONTINUE TO RECEIVE ATTENTION ARE THE REACTIVITY CONSEQUENCES OF CORE SUPPORT COLLAPSE RESULTING FROM WEAKENING BY SEISMIC EVENTS OR STEAM CORROSION. THE PHYSICS CALCULATIONS HAVE BEEN EXTENSIVELY COMPARED WITH EXPERIMENTAL RESULTS IN CRITICAL FACILITIES AND OPERATING REACTORS. DESIGNERS HAVE CUSTOMARILY DEALT WITH DIFFERENCES BETWEEN OBSERVATION AND CALCULATION BY USE OF PESSIMISTIC ASSUMPTIONS AND BY CONTINUAL ATTEMPTS TO IMPROVE THEORETICAL APPROACHES. INDEPENDENT CHECKING IS CURRENTLY SPONSORED BY THE NUCLEAR REGULATORY COMMISSION'S OFFICE OF NUCLEAR REGULATORY RESEARCH.

16-5-3-557 IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM
MAGEN, E. W.

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE REVIEWS THE NUCLEAR SAFETY RELATED PORTIONS OF THE 6TH IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM HELD IN WASHINGTON, D.C., DEC. 11-13, 1974. THE MEETING, HELD CONCURRENTLY WITH THE 21ST NUCLEAR SCIENCE SYMPOSIUM AND THE 14TH SCINTILLATION AND SEMICONDUCTOR COUNTER SYMPOSIUM, WAS SPONSORED BY THE INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE) AND THE U.S. ATOMIC ENERGY COMMISSION. IT WAS THE LATEST IN A SERIES OF MEETINGS DESIGNED SPECIFICALLY FOR ELECTRICAL ENGINEERS WHO ARE INVOLVED WITH NUCLEAR POWER GENERATION. SEVERAL SESSIONS WERE DEVOTED TO UPDATING INFORMATION ON STANDARDS, STARTUP AND OPERATING EXPERIENCES, AND INSTRUMENTATION DEVELOPMENT.

16-5-4-564 NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER REACTOR PLANT
GRAHAM, J.

WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PA.

THIS ARTICLE REVIEWS THE DESIGN PHILOSOPHY AND SAFETY FEATURES OF THE 975-MW(t) CLINCH RIVER BREEDER REACTOR (CRBR), A SODIUM COOLED DEMONSTRATION REACTOR TO BE BUILT NEAR OAK RIDGE, TENN. THE OVERALL SAFETY OF THE PLANT IS BASED ON THREE LEVELS OF PROTECTION: (1) RELIABLE OPERATION THROUGH INTRINSIC FEATURES OF THE DESIGN, (2) PROTECTION PROVIDED AGAINST ANTICIPATED FAULTS AND UNLIKELY EVENTS, AND (3) PROVISION FOR EXTREMELY UNLIKELY EVENTS. THE PRINCIPAL FEATURES OF EACH OF THESE THREE SAFETY DESIGN LEVELS ARE DISCUSSED. IN ADDITION, WORK IS CONTINUING ON A PARALLEL DESIGN APPROACH THAT TREATS A CORE DISRUPTIVE ACCIDENT AS A DESIGN BASIS.

16-5-4-561 SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS

KIMBLEY, A. M. & GOODEE, M. W.

MOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS REVIEW OF SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS THROUGH 1972 SHOWS THAT BOILING WATER REACTORS (BWRs) CUMULATIVELY GENERATED OVER TWICE AS MUCH WASTE AS PRESSURIZED-WATER REACTORS (PWRs) (3.3×10^{15} VS. 1.4×10^{15} CUBIC FT) AND PRODUCED ABOUT THE SAME CUMULATIVE THERMAL OUTPUT (2.2×10^{18} VS. 2.5×10^{18} MWH(t)). THE CUMULATIVE UNDECAYED

CONTENTS OF THESE WASTES WERE 4.7×10^{13} AND 7.7×10^{13} CI FOR BWRs AND PWRs, RESPECTIVELY. GENERALLY, PWRs INCORPORATED ALL WET PROCESS WASTES EXCEPT SPENT BEAD RESINS IN CEMENT, WHEREAS SEVERAL BWRs TENDED TO Dewater SLURGES AND RESINS AND TO SOBB EVAPORATOR CONCENTRATES ON HIGH SURFACE AREA MATERIALS WITHOUT BINDER FOR SHIPMENT AND BURIAL. A RECENT TREND FOR BWRs IS TO INCORPORATE WASTE IN SOLID MATRICES.

14-5-5-593

THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT
PALMS, J. M. + VELURI, V. R. + DOORNE, F. W.
ALLIED-GENERAL NUCLEAR SERVICES, BARNWELL, S.C.

THE ENVIRONMENTAL IMPACT OF IODINE-129 RELEASED BY THE ALLIED GENERAL NUCLEAR SERVICES - BARNWELL NUCLEAR FUEL PLANT (BNFP) IS ASSESSED. ON THE BASIS OF PRESENT KNOWLEDGE, IT IS EXPECTED THAT THE PREDICTED RELEASED FROM THE PLANT WILL NOT RAISE THE CONCENTRATION OF IODINE-129 TO LEVELS THAT WOULD BE HAZARDOUS TO MAN OR THE ENVIRONMENT. THIS ARTICLE SUMMARIZES THE ANALYSES ASSOCIATED WITH THE RELEASE OF IODINE-129 TO THE ENVIRONMENT, INCLUDING THE PRESENTLY ESTIMATED BNFP RELEASES AND CALCULATIONS OF RESULTING DOSE TO MAN USING THE STATE OF THE ART DOSE MODELS. THYROID DOSES ARE CALCULATED BY THE SPECIFIC ACTIVITY MODEL AND THE CRITICAL PATHWAY MODEL. THE DEGREE OF CONSERVATIVENESS INVOLVED IN THE SPECIFIC ACTIVITY MODEL WHICH MAKES IT UNACCEPTABLE AS A REALISTIC MODEL IS DISCUSSED, AND THE CRITICAL PATHWAY MODEL IS BRIEFLY ASSESSED. THYROID DOSES FOR ADULTS AND INFANTS DUE TO INHALATION AND INGESTION ARE PRESENTED. FOR AN AIR CONCENTRATION OF 3.6×10^{-5} PCI/M³ OF IODINE-129, RESULTING FROM A RELEASE AT THE RATE OF 1.5×10^{-9} CI/SEC, THE INFANT AND THE ADULT THYROID DOSES DUE TO INGESTION VIA MILK ARE CALCULATED BY THE CRITICAL PATHWAY MODEL TO BE 0.24 AND 0.12 MRE/YEAR, RESPECTIVELY. THE ADULT THYROID DOSE DUE TO INGESTION OF LEAFY VEGETABLES IS FOUND TO BE 0.04 MRE/YEAR. THE INHALATION AND WHOLE BODY DOSES ARE ORDERS OF MAGNITUDE SMALLER.

14-5-6-603

STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973

STEVENS-GUILLE, P. D. + HARE, P. G.
ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO
THIS ARTICLE SUMMARIZES STEAM GENERATOR TUBE FAILURES IN WATER COOLED REACTORS FOR 1973. FAILURES OCCURRED IN 11 OF 49 REACTORS, MAINLY DUE TO CORROSION AND VIBRATION. THE TWO MOST IMPORTANT VARIABLES IN PREVENTING THESE FAILURES APPEAR TO BE SECONDARY WATER CHEMISTRY AND DESIGN.

14-5-6-614

OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER PLANTS
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE SUMMARIZES THE RESULTS OF AN INVESTIGATION OF OCCUPATIONAL RADIATION EXPOSURES AT NUCLEAR POWER PLANTS CARRIED OUT BY SAI SERVICES FOR THE ATOMIC INDUSTRIAL FORUM. OCCUPATIONAL RADIATION EXPOSURES AND THEIR SOURCES WERE INVESTIGATED AT EIGHT BOILING WATER REACTORS (BWRs) AND AT SIX PRESSURIZED WATER REACTORS (PWRs) FROM 1969 TO 1973. ACTIVATION PRODUCTS RATHER THAN FISSION PRODUCTS WERE FOUND TO BE THE MAJOR SOURCES OF RADIATION EXPOSURE TO IN-PLANT PERSONNEL FOR BOTH TYPES OF REACTORS. THE SINGLE MOST IMPORTANT NUCLIDE CONTRIBUTING TO EXPOSURES AT BWRs WAS COBALT-60. NO SINGLE NUCLIDE WAS FOUND TO BE DOMINANT IN PWR EXPOSURES, BUT STEAM GENERATOR WORK WAS THE LARGEST SOURCE OF EXPOSURE. THE ANNUAL EXPOSURE RATE WAS FOUND TO INCREASE WITH PLANT AGE ON BWRs, BUT THERE IS NO CONSISTENT PATTERN FOR EXPOSURE RATE CHANGE WITH PLANT AGE ON PWRs.

14-6-1-659

EPRI WATER REACTOR SAFETY PROGRAM
LOEWENSTEIN, W. B.

ELECTRIC POWER RESEARCH INSTITUTE, PALO ALTO, CALIF.
THE RATIONALE, STRUCTURE, AND CURRENT STATUS OF THE ELECTRIC POWER RESEARCH INSTITUTE (EPRI) WATER REACTOR SAFETY PROGRAM ARE SUMMARIZED. THE EFFORTS EMPHASIZE QUANTIFIED ASSURANCE OF SAFETY, USUALLY BASED ON THE SYNTHESIS OF PERTINENT EXPERIMENTAL, ANALYTICAL, AND CALCULATIONAL RESULTS. THE SCOPE OF THE PROGRAM RANGES FROM THE QUANTIFIED DEFINITION OF THE COURSE OF THE POSTULATED LOSS OF COOLANT ACCIDENT TO CONTINUING ROUTINE MONITORING OF THE PRESSURE BOUNDARY. THIS INCLUDES RESEARCH ON SUCH DIVERSE EFFORTS AS TWO-PHASE FLOW BEHAVIOR IN COMPLEX GEOMETRIES, INTERACTION OF POTENTIAL TORNADO GENERATED MISSILES WITH REINFORCED CONCRETE STRUCTURES, ASPECTS OF PROBABILISTIC SAFETY APPRAISAL, AND TECHNIQUES TO QUANTIFY THE DIAGNOSIS OF THE PERFORMANCE OF THE PRESSURE BOUNDARY. THE EPRI PROGRAM EFFORTS ARE COORDINATED WITH THE NEEDS OF THE UTILITY INDUSTRY THROUGH SEVERAL ADVISORY COMMITTEES. THE PROGRAM IS COORDINATED WITH THE PROGRAMS OF NATIONAL SPONSORING AGENCIES AND MAINTAINS LIAISON WITH REACTOR VENDORS AND ARCHITECT ENGINEERS. PROGRAM SEGMENTS ARE IMPLEMENTED BY REACTOR VENDORS, ARCHITECT ENGINEERS, CONSULTING ORGANIZATIONS, NATIONAL LABORATORIES, INDEPENDENT RESEARCH ORGANIZATIONS, AND UNIVERSITIES. IN ADDITION TO COORDINATION WITH NATIONAL AGENCIES, ARRANGEMENTS FOR COOPERATION AND EXCHANGE HAVE BEEN INITIATED WITH SEVERAL FOREIGN NATIONAL AND UTILITY ORGANIZATIONS.

- 16-6-1-667 EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM
 ROWE, M. D. + GALPIN, F. L. + PETERSON, M. Y., JR.
 U.S. ENVIRONMENTAL PROTECTION AGENCY, WASHINGTON, D.C.
 A PRINCIPAL ROLE OF THE ENVIRONMENTAL PROTECTION AGENCY'S
 OFFICE OF RADIATION PROGRAMS IS TO ASSESS ENVIRONMENTAL
 RADIOACTIVITY LEVELS AND TO ESTIMATE THE IMPACT OF RADIATION
 TECHNOLOGY ON MAN AND HIS ENVIRONMENT. THIS ARTICLE DESCRIBES
 THE APPROACH OF THE EPA AND ITS PROGRAM TO FULFILL THIS ROLE.
- 16-6-2-689 FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM
 CRONENBERG, A. M. + GRELINES, M. A.
 ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
 AN IMPORTANT ASPECT OF THE FUEL COOLANT INTERACTION PROBLEM
 RELATIVE TO LIQUID METAL COOLED FAST BREEDER REACTOR SAFETY
 ANALYSIS IS THE FRAGMENTATION OF MOLTEN OXIDE FUEL ON CONTACT
 WITH LIQUID SODIUM COOLANT. A PROPER DESCRIPTION OF THE
 KINETICS OF SUCH AN EVENT REQUIRES AN UNDERSTANDING OF THE
 BREAKUP PROCESS AND AN ESTIMATE OF THE SIZE AND DISPERSION OF
 SUCH FINELY DIVIDED FUEL IN THE COOLANT. IN RECENT YEARS,
 CONSIDERABLE INTEREST HAS CENTERED ON THE PROBLEM OF
 DETERMINING THE NATURE OF THE FRAGMENTATION PROCESS. THIS
 ARTICLE REVIEWS BOTH ANALYTIC AND EXPERIMENTAL STUDIES
 PERTAINING TO SUCH BREAKUP IN LIGHT OF RECENT DEVELOPMENTS IN
 THE UNDERSTANDING OF HEAT TRANSFER AND SOLIDIFICATION
 PHENOMENA DURING QUENCHING OF URANIUM DIOXIDE IN SODIUM. WHERE
 POSSIBLE, AN ATTEMPT IS MADE TO ASSESS THE WORK POTENTIAL FOR
 FRAGMENTATION OF THE VARIOUS PROPOSED MODELS AND TO COMPARE THE
 PREDICTED PARTICLE SIZE WITH EXPERIMENTAL RESULTS.
- 16-6-3-701 SAFETY INSTRUMENTATION FOR THE SODIUM COOLED FAST REACTOR
 HALL, R. S.
 BERKELEY NUCLEAR LABORATORIES, GLOUCESTERSHIRE, ENGLAND
 THE PARTICULAR SAFETY PROBLEMS OF THE FAST REACTOR AND THE
 ROLE OF INSTRUMENTED PROTECTION IN RELATION TO THE OVERALL
 SAFETY DESIGN OF THE REACTOR ARE DISCUSSED. THE IMPORTANCE OF
 THE ACCIDENT SEQUENCE ARISING FROM A FAULT WITHIN ONE
 SUBASSEMBLY IS INDICATED, AND THE PHYSICAL PHENOMENA INVOLVED
 ARE DISCUSSED WITH REGARD TO THE GENERATION OF DETECTABLE
 SIGNALS. SEVERAL POSSIBLE TECHNIQUES FOR DETECTING SUBASSEMBLY
 ACCIDENTS ARE DESCRIBED, INCLUDING THOSE WITH DETECTORS
 SITUATED AT THE OUTLET OF EACH SUBASSEMBLY AND ALSO THOSE
 INVOLVING WHOLE-CORE PARAMETERS. THE CURRENT STATUS OF THESE
 TECHNIQUES IS INDICATED, AND, WHERE APPROPRIATE, THE STEPS
 NECESSARY FOR THEIR FUTURE APPLICATION ARE OUTLINED. REFERENCE
 IS MADE TO THE WAY IN WHICH TYPES OF INSTRUMENTS WOULD HAVE TO
 BE COMBINED TO GIVE A HIGH DEGREE OF PROTECTION TO THE SYSTEM.
 THE ACTUAL PROTECTION REQUIRED BEING DEPENDENT ON THE OVERALL
 SAFETY INTENTIONS. ATTENTION IS DRAWN TO THE PROBLEMS OF
 MINIMIZING THE SPURIOUS TRIP RATE FOR A WELL INSTRUMENTED
 REACTOR, WHICH LEAD TO STRINGENT REQUIREMENTS ON INSTRUMENT
 RELIABILITY AND/OR REPLACEABILITY. THE POSSIBLE ROLE OF THE
 COMPUTER IN HANDLING THE MULTIPLICITY OF COMPLEX SIGNALS IS
 MENTIONED. TOGETHER WITH THE PROBLEMS THAT HAVE TO BE SOLVED
 BEFORE THIS CAN BE DONE, IT IS CONCLUDED THAT SATISFACTORY
 INSTRUMENT PROTECTION IS AVAILABLE FOR WHOLE-CORE FAULTS, BUT
 WITH REGARD TO SUBASSEMBLY FAULT DETECTION THE SITUATION IS
 LESS CLEAR. ALTHOUGH SOME INFORMATION IS AVAILABLE FOR GUIDANCE
 ON THE INSTRUMENTS AND THEIR SPECIFICATIONS, THE JUSTIFICATION
 AND ACHIEVABILITY OF THE LATTER ARE DEPENDENT ON DEVELOPMENT
 WORK THAT IS STILL PROCEEDING. IT MAY WELL BE THAT
 UNCERTAINTIES CONCERNING THE EFFECTS OF THE REACTOR ENVIRONMENT
 WILL REQUIRE THAT SOME OF THIS WORK TAKE THE FORM OF IN-REACTOR
 EXPERIMENTS.
- 16-6-3-714 SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT
 BHATIA, P.
 BALTIMORE GAS AND ELECTRIC COMPANY, BALTIMORE, MD.
 EARLY IN 1970 THE BALTIMORE GAS + ELECTRIC COMPANY DECIDED TO
 USE SILICONE RUBBER INSULATED CABLES, SIZE NO. 2 AWG AND
 SMALLER, FOR ALL LOW-VOLTAGE POWER, CONTROL, AND
 INSTRUMENTATION APPLICATIONS FOR THE CALVERT CLIFFS NUCLEAR
 POWER PLANT, UNITS 1 AND 2. THE DECISION WAS BASED ON
 EXTENSIVE TESTS MADE BY THE COMPANY TO DETERMINE THE OPTIMUM
 BALANCE OF PROPERTIES OF CONTROL AND POWER CABLES TO ENSURE
 THEIR SATISFACTORY OPERATION DURING A SEVERE FIRE AND AFTER
 EXPOSURE TO RADIATION. RESULTS OF THE TESTS INDICATED THAT
 SILICONE RUBBER INSULATED CABLES (PETHYL PHENYL VINYL BASE
 COMPOUND) WITH GLASS BRAID OVER THE INSULATED CONDUCTORS,
 ASBESTOS FILLERS, AND OVERALL ASBESTOS-BRAID JACKETS WILL
 OPERATE SUCCESSFULLY DURING AND AFTER AN OIL FIRE AND AFTER
 EXPOSURE TO A TOTAL RADIATION OF 10181 RADS AND BOILED STEAM.
- 16-6-5-720 POPULATION EXPOSURES - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY
 BANTON, C. J. + DICKSON, M. M. + PARZYCK, D. C.
 ROHWER, P. S. + TURNER, J. E.
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
 THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS
 SOCIETY WAS HELD AT KNOXVILLE, TENN., OCT. 21-24, 1974. ALL
 BUT 4 OF THE 56 PAPERS PRESENTED ARE INCLUDED IN THE PRINTED
 PROCEEDINGS THAT WERE DISTRIBUTED AT THE MEETING. TOPICS
 COVERED IN THE VARIOUS SESSIONS ARE BACKGROUND RADIATION
 EXPOSURES, MEDICAL RADIATION EXPOSURES (NOT REVIEWED IN THIS
 ARTICLE), NUCLEAR POWER EXPOSURES, DOSIMETRY, AND POPULATION
 EXPOSURES FROM SOURCES OTHER THAN NUCLEAR POWER. A PUBLIC FORUM

ON POPULATION EXPOSURES FROM ELECTRIC POWER GENERATION NUCLEAR AND NONNUCLEAR PRODUCED SOME RATHER LIVELY INTERCHANGES BETWEEN A PANEL OF EXPERTS AND THE AUDIENCE. THE BROAD RANGE OF TOPICS COVERED IN THE SYMPOSIUM SHOWS THAT THE TASKS OF THE HEALTH PHYSICIST ARE GROWING MORE COMPLEX.

16-6-5-728

UUD VADIS. PERSONNEL MONITORING

BECKER, K.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

WITH THE INCREASING USE OF NUCLEAR POWER AND RADIATION SOURCES, THE SELECTION OF OPTIMUM SYSTEMS FOR PERSONNEL MONITORING IS BECOMING A MATTER OF WORLDWIDE CONCERN. THE PRESENT STATUS OF PERSONNEL DOSIMETRY, SOMETIMES CHARACTERIZED BY UNSTABLE AND INACCURATE DETECTORS AND OVERSIMPLIFIED INTERPRETATION OF THE RESULTS, LEAVES MUCH TO BE DESIRED. IN PARTICULAR, PHOTOGRAPHIC FILM, ALTHOUGH HAVING CERTAIN ADVANTAGES WITH REGARD TO ECONOMICS AND INFORMATION CONTENT, UNDERGOES RAPID CHANGES IN DARK AND HUMID CLIMATES. CAREFUL SEALING REDUCES, BUT DOES NOT PREVENT, THESE PROBLEMS. THE REPLACEMENT OF FILM BY SOLID STATE DOSIMETERS, PRIMARILY THERMOLUMINESCENCE DOSIMETERS, IS IN PROGRESS OR BEING CONSIDERED BY AN INCREASING NUMBER OF INSTITUTIONS AND REQUIRES A NUMBER OF DECISIONS CONCERNING THE CHOICE OF THE OPTIMUM DETECTOR(S), BADGE DESIGN, AND EVALUATION SYSTEM. ORGANIZATIONAL MATTERS, SUCH AS THE DESIRABILITY OF AUTOMATION AND COMPUTERIZED BOOKKEEPING, ETC. THE CHANGE ALSO IMPLIES THE POTENTIAL USE OF SUCH ADVANCED CONCEPTS AS DIFFERENT DETECTORS AND MONITORING PERIODS FOR THE LARGE NUMBER OF LOW RISK PERSONS AND THE SMALL NUMBER OF HIGH RISK RADIATION WORKERS.

16-6-6-734

SUMMARY OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS DURING 1973

NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

RELEASES OF RADIOACTIVITY IN AIRBORNE AND LIQUID EFFLUENTS AND THE NUMBER OF SHIPMENTS AND ACTIVITY OF SOLID WASTE HAVE BEEN COMPILED BY THE NUCLEAR REGULATORY COMMISSION FROM LICENSEE REPORTS FOR 1973. THE WIDE VARIATIONS IN THE RADIOACTIVITY RELEASES WERE DUE TO DIFFERENCES IN PLANT SIZE, POWER LEVEL, FUEL PERFORMANCE, AND EFFLUENT TREATMENT METHODS. DATA COVERING SPECIFIC ISOTOPES OF PARTICULAR INTEREST ARE SUMMARIZED. IN ALL CASES, RELEASES OF RADIOACTIVITY WERE ONLY SMALL FRACTIONS OF PERMISSIBLE LIMITS SET BY APPLICABLE REGULATIONS OR IN TECHNICAL SPECIFICATIONS.

17-1-1-1

PLANNING FOR NUCLEAR EMERGENCIES

MOLLER, D. W. + SELBY, J. M.

HARVARD UNIVERSITY, SCHOOL OF PUBLIC HEALTH BOSTON, MASS.

A PROPERLY DEVELOPED AND EXECUTED EMERGENCY PLAN REPRESENTS AN ADDITIONAL LEVEL OF SAFETY IN DEALING WITH POTENTIAL ACCIDENTS IN NUCLEAR FACILITIES. THIS STATE OF THE ART REVIEW OF THE SUBJECT, BASED PRIMARILY ON MATERIAL PRESENTED BY A VARIETY OF SPEAKERS DURING A SHORT COURSE HELD AT THE HARVARD SCHOOL OF PUBLIC HEALTH IN MAY 1975, SHOWS THAT, ALTHOUGH PROGRESS IS BEING MADE, ADDITIONAL WORK REMAINS TO BE DONE. A CERTAIN DEGREE OF CONFUSION HAS EXISTED BECAUSE OF THE MULTITUDE OF FEDERAL AND STATE AGENCIES HAVING RESPONSIBILITIES IN THIS FIELD. HOWEVER, STEPS ARE BEING TAKEN TO CORRECT THIS SITUATION. ALTHOUGH UPDATED PROTECTIVE ACTION GUIDES FOR AIRBORNE RELEASES HAVE BEEN PUBLISHED, SIMILAR ACTION IS NEEDED FOR LIMITATIONS ON RADIONUCLIDE INTAKE VIA FOOD AND WATER. INDICATIONS ARE THAT, FOR A SINGLE PUFF TYPE OF AIRBORNE RELEASE, IT MAY NOT BE POSSIBLE TO EVACUATE THE NEIGHBORING POPULATION WITHIN THE SHORT TIME SPAN AVAILABLE TO AVOID EXPOSURE. FOR A LONGER TERM CONTINUOUS TYPE OF AIRBORNE RELEASE, HOWEVER, EVACUATION CAN BE VERY USEFUL. STILL IN NEED OF FURTHER EVALUATION AS AN ADJUNCT OR ALTERNATIVE TO EVACUATION IS THE USE OF PROTECTIVE SHELTER AND/OR RADIO-PROTECTIVE PROPHYLAXIS. ALSO IN NEED OF ADDITIONAL STUDY AND/OR DEVELOPMENT ARE METHODS FOR ASSESSING THE NATURE AND COURSE OF AN ACCIDENT, TECHNIQUES FOR RAPIDLY ESTIMATING THE PATHWAY OF A RELEASE AND ANTICIPATED POPULATION DOSES. ASSESSMENT OF THE LONG RANGE IMPLICATIONS OF POTENTIAL WIDESPREAD RADIOACTIVE CONTAMINATION OF LAND AREAS, AND IMPROVEMENTS IN THE CAPABILITIES OF STATE AND LOCAL AGENCIES IN PROVIDING RADIOLOGICAL EMERGENCY RESPONSE.

17-1-1-15

STATE AND LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES

NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE WAS ADAPTED FROM A REPORT THAT PROVIDES GUIDANCE TO STATE AND LOCAL GOVERNMENTS ON RADIOLOGICAL EMERGENCY RESPONSE PLANNING. THE REPORT LISTS SPECIFIC PLANNING OBJECTIVES FOR A RADIOLOGICAL EMERGENCY RESPONSE PLAN, ALONG WITH GUIDANCE FOR DETERMINING WHETHER A PLAN MEETS THESE OBJECTIVES. THE GUIDANCE DATA SHOULD BE INCLUDED IN STATE RADIOLOGICAL EMERGENCY RESPONSE PLANS AND, WHERE APPROPRIATE, IN OTHER STATE AND LOCAL GOVERNMENT EMERGENCY PLANS. A CHECKLIST OF MAJOR PLANNING ELEMENTS IS PROVIDED TO ASSIST BOTH EXPERIENCED AND INEXPERIENCED PLANNERS IN CONSTRUCTING A COMPREHENSIVE RADIOLOGICAL EMERGENCY RESPONSE PLAN. EACH SECTION OF THE CHECKLIST IS SUPPORTED BY SPECIFIC GUIDANCE LANGUAGE. COMPLETION OF THE CHECKLIST WILL NOT IN ITSELF

CONSTITUTE A RADIOLOGICAL EMERGENCY RESPONSE PLAN BUT WILL AID IN IDENTIFYING DEFICIENCIES IN CURRENT PLANS.

- 17-1-2-19 PARTIAL BLOCKAGES IN LMFBR FUEL ASSEMBLIES
FONTANA, M. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
EXPERIMENTAL AND ANALYTICAL DATA ON THE EFFECTS OF PARTIAL BLOCKAGES IN SIMULATED LIQUID METAL COOLED FAST BREEDER REACTOR ROD BUNDLES ARE REVIEWED AND THE RESULTS PRESENTED. EXPERIMENTS PERFORMED IN THE FUEL FAILURE MOCKUP AT OAK RIDGE NATIONAL LABORATORY WITH 19- AND 24-SUBCHANNEL INLET BLOCKAGES IN 19-ROD SODIUM COOLED ELECTRICALLY HEATED ROD BUNDLES INDICATE THAT EXCESSIVE TEMPERATURES DO NOT OCCUR AS A RESULT OF THE BLOCKAGES. SIMILAR EXPERIMENTS WITH NONHEAT GENERATING BLOCKAGES OF 6 CENTRAL SUBCHANNELS AND 14 EDGE SUBCHANNELS IN THE HEATED ZONE OF THE ROD BUNDLE INDICATE ACCEPTABLE LOCAL TEMPERATURE INCREASES AT OPERATING CONDITIONS. EXPERIMENTS WITH WATER MOCKUPS SHOW COMPLEX FLOW PATTERNS IN THE WAKE ZONE BEHIND BLOCKAGES. ESTIMATES OF LOCAL CONVECTIVE HEAT TRANSFER IN THE WAKE ZONE WERE MADE BY MEASURING MASS INTERCHANGE BETWEEN THE RECIRCULATING FLOW ZONE AND THE FREE STREAM BY SALT INJECTION TECHNIQUES. GENERALIZATIONS OBTAINED FROM THE WATER MOCKUPS WERE USED TO PREDICT TEMPERATURES IN SODIUM COOLED ROD BUNDLES. ESTIMATES INDICATE THAT LARGE BLOCKAGES (APPROXIMATELY 3 IN. IN DIAMETER) WOULD BE REQUIRED TO CAUSE SODIUM BOILING IN FULL SCALE REACTORS.
- 17-1-3-31 ACOUSTIC EMISSION - A CRITICAL ASSESSMENT
STAHLKOPF, K. E. + DAU, G. J.
ELECTRIC POWER RESEARCH INSTITUTE, PALO ALTO, CALIF.
THE PURPOSE OF THIS ARTICLE IS TO HIGHLIGHT THE LIMITATIONS OF ACOUSTIC EMISSION FOR USE IN HYDROSTATIC TEST MONITORING AND CONTINUOUS MONITORING OF PRESSURE VESSELS AS DETERMINED FROM A REVIEW OF PRIOR WORK. WITH THE PRESENT STATE OF THE ART FOR MONITORING STRUCTURAL INTEGRITY, ACOUSTIC EMISSION CAN PROBABLY REVEAL ABNORMAL INCIDENTS AND THEIR LOCATIONS, BUT IT CANNOT DESCRIBE THE INCIDENT OR ITS SERIOUSNESS. SPECIFIC CONCLUSIONS ABOUT THE MATURITY OF ACOUSTIC EMISSION MONITORING ARE DRAWN, AND SUGGESTIONS ARE GIVEN FOR FUTURE RESEARCH AND DEVELOPMENT EFFORTS.
- 17-1-3-43 ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QUO
MAGEN, E. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE PURPOSE OF REPORT WASH-1270 IS TO ENSURE A HIGH DEGREE OF RELIABILITY FOR THE PLANT SAFETY SYSTEMS OF WATER COOLED NUCLEAR POWER PLANTS TO PROTECT THE HEALTH AND SAFETY OF THE PUBLIC. IMPLEMENTATION OF THE REQUIREMENTS SET FORTH IN THE COVER LETTER SENT WITH THAT REPORT TO THE POWER UTILITIES HAS BEEN PROPOSED BY THE UTILITIES, AND REVIEWS OF THESE RESPONSES AND ANALYSES ARE UNDER CONSIDERATION BY THE NUCLEAR REGULATORY COMMISSION. ACCEPTANCE OF THE UTILITIES' POSITIONS HAS NOT BEEN GRANTED. NRC HAS FURTHER GUIDANCE OR DIRECTION BEEN PROPOSED FOR POWER PLANTS NOW OPERATING OR UNDER CONSTRUCTION. FUTURE PLANTS APPARENTLY WILL HAVE TO INCORPORATE SOME AS YET UNDEFINED DESIGN FOR A DUAL ACTING PLANT SAFETY SYSTEM.
- 17-1-4-55 THE SAFETY OF REACTOR PRESSURE VESSELS
COOPER, L. F. + LANGER, B. J.
TELEDYNE MATERIALS RESEARCH COMPANY, WALTHAM, MASS.
WE BELIEVE THAT NUCLEAR REACTOR VESSELS ARE SAFE. DEBATE ON THIS SUBJECT HAS RANGED FROM PURELY EMOTIONAL ARGUMENTS TO LENGTHY AND COMPLICATED STATISTICAL STUDIES. THE PRESENT PAPER WAS PREPARED AS A SUMMARY STATEMENT WITHOUT TECHNICAL DETAIL, BUT WITH A BRIEF DESCRIPTION OF THE TECHNOLOGY AND OF THE MANNER IN WHICH THE TECHNOLOGY IS IMPLEMENTED IN VESSEL CONSTRUCTION.
- 17-1-4-62 IMPROVING REACTOR PRESSURE VESSEL AVAILABILITY BY DESIGN
COOPER, L. F.
TELEDYNE MATERIALS RESEARCH COMPANY, WALTHAM, MASS.
ALTHOUGH REACTOR PRESSURE VESSELS ARE SAFE, THEY PRESENTLY CONTRIBUTE TO THE UNAVAILABILITY TIME OF NUCLEAR POWER SYSTEMS. THIS EFFECT COULD BE REDUCED SIGNIFICANTLY BY BETTER APPLICATION OF THE NOW AVAILABLE DESIGN TECHNOLOGY. THIS ARTICLE BRIEFLY DESCRIBES THE STATUS OF THIS TECHNOLOGY, AS PERTINENT TO REACTOR PRESSURE VESSEL AVAILABILITY, AND THE APPLICATION OF THIS TECHNOLOGY DURING THE CONSTRUCTION AND OPERATION PHASES. RECOMMENDATIONS ARE THEN MADE AS TO HOW THIS TECHNOLOGY COULD BE APPLIED TO IMPROVING VESSEL AVAILABILITY.
- 17-1-5-68 TURBULENT DIFFUSION TYPING SCHEMES - A REVIEW
GIFFORD, F. A.
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION, OAK RIDGE, TENN.
RECENT ENVIRONMENTAL CONCERNS HAVE GREATLY INCREASED THE NEED FOR TURBULENT TYPING SCHEMES IN ATMOSPHERIC DIFFUSION CALCULATIONS. THE STANDARD METHODS OF BROOKHAVEN NATIONAL LABORATORY, P. SQUILL, THE TENNESSEE VALLEY AUTHORITY, AND OTHERS ARE REVIEWED, AND DIFFERENCES, INCONSISTENCIES, AND MODIFICATIONS TO THE BASIC SCHEMES ARE DISCUSSED. VARIOUS EXCEPTIONAL FLOWS OCCUR TO WHICH EXISTING TURBULENCE TYPING

SCHEMES SHOULD NOT BE APPLIED DIRECTLY - DIFFUSION IN NEAR CALM, VERY STABLE CONDITIONS, DIFFUSION OVER CITIES, WATER BODIES, AND IRREGULAR TERRAIN, AND DIFFUSION IN BUILDING WAKES AND NEAR HIGHWAYS. POSSIBLE MODIFICATIONS TO TYPING SCHEMES IN THESE CASES ARE DISCUSSED. IN ALL SUCH EXCEPTIONAL CASES, MANY MORE OBSERVATIONAL DATA ARE NEEDED BEFORE RELIABLE DIFFUSION ESTIMATES CAN BE MADE.

17-1-6-87

QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLANT

MCGLOTHLIN, C. K.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE EXAMINES THE SMOKE CAUSE ORDER ISSUED BY THE DIRECTOR OF REGULATION OF THE ATOMIC ENERGY COMMISSION (AEC) IN 1975 AND THE ACTIONS TAKEN BY THE AEC (NOW NUCLEAR REGULATORY COMMISSION), THE OWNER, THE ARCHITECT ENGINEER, AND OTHERS IN IDENTIFYING AND RESOLVING CERTAIN QUALITY DEFICIENCIES THAT HAVE OCCURRED SINCE 1970 IN THE DESIGN AND CONSTRUCTION PHASES OF THE MIDLAND NUCLEAR POWER PLANT. IMPROVEMENTS IN THE MIDLAND QUALITY ASSURANCE PROGRAM, WHICH RESULTED IN A RULING BY THE AEC REGULATORY STAFF IN FAVOR OF THE OWNER, ARE DISCUSSED.

17-1-6-92

SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSONNEL

ROTH, D. R.

GENERAL PHYSICS CORPORATION, COLUMBIA, MD.

THIS ARTICLE IS A REVIEW OF THE SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSONNEL, HELD MAY 11-14, 1975, AT GAITHERSBURG, TENN. THE SYMPOSIUM, COSPONSORED BY THE OAK RIDGE NATIONAL LABORATORY AND THE AMERICAN NUCLEAR SOCIETY'S REACTOR OPERATIONS DIVISION AND OAK RIDGE SECTION, WAS ATTENDED BY UTILITY AND INDUSTRY REPRESENTATIVES AS WELL AS BY MEMBERS OF GOVERNMENT AND REGULATORY AGENCIES. IN ADDITION TO SOURCES, SELECTION, AND TRAINING OF PERSONNEL AT NUCLEAR UTILITIES, TRAINING OF OPERATORS AT FUEL PROCESSING PLANTS WAS INCLUDED. THE EDUCATIONAL COMMUNITY PRESENTED SOME NEW APPROACHES TO SUPPLYING QUALIFIED PERSONNEL FOR THE INDUSTRY, AND UTILITY PROGRAMS FOR TRAINING OF SUPPORT AND NONLICENSED PERSONNEL WERE DISCUSSED. AS EVIDENCED BY THE SYMPOSIUM, THERE IS A CONTINUING STRONG INTEREST IN EFFECTIVE TRAINING PROGRAMS. PROGRESS HAS BEEN MADE IN MANY AREAS, BUT SOURCES OF TRAINED PERSONNEL AND EVOLVING REGULATORY REQUIREMENTS CONTINUE TO BE A PROBLEM.

17-2-1-143

WATER REACTOR SAFETY RESEARCH INFORMATION MEETING

COTTRELL, W. B.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE IS A REVIEW OF THE THIRD WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE NUCLEAR REGULATORY COMMISSION (NRC) DIVISION OF REACTOR SAFETY RESEARCH, HELD AT THE NATIONAL BUREAU OF STANDARDS, GAITHERSBURG, MD., SEPT. 29-OCT. 2, 1975. THIS MEETING CONSISTED OF PARALLEL TECHNICAL PRESENTATIONS IN THE MORNING, FOLLOWED BY SEVERAL SMALLER WORKSHOPS OR DISCUSSION SESSIONS IN THE AFTERNOON. THE TECHNICAL SESSIONS WERE (1) LOSS OF COOLANT ACCIDENT TEST PROGRAM, (2) FUEL BEHAVIOR PROGRAM, (3) ANALYSIS DEVELOPMENT PROGRAM, AND (4) METALLURGY AND MATERIALS PROGRAM. OVER 575 PERSONS, INCLUDING SOME 95 FOREIGN VISITORS FROM 16 COUNTRIES, ATTENDED THE MEETING. SUMMARIES OF MOST OF THE MORNING SESSIONS, WHICH WERE AVAILABLE AT THE MEETING, HAVE BEEN FURTHER CONDENSED AND REFERENCED IN THIS ARTICLE, TOGETHER WITH SOME COMMENTARIES ON SOME OF THE AFTERNOON DISCUSSIONS. NO PROCEEDINGS WILL BE PUBLISHED. SPECIAL FEATURES OF THE MEETING, IN ADDITION TO THE REVIEW OF NRC SPONSORED WATER REACTOR SAFETY RESEARCH PROGRAMS, WERE EIGHT INVITED PAPERS BY INTERNATIONAL EXPERTS, AND INCREASED PARTICIPATION BY BOTH THE U.S. NUCLEAR INDUSTRY AND THE VARIOUS NRC SESSION CHAIRMEN WHO WERE ADMINISTRATIVELY RESPONSIBLE FOR THE WORK IN QUESTION. MANY PROBLEMS AND PROGRAMS WERE DISCUSSED, AND MUCH WAS LEARNED. IT IS REASSURING THAT THESE RESEARCH RESULTS CONTINUE TO SUBSTANTIATE OUR UNDERSTANDING OF REACTOR SAFETY.

17-2-1-174

COMPARATIVE RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF ELECTRICAL ENERGY

NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS STUDY QUANTIFIES, NORMALIZES, AND COMPILES CONVENTIONAL AND SOCIETAL COSTS ASSOCIATED WITH THE PRODUCTION OF ELECTRICAL ENERGY BY CURRENTLY AVAILABLE ALTERNATIVE SYSTEM BASED ON COAL, GAS, NUCLEAR FUELS, AND HYDROENERGY. PARTICULAR EMPHASIS IS PLACED ON EXAMINING EACH ENERGY SYSTEM IN ITS ENTIRETY - BOTH THE POWER PLANT AND ITS SUPPORTING FUEL CYCLE. HOWEVER, THE STUDY IS RESTRICTED TO ROUTINE IMPACTS, INCLUDING ROUTINE ACCIDENTS WHOSE FREQUENCIES CAN BE ESTABLISHED FROM HISTORICAL DATA. FROM THE AVAILABLE DATA, WHICH ARE THOROUGHLY REFERENCED HEREIN, IT IS CONCLUDED THAT NATURAL GAS INCURS MINIMAL ENVIRONMENTAL- AND HUMAN-IMPACT COSTS BUT REMAINING SUPPLIES ARE SMALL. OIL PRESENTS CONSIDERABLY GREATER ENVIRONMENTAL AND HUMAN IMPACTS BUT SUBSTANTIALLY LESS THAN THOSE FROM COAL, WHICH IS BOTH THE MOST SERIOUS ENVIRONMENTAL OFFENDER AND THE MOST ABUNDANT DOMESTIC FUEL SOURCE. NUCLEAR FUELS, WHICH ARE ABUNDANT NATURAL RESOURCES, HAVE SOMEWHAT LESS ENVIRONMENTAL AND HUMAN IMPACTS THAN GAS. THE CONVENTIONAL FUEL COSTS OF COAL AND NUCLEAR FUEL CYCLES ARE COMPARABLE AND CONSIDERABLY LESS EXPENSIVE THAN GAS OR OIL, BUT IT APPEARS THAT THE COST OF

STATEMENT AND HEALTH AND SAFETY MEASURES WILL SIGNIFICANTLY INCREASE THE COST OF ENERGY FROM COAL OVER THAT FROM NUCLEAR FUEL.

- 17-2-2-185 STEAM - WATER MIXING STUDIES RELATED TO EMERGENCY CORE COOLING SYSTEM PERFORMANCE
CUONIK, R. A. + CARBIENER, W. A.
BATTELLE COLUMBUS LABORATORIES, COLUMBUS, OHIO
THIS ARTICLE IS A REVIEW OF RECENT EXPERIMENTAL WORK RELATED TO THE INTERACTIONS BETWEEN THE PRIMARY SYSTEM FLUID AND EMERGENCY CORE COOLING (ECC) WATER IN LIGHT WATER REACTOR SYSTEMS DURING RECOVERY FROM A POSTULATED LOSS OF COOLANT ACCIDENT. THE TESTING PROGRAMS ARE EXPLORATORY SEPARATE EFFECTS TESTS IN REDUCED SIZE SIMULATORS OF REACTOR SYSTEMS. THE TESTS ADDRESS THE COLD-LEG MANOMETER LOOP, THE COLD-LEG PIPE ECCS INJECTION SECTION, AND THE DOWNCOMER ANNULUS LOWER PLENUM REGIONS OF REACTOR SYSTEMS. DATA TO DATE INDICATE THE ABSENCE OF COLD-LEG PIPE PLUGGING, THE PRESENCE OF OSCILLATORY FLOW BEHAVIOR INITIATED BY FULL PIPE FLOW, AND THE PREDOMINANT ROLE OF CONDENSATION IN BOTH THE INJECTION SECTION AND ANNULUS REGIONS.
- 17-2-2-194 THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT ANALYSIS
SOLBRIG, C. W. + HARNUP, D. J.
AEROSJET NUCLEAR COMPANY, IDAMO FALLS, IDAHO
THE RELAP4 COMPUTER CODE IS A VERY USEFUL TOOL FOR NUCLEAR SAFETY ANALYSIS. IT IS USED PRINCIPALLY IN THE ANALYSIS OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT BUT IS ALSO USED IN SEVERAL OTHER APPLICATIONS. THIS ARTICLE IS THE FIRST OF A THREE PART SERIES WHICH DISCUSSES, RESPECTIVELY, THE RELAP4 PROGRAM, INPUT MODELING, AND TYPICAL RESULTS, AND IS DIRECTED TOWARD THE POTENTIAL CODE USER. THIS ARTICLE DESCRIBES THE BASIC FLUID MODEL, THE IMPROVEMENTS OVER ITS PREDECESSOR, RELAP3, AND A FURTHER MODIFICATION, RELAP-EM, SPECIFICALLY DESIGNED TO PRODUCE CONSERVATIVE RESULTS. RELAP4 IS COMPARED TO OTHER SIMILAR CODES, AND THE GENERIC LIMITATIONS OF THESE CODES ARE NOTED. HOWEVER, IT IS CONCLUDED THAT RELAP4 IS AN EXAMPLE OF THE BETTER CURRENT NUCLEAR SAFETY CODES.
- 17-2-4-208 EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTORS
CHAPMAN, R. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
CONCEPTS AND PRACTICES USED IN THE DESIGN OF EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTOR (LMFBR) SYSTEMS WERE SURVEYED TO ASCERTAIN THE MANNER BY WHICH THE FUNCTIONAL REQUIREMENTS WERE SATISFIED, THE SEVERITY OF SODIUM SPILLS THE LINERS WERE DESIGNED TO ACCOMMODATE, AND THE PROBLEMS ENCOUNTERED IN DESIGN AND CONSTRUCTION. THE SURVEY WAS LIMITED TO 'LOOP-TYPE' LMFBRs, WITH PRIMARY INTEREST ON RECENTLY CONSTRUCTED PLANTS. THIS ARTICLE IS ESSENTIALLY THE INTRODUCTION AND SUMMARY OF A STATE OF THE ART REPORT THAT DISCUSSES STEEL LINED CONCRETE STRUCTURES, DESCRIBES CELL LINER DESIGNS USED IN SEVERAL LMFBR PLANTS, WITH PARTICULAR EMPHASIS ON THE SOUTHWEST EXPERIMENTAL FAST OXIDE REACTOR (SEFOR), WHICH USES A FIXED LINER, AND THE FAST FLUX TEST FACILITY (FFTF), WHICH USES A FREE FLOATING LINER, AND IDENTIFIES RESEARCH AND DEVELOPMENT BELIEVED NECESSARY TO PERMIT A RATIONAL AND THOROUGH ASSESSMENT OF CELL LINER DESIGN CONCEPTS.
- 17-2-5-216 RADIOLOGICAL ASPECTS OF ENVIRONMENTAL TRITIUM
RUMER, P. S. + WILCOX, W. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE POTENTIAL RADIOLOGICAL IMPLICATIONS OF TRITIUM RELEASED TO THE ENVIRONMENT MUST BE ASSESSED TO DEVELOP A POLICY FOR MANAGING THE TRITIUM INVENTORY PROJECTED FOR THE NUCLEAR POWER INDUSTRY, WHICH ALREADY PRODUCES TRITIUM IN MEGACURIE QUANTITIES ANNUALLY. DEVELOPMENT OF FUSION REACTORS WILL CREATE LARGE POTENTIAL SOURCES FOR CONTINUOUS AND PULSE RELEASES OF TRITIUM, MUCH OF IT AS TRITIUM GAS. AT PRESENT 90 PERCENT OF THE TRITIUM PRODUCED IS RELEASED IN GASEOUS AND LIQUID EFFLUENTS TO BE DEPOSITED IN THE HYDROSPHERE AS TRITIATED WATER. TWO ALTERNATIVES MUST BE CONSIDERED RELATIVE TO A LONG TERM POLICY FOR TRITIUM MANAGEMENT. ONE METHOD IS TO DILUTE AND DISPERSE THE TRITIUM FROM POWER STATIONS AND NUCLEAR FUEL REPROCESSING PLANTS AT A RATE COMMENSURATE WITH PRODUCTION AT THE FACILITY, AND THE SECOND METHOD IS TO TAKE STEPS TO CONTAIN THE TRITIUM FOR STORAGE. IN THIS ARTICLE A NUMBER OF FACTORS THAT INFLUENCE THE MAGNITUDE OF THE ESTIMATED RADIOLOGICAL IMPACT OF TRITIUM ON MAN ARE DISCUSSED, AND KEY POINTS CONCERNING THE BEHAVIOR OF TRITIUM ALONG THE EXPOSURE PATHWAYS TO MAN ARE SUMMARIZED. BIOACCUMULATION FACTORS FOR TRITIUM APPROXIMATE UNITY FOR ALL HYDROGEN POOLS IN SPITE OF THE LARGE MASS DIFFERENCE OF TRITIUM RELATIVE TO PROTIUM. THE QUALITY FACTOR FOR TRITIUM RELATING LINEAR ENERGY TRANSFER AND BIOLOGICAL EFFECTIVENESS IS CURRENTLY 1.0. HOWEVER, THE POSSIBLE NEED FOR A LARGER QUALITY FACTOR, PARTICULARLY FOR LOW DOSES AND DOSE RATES, IS ACKNOWLEDGED. OTHER TOPICS DISCUSSED INCLUDE TRANSMUTATION AND POSITION EFFECTS, UNCERTAINTIES CONCERNING THE OXIDATION RATE OF TRITIUM GAS IN THE ENVIRONMENT, THE POSSIBLE IMPORTANCE OF THE AGE OF THE EXPOSED INDIVIDUAL, AND CURRENT RADIATION SAFETY GUIDES THAT LIMIT THE EXPOSURE OF MAN TO TRITIUM. THE ESTIMATED DOSE TO MAN FROM ORGANICALLY BOUND TRITIUM IS THOUGHT TO INCREASE THE DOSE

ESTIMATES CALCULATED ON THE BASIS OF TISSUE WATER TRITIUM ALONE BY APPROXIMATELY 20 PERCENT. THUS THE ESTIMATED TOTAL DOSE TO MAN FOR INTAKES OF ENVIRONMENTAL TRITIUM IS 0.07 MREM/MICRO-CURIES.

- 17-2-5-223 A SURVEY OF FIELD MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED INVERSION CONDITIONS
VAN DER MEYEN, I.
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION, SILVER SPRING, MD.
MEASURED PLUME PEAK CONCENTRATIONS FROM FIVE SEPARATE FIELD EXPERIMENTS UNDER LOW WIND SPEED INVERSION CONDITIONS ARE ANALYZED AND COMPARED WITH COMPUTATIONS BASED ON DIFFUSION PARAMETER-TYPING PROCEDURES CURRENTLY IN USE BY THE U.S. NUCLEAR REGULATORY COMMISSION. IN ALL CASES THE MEASURED CONCENTRATIONS FROM GROUND SOURCES WERE LOWER THAN CALCULATED VALUES, THE DIFFERENCE BEING PRIMARILY DUE TO ENHANCED CROSSWIND SPREAD. MOREOVER, THE DIFFERENCES APPEARED TO BE A FUNCTION OF SURFACE ROUGHNESS, BEING GREATEST OVER HILLY FORESTED TERRAIN.
- 17-2-6-231 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974
MARE, M. G.
CHALK RIVER NUCLEAR LABORATORIES, ONTARIO, CANADA
STEAM GENERATOR TUBE FAILURES WERE REPORTED AT 25 OF 59 WATER COOLED NUCLEAR POWER REACTORS SURVEYED IN 1974, COMPARED TO 11 OF 49 IN 1973. THIS ARTICLE SUMMARIZES THESE FAILURES, MOST OF WHICH, WHERE THE CAUSE IS KNOWN, WERE THE RESULT OF CORROSION, WATER CHEMISTRY CONTROL, INSPECTION AND REPAIR PROCEDURES, AND FAILURE RATES ARE DISCUSSED.
- 17-3-1-201 ATMOSPHERIC RELEASE ADVISORY CAPABILITY
OICKERSON, M. H. & ORPHAN, R. C.
LAWRENCE LIVERMORE LABORATORY, LIVERMORE, CALIF.
THE ATMOSPHERIC RELEASE ADVISORY CAPABILITY (ARAC) IS A CONCEPT FOR A SERVICE TO FACILITIES REQUIRING A MEANS OF REAL TIME PREDICTION OF THE EXTENT OF HEALTH HAZARDS THAT MAY RESULT FROM A RELEASE OF RADIONUCLIDES OR OTHER TOXIC MATERIALS. THE ARAC SYSTEM, SPONSORED BY THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION (ERDA), CONSISTS OF A NETWORK OF SERVICED SITE FACILITIES AND A CENTRAL FACILITY LOCATED AT THE UNIVERSITY OF CALIFORNIA, LAWRENCE LIVERMORE LABORATORY (LLL). SINCE 1973, WHEN THE CONCEPT WAS INITIATED, A JOINT FEASIBILITY STUDY OF THE ARAC SYSTEM HAS BEEN CONDUCTED BY LLL AND SAVANNAH RIVER LABORATORY (SRL), A SYSTEM OF THREE SITES, LLL, SRL, AND THE ROCKY FLATS PLANT, IS BEING TESTED AND EVALUATED DURING FY 1976. PLANS ARE READY TO IMPLEMENT THE ARAC SERVICE FOR ADDITIONAL ERDA NUCLEAR FACILITIES OVER THE NEXT 3 YEARS. THIS ARTICLE BRIEFLY DESCRIBES THE ARAC CONCEPT, DISCUSSES THE PROGRESS TO DATE, AND OUTLINES FUTURE PLANS FOR DEVELOPING THE SYSTEM.
- 17-3-1-209 AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975
KEINOLTZ, G. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE BRIEFLY REVIEWS THE AMERICAN NUCLEAR SOCIETY TOPICAL MEETING ON NUCLEAR SAFETY HELD AT TUCSON, ARIZ., OCT. 5-8, 1975. A COMPREHENSIVE SURVEY WAS MADE OF SAFETY ASPECTS OF THE CONTEMPORARY UTILIZATION OF NUCLEAR ENERGY, WITH EMPHASIS ON FUEL PROCESSING AND TRANSPORT, REACTOR PLANT SAFETY, AND NUCLEAR WASTE MANAGEMENT. INVITED SPEAKERS FROM INDUSTRY, UTILITIES, AND GOVERNMENT DISCUSSED SUBJECTS BASED ON THE EXPERIENCE OF THE LIGHT WATER AND GAS COOLED REACTOR INDUSTRIES. THE INTERNATIONAL PROGRAMS IN KEY AREAS WERE COVERED.
- 17-3-2-299 THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT MODEL
BARNUM, D. J. & SOLBRIG, C. W.
AEROSJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO
THE RELAP4 COMPUTER CODE IS AN IMPORTANT ANALYSIS TOOL FOR NUCLEAR SAFETY ANALYSIS. IT IS USED PRINCIPALLY IN THE ANALYSIS OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT BUT IS ALSO USED IN SEVERAL OTHER APPLICATIONS. THIS ARTICLE IS THE SECOND OF A THREE PART SERIES WHICH DISCUSSES, RESPECTIVELY, THE RELAP4 PROGRAM, INPUT MODELING, AND TYPICAL RESULTS. IN THIS ARTICLE IS DESCRIBED SOME OF THE CONSIDERATIONS REQUIRED TO MODEL A THERMAL AND HYDRAULIC SYSTEM WITH PARTICULAR EMPHASIS IN LIGHT WATER NUCLEAR POWER REACTORS. ENGINEERING DECISIONS REQUIRED IN PREPARING INPUT ARE AS IMPORTANT IN THE FINAL CODE RESULTS AS THE CODE ITSELF. CODES THAT ARE SIMILAR TO RELAP4 MENTIONED IN PART 1) REQUIRE SIMILAR INPUT CONSIDERATIONS. THE ARTICLE'S CONCLUSION IS THAT THE INPUT DESCRIPTION OF A SYSTEM IS NOT UNIQUE, AND DIFFERENT MODELERS WOULD PRODUCE DIFFERENT INPUT WITH CONSEQUENT DIFFERENT OUTPUT. HOWEVER, IT IS ALWAYS POSSIBLE TO OBTAIN CONSERVATIVE RESULTS, IF DESIRED, WITH THE USE OF THE EVALUATION MODEL (EM) VERSION OF THE CODE.
- 17-3-2-312 AIRCRAFT CRASH PROBABILITIES
(EDITOR'S NOTE - A COMPREHENSIVE REVIEW OF THE RISK OF AIRCRAFT CRASH TO NUCLEAR POWER PLANTS WAS PRESENTED IN NUCLEAR SAFETY 1973). THE PRESENT ARTICLE IS TAKEN FROM THE NRC REACTOR SAFETY STUDY AND SUMMARIZES THE PROCEDURE FOLLOWED BY THE REGULATORY

STAFF IN ASSESSING AIRCRAFT RISK AND ALSO TABULATES CRASH PROBABILITIES. SUCH INFORMATION IS NECESSARY FOR AN AIRCRAFT HAZARDS ANALYSIS AS DESCRIBED IN THE NRC REGULATORY GUIDE.)

17-3-3-315 HUMAN RELIABILITY ANALYSIS

THIS EDITED VERSION OF HUMAN RELIABILITY ANALYSIS WAS TAKEN FROM THE RISK ASSESSMENT ANALYSIS AS ORIGINALLY PRESENTED IN REPORT WASH-1400, THE REACTOR SAFETY STUDY. THE REFERENCES GIVEN IN THE REPORT ARE SUPPLEMENTED BY THOSE IN THE POSTSCRIPT, AND A SHORT BIBLIOGRAPHY IS APPENDED.

17-3-4-327 NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VESSEL STEELS
STEELE, L. E.

NAVAL RESEARCH LABORATORY, WASHINGTON, D. C.

THE FUTURE OF NUCLEAR POWER DEPENDS IMPORTANTLY ON THE ASSURANCE OF SAFETY AND RELIABILITY. THE PRIMARY PRESSURE BOUNDARY, ESPECIALLY THE CORE REGION PRESSURE VESSEL, MUST WITHSTAND THE USUAL SERVICE CONDITIONS PLUS NEUTRON RADIATION, WHICH EMBRITTLES, HARDENS, AND STRENGTHENS THE STEEL USED IN THE PRESSURE VESSEL. THIS ARTICLE REVIEWS THE CRITICAL FACTORS ASSOCIATED WITH RADIATION EMBRITTLEMENT AND THE MEASURES THAT CAN BE TAKEN TO MINIMIZE THIS EFFECT AND THUS ENHANCE SYSTEM SAFETY FOR LIGHT WATER REACTORS.

17-3-5-344 IDENTIFICATION OF POTENTIAL IMPROVEMENTS IN ENVIRONMENTAL SURVEILLANCE TECHNIQUES

HAITE, D. A. + DENHAM, D. M.

PACIFIC NORTHWEST LABORATORIES, RICHLAND, WASH.

IN THE LAST 2 YEARS, SEVERAL POLLS WERE TAKEN AMONG DIFFERENT COMPONENTS OF THE APPLIED ENVIRONMENTAL SURVEILLANCE COMMUNITY TO IDENTIFY AREAS OF ENVIRONMENTAL SURVEILLANCE METHODOLOGY WHICH DESERVE PRESENT AND FUTURE INVESTIGATIONAL EMPHASIS. "PROGRAM DESIGN RATIONALE," "DATA HANDLING AND INTERPRETATION," AND "QUALITY CONTROL" CONSISTENTLY RANKED 1, 2, AND 3. "SAMPLING" AND "SAMPLE ANALYSIS" RANKED 4 AND 5. IMPROVEMENTS IN PROGRAM RATIONALE AND DATA INTERPRETATION METHODOLOGY ARE CURRENTLY BEING EFFECTED THROUGH THE USE OF CRITICAL PATHWAY ANALYSIS AND DISTRIBUTION ANALYSIS. THE USE OF EXISTING REGIONAL ENVIRONMENTAL SURVEILLANCE DATA AND FAST KNOWLEDGE OF CONTAMINANT TRANSPORT CHARACTERISTICS MAKES THE PROCESS OF ELIMINATING NONCRITICAL CONTAMINANTS AND MEDIA RELATIVELY SIMPLE, SO THAT FURTHER INVESTIGATION OF CRITICAL PATHWAYS AND CONTAMINANTS CAN BE EMPHASIZED. DISTRIBUTION ANALYSIS CAN BE USED WITH CONFIDENCE FOR INTERPRETING THE DATA IN TERMS OF SAMPLE REPRESENTATIVENESS AND FOR THE IDENTIFICATION OF TYPICAL ENVIRONMENTAL LEVELS (FROM GEOMETRIC MEANS) AND EXPECTED UPPER LIMITS (STANDARD GEOMETRIC DEVIATIONS).

17-3-5-351 RADIATION DOSES AND EFFECTS ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILITIES

BLAYLOCK, R. G. + WITHERSPON, J. P.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

AQUATIC ORGANISMS ARE EXPOSED TO RADIONUCLIDES RELEASED TO THE ENVIRONMENT DURING VARIOUS STEPS OF THE NUCLEAR FUEL CYCLE. ROUTINE RELEASES FROM THESE PROCESSES ARE RESTRICTED IN COMPLIANCE WITH THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION, WHICH RECOMMENDS LIMITS FOR RADIATION DOSES TO THE GENERAL PUBLIC. IT IS GENERALLY ACCEPTED THAT AQUATIC ORGANISMS WILL NOT RECEIVE DAMAGING EXTERNAL RADIATION DOSES IN SUCH ENVIRONMENTS. BECAUSE OF THE POSSIBLE BIOACCUMULATION OF RADIONUCLIDES, HOWEVER, THERE IS CONCERN THAT AQUATIC ORGANISMS MIGHT BE ADVERSELY AFFECTED BY INTERNAL DOSES. THE OBJECTIVES OF THIS ARTICLE ARE (1) TO ESTIMATE THE RADIATION DOSE RECEIVED BY AQUATIC BIOTA FROM THE DIFFERENT PROCESSES AND TO DETERMINE THE MAJOR DOSE CONTRIBUTING RADIONUCLIDES AND (2) TO ASSESS THE IMPACT OF ESTIMATED DOSES ON AQUATIC BIOTA. DOSE ESTIMATES ARE MADE BY USING MEASUREMENTS OF RADIONUCLIDE CONCENTRATIONS IN THE LIQUID EFFLUENTS OF REPRESENTATIVE FACILITIES. WHERE SUCH MEASUREMENTS ARE NOT AVAILABLE, PREDICTED RADIOACTIVE RELEASES TO THE AQUATIC ENVIRONMENT ARE USED. ALTHOUGH RADIOACTIVE RELEASES FROM REACTORS USED TO GENERATE ELECTRICAL ENERGY HAVE RECEIVED THE MOST ATTENTION AND ARE THE BEST DOCUMENTED, THIS EVALUATION SHOWS THE POTENTIAL FOR A GREATER RADIATION DOSE TO AQUATIC BIOTA FROM THE NUCLEAR FUEL-SUPPLY FACILITIES (I.E., MINING AND MILLING). THE EFFECTS OF CHRONIC LOW LEVEL RADIATION ON AQUATIC ORGANISMS ARE DISCUSSED FROM SOMATIC AND GENETIC VIEWPOINTS. ON THE BASIS OF THE BODY OF RADIOBIOLOGICAL EVIDENCE ACCUMULATED TO DATE, NO SIGNIFICANT DELETERIOUS EFFECTS ARE PREDICTED FOR POPULATIONS OF AQUATIC ORGANISMS EXPOSED TO THE ESTIMATED DOSE RATES RESULTING FROM ROUTINE RELEASES FROM CONVERSION, ENRICHMENT, FABRICATION, REACTOR AND REPROCESSING FACILITIES. AT THE DOSES ESTIMATED FOR MILLING AND MINING OPERATIONS, IT WOULD BE DIFFICULT TO DETECT RADIATION EFFECTS ON AQUATIC POPULATIONS. HOWEVER, THE SIGNIFICANCE OF SUCH RADIATION EXPOSURES TO AQUATIC POPULATIONS CANNOT BE FULLY EVALUATED WITHOUT FURTHER RESEARCH ON EFFECTS OF CHRONIC LOW LEVEL RADIATION.

- 17-3-6-363 THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTOR INDUSTRIES
BAKER, R. R.
U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D.C.
THIS ARTICLE REVIEWS SAFETY RELATED DATA FOR 1973 AND 1974 COLLECTED FROM PRIVATE INDUSTRIES ENGAGED IN THE PRODUCTION OF URANIUM FUEL OR REACTOR COMPONENTS FOR COMMERCIAL NUCLEAR POWER REACTORS. OCCUPATIONAL INJURY AND ILLNESS INCIDENCE RATES CALCULATED FROM THE DATA ARE COMPARED WITH THOSE OF OTHER INDUSTRIES. RADIOLOGICAL HEALTH DATA ARE ALSO PRESENTED AND DISCUSSED.
- 17-4-1-411 NUCLEAR ENERGY CENTER SITE SURVEY - 1975
NRC OFFICE OF SPECIAL STUDIES, WASHINGTON, DC
(EDITOR'S NOTE - THE ENERGY REORGANIZATION ACT OF 1974 REQUIRED THE NEWLY ESTABLISHED U.S. NUCLEAR REGULATORY COMMISSION (NRC) TO UNDERTAKE A NUCLEAR ENERGY CENTER SITE SURVEY. THAT SURVEY AND THE CONCOMITANT CONSIDERATIONS ARE CONTAINED IN USNRC REPORT NUREG-00001 PUBLISHED JANUARY 1976 AND SOLD BY NTIS. THE FINAL REPORT INCLUDES SEVERAL SEPARATE DOCUMENTS AS FOLLOWS - EXECUTIVE SUMMARY (20 PAGES), \$4.00. PART I, SUMMARY AND CONCLUSIONS (220 PAGES), \$8.00. PART II, APPENDIX A, U.S. MAP COARSE SCREENING RESULTS, \$3.50. PART II, THE U.S. ELECTRIC POWER SYSTEM AND THE POTENTIAL ROLE OF NUCLEAR ENERGY CENTERS (225 PAGES), \$8.00. PART III, TECHNICAL CONSIDERATIONS (615 PAGES), \$16.75. PART IV, PRACTICAL ISSUES OF IMPLEMENTATION (100 PAGES), \$18.75. PART V, RESOURCE AVAILABILITY AND SITE SCREENING (230 PAGES), \$8.00. INCLUDED IN THIS ARTICLE (WITH MINOR EDITING) ARE SEC. 1, INTRODUCTION AND RESULTS, FROM THE EXECUTIVE SUMMARY, A U.S. MAP CONTAINING THE COARSE SCREENING RESULTS, AND A BIBLIOGRAPHY OF THE LITERATURE ON NUCLEAR ENERGY CENTERS PREPARED BY THE NUCLEAR SAFETY INFORMATION CENTER. THE NRC REPORT INDICATES THAT NUCLEAR ENERGY CENTERS, WITH UP TO 20 NUCLEAR POWER REACTORS, CAN BE FEASIBLE AND PRACTICAL IN MANY LOCATIONS BUT THAT FEDERAL AND STATE PARTICIPATION WOULD PROBABLY BE REQUIRED TO FURTHER THE DEVELOPMENT OF A SUBSTANTIAL NUMBER OF CENTERS.)
- 17-4-2-422 THE RELAP4 COMPUTER CODE. III. LOCA ANALYSIS RESULTS OF A TYPICAL PWR PLANT
BAARUM, D. J., & SOLBRIG, C.
AEROSOL NUCLEAR COMPANY, IDAHO FALLS, IDAHO
THE RELAP4 COMPUTER PROGRAM IS A VALUABLE TOOL FOR USE IN NUCLEAR SAFETY ANALYSIS. IT IS USED PRINCIPALLY IN THE ANALYSIS OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT BUT IS ALSO USED IN SEVERAL OTHER APPLICATIONS. THIS ARTICLE IS THE LAST OF A THREE PART SERIES THAT DISCUSSES (1) THE RELAP4 PROGRAM, (2) INPUT MODELING, AND (3) TYPICAL RESULTS. THIS ARTICLE CONSIDERS THE INPUT REQUIRED TO MODEL A TYPICAL FIRM-LOOP PRESSURIZED WATER REACTOR, THE CALCULATIONAL RESULTS FOR THIS PLANT, AND THE PHYSICAL PHENOMENA THAT THESE RESULTS REPRESENT. THE CALCULATIONS WERE PERFORMED WITH THE STANDARD VERSION OF RELAP4 (THE LATEST PUBLICLY AVAILABLE VERSION) INSTEAD OF THE CONSERVATIVE VERSION USED FOR LICENSING. THE RESULTS ARE REPRESENTATIVE OF LARGE WATER REACTORS, BUT DIFFERENT DESIGNS WILL EXHIBIT DIFFERENT PHENOMENA.
- 17-4-3-437 RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH REACTOR
WERNER, R. A., & LOYALKO, S. R.
UNIVERSITY OF MISSOURI, COLUMBIA, MISSOURI
THE RELIABILITY ANALYSIS OF ANTICIPATED TRANSIENTS WITHOUT SCRAM IS A TOPIC OF CONSIDERABLE SIGNIFICANCE IN REACTOR SAFETY STUDIES. THIS ARTICLE DESCRIBES THE RESULTS OF A RECENTLY COMPLETED STUDY ON THE RELIABILITY OF THE MISSOURI UNIVERSITY RESEARCH REACTOR (MURR) SCRAM SYSTEM. FOR THIS REACTOR IT HAS BEEN DETERMINED THAT THE FAILURE TO INITIATE A SCRAM AUTOMATICALLY OR MANUALLY WITHIN 7.5 SEC OF AN ISOLATION VALVE CLOSURE CAN LEAD TO CORE MELTDOWN. SINCE VALVE CLOSURE IS A CREDIBLE ACCIDENT (IT HAS OCCURRED ONCE DURING THE PAST 5 YEARS), IT IS IMPORTANT TO KNOW THE RELIABILITY OF THE SCRAM SYSTEM. THE AUTHORS HAVE USED THE EVENT AND FAULT TREE METHODOLOGIES TO ANALYZE ACCIDENT SEQUENCES AND THE SCRAM SYSTEM. SEVERAL COMMON MODE FAILURES HAVE BEEN IDENTIFIED, AND THE AVAILABILITY PROBABILITIES FOR EACH PRIMARY EVENT WERE OBTAINED BY A DETAILED EXAMINATION OF THE MURR OPERATING RECORDS. DETAILED ANALYSIS SHOWS THAT THE MURR SCRAM SYSTEM IS HIGHLY RELIABLE AND COMPARES FAVORABLY WITH THE CORRESPONDING RESULTS FOR SURRY 1, WHICH WAS DISCUSSED IN THE REACTOR SAFETY STUDY.
- 17-4-4-447 RELATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO LWR SAFETY
MERKLE, J. G., & WHITMAN, G. C., & BRYAN, R. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
UNDER THE AUSPICES OF THE HEAVY-SECTION STEEL TECHNOLOGY PROGRAM AT OAK RIDGE NATIONAL LABORATORY, EIGHT INTERMEDIATE SIZED (4-16 IN. WALL THICKNESS AND 39-IN. OUTSIDE DIAMETER) STEEL PRESSURE VESSELS CONTAINING CAREFULLY PREPARED AND SHARPENED SURFACE CRACKS HAVE BEEN TESTED TO PROVIDE AN IMPROVED QUANTITATIVE BASIS FOR EVALUATING THE SAFETY MARGINS AGAINST FRACTURE OF NUCLEAR REACTOR PRESSURE VESSELS. THE CYLINDRICAL PORTIONS OF THE TEST VESSELS WERE FABRICATED FROM EITHER A508 CLASS 2 FORGING STEEL OR A533, GRADE B, CLASS 1 STEEL PLATE. THE FLAWS IN THE TEST VESSELS WERE 1.20 TO 5.30 IN. DEEP, AND

TEST TEMPERATURES RANGED FROM 32F TO 196F. EXTENSIVE FAST FRACTURE WAS OBSERVED, AS EXPECTED, AT 32F AT A PRESSURE NEAR THE GROSS YIELD PRESSURE OF THE TEST VESSEL, AND TWO VESSELS LEAKED WITHOUT FRACTURING AT OR SLIGHTLY ABOVE 190F. EXTENSIVE FRACTURE ANALYSES WERE PERFORMED ON ALL VESSELS. THE ANALYTICAL STUDIES PERFORMED INDICATE THAT, BELOW THE UPPER-SHELF TEMPERATURE RANGE, LINEAR ELASTIC FRACTURE MECHANICS (EXPRESSED IN TERMS OF STRAIN) IS ACCURATE OR CONSERVATIVE, DEPENDING ON TRANSVERSE RESTRAINT CONDITIONS PRIOR TO THE ONSET OF THROUGH THE THICKNESS YIELDING. IN ADDITION, IN THE CYLINDRICAL REGION OF A VESSEL, WITHIN THE UPPER SHELF TEMPERATURE RANGE, FAILURE IS CONTROLLED BY THE ONSET OF PLASTIC INSTABILITY IN THE REGION SURROUNDING THE FLAW IF THE UPPER SHELF TOUGHNESS IS SUFFICIENTLY HIGH. FOR SURFACE FLAWS OF LESS THAN HALF THE TEST VESSEL WALL THICKNESS IN DEPTH, FAILURE LOADS WERE APPROXIMATELY THREE TIMES THE CODE DESIGN PRESSURE OF THE TEST VESSELS. APPLICATION OF THE ANALYSIS PROCEDURES DEVELOPED FOR THESE TESTS ON INTERMEDIATE SIZED VESSELS TO A HYPOTHETICAL REACTOR PRESSURE VESSEL INDICATES THAT A SIMILAR MARGIN OF SAFETY IS INHERENT IN FULL SCALE VESSELS.

17-4-5-464 CURRENT STATUS OF THE PLUTONIUM HOT PARTICLE PROBLEM

RICHMOND, C. R.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

IN FEBRUARY 1974 THE NATURAL RESOURCES DEFENSE COUNCIL, INC. (NRDC), BROUGHT A PETITION TO THE ATTENTION OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY AND THE U.S. ATOMIC ENERGY COMMISSION WHICH CALLED FOR A REDUCTION IN RADIATION STANDARDS FOR INSOLUBLE, INHALED ALPHA EMITTING TRANSURANIUM ELEMENTS BY A FACTOR OF 115,000. THE PETITION TO AMEND RADIATION PROTECTION STANDARDS AS THEY APPLY TO HOT PARTICLES WAS SUBMITTED ALONG WITH A SUPPORTING DOCUMENT ENTITLED 'RADIATION STANDARDS FOR HOT PARTICLES.' THIS ARTICLE SUMMARIZES THE RESPONSES OF VARIOUS AGENCIES, ORGANIZATIONS, AND INDIVIDUALS THAT HAVE APPEARED DURING THE TWO YEARS SINCE THE PETITION WAS SUBMITTED. THE BULK OF SCIENTIFIC EVIDENCE AVAILABLE TO DATE DOES NOT APPEAR TO SUPPORT THE PETITION OR THE SUPPORTING HYPOTHESIS. NOT CONSIDERED AT THIS TIME ARE CHANGES IN THE ORIGINAL PETITION OR REBUTTALS PREPARED IN RESPONSE TO SOME OF THE WORKS PRESENTED IN THIS ARTICLE.

17-4-5-471 NATURAL BACKGROUND RADIATION IN THE UNITED STATES

NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS.

WASHINGTON, D.C.

EDITOR'S NOTE - RADIATION IN THE ENVIRONMENT FROM NATURAL SOURCES IS THE MAJOR SOURCE OF RADIATION EXPOSURE TO MAN. FOR THIS REASON IT IS FREQUENTLY USED AS A STANDARD OF COMPARISON FOR EXPOSURES FROM MEDICAL USES, WEAPONS TESTS FALLOUT, AND NUCLEAR POWER. TO MAKE NATURAL BACKGROUND RADIATION DATA MORE ADAPTABLE, THE NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS (NCRP) DEFINED THE SOURCES OF EXPOSURE IN EXPLICIT DETAIL IN A COMPREHENSIVE REPORT, COMPLETE WITH ABOUT 300 PERTINENT REFERENCES. THIS NUCLEAR SAFETY ARTICLE CONTAINS THE SUMMARY FROM THAT REPORT AND SOME EXCERPTS FROM APPENDIX B OF THE REPORT. THE REPORT IS ENTITLED 'NATURAL BACKGROUND RADIATION IN THE UNITED STATES' AND IS AVAILABLE AS NCRP REPORT 45 FROM NCRP PUBLICATIONS, P.O. BOX 30175, WASHINGTON D.C. 20014. AN ATTRACTIVE FEATURE IN THE PRESENTATION OF THE DATA IS THAT THEY ARE EXPRESSED IN TERMS OF THE CRITICAL ORGANS WHICH ARE EXPOSED. ALTHOUGH THE MAJOR CONTRIBUTION TO RADIATION DOSE TO HUMANS IS FROM NATURAL BACKGROUND, THE GREATEST PORTION OF MAN MADE RADIATION DOSE IS DUE TO EXPOSURES ACCRUED DURING MEDICAL DIAGNOSTIC PROCEDURES. THE ESTIMATED ANNUAL GENETICALLY SIGNIFICANT DOSE CONTRIBUTIONS FROM RADIOGRAPHIC EXAMINATIONS IN THE UNITED STATES IN 1970 IS APPROXIMATELY 20 MRADS (APPROXIMATELY EQUALS 20 REMS) (SOURCE - GONAD OSES AND GENETICALLY SIGNIFICANT DOSE FROM DIAGNOSTIC RADIOLOGY U.S., 1969 AND 1970. BUREAU OF RADIOLOGICAL HEALTH, EDUCATION AND WELFARE, APRIL 1974). ALSO, THE CONTRIBUTION FROM DEVELOPING NUCLEAR POWER INDUSTRY IS EXPECTED TO CONTRIBUTE A POPULATION DOSE OF LESS THAN 1 PERCENT OF NATURAL BACKGROUND.

17-4-6-475 PIPE CRACKING IN BOILING WATER REACTORS

NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED FROM A NUCLEAR REGULATORY COMMISSION REPORT ENTITLED 'INVESTIGATION AND EVALUATION OF CRACKING IN AUSTENITIC STAINLESS STEEL PIPING OF BOILING WATER REACTOR PLANTS.' THIS REPORT WAS PREPARED BY THE PIPE CRACKING STUDY GROUP THAT WAS FORMED BY NRC TO INVESTIGATE THIS PROBLEM AFTER A SERIES OF SUCH CRACKS HAD OCCURRED. THE STUDY GROUP CONCLUDED THAT THE CRACKS WERE CAUSED BY INTERGRANULAR STRESS CORROSION AND MADE EXTENSIVE RECOMMENDATIONS FOR (1) THE EARLY IDENTIFICATION OF SUCH CRACKS IN OPERATING PLANTS AND (2) THE ULTIMATE REDUCTION OF THIS PHENOMENON. THE STUDY GROUP ALSO CONCLUDED THAT THE PROBABILITY WAS EXTREMELY LOW THAT THE PRESENCE OF SUCH CRACKS COULD LEAD TO A SIGNIFICANT SAFETY HAZARD TO THE PUBLIC. INCLUDED AT THE END OF THIS ARTICLE IS A BIBLIOGRAPHY PREPARED BY THE STUDY GROUP.

- 17-5-1-525 COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS
EICHMOLZ, G. G.
GEORGIA INSTITUTE OF TECHNOLOGY, ATLANTA, GA.
A COST-BENEFIT ASSESSMENT IS AN ESSENTIAL PART OF THE ENVIRONMENTAL IMPACT STATEMENT SUBMITTED AS PART OF THE LICENSING CONSIDERATIONS FOR A NUCLEAR FACILITY. SUCH AN ASSESSMENT FORMS PART OF THE INITIAL DECISION TO BUILD A NUCLEAR FACILITY, ENTERS CRITICALLY INTO THE SELECTION OF A SUITABLE SITE, AND ULTIMATELY FORMS PART OF THE DESIGN PROCEDURES TO OPTIMIZE ENGINEERING SOLUTIONS TO DEAL WITH WASTE-HEAT DISSIPATION, TREATMENT METHODS FOR RADIOACTIVE EFFLUENT CONTROL, AND LAND AND SITE USE. WHEREAS THE INITIAL DECISION USUALLY CAN BE MADE IN PURELY ECONOMIC TERMS, THE LATTER STAGES INVOLVE ENVIRONMENTAL AND SOCIAL ISSUES THAT ARE NOT READILY QUANTIFIED AND INVOLVE A QUALITATIVE JUDGMENT OF WHAT CONSTITUTES THE LEAST, READILY ACHIEVABLE IMPACT. THE RADIOLOGICAL IMPACT OF THE PLANT ON THE SURROUNDING POPULATION FROM THE RELEASE OF LOW LEVEL EFFLUENTS CAN BE QUANTIFIED AND TREATED AS A FINANCIAL "COST." ALTERNATIVELY IT CAN BE TREATED AS A "RISK" AND RELATED TO OTHER RISKS MODERN MAN IS SUBJECTED TO AND CAN BE USED AS A MEANS TO ESTABLISH SITE BOUNDARIES. BOTH COST-BENEFIT AND RISK-BENEFIT ANALYSES REPRESENT ESSENTIALLY OPTIMIZATION APPROACHES TO THE PROBLEM OF MAKING NUCLEAR POWER PLANTS ECONOMICALLY COMPETITIVE, SOCIALLY AND POLITICALLY ACCEPTABLE, AND AS SAFE OR INNOCUOUS AS ONE CAN REASONABLY MAKE THEM.
- 17-5-1-539 CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTEREST
BROWMAN, L. M. & PUTTINGLY, T. J., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
CRITICAL MASS '74 AND '75, NATIONAL CONFERENCES OF OPPONENTS OF NUCLEAR POWER CONVENED BY CONSUMER ACTIVIST RALPH BADER, WERE HELD IN WASHINGTON, D.C., IN MID-NOVEMBER 1974 AND 1975. SESSIONS OF THESE CONFERENCES WERE DEVOTED TO MAKING THE CASE AGAINST NUCLEAR POWER DEVELOPMENT IN THE UNITED STATES AND ABROAD AS WELL AS TO DELINEATING STRATEGIES FOR CITIZEN ACTION AGAINST THE NUCLEAR ALTERNATIVE. THE CONFERENCES POINTED OUT THE BROADENING OF OPPONENTS' CONCERNS FROM MERELY TECHNICAL ISSUES TO A WIDE SPECTRUM OF SOCIAL, ECONOMIC, POLITICAL, AND MORAL ISSUES. THE AUTHORS, SOCIAL SCIENTISTS AT THE OAK RIDGE NATIONAL LABORATORY, DISCUSS THE IMPLICATIONS OF THIS BROADENING DEBATE FOR ENERGY POLICY.
- 17-5-2-550 THE ROLE OF CORE DISRUPTIVE ACCIDENTS IN DESIGN AND LICENSING OF LMFBRs
FAUSKE, H. K.
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
THE ROLE OF CORE DISRUPTIVE ACCIDENTS (CDA) IN DESIGN AND LICENSING OF LIQUID METAL COOLED FAST BREEDER REACTORS IS REVIEWED, INCLUDING A DESCRIPTION OF CDA INITIATORS, LIKELY ACCIDENT PATHS, CORE MELTDOWN ENERGETICS, AND RADIOLOGICAL CONSEQUENCES. IT IS CONCLUDED THAT (1) THE PROBABILITIES OF INITIATORS LEADING TO CORE MELTDOWN SHOULD AND CAN BE MADE SUFFICIENTLY LOW (OBJECTIVE, LESS THAN 10^{-6} PER REACTOR YEAR) TO REDUCE THEM TO CLASS 9 ACCIDENTS, (2) BEST ESTIMATE ANALYSIS INCLUDING DESIGN CONSIDERATIONS SHOULD AND CAN DEMONSTRATE THE UNLIKELIHOOD (OBJECTIVE, LESS THAN 10^{-2}) OF A POSTULATED CORE MELTDOWN LEADING TO SUBSTANTIAL ENERGETICS THAT WOULD CHALLENGE THE ENERGY ABSORPTION CAPABILITY PROVIDED BY THE PRIMARY SYSTEM DESIGN, I.E., THE ABSENCE OF ENERGETIC HYDRODYNAMIC DISASSEMBLY AND/OR ENERGETIC FUEL COOLANT INTERACTIONS, (3) THE PRINCIPAL BASIS FOR THE PRIMARY SYSTEM DESIGN SHOULD BE SET BY FUNCTIONAL REQUIREMENTS WHERE ANY WEAK LINKS IN THE RESULTING DESIGN SHOULD BE UPGRADED TO GIVE AN OVERALL CONSISTENT SYSTEM WITH AN OPTIMUM ENERGY ABSORPTION CAPABILITY (ESSENTIALLY CURRENT PRACTICE) AND NOT BY ARBITRARY CDA ENERGETICS, AND (4) ON THE BASIS OF BEST ESTIMATE ANALYSIS INCLUDING DESIGN CONSIDERATIONS, THE OBJECTIVE SHOULD AND CAN BE TO DEMONSTRATE LONG-TERM CONTAINMENT CAPABILITY OF THE FUEL DEBRIS FOLLOWING A POSTULATED CORE MELTDOWN ACCIDENT. THIS BALANCED APPROACH IS BELIEVED NECESSARY, AT LEAST IN THE NEAR TERM, TO ADEQUATELY DEMONSTRATE THAT THE SAFETY OBJECTIVE THAT THE OCCURRENCE OF RADIOLOGICAL CONSEQUENCES OUTSIDE THE PLANT BOUNDARY IN EXCESS OF ACCEPTABLE LEVELS MUST BE LESS THAN 10^{-6} PER REACTOR YEAR HAS INDEED BEEN ACHIEVED.
- 17-5-4-548 RELIABILITY OF PIPING IN LIGHT WATER REACTORS
FUSH, S. M.
BATTELLE PACIFIC NORTHWEST LABORATORIES, RICHLAND, WASH.
THIS ARTICLE ASSESSES THE RELIABILITY OF PIPING IN LIGHT WATER REACTORS BASED ON NONNUCLEAR FAILURE DATA, CONDITIONAL FAILURE PROBABILITIES, THE ROLE OF PERIODIC INSPECTION, AND A REVIEW OF NUCLEAR SYSTEM FAILURES. FAILURE STATISTICS CONFIRM RATES OF 10^{-4} TO 10^{-6} PER REACTOR YEAR IN LARGE PIPES, WITH HIGHER RATES AS THE SIZE DECREASES. PERIODIC INSPECTION, A CRITICAL FACTOR, ENHANCES RELIABILITY BY FACTORS OF 10 TO 10,000. NUCLEAR FAILURES ARE CLASSIFIED INTO TWO STATISTICAL CATEGORIES (1) THOSE DUE TO INTERGRANULAR STRESS CORROSION CRACKING (IGSCC), AND (2) ALL OTHERS DUE TO CONSTRUCTION, DESIGN, OR OPERATIONAL ERRORS. THE SPECTRUM OF PIPE SIZES INFLUENCED BY IGSCC DIFFERS FROM THAT INFLUENCED BY OTHER MECHANISMS.

- 17-5-5-500 THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT
VELUJI, V. R. + BOONE, F. W. + PALMS, J. R.
EMORY UNIVERSITY, ATLANTA, GA.
THE ENVIRONMENTAL IMPACT OF THE PREDICTED CARBON-14 RELEASE BY THE BARNWELL NUCLEAR FUEL PLANT (BNFP) IS ASSESSED. THE EXTERNAL DOSE AND THE WHOLE-BODY DOSES DUE TO INHALATION AND INGESTION OF CARBON-14 ARE CALCULATED. FOR A PREDICTED RELEASE OF 1005 CI/YEAR, THE EXTERNAL DOSE RATE AT THE SITE BOUNDARY IS 2.9×10^{10} R/HR. THE WHOLE-BODY INHALATION DOSE RATE IS 7.0×10^{10} R/HR. AND THE WHOLE BODY DOSE RATE VIA INGESTION OF FOOD MATERIALS IS 0.20 R/HR. THESE RATES COMPARE WITH AN AVERAGE ANNUAL DOSE RATE PER PERSON OF 135 MREMS/YEAR DUE TO NATURAL BACKGROUND RADIATION. THE LONG TERM ASPECTS OF GLOBAL RELEASES OF CARBON-14 FROM THE NUCLEAR INDUSTRY ARE BRIEFLY DISCUSSED. THE 25-YEAR DOSE COMMITMENT TO A PERSON DUE TO CARBON-14 DISCHARGES FROM THE TOTAL WORLD NUCLEAR FACILITIES DURING THE PERIOD 1975 TO 2000 IS ESTIMATED TO BE APPROXIMATELY 1.4 MREMS. DURING THE SAME 25-YEAR PERIOD, THE BNFP CONTRIBUTION WILL BE APPROXIMATELY 0.02 MREM OF THE 1.4 MREMS. THE DOSE COMMITMENT TO A PERSON FOR THE ESTIMATED 40-YEAR LIFETIME OF BNFP WILL BE APPROXIMATELY 0.08 MREM.
- 17-5-6-592 BROWNS FERRY NUCLEAR POWER PLANT FIRE ON MAR. 22, 1975
SCOTT, P. L.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE REVIEWS THE MAR. 22, 1975, FIRE AT THE BROWNS FERRY NUCLEAR POWER PLANT. THE FIRE ORIGINATED IN THE ELECTRICAL CABLE TRAYS AND BURNED FOR 7 HR BEFORE IT WAS EXTINGUISHED BY WATER. THE USE OF WATER WAS DELAYED UNTIL THE REACTORS WERE IN A STABLE SHUTDOWN CONDITION BECAUSE OF THE POSSIBILITY OF SHORTING CIRCUITS, WHICH MIGHT HAVE CAUSED FURTHER DEGRADATION OF CONDITIONS THAT WOULD HAVE BEEN MORE DIFFICULT TO CONTROL. HOWEVER, WHEN WATER WAS AUTHORIZED, THE FIRE WAS QUICKLY EXTINGUISHED. THE FIRE-FIGHTING EFFORTS AND THE DAMAGE CAUSED BY THE FIRE ARE DESCRIBED. THE LOSS OF ELECTRICAL POWER AND CONTROL CIRCUITS RESULTED IN THE UNAVAILABILITY OF EMERGENCY CORE COOLING SYSTEMS AND HAMPED EFFORTS TO PROVIDE NORMAL COOLING TO THE REACTOR FUEL. THE AVAILABILITY OF ALTERNATE COOLING METHODS IS REVIEWED. THE EFFORTS TO MAINTAIN COOLING OF THE REACTOR FUEL ARE DISCUSSED, AND THE BASIC REASONS FOR THE COMMON-MODE FAILURES ARE DESCRIBED. ASSESSMENTS OF THE FIRE WERE MADE BY THREE GROUPS IN THE U.S. NUCLEAR REGULATORY COMMISSION (NRC), AS WELL AS BY AN INDEPENDENT INSURANCE GROUP. SOME OF THE DETAILS OF THESE ASSESSMENTS ARE PRESENTED. IN PARTICULAR, SOME DEFICIENCIES THAT THE NRC OFFICE OF INSPECTION AND ENFORCEMENT FOUND DURING ITS INVESTIGATION AND SOME OF THE LESSONS LEARNED FROM THE EVENTS AS DETERMINED BY THE NRC SPECIAL REVIEW GROUP.
- 17-5-6-622 OCCUPATIONAL RADIATION EXPOSURES AT LWRs, 1969-1974
MURPHY, T. D. + HINSON, C. S.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
THIS ARTICLE SUMMARIZES A REPORT BY THE NUCLEAR REGULATORY COMMISSION WHICH PRESENTS COMPILATIONS OF OCCUPATIONAL RADIATION EXPOSURES AT COMMERCIAL LIGHT WATER COOLED POWER REACTORS FROM 1969 TO 1974. THE EXPOSURE IN MAN REMS PER UNIT FOR ALL REACTORS IN 1974 WAS LESS THAN THE 1973 VALUE, BUT THE GRAND AVERAGE SINCE 1969 CONTINUED TO INCREASE. HOWEVER, NO SIGNIFICANT TREND WAS INDICATED. OVER THE PERIOD 1969-1974, IN THE MEAN VALUE OF MAN REMS PER MEGAWATT YEAR.
- 17-6-1-659 ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES
CHESTER, C. V.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE POTENTIAL FATALITIES, OR EXTENT OF POTENTIAL LETHAL CONSEQUENCES, FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES ARE ESTIMATED. THE MOST SEVERE THREAT IS FROM THEFT OF FISSIONABLE MATERIAL AND SUBSEQUENT FABRICATION OF A CLAUDESTINE NUCLEAR EXPLOSIVE. A NUCLEAR EXPLOSIVE OF EFFICIENT DESIGN EXPLODED WITHOUT WARNING IN A CROWDED HIGH RISE COMMERCIAL DISTRICT COULD PRODUCE OVER A MILLION FATALITIES. THE UNCONTAINED MELTDOWN OF A POWER REACTOR AND, TO A LESSER EXTENT, THE DISPERSAL OF PLUTONIUM ARE MINOR THREATS TO HUMAN LIFE IF THERE IS ANY WARNING, BUT THEY ARE POTENTIALLY LARGE AND VERY COERCIVE THREATS TO PROPERTY. THE TOXICITY OF PLUTONIUM IS NO WORSE THAN THAT OF THE MUCH MORE EASILY AVAILABLE NERVE GAS AND REQUIRES WEEKS OR MONTHS TO KILL AS OPPOSED TO MINUTES FOR NERVE GAS. ATTACKS ON SPENT FUEL SHIPMENTS, HIGH LEVEL WASTE SHIPMENTS, REPROCESSING PLANTS, OR WASTE TANKS PRESENT MINIMAL THREATS TO HUMAN LIFE.
- 17-6-1-665 SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF SABOTAGE
SANDIA STAFF
SANDIA LABORATORIES, ALBUQUERQUE, N.MEX., AND LIVERMORE, CALIF.
A STUDY HAS BEEN MADE OF THE VULNERABILITY OF U.S. COMMERCIAL LIGHT WATER REACTOR POWER PLANTS TO SABOTAGE. THE SUSCEPTIBILITY OF NUCLEAR PLANTS TO SABOTAGE AND THE CONSEQUENCES OF A SUCCESSFUL ATTACK ARE COMPARED WITH RESPECT TO OTHER INDUSTRIAL AND CIVIL TARGETS. RECOMMENDATIONS ARE GIVEN TO FURTHER REDUCE THE VULNERABILITY OF NUCLEAR POWER PLANTS TO SOPHISTICATED SABOTAGE THREATS.

- 17-0-2-671 DATA SOURCES FOR LOCA CODE VERIFICATION
FABIC, S.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
MATHEMATICAL MODELS IN THE CURRENT AND ADVANCED LOSS OF COOLANT ACCIDENT CODES UNDER DEVELOPMENT ARE CATEGORIZED, AND INDICATIONS ARE GIVEN OF THE DEPENDENT VARIABLES THAT COULD BE SOLVED FOR AND OF THE NUMBER AND TYPE OF CONSTITUTIVE EQUATIONS THAT NEED TO BE VERIFIED. TEST DATA SOURCES ARE CLASSIFIED ACCORDING TO THE COMPLEXITY AND DIVERSITY OF MEASUREMENTS. EXISTING DATA SOURCES, BOTH DOMESTIC AND FOREIGN, ARE LISTED FOR EACH CLASS OF TESTS. ADDITIONAL TEST DATA NEEDS ARE OUTLINED, FOLLOWED BY A DESCRIPTION OF THE EXISTING PLANS FOR CODE VALIDATION AND FOR UNCERTAINTY STUDIES ON CODE RESULTS. THE CONCLUSION IS REACHED THAT THERE IS AN EXTENSIVE DATA BASE AVAILABLE FOR CODE VERIFICATION, EXCEPT FOR THOSE BEST ESTIMATE CODES WHICH MODEL MULTIDIMENSIONAL EFFECTS AND THE LOCAL EFFECTS OF INTERPHASE MASS, MOMENTUM, AND ENERGY TRANSFER. THE NUCLEAR REGULATORY COMMISSION IS IN THE PROCESS OF CONTRACTING FOR THE ADDITIONAL RESEARCH REQUIRED TO SUPPLEMENT THE EXISTING DATA BASE.
- 17-0-3-606 COMMON-MODE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO REACTOR SAFETY
MAYDEN, R. C. + MAGER, E. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
A BROAD CATEGORY OF FAILURE MECHANISMS THAT CAN CAUSE COMMON-MODE FAILURES IN NUCLEAR PLANT REDUNDANT SYSTEMS AND OTHER HIGH RELIABILITY SYSTEMS IS EXAMINED. THIS CLASS OF MECHANISMS INCLUDES CAUSES OF MULTIPLE FAILURES THAT HAVE NOT BEEN WIDELY RECOGNIZED AS COMMON-MODE FAILURES IN THE PAST. FAILURE MECHANISMS WERE DEDUCED FROM REACTOR OPERATING EXPERIENCES AND REPORTS. SEVERAL CATEGORIES OF MULTIPLE FAILURE MECHANISMS ARE PROPOSED AS A STARTING POINT FOR THE DEVELOPMENT OF DESIGN AND OPERATING GUIDELINES FOR REDUCING THE PROBABILITY OF COMMON-MODE FAILURES.
- 17-0-3-693 SAFETY EVALUATION EXPERIENCE WITH DIGITAL COMPUTER SOFTWARE
BELLIACCHI, L. + BULLOCK, J. B.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE USE OF DIGITAL COMPUTERS IN REACTOR PROTECTION SYSTEMS PRESENTS NEW CONSIDERATIONS FOR THE DESIGNERS OF BOTH THE REACTOR AND THE SAFETY SYSTEM. THIS ARTICLE DISCUSSES EXPERIENCES IN THE SAFETY EVALUATION OF PROTECTION SYSTEM SOFTWARE IN TERMS OF DEVELOPED GUIDELINES, THE IMPORTANCE OF THE SOFTWARE DEVELOPMENT CYCLE, AND THE APPLICATION OF THE GUIDELINES. IMPORTANT GUIDELINES SUCH AS CRITICAL DESIGN FAULTS AND QUALITATIVE RELIABILITY ARE CURRENTLY BEING USED FOR EVALUATION PURPOSES, AND MINIMUM REQUIREMENTS FOR THE DESIGN QUALIFICATION AND ACCEPTANCE TESTING OF THE SOFTWARE HAVE BEEN IDENTIFIED. ALTHOUGH THE SAFETY REVIEW IS INCOMPLETE, MOST OF THE PROTECTION ALGORITHMS, TEST PLANS, AND SOME TEST RESULTS HAVE BEEN REVIEWED. OUR EXPERIENCES TO DATE MAY PROVE FRUITFUL FOR OTHERS CONTEMPLATING THE DEVELOPMENT AND REVIEW OF SOFTWARE IN SAFETY RELATED SYSTEMS. THE OPINIONS EXPRESSED HEREIN REFLECT THE CURRENT EXPERIENCE OF THE AUTHORS. FINAL REGULATORY GUIDANCE OF THE NUCLEAR REGULATORY COMMISSION HAS NOT BEEN DEVELOPED.
- 17-0-4-708 EMERGENCY SHUTDOWN COOLING TOWERS - CONSIDERATIONS IN THE EVOLUTION OF OPTIMUM TOWER DESIGN
KLEIN, S. M.
UNITED ENGINEERS - CONSTRUCTORS INC., PHILADELPHIA, PA.
THIS ARTICLE DISCUSSES THE VARIOUS REGULATORY REQUIREMENTS AND CRITERIA GOVERNING THE DESIGN OF EMERGENCY SHUTDOWN COOLING TOWERS FOR NUCLEAR POWER PLANTS. THE EFFECTS OF KEY TOWER PARAMETERS (E.G., WET BULB TEMPERATURE, FLOW RATES, AND HEAT LOAD) ON TOWER SIZE AND THEIR INTERACTIONS WITH SYSTEM AND SAFETY REQUIREMENTS ARE EXPLORED. THE EVOLUTION OF THE SEABROOK STATION TOWER AND ITS RELATIONSHIP TO A COMPANION COOLING WATER SOURCE (THE ATLANTIC OCEAN) ARE PRESENTED AS AN EXAMPLE OF OPTIMUM TOWER / SYSTEM DESIGN THAT COMPLIES WITH REGULATORY REQUIREMENTS.
- 17-0-4-710 THE ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE SUPPRESSION
LIPARULO, M. J. + TINKLER, C. G. + GEORGE, J. A.
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PA.
THIS ARTICLE DESCRIBES THE WESTINGHOUSE ICE CONDENSER SYSTEM FOR SUPPRESSING PRESSURE CAUSED BY THE RELEASE OF STEAM WITHIN THE CONTAINMENT SYSTEM OF A POWER REACTOR. THE BASIC CONCEPT, SYSTEM CHARACTERISTICS, CONTAINMENT LAYOUT, AND SIZE ARE PRESENTED, AND THE TEST PROGRAM FOR ICE CONDENSER HEAT TRANSFER AND A TYPICAL RESPONSE TO A LOSS OF COOLANT ACCIDENT ARE DESCRIBED.
- 17-0-5-722 RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING SITES - AN OVERVIEW
GOLDSMITH, W. A.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
RADIOACTIVE RESIDUES - CALLED TAILINGS - OF DISCONTINUED URANIUM MILLING OPERATIONS ARE PRESENT AT 23 LOCATIONS IN THE WESTERN UNITED STATES. THE SHORT LIVED PROGENY OF THE RADON-222 EMANATING FROM THE TAILINGS GIVES RISE TO MOST OF THE PUBLIC RADIATION EXPOSURE RESULTING FROM PRESENT MANAGEMENT OF THESE TAILINGS. SINCE PRECURSORS OF RADON-222 HAVE EXTREMELY LONG

HALF LIVES. LONG TERM MANAGEMENT POLICIES AND TECHNIQUES ARE REQUIRED IF FURTHER REDUCTION OF RADIATION EXPOSURE TO THE PUBLIC IS DESIRED.

- 17-6-4-733 IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PRESSURE COMPONENTS
LAUTZENHEISER, C. E.
SOUTHWEST RESEARCH INSTITUTE, SAN ANTONIO, TEXAS
THE EARLY LIGHT WATER REACTOR SYSTEMS FOR PRODUCTION OF COMMERCIAL POWER WERE DESIGNED AND FABRICATED IN ACCORDANCE WITH THE CODES THEN BEING USED FOR FOSSIL FIRED POWER GENERATING STATIONS WITH SOME DESIGN CHANGES FOR INCREASED INSPECTABILITY DURING FABRICATION. OVER THE PAST FEW YEARS, MAJOR STRIDES HAVE BEEN MADE IN IN-SERVICE INSPECTION TECHNOLOGY. WORK HAS BEEN UNDER WAY TO DETERMINE THE RELIABILITY OF NONDESTRUCTIVE TESTING METHODS AND TO DEVELOP FORMAL INSPECTION PROGRAMS THROUGHOUT THE WORLD. THE MAJOR PROBLEMS ASSOCIATED WITH IN-SERVICE INSPECTION ARE THE SCARCITY OF QUALIFIED PERSONNEL, THE VARIABILITY IN PROCEDURES AND DATA RECORDING BETWEEN INSPECTION AGENCIES, AND EXPOSURE OF INSPECTION PERSONNEL TO RADIATION. FURTHER WORK WILL BE REQUIRED TO MORE COMPLETELY MECHANIZE PIPING INSPECTIONS TO REDUCE RADIATION EXPOSURE AND TO STANDARDIZE INSPECTION PROCEDURES, EQUIPMENT, AND CERTIFICATION OF PERSONNEL. WORLDWIDE ATTENTION TO THE REQUIREMENTS OF THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS' BOILER AND PRESSURE VESSEL CODE, THE SIZE AND INTEGRITY OF INSPECTION AGENCIES, AND EFFORTS SUCH AS THE DEVELOPMENT OF PERSONNEL QUALIFICATION AND CERTIFICATION GUIDES EMPHASIZE THE IMPORTANCE OF IN-SERVICE INSPECTION TO NUCLEAR SAFETY.
- 17-6-6-763 OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES, 1974
BROOKS, B. G.
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
PERSONNEL OCCUPATIONAL RADIATION EXPOSURES FOR CALENDAR YEAR 1974 WERE OBTAINED FROM ANNUAL AND TERMINATION REPORTS SUBMITTED BY CERTAIN TYPES OF AEC LICENSEES, I.E., OPERATING NUCLEAR POWER FACILITIES, INDUSTRIAL RADIOGRAPHERS, FUEL PROCESSORS, FABRICATORS, AND REPROCESSORS, COMMERCIAL PROCESSORS, AND DISTRIBUTORS OF SPECIFIED QUANTITIES OF BY-PRODUCT MATERIALS. THESE DATA ARE PRESENTED IN A NUCLEAR REGULATORY COMMISSION REPORT, WHICH IS SUMMARIZED HERE. REPORTS FROM 421 LICENSEES INDICATED THAT 85,097 INDIVIDUALS WERE MONITORED FOR EXPOSURE TO RADIATION DURING 1974 AND THAT 17,627 INDIVIDUALS TERMINATED THEIR EMPLOYMENT OR WORK ASSIGNMENT WITH LICENSEES IN 1974. BOTH FIGURES SHOW AN INCREASE OF ABOUT 23 PERCENT OVER THOSE OF 1973. DESPITE THE INCREASE IN THE NUMBER OF INDIVIDUALS MONITORED DURING THE 7 YEARS, THE NUMBER OF THE MORE SIGNIFICANT EXPOSURES HAS REMAINED FAIRLY CONSTANT.
- 18-1-1-1 NAC WATER REACTOR SAFETY RESEARCH PROGRAM
TONG, L. S. + BENNETT, G. L.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
THE WATER REACTOR SAFETY RESEARCH PROGRAM OF THE NUCLEAR REGULATORY COMMISSION IS DESCRIBED, AND THE BASIC RESULTS ARE PRESENTED. THE PROGRAM CONSISTS OF FIVE BASIC RESEARCH AREAS - INTEGRITY OF VESSEL AND PIPING, THERMAL HYDRAULIC TESTS, FUEL ROD BEHAVIOR, CODE DEVELOPMENT AND VERIFICATION, AND REACTOR OPERATIONAL SAFETY. RESULTS FROM THE VESSEL AND PIPING INTEGRITY RESEARCH HAVE DEMONSTRATED THE HIGH SAFETY MARGINS IN SCALED VESSELS AND THE ANALYTICAL PROCEDURES FOR CALCULATING VESSEL BEHAVIOR UNDER PRESSURE. NONDESTRUCTIVE EXAMINATION TECHNIQUES ARE BEING IMPROVED. WORK IS ALSO PROCEEDING TO DEFINE THE MATERIAL CONSTITUENTS WITH WHICH TO REDUCE THE SUSCEPTIBILITY OF COMPONENTS AND STRUCTURES TO IRRADIATION EMBRITTLEMENT AND STRESS CORROSION CRACKING. THE THERMAL HYDRAULIC TESTS HAVE COVERED THE VARIOUS PHASES OF A HYPOTHETICAL LOSS OF COOLANT ACCIDENT AND ACTIVATION OF THE EMERGENCY CORE COOLING SYSTEM. THESE TESTS HAVE LED TO THE DEVELOPMENT OF MORE REALISTIC ENGINEERING CORRELATIONS TO DESCRIBE THE PHENOMENA IN ORDER TO FURTHER QUANTIFY THE SAFETY MARGINS IN COMMERCIAL NUCLEAR POWER PLANTS. THE FUEL BEHAVIOR RESEARCH HAS PROVIDED VALUABLE INFORMATION ON DECAY HEAT, CLADDING OXIDATION, FUEL ROD BEHAVIOR, AND FUEL MELTING. BOTH THE DECAY HEAT AND THE CLADDING OXIDATION HAVE BEEN SHOWN TO BE LOWER THAN ASSUMED IN THE LICENSING EVALUATIONS. THE REACTOR OPERATIONAL SAFETY RESEARCH IS JUST STARTING - INITIALLY IT ADDRESSES FIRE PROTECTION, COMPONENT AGING, AND HUMAN ENGINEERING. TO DATE, THE NAC WATER REACTOR SAFETY RESEARCH PROGRAM HAS GREATLY EXPANDED THE SAFETY DATA BASE, WHICH IN TURN IS USED FOR FURTHER QUANTIFICATION OF THE INHERENT SAFETY MARGINS IN NUCLEAR POWER PLANTS.
- 18-1-2-45 REFLECTIONS ON THE RECRITICALITY CONFERENCE AT ARGONNE NATIONAL LABORATORY
GRIFFITH, J. D.
U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D.C.
THE CONSENSUS OF THE RECRITICALITY CONFERENCE AT ARGONNE NATIONAL LABORATORY WAS THAT THE ENERGETIC RECRITICALITY ACCIDENT IS A HIGHLY IMPROBABLE EVENT BUT THAT PROOF OF ITS IMPOSSIBILITY IS NOT YET FULLY CONVINCING TO THE INTERESTED SCIENTIFIC COMMUNITY. THE AUTHOR EXTENDS THE DISCUSSION AND SUGGESTS THAT AN FUNDLESS EFFORT TO ESTABLISH THE EXISTENCE OF

VERY LOW PROBABILITY EVENTS OR TO PROVE THE IMPOSSIBILITY OF SOME POSTULATED EVENTS WOULD BE A FRUITLESS ENDEAVOR. IT IS CONCLUDED THAT THE EMPHASIS SHOULD BE SHIFTED FROM A SEARCH FOR GREATER ASSURANCE OF THE NONEXISTENCE OF LOW PROBABILITY EVENTS TO THE UNDERSTANDING OF REAL PHENOMENA AT THE VARIOUS NATURAL LINES OF ASSURANCE THAT EXIST FOR A LIQUID METAL COOLED FAST BREEDER REACTOR. THE AUTHOR PROPOSES THAT THIS BE DONE WITH AN APPROPRIATE RISK CURVE INCORPORATING THE LINES OF ASSURANCE AND A PROPOSED CRITERION. THE CRITERION PROPOSED IS THAT PHENOMENA THAT CAN BE MADE TO OCCUR EXPERIMENTALLY UNDER REALISTIC REACTOR CONDITIONS BE STUDIED AND UNDERSTOOD AND PHENOMENA THAT CANNOT BE MADE TO HAPPEN EXPERIMENTALLY BE ASSUMED TO HAVE A PROBABILITY OF OCCURRENCE LOWER BY A FACTOR OF 10^{10} (10^{12} TO 10^{14}) AND THE CONSEQUENCES OF THESE LOWER-PROBABILITY EVENTS BE STUDIED AT THE NEXT LINE OF ASSURANCE.

10-1-3-53

LOSS OF ELECTRIC POWER COINCIDENT WITH LOCA NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE ANALYSIS CONDUCTED IN THE REACTOR SAFETY STUDY (NASH-1400) PRESENTS A METHOD FOR ESTABLISHING A RISK PROBABILITY FOR POSTULATED ACCIDENT CIRCUMSTANCES. SINCE THESE PROBABILITIES PROVIDE A MEANS FOR PLACING EVENTS INTO A RELATIVE PERSPECTIVE, THE EDITOR HAS PREPARED THAT PORTION OF THE STUDY CONCERNED WITH AND ENTITLED "TOTAL LOSS OF ELECTRIC POWER" FOR REPLICATION HERE FOR A BROADER AUDIENCE. THE STUDY CONCLUDED THAT THE PROBABILITY OF THE TOTAL LOSS OF ELECTRIC POWER WAS 10^{10} (10^{12} TO 10^{14}) AT THE TIME OF A LOSS OF COOLANT ACCIDENT (LOCA) AND RANGED FROM ABOUT 10^{10} (10^{12} TO 10^{14}) TO 10^{10} (10^{12} TO 10^{14}) FOR VARIOUS TIMES AND CONFIDENCE LEVELS FOLLOWING A LOCA. THE "EDITOR'S POSTSCRIPT" TO THIS EDITED VERSION OF THE RISK ASSESSMENT ANALYSIS IS A STATEMENT OF THE PRIMARY PURPOSE AND FUNCTION OF THE TWO ELECTRIC POWER SYSTEMS ASSOCIATED WITH NUCLEAR POWER PLANTS. SOME ACTUAL PLANT OPERATING DATA AND BLACKOUT EXPERIENCES ARE PRESENTED FOR RELEVANCE AND TO SUPPLEMENT THE LIMITED DATA BASE CHOSEN FOR THE STUDY. THE REFERENCE LIST GIVEN IN THE REPORT IS ALSO INCLUDED AND IS SUPPLEMENTED BY REFERENCES THAT ARE CITED IN THE POSTSCRIPT. A SHORT BIBLIOGRAPHY IS APPENDED.

10-1-4-60

PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS DISALVO, R.

U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
RENEWED INTEREST HAS RECENTLY DEVELOPED IN ANALYZING THE COURSE AND CONSEQUENCES OF HIGHLY IMPROBABLE, HYPOTHETICAL ACCIDENTS THAT INVOLVE MELTING OF A SIGNIFICANT PORTION OF THE FUEL IN LIGHT WATER REACTORS. PHYSICAL PHENOMENA ASSOCIATED WITH SUCH ACCIDENTS AND CURRENT TRENDS IN SAFETY RESEARCH APPLICABLE TO THEIR ANALYSIS ARE REVIEWED. THE OBJECTIVES, TECHNICAL APPROACHES, AND RECENT FINDINGS OF SELECTED PROGRAMS IN THE UNITED STATES AND THE FEDERAL REPUBLIC OF GERMANY ARE SUMMARIZED.

10-1-6-79

RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974 NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
MEASURED RELEASES OF RADIOACTIVE MATERIALS IN AIRBORNE AND LIQUID EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS DURING 1974 ARE SUMMARIZED AND COMPARED TO FORMER YEARS. THIS REPORT SUPPLEMENTS THE EARLIER ANNUAL REPORTS ISSUED BY THE ATOMIC ENERGY COMMISSION AND THE NUCLEAR REGULATORY COMMISSION. ALTHOUGH THE 1974 RELEASES WERE IN ALL CASES BELOW THE LIMITS SET FORTH IN APPLICABLE REGULATIONS, THE AIRBORNE EFFLUENTS INCREASED ABOUT 2 PERCENT AND THE LIQUID EFFLUENTS DECREASED ABOUT 6 PERCENT IN 1974 AS COMPARED TO 1973.

10-2-1-127

LEGAL AND INSTITUTIONAL PROBLEMS IN POWER PLANT SITING

BORKO, B. & JUST, J. E.
METRE CORPORATION, McLEAN, VA.
UNCERTAIN LONG RANGE DEMAND, RISING POWER PLANT CAPITAL AND OPERATING COSTS, INCREASING CONSTRUCTION TIME, AND THE IMPOSITION OF MORE STRINGENT REGULATORY REQUIREMENTS FOR NEW POWER PLANTS HAVE RESULTED IN AN INCREASINGLY COMPLEX PROCESS FOR SITING NEW ELECTRIC GENERATING CAPACITY. MAJOR LEGAL AND INSTITUTIONAL IMPEDIMENTS TO A MORE EXPEDITIOUS SITING PROCESS INCLUDE THE NEED FOR ENUNCIATED NATIONAL STRATEGIES ON SUCH ISSUES AS SAFETY STANDARDS, THE NUCLEAR FUEL CYCLE, AND COMMITMENT TO CONSERVATION. THE LACK OF A DEFINITIVE MECHANISM ASSIGNING SPECIFIC RESPONSIBILITY FOR SITE SELECTION, AND THE FACT THAT PUBLIC ACCESS TO SITING DECISIONS IS FIRST PROVIDED AT A LATE STAGE IN THE DECISION PROCESS.

10-2-1-133

FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING COTTELL, W. B.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE IS A REVIEW OF THE FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE NUCLEAR REGULATORY COMMISSION'S (NRC'S) DIVISION OF REACTOR SAFETY RESEARCH, HELD AT THE NATIONAL BUREAU OF STANDARDS, GAITHERSBURG, MD., SEPT. 27-30, 1976. THIS MEETING CONSISTED OF PARALLEL TECHNICAL PRESENTATIONS IN THE MORNING, FOLLOWED BY SEVERAL SMALLER WORKSHOPS OR DISCUSSION SESSIONS IN THE AFTERNOON. THE TECHNICAL SESSIONS WERE (1) LOSS OF COOLANT

ACCIDENT STUDIES, (2) ANALYSIS DEVELOPMENT PROGRAM, (3) METALLURGY AND MATERIALS RESEARCH PROGRAM, AND (4) FUEL BEHAVIOR RESEARCH PROGRAM. SUMMARIES OF THE WORK IN EACH OF THESE FOUR MAJOR AREAS ARE PRESENTED HERE. OVER 635 PERSONS, INCLUDING SOME 126 FOREIGN VISITORS FROM 14 COUNTRIES, ATTENDED THE MEETING. IN ADDITION TO THE REVIEW OF NRC-SPONSORED WATER REACTOR SAFETY RESEARCH PROGRAMS, THE MEETING INCLUDED PRESENTATIONS ON SEVERAL FOREIGN REACTOR SAFETY PROGRAMS AS WELL AS ONE AFTERNOON SESSION DEVOTED TO RESEARCH SPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE. THE MEETING WAS NOTABLE FOR THE HEALTH OF TECHNICAL DATA AND EXPERIMENTAL RESULTS THAT WERE REPORTED. MANY TOPICS WERE DISCUSSED, AND MUCH WAS LEARNED. IT IS REASSURING THAT THESE RESEARCH RESULTS CONTINUE TO SUBSTANTIATE OUR UNDERSTANDING OF REACTOR SAFETY.

18-2-2-154 BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY FORCED CONVECTION SYSTEMS
BERGLES, A. F.

IONA STATE UNIVERSITY, AMES, IOWA

RECENT EXPERIMENTAL AND ANALYTICAL DEVELOPMENTS REGARDING BURNOUT IN SUBCOOLED AND LOW QUALITY FORCED CONVECTION SYSTEMS ARE REVIEWED. MANY DATA HAVE BEEN ACCUMULATED WHICH CLARIFY THE PARAMETRIC TRENDS AND LEAD TO NEW DESIGN CORRELATIONS FOR WATER AND A VARIETY OF OTHER COOLANTS IN BOTH SIMPLE AND COMPLEX GEOMETRIES. A NUMBER OF CRITICAL EXPERIMENTS AND MODELS HAVE BEEN DEVELOPED TO ATTEMPT TO CLARIFY THE BURNOUT MECHANISMS IN SIMPLER GEOMETRIES. OTHER TOPICS DISCUSSED INCLUDE BURNOUT WITH POWER TRANSIENTS AND TECHNIQUES TO AUGMENT BURNOUT.

18-2-3-168 ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC POWER
AITKEN, A.

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, GREAT BRITAIN

THIS ARTICLE OUTLINES THE PROBLEM AND THE PROBLEM AREAS AS OBSERVED IN A RECENT ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR THE PROTOTYPE FAST REACTOR, A LIQUID METAL COOLED FAST BREEDER REACTOR AT DUNDEE, TARGETS FOR RELIABILITY IN INDIVIDUAL MEASUREMENTS, SAFETY CIRCUITS, AND SHUTDOWN DEVICES ARE DETERMINED BY RELIABILITY APPORTIONMENT WITHIN THE DIVERSE SYSTEM THAT WAS DESIGNED TO MEET WELL-RECOGNIZED BASIC PRECEPTS. SOME COMMENTS ARE MADE ON OPERATING EXPERIENCE IN RELATION TO THE HIGH REQUIREMENTS.

18-2-4-174 THE FOURTEENTH ERDA AIR CLEANING CONFERENCE
MOELLER, D. W. + UNDERHILL, D. W. + FIRST, M. W.
HARVARD UNIVERSITY, BOSTON, MASS.

THE FOURTEENTH ERDA AIR-CLEANING CONFERENCE WAS HELD AUG. 2-4, 1976, IN SUN VALLEY, IDAHO. THE 324 ATTENDEES INCLUDED REPRESENTATIVES FROM 13 FOREIGN COUNTRIES AND AIR CLEANING SPECIALISTS FROM ESSENTIALLY ALL FACETS OF INDUSTRY, FROM GOVERNMENTAL AGENCIES, AND FROM EDUCATIONAL INSTITUTIONS. MAJOR TOPICS WERE RADIOIODINE SAMPLING, REMOVAL, AND RETENTION, THE CONCENTRATION AND STORAGE OF NOBLE GASES, TRITIUM, AND CARBON-14, PARTICULATE COLLECTORS, SYSTEMS PROTECTION FROM FIRES, EXPLOSIONS, AND NATURAL DISASTERS, SAMPLING AND MONITORING, AIR CLEANING AND VENTILATION SYSTEM DESIGN, AIR CLEANING PROBLEMS ASSOCIATED WITH THE TREATMENT OF RADIOACTIVE WASTES, AIR CLEANING SYSTEMS FOR THE LIQUID METAL COOLED FAST BREEDER REACTOR, AND THE REGULATORY ASPECTS OF THE AIR CLEANING FIELD. AN INTERESTING ASPECT OF THE CONFERENCE WAS THE DEGREE TO WHICH PROBLEMS ASSOCIATED WITH RADIOIODINE STILL MAINTAIN A PROMINENT PLACE IN AIR CLEANING RESEARCH AND DEVELOPMENT. NEWER CHALLENGES BECAME EVIDENT FROM THE BROWNS FERRY FIRE, WHICH REVEALED WEAKNESSES IN AIR CLEANING AND VENTILATION SYSTEMS IN NUCLEAR POWER PLANTS, AND FROM THE REACTOR SAFETY STUDY, WHICH SHOWED A NEED TO DEVELOP ADDITIONAL DATA ON THE RELIABILITY OF SUCH SYSTEMS, PARTICULARLY UNDER EMERGENCY CONDITIONS. ASSESSMENTS OF THE DEGREE TO WHICH ENGINEERED SAFETY FEATURES CAN BE USED TO COMPENSATE FOR SPECIFIC DEFICIENCIES IN NUCLEAR FACILITY SITES ALSO CONTINUE TO CHALLENGE THOSE INVOLVED IN RISK-BENEFIT EVALUATIONS.

18-2-4-189 TRENDS IN THE DESIGN OF PRESSURIZED WATER REACTOR CONTAINMENT STRUCTURES AND SYSTEMS
RENTA, D. S. + OSCOOD, M. W. + BINGHAM, A. J.

BUCHERT, R. P.

BECHTEL POWER CORPORATION, GATHERSBURG, MD.

THIS ARTICLE TRACES THE EVOLUTION OF PRESSURIZED WATER REACTOR (PWR) CONTAINMENT DESIGN REQUIREMENTS AND CONCEPTS SINCE THE MID-1960S. DISCUSSES THE STRUCTURES AND SYSTEMS CURRENTLY BEING USED FOR NEW PLANTS, AND PRESENTS TABULATED DATA CONCERNING SIZE AND TYPE OF CONTAINMENT STRUCTURE, INTERNAL DESIGN PRESSURE, AND SAFE SHUTDOWN GROUND ACCELERATION VALUES FOR 127 NUCLEAR POWER PLANTS. IN ADDITION, VARIOUS CONTAINMENT SYSTEMS, SUCH AS FISSION-PRODUCT REMOVAL, HEAT REMOVAL, COMBUSTIBLE GAS CONTROL, AND PURGE, ARE BRIEFLY REVIEWED.

18-2-5-203 RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FUSION POWER
EASTERLY, C. E. + SHANN, R. E. + SHoup, R. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

FUSION REACTOR TECHNOLOGY IS PRESENTLY IN CONCEPTUAL AND EARLY DEVELOPMENTAL STAGES. CONCOMITANT WITH HARDWARE DEVELOPMENT, POTENTIAL HEALTH AND ENVIRONMENTAL IMPACTS MUST BE EVALUATED TO ENSURE THAT TECHNOLOGISTS HAVE PERTINENT INFORMATION AVAILABLE SO THAT ADEQUATE CONSIDERATION MAY BE GIVEN TO HEALTH AND

ENVIRONMENTAL PROBLEMS. THIS ARTICLE DISCUSSES PROBLEM AREAS ATTENDANT TO TRIUM, ACTIVATION PRODUCTS, AND MAGNETIC FIELDS ASSOCIATED WITH FUSION REACTOR SYSTEMS.

18-2-5-215

RADIOLOGICAL QUALITY OF THE ENVIRONMENT NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS REPORT IS PART OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY'S DOSE ASSESSMENT PROGRAM FOR EVALUATING THE RADIOLOGICAL QUALITY OF THE ENVIRONMENT. ITS PUBLICATION HERE DOES NOT CONSTITUTE ENDORSEMENT OF THE ORIGINAL REPORT BY THE NUCLEAR REGULATORY COMMISSION. RATHER, THE EDITORS OF NUCLEAR SAFETY BELIEVE THE AUTHORS HAVE BROUGHT TOGETHER A WEALTH OF DATA AND EXTENSIVE REFERENCES TO THE CURRENT LITERATURE, BOTH OF WHICH SHOULD BE USEFUL TO THE GENERALIST AND SPECIALIST ALIKE. THE REPORT RECOGNIZES THE NEED FOR ADDITIONAL INFORMATION, AND THE INTERESTED READER IS URGED TO CONSULT THE ORIGINAL REPORT FOR ADDITIONAL DETAILS, QUALIFICATIONS, AND SOURCES PERTINENT TO ALL OF THE DATA, AS A PROTOTYPE EFFORT. THIS REPORT IS INTENDED ONLY TO SUMMARIZE INFORMATION AVAILABLE IN THE OPEN LITERATURE. SPECIAL EMPHASIS WAS PLACED ON ACQUIRING RECENT DOSE DATA FOR SOME SOURCE CATEGORIES. DOSE INFORMATION WAS AVAILABLE FOR CALENDAR YEAR 1975, WHEREAS FOR OTHER CATEGORIES THE MOST RECENT DATA GO BACK TO THE EARLY 1970s. IT IS NOT INTENDED IN THIS INITIAL EFFORT TO CALCULATE OR EXTRAPOLATE FROM EXISTING DATA TO SUPPLY MISSING DOSE INFORMATION. INSTEAD, THE CONCERN IS TO REVIEW THE AVAILABLE DATA AND TO DETERMINE WHAT THE EXISTING DATA PROVIDE FOR INDIVIDUAL AND POPULATION DOSE INFORMATION. SINGLE COPIES OF THE REPORT MAY BE OBTAINED FROM THE OFFICE OF RADIATION PROGRAMS, U.S. ENVIRONMENTAL PROTECTION AGENCY, WASHINGTON, D.C. 20460. IT WAS CONCLUDED, ON THE BASIS OF THE POPULATION DOSE DATA ACQUIRED IN THIS REPORT, THAT THE THREE MAJOR SOURCE CATEGORIES OF RADIATION DOSE IN THE U.S. POPULATION ARE (1) AMBIENT IONIZING RADIATION, (2) THE APPLICATION OF RADIOPHARMACEUTICALS IN MEDICINE, AND (3) TECHNOLOGICALLY ENHANCED NATURAL RADIATION.

18-2-6-223

HUMAN ENGINEERING - AIDS TO SMOOTH OPERATION RANZ, G. W.

U.S. NUCLEAR REGULATORY COMMISSION, BETHESDA, MD.

NUCLEAR PLANT CONTROL CONSOLES ARE HUGE, COMPLEX, AND SOMETIMES CONFUSING. SURPRISINGLY, LITTLE ATTENTION TO DATE HAS BEEN PAID TO THE HUMAN ENGINEERING PRACTICES THAT MAXIMIZE RELIABLE HUMAN PERFORMANCE. MAJOR MODIFICATIONS ARE PROHIBITIVE BY COSTS AND PLANT AVAILABILITY, BUT THERE IS MUCH THE OPERATOR CAN DO TO BACKFIT OPERATOR AIDS. THIS ARTICLE PRESENTS NUMEROUS PRACTICAL APPLICATIONS OF INNOVATIVE IDEAS TO AID THE OPERATOR, INCLUDING SOME THAT ARE ALREADY IN USE AT VARIOUS NUCLEAR PLANTS. THESE INNOVATIONS ARE INTENDED TO ASSIST IN LOCATING CONSOLE COMPONENTS, TO SUPPLY ADDITIONAL OPERATING INFORMATION, TO IMPROVE THE USE OF PROCEDURES, AND TO PROTECT VITAL CONTROLS. IF PROPERLY APPLIED, THESE AIDS SHOULD IMPROVE THE SAFETY AND EFFICIENCY OF THE NUCLEAR POWER PLANT.

18-3-1-281

THE REACTOR LICENSING PROCESS - A STATUS REPORT LONG, J. A.

U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.

THE NUCLEAR REGULATORY COMMISSION (NRC), IN ITS REVIEW OF APPLICATIONS FOR LICENSES TO CONSTRUCT AND OPERATE NUCLEAR POWER PLANTS, IS REQUIRED TO CONSIDER THOSE MEASURES NECESSARY TO ENSURE THE PROTECTION OF THE HEALTH AND SAFETY OF THE PUBLIC AND THE ENVIRONMENT. THIS ARTICLE DISCUSSES THE NRC STAFF PROCEDURES AND POLICIES FOR CONSIDERING THE DETAILED SAFETY, ENVIRONMENTAL, AND ANTITRUST REVIEWS THAT PROVIDE THE BASIS FOR THESE ASSURANCES. INCLUDED IS A DISCUSSION OF THE IMPROVEMENTS TO THE LICENSING PROCESS CURRENTLY BEING PROPOSED OR IMPLEMENTED TO ENHANCE ITS STABILITY AND PREDICTABILITY FOR THE BENEFIT OF ALL INVOLVED WITH THE REGULATION OF NUCLEAR POWER. THE VIEWS AND OPINIONS EXPRESSED IN THIS ARTICLE ARE THOSE OF THE AUTHOR ALONE AND DO NOT REPRESENT POSITIONS OF THE NRC.

18-3-1-291

TRANSPORT OF RADIOACTIVE MATERIALS IN THE UNITED STATES NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

IN 1975 THE NUCLEAR REGULATORY COMMISSION SPONSORED A SURVEY OF SHIPMENTS OF RADIOACTIVE MATERIALS IN THE UNITED STATES. THE SURVEY WAS CONDUCTED BY BATTELLE PACIFIC NORTHWEST LABORATORIES. OF OVER 15,000 LICENSEES, 2279 WERE SENT QUESTIONNAIRES, AND 59 PERCENT OF THE RECIPIENTS RESPONDED. ON THE BASIS OF THE RESPONSES, IT IS ESTIMATED THAT THE TOTAL NUMBER OF PACKAGES TRANSPORTED IN THE UNITED STATES IS ON THE ORDER OF 2.5 MILLION PACKAGES PER YEAR. ABOUT ONE-THIRD OF THE PACKAGES CONTAIN ONLY SMALL QUANTITIES OF RADIOACTIVE MATERIALS AND ARE EXEMPT FROM PACKAGING AND LABELING REQUIREMENTS OF DEPARTMENT OF TRANSPORTATION REGULATIONS. ON THE BASIS OF THE NUMBER OF PACKAGES SHIPPED ANNUALLY, THE MAJOR RADIOISOTOPES ARE IODINE-131, IODINE-125, TECHNETIUM-99m, POLYBROMINUM-99, AND URANIUM-238, WHEREAS THOSE SHIPPED IN THE GREATEST QUANTITIES (GRAMS OR CURIES) ARE COBALT-60, IRIIDIUM-192, AND URANIUM-238. THE MAJORITY OF PACKAGE TYPES SHIPPED ARE EXEMPT TYPES A AND LS (LOW SPECIFIC ACTIVITY), AND THE MOST COMMON MODES OF TRANSPORT WERE TRUCK, AIR, AND RAIL.

- 19-3-2-298 CRITICAL HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT
GRIFFITH, P. + PEARSON, J. F. + LEPKOWSKI, R. ..
MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASS.
A METHOD OF CALCULATING THE MINIMUM TIME TO CRITICAL HEAT FLUX
DURING A LOSS OF COOLANT ACCIDENT IS DEVELOPED. THE TIMES
CALCULATED IN THIS WAY ARE SHOWN TO BE CONSERVATIVE BUT ARE
CLOSE TO THE EXPERIMENTAL VALUES FOR WATER AND QUITE
CONSERVATIVE FOR FREON 113. THE MODEL INVOLVES CALCULATING THE
TIME REQUIRED TO DRY OUT A CHANNEL IN WHICH THE FLOW IS
STAGNATED IN THE MIDDLE IN THE HOT REGION.
- 18-3-2-306 RESULTS OF THE FIRST THREE NONNUCLEAR TESTS IN THE LOFT FACILITY
MCPherson, G. D.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
THE LOFT FACILITY IS A WELL INSTRUMENTED, SCALED MODEL OF A
COMMERCIAL PRESSURIZED-WATER REACTOR. THE FACILITY IS DESIGNED
TO STUDY THE BEHAVIOR OF SUCH ENGINEERED SAFETY SYSTEMS AS
EMERGENCY CORE-COOLING SYSTEMS DURING REACTOR ACCIDENT
CONDITIONS. THIS ARTICLE DESCRIBES THE LOFT FACILITY, THE
CURRENT NONNUCLEAR EXPERIMENT SERIES, AND THE FORTHCOMING
NUCLEAR EXPERIMENTS. SIGNIFICANT NONNUCLEAR EXPERIMENTAL
RESULTS ALSO ARE REPORTED.
- 18-3-3-317 QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR NUCLEAR POWER APPLICATIONS
RHODES, E. W.
ITE IMPERIAL CORPORATION, MONTGOMERYVILLE, PA.
THIS ARTICLE DISCUSSES SOME OF THE PROBLEMS ENCOUNTERED AND A
MEANS FOR MEETING THE REQUIREMENTS OF IEEE STANDARD 323-1974 IN
DEMONSTRATING QUALIFICATION OF SWITCHGEAR FOR SAFETY RELATED
APPLICATIONS IN NUCLEAR POWER GENERATING STATIONS. THE
SWITCHGEAR ASSEMBLIES ARE SUBJECTED TO A NUMBER OF TESTS (E.G.,
SERVICE CONDITIONS, SEISMIC CONDITIONS, LIFE, AND AGING), WHICH
ARE REPORTED AND EVALUATED IN A QUALIFICATION SUMMARY REPORT.
THE ARTICLE CONTAINS RECOMMENDATIONS FOR MAINTENANCE,
INSPECTION, AND TESTING.
- 18-3-3-322 EMP AND NUCLEAR PLANT SAFETY
HARNES, P. R.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE ELECTROMAGNETIC PULSE (EMP) FROM A HIGH ALTITUDE NUCLEAR
DETONATION CONSISTS OF A TRANSIENT PULSE OF HIGH INTENSITY
ELECTROMAGNETIC FIELDS THAT INDUCE CURRENT AND VOLTAGE
TRANSIENTS IN ELECTRICAL CONDUCTORS. ALTHOUGH MOST NUCLEAR
POWER PLANT CABLES ARE NOT DIRECTLY EXPOSED TO THESE FIELDS,
THE ATTENUATED EMP FIELDS THAT PROPAGATE INTO THE PLANT WILL
COUPLE SOME EMP ENERGY TO THESE CABLES. THIS ARTICLE ATTEMPTS
TO PREDICT THE PROBABLE EFFECTS OF THE EMP TRANSIENTS THAT
COULD BE INDUCED IN CRITICAL CIRCUITS OF SAFETY RELATED
SYSTEMS. IT IS CONCLUDED THAT THE MOST LIKELY CONSEQUENCE OF
EMP FOR NUCLEAR PLANTS IS AN UNSCHEDULED SHUTDOWN. IN GENERAL,
EMP COULD BE A NUISANCE TO NUCLEAR POWER PLANTS, BUT IT IS NOT
CONSIDERED A SERIOUS THREAT TO PLANT SAFETY.
- 18-3-5-329 COLD SHOCK TO AQUATIC ORGANISMS - GUIDANCE FOR POWER PLANT SITING, DESIGN, AND OPERATION
COUTANT, C. C.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
PROBLEMS OF COLD SHOCK DAMAGES TO AQUATIC ORGANISMS HAVE ARISEN
AT SOME CONDENSER COOLING WATER DISCHARGES OF THERMAL POWER
STATIONS WHEN THE WARM WATER RELEASES HAVE SUDDENLY TERMINATED.
THE BASIS FOR SUCH DAMAGE LIES IN THE EXPOSURE OF RESIDENT
ORGANISMS TO A RAPID DECREASE IN TEMPERATURE AND A SUSTAINED
EXPOSURE TO LOW TEMPERATURE THAT INDUCES ABNORMAL BEHAVIORAL OR
PHYSIOLOGICAL PERFORMANCE AND OFTEN LEADS TO DEATH. ALTHOUGH
SOME SPECTACULAR FISH KILLS FROM COLD SHOCK HAVE OCCURRED, THE
PRESENT KNOWLEDGE OF THE HYDRAULIC AND BIOLOGICAL PROCESSES
INVOLVED CAN PROVIDE GUIDANCE FOR THE SITING, DESIGN, AND
OPERATION OF POWER PLANT COOLING SYSTEMS TO MINIMIZE THE
LIKELIHOOD OF SIGNIFICANT COLD SHOCK EFFECTS. PREVENTING
COLD-SHOCK DAMAGES IS ONE CONSIDERATION IN MINIMIZING OVERALL
ENVIRONMENTAL IMPACTS OF POWER PLANT COOLING AND IN BALANCING
PLANT COSTS WITH ENVIRONMENTAL BENEFITS.
- 18-3-5-343 COMPUTER CODES FOR THE ASSESSMENT OF RADIONUCLIDES RELEASED TO THE ENVIRONMENT
HOFFMAN, F. G. + MILLER, C. W. + SHAEFFER, D. L.
GARTEN, C. T., JR.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE PRESENTS A COMPILATION OF COMPUTER CODES THAT MAY
BE USED FOR THE ASSESSMENT OF ACCIDENTAL OR ROUTINE RELEASES OF
RADIOACTIVITY TO THE ENVIRONMENT FROM NUCLEAR POWER FACILITIES.
THE CAPABILITIES OF 83 COMPUTER CODES IN THE AREAS OF
ENVIRONMENTAL TRANSPORT AND RADIATION DOSIMETRY ARE SUMMARIZED
IN TABULAR FORM. THIS PRELIMINARY ANALYSIS CLEARLY INDICATES
THAT THE INITIAL EFFORTS IN ASSESSMENT METHODOLOGY DEVELOPMENT
HAVE CONCENTRATED ON ATMOSPHERIC DISPERSION, EXTERNAL
DOSIMETRY, AND INTERNAL DOSIMETRY VIA INHALATION. THE
INCORPORATION OF TERRESTRIAL AND AQUATIC FOOD-CHAIN PATHWAYS
HAS BEEN A MORE RECENT DEVELOPMENT AND REFLECTS THE NEED FOR
SATISFYING THE CURRENT REQUIREMENTS OF ENVIRONMENTAL
LEGISLATION AND THE NEEDS OF REGULATORY AGENCIES. THE
CHARACTERISTICS OF THE CONCEPTUAL MODELS EMPLOYED BY THESE
CODES ARE REVIEWED.

- 18-3-6-355 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR REACTORS IN 1975
HARE, M. G.
ATOMIC ENERGY OF CANADA LIMITED, ONTARIO, CANADA
STEAM GENERATOR TUBE FAILURES WERE REPORTED IN 22 OUT OF 62 WATER COOLED NUCLEAR POWER PLANTS SURVEYED IN 1975. THIS WAS LESS THAN THE NUMBER OF PLANTS WITH REPORTED TUBE FAILURES IN 1974, AND THE NUMBER OF TUBES AFFECTED WAS NOTICEABLY LESS. THIS ARTICLE SUMMARIZES THESE FAILURES, MOST OF WHICH WERE DUE TO CORROSION. SECONDARY WATER CHEMISTRY CONTROL, PROCEDURES FOR INSPECTION AND REPAIR, TUBE MATERIALS, AND FAILURE RATES ARE DISCUSSED.
- 18-3-6-365 OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975
MURPHY, T. D. + DAYEN, M. J. + BLAND, J. S.
PASCIAK, W. J.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
THIS ARTICLE IS A COMPILATION OF OCCUPATIONAL RADIATION EXPOSURES AT COMMERCIAL LIGHT WATER COOLED REACTORS (LWRs) FROM 1969 TO 1975 AND UPDATES PREVIOUS INFORMATION THAT COVERED EXPOSURES THROUGH 1974. THE INFORMATION WAS DERIVED FROM REPORTS SUBMITTED TO THE NUCLEAR REGULATORY COMMISSION IN ACCORDANCE WITH REQUIREMENTS OF INDIVIDUAL PLANT TECHNICAL SPECIFICATIONS AND THE CODE OF FEDERAL REGULATIONS. THE COLLECTIVE DOSE TO PERSONNEL (MAN-REMS PER REACTOR PER YEAR) AT LWRs WAS GREATER IN 1975 THAN IN 1974. ALTHOUGH THE AVERAGE EXPOSURE PER INDIVIDUAL REMAINED AT 0.8 REM/YEAR, THE AVERAGE NUMBER OF PERSONNEL RECEIVING MEASURABLE EXPOSURES PER REACTOR INCREASED IN 1975.
- 18-3-6-370 RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS IN EUROPE, 1970-1974
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
(EIGHTH'S NOTE - THE PRODUCTION OF ELECTRICITY BY THE USE OF NUCLEAR POWER IS A WORLDWIDE PHENOMENON, AS IS THE CONCOMITANT CONCERN REGARDING RADIOACTIVE EFFLUENTS.) THIS ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY STAFF FROM A RECENT REPORT BY THE COMMISSION OF EUROPEAN COMMUNITIES THAT SUMMARIZES THE DISCHARGE DATA FOR SOME 34 POWER REACTORS (LESS THAN 50 MW(E)) OPERATING WITHIN THE EUROPEAN COMMUNITY. ON THE BASIS OF THESE DISCHARGES, MAXIMUM EXPOSURE IN THE VICINITY OF POWER STATIONS IS ASSESSED AND COMPARED WITH THE DOSE LIMITS FIXED BY RADIOLOGICAL PROTECTION STANDARDS AND WITH THE NATURAL RADIATION LEVEL. ALSO, THE RADIOACTIVE WASTE DISCHARGE PER UNIT ELECTRICAL ENERGY PRODUCED IS GIVEN FOR EACH POWER STATION. IN GENERAL, THE EUROPEAN EXPERIENCE IS SIMILAR TO THAT OF THE UNITED STATES, WHERE, IN ACCORDANCE WITH NRC 'AS LOW AS REASONABLY ACHIEVABLE' REGULATIONS, INDUSTRIAL OFF-SITE EXPOSURES MUST BE KEPT BELOW 5 MREMS/YEAR.
- 18-4-1-427 THE HOMEMADE NUCLEAR BOMB SYNDROME
MEYER, W. + LOVILKA, S. K. + NELSON, W. E.
WILLIAMS, R. W.
UNIVERSITY OF MISSOURI, COLUMBIA, MO.
WITH THE PUBLICATION OF NUCLEAR THEFT - RISKS AND SAFEGUARDS BY WILLRICH AND TAYLOR, SIGNIFICANT ATTENTION HAS BEEN FOCUSED BY THE MEDIA AND THE PUBLIC ON THE POSSIBILITY OF FISSILE MATERIALS BEING STOLEN BY A TERRORIST ORGANIZATION AND DIVERTED TO THE ACTUAL BUILDING, OR THE THREAT OF BUILDING, OF A NUCLEAR EXPLOSIVE DEVICE. THE IMPLICATION HAS BEEN CREATED THAT ONE OR SEVERAL RELATIVELY INEXPERIENCED INDIVIDUALS COULD OBTAIN THE MATERIALS NECESSARY AND FABRICATE A LOW-YIELD NUCLEAR EXPLOSIVE. THIS ARTICLE EXAMINES THESE CONTENTIONS IN SOME DETAIL. THE SAFEGUARDS AND USE-DENIAL METHODS PRESENTLY USED IN THE NUCLEAR FUEL CYCLE ARE CONSIDERED, AND THE DIFFICULTIES THEY PRESENT IN OBTAINING SIGNIFICANT AMOUNTS OF STRATEGIC NUCLEAR MATERIALS ARE EXAMINED. THE CHARACTERISTICS OF REACTOR GRADE PLUTONIUM ARE DISCUSSED, AND THE DIFFICULTIES ASSOCIATED WITH THE ASSEMBLY OF AN EFFICIENT NUCLEAR EXPLOSIVE DEVICE ARE OUTLINED.
- 18-4-1-430 THE RUSSIAN APPROACH TO NUCLEAR REACTOR SAFETY
LEWIN, J.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
SOVIET REACTOR AND POWER STATION DESIGN INITIALLY PROCEEDED FROM A SAFETY PHILOSOPHY THAT DID NOT ACKNOWLEDGE A LOSS OF COOLANT ACCIDENT CAUSED BY A DOUBLE ENDED PIPE BREAK NOR A MASSIVE CORE MELTDOWN AS CREDIBLE EVENTUALITIES TO BE CONSIDERED IN THE DESIGN OF SYSTEMS AND DETAILS. GENERALLY, ENGINEERED SAFEGUARDS AND CONSERVATISM IN DESIGN HAVE BEEN REGARDED AS ADEQUATE INSURANCE AGAINST ACCIDENTS THAT COULD ESCALATE TO A POINT WHERE THERE IS SIGNIFICANT RADIATION DAMAGE TO EITHER PLANT PERSONNEL OR THE PUBLIC. RECENTLY, THERE HAS BEEN SOME CHANGE IN THE ATTITUDE OF SCIENTISTS TOWARD SECONDARY CONTAINMENT IN PRESSURIZED WATER REACTOR PLANTS. IN PRESSURE TUBE BOILING WATER REACTORS AND LIQUID METAL COOLED FAST BREEDER REACTORS, SOVIET EXPERIENCE ON SEVERAL DEMONSTRATION AND 'SEMICOMMERCIAL' UNITS HAS BEEN INTERPRETED TO MEAN THAT CORE DAMAGE PROPAGATION AND ACCIDENTS INVOLVING LARGE ENERGY RELEASES ARE NOT CREDIBLE. IT APPEARS, HOWEVER, THAT THERE IS NOT COMPLETE UNANIMITY ON ALL SAFETY QUESTIONS, AND GREATER DISPERSION OF AUTHORITY AND MORE FORMAL SAFETY REVIEWS SEEM TO BE IN THE MAKING.

- 18-4-2-451 1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSICS
FONTANA, M. M.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THIS ARTICLE REVIEWS SOME OF THE SIGNIFICANT SAFETY TOPICS THAT WERE DISCUSSED DURING THE INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSICS HELD IN CHICAGO ON OCT. 5-8, 1976, UNDER THE AUSPICES OF THE AMERICAN NUCLEAR SOCIETY AND THE NEWLY FORMED EUROPEAN NUCLEAR SOCIETY. TWENTY-NINE SESSIONS WERE HELD, INCLUDING TWO LUNARY SESSIONS. MORE THAN 226 PAPERS WERE PRESENTED. BECAUSE OF THE IMPOSSIBILITY OF REPORTING ALL THE SESSIONS, THE REVIEWER HAS ATTEMPTED TO CONVEY A CONSENSUS OF THE STATE OF THE ART OF FAST REACTOR SAFETY AS REPORTED AT THIS MEETING.
- 18-4-3-469 IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FAST BREEDER REACTORS
MCCLUNG, R. W. + SPANMER, J. C. + NAGEN, E. W.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN. AND WESTINGHOUSE HANFORD COMPANY, HANFORD, WASH.
ALTHOUGH FIRM REQUIREMENTS HAVE NOT YET BEEN ESTABLISHED IN THE UNITED STATES FOR IN-SERVICE INSPECTION OF LIQUID METAL COOLED FAST BREEDER REACTORS, SOME INITIAL DEVELOPMENT WORK ON POTENTIALLY APPLICABLE NONDESTRUCTIVE TESTING METHODS HAS BEEN CONDUCTED. THIS ARTICLE DESCRIBES PRELIMINARY INVESTIGATIONS OF SEVERAL ADVANCED NONDESTRUCTIVE TESTING CONCEPTS FOR LIQUID SODIUM SYSTEMS. THE METHODS HIGHLIGHTED FOR POTENTIAL APPLICATION ARE ULTRASONICS, EDDY CURRENTS, ELECTROTHERMAL TESTING, UNDER SODIUM VIEWING, AND RADIOGRAPHY.
- 18-4-4-481 NUCLEAR SAFETY EXPERIMENTS IN THE MARViken POWER STATION
SLAUGHTERBECK, D. C. + ERICSON, L.
MARVIKEN, SWEDEN
THIS ARTICLE REVIEWS THREE MULTINATIONAL PROJECTS CONCERNING FULL SCALE NUCLEAR SAFETY EXPERIMENTS AT THE MARViken POWER STATION IN SWEDEN. EXPERIMENTS IN THE FIRST PROJECT, CARRIED OUT IN 1972 AND 1973, WERE RELATED TO THE RESPONSE OF THE PRESSURE SUPPRESSION CONTAINMENT TO SIMULATED RUPTURES IN PIPE SYSTEMS CONNECTED TO THE PRESSURE VESSEL. EXPERIMENTS IN THE SECOND PROJECT, CURRENTLY UNDER WAY, ARE RELATED TO PRESSURE OSCILLATIONS IN THE CONTAINMENT SYSTEM FOLLOWING SIMULATED RUPTURES IN THE PIPE SYSTEM. THE THIRD PROJECT CONCERNS A PROPOSED PROGRAM FOR THE EXPERIMENTAL INVESTIGATION OF CRITICAL MASS FLOW THROUGH SIMULATED RUPTURES IN A FULL SCALE PIPING SYSTEM.
- 18-4-5-492 CONTROLLING OCCUPATIONAL RADIATION EXPOSURE AT OPERATING NUCLEAR POWER STATIONS
DICKSON, H. W. + JAKES, T. W. + SHANK, R. E.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
THE HISTORICAL DEVELOPMENT OF THE PHILOSOPHY OF KEEPING THE RADIATION EXPOSURE OF WORKERS AT LIGHT WATER REACTORS AS LOW AS REASONABLY ACHIEVABLE (ALARA) IS PRESENTED. A REVIEW IS MADE OF SOME OF THE ALARA ACTIVITIES OF THE NUCLEAR REGULATORY COMMISSION, THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, AND VARIOUS NUCLEAR INSTALLATIONS. DATA COMPILED BY THE NRC SHOW THAT ROUTINE AND SPECIAL MAINTENANCE AT LIGHT WATER REACTORS ACCOUNTS FOR 72 PERCENT OF ALL OCCUPATIONAL EXPOSURE AT THESE SITES. THE ROLE THAT OAK RIDGE NATIONAL LABORATORY HAS TAKEN IN ALARA RESEARCH IS PRESENTED, WITH EMPHASIS PLACED ON A STUDY OF VALVE MALFUNCTIONS AT LIGHT WATER REACTORS. THE VALVE STUDY INDICATES A TREND TOWARD DECREASING VALVE RELIABILITY OVER THE PAST FEW YEARS. FINALLY A COST BENEFIT ANALYSIS OF RADIATION DOSE REDUCTION IS DISCUSSED. THE RATIONALE FOR ASSIGNING A COST PER MAN REM BASED ON THE RADIATION EXPOSURE LEVEL THAT IS ENCOUNTERED IS PRESENTED.
- 18-4-5-502 INTERNATIONAL WASTE MANAGEMENT SYMPOSIUM
SMOUP, R. L.
UNION CARBIDE CORPORATION, NUCLEAR DIVISION, OAK RIDGE, TENN.
AN INTERNATIONAL SYMPOSIUM ON THE MANAGEMENT OF WASTES FROM THE LWR FUEL CYCLE WAS HELD IN DENVER, COLO., ON JULY 11-16, 1976. THE SYMPOSIUM COVERED A BROAD RANGE OF TOPICS FROM POLICY ISSUES TO TECHNOLOGY. PRESENTATIONS WERE MADE BY NATIONAL AND INTERNATIONAL SPEAKERS INVOLVED IN ALL ASPECTS OF WASTE MANAGEMENT - GOVERNMENT AND AGENCY OFFICIALS, LABORATORY MANAGERS, DIRECTORS, AND RESEARCHERS, AND INDUSTRIAL REPRESENTATIVES. MANY SPEAKERS ADVOCATED PRAGMATIC ACTION ON PROGRAMS FOR THE MANAGEMENT OF COMMERCIAL NUCLEAR WASTES TO COMPLETE THE LIGHT WATER REACTOR (LWR) FUEL CYCLE. THE INDUSTRIALIZED NATIONS' DEMAND FOR INCREASING SUPPLIES OF ENERGY AND THEIR INCREASING DEPENDENCE ON NUCLEAR ENERGY TO FULFILL THIS DEMAND WILL NECESSITATE THE DEVELOPMENT OF AN ACCEPTABLE SOLUTION TO THE DISPOSAL OF NUCLEAR WASTES WITHIN THE NEXT DECADE FOR SOME INDUSTRIAL NATIONS. WASTE DISPOSAL TECHNOLOGY SHOULD BE IMPLEMENTED ON A COMMERCIAL SCALE, BUT THE COMMERCIALIZATION MUST BE ACCOMPANIED BY THE DECISION TO USE THE TECHNOLOGY. AN IMPORTANT ISSUE IN THE USE OF NUCLEAR ENERGY IS THE QUESTION OF SHARING THE TECHNOLOGY WITH THE LESS INDUSTRIALIZED NATIONS AND WITH NATIONS THAT MAY NOT HAVE SUITABLE MEANS TO DISPOSE OF NUCLEAR WASTES. THE ESTABLISHMENT OF INTERNATIONAL AND MULTINATIONAL COOPERATION WILL BE AN IMPORTANT KEY IN REALIZING THIS OBJECTIVE. PRESSING ISSUES THAT INTERNATIONAL ORGANIZATIONS OR TASK GROUPS WILL HAVE TO

ADDRESS ARE OCEAN DISPOSAL, PLUTONIUM RECYCLING AND SAFEGUARDS, AND DISPOSAL CRITERIA. THE IMPORTANCE OF ACHIEVING A VIABLE WASTE MANAGEMENT PROGRAM IS MADE EVIDENT BY THE INCREASED FUNDING AND ATTENTION THAT THE BACK END OF THE FUEL CYCLE IS NOW RECEIVING.

- 10-4-6-513 REACTOR VESSEL PRESSURE TRANSIENTS
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY SECTION EDITOR FROM A NUCLEAR REGULATORY COMMISSION (NRC) DOCUMENT ENTITLED "TECHNICAL REPORT ON REACTOR PRESSURE VESSEL TRANSIENTS," WHICH WAS INCLUDED AS AN ATTACHMENT TO NUREG-0130, "STAFF DISCUSSION OF FIFTEEN TECHNICAL ISSUES LISTED IN ATTACHMENT TO NOVEMBER 3, 1976, MEMORANDUM FROM DIRECTOR OF NRC TO NRC STAFF." SINCE SPACE LIMITATIONS DO NOT PERMIT US TO INCLUDE THE TECHNICAL REPORT IN ITS ENTIRETY, THE EDITORS HAVE PREPARED THE FOLLOWING CONDENSED VERSION LARGELY FROM EXCERPTS FROM THE ORIGINAL. THE ORIGINAL REPORT, DATED NOV. 3, 1976, WAS PREPARED BY A TASK GROUP WORKING UNDER THE AUSPICES OF THE NRC OFFICE OF NUCLEAR REACTOR REGULATION AND CHAIRED BY G. G. EISENHUT. THIS REPORT SUMMARIZES THE RELEVANT TECHNICAL CONSIDERATIONS, DISCUSSES THE SAFETY CONCERNS AND EXISTING MARGINS AT OPERATING REACTORS, AND DESCRIBES THE REGULATORY ACTIONS BEING TAKEN TO REDUCE THE LIKELIHOOD OF FUTURE PRESSURE TRANSIENT EVENTS AT OPERATING REACTORS.
- 10-4-6-523 OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES, 1975
BROOKS, B. G.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
PERSONNEL OCCUPATIONAL RADIATION EXPOSURES FOR CALENDAR YEAR 1975 WERE OBTAINED FROM ANNUAL AND TERMINATION REPORTS SUBMITTED BY VARIOUS TYPES OF NUCLEAR REGULATORY COMMISSION LICENSEES, INCLUDING NUCLEAR POWER PLANTS AND INDUSTRIAL RADIOGRAPHERS, AS WELL AS FUEL AND BY-PRODUCT PROCESSORS, FABRICATORS, AND REPROCESSORS. ANNUAL REPORTS RECEIVED FROM 387 LICENSEES INDICATED THAT SOME 78,713 INDIVIDUALS, WHO INCURRED AN AVERAGE EXPOSURE OF 0.36 REM, WERE MONITORED FOR EXPOSURE TO RADIATION DURING 1975 AND THAT 21,601 INDIVIDUALS TERMINATED THEIR EMPLOYMENT OR WORK ASSIGNMENT IN 1975. THE NUMBER OF PERSONNEL OVEREXPOSURES REPORTED IN 1975 DECREASED FROM PREVIOUS YEARS.
- 10-5-1-501 TRENDS IN THE LICENSING OF NUCLEAR POWER PLANTS
KATH, D. F. + MCWEN, J. E., JR.
NRC, INC., WASHINGTON, D.C.
THIS ARTICLE PRESENTS A BRIEF SUMMARY OF THE U.S. NUCLEAR LICENSING EXPERIENCE AND DISCUSSES THE EFFECT ON COSTS AND TIME TO PLACE A UNIT IN SERVICE. RECENT NUCLEAR REGULATORY COMMISSION POLICY INNOVATIONS, SUCH AS STANDARD REVIEW PLANS, STANDARD FORMAT, STANDARDIZATION, AND GENERIC HEARINGS, ARE DISCUSSED ALONG WITH OBSERVATIONS OF THE IMPACT ON THE LICENSING REVIEW. TECHNICAL AND POLICY UNCERTAINTIES THAT ARE CURRENTLY FACING LICENSEES ARE ALSO DISCUSSED, AS ARE THE POTENTIAL IMPACTS OF TECHNICAL AND LEGAL INTERFACES REQUIRED BY THE INCREASING NUMBER OF GENERIC HEARINGS, STATE HEARINGS, AND FEDERAL COURT REVIEWS.
- 10-5-1-509 NRC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEARCH
BENNETT, G. L. + SPANO, A. M. + SZANLEWICZ, S. A.
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.
THE NUCLEAR REGULATORY COMMISSION AND ITS PREDECESSOR, THE ATOMIC ENERGY COMMISSION, HAVE ENTERED INTO A NUMBER OF REACTOR SAFETY RESEARCH AGREEMENTS WITH OTHER COUNTRIES. THESE AGREEMENTS INVOLVE VARIOUS FORMS OF COOPERATION INCLUDING BILATERAL INFORMATION EXCHANGE AND JOINT RESEARCH PARTICIPATION IN SPECIFIC PROJECTS ON A BILATERAL OR MULTILATERAL LEVEL. UNDER THE TERMS OF THESE AGREEMENTS, REPORTS, COMPUTER CODES, AND DATA MAY BE EXCHANGED AND PERSONNEL VISITS AND ASSIGNMENTS PERMITTED. THESE AGREEMENTS HAVE PROVED TO BE BENEFICIAL IN PROVIDING FOR A COST EFFECTIVE EXTENSION OF THE BASE OF REACTOR SAFETY INFORMATION AVAILABLE TO THE PARTIES CONCERNED. SUCH AGREEMENTS HELP TO ENHANCE REACTOR SAFETY WORLDWIDE.
- 10-5-2-506 A REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER
BJERRE, M. A. + HOLM, J. S. + SHAY, M. R.
SPINRAD, B. I.
OREGON STATE UNIVERSITY, CORVALLIS, OREG.
EXPERIMENTS ON SHORT TERM FISSION PRODUCT DECAY POWER, WHICH MAY BE IMPORTANT FOR LOSS OF COOLANT ACCIDENT ANALYSIS, ARE REVIEWED. THE MOST RECENT EXPERIMENTS GIVE SUFFICIENT DATA TO FORM THE BASIS OF REASONABLE STANDARDS, PARTICULARLY WHEN THEY ARE SUPPLEMENTED WITH RESULTS FROM JURNATION PREDICTIONS. THE PREPARATION OF IMPROVED STANDARDS FOR SCIENTIFIC AND REGULATORY PURPOSES IS IN AN ADVANCED STAGE. PRELIMINARY ESTIMATES INDICATE THAT THE EXISTING STANDARD PROPOSED BY THE AMERICAN NUCLEAR SOCIETY HAS AN EXTREMELY CONSERVATIVE UNCERTAINTY BAND ASSOCIATED WITH IT. NEW DATA PROVIDE FIRM JUSTIFICATION FOR REDUCING THE UNCERTAINTY ASSOCIATED WITH THE EXISTING STANDARD.

- 18-5-3-617 INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT SITES
ALLEN, J. M. + KARNER, D. B.
ARIZONA NUCLEAR POWER PROJECT, PHOENIX, ARIZ.
TYPICAL INSTRUMENTATION PROGRAMS TO DETERMINE THE SUITABILITY OF A PROPOSED NUCLEAR POWER PLANT SITE ARE DESCRIBED. AN OVERVIEW OF REGULATORY REQUIREMENTS IS PRESENTED, ALONG WITH A BRIEF DISCUSSION OF TYPICAL METEOROLOGICAL, SEISMOLOGICAL, GEOLOGICAL, RADIOLOGICAL, AND SEWAGE EFFLUENT MONITORING SYSTEMS. THE DISCUSSION DEFINES THE VARIOUS PARAMETERS THAT MUST BE MEASURED AND DESCRIBES THE TYPICAL SENSORS, TRANSDUCERS, AND INSTRUMENTATION USED. PROBLEMS PRESENTED BY A REMOTE DESERT SITE, SUCH AS ONE LOCATED IN THE ARIZ SOUTHWESTERN UNITED STATES, ARE ALSO DISCUSSED.
- 18-5-3-626 COMMON-MODE FAILURES IN REACTOR SAFETY SYSTEMS
JOLLY, M. E. + WREATHALL, J.
U.K. CENTRAL ELECTRICITY GENERATING BOARD
THIS ARTICLE DESCRIBES THE PRINCIPLES ADOPTED BY THE U.K. CENTRAL ELECTRICITY GENERATING BOARD IN TACKLING THE HAZARDS OF COMMON-MODE FAILURES IN REACTOR SAFETY EQUIPMENT AND INDICATES THE WAYS IN WHICH THE PRINCIPLES ARE IMPLEMENTED IN PRACTICE. WHERE APPROPRIATE, REFERENCE IS ALSO MADE TO APPLICATIONS IN PCESTRIP COOLING AREAS. RECOGNITION IS GIVEN TO THE FACT THAT DIVERSITY IS NOT AN ABSOLUTE MEASURE, BUT ONE WHICH HAS VARYING DEGREES OF CEPTH. THE DISCUSSION IS EXTENDED TO SHOW THAT THE USE OF EXAMINATION IN DEPTH MUST INCLUDE NOT ONLY HARDWARE BUT ALSO CALCULATIONAL METHODS AND OPERATOR ASPECTS. IT IS CONCLUDED THAT THERE IS NO OBJECTIVE WAY OF ESTABLISHING THE PROBABILITY OF COMMON-MODE FAILURE FOR HIGH INTEGRITY EQUIPMENT AND THAT THERE IS NO SUBSTITUTE FOR THE USE OF ENGINEERING EXPERIENCE IN DEPTH.
- 18-5-4-633 CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES
MOELLER, D. M.
HARVARD UNIVERSITY, BOSTON, MASS.
THE SAFE OPERATION OF NUCLEAR FACILITIES IS HEAVILY DEPENDENT UPON THE ADEQUATE PERFORMANCE OF AIR CLEANING SYSTEMS. ALTHOUGH MANY PROBLEMS HAVE BEEN SOLVED, NEW QUESTIONS AND NEW CHALLENGES CONTINUE TO ARISE. THESE ARE WELL ILLUSTRATED BY WEAKNESSES IN AIR CLEANING AND VENTILATING SYSTEMS REVEALED IN THE BROWNS FERRY FIRE AND BY THE NEED TO DEVELOP ADDITIONAL DATA ON THE RELIABILITY OF SUCH SYSTEMS, PARTICULARLY UNDER EMERGENCY CONDITIONS. AS ENUMERATED IN THE REACTOR SAFETY STUDY, ASSESSMENTS OF THE DEGREE TO WHICH ENGINEERED SAFETY FEATURES CAN COMPENSATE FOR DEFICIENCIES IN NUCLEAR POWER PLANT SITES CONTINUE TO CONCERN THOSE INVOLVED IN RISK / BENEFIT EVALUATIONS.
- 18-5-5-647 TRENDS IN PUBLIC HEALTH IN THE POPULATION NEAR NUCLEAR FACILITIES - A CRITICAL ASSESSMENT
PATRICK, C. M.
U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D.C.
TEN STUDIES THAT HAVE LOOKED SPECIFICALLY AT CHANGES IN PUBLIC HEALTH IN AREAS NEAR NUCLEAR FACILITIES ARE CRITICALLY REVIEWED. ALL BUT ONE OF THESE STUDIES HAVE BEEN UNABLE TO SHOW ADVERSE HEALTH EFFECTS IN THE LOCAL POPULATION THAT MIGHT BE RELATED TO RADIATION EXPOSURE. THE ONE STUDY THAT PURPORTS TO FIND AN ADVERSE EFFECT HAS SEVERE METHODOLOGICAL LIMITATIONS, WHICH PRECLUDE ANY MEANINGFUL INTERPRETATION OF THE DATA. ALSO PRESENTED IS AN ANALYSIS OF THE INDICATORS OF PUBLIC HEALTH IN THE AREA OF OAK RIDGE, TENN., WHICH SHOWS CANCER MORTALITY RATES THAT ARE NOT SIGNIFICANTLY HIGHER THAN WOULD BE EXPECTED IN THE GENERAL U.S. POPULATION. ALTHOUGH MUCH MORE RESEARCH IS NEEDED BEFORE ALL THE EFFECTS OF VERY LOW LEVELS OF RADIATION FROM NUCLEAR REACTORS WILL BE KNOWN, THE EXISTING STUDIES SUGGEST THAT NUCLEAR POWER PLANTS WILL NOT HAVE A SIGNIFICANT IMPACT ON PUBLIC HEALTH AS A RESULT OF NORMAL OPERATIONS.
- 18-5-6-664 NUCLEAR POWER PLANT PERFORMANCE ANALYSIS
KUPFER, K.
NORDOSTSCHWEIZERISCHE KRAFTWERK, ZADEN, SWITZERLAND
EDITOR'S NOTE - IN NOVEMBER 1976 THE INTERNATIONAL CONFERENCE ON WORLD NUCLEAR POWER WAS HELD IN WASHINGTON, D.C., AND WAS JOINTLY SPONSORED BY THE AMERICAN NUCLEAR SOCIETY AND THE EUROPEAN NUCLEAR SOCIETY. K. KUPFER, WHO WAS COCHAIRMAN OF ONE OF THE SESSIONS, OPENED THAT SESSION WITH THE REMARKS THAT COMPRISE THE TEXT OF THIS ARTICLE. DR. KUPFER IS ASSOCIATED WITH NORDOSTSCHWEIZERISCHE KRAFTWERK OF BADEN, SWITZERLAND, AND HAS BEEN DEEPLY INVOLVED WITH THE OPERATION OF THE BEZNAU NUCLEAR POWER STATION. HIS REMARKS SUMMARIZE POWER PLANT PERFORMANCE IN EUROPE, IN THE UNITED STATES, AND ELSEWHERE AND SHOULD BE OF INTEREST TO ALL PERSONS CONCERNED WITH SUCH ACTIVITIES.
- 18-5-6-666 OPERATING EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE
LUTZ, M. R. + KUPFER, K. + SCHENK, K.
KERNKRAFTWERK MUEHLEBERG DER BERNISCHE KRAFTWERK, MUEHLEBERG, SWITZERLAND / KERNKRAFTWERK BEZNAU DER NORDOSTSCHWEIZERISCHE KRAFTWERK, DOETTINGEN, SWITZERLAND / KERNKRAFTWERK OBRIGHEIM GMBH, UBRIGHEIM, NECKAR, FEDERAL REPUBLIC OF GERMANY
THE OPERATING EXPERIENCE OF 13 EUROPEAN LIGHT WATER REACTOR (LWR) POWER STATIONS THAT BEGAN OPERATION PRIOR TO JANUARY

1973 IS PRESENTED. GIVEN ARE KEY PARAMETERS, SUCH AS AVERAGE LOAD FACTOR, LOAD DIAGRAMS, NONAVAILABILITY ANALYSES, STATISTICS ON LEAKING FUEL ELEMENTS, RADIOACTIVITY DISCHARGE VALUES, SIZE OF POWER STATION STAFFS, MAN REM EXPOSURES, ADDITIONAL INVESTMENTS, ETC. SOME SPECIAL EVENTS ARE DESCRIBED IN DETAIL. THEORIES FOR THE DISPARITIES IN CAPACITY FACTORS BETWEEN EUROPEAN AND AMERICAN LWR POWER STATIONS AND BETWEEN PRESSURIZED WATER REACTOR AND BOILING WATER REACTOR POWER STATIONS ARE ALSO PRESENTED.

- 18-6-1-727 GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM
SEIPEL, W. G. + LUMMERZHEIM, G. + RITTEG, D.
FEDERAL MINISTRY OF RESEARCH AND TECHNOLOGY, FEDERAL REPUBLIC OF GERMANY
- THE LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM, WHICH IS PART OF THE ENERGY PROGRAM OF THE FEDERAL REPUBLIC OF GERMANY, IS PRESENTED IN THIS ARTICLE. THE PROGRAM, FOR WHICH THE FEDERAL MINISTER OF RESEARCH AND TECHNOLOGY OF THE FEDERAL REPUBLIC OF GERMANY IS RESPONSIBLE, IS SUBDIVIDED INTO THE FOLLOWING FOUR MAIN PROBLEM AREAS, WHICH IN TURN ARE SUBDIVIDED INTO PROJECTS (1) IMPROVEMENT OF THE OPERATIONAL SAFETY AND RELIABILITY OF SYSTEMS AND COMPONENTS (PROJECTS - QUALITY ASSURANCE, COMPONENT SAFETY) (2) ANALYSIS OF THE CONSEQUENCES OF ACCIDENTS (PROJECTS - EMERGENCY CORE COOLING, CONTAINMENT, EXTERNAL IMPACTS, PRESSURE VESSEL FAILURE, CORE MELTDOWN) (3) ANALYSIS OF RADIATION EXPOSURE DURING OPERATION, ACCIDENT, AND DECOMMISSIONING (PROJECT - FISSION PRODUCT TRANSPORT AND RADIATION EXPOSURE) AND (4) ANALYSIS OF THE RISK CREATED BY THE OPERATION OF NUCLEAR POWER PLANTS (PROJECT - RISK AND RELIABILITY). VARIOUS PROBLEMS, WHICH ARE INCLUDED IN THE ABOVE MENTIONED PROJECTS ARE CONCURRENTLY STUDIED WITHIN THE NEISS-DAMP REACTOR EXPERIMENTS. INVESTIGATIONS ON THE SAFETY OF PRESSURIZED REACTOR COMPONENTS IN CONNECTION WITH RESEARCH AND DEVELOPMENT ACTIVITIES ON NONDESTRUCTIVE TESTING HAVE SHOWN THAT THE HIGH SAFETY STANDARDS THAT MUST BE SET FOR NUCLEAR INSTALLATIONS CAN BE MET BY A COMPREHENSIVE QUALITY ASSURANCE SYSTEM, WHEREBY THE MATERIAL AND PROCEDURAL TESTS, AS WELL AS THE NONDESTRUCTIVE TESTS BEFORE AND DURING THE OPERATION, ARE CAREFULLY COORDINATED WITH EACH OTHER. FURTHER INVESTIGATIONS ARE CONCENTRATED ON THE SAFETY MARGINS DURING LONGTIME OPERATION.

- 18-6-1-756 NUCLEAR SAFETY AT SALZBURG
NUCLEAR SAFETY STAFF
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
- THIS ARTICLE IS A REVIEW OF SELECTED MATERIAL FROM THE IAEA INTERNATIONAL CONFERENCE ON NUCLEAR POWER AND ITS FUEL CYCLE HELD IN SALZBURG, AUSTRIA, MAY 2-13, 1977 (IAEA-CN-36). THE SESSIONS CONSIDERED DEAL WITH NUCLEAR REACTOR SAFETY AND PUBLIC OPINION, ALTHOUGH THE SUBSEQUENT DISCUSSION INCLUDES COMMENTS ON THE ENTIRE MEETING. IN GENERAL, THE SAFETY PAPERS ARE OF VALUE BECAUSE OF THEIR COMPREHENSIVE REVIEW OF THE SUBJECT MATTER RATHER THAN TO ANY SIGNIFICANT NEW DEVELOPMENTS. THE SESSIONS ON PUBLIC OPINION NOT ONLY INDICATED THE UNIVERSALITY OF THIS ELEMENT BUT ALSO REVEALED DIFFERING DEGREES OF CONCERN AND LEVELS OF RESPONSE. DESPITE THE MANY TECHNICAL PRESENTATIONS OF MERIT, THE CONFERENCE WAS DOMINATED BY THE PREVIOUSLY ANNOUNCED U.S. POLICY CONCERNING THE RECYCLING OF NUCLEAR FUEL AND THE DEVELOPMENT OF THE FAST BREEDER REACTOR. THE GENERAL AGREEMENT WITH REGARD TO THE NEED TO PREVENT THE SPREAD OF NUCLEAR WEAPONS DID NOT ENCOMPASS THE NEW U.S. POSITION.

- 18-6-2-761 AN ASSESSMENT OF HIGH ACCIDENT CONSEQUENCES
BARSELL, A. W. + JOKSIPOVIC, V. + SILADY, F. A.
GENERAL ATOMIC COMPANY, SAN DIEGO, CALIF.
- ASSESSMENTS WERE MADE OF THE CONSEQUENCES OF THE HIGHER RISK ACCIDENT CONDITIONS POSTULATED TO OCCUR IN A REFERENCE 1975 GENERAL ATOMIC 3000-MW(e) HIGH TEMPERATURE GAS COOLED REACTOR. THIS PROBABILISTIC RISK ASSESSMENT STUDY, KNOWN AS ACCIDENT INITIATION AND PROGRESSION ANALYSIS, IS FUNDED BY THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION. THE MOST REPRESENTATIVE ACCIDENT CONDITIONS ARE (1) CORE HEATUP CAUSED BY A LOSS OF OFF-SITE POWER OR BY A LARGE EARTHQUAKE, LEADING TO A LOSS OF FORCED CIRCULATION, (2) REHEATER TUBE FAILURE, (3) DEPRESSURIZATION OF THE PRIMARY COOLANT, AND (4) STEAM GENERATOR MAIN BUNDLE TUBE FAILURE. THE RADIOLOGICAL CONSEQUENCES, WHICH ARE BASED ON REPRESENTATIVE U.S. POPULATION DENSITIES, WERE ASSESSED IN TERMS AS A FUNCTION OF DISTANCE FROM THE PLANT AND MAN-REM EXPOSURES TO THE SURROUNDING ENVIRONMENT. THE RESULTS INDICATE THAT THE HIGH TEMPERATURE GAS COOLED REACTOR HAS EXCELLENT SAFETY CHARACTERISTICS, WHICH ARE INHERENT IN THE CONCEPT AND ARE PRIMARILY ASSOCIATED WITH THE CHOICE OF COOLANT AND CORE DESIGN. OVER A WIDE RANGE OF ACCIDENT FREQUENCIES (FROM ONE ACCIDENT PER REACTOR YEAR TO ONE ACCIDENT IN 10 MILLION REACTOR YEARS), NO ACCIDENTS CONSIDERED IN THE STUDY ARE PREDICTED TO CAUSE EARLY OR DELAYED FATALITIES OR ILLNESSES.

- 18-6-3-774 HUMAN FACTORS IN THE NUCLEAR CONTROL ROOM
SERINARA, J. L. • PARK, A. W. • GONZALEZ, W. R.
PARSONS, S. G.
ELECTRIC POWER RESEARCH INSTITUTE, PALO ALTO, CALIF. / LOCKHEED
MISSILES AND SPACE COMPANY, INC., SUNNYVALE, CALIF.
HUMAN FACTORS ENGINEERING IS AN INTERDISCIPLINARY SPECIALTY
CONCERNED WITH INFLUENCING THE DESIGN OF EQUIPMENT SYSTEMS,
FACILITIES, AND OPERATIONAL ENVIRONMENTS TO PROMOTE SAFE,
EFFICIENT, AND RELIABLE OPERATOR PERFORMANCE. THE HUMAN FACTORS
ASPECTS OF FIVE REPRESENTATIVE NUCLEAR POWER PLANT CONTROL
ROOMS WERE EVALUATED USING SUCH METHODS AS A CHECKLIST GUIDED
OBSERVATION SYSTEM BASED ON MILITARY STANDARDS, STRUCTURED
INTERVIEWS WITH OPERATORS AND TRAINERS, DIRECT OBSERVATIONS OF
OPERATOR BEHAVIOR, TASK ANALYSES, PROCEDURE EVALUATIONS, AND
HISTORICAL ERROR ANALYSES. THE REVIEW HAS SURFACED A WIDE
SPECTRUM OF HUMAN FACTORS PROBLEM AREAS AND NEEDED
IMPROVEMENTS. THE STUDY RECOMMENDS THAT A DETAILED SET OF
APPLICABLE HUMAN FACTORS STANDARDS BE DEVELOPED TO STIMULATE
A UNIFORM AND SYSTEMATIC CONCERN FOR HUMAN FACTORS. IT IS
FURTHER RECOMMENDED THAT DESIGN GUIDES BE DEVELOPED TO
FACILITATE THE IMPLEMENTATION OF SUCH STANDARDS BOTH FOR NEW
DESIGNS AND FOR UPDATING EXISTING CONTROL ROOMS. A NUMBER OF
RESEARCH AREAS ARE DELINEATED IN ORDER TO DEVELOP A MORE
COMPREHENSIVE DATA BASE ON WHICH TO PREDICATE HUMAN FACTORS
STANDARDS.
- 18-6-4-791 FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEELS
JAMES, L. A.
WESTINGHOUSE HANFORD COMPANY, RICHLAND, WASH.
THE RESULTS OF A NUMBER OF EXPERIMENTS DEALING WITH FATIGUE
CRACK PROPAGATION IN IRRADIATED REACTOR PRESSURE VESSEL STEELS
ARE REVIEWED. THE STEELS INCLUDED ASTM ALLOYS A502B, A533B,
A508-2, AND A543, AS WELL AS DEFORMATIONS IN A543 STEEL. FLUENCES
AND IRRADIATION CONDITIONS WERE GENERALLY TYPICAL OF THOSE
EXPERIENCED BY MOST POWER REACTORS. IN GENERAL, THE EFFECT OF
NEUTRON IRRADIATION ON THE FATIGUE CRACK PROPAGATION BEHAVIOR
OF THESE STEELS WAS NEITHER SIGNIFICANTLY BENEFICIAL NOR
SIGNIFICANTLY DETRIMENTAL.
- 18-6-5-802 POWER PLANT DISCHARGES - TOWARD MORE REASONABLE EFFLUENT LIMITS (7). CHLORINE
MATTICE, J. S.
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.
A METHOD IS PRESENTED FOR RESTRICTING CHLORINE IN POWER-PLANT
EFFLUENTS TO ENVIRONMENTALLY SAFE LEVELS. DEVELOPMENT OF THIS
METHOD WAS STIMULATED BY THE CONTROVERSY BETWEEN ELECTRIC
UTILITIES AND REGULATORY AGENCIES OVER THE JUSTIFICATION OF
THE PRESENT UNIVERSALLY APPLIED LIMITS. THE SCIENTIFIC
LITERATURE CONCLUSIVELY DEMONSTRATES THE EFFECTS OF PHYSICAL,
CHEMICAL, AND BIOTIC FACTORS ON CHLORINE TOXICITY. THE METHOD
PROPOSED INCLUDES THESE FACTORS, TO THE EXTENT CURRENTLY
POSSIBLE, TO SET LIMITS BASED ON SITE SPECIFIC AQUATIC
CONDITIONS AND PLANT DESIGN AND OPERATION SPECIFICATIONS. IN
THESE EFFLUENT LIMITS, THE ORGANISMS CONSIDERED ARE THOSE WHICH
ARE ENTRAINED INTO THE PLUME OR WHICH MAINTAIN THEMSELVES
WITHIN THE PLUME DURING CHLORINATION. IN EACH INSTANCE THE
TIME COURSE OF EXPOSURE CONCENTRATION IS DIVIDED INTO SMALL
TIME INTERVALS. WEIGHTED PEAK CONCENTRATIONS FOR SUCCESSIVELY
LARGER TIME INTERVALS FOLLOWING INITIAL EXPOSURE ARE THEN
CALCULATED. EXPOSURES RESULTING FROM RELEASES AT VARIOUS LEVELS
ARE COMPARED EITHER GRAPHICALLY OR MATHEMATICALLY WITH ACUTE
AND CHRONIC MORTALITY THRESHOLDS TO FIND THE HIGHEST DISCHARGE
CONCENTRATION THAT DOES NOT CAUSE MORTALITY. THE THRESHOLDS ARE
DERIVED FROM EXISTING TOXICITY DATA AND ARE DIFFERENT FOR
MARINE AND FRESHWATER ORGANISMS. THIS METHOD IS BASED ON THE
LATEST LITERATURE AVAILABLE AND CAN INCORPORATE FURTHER DATA
CONCERNING CHEMISTRY, TOXICITY, AND BEHAVIOR AS THEY BECOME
AVAILABLE. THE METHOD ALSO IS AMENABLE TO COUPLING WITH MODELS
OF CHEMICAL DISPERSION AND POPULATION DYNAMICS TO PERMIT MORE
COMPLETE ANALYSIS. THIS APPROACH SERVES TO PERMIT USE OF
CHLORINE FOR BIOFOULING CONTROL AT POWER PLANTS, WHILE ENSURING
THAT THIS USE WILL NOT BE INIMICAL TO THE ENVIRONMENT.

Section 2

PERMUTED-TITLE (KWIC) INDEX

A KWIC (KeyWord In Context) index is one in which article titles are permuted around the various significant words contained therein. For example, the title, "Design Basis for Nuclear Power Plant Protection Systems," is indexed under the words Design, Nuclear, Power, Plant, and Protection. The index words are arranged alphabetically in a column in the center of the page, with the titles permuted around them. In some cases, additional significant words in parentheses have been added to the title by the editors to allow more precise indexing. A slash (/) indicates the end of a title. The location of the articles listed in the main index (orange) is indicated by the seven-digit numbers in the column to the right of the page, as described in the Introduction.

PERMUTED TITLE PAGE INDEX

1/	SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER REACTOR FACILITIES	15-2-5-190
URANIUM-235 SOLUTION IN TANKS CONTAINING A FLUX NEUTRON	THE SAFETY AND CONTROL OF	15-2-5-200
BEAR SAFETY CONSIDERATIONS AT THE STAMFORD LINEAR	ACCELERATION CENTER/	11-6-1-400
SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW	ACCEPTANCE CRITERIA FOR EMERGENCY CORE COOLING	15-2-4-170
SIZING OF AIR CLEANING SYSTEMS FOR	ACCESS TO NUCLEAR PLANT SPACES/	15-2-4-600
CRITICAL HEAT FLUX DURING A LOSS OF COOLANT	ACCIDENT/	15-2-2-200
PHENOMENOLOGICAL RESEARCH IN LWRs	ACCIDENT ANALYSIS/	15-2-2-300
STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER	ACCIDENT CONDITIONS/	15-2-2-100
U.S. STUDIES ON LWR FUEL BEHAVIOR UNDER	ACCIDENT CONDITIONS/	15-2-2-400
AN ASSESSMENT OF HIGH	ACCIDENT CONSEQUENCES/	14-2-2-700
ENTRAPPED FOR MONITORING THE HYPOTHETICAL LOSS-OF-COOLANT	ACCIDENT IN LARGE LIGHT WATER POWER REACTORS/ IN	11-2-3-400
PLANTS/	AN ASSESSMENT OF	15-2-1-600
OMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY/	ACCIDENTAL COOLANT-60 EXPOSURE AT THE UNIVERSITY	13-4-4-300
FROM AN LWR/	CONSEQUENCES OF AN	14-4-5-300
IAEA - WMO SYMPOSIUM ON HANDLING OF RADIATION	ACCIDENTS/	12-4-5-200
COMPUTER CODES FOR ANALYZING NUCLEAR	ACCIDENTS/	12-5-3-400
FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR	ACCIDENTS/	15-2-3-400
COMPUTER CODES FOR ANALYZING NUCLEAR	ACCIDENTS/	15-2-3-500
ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF COOLANT	ACCIDENTS/	14-2-2-600
- A COMPARISON OF THE LATENT MORTALITY RISKS FROM REACTOR	ACCIDENTS/	12-2-4-400
PRESSURIZED WATER REACTOR LOSS OF COOLANT	ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE/	14-2-2-200
THE ROLE OF CORE DISRUPTIVE	ACCIDENTS IN DESIGN AND LICENSING OF LWRs/	17-2-2-300
POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRON	ACCIDENTS IN HTGRs/	15-2-2-300
PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN	ACCIDENTS IN LIGHT WATER REACTORS/	14-1-4-400
ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL	ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AEC STUDY	15-4-1-100
RADIOLOGIC HYDROGEN GENERATION AFTER LOSS OF COOLANT	ACCIDENTS IN WATER COOLED POWER REACTORS/	15-2-2-400
EL CYCLE/ PROBABILITY AND CONSEQUENCES OF TRANSPORTATION	ACCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMENT	14-2-2-300
COOLING/	COMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE	15-2-2-300
ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT	ACOUSTIC EMISSION - A CRITICAL ASSESSMENT/	17-1-3-300
NUCLEAR PRESSURE VESSELS/ A PROGRESS REPORT ON THE USE OF	ACOUSTIC EMISSION TO DETECT INCIPENT FAILURE IN	15-2-3-300
PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION CONTROL	ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS 1. A	15-2-1-200
AND PROCEDURES/ THE NEW FEDERAL WATER POLLUTION CONTROL	ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS PART	15-4-1-200
ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON	ACTIVATED CHARCOAL AT LOW CONCENTRATIONS/	15-2-4-711
RADIATION PROTECTION	ACTIVITIES OF THE BUREAU OF RADIOLOGICAL HEALTH/	15-2-5-100
NUCLEAR TECHNOLOGY/	ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR	14-4-6-200
ATTITUDE OF AN ANTIMONY - BERYLLIUM SOURCE ROD/	ACTIVITY CONFINEMENT AND DECONTAMINATION AFTER F	17-2-1-400
ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST	ACTS AGAINST NUCLEAR FACILITIES/	17-2-1-400
SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO	ACTS OF SABOTAGE/	22-3-3-300
SAFE DESIGN/	ACTUATORS - LOGIC ELEMENTS IN RELATION TO FAIL	15-2-3-300
FOR MANAGEMENT 1/ U.S.A. STANDARD N13.2-1969 - GUIDE FOR	ADMINISTRATIVE PRACTICES IN RADIATION MONITORING	13-4-6-400
EFFECT OF ALPITUDE IN A PRESSURIZED NUCLEAR GAS	ADSORPTION BED/	15-2-4-711
ELEMENTAL IODINE AND METHYL IODIDE	ADSORPTION ON ACTIVATED CHARCOAL AT LOW CONCENTR	15-2-4-711
ATMOSPHERIC RELEASE	ADVISORY CAPABILITY/	17-3-1-200
REACTOR LICENSING PROCESS/	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE	11-1-1-100
THE ROLE OF THE	AEC AIR CLEANING CONFERENCE/	11-2-4-100
THE ELEVENTH	AEC AIR CLEANING CONFERENCE/	16-2-4-100
THE THIRTEENTH	AEC AIR-CLEANING CONFERENCE/	14-2-4-100
THE TWELFTH	AEC FUEL REPROCESSING OPERATIONS/	14-2-5-400
MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM	AEC GOES PUBLIC - A CASE HISTORY/	11-2-1-200
STORAGE, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS 11.	AEC LICENSED FACILITIES/	15-1-5-71
MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS 11.	AEC OWNED FACILITIES/	15-1-5-71
12. HEARING/	AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICAB	15-4-1-100
13. CONCLUDING STATEMENT OF THE	AEC STUDY ON THE ESTIMATION OF RISKS TO THE PUBL	15-4-1-100
14. FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE	AEC TESTIMONY AT THE 1973 JOCE HEARINGS ON REACT	15-2-2-100
OR SAFETY/	AEC WORKING PAPER ON POPULATION DENSITY AROUND N	15-1-2-3
NUCLEAR POWER PLANT SITES/	AEC'S NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS,	15-2-1-100
AND SCHEDULES/	AGREEMENTS ON REACTOR SAFETY RESEARCH/	14-2-1-100
NRC INTERNATIONAL	AGRICULTURAL RESEARCH LABORATORY/ ACCIDENTAL COB	13-4-4-300
THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSION	AIDS TO SMOOTH OPERATION/	14-2-4-100
HUMAN ENGINEERING -	AIR CLEANING AT NUCLEAR FACILITIES/	15-2-4-100
CURRENT CHALLENGES IN	AIR CLEANING CONFERENCE/	12-2-4-100
THE ELEVENTH AEC	AIR CLEANING CONFERENCE/	16-2-4-100
THE THIRTEENTH AEC	AIR CLEANING CONFERENCE/	19-2-4-100
THE FOURTEENTH ERDA	AIR CLEANING SYSTEMS/	14-2-4-100
PROBLEMS IN NUCLEAR	AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT	14-2-4-100
SPACES/	SEIZING OF	14-2-4-100
THE TWELFTH AEC	AIR-CLEANING CONFERENCE/	17-2-4-100
PROBABILISTIC ASSESSMENT OF	AIRCRAFT CRASH PROBABILITIES/	15-2-4-100
RISK MINIMIZATION BY OPTIMUM	AIRCRAFT RISK FOR NUCLEAR POWER PLANTS/	12-2-4-100
COMPARATIVE RISK - COST - BENEFIT STUDY OF	ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUC	17-2-4-100
UNEXPECTED MELTDOWN OF SCRAP URANIUM -	ALTERNATIVE SOURCES OF ELECTRICAL ENERGY/	15-2-4-100
A INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCIETY OF	ALUMINUM CEMENT CORES DURING HTGRs/	13-2-4-100
AM SAFETY 1975/	AMERICA/	17-2-4-100
REACTOR SAFETY/	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLE	14-2-4-100
NUCLEAR SAFETY IN	AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER	12-2-4-100
BENEFIT COST	AMERICAN RADIOCHEMICAL PROCESSING PLANTS/	15-2-4-100
COMPARATIVE RELIABILITY	ANALYSES IN LICENSING OF NUCLEAR POWER REACTORS/	14-2-4-100
LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS	ANALYSES OF REACTOR SAFETY SYSTEMS/	14-2-4-100
PHENOMENOLOGICAL RESEARCH IN LWRs/ ACCIDENT	ANALYSIS/	14-2-4-100
SMOKE-CIRCUIT	ANALYSIS/	14-2-4-100
HUMAN RELIABILITY	ANALYSIS/	14-2-4-100
NUCLEAR POWER PLANT PERFORMANCE	ANALYSIS/	14-2-4-100
AP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT	ANALYSIS/	14-2-4-100
OF COOLANT ACCIDENTS/	PROBABILITY	14-2-4-100
INITIATED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING/	ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS	14-2-4-100
NUCLEAR POWER REACTORS/	ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCO	14-2-4-100
CHANNEL BY RAPID HEATING/	AN ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN	14-2-4-100
VERITY RESEARCH REACTOR/	RELIABILITY	14-2-4-100
THE RELAP4 COMPUTER CODE 111. LOCA	ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNI	14-2-4-100
	ANALYSIS RESULTS OF A TYPICAL PWR PLANT/	14-2-4-100

BLANK PAGE

DES FOR POWER INSTRUMENTATION/	COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	12-5-3-461
CE JACOBS - 1970/	COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	15-5-2-535
APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE	THE 15TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES	15-6-3-417
INSTRUMENTS/	JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR SCIENCES	12-6-3-310
FFTY/	ANOMALIES/	11-6-6-162
E SYSTEMS/	SAN JUAN EXPERIENCE WITH	12-2-4-134
	ANS CONFERENCE ON POWER REACTOR SYSTEMS AND COMP	16-5-1-439
	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SA	15-3-3-292
	ANS STANDARDS MEETING ON DESIGN BASES FOR PROTECTIV	15-6-1-141
	1976 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	15-3-1-273
	REVIEW OF THE ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING	15-6-1-615
	THE ANS-NSMB NUCLEAR STANDARDS PROGRAM/	17-1-3-43
DEATED POWER FACTORS/	ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QU	15-2-3-151
VITY CONFINEMENT AND DECONTAMINATION AFTER FAILURE OF AN	ANTICIPAY - BERYLLIUM SOURCE ROD/	14-6-6-362
ERATURE ANOMALIES/	AN APPARENT POWER MISMATCH AND REACTOR COOLANT TEMP	11-2-6-142
	AN APPRECIATION OF FAST REACTOR SAFETY-1970/	12-2-1-83
LE FACILITIES' RADIATION DOSES AND EFFECTS ESTIMATED FOR	AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FR	17-3-5-351
ING DESIGN AND OPERATION/	COLE SMOOK TO AQUATIC ORGANISMS - GUIDANCE FOR POWER PLANT SIT	19-3-5-329
TIONS/	MANAGEMENT OF RADIOACTIVE	14-5-5-402
	REFLECTIONS ON THE RECRITICALITY CONFERENCE AT	19-1-2-45
	SYMPOSIUM ON HEALTH PHYSICS IN THE HEALING	14-6-5-340
REACTORS/	THE ASSURE CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR	13-2-1-099
	CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL/	11-2-6-119
	PARTIAL BLOCKAGES IN LMFBR FUEL ASSEMBLIES/	17-1-2-19
	ACCUSTIC EMISSION - A CRITICAL ASSESSMENT/	17-1-3-33
MOGRADING NUCLEAR PLANT SITING - A TECHNICAL AND SAFETY	ASSESSMENT/	15-5-1-519
IN THE POPULATION NEAR NUCLEAR FACILITIES - A CRITICAL	ASSESSMENT/	10-5-5-647
COST - BENEFIT AND RISK - BENEFIT	ASSESSMENT FOR NUCLEAR POWER PLANTS/	17-3-1-525
FOR LOSS OF ELECTRIC POWER/	ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM	10-2-3-148
NUCLEAR POWER PLANTS/	AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL	15-6-1-673
INTS/	PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PL	15-3-2-276
UNITED KINGDOM/	SAFETY ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE	11-6-1-203
PLANTS/	PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER	15-6-2-399
	AN ASSESSMENT OF HTGR ACCIDENT CONSEQUENCES/	10-6-2-761
UMENT/	COMPUTER CODES FOR THE ASSESSMENT OF RADIONUCLIDES RELEASED TO THE ENVI	10-3-5-343
LITY/	SAFETY ASSESSMENT OF REACTOR SYSTEMS/	15-2-3-154
	SAFETY ASSESSMENT PHILOSOPHY OF THE FAST FLUX TEST FACI	14-2-1-079
LANES/	EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM/	10-6-1-667
T/	QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER P	16-2-1-127
	QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLAN	17-1-6-07
	QUALITY ASSURANCE STANDARDS AND PRACTICES/	12-6-1-549
THE PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN THE	ATMOSPHERE/	15-3-5-306
R REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM PINE	ATMOSPHERES/	14-6-5-643
SLING CONDITIONS/	A SURVEY OF FIELD MEASUREMENTS OF	17-2-5-223
/	ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED INVER	17-3-1-201
	ATMOSPHERIC RELEASE ADVISORY CAPABILITY/	13-3-5-391
	ATMOSPHERIC TRANSPORT AND DISPERSION OVER CITIES	14-6-5-651
NTAL COAL-TO-PO EXPOSURE AT THE UNIVERSITY OF TENNESSEE -	ATOMIC BOMB CASUALTY COMMISSION/	13-6-6-304
	ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH L	15-6-1-383
NCE AND EXHIBIT/	THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL/	13-5-3-366
	INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA CONFERE	14-2-3-095
AT JRM/	OBSTACLES TO COMPLETE AUTOMATION OF REACTOR CONTROL/	12-2-3-115
	EVALUATION OF NUCLEAR POWER PLANT AVAILABILITY/	15-5-6-599
ITY OF SERVICE/	U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973/	15-6-6-730
	REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINU	12-5-6-499
	IMPROVING REACTOR PRESSURE VESSEL AVAILABILITY BY DESIGN/	17-1-6-82
RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES	NATURAL BACKGROUND RADIATION IN THE UNITED STATES/	17-4-2-365
RESS - THE IMPACT OF THE COURTS/	BALANCING ENVIRONMENTAL IMPACT AND ECONOMIC PROG	17-6-5-471
	ANS STANDARD NINE ON DESIGN BASES FOR PROTECTIVE SYSTEMS/	13-3-1-209
	SAFETY DESIGN BASES OF THE HTGR/	15-3-3-292
	FISSION GAS EFFECTS IN REACTOR FUELS I.	14-6-6-618
R ACCELERATOR CENTER/	NASTIC STUDIES/	12-6-2-297
EFFECT OF RUPTURE IN A PRESSURIZED MOBILE GAS ADSORPTION	BEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEA	11-6-1-435
LED FAST BREEDER REACTORS I. PRODUCTION/ RADIONUCLIDE	BEH/	13-6-6-478
COOLED FAST BREEDER REACTORS II. TRANSPORT/ RADIONUCLIDE	BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL	16-1-6-43
LMFBR SAFETY I. FISSION PRODUCT BEHAVIOR IN SODIUM/	BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL	15-3-6-318
ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE ENVIRONMENT/		11-5-3-379
SPHERE/	IAEA-WMO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN THE ATMO	12-6-6-326
	STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS/	15-3-5-306
	U.S. STUDIES ON LMFBR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS/	11-3-2-195
R POWER PLANTS/	COST - BENEFIT AND RISK - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEA	14-5-2-452
	COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS/	17-5-1-525
REA REACTORS/	BENEFIT ANALYSES IN LICENSING OF NUCLEAR PO	15-6-1-665
AL ENERGY/	COMPARATIVE RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF ELECTRIC	17-2-1-171
	NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE	12-6-1-283
ENENT AND DECONTAMINATION AFTER FAILURE OF AN ANTIMONY	BENTON GIANT/	14-6-6-362
	SENSITIVITY OF VESSEL TO BERYLLIUM SOURCE ROD/	16-6-3-452
ENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I.	BIOTICAL EFFECTS OF NOBLE GASES (A REVIEW OF	15-6-5-732
ITIFS/ RADIATION DOSES AND EFFECTS ESTIMATED FOR AQUATIC	BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LMF F	17-3-5-351
ERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM	BIOTIC EFFECTS PROBLEM/	12-1-3-025
	PARTIAL BLOCKAGES IN LMFBR FUEL ASSEMBLIES/	17-1-2-19
	HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS/	14-1-3-021
THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL/		15-6-1-383
LITY FORCED CONVECTION SYSTEMS/	BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILING SYSTEMS/	16-1-2-29
	BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW QUA	10-2-2-134
	PIPE CRACKING IN BOILING SYSTEMS/	16-1-2-29
N OF INCIDENTS OF PRIMARY COOLANT RELEASE FROM OPERATING	BOILING WATER REACTORS/	17-6-6-475
THE ORIGIN AND FINDINGS OF THE ATOMIC	BOILING WATER REACTORS/	15-1-6-076
THE HOMEMADE NUCLEAR	BOMB CASUALTY COMMISSION/	14-6-5-651
FRAGMENTATION MODELING RELATIVE TO THE	BOMB SYNDROME/	18-6-1-427
	BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM/	16-6-1-683

SSIGN/	THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM/	11-3-4-215
	THE ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE SUPPLE	17-6-4-710
	A SURVEY OF HEAT CONDUCTION COMPUTER PROGRAMS/	12-6-2-569
	THE ELEVENTH AEC AIR CLEANING CONFERENCE/	12-2-4-100
	THE TWELFTH AEC AIR-CLEANING CONFERENCE/	16-2-4-111
	THE THIRTEENTH AEC AIR CLEANING CONFERENCE/	16-2-4-190
	THE FOURTEENTH AEC AIR CLEANING CONFERENCE/	16-2-4-174
EVEN OF THE NUCLEAR SAFETY ASPECTS OF THE FOURTH GENEVA	CONFERENCE/ NUCLEAR SAFETY AT GENEVA - A R	13-3-0-101
NUTRITION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA	CONFERENCE AND EXHIBIT/ INST	13-5-3-366
REFLECTIONS ON THE REACTIVITY	CONFERENCE AT ARGONNE NATIONAL LABORATORY/	10-1-2-45
REPORT ON THE 1970 AHS	CONFERENCE ON POWER REACTOR SYSTEMS AND COMPON	12-2-6-134
ACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST	CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER	13-4-2-287
	CONFERENCE ON WASTE HEAT UTILIZATION/	13-3-1-216
	STRUCTURAL EFFECTS OF	13-2-2-107
AN ANTINEUTRON - BERYLLIUM SOURCE ROD/	CONFINEMENT AND DECONTAMINATION AFTER FAILURE OF	16-4-3-362
	INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS/	11-4-4-315
PRESSURE VESSEL/	CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR	11-2-4-119
	CONSTRUCTION OF NUCLEAR POWER PLANTS/	16-2-1-127
	QUALITY ASSURANCE IN THE	14-5-4-670
	DESIGN AND EVALUATION OF FFTF	12-5-5-516
AGGREGATE REMOVAL/	REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR FISSION P	11-3-4-223
WATER REACTORS/	RESEARCH ON THE USE OF	11-3-4-223
RELEASE/	RACON CONCENTRATION IN REACTOR	11-3-4-235
	GENERAL STRUCTURAL DESIGN CRITERIA FOR PUR	13-5-4-373
973 NUCLE GASES SYMPOSIUM AT LAS VEGAS 17 SEPARATION AND	CONTAINMENT OF MOLE GASES I A REVIEW OF NINE PA	15-3-4-302
	THE ICE CONDENSER SYSTEM FOR	17-6-4-710
TRENDS IN THE DESIGN OF PRESSURIZED WATER REACTOR	CONTAINMENT PRESSURE SUPPRESSION/	10-2-4-109
	CONTAINMENT STRUCTURES AND SYSTEMS/	11-3-4-215
	THE ICE CONDENSER REACTOR	15-2-4-163
EVOLUTION AND CURRENT STATUS OF THE BUR	CONTAINMENT SYSTEM/	15-6-3-702
LIED INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER REACTOR	CONTAINMENTS/	15-3-5-306
EA-ING SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF RADIOACTIVE	CONTAMINANTS IN THE ATMOSPHERE/	13-1-4-037
LIQUID METAL COOLED FAST BREEDER REACTORS/	CONTAMINATION CONTROL OF SODIUM RELEASES FROM LI	12-5-4-499
	REACTOR AVAILABILITY AND STATION RELIABILITY FOR	16-2-3-095
	GOALS TO COMPLETE AUTOMATION OF REACTOR	16-3-3-316
IFICATION OF MAN - MACHINE SYSTEM RELIABILITY IN PROCESS	CONTROL/	15-3-1-262
THROUGH PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION	CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLAN	16-1-4-421
SUCTION AND PROCEDURES/ THE NEW FEDERAL WATER POLLUTION	CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLAN	15-1-3-015
IAEA INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT	CONTROL AND INSTRUMENTATION/	11-2-3-115
	AUTOMATION OF REACTOR	15-6-3-691
	COMPUTER CONTROL AT BUKLE NUCLEAR GENERATING STATION/	14-1-3-021
LFD FAST BREEDER REACTORS/	HUMAN ENGINEERING FACTORS IN	13-1-4-037
ING A FIXED NEUTRON ABSORBER/	CONTAMINATION	15-3-4-295
REACTORS/	THE SAFETY AND	16-4-3-315
	AN ANALYSIS OF	10-6-3-774
	HUMAN FACTORS IN THE NUCLEAR	13-5-3-366
MINITY/	INSTRUMENTATION AND AUTOMATIC	16-1-5-60
ITY IN EFFLUENTS I. AEC WNEED FACILITIES/	THE	16-1-5-71
ITY IN EFFLUENTS II. AT LICENSED FACILITIES/	THE	16-4-5-492
PERATING NUCLEAR POWER STATIONS/	CONTROLLING OCCUPATIONAL RADIATION EXPOSURE AT O	10-2-2-154
LING HEAT TRANSFER II. SUCCEEDED AND LOW QUALITY FORCED	CONVECTION SYSTEMS/	10-3-2-298
	CRITICAL HEAT FLUX DURING A LOSS OF	16-1-2-014
ILITY ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF	COOLANT ACCIDENTS/	16-4-2-271
/	PRESSURIZED WATER REACTOR LOSS OF	13-6-2-459
/	RADIOLYTIC HYDROGEN GENERATION AFTER LOSS OF	15-3-2-285
NEY CORE COOLING/	ANALYSIS OF A SUDDEN MAJOR LOSS OF	16-4-2-436
	CSNI MEETING ON FUEL -	15-1-6-076
CTORS/	EVALUATION OF INCIDENTS OF PRIMARY	11-2-6-142
DEAL EXPERIENCE WITH APPARENT POWER MISMATCH AND REACTOR	COOLANT TEMPERATURE ANOMALIES/	16-1-4-43
NUCLEIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL	COOLED FAST BREEDER REACTORS I. PRODUCTION/ RA	16-3-2-291
PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL	COOLED FAST BREEDER REACTOR FUEL SUBASSEMBLIES/	17-2-4-200
EQUIPMENT CELL LINERS FOR LIQUID METAL	COOLED FAST BREEDER REACTORS/	10-4-3-449
IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID METAL	COOLED FAST BREEDER REACTORS/	13-1-4-037
NTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL	COOLED FAST BREEDER REACTORS/	16-3-4-318
CHITIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL	COOLED -AST BREEDER REACTORS II. TRANSPORT/ QAO	16-6-3-701
	SAFETY INSTRUMENTATION FOR THE SODIUM	15-2-4-173
ITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER	COOLED NUCLEAR POWER REACTORS/ NEW ACCEPTANCE CR	16-3-6-354
TEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER	COOLED NUCLEAR POWER REACTORS DURING 1972/	16-5-6-603
TEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER	COOLED NUCLEAR POWER REACTORS IN 1973/	17-2-6-231
TEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER	COOLED NUCLEAR POWER REACTORS IN 1974/	16-3-6-355
	COOLED NUCLEAR REACTORS IN 1974/	15-2-3-151
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER	COOLED POWER REACTORS/	13-6-2-159
HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER	COOLED POWER REACTORS/	16-3-6-165
OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER	COOLED POWER REACTORS, 1969-1975/	15-3-2-285
COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE	COOLING/ ANALYSIS OF A SUDDEN MAJOR LOSS OF	11-4-4-323
	THE ORR EMERGENCY	17-2-7-185
STEAM - WATER MIXING STUDIES RELATED TO EMERGENCY CORE	COOLING SYSTEM PERFORMANCE/	15-2-4-173
WER REACTORS/ NEW ACCEPTANCE CRITERIA FOR EMERGENCY CORE	COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR PO	15-1-5-150
FOR AND DRIFT DEPOSITION FROM EVAPORATIVE	COOLING TOWERS/	17-6-4-701
OF OPTIMUM TOWER DESIGN/	EMERGENCY SHUTDOWN	12-6-5-600
	EFFECTS ON ORGANISMS OF ENTRAINMENT IN	15-5-5-592
	SYMPOSIUM ON	11-3-2-195
STUDIES OF FAST REACTOR	COOLING WATER - STEPS TOWARD PREDICTABILITY/	15-3-2-285
S OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY	COOLING TOWER ENVIRONMENT - 1974/	17-2-2-185
TEAM - WATER MIXING STUDIES RELATED TO EMERGENCY	COOLING TOWERS UNDER ACCIDENT CONDITIONS/	15-2-4-173
AN POWER REACTORS/ NEW ACCEPTANCE CRITERIA FOR EMERGENCY	CORE COOLING/ ANALYSIS OF A SUDDEN MAJOR LOS	17-5-2-550
G OF LNBRS/	CORE COOLING SYSTEM PERFORMANCE/	16-3-2-201
NG PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST REACTOR	CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLE	15-4-6-455
UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM CERMET	CORE DISRUPTIVE ACCIDENTS IN DESIGN AND LICENSIN	17-5-1-525
NUCLEAR POWER PLANTS/	CORES/ FACTORS LIMIT	17-2-1-171
LECTRICAL ENERGY/	CORES DURING OUTGASSING/	15-6-1-665
TORS/	COST - BENEFIT AND RISK - BENEF. ASSESSMENT FOR	16-2-2-091
	COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF E	
	COST ANALYSES IN LICENSING OF NUCLEAR POWER REAC	
	COUPLED NEUTRONICS HYDRODYNAMICS METHODS/	

ENVIRONMENTAL IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE PRESSURE VESSEL STEELS/	COMETS/	BALANCING ENVIRONMENTAL PROGRESS IN NEUTRON IRRADIATED MATERIALS/	14-3-1-209
	FAILURE OF PIPE	CRACK PROPAGATION IN BOILING WATER REACTORS/	14-3-1-791
	AIRCRAFT	CRASH PROBABILITIES/	17-4-4-475
AS/ SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970	CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE REACTORS/	CREST SUMMARY - WATER-COOLED REACTOR SAFETY/	17-3-2-312
ON SYSTEMS/	CRITERIA AND REQUIREMENTS FOR RGT PLANT PROTECTION/	CRITERIA BASED UPON RISK PROBABILITY/	13-4-2-287
IGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW ACCEPTANCE	CRITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF L	CRITERIA FOR PWR CONTAINMENT INTERIOR STRUCTURES	12-3-1-194
/	ACOUSTIC EMISSION - A	CRITICAL ASSESSMENT/	11-5-2-375
LIC HEALTH IN THE POPULATION NEAR NUCLEAR FACILITIES - A	CRITICAL ASSESSMENT/	TRENDS IN PWR	13-1-2-022
DENT/	CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PU	CRITICAL REVIEW/	15-2-4-173
BLIC INTEREST/	PLUME PISE - A RECENT	CRITICAL MEETING ON FUEL - COOLANT INTERACTIONS/	13-5-4-373
	EVOLUTION AND	CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FA	17-1-3-33
CILITIES/	OLEN/	A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND	14-5-5-647
	URE/	PROBLEMS AND TECHNIQUES FOR REMOVAL OF RADON AND RADON	14-3-2-250
	ERYLLIUM SOURCE ROD/	A REVIEW OF SHORT TERM FISSION PRODUCT	12-1-3-015
		ACTIVITY CONFINEMENT AND	16-4-2-436
		AEC WORKING PAPER ON POPULATION	14-3-4-033
		IMPROVING REACTOR PRESSURE VESSEL AVAILABILITY BY	15-2-4-163
		OF ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL SAFE	17-4-5-444
		OWERS - CONSIDERATIONS IN THE EVOLUTION OF OPTIMUM TOWER	14-3-2-187
		THE ROLE OF CORE DISRUPTIVE ACCIDENTS IN	14-5-5-643
		AND STANDARD NUCLEAR ON	14-5-2-596
		SYSTEMS/	14-4-4-362
		LECTURES/	14-4-4-354
		STRUCTURES AND SYSTEMS/	14-1-1-1
			15-2-5-190
			17-1-4-62
			12-3-3-226
			17-4-4-701
			14-5-4-470
			17-5-2-550
			15-3-3-292
			14-4-4-819
			11-1-3-020
			13-5-4-373
			14-1-3-071
			14-1-1-001
			15-4-4-432
			14-2-4-189
			14-5-4-564
			17-3-2-299
			14-5-3-329
			12-4-1-553
			13-3-3-220
			12-2-3-90
			11-3-4-237
			14-2-5-224
			11-4-4-315
			17-1-5-48
			17-2-5-723
			17-4-3-493
			14-4-2-082
			11-4-2-074
			15-3-1-262
			14-4-5-802
			13-5-5-391
			11-5-4-191
			11-2-5-130
			17-5-2-550
			15-5-1-513
			11-4-4-475
			13-2-5-130
			17-3-5-351
			15-1-5-056
			15-4-4-723
			15-5-4-572
			12-5-7-538
			15-2-5-190
			14-2-4-223
			13-2-2-107
			13-4-2-287
			14-3-3-206
			13-2-2-114
			14-1-1-001
			14-4-2-586
			15-1-4-030
			12-4-4-326
			12-1-3-025
			13-3-1-209
			14-5-5-802
			14-1-5-60
			13-1-5-71
			15-3-6-311
			14-6-1-734
			14-3-4-370
			14-4-5-720
			14-2-3-180
			14-1-3-53
			17-2-1-171
			14-5-1-409

ACTIVATED CHARCOAL AT LOW CONCENTRATIONS/	ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON	15-6-4-711
THE	THE ELEVENTH AEC AIR CLEANING CONFERENCE/	12-2-4-100
NEUTRON IRRADIATION	EMBRIITLEMENT OF REACTOR PRESSURE VESSEL STEELS/	17-3-4-327
PLANNING FOR NUCLEAR	EMERGENCIES/	17-1-1-1
THE ORR	EMERGENCY COOLING FAILURE/	17-4-6-323
MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF	EMERGENCY CORE COOLING/ ANALYSIS OF A SUDDEN	15-3-2-285
STEAM - WATER MIXING STUDIES RELATED TO	EMERGENCY CORE COOLING SYSTEM PERFORMANCE/	17-2-2-185
OLD NUCLEAR POWER REACTORS/ NEW ACCEPTANCE CRITERIA FOR	EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER CO	15-2-4-173
NUCLEAR	EMERGENCY PLANNING IN THE STATE OF NEW JERSEY/	14-6-1-563
STANDBY	EMERGENCY POWER SYSTEMS. I. THE EARLY PLANTS/	14-3-2-266
STANDBY	EMERGENCY POWER SYSTEMS. II. THE LATER PLANTS/	16-2-3-162
LEAR FACILITIES/ STATE AND LOCAL GOVERNMENT RADIOLOGICAL	EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUC	17-1-1-15
NS IN THE EVOLUTION OF OPTIMUM TOWER DESIGN/	EMERGENCY SHUTDOWN COOLING TOWERS - CONSIDERATIO	17-6-4-701
ICER/	THE EMERGING ROLE OF THE CAMPUS RADIATION SAFETY OFF	13-6-5-482
ACQUSTIC	EMISSION - A CRITICAL ASSESSMENT/	17-1-3-33
ESSURE VESSELS/ A PROGRESS REPORT ON THE USE OF ACOUSTIC	EMISSION TO DETECT INCIPENT FAILURE IN NUCLEAR	15-5-3-554
TC NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPTON-85	EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PL	13-2-5-130
OST - HERE IT STUDY OF ALTERNATIVE SOURCES OF ELECTRICAL	ENERGY/ COMPARATIVE RISK - C	18-3-3-522
NG/	ENERGY CENTER SITE SURVEY - 1975/	17-2-1-171
BALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC	ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITI	17-4-1-411
OFFSHORE SITING OF NUCLEAR	ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATO	16-3-1-282
FISSION GAS EFFECTS IN REACTOR FUELS 11.	ENERGY STATIONS/	13-4-6-304
THE RELAP4 COMPUTER CODE 2.	ENGINEERING - AIDS TO SMOOTH OPERATION/	12-1-2-009
NUCLEAR POWER PLANTS/	ENGINEERING APPLICATIONS/	10-2-6-273
NER SYSTEMS/	ENGINEERING DESIGN OF THE INPUT MODEL/	12-6-2-562
RELIABILITY	ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR	17-3-2-299
REVIEW OF	ENGINEERING METHODS IN REACTOR SAFETY TECHNOLOGY	14-1-3-021
EARTHQUAKE RESISTANT DESIGN OF	ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR PO	12-5-1-496
EFFECTS ON ORGANISMS OF	ENGINEERING STRUCTURES/	12-3-3-217
ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE	ENTRAINMENT IN COOLING WATER - STEPS TOWARD PRED	14-1-1-001
NATURAL RADIATION IN THE URBAN	ENVIRONMENT/	12-6-5-600
RADIOLOGICAL QUALITY OF THE	ENVIRONMENT/	12-4-4-326
DOES FOR THE ASSESSMENT OF RADIONUCLIDES RELEASED TO THE	ENVIRONMENT/	13-4-1-275
ON RADIOECOLOGY APPLIED TO THE PROTECTION OF MAN AND HIS	ENVIRONMENT/	18-2-5-215
SYMPOSIUM OF COOLING-TOWER	ENVIRONMENT - 1974/	18-3-5-343
CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE	ENVIRONMENT FROM AN LMFBR/	13-5-5-380
RADIOLOGICAL AND	ENVIRONMENTAL ASPECTS OF FUSION POWER/	15-5-5-592
THE IAEA-AEC SYMPOSIUM ON	ENVIRONMENTAL ASPECTS OF NUCLEAR POWER/	14-5-5-325
THE REGULATION OF THE	ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS/	18-2-5-203
THE REGULATION OF THE	ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS/	12-2-1-75
BALANCING	ENVIRONMENTAL IMPACT AND ECONOMIC PROGRESS - THE	14-1-1-006
THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NU	ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A	14-3-1-165
THE ENVIRONMENTAL	ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A	13-3-1-209
LOW LEVEL	ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSIS	16-5-5-593
EPA'S	ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM/	17-5-5-580
ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACIL	ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACIL	14-2-3-105
ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUEL	ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUEL	16-6-1-667
ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW A	ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW A	16-2-5-204
ENVIRONMENTAL SURVEILLANCE TECHNIQUES/	ENVIRONMENTAL SURVEILLANCE TECHNIQUES/	12-3-1-185
ENVIRONMENTAL TRITIUM/	ENVIRONMENTAL TRITIUM/	15-4-5-440
EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM	EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM	17-3-5-344
EPAI WATER REACTOR SAFETY PROGRAM/	EPAI WATER REACTOR SAFETY PROGRAM/	17-2-5-216
EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMEN	EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMEN	16-6-1-667
EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIE	EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIE	16-6-1-659
EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL/	EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL/	16-3-5-337
EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FA	EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FA	11-6-2-450
ERDA AIR CLEANING CONFERENCE/	ERDA AIR CLEANING CONFERENCE/	13-6-2-467
THE ERDA RADIOLOGICAL ASSISTANCE PROGRAM/	THE ERDA RADIOLOGICAL ASSISTANCE PROGRAM/	17-2-4-208
ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTI	ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTI	18-2-4-174
ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULAT	ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULAT	16-3-5-345
ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIS	ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIS	17-3-5-351
ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL	ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL	13-2-5-130
ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL	ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL	17-6-1-659
EUROPE/	EUROPE/	13-1-5-054
EUROPE, 1970-1974/	EUROPE, 1970-1974/	15-4-1-375
EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE N	EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE N	18-5-6-666
EVAPORATIVE COOLING TOWERS/	EVAPORATIVE COOLING TOWERS/	18-3-6-370
EVOLUTION AND CURRENT STATUS OF THE BWR CONTAINM	EVOLUTION AND CURRENT STATUS OF THE BWR CONTAINM	16-4-4-458
EVOLUTION OF OPTIMUM TOWER DESIGN/	EVOLUTION OF OPTIMUM TOWER DESIGN/	15-2-5-190
EXCURSIONS IN IRRADIATED FAST REACTOR CORES/	EXCURSIONS IN IRRADIATED FAST REACTOR CORES/	15-2-4-163
EXHIBIT/	EXHIBIT/	17-6-4-701
EXPERIENCE AT NUCLEAR POWER PLANTS/	EXPERIENCE AT NUCLEAR POWER PLANTS/	14-3-2-201
EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR	EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR	13-5-3-366
EXPERIENCE GAINED FROM RAPSOOLIE OPERATION/	EXPERIENCE GAINED FROM RAPSOOLIE OPERATION/	16-2-6-224
EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	16-1-6-79
EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	14-1-6-027
EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	16-3-6-354
EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR	16-5-6-603
EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1	EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1	17-2-6-231
EXPERIENCE WITH APPARENT POWER MISMATCH AND REAC	EXPERIENCE WITH APPARENT POWER MISMATCH AND REAC	18-3-6-354
EXPERIENCE WITH DIGITAL COMPUTER SOFTWARE/	EXPERIENCE WITH DIGITAL COMPUTER SOFTWARE/	11-2-6-142
EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE	EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE	17-6-3-693
EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CY	EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CY	18-5-6-666
EXPOSURE AT NUCLEAR POWER PLANTS/	EXPOSURE AT NUCLEAR POWER PLANTS/	17-3-5-351
EXPOSURE AT OPERATING NUCLEAR POWER STATIONS/	EXPOSURE AT OPERATING NUCLEAR POWER STATIONS/	16-5-6-614
EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC	EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC	16-4-5-492
EXPOSURE BE RECORDED FOR RADIATION WORKERS/	EXPOSURE BE RECORDED FOR RADIATION WORKERS/	13-4-6-304
EXPOSURE GUIDELINES/	EXPOSURE GUIDELINES/	14-3-5-220
EXPOSURE TO X-RAYS - U.S. 1970/	EXPOSURE TO X-RAYS - U.S. 1970/	12-5-2-454
EXPOSURE - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM	EXPOSURE - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM	15-4-5-453
EXPOSURES AT LICENSED FACILITIES, 1974/	EXPOSURES AT LICENSED FACILITIES, 1974/	16-6-5-720
		17-6-6-743

1969-1975/	OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES, 1975/	18-4-6-523
	OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS,	18-4-6-365
	OCCUPATIONAL RADIATION EXPOSURES AT LWRs, 1969-1974/	17-5-6-622
IAEA-IMFR MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHMENT/		15-2-2-100
THE USE OF ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL SAFE DESIGN/		17-3-3-221
	DETECTION OF FAILED FUEL ELEMENTS/	13-3-3-221
	THE ORR EMERGENCY COOLING FAILURE/	11-4-5-313
PROBABILITY OF DAMAGE TO NUCLEAR COMPONENTS DUE TO TURBINE FAILURE/		14-3-2-187
ACCIDENTS/	FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR A	12-5-3-487
PORT ON THE USE OF ACOUSTIC EMISSION TO DETECT INCIPIENT FAILURE IN NUCLEAR PRESSURE VESSELS/ A PROGRESS		15-5-3-554
TO REACTOR SAFETY/	COMMON-MODE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT	17-6-3-686
	ACTIVITY CONFINEMENT AND DECONTAMINATION AFTER FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE ROD/	14-4-6-362
OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING/	ANALYSIS	15-3-2-285
	FAILURE OF A REACTOR PRIMARY SCRAM SYSTEM/	12-6-6-468
	PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES/	15-4-2-387
BREEDER REACTOR FUEL SUBASSEMBLIES/	PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL COOLED FAST	16-3-2-291
	PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES/	15-4-2-387
EAR POWER REACTORS DURING 1972/	STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL	16-5-6-354
EAR POWER REACTORS IN 1973/	STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL	16-5-6-603
EAR POWER REACTORS IN 1974/	STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL	17-2-6-231
EAR REACTORS IN 1975/	STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL	19-3-6-354
	GBR-4 PROTECTION SYSTEMS - FAILURES AND THEIR CONSEQUENCES/	16-2-5-150
	SWITCH FAILURES AT NUCLEAR FACILITIES/	14-6-6-660
	COMMON-MODE FAILURES IN REACTOR SAFETY SYSTEMS/	18-5-3-624
NUCLEAR FACILITIES/	FAILURES OF THREADED FITTINGS AND FASTENERS AT N	13-1-5-047
	FAILURES OF THREADED FITTINGS AND FASTENERS AT N	13-1-5-047
FERRITIC PRESSURE VESSEL STEELS/	FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED	18-6-4-791
PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE FEDERAL REPUBLIC OF GERMANY/		15-4-3-409
INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPA		15-3-1-262
CA ON NRC LICENSING JURISDICTION AND PROCEDURES/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPA		16-4-1-421
	A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS/	13-4-3-295
	FUEL MELTING INCIDENT AT THE FERMI REACTOR ON OCT. 3, 1966/	12-2-6-123
FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEELS/		18-6-4-791
	BROWNS FERRY NUCLEAR POWER PLANT FIRE ON MAR. 22, 1975/	17-5-6-592
	DESIGN AND EVALUATION OF FFF CONTAINMENT/	14-5-4-470
R LOW WIND SPEED INVERSION CONDITIONS/	A SURVEY OF FIELD MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDE	17-2-5-223
LUATION OF NUCLEAR POWER PLANTS/	FIFTH GERMAN SYMPOSIUM ON PROGRESS IN SAFETY EVA	11-6-2-443
LOW AS PRACTICABLE HEARING/	REVIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNING THE AS	15-4-5-440
	THE ORIGIN AND FINDINGS OF THE ATOMIC BOMB CASUALTY COMMISSION/	14-6-5-651
	BROWNS FERRY NUCLEAR POWER PLANT FIRE ON MAR. 22, 1975/	17-5-6-592
	KINETIC'S EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMENA/	16-3-5-337
STUDIES/	FISSION GAS EFFECTS IN REACTOR FUELS I. BASIC S	12-4-2-297
ERING APPLICATIONS/	FISSION GAS EFFECTS IN REACTOR FUELS II. ENGINE	12-4-2-562
	LMFBR SAFETY I. A REVIEW OF SHORT TERM FISSION PRODUCT BEHAVIOR IN SODIUM/	11-5-3-379
	FISSION PRODUCT DECAY POWER/	18-5-2-596
ATURE GAS-COOLED REACTORS/	FISSION PRODUCT DETECTION SYSTEMS IN HIGH TEMPER	12-2-3-90
REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR FISSION PRODUCT REMOVAL/		12-5-5-516
INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS/		11-4-4-315
CE STRENGTH/	ON ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOUR	13-1-5-054
	FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR FACILITIES/	13-1-5-047
NO CONTROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FIXED NEUTRON ABSORBER/	THE SAFETY A	15-3-4-295
MENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES/	STATE AND LOCAL GOVERN	17-1-1-15
HE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FLATS PLANT I./		15-5-4-572
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FLATS PLANT II./		15-6-4-723
	PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER PLANTS/	15-4-2-379
	LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSIS/	14-2-3-160
	LOSS OF FLUID TEST INTEGRAL TEST FACILITY AND PROGRAM/	15-6-2-617
	CRITICAL HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT/	18-3-2-298
	SAFETY ASSESSMENT PHILOSOPHY OF THE FAST FLUX TEST FACILITY/	14-2-1-079
G TOWERS/	FOG AND DRIFT DEPOSITION FROM EVAPORATIVE COOLIN	15-2-5-197
	TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN FOOD CHAINS/	11-1-5-047
IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY FORCED CONVECTION SYSTEMS/		18-2-2-154
WER REACTOR WASTES/	STATUS OF INVESTIGATIONS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE PO	11-2-5-130
COMPARISONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/	RADIATION IN PERSPEC	12-3-1-185
	THE FOURTEENTH ERDA AIR CLEANING CONFERENCE/	18-2-4-174
E INSTRUMENT SOCIETY OF AMERICA/	THE FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM OF TH	13-1-3-029
T GENEVA - A REVIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOURTH GENEVA CONFERENCE/	NUCLEAR SAFETY A	13-3-0-181
MEETING/	FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION	18-2-1-133
SECTION STEEL TECHNOLOGY PROGRAM/	FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY	12-5-5-523
	RADIOACTIVE WASTE DISPOSAL BY HYDRAULIC FRACTURING/	11-5-4-391
F MOLTEN URANIUM DIOXIDE IN SODIUM/	FRAGMENTATION MODELING RELATIVE TO THE BREAKUP O	16-6-2-683
TS OF ELECTRICITY GENERATION FROM COAL, OIL, AND NUCLEAR FUEL/	HEALTH EFFECT	14-5-1-409
RELATING TO AN EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL/	SOME PRELIMINARY CONSIDERATIONS	13-6-2-467
ON SUPPRESSION DEVICES FOR TWO TYPES OF RESEARCH REACTOR FUEL/	A COMPARISON OF TWO NITROGEN-16 RADIATI	11-3-6-237
	CASKS FOR IRRADIATED FUEL - A LOOK AT THE CASK DESIGNERS GUIDE/	12-6-1-553
	CSNI MEETING ON FUEL - COOLANT INTERACTIONS/	16-4-2-436
	THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTOR INDUSTRIES/	17-3-6-363
	PARTIAL BLOCKAGES IN LMFBR FUEL ASSEMBLIES/	17-1-2-14
	U.S. STUDIES ON LMFBR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS/	14-5-2-452
INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL CYCLE/	PROBABILITY AND CONSEQUENCES OF TRAN	14-6-2-597
R AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILITIES/	RADIATION DOSES AND EFFEC	17-3-5-51
	DETECTION OF FAILED FUEL ELEMENTS/	13-3-3-220
T.S. 1966/	FUEL MELTDOWN AT ST. LAURENT I/	12-1-4-035
	MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL MELTING INCIDENT AT THE FERMI REACTOR ON OC	12-2-6-123
HE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESSING OPERATIONS/		14-5-5-482
ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/		16-5-5-593
ATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT/	ESTIMATES OF DOSE TO NO	17-5-5-130
REACTOR ACCIDENTS/	FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER	12-5-3-487
	PROPAGATION IN LIQUID METAL COOLED FAST BREEDER REACTOR FUEL SUBASSEMBLIES/	16-3-2-291
ISONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/	RADIATION IN PERSPECTIVE -	12-3-1-185
	IAEA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS/	18-1-6-79

DENSIFICATION OF REACTOR FUELS/	FUELS 1. BASIC STUDIES/	14-4-356
FISSION GAS EFFECTS IN REACTOR FUELS	FUELS II. ENGINEERING APPLICATIONS/	12-4-2-297
PREDICTING SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTAL LOCATIONS		12-6-2-562
RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FUSION POWER/		12-2-5-110
INITIAL OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER/		18-2-5-203
ITS IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION OF THE PRELIMINARY OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER/		13-5-1-353
S IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF THE FUSION POWER/		15-3-1-262
SAFETY EXPERIENCE GAINED FROM RAPIDOCIE OPERATION/		16-4-1-221
EFFECT OF RUPTURE IN A PRESSURIZED MOBILE GAS ADSORPTION BED/		14-1-6-027
FISSION GAS EFFECTS IN REACTOR FUELS 1. BASIC STUDIES/		13-6-4-478
FISSION GAS EFFECTS IN REACTOR FUELS II. ENGINEERING AP		12-4-2-297
GAS-COOLED REACTORS/		12-6-2-562
GASES I A REVIEW OF NINE PAPERS PRESENTED AT THE		12-2-3-90
GASES II A REVIEW OF SELECTED PAPERS PRESENTED AT THE		15-3-4-302
GASES SYMPOSIUM AT LAS VEGAS I/ SEPARATION AND C		15-6-5-732
GASES SYMPOSIUM AT LAS VEGAS I/ BIOLOGICAL EFPE		15-3-4-302
GMR-4 PROTECTION SYSTEMS - FAILURES AND THEIR CO		15-6-5-732
GENERATING STATION/		16-2-3-150
GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WA		15-6-3-691
GENERATION FROM COAL, OIL, AND NUCLEAR FUEL/		13-6-2-459
GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER		14-5-1-409
GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA		16-2-6-224
GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA		15-6-6-603
GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA		17-2-6-231
GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA		18-3-6-355
GENEVA - A REVIEW OF THE NUCLEAR SAFETY ASPECTS		13-3-0-181
GENEVA CONFERENCE/		13-3-0-181
GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGR		18-6-1-727
GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOG		14-3-1-181
GERMAN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATIO		11-6-2-443
GERMANY/		15-6-3-409
GIANT/		12-4-1-243
GOES PUBLIC - A CASE HISTORY/		11-5-1-365
GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS		17-1-1-15
GUIDANCE FOR POWER PLANT SITING, DESIGN, AND OPE		18-3-5-329
GUIDE/		12-6-1-553
GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION		11-1-5-039
GUIDE FOR MANAGEMENT I/ U.S.A. STANDARD N13.2-19		11-1-5-039
GUIDELINES/		12-5-1-456
HAZARD FOR NUCLEAR POWER PLANTS/		15-6-6-460
HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WAST		15-6-2-399
HEALING ARTS/		16-2-6-180
HEALTH/		14-6-5-340
HEALTH/		12-1-1-001
HEALTH EFFECTS OF ELECTRICITY GENERATION FROM CO		15-2-5-185
HEALTH IN THE POPULATION NEAR NUCLEAR FACILITIES		14-5-1-409
HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITIN		18-5-5-647
HEALTH PHYSICS IN THE HEALING ARTS/		12-5-6-530
HEALTH PHYSICS SOCIETY/		14-6-5-340
HEALTH RISKS OF THERMAL POWER PLANTS/		16-6-5-720
HEARING/		14-6-1-267
HEARING/		15-1-4-030
HEARING/		15-4-5-440
HEARINGS ON REACTOR SAFETY/		15-4-5-443
HEAT AND MOISTURE PRODUCED BY MAN/		15-2-1-132
HEAT CONDUCTION COMPUTER PROGRAMS/		12-2-5-114
HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT/		12-6-2-569
HEAT TRANSFER I. POOL BOILING SYSTEMS/		18-3-2-298
HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY FOR		16-1-2-29
HEATING/		18-2-2-154
HEAVY SECTION STEEL TECHNOLOGY PROGRAM/		13-3-1-216
Hemispheric Population Groups from Krypton-85 EMI		11-1-2-012
HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELE		12-5-5-523
HIGH TEMPERATURE GAS-COOLED REACTORS/		13-2-5-130
HIS ENVIRONMENT/		18-2-3-168
HISTORY/		12-2-3-90
HISTORY REFLECTING THE SUCCESS OF NUCLEAR SAFETY		13-5-5-380
HOMEMADE NUCLEAR BOMB SYNDROME/		11-5-1-365
HOT PARTICLE PROBLEM/		12-4-1-291
HTGR/		18-4-1-427
HTGR ACCIDENT CONSEQUENCES/		17-4-5-464
HTGR SAFETY/		14-6-4-618
HUMAN ENGINEERING - AIDS TO SMOOTH OPERATION/		18-6-2-761
HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIG		12-5-1-438
HUMAN FACTORS IN THE NUCLEAR CONTROL ROOM/		16-5-2-546
HUMAN RELIABILITY ANALYSIS/		18-2-6-223
HYDRAULIC FRACTURING/		14-1-3-021
HYDRODYNAMICS METHODS/		18-6-3-774
HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDE		17-3-3-315
HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE L		11-5-4-351
HYPOTHETICAL VESSEL RUPTURE/		14-2-2-091
IAEA - WHO SYMPOSIUM ON HANDLING OF RADIATION AC		17-6-2-459
IAEA INTERNATIONAL SYMPOSIUM ON NUCLEAR POWER P		11-6-3-468
IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIO		14-2-2-291
IAEA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND		12-4-5-338
IAEA-NEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF N		15-1-3-015
IAEA-NEC MEETING ON SODIUM COMBUSTION AND ITS		13-2-1-103
IAEA-WHO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF A		16-1-6-79
ICE CONDENSER REACTOR CONTAINMENT SYSTEM/		12-2-1-75
		15-2-2-146
		15-3-5-306
		11-3-4-215

PPRESSION/	THE	ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE SU	17-6-710
	JOINT ANNUAL SYMPOSIUM OF	IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM/	16-5-3-557
RESPONSIBILITIES FOR NUCLEAR POWER - LAPP REPORT TO THE		IEEE POWER AND NUCLEAR SCIENCE GROUPS - 1970/	12-4-3-310
COURTS/	BALANCING ENVIRONMENTAL	ILLINOIS COMMERCE COMMISSION/ STATE	14-6-1-574
PROCESSING PLANT/	THE ENVIRONMENTAL	IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE	13-3-1-209
PROCESSING PLANT/	THE ENVIRONMENTAL	IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REP	16-5-5-593
LANCING ENVIRONMENTAL IMPACT AND ECONOMIC PROGRESS - THE		IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL R	17-5-5-580
OMS FOR THE SAFE TRANSPORT OF RADIOACTIVE MATERIALS/ THE		IMPACT OF THE COURTS/	13-3-1-209
AMS/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS		IMPACT OF THE PROPOSED REVISIONS TO IAEA REGULAT	13-2-1-103
RES/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS		IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION O	15-3-1-262
PRELIMINARY OBSERVATIONS ON THE RADIOLOGICAL		IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFF	16-4-1-421
SSURE COMPONENTS/		IMPLICATIONS OF FUSION POWER/	13-5-1-353
L COOLED FAST BREEDER REACTORS/	RADIOLOGICAL ASPECTS OF	IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PRE	17-6-6-733
	FUEL MELTING	IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID META	18-4-3-469
		INACTIVE URANIUM MILLING SITES - AN OVERVIEW/	17-6-5-722
		INCIDENT AT THE FERMI REACTOR ON OCT. 5, 1966/	12-2-6-123
		INCIDENT AT THE LUCENS REACTOR/	16-1-6-76
		INCIDENT OF JUNE-5, 1970/	12-5-7-530
ING BOILING WATER REACTORS/	EVALUATION OF	INCIDENTS OF PRIMARY COOLANT RELEASE FROM OPERAT	15-1-6-076
PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION TO DETECT		INCIDENT FAILURE IN NUCLEAR PRESSURE VESSELS/ A	15-5-3-554
1. APPLICATION OF THE FWPCA AND RELATED LEGISLATION TO		INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS/	15-3-1-262
		INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS/	11-2-1-107
THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTOR		INDUSTRIES/	17-3-6-363
F EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE NUCLEAR		INDUSTRY/	16-4-4-458
PUBLIC OPPOSITION TO NUCLEAR POWER - AN		INDUSTRY OVERVIEW/	12-5-2-448
POPULATION DOSES FROM THE NUCLEAR		INDUSTRY TO 2000 A.D./	15-1-5-056
WATER REACTOR SAFETY RESEARCH		INFORMATION MEETING/	15-3-1-241
WATER REACTOR SAFETY RESEARCH		INFORMATION MEETING/	16-1-1-8
WATER REACTOR SAFETY RESEARCH		INFORMATION MEETING/	17-2-1-143
FOURTH WATER REACTOR SAFETY RESEARCH		INFORMATION MEETING/	18-2-1-133
THE RELAP4 COMPUTER CODE	2. ENGINEERING DESIGN OF THE	INPUT MODEL/	17-3-2-299
MENTS/	IN-SERVICE	INSPECTION OF NUCLEAR POWER PLANT PRESSURE COMPO	17-6-6-733
ST BREEDER REACTORS/	IN-SERVICE	INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FA	18-4-3-469
	LEGAL AND	INSTITUTIONAL PROBLEMS IN POWER PLANT SITING/	18-2-1-127
THE FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM OF THE		INSTRUMENT SOCIETY OF AMERICA/	13-1-3-029
TOP CONTAINMENTS/	A SURVEY OF APPLIED	INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER REAC	15-6-3-702
SET-POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RELATED		INSTRUMENTATION/	16-2-6-223
ERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT CONTROL AND		INSTRUMENTATION/	15-1-3-015
L POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER		INSTRUMENTATION/	15-4-3-417
THE 26TH ISA CONFERENCE AND EXHIBIT/		INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS -	13-5-3-366
OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER REACTORS/		INSTRUMENTATION FOR MONITORING THE HYPOTHETICAL	11-6-3-468
OP/	SAFETY	INSTRUMENTATION FOR THE SODIUM COOLED FAST REACT	16-4-3-701
SITES/		INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT	18-5-3-617
INSTRUMENTATION/	THE 16TH ANNUAL POWER	INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER	15-4-3-417
ETY OF AMERICA/	THE FOURTEENTH POWER	INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCI	13-1-3-329
WER REACTOR PLANTS/	PROTECTION	INSTRUMENTATION SYSTEMS IN LIGHT WATER-COOLED PO	11-3-3-206
	SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY	INSTRUMENTS/	16-4-3-452
R PLANT/	SILICONE RUBBER	INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWE	16-4-3-714
SS OF NUCLEAR SAFETY/	NUCLEAR LIABILITY	INSURANCE - A BRIEF HISTORY REFLECTING THE SUCE	12-4-1-291
	NUCLEAR LIABILITY	INSURANCE - A RESUME OF RECENT YEARS/	16-5-1-537
	LOSS OF FLUID TEST	INTEGRAL TEST FACILITY AND PROGRAM/	15-6-2-676
POWER/	ASSESSMENT OF A HIGH	INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC	18-2-3-168
	CSNI MEETING ON FUEL - COOLANT	INTERACTIONS/	16-4-2-436
GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT		INTERIOR STRUCTURES/	13-5-4-373
RCN/	NRC	INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEA	18-5-1-589
ON PRODUCTS/		INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSI	11-4-4-315
RELATED PHYSICS/	1976	INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND	18-4-2-451
RTATION OF RADIOACTIVE MATERIALS/	THIRD	INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSP	14-4-1-274
CONTROL AND INSTRUMENTATION/	IAEA	INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT	15-1-3-015
OF REACTOR SAFETY/		INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS	14-5-1-428
	SOME EFFECTS OF PUBLIC	INTERNATIONAL WASTE MANAGEMENT SYMPOSIUM/	18-4-5-502
ASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED		INTERVENTION ON THE REACTOR LICENSING PROCESS/	13-1-1-013
CONCENTRATIONS/	ELEMENTAL IODINE AND METHYL	INVERSION CONDITIONS/ A SURVEY OF FIELD ME	17-2-5-223
CHARCOAL AT LOW CONCENTRATIONS/	ELEMENTAL	IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT LOW C	15-6-4-711
NG PLANT/	THE ENVIRONMENTAL IMPACT	IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED	15-6-4-711
NTRATION IN REACTOR CONTAINMENT BUILDINGS MASQUERADES AS		IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESS	16-5-5-593
FACTORS LIMITING PROMPT-CRITICAL EXCURSIONS IN		IODINE-131 RELEASE/	11-3-6-235
FATIGUE CRACK PROPAGATION IN NEUTRON		IRRADIATED FAST REACTOR CORES/	14-3-2-201
UIDE/	CASKS FOR	IRRADIATED FERRITIC PRESSURE VESSEL STEELS/	18-6-4-791
MANY CONSIDERATIONS RELATING TO AN EQUATION OF STATE FOR	NEUTRON	IRRADIATED FUEL - A LOOK AT THE CASK DESIGNERS G	12-6-1-553
SSIL STEELS/		IRRADIATED NUCLEAR FUEL/	13-6-2-467
INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH		IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VE	17-3-4-327
	AFG TESTIMONY AT THE 1973	ISA CONFERENCE AND EXHIBIT/	13-5-3-366
	NUCLEAR EMERGENCY PLANNING IN THE STATE OF NEW	ISPRAS CONTRIBUTION TO REACTOR SAFETY/	13-6-1-451
SCIENCE GROUPS - 1970/	JERSEY/	JCAE HEARINGS ON REACTOR SAFETY/	15-2-1-132
	JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR		14-6-1-563
ER PLANTS PART II. THE EFFECT OF FWPCA ON NRC LICENSING	JUNE-5, 1970/		12-4-3-310
RECENT DEVELOPMENTS IN FAST REACTOR	JURISDICTION AND PROCEDURES/ THE NEW FEDERAL WAT		12-5-7-538
PHENOMENA/	KINETICS/		16-4-1-421
ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE UNITED	KINETICS EGATION FOR LINEAR FIRST-ORDER NUCLEAR		11-4-2-289
	KINGDOM/	SAFETY	16-3-5-337
ES OF DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FROM	KRYPTON - XENON REMOVAL SYSTEMS/		11-4-1-283
STATE RESPONSIBILITIES FOR NUCLEAR POWER -	KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPR		12-4-4-591
THE 1971 TRITIUM SYMPOSIUM AT	LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION/		13-2-5-130
G PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT	LAS VEGAS I/ BIOLOGICAL EFFECTS OF NOBLE GASES I		14-6-1-574
ME PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT	LAS VEGAS I/ SEPARATION AND CONTAINMENT OF NOBLE		13-3-5-225
LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE	LATE MORTALITY RISKS FROM REACTOR ACCIDENTS/		15-6-5-732
STANDBY EMERGENCY POWER SYSTEMS. II. THE	LATER PLANTS/		15-3-4-302
FUEL MELTDOWN AT ST.	LAURENT I/		11-6-4-482
THE	LAW AND LOW LEVEL RADIATION/		16-2-3-162
			12-1-4-035
			15-5-5-585

15-4-6-460
18-2-1-127
15-3-1-262
11-6-4-481
12-4-1-291
16-5-1-537
16-1-5-71
17-6-6-743
18-4-6-253
15-4-1-303
16-4-1-21
17-5-2-550
18-5-1-
15-6-1-665
13-1-1-013
13-1-1-001
18-3-1-281
15-2-4-175
18-3-6-363
11-6-3-468
12-5-3-487
15-5-3-702
12-5-1-433
16-5-1-542
18-6-1-727
17-5-4-568
18-1-4-66
14-1-2-214
18-5-6-666
11-3-3-206
14-3-2-201
18-6-5-822
11-6-1-435
16-3-5-337
17-2-4-208
16-1-4-43
13-3-2-291
17-1-4-037
18-4-3-469
16-3-6-318
11-1-1-001
15-5-2-446
16-4-4-458
12-6-3-583
14-5-3-325
14-2-2-304
17-1-2-19
14-5-2-452
12-5-1-421
11-5-3-319
17-5-2-550
13-2-2-107
18-1-3-53
17-4-2-422
17-6-7-671
17-1-1-15
12-2-5-110
18-3-2-306
12-3-3-226
12-6-1-553
18-3-2-98
14-1-2-014
13-6-2-459
15-3-2-285
18-2-3-168
10-1-3-53
15-6-2-676
11-6-3-468
15-4-5-440
15-5-4-433
15-6-6-711
14-2-3-105
15-5-5-585
18-2-2-154
17-2-5-223
16-1-6-76
17-3-5-351
17-4-4-447
17-5-6-622
16-3-3-316
15-3-6-316
14-4-3-315
12-2-5-114
16-3-3-316
13-5-5-303
11-1-5-039
15-5-4-628
17-5-5-502
17-5-6-592
18-4-4-481
11-3-6-235

REST/	CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTE	17-5-1-539
CTOR SAFETY/	RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WASTE/	16-2-4-180
TION WORKERS/	COMMON-MODE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO REA	17-6-3-686
TS/	SHOULD MEDICAL RADIATION EXPOSURE BE RECORDED FOR RADIA	14-3-5-220
	SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFEC	11-6-4-475
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	15-3-1-241
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	16-1-1-8
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	17-2-1-143
	FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-2-1-133
	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	17-3-1-289
	THE THIRD RELIABILITY MEETING AT RISQ/	11-4-3-309
	1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	16-2-1-141
CS/	1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSI	18-4-2-451
	CSNI MEETING ON FUEL - COOLANT INTERACTIONS/	16-4-2-436
	REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING/	16-3-1-273
	THE 1974 SPECIALISTS MEETING ON REACTOR NOISE/	16-3-3-308
ENT/	MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHM	15-2-2-146
	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/	14-5-1-439
	PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS/	18-1-4-60
	FUEL MELTDOWN AT ST. LAURENT I/	12-1-4-035
S DURING OUTGASSING/	UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM CERMET CORE	15-4-6-455
966/	FUEL MELTING INCIDENT AT THE FERNI REACTOR ON OCT.5.1	12-2-6-123
RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID	METAL COOLED FAST BREEDER REACTORS I. PRODUCTI	16-1-4-43
LIES/	PIN-TO-PIN FAILURE PROPAGATION I. LIQUID METAL COOLED FAST BREEDER REACTOR FUEL SUBASSEMB	16-3-2-291
	CONTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER REACTORS/	13-1-4-037
	EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTORS/	17-2-4-208
	IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FAST BREEDER REACTORS/	18-4-3-469
	RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPOR	16-3-4-318
	THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM/	11-1-1-001
PRODUCED BY MAN/	METEOROLOGICAL EFFECTS OF THE HEAT AND MOISTURE	12-2-5-114
T LOW CONCENTRATIONS/	ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL A	15-6-4-711
	QUALITY ASSURANCE PROBLEMS AT MIDLAND, NUCLEAR POWER PLANT/	17-1-6-87
SOCIETY/	POPULATION EXPOSURES - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS	16-6-5-720
	RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING SITES - AN OVERVIEW/	17-6-5-722
ES FOR REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM	MINE ATMOSPHERES/ PROBLEMS AND TECHNIQU	14-6-5-643
AVAILABLE FOR RISK REDUCTION/	RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES	12-4-2-305
ES/	SAN ONOPRE EXPERIENCE WITH APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE ANOMALI	11-2-6-142
	A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PROBABILITIES/	16-4-2-443
	RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH REACTOR/	17-4-3-437
SYSTEM PERFORMANCE/	STEAM - WATER MIXING STUDIES RELATED TO EMERGENCY CORE COOLING	17-2-2-185
RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT	MODEL/	17-2-2-299
UM DIOXIDE IN SODIUM/	FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANI	16-6-2-643
	METEOROLOGICAL EFFECTS OF THE HEAT AND MOISTURE PRODUCED BY MAN/	12-2-5-114
	FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM/	16-6-2-683
	QUO VADIS, PERSONNEL MONITORING/	16-6-5-728
2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION	MONITORING (A GUIDE FOR MANAGEMENT I) U.S.A. ST	11-1-5-079
	LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSIS/	14-2-3-105
IN LARGE LIGHT WATER POWER REACTORS/ INSTRUMENTATION FOR	MONITORING THE HYPOTHETICAL LOSS-OF-COOLANT ACCI	11-6-3-668
FLUENTS I. AEC OWNED FACILITIES/	THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EF	16-1-5-60
FLUENTS II. AEC LICENSED FACILITIES/	THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EF	16-1-5-71
EUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE LATE	MORTALITY RISKS FROM REACTOR ACCIDENTS/	11-6-4-482
S/	SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER PLANT	13-2-2-114
	NATIONAL CONFERENCE ON WASTE HEAT UTILIZATION/	13-3-1-216
	REFLECTIONS ON THE RECRITICALITY CONFERENCE AT ARGONNE	18-2-2-45
/	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY	14-5-1-439
S/	NATURAL BACKGROUND RADIATION IN THE UNITED STATE	17-4-5-471
	NATURAL RADIATION IN THE URBAN ENVIRONMENT/	13-4-1-275
TAOL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FIXED	NEUTRON ABSORBER/ THE SAFETY AND CON	15-3-4-295
LS/	FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEE	18-6-4-791
SSURE VESSEL STEELS/	NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRE	17-3-4-327
	POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRONIC ACCIDENTS IN HTGRs/	16-5-2-566
	COUPLED NEUTRONICS HYDRODYNAMICS METHODS/	14-2-2-091
	OZONE FORMATION BY THE RADIOLYSIS OF LIQUID NITROGEN - CALCULATION AND MEASUREMENT/	14-5-2-446
D TYPES OF RESEARCH REACTOR FUEL/	A COMPARISON OF TWO NITROGEN-16 ADSORPTION SUPPRESSION DEVICES FOR TM	11-3-6-237
	EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION BED/	13-6-4-478
	SYMPOSIUM AT LAS VEGAS I/ SEPARATION AND CONTAINMENT OF NOBLE GASES (A REVIEW OF NINE PAPERS PRESENTED	15-3-5-302
E GASSES SYMPOSIUM AT LAS VEGAS I/ BIOLOGICAL EFFECTS OF NOBLE GASES (A REVIEW OF SELECTED PAPERS PRESEN	NOBLE GASES (A REVIEW OF SELECTED PAPERS PRESEN	15-6-5-732
LE GASSES (A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I/ SEPARATION	NOBLE GASSES SYMPOSIUM AT LAS VEGAS I/ BIOLOGICA	15-3-4-702
ASES (A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASSES SYMPOSIUM AT LAS VEGAS I/ BIOLOGICA	NOBLE GASSES SYMPOSIUM AT LAS VEGAS I/ BIOLOGICA	15-6-5-732
	THE 1974 SPECIALISTS MEETING ON REACTOR NOISE/	16-3-3-308
	RESULTS OF THE FIRST THREE NONNUCLEAR TESTS IN THE LOFT FACILITY/	18-3-2-306
R REACTORS I. PRODUCTION/ RADIONUCLIDE BEHAVIOR DURING	NORMAL OPERATION OF LIQUID METAL COOLED FAST BRE	16-1-4-43
ER REACTORS II. TRANSPORT/ RADIONUCLIDE BEHAVIOR DURING	NORMAL OPERATION OF LIQUID METAL COOLED FAST BRE	16-3-4-318
LE NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATES OF DOSE TO	NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPT	13-2-5-130
	NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS/	15-6-1-651
RESEARCH/	NRC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY &	18-5-1-589
ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPCA ON	NRC LICENSING JURISDICTION AND PROCEDURES/ THE N	16-4-1-421
	NRC WATER REACTOR SAFETY RESEARCH PROGRAM/	18-1-1-1
	COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	12-5-3-461
	COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	15-5-2-535
	PROBLEMS IN NUCLEAR AIR CLEANING SYSTEMS/	16-4-4-469
CTIVE - SOME COMPARISONS OF THE ENVIRONMENTAL RISKS FROM	NUCLEAR AND FOSSIL FUELED POWER PLANTS/ RADIATIO	12-3-1-185
	THE HOMEMADE NUCLEAR BOOB SYNDROME/	18-4-1-427
	PROBABILITY OF CARGO TO NUCLEAR COMPONENTS DUE TO TURBINE FAILURE/	14-3-2-187
	HUMAN FACTORS IN THE NUCLEAR CONTROL ROOM/	18-6-3-774
ERSEV/	PLANNING FOR NUCLEAR EMERGENCIES/	17-1-1-1
	NUCLEAR EMERGENCY PLANNING IN THE STATE OF NEW J	14-6-1-363
	NUCLEAR ENERGY CENTER SITE SURVEY - 1975/	17-4-1-411
TOR SITING/	NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REAC	16-3-1-282
	OFFSHORE SITING OF NUCLEAR ENERGY STATIONS/	12-1-2-009
	FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR FACILITIES/	13-1-5-047
	SWITCH FAILURES AT NUCLEAR FACILITIES/	14-6-6-660
	CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES/	18-5-4-633

TES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST	NUCLEAR FACILITIES/	ESTIMA	17-6-1-659
ADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED	NUCLEAR FACILITIES/ STATE AND LOCAL GOVERNMENT R		17-1-1-15
TRENDS IN PUBLIC HEALTH IN THE POPULATION NEAR	NUCLEAR FACILITIES - A CRITICAL ASSESSMENT/		18-5-5-647
ENVIRONMENTAL RADIATION EFFECTS OF	FACILITIES IN NEW YORK STATE/		18-2-5-204
SYMPOSIUM ON THE TRAINING OF	NUCLEAR FACILITY PERSONNEL/		12-6-6-615
SECOND SYMPOSIUM ON TRAINING OF	NUCLEAR FACILITY PERSONNEL/		17-1-6-92
SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF	NUCLEAR FACILITY SITING/		12-5-6-530
IN EFFECTS OF ELECTRICITY GENERATION FROM COAL, OIL, AND	NUCLEAR FUEL/	NEAL	14-5-1-409
EMISSIONS RELATING TO AN EQUATION OF STATE FOR IRRADIATED	NUCLEAR FUEL/	SOME PRELIMINARY CONSID	13-6-2-467
THE SAFETY OF WORKERS IN THE	NUCLEAR FUEL AND REACTOR INDUSTRIES/		17-3-6-363
CCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE	NUCLEAR FUEL CYCLE/ PROBABILITY AND CONSEQUENCES		14-6-2-597
THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A	NUCLEAR FUEL REPROCESSING PLANT/		16-5-5-593
THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A	NUCLEAR FUEL REPROCESSING PLANT/		17-5-5-500
RE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE	NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATES OF DO		13-2-5-130
CATION OF EVAPORATION TO THE TREATMENT OF LIGANDS IN THE	GENERATING STATION/		15-6-3-691
POPULATION DOSES FROM THE	INDUSTRY/	APPLI	16-4-6-450
FLECTING THE SUCCESS OF NUCLEAR SAFETY/	INDUSTRY TO 2000 A.D./		15-1-5-056
YEARS/	LIABILITY INSURANCE - A BRIEF HISTORY RE		12-4-1-291
	LIABILITY INSURANCE - A RESUME OF RECENT		16-5-1-537
SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF	NUCLEAR MATERIALS/		25-5-1-513
KINETICS EQUATION FOR LINEAR FIRST-ORDER	NUCLEAR PHENOMENA/		16-3-5-337
A SYSTEMS APPROACH TO	PLANT SAFETY/		11-6-1-445
EMP AND NUCLEAR	PLANT SAFETY/		18-3-3-322
UNDERGROUND	PLANT SITING - A TECHNICAL AND SAFETY AS		15-5-1-519
SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO	PLANT SPACES/		14-6-6-634
THE IAEA-AEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF	POWER/		12-2-1-75
PUBLIC OPPOSITION TO	NUCLEAR POWER - AN INDUSTRY OVERVIEW/		12-5-2-448
STATE RESPONSIBILITIES FOR	NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMM		14-6-1-574
QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR	NUCLEAR POWER APPLICATIONS/		18-3-3-317
DESIGN GIANT/	NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE		12-4-1-203
SILICONE RUBBER INSULATED CABLES FOR CALVEPT CLIFFS	NUCLEAR POWER PL. IT/		16-7-3-714
QUALITY ASSURANCE PROBLEMS AT MIDLAND	NUCLEAR POWER PLANTS/		17-1-6-87
THE RELAPX COMPUTER CODE 1. APPLICATION TO	NUCLEAR POWER PLANT ANALYSIS/		17-2-2-194
EVALUATION OF	NUCLEAR POWER PLANT AVAILABILITY/		15-5-6-599
STATISTICS FOR 1973/	NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY ST		15-6-6-738
IAEA INTERNATIONAL SYMPOSIUMS ON	NUCLEAR POWER PLANT CONTROL AND INSTRUMENTATION/		15-1-3-015
BROWN'S FERRY	NUCLEAR POWER PLANT FIRE ON MAR.22.1975/		17-5-6-592
	NUCLEAR POWER PLANT PERFORMANCE ANALYSIS/		18-5-6-644
IN-SERVICE INSPECTION OF	NUCLEAR POWER PLANT PRESSURE COMPONENTS/		17-6-6-733
THE DESIGN BASIS FOR	NUCLEAR POWER PLANT PROTECTION SYSTEMS/		11-1-3-020
SET-POINT DRIFT IN	NUCLEAR POWER PLANT SAFETY RELATED INSTRUMENTATI		16-2-6-223
REACTOR OPERATOR TRAINING PROGRAMS UTILIZING	NUCLEAR POWER PLANT SIMULATORS/		14-5-5-402
AEC WORKING PAPER ON POPULATION DENSITY AROUND	NUCLEAR POWER PLANT SITES/		16-1-1-1
INSTRUMENTATION PROGRAMS FOR	NUCLEAR POWER PLANT SITES/		18-5-3-617
REVIEW OF AMS TOPICAL MEETING ON	NUCLEAR POWER PLANT SITING/		16-3-1-273
TORNADO CONSIDERATIONS FOR	NUCLEAR POWER PLANT STRUCTURES/		11-4-2-296
TORNADO RESISTANT DESIGN OF	NUCLEAR POWER PLANT STRUCTURES/		15-4-4-432
INDUSTRIAL SABOTAGE IN	NUCLEAR POWER PLANTS/		11-2-1-107
SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON	NUCLEAR POWER PLANTS/		13-2-2-114
THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF	NUCLEAR POWER PLANTS/		14-1-1-006
HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR	NUCLEAR POWER PLANTS/		14-1-3-021
THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF	NUCLEAR POWER PLANTS/		14-3-1-165
MATERIALS PERFORMANCE AT	NUCLEAR POWER PLANTS/		14-5-6-507
PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR	NUCLEAR POWER PLANTS/		15-3-2-276
VALVE MALFUNCTIONS IN	NUCLEAR POWER PLANTS/		15-3-6-316
PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR	NUCLEAR POWER PLANTS/		15-4-2-399
NOVEL SITING SOLUTIONS FOR	NUCLEAR POWER PLANTS/		15-6-1-651
AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL	NUCLEAR POWER PLANTS/		15-6-1-673
QUALITY ASSURANCE IN THE CONSTRUCTION OF	NUCLEAR POWER PLANTS/		16-2-1-127
DIESEL GENERATOR OPERATING EXPERIENCE AT	NUCLEAR POWER PLANTS/		16-2-6-22
SOLID RADIOACTIVE WASTE PRACTICES AT	NUCLEAR POWER PLANTS/		16-5-4-501
OCCUPATIONAL RADIATION EXPOSURE AT	NUCLEAR POWER PLANTS/		16-5-6-614
COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR	NUCLEAR POWER PLANTS/		17-5-1-525
TRENDS IN THE LICENSING OF	NUCLEAR POWER PLANTS/		18-5-1-581
FTM GERMAN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF	NUCLEAR POWER PLANTS/	FI	11-6-2-463
EA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF	NUCLEAR POWER PLANTS/	IA	16-1-6-79
ATION OF RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN	NUCLEAR POWER PLANTS/ THE AEC STUDY ON THE ESTIM		15-4-1-375
NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON	NUCLEAR POWER PLANTS 1. APPLICATION OF THE FWPC		15-3-1-262
NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON	NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPC		16-4-1-421
CTS PROBLEM/	ECOLOGICAL CONSIDERATIONS IN SITING		12-1-3-025
SUMMARY OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM	NUCLEAR POWER PLANTS DURING 1973/		16-6-6-734
EASES OF RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM	NUCLEAR POWER PLANTS IN 1972/	REL	15-3-6-311
RADIOACTIVE MATERIAL RELEASED FROM	NUCLEAR POWER PLANTS IN 1974/		18-1-6-79
AN ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN	NUCLEAR POWER REACTORS/		14-4-3-315
BENEFIT COST ANALYSES IN LICENSING OF	NUCLEAR POWER REACTORS/		15-6-1-665
FOR EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER COOLED	NUCLEAR POWER REACTORS/ NEW ACCEPTANCE CRITERIA		15-2-4-173
REGULATION OF	NUCLEAR POWER REACTORS AND RELATED FACILITIES/		15-1-1-001
NERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED	NUCLEAR POWER REACTORS DURING 1972/	STEAM-GE	16-3-6-354
NERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED	NUCLEAR POWER REACTORS IN 1973/	STEAM GE	16-5-6-603
NERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED	NUCLEAR POWER REACTORS IN 1974/	STEAM GE	17-2-6-731
SAFETY AND SECURITY OF	NUCLEAR POWER REACTORS TO ACTS OF SABOTAGE/		17-6-1-645
CONTROLLING OCCUPATIONAL RADIATION EXPOSURE AT OPERATING	NUCLEAR POWER STATIONS/		18-4-5-492
RADIOACTIVE EFFLUENTS FROM	NUCLEAR POWER STATIONS IN EUROPE, 1970-1974/		18-3-6-370
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR	NUCLEAR POWER SYSTEMS/		12-3-3-217
TEEE	NUCLEAR POWER SYSTEMS SYMPOSIUM/		16-5-3-557
USE OF ACOUSTIC EMISSION TO DETECT INCIPENT FAILURE IN	NUCLEAR PRESSURE VESSELS/ A PROGRESS REPORT ON T		15-5-3-554
SAFETY RELATED OCCURRENCES IN	NUCLEAR REACTOR POWER PLANTS IN 1972/		15-1-6-067
CONSTRUCTION OF A SITE ASSEMBLED	NUCLEAR REACTOR PRESSURE VESSEL/		11-2-4-119
THE RUSSIAN APPROACH TO	NUCLEAR REACTOR SAFETY/		18-4-1-438
NERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED	NUCLEAR REACTORS/		13-2-1-099
TY INSURANCE - A BRIEF HISTORY REFLECTING THE SUCCESS OF	NUCLEAR REACTORS IN 1975/	STEAM GE	18-3-6-355
	SAFETY/	NUCLEAR LIABILI	12-4-1-291

ERENCE/	NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE	NUCLEAR SAFETY ASPECTS OF THE FOURTH GENEVA CONF	13-3-0-101
AR SAFETY ASPECTS OF THE FOURTH GENEVA CONFERENCE/		NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLE	13-3-0-101
R REACTOR PLANT/		NUCLEAR SAFETY AT SALZBURG/	10-6-1-756
STATION/		NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER	10-5-4-564
ING PLANTS/		NUCLEAR SAFETY EXPERIMENTS IN THE MARViken POWER	10-4-4-401
OCKY FLATS PLANT 11./		NUCLEAR SAFETY IN AMERICAN RADIOCHEMICAL PROCESS	12-3-4-234
ROCKY FLATS PLANT 1./		THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY R	15-6-4-723
		THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANYS	15-5-4-572
	THE UTILITY'S ROLE IN	NUCLEAR SAFETY RESEARCH AND DEVELOPMENT/	11-3-1-105
		AECS NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, AND S	15-2-1-127
CHEDULES/		NUCLEAR SAFETY 1975/	17-3-1-289
	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING -	NUCLEAR SCIENCE GROUPS - 1970/	12-6-3-310
	JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY	17-3-1-289
1975/		THE ANSI-NSM	15-4-1-415
	ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR	NUCLEAR STANDARDS PROGRAM/	14-3-1-101
	AMS STANDARD	NUCLEAR TECHNOLOGY/	11-1-5-039
N MONITORING & A GUIDE FOR MANAGEMENT 1/ U.S.A. STANDARD		NS13.2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES	15-3-3-292
	AMS STANDARD	NS18.8 ON DESIGN BASES FOR PROTECTIVE SYSTEMS/	15-2-1-127
	AECS NUCLEAR SAFETY RESEARCH	OBJECTIVES, PLANS, AND SCHEDULES/	12-2-2-95
	RESTRICTED RELEASE OF PLUTONIUM 1.	OBSERVATIONAL DATA/	14-2-3-095
ROL/		OBSTACLES TO COMPLETE AUTOMATION OF REACTOR CON	10-5-6-614
PLANTS/		OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER	10-4-5-492
LEAR POWER STATIONS/	CONTROLLING	OCCUPATIONAL RADIATION EXPOSURE AT OPERATING NUC	17-6-5-743
ILITIES, 1974/		OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FAC	10-4-6-523
ILITIES, 1975/		OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FAC	10-3-6-365
COOLED POWER REACTORS, 1969-1975/		OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER	11-5-6-622
974/		OCCURRENCES AT POWER REACTOR FACILITIES/	15-4-5-190
	SUMMARY OF RECENT ABNORMAL	OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1	12-2-6-23
972/	SAFETY RELATED	OCT. 5, 1966/	13-6-5-82
	FUEL MELTING INCIDENT AT THE FERMI REACTOR ON	OFFSHORE SITING OF NUCLEAR ENERGY STATIONS/	12-1-2-009
	THE EMERGING ROLE OF THE CAMPUS RADIATION SAFETY	OIL, AND NUCLEAR FUEL/	14-5-1-409
	HEALTH EFFECTS OF ELECTRICITY GENERATION FROM COAL,	ONOFFER EXPERIENCE WITH APPARENT POWER MISMATCH A	11-2-6-142
ND REACTOR COOLANT TEMPERATURE ANOMALIES/		OPERATING AND FUELING OF NUCLEAR POWER PLANTS/	15-1-6-79
	IAEA SYMPOSIUM ON EXPERIENCE FROM	OPERATING BOILING WATER REACTORS/	16-2-6-224
EVALUATION OF INCIDENTS OF PRIMARY COOLANT RELEASE FROM		OPERATING EXPERIENCE AT NUCLEAR POWER PLANTS/	10-5-6-666
	DIESEL GENERATOR	OPERATING EXPERIENCE WITH 13 LIGHT WATER REACTOR	10-4-5-492
S IN EUROPE/		OPERATING NUCLEAR POWER STATIONS/	14-5-5-482
	CONTROLLING OCCUPATIONAL RADIATION EXPOSURE AT	OPERATIONS/	16-4-5-482
OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL REPROCESSING		OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POW	12-5-2-448
EA PLANT SIMULATORS/		OPERATION TRAINING PROGRAMS UTILIZING NUCLEAR POW	12-4-2-305
EN/		OPPOSITION TO NUCLEAR POWER - AN INDUSTRY OVERVI	17-6-4-701
SK REDUCTION/	RISK MINIMIZATION BY	OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RI	10-3-5-329
DOWN COOLING TOWERS - CONSIDERATIONS IN THE EVOLUTION OF		OPTIMUM TOWER DESIGN/	12-6-5-600
IGN, AND OPERATION/	COLD SHOCK TO AQUATIC	ORGANISMS - GUIDANCE FOR POWER PLANT SITING, DES	14-6-5-651
S TOWARD PREDICTABILITY/	EFFECTS ON	ORGANISMS OF ENTRAPMENT IN COOLING WATER - STEP	11-2-3-115
COMMISSION/	THE	ORIGIN AND FINDINGS OF THE ATOMIC BOMB CASUALTY	11-4-6-323
	AUTOMATION OF REACTOR CONTROL AND SAFETY SYSTEMS AT	ORR EMERGENCY COOLING FAILURE/	12-5-2-456
		OUTCRY OVER EXPOSURE GUIDELINES/	15-4-6-455
MELTDOWN OF SCRAP URANIUM - ALUMINUM CERMET CORES DURING		OUTGASSING/	12-5-2-448
PUBLIC OPPOSITION TO NUCLEAR POWER - AN INDUSTRY		OVERVIEW/	17-6-5-722
IOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING SITES - AN		OVERVIEW/	16-1-5-60
ING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS 1. AEC		OWNED FACILITIES/	11-6-5-493
REPORT ON SEMINAR OF TRIGA		OWNERS/	14-5-2-446
OGEN - CALCULATION AND MEASUREMENT/		OZONE FORMATION BY THE RADIOLYSIS OF LIQUID HTR	14-4-1-274
RIALS/	THIRD INTERNATIONAL SYMPOSIUM ON THE	PACKAGING AND TRANSPORTATION OF RADIOACTIVE WATE	15-4-1-383
	THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD	PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER	16-1-1-1
PLANT SITES/	AEC WORKING	PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSI	15-6-5-732
RATION AND CONTAINMENT OF NOBLE GASES & A REVIEW OF NINE		PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOS	17-4-5-464
BIOLOGICAL EFFECTS OF NOBLE GASES & A REVIEW OF SELECTED		PARTICLE PROBLEM/	15-4-4-423
CURRENT STATUS OF THE PLUTONIUM HOT		PENETRATION TESTING FOR THE DETERMINATION OF PRO	15-3-1-262
PERTIES OF SOILS/		PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION	12-6-4-615
NO RELATED LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH		PERSONNEL/	17-1-6-92
SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY		PERSONNEL MONITORING/	16-6-5-728
SECUNO SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY		PERSPECTIVE - SOME COMPARISONS OF THE ENVIRONMEN	12-3-1-185
ROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/ RADIATION IN		PERSPECTIVE - THE PLIGHT OF THE DENIGN GIANT/	12-4-1-203
NUCLEAR POWER IN		PHENOMENA/	16-3-5-337
KINETICS EQUATION FOR LINEAR FIRST-ORDER NUCLEAR		PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MEL	18-1-4-60
TOOWN ACCIDENTS IN LIGHT WATER REACTORS/		PHENOMENOLOGICAL RESEARCH IN LHFBR ACCIDENT ANAL	14-4-2-304
YSIS/		PHILOSOPHY OF THE FAST FLUX TEST FACILITY/	14-2-1-079
	SAFETY ASSESSMENT	PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN	15-3-5-306
THE ATMOSPHERE/	IAEA-WMO SYMPOSIUM ON THE	PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR	10-5-1-542
SAFETY/	AMERICAN	PHYSICS/	18-4-2-451
INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED		PHYSICS ASPECTS OF NUCLEAR FACILITY SITING/	12-5-2-530
	SYMPOSIUM ON HEALTH	PHYSICS IN THE HEALING ARTS/	16-6-5-340
	SYMPOSIUM ON HEALTH	PHYSICS SOCIETY/	16-6-5-720
RES - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH		POPULATION EXPOSU	16-3-2-291
COOLED FAST BREEDER REACTOR FUEL SUBASSEMBLIES/		PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL C	17-6-6-475
		PIPE CRACKING IN BOILING WATER REACTORS/	13-2-4-122
		PIPE RUPTURE STUDY - 1971/	17-5-4-568
	RELIABILITY OF	PIPING IN LIGHT WATER REACTORS/	11-5-1-369
	THE WATER REACTOR SAFETY PROGRAM	PLAN/	17-1-1-1
		PLANNING FOR NUCLEAR EMERGENCIES/	14-6-1-563
ATE AND LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE		PLANNING IN THE STATE OF NEW JERSEY/	17-1-1-15
AECS NUCLEAR SAFETY RESEARCH OBJECTIVES,		PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES/ ST	15-2-1-127
INDUSTRIAL SUBTAGF IN NUCLEAR POWER		PLANTS, AND SCHEDULES/	11-2-1-107
NUCLEAR SAFETY IN AMERICAN RADIOCHEMICAL PROCESSING		PLANTS/	12-3-4-234
STANDBY EMERGENCY POWER SYSTEMS 1. THE EARLY PLANTS/		PLANTS/	14-3-3-206
PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS/		PLANTS/	14-4-1-267
MATERIALS PERFORMANCE AT NUCLEAR POWER		PLANTS/	14-5-6-507

VALVE MALFUNCTIONS IN NUCLEAR POWER PLANTS/	15-3-6-316
MODEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS/	15-6-1-451
QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER PLANTS/	16-2-1-127
STANDBY EMERGENCY POWER SYSTEMS. II. THE LATER PLANTS/	16-2-3-162
DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER PLANTS/	16-2-6-224
SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS/	16-5-4-581
OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER PLANTS/	16-5-6-614
TRENDS IN THE LICENSING OF NUCLEAR POWER PLANTS/	16-5-1-581
HAZARDOUS ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PLANTS/	PRO 15-3-2-276
LIMITING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER PLANTS/	SIMU 13-2-2-114
REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS/	THE 14-1-1-006
REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS/	THE 14-3-1-165
ANALYTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER PLANTS/	PROBA 15-4-2-399
BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS/	COST 17-5-1-525
SHIELD OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS/	AN ASSE 15-6-1-673
FEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS/	HUMAN ENGIN 14-1-3-021
TRUMENTATION SYSTEMS IN LIGHT WATER-COOLED POWER REACTOR PLANTS/	PROTECTION INS 11-3-3-206
POSITION ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER PLANTS/	FIFTH GERMAN SYM 11-6-2-463
AN EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS/	IAEA SYMPOSIUM O 16-1-6-79
ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/ RADIATION IN PERSPECTIVE - SOME COMPARIS	12-3-1-185
TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AEC STUDY ON THE ESTIMATION OF RISKS	15-4-1-375
EA POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION OF THE FWPCA AND RELATED	15-3-1-262
EA POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPCA ON NRC LICE	16-4-1-421
ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM/	12-1-3-025
OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS DURING 1973/	SUMMARY O 16-6-6-734
SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1972/	15-1-6-067
ACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972/	RELEASES OF RADIO 15-3-6-311
RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974/	16-1-6-79
NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE BENIGN GIANT/	12-4-1-283
RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONAL DATA/	12-1-3-015
RESTRICTED RELEASE OF PLUTONIUM II. THEORY/	12-2-2-05
CURRENT STATUS OF THE PLUTONIUM NOT PARTICLE PROBLEM/	12-3-2-203
CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTEREST/	17-4-5-444
CHARGERS THROUGH PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR	17-5-1-539
ASING JURISDICTION AND PROCEDURES/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR	15-3-1-262
BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILING SYSTEMS/	16-4-1-421
SITING PRACTICE AND ITS RELATION TO POPULATION/	16-1-2-29
AEC WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER PLANT SI	14-6-1-574
DO A.D./	16-1-1-1
L SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY/	15-1-5-056
PROCESSING PLANT/ ESTIMATES OF DOSE TO NORTHERN HEMISPHERE	15-4-5-453
ASSESSMENT/ TRENDS IN PUBLIC HEALTH IN THE	16-6-5-720
SENSITIVITY OF	13-2-5-130
PHENOMENOLOGICAL INVESTIGATION OF	16-5-5-647
POTENTIAL EFFECTS AND CONSEQUENCES IN	16-4-3-452
AEC STUDY ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM	16-1-4-60
NEUTRONIC ACCIDENTS IN HTGRS/	16-5-2-546
ANCE TECHNIQUES/ IDENTIFICATION OF	15-4-1-375
RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FUSION	16-5-2-546
A REVIEW OF SHORT TERM FISSION PRODUCT DECAY	17-3-5-344
E IAEA-AEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR	16-2-5-203
OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF FUSION	16-5-2-596
A HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC	TH 12-2-1-75
MISSION/ PUBLIC OPPOSITION TO NUCLEAR	PRELIMINARY 13-5-1-353
STATE RESPONSIBILITIES FOR NUCLEAR	ASSESSMENT OF 16-2-3-168
JOINT ANNUAL SYMPOSIUM OF IEEE	POWER - AN INDUSTRY OVERVIEW/ 12-5-2-448
QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR NUCLEAR	POWER - LAPP REPORT TO THE ILLINOIS COMMERCE COM 14-6-1-574
LOSS OF ELECTRIC	POWER AND NUCLEAR SCIENCE GROUPS - 1970/ 12-4-3-310
NUCLEAR	POWER APPLICATIONS/ 16-3-3-317
ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR	POWER COINCIDENT WITH LOCAL/ 16-1-3-53
POWER INSTRUMENTATION/ THE 16TH ANNUAL	POWER IN PERSPECTIVE - THE PLIGHT OF THE BENIGN 12-4-1-283
THE FOURTEENTH	POWER INSTRUMENTATION/ THE 16TH 15-4-3-417
SAN ONOFRE EXPERIENCE WITH APPARENT	POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR 15-4-3-417
QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR	POWER MISMATCH AND REACTOR COOLANT TEMPERATURE A 13-1-3-029
THE RELAP4 COMPUTER CODE I. APPLICATION TO NUCLEAR	POWER PLANT/ 11-2-6-142
EVALUATION OF NUCLEAR	POWER PLANT/ 17-1-6-87
U.S. NUCLEAR	SIL 16-6-3-714
IAEA INTERNATIONAL SYMPOSIUMS ON NUCLEAR	POWER PLANT ANALYSIS/ 17-2-2-194
EFFLUENT LIMITS ON CHLORINE/	POWER PLANT AVAILABILITY/ 15-5-6-599
BROWNS FERRY NUCLEAR	POWER PLANT AVAILABILITY AND CAPACITY STATISTICS 15-6-6-730
IN-SERVICE INSPECTION OF NUCLEAR	POWER PLANT CONTROL AND INSTRUMENTATION/ 15-1-3-015
THE DESIGN BASIS FOR NUCLEAR	POWER PLANT DISCHARGES - TOWARD MORE REASONABLE 16-6-5-802
SET-POINT DRIFT IN NUCLEAR	POWER PLANT FIRE ON MAR.22,1975/ 17-5-6-592
REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR	POWER PLANT PERFORMANCE ANALYSIS/ 16-5-6-664
AEC WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR	POWER PLANT PRESSURE COMPONENTS/ 17-6-6-733
INSTRUMENTATION PROGRAMS FOR NUCLEAR	POWER PLANT PROTECTION SYSTEMS/ 11-1-3-020
REVIEW OF ANS TOPICAL MEETING ON NUCLEAR	POWER PLANT SAFETY AND EARTHQUAKES/ 14-6-2-586
LEGAL AND INSTITUTIONAL PROBLEMS IN	POWER PLANT SAFETY RELATED INSTRUMENTATION/ 16-2-6-223
COLD SHOCK TO AQUATIC ORGANISMS - GUIDANCE FOR	POWER PLANT SIMULATORS/ 16-4-5-482
TORNADO RESISTANT DESIGN OF NUCLEAR	POWER PLANT SITES/ 16-1-1-1
INDUSTRIAL SABOTAGE IN NUCLEAR	POWER PLANT SITES/ 16-5-3-617
SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR	POWER PLANT SITING/ 16-3-1-273
THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR	POWER PLANT SITING/ 16-2-1-127
THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR	POWER PLANT SITING, DESIGN, AND OPERATION/ 16-3-5-329
PUBLIC HEALTH RISKS OF THERMAL	POWER PLANT STRUCTURES/ 11-4-2-296
MATERIALS PERFORMANCE AT NUCLEAR	POWER PLANT STRUCTURES/ 15-4-4-432
	11-2-1-107
	13-2-2-114
	14-1-1-006
	14-3-1-165
	14-4-1-267
	14-5-6-507

PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PLANTS/	15-3-2-276
VALVE MALFUNCTIONS IN NUCLEAR POWER PLANTS/	15-3-6-376
PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER PLANTS/	15-4-2-299
NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS/	15-6-1-651
QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER PLANTS/	16-2-1-127
DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER PLANTS/	16-2-6-224
SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS/	16-3-4-581
OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER PLANTS/	16-5-6-614
COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS/	17-5-1-525
TRENDS IN THE LICENSING OF NUCLEAR POWER PLANTS/	18-5-1-581
ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS/	15-6-1-673
ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS/	14-1-3-021
AN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER PLANTS/	11-6-2-463
SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS/	16-1-6-79
THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/	12-3-1-185
RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/	15-4-1-375
AL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS/	15-3-1-262
AL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS/	16-4-1-421
ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS/	12-1-3-025
NARY OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS DURING 1973/	16-6-6-734
SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1972/	15-1-6-067
RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972/	15-3-6-311
RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974/	18-1-6-79
SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER REACTOR FACILITIES/	15-2-6-198
PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER-COOLED POWER REACTOR PLANTS/	11-3-3-206
REPORT ON THE 1970 AHS CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENTS/	12-2-6-134
NS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WASTES/	11-2-5-130
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER REACTORS/	15-2-3-151
BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR POWER REACTORS/	15-6-1-665
N ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER REACTORS/	14-4-3-315
MOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS/	13-4-3-295
NERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER REACTORS/	13-6-2-459
POTENTIAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER REACTORS/	11-6-3-466
GENCY CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS/	15-2-4-173
THE 1970 CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS/	13-4-2-287
REGULATION OF NUCLEAR POWER REACTORS AND RELATED FACILITIES/	15-1-1-001
TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	16-3-6-354
TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	16-5-6-603
TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	17-2-6-231
SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF SABOTAGE/	17-6-1-665
OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975/	18-3-6-365
ON ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOURCE STRENGTH/	13-1-5-054
NUCLEAR SAFETY EXPERIMENTS IN THE MARVIKEN POWER STATION/	18-4-4-481
ING OCCUPATIONAL RADIATION EXPOSURE AT OPERATING NUCLEAR POWER STATIONS/	18-4-5-492
RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS IN EUROPE, 1970-1974/	18-3-6-370
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	12-3-3-217
STANDBY EMERGENCY POWER SYSTEMS I. THE EARLY PLANTS/	14-3-3-206
IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM/	16-5-3-557
STANDBY EMERGENCY POWER SYSTEMS, II. THE LATER PLANTS/	16-2-3-162
FINAL ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE HEARING/	15-4-5-440
STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE HEARING/	15-4-5-443
SITING PRACTICE AND ITS RELATION TO POPULATION/	14-6-1-576
QUALITY ASSURANCE STANDARDS AND PRACTICES/	12-6-1-549
SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS/	16-5-4-581
U.S.A. STANDARD N13.2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION MONITORING I A GUIDE FOR EFFECTS ON	11-1-5-039
ORGANISMS OF ENTRAPMENT IN COOLING WATER - STEPS TOWARD PREDICTABILITY/	12-6-5-600
S AT COASTAL LOCATIONS/	12-2-5-110
ON OF STATE FOR IRRADIATED NUCLEAR FUEL/	13-6-2-467
LICATIONS OF FUSION POWER/	13-5-1-353
AND CONTAINMENT OF NOBLE GASES I A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT L	15-3-4-302
CAL EFFECTS OF NOBLE GASES I A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT	15-6-5-732
IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PRESSURE COMPONENTS/	17-6-6-733
APID HEATING/	11-1-2-012
THE ICE CONDENSER SYSTEM FOR CONTAINMENT ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY R	17-6-4-710
REACTOR VESSEL PRESSURE SUPPRESSION/	18-4-6-513
CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR PRESSURE TRANSIENTS/	11-2-4-119
IMPROVING REACTOR PRESSURE VESSEL/	17-1-4-62
PROBABILITIES/	15-4-2-387
NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VESSEL FAILURE STATISTICS AND FAILURE P	17-3-4-327
FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEELS/	18-4-4-791
RELATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO LWR SAFETY/	17-1-4-55
THE SAFETY OF REACTOR PRESSURE VESSELS/	11-1-4-025
REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESSURE VESSELS/	15-5-3-554
ACUSTIC EMISSION TO DETECT INCIPIENT FAILURE IN NUCLEAR PRESSURE VESSELS/	13-6-4-478
EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION BED/	18-2-4-189
AND SYSTEMS/	16-4-2-291
NTS BY HYPOTHETICAL VESSEL RUPTURE/	11-3-4-223
ARCH ON THE USE OF CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER REACTOR LOSS OF COOLANT ACCIDE	11-1-4-025
ATER REACTORS/	15-1-6-076
EVALUATION OF INCIDENTS OF PRESSURIZED WATER REACTORS/	12-6-6-608
FAILURE OF N REACTOR PRIMARY COOLANT RELEASE FROM OPERATING BOILING W	16-3-1-282
NUCLEAR ENERGY CENTERS - A PRIMARY SCRAM SYSTEM/	15-3-2-276
CLEAR POWER PLANTS/	15-4-2-399
NUCLEAR POWER PLANTS/	15-4-2-387
PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES/	17-3-2-312
METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PROBABILITIES/	16-4-2-443
RE DEVELOPMENT OF REACTOR SITING CRITERIA BASED UPON RISK PROBABILITIES/	13-1-2-022
TORS - LOSS OF COOLANT ACCIDENTS/	14-1-2-014
RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL CYCLE/	14-6-2-597
TO TURBINE FAILURE/	14-3-2-187

INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS/	11-4-4-315
S AND TECHNIQUES FOR REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM NINE ATMOSPHERES/	14-6-5-643
A SURVEY OF HEAT CONDUCTION COMPUTER PROGRAMS/	12-6-2-569
TECHNOLOGICAL LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS/	15-3-1-262
INSTRUMENTATION FOR NUCLEAR POWER PLANT SITES/	18-5-3-617
S/ REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT SIMULATOR	16-4-5-482
BALANCING ENVIRONMENTAL IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE COURTS/	13-3-1-209
PLANTS/ FIFTH GERMAN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER P	11-6-2-463
DETECT INCIDENT FAILURE IN NUCLEAR PRESSURE VESSELS/ A PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION	15-5-3-554
ACTOR CORES/ FACTORS LIMITING PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST RE	14-3-2-201
REACTOR FUEL SUBASSEMBLIES/ PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL COOLED FAST BREEDER	16-3-2-291
URE VESSEL STEELS/ FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESS	18-6-4-791
CAL HEALTH/ RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF RADIOLOGI	15-2-5-185
R-COOLED POWER REACTOR PLANTS/ PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATE	11-3-3-236
SYMPOSIUM ON RADIOECLOGY APPLIED TO THE PROTECTION OF MAN AND HIS ENVIRONMENT/	13-5-5-380
FEDERAL REPUBLIC OF GERMANY/ THE DESIGN BASIS FOR NUCLEAR POWER PLANT	15-4-3-409
CRITERIA AND REQUIREMENTS FOR ROT PLANT PROTECTION SYSTEMS/	11-1-3-020
NCES/ GBR-4 PROTECTION SYSTEMS - FAILURES AND THEIR CONSEQUENCE	11-5-2-375
ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC POWER/	16-2-3-168
ANS STANDARD N18.8 ON DESIGN BASES FOR PROTECTIVE SYSTEMS/	15-3-3-292
AEC GOES PUBLIC - A CASE HISTORY/	11-5-1-365
PLANTS/ THE AEC STUDY ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER	15-4-1-375
ITIES/ ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACIL	17-6-1-659
RADIATION STANDARDS AND PUBLIC HEALTH/	12-1-1-001
ILITIES - A CRITICAL ASSESSMENT/ TRENDS IN PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS/	18-5-5-647
CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTEREST/	14-4-1-267
SOME EFFECTS OF PUBLIC INTERVENTION ON THE REACTOR LICENSING PRO	17-5-1-539
OVERVIEW/ PUBLIC OPPOSITION TO NUCLEAR POWER - AN INDUSTRY	13-1-1-013
ING/ ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY RAPID HEAT	12-5-2-440
GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT INTERIOR STRUCTURES/	11-1-2-012
A COMPUTER CODE III. LOCA ANALYSIS RESULTS OF A TYPICAL PWR PLANT/	13-5-4-373
NUCLEAR POWER APPLICATIONS/ THE RELAP	17-4-2-422
POWER PLANTS/ QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR N	18-3-3-317
WER PLANT/ QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR	16-2-1-127
QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR PO	17-1-6-87
QUALITY ASSURANCE STANDARDS AND PRACTICES/	12-6-1-549
QUALITY FORCED CONVECTION SYSTEMS/	18-2-2-154
QUALITY OF THE ENVIRONMENT/	18-2-5-215
QUALITY ASSURANCE PROGRAM FOR NUCLEAR REACTORS/	13-2-1-099
QUANTIFICATION OF MAN - MACHINE SYSTEM RELIABILITY	16-3-3-316
QUO/	17-1-3-43
QUO VADIS. PERSONNEL MONITORING/	16-6-5-728
RADIATION/	15-5-5-585
RADIATION ACCIDENTS/	12-6-5-338
RADIATION AND THERMAL POWER SOURCE STRENGTH/	13-1-5-054
RADIATION ASSESSMENT PROGRAM/	16-6-1-667
RADIATION DOSE AND EFFECTS/	11-6-4-475
RADIATION DOSES AND EFFECTS ESTIMATED FOR AQUATIC	17-3-5-351
RADIATION EFFECTS OF NUCLEAR FACILITIES IN NEW Y	16-2-5-204
RADIATION EXPOSURE AT NUCLEAR POWER PLANTS/	18-5-2-614
RADIATION EXPOSURE AT OPERATING NUCLEAR POWER ST	18-4-5-492
RADIATION EXPOSURE BE RECORDED OR RADIATION MON	14-3-5-220
RADIATION EXPOSURES AT LICENSED FACILITIES, 1974	17-6-6-743
RADIATION EXPOSURES AT LICENSED FACILITIES, 1975	18-4-6-523
RADIATION EXPOSURES AT LIGHT WATER COOLED POWER	18-3-6-365
RADIATION EXPOSURES AT LWRs, 1969-1974/	17-5-6-622
RADIATION IN PERSPECTIVE - SOME COMPARISONS OF ?	12-3-1-185
RADIATION IN THE UNITED STATES/	17-4-5-471
RADIATION IN THE URBAN ENVIRONMENT/	13-4-1-275
RADIATION MONITORING (A GUIDE FOR MANAGEMENT) /	11-1-5-031
RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF	15-2-5-185
RADIATION SAFETY OFFICER/	13-6-5-482
RADIATION STANDARDS AND PUBLIC HEALTH/	12-1-1-001
RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF R	11-3-6-237
RADIATION WORKERS/	14-3-5-220
RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL REPROCE	16-5-1-482
RADIOACTIVE CONTAMINANTS IN THE ATMOSPHERE/	15-3-5-306
RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATION	18-3-6-370
RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER	18-1-6-79
RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FU	14-6-2-597
RADIOACTIVE MATERIALS/	14-4-1-274
RADIOACTIVE MATERIALS/ THE IMPACT OF THE PROPOSE	13-2-1-103
RADIOACTIVE MATERIALS IN THE UNITED STATES/	18-3-1-291
RADIOACTIVE POWER REACTOR WASTES/	11-2-5-170
RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILIT	17-3-5-351
RADIOACTIVE WASTE/	16-2-4-180
RADIOACTIVE WASTE DISPOSAL BY HYDRAULIC FRACTURE	11-5-6-391
RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLA	16-5-4-581
RADIOACTIVITY IN EFFLUENTS I. AEC OWNED FACILIT	16-1-5-40
RADIOACTIVITY IN EFFLUENTS II. AEC LICENSED FAC	16-1-5-71
RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM	15-3-6-311
RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR	18-4-6-734
RADIOCHEMICAL PROCESSING PLANTS/	12-3-4-234
RADIOECLOGY APPLIED TO THE PROTECTION OF MAN AN	13-5-5-380
RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FISSION	18-2-5-203
RADIOLOGICAL ASPECTS OF ENVIRONMENTAL TRITIUM/	17-2-5-216
RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING	17-6-5-722
RADIOLOGICAL ASSISTANCE PROGRAM/	16-3-5-345
RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT	17-1-1-15
RADIOLOGICAL HEALTH/	15-2-5-185
RADIOLOGICAL IMPLICATIONS OF FISSION POWER/	13-5-1-353
RADIOLOGICAL QUALITY OF THE ENVIRONMENT/	18-2-5-215

MEASUREMENT/	CZONE FORMATION BY THE	RADIOLYSIS OF LIQUID NITROGEN - CALCULATION AND	14-5-2-446
LANT ACCIDENTS IN WATER COOLED POWER REACTORS/		RADIOLOGIC HYDROGEN GENERATION AFTER LOSS OF COO	13-6-2-459
QUID METAL COOLED FAST BREEDER REACTORS I. PRODUCTION/		RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF	16-1-4-43
LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPORT/		RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF	16-3-4-318
	SYMPOSIUM ON MEDICAL	RADIONUCLIDES - RADIATION DOSE AND EFFECTS/	11-6-4-475
	TURNOVER AND CONCENTRATION OF	RADIONUCLIDES IN FOOD CHAINS/	11-1-5-043
	COMPUTER CODES FOR THE ASSESSMENT OF	RADIONUCLIDES RELEASED TO THE ENVIRONMENT/	16-3-5-343
ACTIVE WASTE/		RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIO	16-2-4-180
SPHERES/	PROBLEMS AND TECHNIQUES FOR REMOVAL OF	RADON AND RADON DAUGHTER PRODUCTS FROM MINE ATMO	14-6-5-643
INGS MASQUERADES AS IODINE-131 RELEASE/		RADON CONCENTRATION IN REACTOR CONTAINMENT BUILD	11-3-6-235
	PROBLEMS AND TECHNIQUES FOR REMOVAL OF RADON AND	RADON DAUGHTER PRODUCTS FROM MINE ATMOSPHERES/	14-6-5-643
ALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY		RAPID HEATING/	11-1-2-012
	SAFETY EXPERIENCE GAINED FROM	RAPSODIE OPERATION/	14-1-6-027
	CRITERIA AND REQUIREMENTS FOR	ROT PLANT PROTECTION SYSTEMS/	11-5-2-375
ING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER		REACTORS I. PRODUCTION/ RADIONUCLIDE BEHAVIOR	16-1-4-43
CTORS/	A METHOD FOR VERIFYING	REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REA	13-4-3-295
CTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON		REACTIVITY EFFECTS IN LARGE POWER REACTORS/ SPAC	13-4-2-287
	INCIDENT AT THE LUCENS	REACTOR/	16-1-6-76
	SAFETY INSTRUMENTATION FOR THE SODIUM COOLED FAST	REACTOR/	16-6-3-701
	OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH	REACTOR/	17-4-3-437
	FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER	REACTOR ACCIDENTS/	12-5-3-487
ARCINOMA - A COMPARISON OF THE LATE MORTALITY RISKS FROM		REACTOR ACCIDENTS/	11-6-4-482
CONTINUITY OF SERVICE/		REACTOR AVAILABILITY AND STATION RELIABILITY FOR	12-5-4-499
SSION PRODUCT REMOVAL/		REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR F	11-5-5-516
INE-131 RELEASE/		REACTOR CONTAINMENT BUILDINGS MASQUERADES AS IOD	11-3-6-235
	RADON CONCENTRATION IN	REACTOR CONTAINMENT STRUCTURES AND SYSTEMS/	19-2-4-189
	TRENDS IN THE DESIGN OF PRESSURIZED WATER	REACTOR CONTAINMENT SYSTEM/	11-3-4-215
	THE ICE CONDENSER	REACTOR CONTAINMENTS/	15-4-3-702
Y OF APPLIED INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER		REACTOR CONTROL/	14-2-3-055
	OBSTACLES TO COMPLETE AUTOMATION OF	REACTOR CONTROL AND SAFETY SYSTEMS AT OPNL/	11-2-3-115
	AUTOMATION OF	REACTOR COOLANT TEMPERATURE ANOMALIES/	11-2-6-142
SAN ONOPRE EXPERIENCE WITH APPARENT POWER MISMATCH AND		REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS/	11-3-2-195
STUDIES OF FAST		REACTOR CORES/	14-3-2-201
S LIMITING PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST		REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CO	13-4-2-287
REACTIVITY EFFECTS IN LARGE POWER REACTORS/ SPACE - TIME		REACTOR FACILITIES/	15-2-6-198
SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER		REACTOR FUEL/	11-3-6-237
RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF RESEARCH		REACTOR FUEL SUBASSEMBLIES/	16-3-2-291
FAILURE PROPAGATION IN LIQUID METAL COOLED FAST BREEDER		REACTOR FUELS/	14-4-6-356
	DENSIFICATION OF	REACTOR FUELS I. BASIC STUDIES/	12-4-2-297
	FISSION GAS EFFECTS IN	REACTOR FUELS II. ENGINEERING APPLICATIONS/	12-6-2-562
	THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND	REACTOR INDUSTRIES/	17-3-6-363
	RECENT DEVELOPMENTS IN FAST	REACTOR KINETICS/	11-4-2-289
	SOME EFFECTS OF PUBLIC INTERVENTION ON THE	REACTOR LICENSING PROCESS/	13-1-1-013
E OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE		REACTOR LICENSING PROCESS/	13-1-1-001
	THE REACTOR	REACTOR LICENSING PROCESS - A STATUS REPORT/	18-3-1-281
L VESSEL RUPTURE/		REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICA	14-4-2-291
	PRESSURIZED WATER	REACTOR NOISE/	16-3-3-308
	THE 1974 SPECIALISTS MEETING ON	REACTOR ON OCT. 5, 1966/	12-2-6-123
	FUEL MELTING INCIDENT AT THE FERRI	REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUC	16-4-5-482
LEAR POWER PLANT SIMULATORS/		REACTOR PLANT/	16-5-4-564
NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER		REACTOR PLANTS/	11-3-3-206
TIUM INSTRUMENTATION SYSTEMS IN LIGHT WATER-COOLED POWER		REACTOR POWER PLANTS IN 1972/	15-1-6-067
SAFETY RELATED OCCURRENCES IN NUCLEAR		REACTOR PRESSURE VESSEL/	11-2-4-119
CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR		REACTOR PRESSURE VESSEL AVAILABILITY BY DESIGN/	17-1-4-62
	IMPROVING	REACTOR PRESSURE VESSEL STEELS/	17-3-4-327
NEUTRON IRRADIATION EMBRITTLEMENT OF		REACTOR PRESSURE VESSELS/	11-1-4-025
A REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE		REACTOR PRESSURE VESSELS/	17-1-4-55
	THE SAFETY OF	REACTOR PRIMARY SCRAM SYSTEM/	12-6-6-608
	FAILURE OF N	REACTOR SAFEGUARDS IN THE REACTOR LICENSING PROC	13-1-1-001
ESS/		REACTOR SAFETY/	12-3-1-196
	THE ROLE OF THE ADVISORY COMMITTEE ON	REACTOR SAFETY/	12-5-1-433
	CREST SUMMARY - WATER-COOLED	REACTOR SAFETY/	13-6-1-451
	LIGHT WATER	REACTOR SAFETY/	14-5-1-428
	ISPRAS CONTRIBUTION TO	REACTOR SAFETY/	14-5-1-439
INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF		REACTOR SAFETY/	15-2-1-132
ANS NATIONAL TOPICAL MEETING ON WATER		REACTOR SAFETY/	16-2-1-141
AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON		REACTOR SAFETY/	16-5-1-112
1974 ANS TOPICAL MEETING ON FAST		REACTOR SAFETY/	18-4-1-438
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER		REACTOR SAFETY/	17-6-3-686
THE RUSSIAN APPROACH TO NUCLEAR		REACTOR SAFETY AND RELATED PHYSICS/	18-4-2-451
DOE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO		REACTOR SAFETY PROGRAM/	11-1-1-001
1976 INTERNATIONAL MEETING ON FAST		REACTOR SAFETY PROGRAM/	16-6-1-659
THE LIQUID METAL FAST BREEDER		REACTOR SAFETY PROGRAM PLAN/	11-5-1-369
	EPRI WATER	REACTOR SAFETY RESEARCH/	18-5-1-589
	THE WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	15-7-1-741
NRC INTERNATIONAL AGREEMENTS ON		REACTOR SAFETY RESEARCH INFORMATION MEETING/	16-1-1-7
	WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	17-2-1-143
	WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-2-1-133
	FOURTH WATER	REACTOR SAFETY RESEARCH PROGRAM/	19-1-1-1
	NRC WATER	REACTOR SAFETY RESEARCH PROGRAM/	19-6-1-727
GERMAN LIGHT WATER		REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS	11-6-2-450
EQUATION OF STATE FOR FAST		REACTOR SAFETY SYSTEMS/	14-6-3-605
COMPARATIVE RELIABILITY ANALYSES OF		REACTOR SAFETY SYSTEMS/	18-5-3-624
COMMON-MODE FAILURES IN		REACTOR SAFETY TECHNOLOGY/	12-5-4-696
RELIABILITY ENGINEERING METHODS IN		REACTOR SAFETY-1970/	12-2-1-83
AN APPRECIATION OF FAST		REACTOR SITING/	16-3-1-282
NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN		REACTOR SITING CRITERIA BASED UPON RISK PROBABIL	13-1-2-022
THE DEVELOPMENT OF		REACTOR SYSTEMS/	15-2-3-154
SAFETY ASSESSMENT OF		REACTOR SYSTEMS AND COMPONENTS/	12-2-6-134
REPORT ON THE 1970 ANS CONFERENCE ON POWER		REACTOR VESSEL PRESSURE TRANSIENTS/	18-4-6-513
SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE POWER		REACTOR WASTES/	11-2-5-130
THE ASME CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR		REACTORS/	13-2-1-099

BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR POWER REACTORS/	15-6-1-665
PIPE CRACKING IN BOILING WATER REACTORS/	17-4-5-475
RELIABILITY OF PIPING IN LIGHT WATER REACTORS/	17-5-4-568
EQUIPMENT CELL LINES FOR LIQUID METAL COOLED FAST BREEDER REACTORS/	17-2-4-208
UNEXPECTED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER REACTORS/	15-2-3-151
ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER REACTORS/	14-4-7-315
PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED REACTORS/	12-2-2-97
A VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS/	13-4-3-295
SPECTATION TECHNIQUES FOR LIQUID METAL COOLED FAST BREEDER REACTORS/	18-4-3-467
OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER REACTORS/	13-1-4-037
IDENTIFICATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS/	18-1-4-60
CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER REACTORS/	11-3-4-223
OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS/	15-1-6-076
ON AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER REACTORS/	13-6-2-459
ICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER REACTORS/	11-6-3-468
CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS/	15-2-4-173
TO CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS/	13-4-2-207
ING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPORT/ RADIOISOTOPE BEHAVIOR D	16-3-4-318
PROBABILITY ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF COOLANT ACCIDENTS/	14-1-2-014
REGULATION OF NUCLEAR POWER REACTORS AND RELATED FACILITIES/	15-1-1-001
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	16-3-6-354
OPERATING EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE/	18-5-6-666
SAFETY ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE UNITED KINGDOM/	11-4-1-283
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	16-5-6-603
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	17-2-6-231
TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR REACTORS IN 1975/	18-3-6-355
SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF SABOTAGE/	17-6-1-665
NATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975/	18-3-6-365
POWER PLANT DISCHARGES - TOWARD MORE REASONABLE EFFICIENT LIMITS ON CHLORINE/	18-6-5-802
SHOULD MEDICAL RADIATION EXPOSURE BE RECORDED FOR RADIATION WORKERS/	14-3-5-220
ORATORY/ REFLECTIONS ON THE REACTIVITY CONFERENCE AT ARGONNE NATIONAL LAB	18-1-2-45
ON BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUCTION/	12-4-2-305
COMMON-MODE FAILURE MECHANISMS IN NUCLEAR LIABILITY INSURANCE - A BRIEF HISTORY	17-6-3-886
REFLECTING THE SUCCESS OF NUCLEAR SAFETY/	12-4-1-291
REFLECTIONS ON THE REACTIVITY CONFERENCE AT A REGULATION OF NUCLEAR POWER REACTORS AND RELATED	18-1-2-45
THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLE	14-1-1-006
THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLE	14-3-1-165
REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIV	13-2-1-103
REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE M	15-5-5-443
THE RELAP4 COMPUTER CODE III. LOCA ANALYSIS RESULTS	17-4-2-422
THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR	17-2-2-194
THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF T	17-3-2-299
REACTOR CONTAINMENT BUILDINGS MASQUERADES AS IODINE-131	11-3-6-235
ATMOSPHERIC RELEASE ADVISORY CAPABILITY/	17-3-1-281
EVALUATION OF INCIDENTS OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS/	15-1-6-076
RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONAL DATA/	12-2-2-85
RESTRICTED RELEASE OF PLUTONIUM II. THEORY/	12-3-2-203
CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE ENVIRONMENT FROM AN LMF	14-4-5-325
THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	16-5-5-593
THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	17-5-5-580
RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974/	18-1-6-79
SUMMARY OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS	16-6-6-734
COMPUTER CODES FOR THE ASSESSMENT OF RADIOISOTOPES RELEASED TO THE ENVIRONMENT/	18-3-5-343
CONTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER R	13-1-4-037
FACTS ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILITIES/ RADIATI	17-3-5-351
WASTE FROM NUCLEAR POWER PLANTS IN 1972/	15-3-6-311
RS/ RELIABILITY OF PIPING IN LIGHT WATER REACTO	17-5-4-568
COMPARATIVE RELIABILITY ANALYSES OF REACTOR SAFETY SYSTEMS/	14-6-3-605
HUMAN RELIABILITY ANALYSIS/	17-3-3-315
MISSOURI UNIVERSITY RESEARCH REACTOR/ RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE	17-4-3-427
V TECHNOLOGY/ RELIABILITY ENGINEERING METHODS IN REACTOR SAFET	12-5-4-495
REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINUITY OF SERVICE/	12-5-4-499
QUANTIFICATION OF MAN - MACHINE SYSTEM RELIABILITY IN PROCESS CONTROL/	16-3-3-316
THE THIRD RELIABILITY MEETING AT RISQ/	11-4-3-309
OWNED FACILITIES/ THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS I. AEC	16-1-5-60
LICENSED FACILITIES/ THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. AEC	16-1-5-71
MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL REPROCESSING OPERATIONS/	14-5-5-462
ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	16-5-5-593
ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	17-5-5-580
GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATES OF DOSE TO NORTHER	13-2-2-130
PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE FEDERAL REPUBLIC OF GERMANY/	15-1-3-409
ES/ EARTHQUAKE RESISTANT DESIGN OF NUCLEAR POWER PLANT STRUCTURE	17-1-1-001
RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUCTION/	15-4-4-037
A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS/	17-4-2-305
ITIES/ STATE AND LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACIL	17-1-1-15
TO THE ILLINOIS COMMERCE COMMISSION/ RESPONSIBILITIES FOR NUCLEAR POWER - LAPP REPORT	14-6-1-574
L DATA/ RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONAL	12-2-2-85
RESTRICTED RELEASE OF PLUTONIUM II. THEORY/	12-3-2-203
NUCLEAR LIABILITY INSURANCE - A RESUME OF RECENT YEARS/	16-5-1-537
PLUME RISE - A RECENT CRITICAL REVIEW/	12-1-3-015
TUMBULENT DIFFUSION TYPING SCHEMES - A REVIEW/	17-1-5-68
LANT SITING/ REVIEW OF THIS TOPICAL MEETING ON NUCLEAR POWER	16-3-1-273
NUCLEAR POWER SYSTEMS/ REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR	12-3-3-217
NG THE, AS LOW AS PRACTICABLE HEARING/ REVIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNI	15-4-5-440
S VEGAS II SEPARATION AND CONTAINMENT OF NOBLE GASES I A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NUCL	15-3-4-102
IN AT LAS VEGAS II BIOLOGICAL EFFECTS OF NOBLE GASES I A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973	15-6-5-732
/ REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER	15-7-2-596
TH GENEVA CONFERENCE/ NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOUR	17-1-4-161
REACTOR PRESSURE VESSELS/ A REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE	11-1-4-015
LARGE POWER REACTORS/ SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON REACTIVIT	13-4-2-297

ORT OF RADIOACTIVE MATERIALS/ THE IMPACT OF THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE SAFE TRANS	13-2-1-103
TS/	12-1-3-015
ES OF ELECTRICAL ENERGY/	17-5-1-525
PROBABILISTIC ASSESSMENT OF AIRCRAFT	17-2-1-171
RESOURCES AVAILABLE FOR RISK REDUCTION/	15-3-2-276
THE DEVELOPMENT OF REACTOR SITING CRITERIA BASED UPON	12-2-2-305
IZATION BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR	13-1-2-022
N IN PERSPECTIVE - SOME COMPARISONS OF THE ENVIRONMENTAL	12-4-2-305
D THYROID CARCINOMA - A COMPARISON OF THE LATE MORTALITY	12-1-1-185
AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS/	11-6-4-482
PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS/	13-6-1-673
RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN	14-4-1-267
THE THIRD RELIABILITY MEETING AT	15-4-1-375
NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER REACTOR PLANT/	11-4-3-309
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FLATS PLANT I./	16-5-4-564
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FLATS PLANT II./	15-5-4-572
MINATION AFTER FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE	15-6-4-723
ON ACCIDENTS/	14-4-5-362
S/	12-5-3-487
AN ANALYSIS OF CONTROL	14-4-3-315
HUMAN FACTORS IN THE NUCLEAR CONTROL ROOM/	18-6-3-774
AN POWER PLANT/	16-6-3-714
SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLE	15-1-4-030
THE ECCS RULE-MAKING HEARING/	14-4-2-291
REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE/	13-6-4-478
D/	13-2-4-122
EFFECT OF RUPTURE IN A PRESSURIZED GASEOUS GAS ADSORPTION BE	18-4-1-438
PIPE RUPTURE STUDY - 1971/	17-6-1-565
THE RUSSIAN APPROACH TO NUCLEAR REACTOR SAFETY/	11-2-1-107
SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF	12-3-3-226
INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS/	13-2-1-103
E USE OF ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL	15-5-1-513
CT OF THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE	13-1-1-001
LEAR MATERIALS/	11-6-1-445
THE ROLE OF THE ADVISORY COMMITTEE ON REACTOR	12-3-1-196
A SYSTEMS APPROACH TO NUCLEAR PLANT SAFETY/	12-5-1-421
CREST SUPPLY - WATER-COOLED REACTOR SAFETY/	12-5-1-433
LMFBR SAFETY/	12-5-1-438
LIGHT WATER REACTOR SAFETY/	13-6-1-451
HTGR SAFETY/	14-5-1-439
ISPRAS CONTRIBUTION TO REACTOR SAFETY/	15-2-1-132
ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/	16-2-1-141
AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON REACTOR SAFETY/	16-5-1-542
1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	18-3-3-322
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR SAFETY/	13-4-1-438
EMP AND NUCLEAR PLANT SAFETY/	14-5-1-428
THE RUSSIAN APPROACH TO NUCLEAR REACTOR SAFETY/	17-4-4-447
INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF REACTOR	17-6-3-686
ATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO LWR	12-4-1-291
URE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO REACTOR	11-5-3-379
ANCE - A BRIEF HISTORY REFLECTING THE SUCCESS OF NUCLEAR	15-3-4-297
NKS CONTAINING A FIXED NEUTRON ABSORBER/	14-6-2-586
THE SAFETY AND CONTROL OF URANIUM-235 SOLUTION IN TA	15-4-1-383
POWER PLANT SAFETY AND EARTHQUAKES/	18-4-2-451
THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL/	17-6-1-665
1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSICS/	13-3-0-111
ACTS OF SABOTAGE/	15-5-1-514
NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLEAR	11-6-1-283
UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND	15-2-3-154
IN THE UNITED KINGDOM/	14-2-1-079
ST FACILITY/	13-3-0-181
Y ASPECTS OF THE FOURTH GENEVA CONFERENCE/	18-6-1-756
NUCLEAR SAFETY AT SALZBURG/	11-6-1-435
ELEVATOR CENTER/	14-6-4-618
PEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACC	16-5-4-564
NUCLEAR SAFETY DESIGN BASES OF THE HTGR/	17-6-1-693
R PLANT/	11-6-2-463
ER SOFTWARE/	14-1-0-027
FIFTH GERMAN SYMPOSIUM ON PROGRESS IN	13-4-4-481
SAFETY EVALUATION EXPERIENCE WITH DIGITAL COMPUT	12-3-4-234
/	16-6-3-701
NUCLEAR SAFETY EXPERIMENTATION FOR THE SODIUM COOLED FAS	17-1-4-55
TS/	17-3-6-363
T REACTOR/	13-6-5-482
THE SAFETY OF REACTOR PRESSURE VESSELS/	11-1-1-001
R INDUSTRIES/	16-6-1-659
THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTO	15-6-4-723
THE EMERGING ROLE OF THE CAMPUS RADIATION SAFETY OFFICER/	15-5-4-572
THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM/	11-5-1-369
EPRI WATER REACTOR SAFETY PROGRAM/	16-2-6-223
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FLA	15-1-6-067
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY FL	18-3-3-317
THE WATER REACTOR SAFETY PROGRAM PLAN/	18-5-1-589
SET-POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RELATED INSTRUMENTATION/	11-3-1-185
WER PLANTS IN 1972/	15-3-1-241
ICATIONS/	16-1-1-8
QUALIFICATION OF SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR PO	17-2-1-143
MRC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEARCH/	18-2-1-133
THE UTILITY'S ROLE IN NUCLEAR SAFETY RESEARCH AND DEVELOPMENT/	15-2-1-127
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-1-1-1
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-6-1-727
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	11-6-2-450
FOURTH WATER REACTOR SAFETY RESEARCH OBJECTIVES, PLANS, AND SCHEDULES	
AEC'S NUCLEAR SAFETY RESEARCH PROGRAM/	
NRC WATER REACTOR SAFETY RESEARCH PROGRAM/	
GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM/	
EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS/	

COMPARATIVE RELIABILITY ANALYSES OF REACTOR SAFETY SYSTEMS/	14-6-3-005
COMMON-MODE FAILURES IN REACTOR SAFETY SYSTEMS/	10-5-3-624
AUTOMATION OF REACTOR CONTROL AND SAFETY SYSTEMS AT ORNL/	11-2-3-115
RELIABILITY ENGINEERING METHODS IN REACTOR SAFETY TECHNOLOGY/	12-5-4-496
AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	17-3-1-289
AN APPRECIATION OF FAST REACTOR SAFETY-1970/	12-2-1-83
VE POWER REACTOR WASTES/ STATUS OF INVESTIGATIONS OF NUCLEAR SAFETY AT SALZBURG/	11-2-5-130
CH AND REACTOR COOLANT TEMPERATURE ANOMALIES/ SAN ONOFRE EXPERIENCE WITH APPARENT POWER MISMATCH SCHEDULES/	10-6-1-756
AEC'S NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, AND TURBULENT DIFFUSION TYPING SCHEMES - A REVIEW/	11-2-6-142
JOINT ANNUAL SYMPOSIUM OF THE POWER AND NUCLEAR SCIENCE GROUPS - 1970/	15-2-1-127
ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS JUD/	17-1-5-68
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER REACTORS/	12-4-3-310
FAILURE OF A REACTOR PRIMARY SCRAM SYSTEM/	17-1-3-43
RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH SCRAP URANIUM - ALUMINUM CERMET CORES DURING OUT SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTA SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF SA SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASS SEMINAR OF TRIGA OWNERS/	15-2-3-151
REPORT ON SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY INSTRUMENTATION TO ACTS OF SA	12-6-6-000
ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING/	17-4-3-437
LATE INSTRUMENTATION/	15-4-6-455
PLANT SITING, DESIGN, AND OPERATION/	12-2-5-110
RADIATION WORKERS/	17-6-1-665
EVOLUTION OF OPTIMUM TOWER DESIGN/	15-6-5-132
FFS NUCLEAR POWER PLANT/	11-6-5-493
NUCLEAR POWER PLANTS/	16-4-3-452
OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT SIMULATORS/	15-3-4-302
EMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATE SITE ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL/	15-3-2-285
INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT SITES/	12-5-4-499
U. S. PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER PLANT SITES - AN OVERVIEW/	10-2-6-223
SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITES/	14-6-2-597
REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITES/	10-3-5-329
NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITES/	14-3-5-220
LEGAL AND INSTITUTIONAL PROBLEMS IN POWER PLANT SITES/	17-6-4-71
UNDERGROUND NUCLEAR PLANT SITES/	16-6-3-714
THE DEVELOPMENT OF REACTOR SITES/	13-2-2-114
ECOLOGICAL CONSIDERATIONS IN OFFSHORE REACTOR SITES/	16-6-5-482
NOVEL SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPACES/	13-2-5-130
HUMAN ENGINEERING - AIDS TO REACTOR SAFETY/	11-2-4-119
EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY OF AMERICA/	17-4-1-411
TEENTH POWER INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENTATION SOCIETY OF AMERICA/	10-5-3-617
AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	16-1-1-1
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR SAFETY/	17-6-5-722
LMFR SAFETY 1. FISSION PRODUCT BEHAVIOR IN THE FOUR REACTORS/	12-5-6-530
THE RELATIVE TO THE BREAKUP OF MULTIPLE URANIUM DIOXIDE IN THE REACTORS/	16-3-1-273
SAFETY INSTRUMENTATION FOR THE REACTORS/	16-3-1-282
CONSEQUENCES OF AN ACCIDENTAL RELEASE OF REACTOR SAFETY ASSESSMENT OF FAST REACTORS/	10-2-1-127
SAFETY EVALUATION EXPERIENCE WITH DIGITAL COMPUTER MONITORING FOR THE DETERMINATION OF PROPERTIES OF REACTOR WASTES/	15-3-1-519
EM PLANTS/	13-1-2-022
ORREA/	12-1-3-025
DECONTAMINATION AFTER FAILURE OF AN ANTIMONY - BERYLLIUM REACTOR/	12-1-2-009
ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER DATA FOR LOCAL CODE VERIFICATION/	14-6-1-576
COMPARATIVE RISK - COST - BENEFIT STUDY OF ALTERNATIVE REACTOR CONTAINMENT BUILDING RESEARCH ON THE USE OF CONTAINMENT BUILDING FUEL MELTDOWN AT TALL STACKS AT COASTAL LOCATIONS/	15-6-1-651
ELU MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND REACTOR CONTAINMENT BUILDING RESEARCH ON THE USE OF CONTAINMENT BUILDING FUEL MELTDOWN AT TALL STACKS AT COASTAL LOCATIONS/	10-3-5-329
CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE AS LOW AS PRACTICABLE HEARING/	17-4-4-447
RADIATION MONITORING AND A GUIDE FOR MANAGEMENT 1/ U.S.A. STANDARDS AND PRACTICES/	14-6-4-634
STANDARDS AND PRACTICES/	10-2-6-223
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	14-5-3-461
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	16-6-5-720
QUALITY ASSURANCE STANDARDS AND PRACTICES/	13-1-3-029
RADIATION STANDARDS AND PRACTICES/	17-3-1-289
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	16-5-1-542
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	11-5-3-379
QUALITY ASSURANCE STANDARDS AND PRACTICES/	10-6-2-683
RADIATION STANDARDS AND PRACTICES/	15-2-2-144
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	16-3-3-701
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	13-1-4-037
QUALITY ASSURANCE STANDARDS AND PRACTICES/	14-6-5-325
RADIATION STANDARDS AND PRACTICES/	11-4-1-283
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	17-6-3-693
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	15-4-4-423
QUALITY ASSURANCE STANDARDS AND PRACTICES/	16-2-4-180
RADIATION STANDARDS AND PRACTICES/	16-5-4-581
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	15-3-6-311
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	15-3-4-295
QUALITY ASSURANCE STANDARDS AND PRACTICES/	15-6-1-651
RADIATION STANDARDS AND PRACTICES/	14-6-4-362
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	13-1-5-054
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	17-2-1-171
QUALITY ASSURANCE STANDARDS AND PRACTICES/	13-4-2-287
RADIATION STANDARDS AND PRACTICES/	14-6-4-634
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	16-3-3-308
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	17-2-5-223
QUALITY ASSURANCE STANDARDS AND PRACTICES/	12-5-5-516
RADIATION STANDARDS AND PRACTICES/	11-3-4-223
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	12-1-4-035
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	12-2-5-110
QUALITY ASSURANCE STANDARDS AND PRACTICES/	15-4-5-443
RADIATION STANDARDS AND PRACTICES/	11-1-5-039
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	15-3-3-292
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	12-6-1-549
QUALITY ASSURANCE STANDARDS AND PRACTICES/	12-1-1-001
RADIATION STANDARDS AND PRACTICES/	14-3-1-181
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	12-3-3-211
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/	17-3-1-289

INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF REACTOR SAFETY/	14-5-1-420
THE ANST-NSRB NUCLEAR STANDARDS PROGRAM/	16-4-1-415
ANTS/	14-3-3-206
PLANTS/	16-2-3-162
BEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACCELERATOR CENTER/	11-6-1-435
REVIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE	15-4-5-440
CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS	15-4-5-443
LOW AS PRACTICABLE HEARING/	11-6-3-691
COMPUTER CONTROL AT BRUCE NUCLEAR GENERATING STATION/	18-4-4-481
NUCLEAR SAFETY EXPERIMENTS IN THE MARVIAEN POWER STATION/	12-5-4-499
REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINUITY OF SERVICE/	12-1-2-009
OFFSHORE SITING OF NUCLEAR ENERGY STATIONS/	18-4-5-492
CUPATIONAL RADIATION EXPOSURE AT OPERATING NUCLEAR POWER STATIONS/	16-3-6-370
RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS IN EUROPE, 1970-1974/	15-4-2-387
PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES/	15-6-6-730
U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973/	11-2-5-130
DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WASTES/	15-2-4-163
EVOLUTION AND CURRENT STATUS OF THE BWR CONTAINMENT SYSTEM/	12-5-5-523
FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PRO	17-4-5-464
CURRENT STATUS OF THE PLUTONIUM HOT PARTICLE PROBLEM/	17-1-3-43
ANTICIPATED TRANSIENTS WITHOUT SCRAM - A STATUS QUO/	18-3-1-281
THE REACTOR LICENSING PROCESS - A STATUS REPORT/	17-2-2-185
Y CORE COOLING SYSTEM PERFORMANCE/	16-5-6-603
IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	17-2-6-231
IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	18-3-6-355
IN WATER COOLED NUCLEAR REACTORS IN 1975/	16-3-6-354
IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	12-5-5-523
FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM/	17-3-4-327
FROM IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VESSEL	18-6-4-791
OPERATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL	12-6-5-600
EFFECTS ON MECHANISMS OF ENTRAPMENT IN COOLING WATER -	13-1-5-054
ATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOURCE	16-4-2-443
A METHOD OF CALCULATING TURBINE RISK	13-2-2-114
R PLANTS/	13-5-4-373
INTERIOR STRUCTURE/	13-2-2-107
TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT	11-4-1-001
EARTHQUAKE RESISTANT DESIGN OF ENGINEERING	15-4-4-432
TORNADO RESISTANT DESIGN OF NUCLEAR POWER PLANT	13-5-4-373
STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT INTERIOR	18-2-4-189
S IN THE DESIGN OF PRESSURIZED WATER REACTOR CONTAINMENT	16-3-2-291
AGATION IN LIQUID METAL COOLED FAST BREEDER REACTOR FUEL	18-2-2-154
ENS/	12-6-3-583
BURNOUT IN BOILING HEAT TRANSFER II.	12-4-1-291
EAR LIABILITY INSURANCE - A BRIEF HISTORY REFLECTING THE	15-3-2-285
IOUS FAILURE OF EMERGENCY CORE COOLING/	12-3-1-196
ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERI	16-6-6-734
CREST SUMMARY - WATER-COOLED REACTOR SAFETY/	15-2-6-190
ROM NUCLEAR POWER PLANTS DURING 1973/	17-1-1-15
REACTOR FACILITIES/	17-6-4-710
LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN	11-3-6-237
THE ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE	17-3-5-344
ACTOR FUEL/	17-4-1-411
A COMPARISON OF TWO NITROGEN-16 RADIATION	16-4-3-452
IDENTIFICATION OF POTENTIAL IMPROVEMENTS IN ENVIRONMENTAL	15-6-3-702
NUCLEAR ENERGY CENTER SITE	17-2-5-223
SENSITIVITY OF PORTABLE SETA-GAMMA	12-6-2-569
IN LIGHT WATER REACTOR CONTAINMENTS/	14-6-6-680
USION UNDER LOW WIND SPEED INVERSION CONDITIONS/	18-3-3-317
QUALIFICATION OF SAFETY RELATED	16-5-3-557
IEEE NUCLEAR POWER SYSTEMS	18-4-5-502
INTERNATIONAL WASTE MANAGEMENT	15-4-3-417
THE 16TH ANNUAL POWER INSTRUMENTATION	13-3-5-225
THE 1971 TRIUMF	15-6-5-732
EW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES	15-3-4-302
REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES	12-4-3-310
JOINT ANNUAL	16-6-5-720
PS - 1970/	13-1-3-029
POPULATION EXPOSURES - THE EIGHTH BIYEAR TOPICAL	15-5-5-592
THE FOURTEENTH POWER INSTRUMENTATION	12-2-1-75
NEA/	16-1-6-79
NG OF NUCLEAR POWER PLANTS/	12-4-5-338
IAEA - AEC	12-5-6-930
IAEA	14-4-5-340
IAEA - WHO	11-6-4-475
ACILITY SITING/	14-4-1-274
USE AND EFFECTS/	11-6-2-463
TOACTIVE MATERIALS/	13-5-5-380
CLEAR POWER PLANTS/	15-3-5-306
ION OF MAN AND HIS ENVIRONMENT/	12-6-6-615
E CONTAMINANTS IN THE ATMOSPHERE/	17-1-6-92
RSOMEL/	15-1-3-015
NEI/	18-4-1-427
STRUMENTATION/	12-2-5-110
THE HOMERADE NUCLEAR BOMB	15-4-6-460
PREDICTING SEA-BREEZE FUMIGATION FROM	15-3-4-295
THE LEAK OF	15-5-1-519
TANK 106-T AT MANFORD/	12-5-4-496
TANKS CONTAINING A FIXED NEUTRON ABSORBER/	14-3-1-181
TECHNICAL AND SAFETY ASSESSMENT/	11-1-4-025
TECHNOLOGY/	12-5-5-523
TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESS	17-5-1-539
TECHNOLOGY PROGRAM/	
TECHNOLOGY, AND THE PUBLIC INTEREST/	

EXPERIENCE WITH APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE ANOMALIES/	SAN UNOFRE EXP	11-2-6-142
FISSION PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED REACTORS/		12-2-3-90
TOMY/ ACCIDENTAL COBALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSION AGRICULTURAL		13-4-6-304
CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM/	ECOLOGICAL	12-1-3-025
A REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER/		10-5-2-596
ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES/		17-6-1-659
AFET// AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON REACTOR S		15-2-1-132
SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF NUCLEAR MATERIALS/		15-5-1-513
EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS/		11-6-2-450
RESTRICTED RELEASE OF PLUTONIUM II. THEORY/		12-3-2-203
PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS/		14-4-1-267
ON ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOURCE STRENGTH/		13-1-5-054
TRANSPORTATION OF RADIOACTIVE MATERIALS/	THE THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND T	14-4-1-274
	THE THIRD RELIABILITY MEETING AT RISO/	11-4-3-309
	THE THIRTEENTH AEC AIR CLEANING CONFERENCE/	16-2-4-190
ITIES/ FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR FACIL		13-1-5-047
T NUCLEAR FACILITIES/ ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAIN		17-6-1-659
TALITY RISKS FROM REACTOR ACCIDENTS/ LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE LATE MOR		11-6-4-482
E ON REACTIVITY EFFECTS IN LARGE POWER REACTORS/ SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CAE		13-4-2-297
A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS/		13-4-3-295
AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/		17-3-1-289
1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/		16-2-1-141
REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING/		16-3-1-273
ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/		14-5-1-439
POPULATION EXPOSURES - THE EIGHTH MICYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY/		16-6-5-720
STRUCTURES/ TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT S		11-4-2-294
STRUCTURES/ TORNADO RESISTANT DESIGN OF NUCLEAR POWER PLANT		15-4-4-432
LING TOWERS - CONSIDERATIONS IN THE EVOLUTION OF OPTIMUM TOWER DESIGN/	EMERGENCY SHUTDOWN COO	17-6-4-701
FOG AND DRIFT DEPOSITION FROM EVAPORATIVE COOLING TOWERS/		15-2-5-190
MUM TOWER DESIGN/ EMERGENCY SHUTDOWN COOLING TOWERS - CONSIDERATIONS IN THE EVOLUTION OF OPTI		17-6-4-701
	SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PERSONNEL/	12-6-6-615
	SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSONNEL/	17-1-6-92
SIMULATORS/ REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT		16-4-5-402
REACTOR VESSEL PRESSURE TRANSIENTS/		18-4-6-513
REACTORS/ ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QUO/		17-3-3-43
RATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER		15-2-3-151
ATMOSPHERIC TRANSPORT// RADIONUCLIDE BEHAVIOR DURING NORMAL O		16-3-4-318
THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE SAFE TRANSPORT AND DISPERSION OVER CITIES/		13-5-5-391
STATES/ TRANSPORT OF RADIOACTIVE MATERIALS/ THE IMPACT O		13-2-1-103
THE NUCLEAR FUEL CYCLE/ PROBABILITY AND CONSEQUENCES OF TRANSPORT OF RADIOACTIVE MATERIALS IN THE UNITED		10-3-1-291
THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION ACCIDENTS INVOLVING RADIOACTIVE M		14-6-2-597
NUCLEAR FACILITIES - A CRITICAL ASSESSMENT/ TRANSPORTATION OF RADIOACTIVE MATERIALS/		14-4-1-274
A CONTAINMENT STRUCTURES AND SYSTEMS/ TRENDS IN PUBLIC HEALTH IN THE POPULATION NEAR N		10-5-5-647
PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE DESIGN OF PRESSURIZED WATER REACTO		10-2-4-189
	TRENDS IN THE FEDERAL REPUBLIC OF GERMANY/	15-4-3-409
	TRENDS IN THE LICENSING OF NUCLEAR POWER PLANTS/	10-5-1-501
	REPORT ON SEMINAR OF TRIGA OWNERS/	11-6-5-493
RADIOLOGICAL ASPECTS OF ENVIRONMENTAL TRITIUM/		17-2-5-216
ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE ENVIRONMENT/		12-4-4-326
THE 1971 TRITIUM SYMPOSIUM AT LAS VEGAS/		13-3-5-225
NUCLEAR POWER REACTORS DURING 1972/ STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED		16-3-6-354
NUCLEAR POWER REACTORS IN 1973/ STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED		16-5-6-603
NUCLEAR POWER REACTORS IN 1974/ STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED		17-2-6-231
NUCLEAR REACTORS IN 1975/ STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED		18-3-6-355
PROBABILITY OF DAMAGE TO NUCLEAR COMPONENTS DUE TO TURBINE FAILURE/		14-3-2-187
A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PROBABILITIES/		16-4-2-443
	TURBULENT DIFFUSION TYPING SCHEMES - A REVIEW/	17-1-5-68
DOU CHAINS/ TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN F		11-1-5-043
	THE TWELFTH AEC AIR-CLEANING CONFERENCE/	14-2-4-111
	TYPING SCHEMES - A REVIEW/	17-1-5-68
TY STATISTICS FOR 1973/ U.S. COMMERCIAL NUCLEAR POWER PLANTS/		15-6-1-673
NT CONDITIONS/ U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACI		15-6-6-738
	U.S. STUDIES ON LMFBR FUEL BEHAVIOR UNDER ACCIDE	14-5-2-452
	U.S. 1970/	15-4-5-453
ILES IN RADIATION MONITORING (A GUIDE FOR MANAGEMENT) U.S.A. STANDARD N13.2-1969 - GUIDE FOR ADMINIS		11-1-5-039
ND SAFETY ASSESSMENT/ UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL A		15-5-1-519
CERMET CORES DURING OUTGASSING/ UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM		15-4-6-455
SAFETY ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE UNITED KINGDOM/		11-4-1-283
VARIABILITY OF WIND DIRECTION WITHIN THE UNITED STATES/		11-1-5-034
NATURAL BACKGROUND RADIATION IN THE UNITED STATES/		17-4-5-471
TRANSPORT OF RADIOACTIVE MATERIALS IN THE UNITED STATES/		10-3-1-291
RESEARCH LABORATORY/ ACCIDENTAL COBALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSI		13-4-6-304
RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH REACTOR/		17-4-3-437
UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM CERMET CORES DURING OUTGASSIN		15-4-6-455
FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MELTEN URANIUM DICHLORIDE IN SODIUM/		16-6-2-683
RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING SITES - AN OVERVIEW/		17-6-5-722
NEUTRON ABSORBER/ THE SAFETY AND CONTROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FIXED		15-3-4-295
VELOPMENT/ NATURAL RADIATION IN THE URBAN ENVIRONMENT/		13-4-1-275
	THE UTILITY'S ROLE IN NUCLEAR SAFETY RESEARCH AND DE	11-3-1-185
	QUO VADIS, PERSONNEL MONITORING/	16-6-5-728
	VALVE MALFUNCTIONS IN NUCLEAR POWER PLANTS/	15-3-6-316
STATES/ VARIABILITY OF WIND DIRECTION WITHIN THE UNITED		11-1-5-034
	VEGAS/	13-3-5-225
PERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I/ BIOLOGICAL EFFECTS OF NOBLE GASES (A R		15-6-5-732
APERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS II/ SEPARATION AND CONTAINMENT OF NOBLE GAS		15-3-4-302
	DATA SOURCES FOR LOCA CODE VERIFICATION/	17-6-2-671
POWER REACTORS/ VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN		13-4-3-295
INSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL/		11-2-4-119
IMPROVING REACTOR PRESSURE VESSEL AVAILABILITY BY DESIGN/		17-1-4-62
IES/ PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILIT		15-4-2-387
	REACTOR PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILIT	10-4-6-513
	REACTOR PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILIT	14-4-2-291
WATER REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE/	PRESSURIZED	

NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VESSEL STEELS/	17-3-4-327
CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEELS/	18-6-4-791
RELATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO LWR SAFETY/	17-4-4-447
THE SAFETY OF REACTOR PRESSURE VESSELS/	17-1-4-55
THE TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESSURE VESSELS/	11-1-4-025
EMISSION TO DETECT INCIPENT FAILURE IN NUCLEAR PRESSURE VESSELS/ A PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION TO DETECT INCIPENT FAILURE IN NUCLEAR PRESSURE VESSELS/	15-5-3-554
RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WASTE/	14-5-1-420
RELEASES OF RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972/	11-2-4-160
NATIONAL CONFERENCE ON WASTE MANAGEMENT SYMPOSIUM/	11-5-4-391
SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS/	15-3-6-311
NATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WASTES/ STATUS OF INVESTIGATIONS OF SALT FOR MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL REPROCESSING OPERATIONS/	13-3-1-216
EFFECTS ON ORGANISMS OF ENTRAINMENT IN COOLING WATER - STEPS TOWARD PREDICTABILITY/	18-4-5-502
ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY RAPID HEATING/	16-5-4-501
CRITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW ACCEPTANCE CRITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	11-2-5-130
STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	14-5-5-482
STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	12-6-5-600
STEAM-GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1975/	11-1-2-012
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER COOLED POWER REACTORS/	15-2-4-173
C HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER REACTORS/	16-3-6-354
OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975/	16-5-5-603
COOLING SYSTEM PERFORMANCE/	17-2-6-231
UAL DISCHARGERS THROUGH PERMIT PROGRAMS/ THE NEW FEDERAL POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER REACTORS/ INSTRUMENTATION FOR MONITORING OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS/	18-3-6-355
C LICENSING JURISDICTION AND PROCEDURES/ THE NEW FEDERAL POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER REACTORS/ INSTRUMENTATION FOR MONITORING OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS/	15-2-3-151
THE HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER REACTOR ACCIDENTS/	13-6-2-459
FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR CONTAINMENT STRUCTURES AND SYSTEMS	17-2-2-185
TRENDS IN THE DESIGN OF PRESSURIZED WATER REACTOR CONTAINMENTS/	15-3-1-262
SURVEY OF APPLIED INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE/	16-4-1-421
ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/	11-6-3-468
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR SAFETY/	12-5-3-487
EPRI WATER REACTOR SAFETY PROGRAM/	18-2-4-189
THE WATER REACTOR SAFETY RESEARCH INFORMATION MEETING	15-4-3-702
FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING	14-4-2-291
NRC WATER REACTOR SAFETY RESEARCH PROGRAM/	12-5-1-433
GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM/	14-5-1-439
PIPE CRACKING IN BOILING WATER REACTORS/	16-5-1-542
RELIABILITY OF PIPING IN LIGHT WATER REACTORS/	16-6-1-659
INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS/	11-5-1-369
USE OF CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER REACTORS/	15-3-1-241
IDENTS OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS/	16-1-1-8
PROBABILITY ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF COOLANT ACCIDENTS/	17-2-1-143
OPERATING EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE/	18-2-1-133
PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER-COOLED POWER REACTOR PLANTS/	18-1-1-1
CREST SUMMARY - WATER-COOLED REACTOR SAFETY/	18-6-1-727
IAEA - WHO SYMPOSIUM ON HANDLING OF RADIATION ACCIDENTS	17-4-6-475
VARIABILITY OF WIND DIRECTION WITHIN THE UNITED STATES/	17-5-4-568
OF FIELD MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED INVERSION CONDITIONS/ A SURVEY	18-1-4-60
OLD MEDICAL RADIATION EXPOSURE BE RECORDED FOR RADIATION WORKERS/	11-3-4-223
THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTOR INDUSTRY/	15-1-6-076
AR POWER PLANT SITES/	14-1-2-014
FACTORS DURING 1972/	13-5-6-666
FACTORS IN 1973/	11-3-3-206
FACTORS IN 1974/	12-3-1-196
S IN 1975/	12-4-5-338
POPULATION EXPOSURE TO X-RAYS - U.S. 1970/	11-1-5-034
KRYPTON - XENON REMOVAL SYSTEMS/	17-2-5-223
NUCLEAR LIABILITY INSURANCE - A REVIEW OF RECENT YEARS/	14-3-5-220
ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACILITIES IN NEW YORK STATE/	17-3-4-363
THE RELAP5 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT ANALYSIS/	16-1-1-1
THE LEAK OF TANK 106-T AT HANFORD/	16-3-6-354
OPERATING EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE/	16-5-5-603
THE 16TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION/	17-2-6-231
OCCUPATIONAL RADIATION EXPOSURES AT LWRs, 1969-1974/	18-3-6-355
AUTATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975/	15-4-5-453
POPULATION EXPOSURE TO X-RAYS - U.S. 1970/	12-6-4-591
UAL SYMPOSIUM OF IEEE POWER AND NUCLEAR SCIENCE GROUPS - 1970/	15-5-1-527
COMPONENTS/	16-2-5-204
REPORT ON THE 1973 ANS CONFERENCE ON POWER REACTOR SYSTEMS AND FACTORS/ SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON REACTIVITY EFFECTS IN LIGHT WATER REACTORS/	17-2-2-194
ACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS IN EUROPE, 1970-1974/	15-4-5-660
PIPE RUPTURE STUDY - 1971/	18-5-6-666
THE 1971 TRITIUM SYMPOSIUM AT LAS VEGAS/	15-4-3-417
Y RELATED OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1972/	17-5-6-822
N EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972/	18-3-6-365
N EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	15-4-5-453
EAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973/	12-4-3-310
Y RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS DURING 1973/	12-2-6-134
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	13-4-2-287
AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON REACTOR SAFETY/	18-3-6-370
F NOBLE GASES I A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I/ SEPARABLE GASES I A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I/ RADIATION EFFECTS IN COOLING-TOWER ENVIRONMENT - 1974/	13-2-4-122
OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES, 1974/	13-3-5-225
DIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974/	15-1-5-067
	15-3-6-311
	16-3-6-354
	15-6-6-738
	16-6-6-734
	16-5-6-603
	15-2-1-132
	15-3-4-302
	15-6-5-732
	15-5-5-592
	17-6-5-743
	18-1-6-79

WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	STEAM GENERATOR TUBE FAILURES - NO	17-2-6-231
	1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	16-2-1-141
	THE 1974 SPECIALISTS MEETING ON REACTOR NOISE/	16-3-3-308
NUCLEAR ENERGY CENTER SITE SURVEY - 1975/		17-4-1-411
OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES. 1975/		18-4-6-523
AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/		17-3-1-789
S - WORLD EXPERIENCE IN WATER COOLED NUCLEAR REACTORS IN 1975/	STEAM GENERATOR TUBE FAILURE	18-3-6-355
Y AND RELATED PHYSICS/	1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY	18-4-2-451
	OSNEDEN 2 INCIDENT OF JUNE-5, 1970/	12-5-7-538
	THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT MODEL/	17-3-2-299
	POPULATION DOSES FROM THE NUCLEAR INDUSTRY TO 2000 A.D./	15-1-5-054
	INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA CONFERENCE AND EXHIBIT/	13-5-3-366

END KNIC-INDEX

Section 3

AUTHOR INDEX

Authors of *Nuclear Safety* articles are indexed here in alphabetical order. The seven-digit index number following each name provides entry to the main (orange) index. The same numbering system is used in the other index sections and is explained in the introduction. If an author has prepared more than one article for *Nuclear Safety*, his name appears with a specific index number for each article: for example, D. W. Moeller (see index) has had articles in Vol. 11, No. 1, Sect. 5, p. 309; Vol. 12, No. 2, sect. 4, p. 100; Vol. 13, No. 4, Section 1, p. 274; Vol. 14, No. 2, Sect. 4, p. 111; Vol. 16, No. 4, Sect. 4, p. 469; Vol. 17, No. 1, Sect. 1, p. 1; Vol. 18, No. 2, Sect. 4, p. 174; and Vol. 18, No. 5, Sect. 4, p. 633.

AUTHOR LIST NUMBER 1

ACKERMAN, N. J., JR. 12-6-3-503
 AFC REGULATORY STAFF 15-2-3-151
 ALKEN, A. 18-2-3-168
 ALLEN, J. M. 18-5-3-617
 ALVEREZ, G. L. 15-3-4-255
 AMATO, C. J. 16-6-1-563
 AMAVIS, R. J. 13-5-5-380
 ANDERSEN, L. P. 15-6-1-651
 ANDERSON, T. C. 12-1-2-009
 ARDUSS, J. P. 16-1-6-027
 AUENBACH, S. I. 12-1-3-025
 AUXIER, J. S. 12-5-2-456

BAKER, K. A. 17-3-6-363
 BAKER, L. JR. 11-1-1-005
 BARNES, P. A. 18-3-3-322
 BARNUM, G. J. 17-2-2-164
 BARNUM, D. J. 17-3-2-255
 BARNUM, G. J. 17-4-2-422
 BARNELL, A. M. 18-6-2-761
 BARTON, C. J. 13-3-5-225
 BARTON, C. J. 15-3-4-302
 BARTON, C. J. 15-6-5-732
 BARTON, C. J. 16-6-5-720
 BASKIN, K. P. 11-2-6-162
 BAUMANN, M. 16-3-1-273
 BAUMANN, C. D. 12-2-3-90
 BECKER, A. 16-6-5-720
 BELL, C. G. 16-1-1-001
 BELL, A. L. 15-5-3-554
 BELLAMY, R. R. 15-6-4-711
 BELTRACCHI, L. 17-6-3-653
 BENNETT, G. L. 18-1-1-1
 BENNETT, G. L. 16-5-1-589
 BERGLES, A. F. 16-1-2-29
 BERGLES, A. F. 18-2-2-154
 BERLIN, A. 13-5-5-380
 BERNSEN, S. A. 16-2-1-127
 BHATIA, P. 16-6-3-714
 BILES, M. A. 16-1-5-60
 BINGHAM, A. J. 18-2-4-189
 BIERKE, M. A. 18-5-2-556
 BLANT, J. S. 18-3-6-365
 BLAYLOCK, B. G. 17-3-5-351
 BLOOME, F. M. 16-5-5-553
 BLOOME, F. M. 17-5-5-580
 BLOOM, H. 18-2-1-127
 BLOOM, H. 11-5-1-369
 BLOOM, H. 11-2-5-130
 BLOOM, H. 12-1-3-015
 BLOOM, H. 12-5-1-432
 BLOOM, H. 11-1-1-012
 BLOOM, H. 16-6-2-597
 BLOOM, H. 17-5-1-539
 BLOOM, H. 13-6-2-467
 BLOOM, H. 17-6-6-743
 BLOOM, H. 18-6-6-523
 BLOOM, H. 12-3-4-234
 BLOOM, H. 11-5-1-365
 BLOOM, H. 15-6-1-665
 BLOOM, H. 17-4-4-447
 BLOOM, H. 16-1-1-1
 BLOOM, H. 18-2-4-189
 BLOOM, H. 17-6-3-653
 BLOOM, H. 16-2-3-150
 BLOOM, H. 13-1-1-001
 BLOOM, H. 14-3-2-187
 BLOOM, H. 17-5-4-568
 BLOOM, H. 11-6-2-289

BLOOM, H. 12-5-7-538
 BLOOM, H. 17-2-2-185
 BLOOM, H. 12-4-2-257
 BLOOM, H. 12-6-2-562
 BLOOM, H. 15-3-2-285
 BLOOM, H. 11-3-6-237
 BLOOM, H. 11-5-3-379
 BLOOM, H. 16-3-5-337
 BLOOM, H. 16-1-6-027
 BLOOM, H. 17-2-4-208
 BLOOM, H. 16-3-2-291
 BLOOM, H. 17-6-1-659
 BLOOM, H. 16-3-6-235
 BLOOM, H. 13-1-5-054
 BLOOM, H. 11-6-4-675
 BLOOM, H. 16-1-5-60

BLOOM, H. 12-5-7-538
 BLOOM, H. 17-2-2-185
 BLOOM, H. 12-4-2-257
 BLOOM, H. 12-6-2-562
 BLOOM, H. 15-3-2-285
 BLOOM, H. 11-3-6-237
 BLOOM, H. 11-5-3-379
 BLOOM, H. 16-3-5-337
 BLOOM, H. 16-1-6-027
 BLOOM, H. 17-2-4-208
 BLOOM, H. 16-3-2-291
 BLOOM, H. 17-6-1-659
 BLOOM, H. 16-3-6-235
 BLOOM, H. 13-1-5-054
 BLOOM, H. 11-6-4-675
 BLOOM, H. 16-1-5-60

COLLINS, W. P. 12-2-5-110
 COLLINS, J. T. 16-1-5-71
 COLLINS, P. F. 16-4-5-482
 COOPER, C. H. 11-5-1-365
 COOPER, W. E. 17-1-4-55
 COOPER, W. E. 17-1-4-82
 COPE, C. F. 16-3-1-232
 COPE, C. F. 15-6-2-876
 COPE, C. F. 12-1-4-035
 COTTELL, W. B. 12-3-1-194
 COTTELL, W. B. 16-5-1-439
 COTTELL, W. B. 15-1-4-030
 COTTELL, W. B. 15-2-1-132
 COTTELL, W. B. 15-3-1-261
 COTTELL, W. B. 15-1-1-8
 COTTELL, W. B. 17-2-1-143
 COTTELL, W. B. 18-2-1-133
 COTTELL, W. B. 12-6-5-600
 COTTELL, W. B. 16-3-5-329
 COTTELL, W. B. 16-6-2-683
 COTTELL, W. B. 16-2-6-224
 COTTELL, W. B. 15-5-1-519
 COTTELL, W. B. 17-2-2-185
 COTTELL, W. B. 16-4-2-354
 COTTELL, W. B. 16-6-6-660

DANER, M. R. 16-5-2-446
 DAW, W. J. 17-1-3-33
 DAVIS, J. P. 16-1-1-006
 DAVIS, J. P. 14-3-1-165
 DAVIS, J. P. 15-3-1-262
 DAVIS, J. P. 16-4-1-421
 DAVIS, J. P. 11-4-4-315
 DAVIS, J. P. 18-3-6-365
 DAVIS, J. P. 11-5-4-251
 DAVIS, J. P. 16-2-3-150
 DAVIS, J. P. 17-3-5-344
 DAVIS, J. P. 15-2-5-185
 DAVIS, J. P. 11-3-2-155
 DAVIS, J. P. 16-5-2-452
 DAVIS, J. P. 17-3-1-281
 DAVIS, J. P. 16-6-5-720
 DAVIS, J. P. 18-4-5-452
 DAVIS, J. P. 18-1-4-60
 DAVIS, J. P. 12-3-3-276
 DAVIS, J. P. 11-4-2-256
 DAVIS, J. P. 14-4-2-291
 DAVIS, J. P. 15-5-1-519
 DAVIS, J. P. 11-6-3-486
 DAVIS, J. P. 13-5-3-366
 DAVIS, J. P. 16-4-3-215
 DAVIS, J. P. 11-1-5-043

CAUS, B. G. 13-5-3-366
 CASON, C. F. 14-3-5-220
 CASON, C. F. 15-5-5-555
 CASON, C. F. 18-2-5-203
 CASON, C. F. 11-3-6-235
 CASON, C. F. 17-5-1-525
 CASON, C. F. 12-1-1-001
 CASON, C. F. 12-4-4-326
 CASON, C. F. 11-4-6-323
 CASON, C. F. 12-3-3-226
 CASON, C. F. 14-2-3-095
 CASON, C. F. 16-1-4-43
 CASON, C. F. 15-3-4-318
 CASON, C. F. 11-6-4-482
 CASON, C. F. 13-4-4-481
 CASON, C. F. 14-6-4-634

FABIC, S. 17-6-2-471
 FARMER, F. R. 11-4-1-283
 FAUSKE, H. K. 16-3-2-251
 FAUSKE, H. K. 16-4-2-436
 FAUSKE, H. K. 17-5-2-550
 FAUSKE, H. K. 15-3-3-252
 FAUSKE, H. K. 14-2-1-079
 FAUSKE, H. K. 11-3-6-237
 FAUSKE, H. K. 16-2-4-190
 FAUSKE, H. K. 18-2-4-174
 FAUSKE, H. K. 16-2-1-141
 FAUSKE, H. K. 17-1-2-19
 FAUSKE, H. K. 18-4-2-451
 FAUSKE, H. K. 13-5-1-359
 FAUSKE, H. K. 16-3-3-316
 FAUSKE, H. K. 14-5-1-40
 FAUSKE, H. K. 16-3-5-33
 FAUSKE, H. K. 13-4-3-29

BLANK PAGE

VELURI, V. R. 17-5-5-580
 VIEIDER, G. 16-2-3-150
 VISSING, G. S. 16-2-6-224

WADE, G. E. 15-2-4-163
 WADE, L. JR. 13-4-6-304
 WHITE, D. A. 17-3-5-344
 WALKER, C. S. 11-3-3-204
 WALKER, C. S. 11-5-2-375
 WALL, I. B. 15-3-2-276
 WALL, I. B. 15-4-2-399
 WARD, K. 16-3-5-337
 WEENS, S. J. 11-3-4-215
 WERNE, R. A. 17-4-3-437
 MESSMAN, G. L. 14-4-4-618
 WHITMAN, G. D. 12-5-5-523
 WHITMAN, G. D. 16-1-1-8
 WHITMAN, G. D. 17-4-4-447
 WILCOX, W. H. 17-2-5-216
 WILKINS, R. W. 18-4-1-427
 WILSON, R. E. 16-3-2-291
 WINTON, N. L. 12-5-3-441
 WINTON, N. L. 15-5-2-535
 WITHERSPOON, J. P. 17-3-5-351
 WITT, F. J. 12-5-5-523
 WREATHALL, J. 18-5-3-624

YADIGAROGU, G. 15-6-1-651
 YAMURA, T. 11-1-2-012
 YBARRONDO, L. J. 15-6-2-876
 YEATES, D. B. 13-4-1-275

ZIEMER, P. L. 13-6-5-682
 ZITTEL, M. E. 13-6-2-459

AUTHOR LIST NUMBER 2

* STACHURA, S. J. 14-1-6-027
 SASSETT, T. G. 13-1-3-029
 BROOKS, B. G. 14-3-5-220
 BUTLER, M. H. 13-3-5-225
 CUNNING, R. B. 13-3-5-225
 ECKHOFF, N. D. 13-1-5-054
 EROMANN, R. C. 13-1-2-022
 FIRST, N. W. 14-2-4-111
 HARLEY, P. H. 13-1-5-047
 HATHER, D. J. 14-3-2-201
 OAKES, L. C. 14-2-3-095
 RHODE, G. K. 13-1-3-029

NUCLEAR SAFETY

A BIMONTHLY REVIEW JOURNAL PREPARED BY NSIC

Nuclear Safety covers significant developments in the field of nuclear safety.

The scope is limited to topics relevant to the analysis and control of hazards associated with nuclear reactors, operations involving fissionable materials, and the products of nuclear fission.

Primary emphasis is on safety in reactor design, construction, and operation; however, safety considerations in reactor fuel fabrication, spent-fuel processing, nuclear waste disposal, handling of radioisotopes, and related operations are also treated.

Qualified authors are invited to submit interpretive articles, which will be reviewed for technical accuracy and pertinency. Authors will be advised as soon as possible of acceptance or suggested changes. Send inquiries or 3 copies of manuscripts (with the draftsman's original line drawing plus 2 copies, and with continuous-tone glossy prints of photographs plus 2 copies) to Wm. B. Cottrell, Oak Ridge National Laboratory, P.O. Box Y, Oak Ridge, Tennessee 37830.

Nuclear Safety is prepared by the Nuclear Safety Information Center at Oak Ridge National Laboratory for the U.S. Nuclear Regulatory Commission. For subscriptions, address Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. The subscription rate is \$14.00 per year. Below is an order blank for your convenience.

U.S. GOVERNMENT PRINTING OFFICE
DIVISION OF PUBLIC DOCUMENTS
WASHINGTON, D.C. 20402

OFFICIAL BUSINESS
RETURN AFTER 5 DAYS

POSTAGE AND FEES PAID
U.S. GOVERNMENT PRINTING OFFICE

Name _____
Street _____
City _____ State _____ ZIP _____

To Ensure Prompt, Accurate Shipment, Please Print or Type Address on Mailing Label Above

MAIL ORDER FORM TO:

Superintendent of Documents, U.S. Government Printing Office, Washington, D.C., 20402

Enclosed find \$ _____ (check, money order, or Superintendent of Documents coupons).

Please send me _____ subscriptions to *Nuclear Safety* at
\$14.00 per subscription. (Single issues are sold at \$2.40 per issue.)

Please charge this order to my Deposit Account No. _____
Name _____
Street _____
City _____ State _____ ZIP _____

FOR USE OF SUPT. DOCS.

Enclosed _____
To be mailed _____
later _____
Subscription _____
Refund _____
Coupon refund _____
Postage _____

POSTAGE AND REMITTANCE: Postpaid within the United States, Canada, Mexico, and all Central and South American countries except Argentina, Brazil, Guyana, French Guiana, Surinam, and British Honduras. For these and all other countries, add \$3.50 for each annual subscription; for a single issue, add one-fourth of the single-issue price. Payment should be by check, money order, or document coupons, and MUST accompany order. Remittances from foreign countries should be made by international money order or draft on an American bank payable to the Superintendent of Documents or by UNESCO book coupons.

AVAILABILITY OF NSIC DOCUMENTS (Continued)

ORNL/ NSIC	Title	Price*
122	Annotated Bibliography of Safety-Related Occurrences in Nuclear Power Plants as Reported in 1974, R. L. Scott and R. B. Gallaher, May 1975	\$15.00
123	Nuclear Power: Accident Probability, Risks, and Benefits: A Bibliography, NSIC Staff, Feb. 1976	\$ 6.00
118†	Siting of Nuclear Facilities, Selections from <i>Nuclear Safety</i> , J. R. Buchanan, July 1976	\$ 9.75
125	LMFBR Safety, 1. Review of Current Issues and Bibliography of Literature (1960-1969), J. R. Buchanan and G. W. Keilholtz, Sept. 1976	\$12.75
126	Annotated Bibliography of Safety-Related Occurrences in Boiling-Water Nuclear Power Plants as Reported in 1975, R. L. Scott and R. B. Gallaher, July 1976	\$11.00
127	Annotated Bibliography of Safety-Related Occurrences in Pressurized-Water Nuclear Power Plants as Reported in 1975, R. L. Scott and R. B. Gallaher, July 1976	\$10.75
128†	HTGR Safety Literature, J. R. Buchanan and G. W. Keilholtz.	
129	LMFBR Safety, 2. Review of Current Issues and Bibliography of Literature (1970-1972), J. R. Buchanan and G. W. Keilholtz, Dec. 1976.	\$13.00
130	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, November 1975-June 1976, J. R. Buchanan, Oct. 1976.	\$ 5.50
131	LMFBR Safety, 3. Review of Current Issues and Bibliography of Literature (1972-1974), J. R. Buchanan and G. W. Keilholtz, April 1977	\$12.75
132	LMFBR Safety, 4. Review of Current Issues and Bibliography of Literature (1974-1975), J. R. Buchanan and G. W. Keilholtz, April 1977	\$13.00
133	Index to <i>Nuclear Safety</i> , A Technical Progress Review by Chronology, Permuted Title, and Author, Vol. 11, No. 1 Through Vol. 17, No. 6, Wm. B. Cottrell and Ann Klein, April 1977	\$ 5.50
134	Reports Distributed Under the NRC Light-Water Reactor Safety Technical Exchange, Wm. B. Cottrell and D. S. Sharp, April 1977	\$ 4.00
135	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, J. R. Buchanan, March 1977	\$ 5.50
136	Design Data and Safety Features of Commercial Nuclear Power Plants, Vol. VI (Sixth Volume of ORNL/NSIC-55), F. A. Heddleson, June 1977	\$ 5.50
137	Annotated Bibliography of Safety-Related Occurrences in Boiling-Water Nuclear Power Plants as Reported in 1976, R. L. Scott and R. B. Gallaher, Sept. 1977	\$11.75
138	Annotated Bibliography of Safety-Related Occurrences in Pressurized-Water Nuclear Power Plants as Reported in 1976, R. L. Scott and R. B. Gallaher, Aug. 1977	\$12.00
139	LMFBR Safety, 5. Review of Current Issues and Bibliography of Literature: Vol. 5, 1975-1976, J. R. Buchanan and G. W. Keilholtz, July 1977	\$13.75
140	Structural Integrity of Materials in Nuclear Service: A Bibliography, F. A. Heddleson, July 1977	\$ 9.25
141	Summary Data for U.S. Commercial Nuclear Power Plants, F. A. Heddleson	
142	Reports Distributed Under the NRC Light-Water Reactor Safety Technical Exchange, Vol. 111 (Jan.-June 1977), D. S. Sharp and Wm. B. Cottrell, Oct. 1977	\$ 4.00
143	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research - Jan.-June 1977, J. R. Buchanan, Oct. 1977	\$ 5.50
144	Reactor Operating Experiences 1975-1977, U.S. Nuclear Regulatory Commission	
145	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research - July-Dec. 1977, J. R. Buchanan	
146	Reports Distributed in 1977 Under the NRC Light-Water Reactor Safety Technical Exchange, Wm. B. Cottrell and D. S. Sharp	
147	Index to <i>Nuclear Safety</i> , A Technical Progress Review by Chronology, Permuted Title, and Author, Vol. 11, No. 1 Through Vol. 18, No. 6, Wm. B. Cottrell and Ann Klein	

* Due to additional mailing and handling costs, the foreign price per document is double that of the domestic price.

† Reports after this date are published as ORNL/NUREG/NSIC reports.

‡ If no date is given, report has not been published.