DOE/CH/01205--T1

FINAL REPORT

RECEIVED

JUL 08 1993

OSTI

**ESTABLISH FEASIBILITY FOR PROVIDING PASSIVE COOLING WITH
SOLAR UPDRAFT AND EVAPORATIVE DOWNDRAFT CHIMNEYS**

Performed for the U. S. Department of Energy under

**SOLERAS GRANT
DE-FG02-84CH01205**

by

**The Environmental Research Laboratory
University of Arizona
2601 E. Airport Drive
Tucson, Arizona 85706**

W. A. Cunningham, G. V. Mignon, T. L. Thompson

**This report covers all work performed from June 15, 1984 to
December 31, 1987**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

TABLE OF CONTENTS

	<u>Page</u>
TABLE OF CONTENTS	i
LIST OF TABLES	ii
LIST OF FIGURES	ii
ABSTRACT	1
INTRODUCTION	1
OPERATING PRINCIPLES	2
THE DOWNDRAFT TOWER	9
SOLAR CHIMNEYS	15
WIND AND TOWER PERFORMANCE	25
PHOTOVOLTAIC POWERED COOL TOWERS	40
ECONOMIC AND PERFORMANCE MODEL	41
GREENHOUSE COOLING	73
RESIDENTIAL COOLING	80
CONCLUSIONS	81
APPENDIX A - Tests to Determine the Baffle Resistance to Airflow	85
APPENDIX B - Wind Flow Through Low Resistance Surfaces	89
APPENDIX C - Construction Drawings	91
REFERENCES	102

LIST OF TABLES

<u>Table</u>	<u>Page</u>
1. Solar Chimney Test Results	24
2. Default Graph Parameters	43
3. Effects of ΣK on Economics and Airflow	44
4. Effects of Location and Pad Thickness on Economics and Airflow	71
5. Effects of Pad Thickness on Temperature and CFM	73

LIST OF TABLES - APPENDIX

B-1. Flow Through Screens in an Air Stream	90
--	----

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1. Natural Downdraft Test Assembly in Greenhouse	3
2. Solar Chimney Test Assembly in Greenhouse	4
3. ERL's Prototype Natural Draft Cooling System with Cool Tower in Foreground	5
4. ERL's Prototype Natural Draft Cooling System with Solar Chimney in Foreground	6
5. Natural Draft Cooling Flow Diagram	7
6. Chart for Determining Downdraft Tower Velocity for Calm Conditions	11
7. Optimum Pad Thickness - Pad on One Face of Tower	12
8. Optimum Pad Thickness - Pads on Four Tower Faces (No Wind Case)	13
9. Basic Tower Pad Configurations	14
10. Solar Chimneys	16
11. Chart for Calculating Solar Chimney Performance	19
12. Chart for Horizontal Solar Collector - Vertical Chimney Performance	22
13. Diagram of Cloth (Barometric) Dampers	26
14. Ratio of Wind Velocity Head to Total Head	27
15. Test House with Cool Tower - Tucson, Arizona	28
16. Tower Performance with Gravity Dampers (Dampers Fixed Closed)	30
17. Tower Performance with Gravity Dampers (Dampers Free to Open or Close)	31
18. Effect of Discharge Pressure Coefficient on Tower Performance	32
19. Effect of Pad Area on Tower	36
20. Effect of Long Baffle and Pad Area on Tower Performance	37
21. Effect of Pressure Coefficients from Various Sources	38

LIST OF FIGURES (con'd)

<u>Figure</u>	<u>Page</u>
22. Tower Evaporation Rate	39
23. Cool Tower Cost and Performance Model	45
24. Effect of ΣK on Economics, $\Sigma K = 4$	46
25. Effect of ΣK on Economics, $\Sigma K = 6$	46
26. Effect of ΣK on Economics, $\Sigma K = 8$	47
27. Effect of ΣK on Economics, $\Sigma K = 10$	47
28. Effect of ΣK on Economics, $\Sigma K = 12$	48
29. Effect of ΣK on Airflow, $\Sigma K = 4$	48
30. Effect of ΣK on Airflow, $\Sigma K = 6$	49
31. Effect of ΣK on Airflow, $\Sigma K = 8$	49
32. Effect of ΣK on Airflow, $\Sigma K = 10$	50
33. Effect of ΣK on Airflow, $\Sigma K = 12$	50
34. Effect of Pad Thickness on Economics - 4 ft Square Towers	51
35. Effect of Pad Thickness on Economics - 6 ft Square Towers	51
36. Effect of Pad Thickness on Economics - 8 ft Square Towers	52
37. Effect of Pad Thickness on Economics - 10 ft Square Towers	52
38. Effect of Pad Thickness on Economics - 12 ft Square Towers	53
39. Effect of Location on Economics - Phoenix, AZ, 4-inch Pad	53
40. Effect of Location on Economics - Phoenix, AZ, 6-inch Pad	54
41. Effect of Location on Economics - Phoenix, AZ, 8-inch Pad	54
42. Effect of Location on Economics - Albuquerque, NM, 4-inch Pad	55
43. Effect of Location on Economics - Albuquerque, NM, 3-inch Pad	55
44. Effect of Location on Economics - Las Vegas, NV, 4-inch Pad	56
45. Effect of Location on Economics - Las Vegas, NV, 6-inch Pad	56
46. Effect of Location on Economics - Las Vegas, NV, 8-inch Pad	57
47. Effects of Location on Airflow - Phoenix, AZ, 4-inch Pad	57
48. Effects of Location on Airflow - Phoenix, AZ, 6-inch Pad	58
49. Effects of Location on Airflow - Albuquerque, NM, 4-inch Pad	58
50. Effects of Location on Airflow - Albuquerque, NM, 3-inch Pad	59
51. Effects of Location on Airflow - Las Vegas, NV, 4-inch Pad	59
52. Effects of Location on Airflow - Las Vegas, NV, 6-inch Pad	60
53. Effects of Location on Airflow - Palm Springs, CA, 4-inch Pad	60
54. Effects of Location on Airflow - Palm Springs, CA, 6-inch Pad	61
55. Effects of Location on Airflow - Palm Springs, CA, 8-inch Pad	61
56. Effects of Hours Used on Economics - 24 Hours Per Day	62
57. Effects of Hours Used on Economics - 18 Hours Per Day	62
58. Effects of Hours Used on Economics - 12 Hours Per Day	63
59. Effects of Pad Thickness on Temperature - Tucson, AZ, 3-inch Pad	63
60. Effects of Pad Thickness on Temperature - Tucson, AZ, 4-inch Pad	64
61. Effects of Pad Thickness on Temperature - Tucson, AZ, 6-inch Pad	64
62. Effects of Location on Temperature - Phoenix, AZ, 4-inch Pad	65
63. Effects of Location on Temperature - Phoenix, AZ, 6-inch Pad	65
64. Effects of Location on Temperature - Phoenix, AZ, 8-inch Pad	66
65. Effects of Location on Temperature - Albuquerque, NM, 4-inch Pad	66
66. Effects of Location on Temperature - Albuquerque, NM, 3-inch Pad	67
67. Effects of Location on Temperature - Las Vegas, NV, 4-inch Pad	67

LIST OF FIGURES (con'd)

<u>Figure</u>	<u>Page</u>
68. Effects of Location on Temperature - Las Vegas, NV, 6-inch Pad	68
69. Effects of Location on Temperature - Las Vegas, NV, 8-inch Pad	68
70. Effects of Location on Temperature - Palm Springs, CA, 4-inch Pad . . .	69
71. Effects of Location on Temperature - Palm Springs, CA, 6-inch Pad . . .	69
72. Effects of Location on Temperature - Palm Springs, CA, 8-inch Pad . . .	70
73. ERL's Prototype Greenhouse with Cool Tower in Foreground	74
74. Cool Tower Greenhouse Performance with 15-foot Exhaust Tower (June, 1986)	76
75. Greenhouse Solar Chimney Extended to 25 ft Tall; 1987	77
76. Cool Tower Greenhouse Performance Data - June 26 to July 5, 1987 . .	78
77. Cool Tower Greenhouse Performance Data - July 6 to 16, 1987	78
78. Cool Tower Greenhouse Performance Data - July 30 to August 9, 1987 .	79
79. Cool Tower Greenhouse Performance Data - August 10 to 15, 1987 . .	79
80. ERL's Residential Prototype Performance Data - June 1985	82
81. ERL's Residential Prototype Performance Data - July 1985	82
82. ERL's Residential Prototype Performance Data - August 1985	83
83. Proposed Cool Towers for Downtown Phoenix, Arizona	84

LIST OF FIGURES - APPENDIX

A-1. Baffle Test Set-Up	85
A-2. Test Baffle Pressure Drop	88
A-3. ERL Prototype Cooling System Details	91
A-4. ERL Prototype Cooling System Details	92
A-5. Pad Mounting Details	93
A-6. ERL Prototype Greenhouse Modification Details - Greenhouse Wind Tower	94
A-7. ERL Prototype Greenhouse Modification Details - Greenhouse Wind Tower	95
A-8. ERL Prototype Greenhouse Modification Details - Greenhouse Wind Tower	96
A-9. ERL Prototype Greenhouse Modification Details - Greenhouse Solar Chimney	97
A-10. ERL Prototype Greenhouse Modification Details - Greenhouse Solar Chimney	98
A-11. ERL Prototype Greenhouse Modification Details - Greenhouse Solar Chimney	99
A-12. ERL Prototype Greenhouse Modification Details - Solar Chimney Extension Modification	100
A-13. Proposed Layout for a Natural Draft Greenhouse	101

ABSTRACT

Natural draft towers can be used for cooling and ventilating structures. From an operational perspective, the downdraft evaporatively cooled tower is preferred for a dry climate. Solar chimneys, when used alone, tend to require an excessively large solar collector area when appreciable quantities of air must be moved. When used in combination with a downdraft tower, the roof and attic of buildings may assist the solar chimney and their use becomes more attractive. Both a frame building and a greenhouse were successfully cooled during this program. The economics of the downdraft tower compare favorably with conventional evaporative cooling for some applications.

INTRODUCTION

Natural draft towers operate with the density difference between the tower and the outside air. If the density of the air in the tower is less than the ambient air, it will rise; if higher, it will fall. The rate at which air moves through the tower depends on the magnitude of the density difference, the height of the tower, the resistance to airflow provided by the tower and associated structure, and wind forces on the tower-structure envelope. In the solar chimney, the density difference is caused by the heating of air by the sun, although this may be supplemented by other heat sources within the structure. In the downdraft chimney, the density difference is provided by the cooling effect of the evaporation of water. These towers are often compared with Middle Eastern wind towers, or "baud-geers", described in detail by Bahadori (1978, 1979, 1981, & 1985) and Karakatsanis, et al. (1986). However, the wind towers are primarily wind catchers or scoops, whereas the natural draft towers depend on buoyancy forces.

Work on this system dates back to 1976, when, during a review of passive building designs which used a solar chimney to draw air through an evaporative cooling device (without fans), we noted that it would be far more efficient to

place the evaporative cooling pads at the top of a non-solar chimney and allow the cool air to fall into the structure. Further work was done in 1977-78 under an Arizona Solar Energy Commission grant in which a small downdraft chimney was constructed and tested (Moody, et al. 1978). No further experimental work on downdraft chimneys was performed until 1984, when this grant was received from the U. S. Department of Energy for experimentation with a residential building and a greenhouse. The work began when a small-scale downdraft chimney and solar updraft chimney were built and tested inside a greenhouse to eliminate the effects of wind (figures 1 & 2).

An experimental building which was retrofitted with natural draft towers in 1985 proved operationally successful and has received considerable attention because of its unusual design. Figures 3 & 4 are photographs of the residential building after it was modified for passive cooling. A flow diagram of the passive cooling concept can be found in figure 5.

OPERATING PRINCIPLES

The solar chimney is intended to provide ventilation air movement within a structure, usually in combination with the cooled downdraft chimney. Solar chimneys have been used for various drying operations, as described by Zambrano and Alvarado (1984). In the downdraft chimney, air is cooled by an evaporative cooler, either a spray or a wetted packing material, which is an integral part of the chimney. The cooled air, being heavier than ambient air, falls by gravity through the chimney into the structure to be cooled.

The two types of chimneys can be designed to operate in combination with each other, or separately, with one operating when ambient conditions are not favorable for the operation of the other; e.g., the evaporative downdraft chimney will operate alone at night, while the solar chimney would operate alone following a rain or under high humidity conditions. Operation of both types of towers may be improved by wind; however, the tower dimensions are usually determined by the windless case. It is important that the wind does not adversely influence the operation of the downdraft tower, which can occur when the air outlet from the structure is improperly located; this may happen when the downdraft tower is used alone, in the absence of a solar chimney.

Figure 1. Natural Downdraft Test Assembly in Greenhouse

Figure 2. Solar Chimney Test Assembly in Greenhouse

Figure 3. ERL's Prototype Natural Draft Cooling System
with Cool Tower in Foreground

Figure 4. ERL's Prototype Natural Draft Cooling System with Solar Chimney in Foreground

Figure 5. Natural Draft Cooling Flow Diagram

Much of the early work in this program was done to complement the computer modeling for the King Faisal Laboratory Project (1984). In particular, the correct method for combining the effect of both wind and density were determined, largely from a review of the literature, in particular the works of Newberry (1974), Vickery, et al. (1977), and Handa (1979). A simplified equation describing flow through either type of tower is:

$$\Delta C_{wp}(\rho_a V_w^2 / 2g_c) + (g/g_c)Z\Delta\rho = (\rho_t V_t^2 / 2g_c)\Sigma K \quad (I)$$

where ΔC_{wp} is the difference between the wind pressure coefficients at the tower inlet and the outlet; g is the acceleration due to gravity, ft/sec^2 ; Z is the effective height of the tower in ft; $\Delta\rho$ is the difference in air density between the inside of the tower and outside air, lb/ft^3 ; ρ_t is the density of air in the tower, V_t is velocity of air in the tower, ft/sec ; and ΣK is the sum of the pressure loss coefficients for the tower. C_{wp} (dimensionless) is the wind pressure coefficient, determined experimentally as:

$$C_{wp} = (P - P_0) / (\rho_a V_w^2 / 2g_c) \quad (II)$$

where P is the effective pressure, P_0 is the static pressure on the surface, lb/ft^2 ; ρ_a is the density of air, lb/ft^3 ; and g_c is the Newton's law conversion factor, $32.2 \text{ lb}_m\text{-ft/lb}_f \text{ sec}^2$. C_{wp} is generally positive on windward surfaces and negative on leeward surfaces. Tabulations of C_{wp} are available in the literature for a wide variety of cases, see Newberry (1974) and Handa (1979). The tower should be designed for a high positive C_{wp} at the inlet and a negative C_{wp} at the outlet. ΣK consists of coefficients for the following: inlet losses (contraction, louvers, screen, turning), the evaporation media in the downdraft tower, friction, possibly mist eliminators, and the tower outlet. When the tower is attached to a structure, ΣK must include terms for internal resistances in the structure and for flow through the exits.

For the downdraft evaporative cooler the density difference term is: $\Delta\rho = \rho_t - \rho_a$, while for the solar updraft tower the terms are reversed as $\Delta\rho = \rho_a - \rho_t$; note that ρ_t is the average air density in the tower in both cases, while ρ_a is the ambient air density lb/ft^3 . For more complicated cases, where the airflow is down the cooling tower, through a house, possibly through the attic of

the house, and out the solar tower, a plot of density versus elevation can be prepared and integrated to evaluate the $Z\Delta\rho$ term in equation I, similar to the procedure used with the thermosyphon solar water heater systems; for example, see Morrison and Ranatunga (1980).

THE DOWNDRAFT TOWER

While tower performance can be modeled with a computer, a simplified form of equation I can be derived for rapid estimation of downdraft cooler performance. For the windless case, equation I can be written:

$$V_t = [(2gZ/\Sigma K) (1 - \rho_a/\rho_t)]^{\frac{1}{2}} \quad (III)$$

Assuming tower operation to be adiabatic from the bottom of the evaporative cooling media to the tower outlet, if no water were added to the air $\rho_t = (T_a/T_t)\rho_a$, with T_a and T_t the absolute temperatures of ambient and tower air, respectively, °R. The term $1 - \rho_a/\rho_t$ in equation III would become simply $\Delta t/T_a$, with $\Delta t = T_a - T_t$. Of course, moisture is added to the air during passage through the evaporative cooling media, which allows the cooler to function in the first place, and the water vapor, being lighter than air, decreases the change in density. However, the increase in moisture is related to the drop in temperature; hence, one would expect there to be a relatively constant correction factor C_f so that $1 - \rho_a/\rho_t = C_f \Delta t/T_a$. While an algebraic expression can be derived for C_f , which is not truly constant, one can more easily calculate its value from a psychrometric chart. C_f ranges from 0.92 to 0.93, with a value of 0.926 within one percent for most cases.

The drop in air temperature as air passes through an evaporative cooler is related to the wet bulb depression Δt_w (dry bulb - wet bulb temperature) as $\eta = \Delta t/\Delta t_w$, or the evaporative cooler effectiveness, so that equation III can be written:

$$V_t = [2ZgC_f\eta\Delta t_w/T_a\Sigma K]^{\frac{1}{2}} \text{ or } 7.72[Z\eta\Delta t_w/T_a\Sigma K]^{\frac{1}{2}} \quad (IV)$$

This expression is useful for rapid estimation of the probable maximum velocity in many situations. For estimating purposes take $\eta(\max) = 1$ and $\Sigma K(\min) = 1.5$. For special cases ΣK may be reduced to as low as 0.3 (bellmouth entrance, conical outlet and low friction); however, such cases will probably be rare in practical applications.

Low-pressure-drop evaporative cooler pads have been found more satisfactory than sprays for providing evaporative cooling in these towers. These are cross-corrugated cellulose pads, such as CELdek® or GLASdek®, manufactured by Munters Corp., Fort Myers, Fl., or Glacier-Cor®, manufactured by Eng-Cor Inc., La Mirada, Ca.; aspen pads or treated paper mats are not suitable because of their relatively high pressure drop. With sprays, entrained water drops tend to carry over into the ventilated space; moreover, when very fine droplets are used, from very high-pressure or ultrasonic nozzles, minerals in the water tend to settle in the ventilated area as a fine dust.

Pressure loss and effectiveness relationships were obtained for CELdek® by fitting curves presented in Munters bulletin no. 3295-382:

$$\Delta p = K_p(\rho V^2/2g_c), \text{ where } K_p = 12.87x_p \quad (V)$$

$$\eta = 1 - \text{EXP} - 4.76x_p/V^{1/3} \quad (VI)$$

where K_p is the pressure loss coefficient; V is the superficial velocity of air through the pad, ft/sec; and x_p is the pad thickness, ft. x_p is typically 1/4 to one foot. Note that when equation VI is substituted into equation IV the resulting expression cannot be solved directly for the velocity. To facilitate solution of equation IV for the cross-corrugated pad, figure 6 was prepared. The dimensional parameter $x_p(\Sigma A_p/A_t)^{1/3}$, ft, appears because the tower velocity must be converted to the pad velocity, $(V_t A_t/\Sigma A_p)$; as there may be pads on several faces of the tower, ΣA_p is used. Note that Δt_w , the wet bulb depression, appears in the abscissa, which allows the velocity to be determined without first determining the effectiveness.

In figure 6, and all other computed performance graphs, equations V and VI were used to describe pad characteristics. Equation VI tends to predict slightly lower values for pad effectiveness than have been observed during these tests; this is probably caused by the superior wettability of used pads with some mineral deposition.

Chart For Determining Downdraft Tower Velocity

Calm (no wind) Conditions

Cross-Corrugated Cellulose Pads

Figure 6.

Tower (square) height = 15 ft.
 air temp. = 100, WB = 70 deg. F

Figure 7. Optimum Pad Thickness - Pad on One Face of Tower
 (No Wind Case)

Tower (square) height = 15 ft.
 air temp. = 100, WB = 70 deg. F

Figure 8. Optimum Pad Thickness - Pads on Four Tower Faces
 (No Wind Case)

For a given tower configuration in the absence of wind, there is an optimum pad thickness which will provide a maximum air velocity. The optimum thickness for airflow is not necessarily the optimum for comfort, and is of limited importance. Recall that the temperature of air leaving the tower is $t_a - \eta \Delta t_w$. From figures 7 and 8, observe that the curves for velocity versus pad thickness are relatively flat and selection of the optimum thickness for airflow is not critical in this respect. Figure 7 is for a configuration with a pad on one face of the tower only, as illustrated by case A on figure 9; while figure 8 shows a tower with pads on four faces, or case B on figure 9. In figure 7 $\Sigma A_p/A_t$ = pad height/tower width ratio, while in figure 8, $\Sigma A_p/A_t = 4$ (pad height)/tower width. These examples are for towers with low airflow resistances: a turn at the tower base ($K = 1.3$), with the exit area equal the tower cross-section, and a single enlargement into a large volume ($K = 1$). The loss term for the turn at the top of the tower can be determined from the relationships in Appendix A. If A_p = the area on one face of the tower, for figure 7: $\Sigma K = K_p(A_t/A_p)^2 + 1.3(A_t/A_p) + 1.3 + 1$, while for figure 8: $\Sigma K = (K_p/16)(A_p/A_t)^2 + (1.3/4)(A_p/A_p) + 1.3 + 1$, so the resistance to airflow is considerably lower for the case in figure 8. Figure 9(B) is the preferred configuration in most installations.

Figure 9. Basic Tower Pad Configurations

Computer studies have been performed for the case of non-adiabatic tower operation, where significant heat transfer occurs through the wall of the downdraft cooler, increasing the temperature and reducing airflow in the windless case. The effect appears to be significant primarily in tall, narrow towers, and should have only minor effects in most installations. Figure 12 in the solar chimney section of this report can be used to compute the non-adiabatic performance of a tower using pads for cooling, where the tower walls will normally be dry.

SOLAR CHIMNEYS

Equation 1 is also used to determine airflow through a solar chimney; through algebraic manipulation of equations in the solar energy literature an expression can be derived for air velocity through the collector (chimney). The resulting equation does not permit a direct solution for the velocity; an iterative procedure is required because of the temperature dependence of many of the heat transfer coefficients involved.

The solar chimney design first treated here, shown at the top of figure 10, consists of a black absorber, oriented vertically or at an angle with the horizontal, covered by one or more glazings of glass or clear plastic films. The airflow passage is between the absorber and innermost glazing. Wind effects on the inlet and outlet will not be considered.

Required first is an expression for the mean air temperature in the chimney. The useful energy gain (q_u) in a solar collector is given by Duffie and Beckman (1975):

$$q_u = F_R \{ q_{abs} - U_L(t_i - t_a) \} \quad (VII)$$

Where q_{abs} is the solar energy absorbed by the absorber plate, Btu/hr ft²; U_L is the coefficient for heat loss, Btu/(ft²)(hr)(°F); t_i and t_a are air inlet and ambient air temperatures, respectively, °F; and F_R is the collector heat removal factor, given by:

$$F_R = (F'/N_t) (1 - \exp(-N_t)) \quad (VIII)$$

Separate Absorber-Chimney (Solar Dryer)

Combined Solar Absorber-Chimney

Figure 10. Solar Chimneys

Where F' is the collector efficiency factor; N_t is an expression similar to the number of transfer units in a heat exchanger.

$$N_t = U_L F' / G' C_p = U_L F' L_c / V_t \rho_t X_w C_p \quad (IX)$$

G' is the mass flow rate of air per square foot of absorber area, $\text{lb/ft}^2 \text{hr}$; C_p is the specific heat of air $\text{Btu/lb}^\circ\text{F}$; L_c is the collector length, ft; X_w is the depth of the airflow channel, ft.

The temperature rise in the air stream passing through the collector is:

$$\Delta t_c = q_u / G' C_p \quad (X)$$

An expression for the mean air temperature in the collector can be determined from Klien (1973) as:

$$t_m = t_i + \Delta t_c \{ [1/(1 - \text{EXP} - N_t)] - 1/N_t \} \quad (XI)$$

Where t_m is the mean air temperature. An expression similar to that for the downdraft tower, equation IV, can be derived by utilizing the heat exchanger effectiveness concept for solar collectors from Phillips (1981). The maximum or stagnation temperature (t_s) is:

$$t_s = (q_{\text{abs}} / U_L) + t_i \quad (XII)$$

while the heat exchanger effectiveness is given by:

$$\eta_{\text{ex}} = \Delta t_c / (t_s - t_i) = 1 - \text{EXP} - N_t \quad (XIII)$$

However, the effectiveness term for the solar chimney (η_{sc}) must be based on the mean air temperature in the chimney. Combining equations XI and XIII

$$\begin{aligned} \eta_{\text{sc}} &= (t_m - t_i) / (t_s - t_i) = \eta_{\text{ex}} \{ [1/(1 - \text{EXP} - N_t)] - 1/N_t \} \\ &= 1 - [(1 - \text{EXP} - N_t) / N_t] \end{aligned} \quad (XIV)$$

η_{sc} varies from zero to one as N_t varies from 0 to ∞ ; below $N_t = 0.4$ it can be approximated by $\eta = 0.452 N_t$.

If $\Delta t_{si} = t_s - t_i$, with $V_w = 0$, equation I can be written:

$$V_t = \{(2gZ/\Sigma K)[(\eta_{sc}\Delta t_{si}/T_a) + (T_i/T_a) - 1]\}^{\frac{1}{2}} \quad (XV)$$

Where T_i is the absolute inlet air temperature, $^{\circ}R$. Expression XV is similar to equation IV when $T_i = T_a$, or when ambient air is drawn into the base of the chimney. If $\Delta t_{ai} = t_a - t_i$, equation XV can also be expressed as:

$$V_t = \{(2gZ/T_a \Sigma K)[(\eta_{sc}q_{abs}/U_L) - (1 - \eta_{sc}) \Delta t_{ai}]\}^{\frac{1}{2}} \quad (XVI)$$

Since η_{sc} is a function of both V_t and temperature, equations XV or XVI cannot be solved directly. For the case where $t_i = t_a$ and $N_t < 0.4$, equation XVI becomes

$$V_t = (0.452)^{1/3} [(2gZ/T_a \Sigma K)(L_c F' q_{abs}/\rho_t X_w C_p)]^{1/3} \quad (XVII)$$

For most cases of interest in this model, $t_i < t_a$; that is, the chimney is used to draw cooled ventilation air through a building. To facilitate solar chimney calculations, figure 11 was prepared. Substituting equations IX and XIV into equation XVI, the following expression is obtained:

$$\begin{aligned} (U_L F' L_c / \rho_t X_w C_p) [(T_a \Sigma K / 2gZ)(U_L / q_{abs})]^{\frac{1}{2}} = \\ N_t \{1 - [(1 - \text{EXP} - N_t) / N_t][1 + (U_L / q_{abs}) \Delta t_{ai}]\}^{\frac{1}{2}} \end{aligned} \quad (XVIII)$$

Figure 11 is a plot of N_t versus the R.H.S. (and also the L.H.S.) of equation XVIII. V_t is determined by evaluating the group $f(N_t)$ on the L.H.S. of equation XVIII, and using the line for the group $U_L \Delta t_{ai} / q_{abs}$, reading the value for N_t from figure 11; then $V_t = (U_L F' L_c / \rho_t X_w C_p) / N_t$. The use of figure 11 will be illustrated in the example below.

Normally, several iterations are required to obtain the correct values for U_L and F' in these expressions. Quite often an approximate value for V_t is satisfactory for preliminary designs. The following values are suggested for estimates:

Figure 11. Chart for Calculating Solar Chimney Performance

<u>Number of Glazings</u>	<u>U_L</u>	<u>F'</u>
1	1.4	0.64
2	0.8	0.8
3	0.5	0.84

Example:

Determine the amount of ventilation air which can be provided by a solar chimney 16' high by 8' wide, with a 6" airflow space between the absorber and glazing if the outside temperature is 100°F and the entering air is 75°F. Take $\Sigma K = 3$, $q_{abs} = 200$ Btu/sq ft hr and from the above table, $U_L = 1.4$ Btu/(sq ft)hr°F and $F' = 0.64$.

For a first estimate, take $\rho_t = 0.074$ lb/cu ft.

$$(U_L F' L_c / \rho_t X_w C_p) = (1.4 \times 0.64 \times 16 / 0.074 \times 0.5 \times 0.24) = 1614 \text{ ft/hr}$$

$$(T_a \Sigma K / 2gZ) = [(460 + 100) \times 3 / 2 \times 32.2 \times (3600^2) \times 16] = 1.258 \times 10^{-7} \text{ } ^\circ R \text{ hr}^2/\text{ft}^2$$

$$(U_L / q_{abs}) = 1.4 / 200 = 0.007 / ^\circ F; (U_L \Delta t_{ai} / q_{abs}) = 0.007 \times (100 - 75) = 0.175$$

$$(U_L F' L_c / \rho_t X_w C_p) [(T_a \Sigma K / 2gZ) (U_L / q_{abs})]^{1/2} = 0.0479$$

From chart: $N_t = 0.37$

$$V_t = (U_L F' L_c / \rho_t X_w C_p) / N_t = 1614 / 0.37 = 4363 \text{ ft/hr or 73 fpm}$$

The calculation must be repeated until constant values of N_t and ρ_t are obtained.

$$F_R = (F' / N_t) (1 - \text{EXP} - N_t) = (0.64 / 0.37) \times (1 - e^{-0.37}) = 0.5349$$

$$q_u = F_R [q_{abs} - U_L (t_i - t_a)] = 0.5349 \times [200 - 1.4 \times (75 - 100)] = 125.71 \text{ Btu/sq ft hr}$$

$$G' = V_t \rho_t X_w / L_c = 4363 \times 0.074 \times 0.5 / 16 = 10.09 \text{ lb/sq ft hr}$$

$$\Delta t_c = q_u / G' C_p = 125.71 / 10.09 \times 0.24 = 51.9^\circ$$

$$\Delta t_c = q_u / G C_p = 125.71 / 10.09 \times 0.24 = 51.9^\circ$$

$$t_m = t_i + \Delta t_c \{ [1 / (1 - \exp(-N_t))] - 1 / N_t \} =$$

$$75 + 51.9 \times \{ [1 / (1 - e^{-0.37})] - 1 / 0.37 \} = 102.55^\circ$$

$$\text{New } \rho_t = [(75 + 460) / (102.55 + 460)] \times 0.074 = 0.07038 \text{ lb/cu ft}$$

$$(U_L F' L_c / \rho_t X_w C_p) = 1614 \times (562.55 / 535) = 1698 \text{ ft/hr}$$

$$(U_L F' L_c / \rho_t X_w C_p) [(T_a \Sigma K / 2gZ)(U_L / q_{\text{abs}})]^{1/2} =$$

$$0.0479 \times (562.55 / 535) = 0.0504$$

From chart: $N_t = 0.37$ (unchanged)

Solution: $V_t = 1698 / 0.37 = 4588 \text{ ft/hr}$ or 76.5 fpm

Airflow = $76.5 \times 0.5 \times 8 = 306 \text{ cfm}$ at 102.6°F or 291 cfm at 75°F

Where a substantial number of solar chimney designs are to be examined, it is worth the effort to write a computer program to solve equation XVIII. After squaring both sides of the equation, it can be solved by Newton's method.

Solar dryers for agricultural products often separate the chimney from the solar collector as shown in figure 10 and discussed by Zambrano and Alvarado (1984). The material to be dried is placed in a horizontal collector while the moisture and warm air are removed by a simple vertical chimney at one end of the collector. The chimney can be treated as a heat exchanger with a capacity rate ratio of zero; see Kays and London (1958) for a detailed treatment of this type of exchanger. The number of transfer units for the chimney is:

$$N_{tc} = A_{Lc} U_c / V_t A_t \rho_t C_p \quad (\text{XIX})$$

where A_{Lc} is the area of the chimney for heat losses; U_c is the overall heat transfer coefficient for losses; and A_t is the cross-sectional flow area. When combined with the chimney equation and the effectiveness-NTU relationships from Kays and London (1958), an expression results which can be used with figure 12 to determine the hot airflow in a non-isothermal chimney:

$$\frac{U_c A_{Lc}}{\rho_t A_t C_p} \sqrt{\frac{T_d \Sigma K U_L}{2gZ q_{abs}}} \quad \text{or} \quad \frac{U_c A_{Lc}}{\rho_t A_t C_p} \sqrt{\frac{T_d \Sigma K}{2gZ (t_i - t_d)}}$$

for $U_L A_{sc} F' / U_c A_{Lc} \rightarrow \infty$

Figure 12. Chart for Horizontal Solar Collector - Vertical Chimney Performance

$$(A_{Lc}U_c/A_t\rho_tC_p)[(T_a\Sigma K/2gZ)/(t_i-t_a)]^{\frac{1}{2}} = [N_{tc}(1-EXP-N_{tc})]^{\frac{1}{2}} \quad (XX)$$

The L.H.S. of equation XX is evaluated first, N_{tc} obtained from figure 12, and the velocity computed as: $V_t = A_{Lc}U_c/A_t\rho_tC_pN_{tc}$. Figure 12 and equation XX can also be used to determine the non-isothermal airflow in an evaporatively cooled downdraft chimney by replacing (t_i-t_a) with (t_a-t_t) , provided the tower walls are dry. Expression XX can be combined with the solar collector equations to yield an equation for the collector-chimney combination, where $t_i = t_a$:

$$(A_{Lc}U_c/A_t\rho_tC_p)[(T_a\Sigma K/2gZ)/(q_{abs}/U_L)]^{\frac{1}{2}} = [N_{tc}(1-EXP-N_{tc})[1-EXP-(A_{sc}U_LF^*/A_{Lc}U_c)N_{tc}]]^{\frac{1}{2}} \quad (XXI)$$

Figure 12 is a plot of equation (XXI) for different values of $(A_{sc}U_LF^*/A_{Lc}U_c)$, where A_{sc} is the solar collector area. The curve for equation (XX) on figure 12 is that for $(A_{sc}U_LF^*/A_{Lc}U_c) \rightarrow \infty$, with (t_i-t_a) replacing (q_{abs}/U_L) in the abscissa expression. Note that ΣK must include resistance for both the solar collector and chimney.

A small solar chimney, shown in figure 2, was constructed and tested inside an empty greenhouse to avoid wind. The chimney was constructed of 3/4-inch plywood, 4 ft wide x 14 ft long (approximately 7% shaded by structural members), painted flat black, and insulated on the bottom with 1 inch of styrofoam. The airflow channel between the black absorber and first glazing was 6 inches deep ($X_w = 0.5$); from one to three layers of 12-mil polyethylene glazing, 6 inches apart, could be mounted above the absorber. The height of the chimney (Z) was varied by changing the angle of inclination of the assembly with the horizontal; that is, raising or lowering one end. Table 1 gives the results of these tests. The absorbed radiation was estimated as the difference between incident and reflected solar radiation on the plane of the assembly. Since the losses through the back of the chimney are significant, the equations of Parker (1979) are used to compute U_L and F^* :

$$U_L = U_b + U_t(U_b + h_c + 2h_r)/(U_t + h_c + 2h_r) \quad (XXII)$$

$$F' = \left\{ 1 + \frac{U_b + [U_t U_b + h_r(U_b + U_t)]/h_c}{U_t + h_c + 2h_r} \right\}^{-1} \quad (\text{XXIII})$$

Where h_c is the convective heat transfer coefficient between the moving air stream and the absorber plate, as well as the air stream and innermost glazing; h_r is the radiative heat transfer coefficient between the absorber plate and innermost glazing; U_b is the overall coefficient for losses through the rear or bottom, or from the absorber to the outside air and surroundings; while U_t is the overall coefficient from the innermost glazing to the outside, Btu/(sq ft) in $^{\circ}\text{F}$. See Agarwal and Larson (1981) for methods which may be used to compute U_t .

The results of the solar chimney tests are shown in Table 1. Unfortunately, these tests were complicated by the existence of fairly substantial temperature gradients in the greenhouse; for this reason two ambient air temperatures are given in Table 1, near the top and bottom of chimney. For the calculated air velocities in the table the average air temperature was used, with Δt_{ai} taken as zero. Note that the agreement between computed and experimental velocities is only fair.

Table 1

SOLAR CHIMNEY TEST RESULTS

$L_c = 14$ ft (13 ft effective); $Z = 14$ sin (angle with horizontal); $X_w = 0.5$ ft.

$U_b = 0.18$ Btu/(sq ft) hr $^{\circ}\text{F}$; $\Sigma K \approx 2.4$; Glazing material: 12-mil polyethylene.

Number of Covers	Ambient Temperature, $^{\circ}\text{F}$		Absorbed Insolation Btu/ft hr	Angle with Horizontal, $^{\circ}$	Air velocity, ft/min	
	Bottom	Top			Measured	Calculated
1	91.4	102.2	214	55	146	143
1	98.6	112.1	216	44.4	149	134
1	105.8	119.3	174	44.4	142	122
2	91.4	104.0	198	55	141	150
2	98.6	105.8	179	44.4	136	135
3	96.8	109.4	149	55	125	138
3	98.6	109.4	130	55	147	131
3	105.8	116.6	146	44.4	137	128

WIND AND TOWER PERFORMANCE

The influence of wind on the tower shown in figure 9(A), having a pad on one face will be considered first. If the wind is normal to the pad, the tower operation will be nearly the same as that of a tower with pads on four sides equipped with gravity dampers, such as those illustrated in figure 13, which requires a term for pressure loss across the damper (K_d). Equation I will be employed, with the correction for wind flow through a low resistance surface included (Appendix B). Because the correction does not apply in the absence of wind, a factor R will be used in association with the correction terms, which will be zero in the absence of wind, and equal to one when the wind is substantial. There is a region of low wind velocities for which the value of R is presently not known; in these calculations the term $R = H_w/(H_w + H_d)$ was used, or the ratio of the wind velocity head ($H_w = \rho_a V_w^2 / 2g_c$) to the sum of the wind velocity head and density head in the tower ($H_d = gZ\Delta\rho/g_c$). Figure 14 is plot of R against the Froude number ($V_w/\sqrt{gZ}$), for different values of $\Delta t/T_a$, where Δt is the temperature difference between outside air and the mean air temperature in the tower, and T_a is the absolute ambient air temperature. The correction is most significant when ΣK is small. Equation I then becomes:

$$V_t = V_w \sqrt{\{\Delta C_{wp} + (C_f \Delta t_w / T_a) [(2gZ/V_w^2) - \Delta C_{wp}]\} / \Sigma K} \quad (XXIV)$$

$$\Sigma K = (K_p + K_d + RC_w)(A_t/A_p)^2 + 1.3(A_t/A_p) + (\Sigma K)_t - RC \quad (XXV)$$

where C_w is the windward wind pressure coefficient, for wind normal to the pad; C is the wind pressure coefficient at the outlet from the tower or connected structure, $\Delta C_{wp} = C_w - C$, and $(\Sigma K)_t$ is the sum of the pressure loss coefficients down the length of the tower and other losses at the outlet or within an associated structure.

To illustrate the effect of wind and discharge pressure coefficient, the tower shown in figure 15 will be used, which is installed on a home in Tucson. The tower has an effective height of approximately ten feet, with the pad area (on one face) approximately equal to the tower cross-sectional area, roughly 12 sq ft. There is no solar chimney on this structure; the tower discharges into

Figure 13. Diagram of Cloth (Barometric) Dampers

Ratio of Wind Velocity Head to Total Head

$$R = H_w / (H_w + H_d)$$

Figure 14.

Figure 15. Test House with Cool Tower — Tucson, Arizona

the house in an opening in the kitchen ceiling, and the exhaust air may be discharged through several possible openings, the preferred being a zaguan immediately adjacent to the kitchen, which is connected by a door of 16.5 sq ft open area. With $(\Sigma K)_t = 1.77$ and $C_w = 0.9$, equations XXIV and XXV give the curves for normal flow on figure 16, when the pressure coefficient at the outlet is varied from -1 to +1. Note that when $C = +1$, flow down the tower ceases when the velocity head of wind acting up the tower is large enough to overcome the density head. Similarly, if the wind flow is at a 45° angle to the tower, and the rear pads are closed, the second series of curves on figure 16 are obtained. For the diagonal flow case with gravity dampers equation XXIV also applies, but:

$$\Sigma K = 0.25 (K_p + K_d + RC_w)(A_t/A_p)^2 + 0.65(A_t/A_p) + (\Sigma K)_t - RC \quad (XXVI)$$

In the diagonal case $C_w = +0.54$ with $(\Sigma K)_t$ unchanged. The curves for the diagonal case are usually above the case for flow perpendicular to the face due to the greater inlet area; however for $C = +1$, flow stops at a lower wind velocity because C_w is lower.

In figure 16 the dampers are considered fixed even at the zero wind condition for illustrative purposes. When the dampers are allowed to swing freely, the curves given by figure 17 will result. At low wind velocities the dampers are open and airflow is through all four sides, as the wind velocity increases the pressure is reduced at the rear and/or side pads, the dampers shut, and air flow is only through the pads with positive pressure coefficients.

In those tower designs where the designer knows that the pressure coefficient at discharge will be favorable, due to the direction of the prevailing winds, or when a solar chimney is used for the outlet, with $C = -1$, the gravity damper may be omitted. In such a case a baffle in the "X" shape, connecting the top interior corners is sometimes employed, to reduce the airflow directly between the windward and leeward pads. The presence of multiple outlets makes the tower design more difficult to analyze. Consider first the case where the direction of wind flow is diagonal to the tower; at low wind velocities there are effectively two inlets, the two windward and the two leeward pads, and a single outlet, either at the tower base, or from the structure or solar chimney; at higher velocities the direction of flow will reverse through the leeward pads, and a condition will exist where there are now two outlets and a single inlet. In the low wind case:

Tower Performance with Gravity Dampers

Dampers Fixed in Closed Position at Rear and/or Sides
 $A_p=12.18$, $A_t=11.82$ sq ft, $Z=9.85$ ft, $T_a=100$, $T_{wb}=70$ deg F

Figure 16.

Tower Performance with Gravity Dampers

Dampers Free to Open or Close
 $A_p=12.18$, $A_t=11.82$ sq ft, $Z=9.85$ ft, $T_a=100$, $T_{wb}=70$ deg F

Figure 17.

Effect of Discharge Pressure Coefficient on Tower Performance

Ap=12.18, At=11.82 sq ft, Z=9.85 ft, Ta=100, Twb=70 deg F

Figure 18.

$$m_t = m_i + m_l \quad (\text{XXVII})$$

where m_t is the low rate of dry air through the tower, m_i is the rate of flow into the windward pads, and m_l is the flow in the leeward pads, lb_{dry} air/sec. The equation relating flow between the windward pads and the outlet is:

$$(\Sigma K)_i H_i + (\Sigma K)_t H_t = C_w(H_w - RH_i) - C(H_w - RH_t) + H_d \quad (\text{XXVIII})$$

where $H_i = \rho_i V_i^2 / 2g_c$, $H_t = \rho_t V_t^2 / 2g_c$, $H_w = \rho_a V_w^2 / 2g_c$, and $H_d = (g/g_c)Z\Delta\rho$; V_i, V_t , and V_w are the air velocities through the windward pads, down the tower, and the wind; ρ_i , ρ_t , and ρ_a are the densities of air leaving the windward pads, in the tower, and of the outside air. Z is the effective tower height and $\Delta\rho$ is the density difference between air in the tower and the outside air; if a solar chimney is present H_d must be modified accordingly. $(\Sigma K)_i$ is the summation of loss coefficients associated with the inlet, $K_p + 5.2(A_p/A_t) + 4(A_p/A_t)^2$. The equation for flow through the leeward pads is similar:

$$(\Sigma K)_l H_l + (\Sigma K)_t H_t = C_l(H_w - RH_l) - C(H_w - RH_t) + H_d \quad (\text{XXIX})$$

where $H_l = \rho_l V_l^2 / 2g_c$, with ρ_l and V_l the density and velocity of air leaving the leeward pads. C_w , C_l , and C are the windward, leeward, and outlet wind pressure coefficients. $(\Sigma K)_l$ is equal to $(\Sigma K)_i$ from the previous equation.

At higher wind velocities, equation XXVII becomes:

$$m_i = m_t + m_l \quad (\text{XXX})$$

and equation XXIX must be rewritten:

$$(\Sigma K)_i H_i + (\Sigma K)_{l0} H_l = C_w(H_w - RH_i) - C_l(H_w - RH_l) \quad (\text{XXXI})$$

The term $(\Sigma K)_{l0}$ is the loss coefficient for reverse flow out the rear pads, $K_p + 5.2(A_p/A_t) + 32(A_p/A_t)^2$. See Appendix A for the loss coefficients relating to the baffle and flow reversal in the tower.

The equations must be solved simultaneously for the low and high wind velocity cases. A similar set of equations may be derived for flow normal to the tower face, however, at least one additional equation will be required for flow through the side pads.

Figure 18 shows the effect of the discharge wind pressure coefficient on the figure 15 tower performance without the gravity dampers. If $C > 0$, with the wind normal to the face, the tower will cease to operate at 4-5 mph, to the distress of any occupants.

The question of the proper pad area for these towers often arises. Figure 19 shows the effect of increasing the pad area by up to three times. Note that only a slight increase in velocity is obtained.

Figure 20 shows the effect of increasing the length of the interior baffle down the entire length of the tower. There is little improvement in tower performance, however, abrupt "steps" appear in the curves when flow reversal occurs.

Since there are a number of different wind pressure coefficients found in the literature for geometries similar to the top of the tower, in particular for flow perpendicular to the tower face, which is the most critical case, a sensitivity analysis was performed. The three selected for comparison are:

Bahadori (1981):

Sakamoto (1985):

BSI (1972):

Figure 21 shows the calculated tower velocity plotted against wind velocity for three different values of the outlet wind pressure coefficient and the tower coefficients from above. Note that all of the three sets of pressure coefficients predict that the tower will stall for an outlet coefficient of zero, in the range of 4-7 mph.

Figure 22 illustrates the calculated water evaporation rate from the tower shown in figure 15 for the two curves labeled $C = -1$ on figure 18. "Lost" water is that which is evaporated into air streams which do not enter the house. The use of gravity (barometric) dampers or a cloth baffle reduces the losses substantially.

Pad Area and Tower Performance
 $A_p = A_o = 12.18$, $A_t = 11.82$ sq ft, $Z = 9.85$ ft
 $T_a = 100$, $T_{wb} = 70$ deg F

36

Figure 19.

Pad Area, Baffle Length and Tower Performance
 $A_p = A_o = 12.18$, $A_t = 11.82$ sq ft, $Z = 9.85$ ft
 $T_a = 100$, $T_{wb} = 70$ deg F

37

Figure 20.

Effect of Wind Pressure Coefficients from Various Sources

Ap=12.18, At=11.82 sq ft, Z=9.85 ft, Ta=100, Twb=70 deg F

Figure 24.

Tower Evaporation Rate

$A_p = 12.18$, $A_t = 11.82$ sq ft, $Z = 9.85$ sq ft
 $T_a = 100$, $T_{wb} = 70$ deg F
 $C = -1$, $CW = +0.9$, $CI = -0.6$, $CS = -0.92$

Figure 22.

PHOTOVOLTAIC POWERED COOL TOWERS

There is a strong connection between photovoltaic (PV) powered buildings and cool towers (this term will be used to refer to the downdraft, evaporatively cooled towers discussed here). Often in the southwest the largest single electrical load in a building is the cooling system. By installing cool towers in place of conventional cooling systems, the building's electrical load can be substantially reduced; thereby increasing the attractiveness of PV power. This is especially true in remote locations where utility power is not available. The capital saved by purchasing fewer PV modules will more than pay for the cool tower. For example:

Assume that a 1/2-horsepower evaporative cooler is required to run 24 hours per day to meet the cooling load. The blower in the cooler would use approximately 500 watts for 24 hours, which is 12 kWh's per day. This would require 2000 peak watts of PV power, which would have a capital cost of \$11,000, if the purchase price was \$5.50/watt. A cooler of this size would deliver about 4,000 cfm and could be replaced by 6 ft by 6 ft cool tower costing \$3,000; and a 24-watt d-c powered pump would require enough panels to produce only 102 peak watts of PV power, with an initial cost of \$561. This system would operate during the night, with a small storage battery. There would also be another substantial capital savings in the reduction of the batteries required to run a standard evaporative cooler at night. This is a capital savings of greater than \$7,000 in a stand-alone system using a cool tower rather than an evaporative cooler. If refrigeration type cooling is replaced by a cool tower, the savings would be further increased.

Direct current pumps should be used with photovoltaic-powered cool towers because of their higher efficiencies. Small a-c pumps commonly use shaded pole-type motors which have typical efficiencies of 10 to 15%, while small d-c motors can be as high as 80%. Also an a-c to d-c inverter will be necessary to run an a-c motor from a pv-charged battery bank, which will further reduce the efficiency of the system.

ECONOMIC AND PERFORMANCE MODEL

Another computerized model was developed to evaluate the economics and performance of free-standing downdraft evaporative cooling towers. This program analyzes 35 different tower sizes at a time: five cross-sectional sizes, and seven tower heights. As a set of design tools for engineers and architects, several sets of graphs were generated with the model to analyze and optimize downdraft cooling towers, and can be used to evaluate the cooling performance of various sizes of downdraft cooling towers, as well as the economics in terms of first cost and payback period for different geographical locations, ambient conditions, and electricity prices. The model is for ground-mounted, frame-type construction that would be suitable for residential or commercial structures, and employs construction techniques and materials similar to those found in figures A-3 and A-4.

The model operates by generating a materials list for a specific size tower, and totaling the cost. Next it estimates the construction-labor cost by initially using a factor of 70% of the material costs and increases the labor percentage linearly as the height of the tower increases, due to the added expense of scaffolding, increased construction time, and higher wages for the more skilled labor required to work on tall structures. Concrete footing sizes are also increased with height and width, due to the increased wind loading of taller, wider towers; and therefore material costs are also proportionally larger for taller towers. The labor and material costs are totaled to give I_{ct} , the cool tower investment cost. The program then calculates the cooling capacity in cfm (cubic feet of airflow per minute) for each of the 35 designs. It then determines the annual cost of an equivalent standard evaporative cooler with the following equation:

$$C_{st} = I_{cs}/n + C_e + C_m$$

where:

C_{st} = Annual cost of a standard evaporative cooler

I_{cs} = Initial investment for a standard evaporative cooler

n = Number of years service life (6 for this study)

C_e = Annual electricity expenses

C_m = Annual maintenance expenses

The annual cost of the cool tower can be found from:

$$C_{ct} = C_m + C_e + C_{pt}$$

where:

C_{ct} = Annual cost of a cool tower

C_m = Annual maintenance cost

C_e = Annual electricity expenses

C_{pt} = Annual parts replacement parts expenses

I_{ct} was not included in the C_{ct} equation because the C_{pt} term includes periodic replacement of all the parts that contact water (pan, pad holders, pumps, and plumbing). The tower framework is part of the structure, and should last as long as the building.

The annual savings realized by using a cool tower over a conventional system is then found by:

$$P = C_{st} - C_{ct}$$

where:

P = Net annual savings

Now the payback period can be determined by:

$$T = I_{ct}/P$$

where:

T = Payback Period without interest in years

I_{ct} = cool tower initial cost

We have not used the equation for payback period with interest (i), in which the term I_{cs}/n in the equation for C_{st} above would be replaced with $I_{cs}[i(i+1)^n/(i+1)^n-1]$, because of the large variations in interest and inflation rates during the last decade.

Five different cross-sectional areas were chosen for this study: 4 foot square to 12 foot square in increments of two feet; with seven tower heights: 14 foot to 50 foot tall in 6 foot increments. This represents airflow rates from 1,200 cfm to 34,000 cfm, for design conditions in Tucson, Arizona. A typical 1500-square-foot residence structure, with 8-foot ceilings would require from 4,000 to 6,000 cfm of evaporatively cooled air to meet the cooling load; based upon an air change every two to three minutes. This is a quick method to size evaporative coolers that is commonly used in the trade; a more precise method

of sizing can be used by calculating the heat gain to the space, and picking an acceptable temperature rise through the space to be cooled as described by Watt (1986).

Results of the economic and performance model are shown in graphs found in figures 23 through 72. ASHRAE (1978) summer design conditions for wet and dry bulb temperatures that were used are given in table 2, with residential electricity prices from Tucson Electric Power Co. (based upon the 1987 residential rate with a usage of 500 kwh per month.)

Table 2
DEFAULT GRAPH PARAMETERS

<u>Location</u>	<u>Dry Bulb °F</u>	<u>Wet Bulb °F</u>	<u>\$/kWh</u>
Tucson, Arizona:	104	66	.075
Phoenix, Arizona:	109	71	.094
Albuquerque, New Mexico:	96	61	.094
Las Vegas, Nevada:	108	66	.057
Palm Springs, California:	112	71 (not available)	

All graphs, unless otherwise noted, are for Tucson, Arizona with the conditions for wet and dry bulb listed above. Other default conditions for the graphs are: 0 mph wind; $\Sigma K = 6$; 4-inch-thick pad; \$.075/kwh; cooling on 24 hours per day, 120 days per year. The effective pad height for all of the cool towers in this model is one-half of the tower width.

Total tower heights, as shown on the graphs, should not be confused with the effective tower height. In the following sets of graphs, the effective height is calculated by subtracting the pad height (one-half the tower width in this case) and the opening height at the tower's base. The opening height is equal to the tower width, with a maximum of 6 feet; that is, 6-foot-high openings were used on the 6, 8, 10 and 12-foot-wide towers. Width dimensions shown on the graphs are total outside measurements; to obtain the inside or effective area of the tower, 0.5 feet must be subtracted from each side to correct for wall thickness.

The first graph (figure 23) is a plot of tower construction cost against airflow rate and can be used to find the optimum tower size for a given airflow

rate. For example, if 14,000 cfm is needed in Tucson, Arizona, there are three tower sizes that will work: an 8 foot by 8 foot by 50 feet tall, for \$11,000, a 10 foot by 10 foot by 26 feet tall for \$6,500, or a 12 foot by 12 foot by 20 feet high for \$7,000. Therefore the optimum size in terms of first cost is the 10 foot-square tower by 26 feet tall for \$6,500.

The first and second sets of graphs (figures 24 through 33) are for determining the effects of the total resistance to airflow (ΣK) on the payback period and airflow. These figures are plots of payback period versus tower height, with the ΣK values ranging from 4 to 12, in increments of 2. Cool towers that are not connected to buildings (such as outdoor wind-sheltered cooling applications) have a ΣK of approximately 4, while typical building-connected installations have ΣK values of 6 or greater depending upon the design. It is not recommended that cool towers be connected to conventional duct systems that were sized for high-velocity air because the large number of fittings and long runs of small diameter ducts will create a higher resistance to airflow.

An inspection of this series reveals an economic optimum height of about 26 feet for all cross-sections except the 4 ft by 4 ft towers. Table 3 is a summary of the graphs, and compares only the 8 ft wide by 26 ft tall towers. The importance of a low ΣK is evident in the rapidly increasing payback period and decreasing airflow.

Table 3
EFFECTS OF ΣK ON ECONOMICS AND AIRFLOW

ΣK	<u>Payback Period</u>	<u>Airflow, cfm</u>
4	4.0	11822
6	5.2	9779
8	6.3	8545
10	7.3	7659
12	8.3	7062

Figures 34 through 38 show the effects of pad thickness on economics for Tucson. Each graph represents a different cross-sectional area and includes data for 3, 4, 6, and 8-inch-thick pads. The graphs illustrate that there is almost no difference between the 3 and 4-inch pads in terms of payback economics. But

COOL TOWER COST AND PERFORMANCE MODEL

Figure 23.

EFFECT OF ΣK ON ECONOMICS

46

Figure 24.

EFFECT OF ΣK ON ECONOMICS

Figure 25.

EFFECT OF ΣK ON ECONOMICS

47

Figure 26.

EFFECT OF ΣK ON ECONOMICS

Figure 27.

EFFECT OF ΣK ON ECONOMICS

48

Figure 28.

EFFECT OF ΣK ON AIRFLOW

Figure 29.

EFFECT OF ΣK ON AIRFLOW

49

Figure 30.

EFFECT OF ΣK ON AIRFLOW

Figure 31.

EFFECT OF ΣK ON AIRFLOW

50

Figure 32.

EFFECT OF ΣK ON AIRFLOW

Figure 33.

EFFECT OF PAD THICKNESS ON ECONOMICS

51

Figure 34.

EFFECT OF PAD THICKNESS ON ECONOMICS

Figure 35.

EFFECT OF PAD THICKNESS ON ECONOMICS

52

Figure 36.

EFFECT OF PAD THICKNESS ON ECONOMICS

Figure 37.

EFFECT OF PAD THICKNESS ON ECONOMICS

53

Figure 38.

EFFECT OF LOCATION ON ECONOMICS

Figure 39.

EFFECT OF LOCATION ON ECONOMICS

54

Figure 40.

EFFECT OF LOCATION ON ECONOMICS

Figure 41.

EFFECT OF LOCATION ON ECONOMICS

55

Figure 42.

EFFECT OF LOCATION ON ECONOMICS

Figure 43.

EFFECT OF LOCATION ON ECONOMICS

56

Figure 44.

EFFECT OF LOCATION ON ECONOMICS

Figure 45.

EFFECT OF LOCATION ON ECONOMICS

57

Figure 46.

EFFECTS OF LOCATION ON AIRFLOW

Figure 47.

EFFECTS OF LOCATION ON AIRFLOW

58

Figure 48.

EFFECTS OF LOCATION ON AIRFLOW

Figure 49.

EFFECTS OF LOCATION ON AIRFLOW

59

Figure 50.

EFFECTS OF LOCATION ON AIRFLOW

Figure 51.

EFFECTS OF LOCATION ON AIRFLOW

60

Figure 52.

EFFECTS OF LOCATION ON AIRFLOW

Figure 53.

EFFECTS OF LOCATION ON AIRFLOW

61

Figure 54.

EFFECTS OF LOCATION ON AIRFLOW

Figure 55.

EFFECT OF HOURS USED ON ECONOMICS

62

Figure 56.

EFFECT OF HOURS USED ON ECONOMICS

Figure 57.

EFFECT OF HOURS USED ON ECONOMICS

63

Figure 58.

EFFECTS OF PAD THICKNESS ON TEMPERATURE

Figure 59.

EFFECTS OF PAD THICKNESS ON TEMPERATURE

64

Figure 60.

EFFECTS OF PAD THICKNESS ON TEMPERATURE

Figure 61.

EFFECT OF LOCATION ON TEMPERATURE

Phoenix, Arizona, 4 in. Pad

65

Figure 62.

EFFECT OF LOCATION ON TEMPERATURE

Phoenix, Arizona, 6 in. Pad

Figure 63.

EFFECT OF LOCATION ON TEMPERATURE

66

Figure 64.

EFFECT OF LOCATION ON TEMPERATURE

Figure 65.

EFFECT OF LOCATION ON TEMPERATURE

Albuquerque, New Mexico, 3 in. Pad

67

Figure 66.

EFFECT OF LOCATION ON TEMPERATURE

Las Vegas, Nevada, 4 in. Pad

Figure 67.

EFFECT OF LOCATION ON TEMPERATURE

68

Figure 68.

EFFECT OF LOCATION ON TEMPERATURE

Figure 69.

EFFECT OF LOCATION ON TEMPERATURE

69

Figure 70.

EFFECT OF LOCATION ON TEMPERATURE

Figure 71.

EFFECT OF LOCATION ON TEMPERATURE

70

Figure 72.

there are increasingly larger differences between the 4 and 6-inch pads, and between the 6 and 8-inch pads. Thinner pads usually have the shorter payback periods. Pad manufacturers do not recommend cutting pads down to 3 inches thick, as it may shorten the life of the pad. Pads can be purchased in any thickness from 4 to 12 inches.

Figures 39 through 46 show the effects of pad thickness on economics at different geographic locations, and figures 47 through 55 show the effects of pad thickness and location on airflow. Payback periods for four other southwestern cities are plotted against tower height. The cities included in this series are: Phoenix, Arizona, Albuquerque, New Mexico, and Las Vegas, Nevada. ASHRAE (1978) summer design conditions for wet and dry bulb temperatures and the electrical energy prices are listed above. Table 4 is included as a summary of pad thickness and geographical location, and compares only data on the 8 ft by 8 ft by 26 ft tall towers.

Table 4
EFFECTS OF LOCATION AND PAD THICKNESS
ON ECONOMICS AND AIRFLOW

	<u>Pad Thickness</u>	<u>Payback Period</u>	<u>Airflow, cfm</u>
Tucson:	3	5.1	9500
	4	5.2	9776
	6	5.9	9672
	8	7.2	9111
Phoenix:	4	4.8	9739
	6	5.4	9632
	8	6.5	9071
Las Vegas:	4	5.4	10213
	6	6.2	10112
	8	7.5	9532
Albuquerque:	4	4.9	9474
	3	4.9	9207

Pad thickness seems to have almost no effect on airflow, and differences are so slight that they are hard to detect from the graphs. As pad thickness increases, the resistance to airflow and the evaporation effectiveness increase

together, thus canceling each other. This was illustrated earlier in figures 7 and 8. However increasing pad thickness does have a noticeable effect on the payback period and the temperature. The effects on temperature are discussed later in this report. This set shows that cool towers will work well in all of the cities represented, or in any location that has similar design conditions.

Figures 56 through 58 show the results of changing the number of hours per day that the cooling system is on. Cases were run for 12, 18, and 24 hours per day for a 120-day cooling season in Tucson, Arizona. As expected, the payback period decreases as the number of hours per day of usage increases. The payback period increases only slightly from 5.2 to 5.8 years as the number of hours are changed from 24 to 18. At 12 hours per day the payback period becomes 6.5 years.

Theoretical temperature performance was also plotted against tower height for several geographical locations and pad thicknesses to give an indication of comfort. These are found in figures 59 through 72. Note that there is a strong correlation between pad thickness and output temperature. For Tucson, Arizona a 4-inch-thick pad is adequate, but in Phoenix, Arizona or Palm Springs, California a 6 or an 8-inch-thick pad is more desirable to reduce the output temperatures down into an acceptable range; while Albuquerque, New Mexico can be comfortable with a 3-inch pad. Output temperatures increase with tower height due to the decreasing effectiveness caused by the increasing velocity through the pad. Pad thickness seems to have almost no effect on the terminal air velocity in the tower, as previously discussed. Hence, a thicker pad will deliver nearly the same quantity of air at a cooler temperature. However, there is an economic optimum for pad thickness, as can be seen in the graphs. Table 5 was prepared as a summary of the output temperature data found in the graphs.

Table 5
EFFECTS OF PAD THICKNESS ON TEMPERATURE AND CFM

	<u>Pad Thickness</u>	<u>Temperature</u>	<u>Airflow, cfm</u>
Tucson:	3	77.8	9500
	4	74.2	9776
	6	70.1	9672
Phoenix:	4	79.2	9739
	6	75.0	9632
	8	73.0	9071
Las Vegas:	4	75.3	10213
	6	70.6	10112
	8	68.3	9532
Albuquerque:	4	68.5	9474
	3	71.7	9207

GREENHOUSE COOLING

During the spring of 1986 a well-instrumented, 2300-square-foot double polyethylene greenhouse was retrofitted with a push-pull type passive cooling system. A 25-foot-tall evaporative downdraft tower was built on the south end, and a 15-foot-tall solar chimney-exhaust on the north (figure 73). Both chimneys extend 8 feet beyond the end of the greenhouse and are the full 24 foot width of the greenhouse. The cooling tower was also glazed with double polyethylene, to minimize the shading of the house, and the solar chimney was covered with black polyethylene on its north side to absorb the sunlight which was transmitted through the clear fiberglass on the south side. A complete set of drawings for this greenhouse is included in the appendix (figures A-6 through A-12).

Data were taken on the original prototype greenhouse during the fall of 1985 and the summer of 1986. This work has been discussed by Cunningham and Thompson (1987). Results show that the prototype cooling system is capable of achieving temperatures inside the greenhouse that are 14°F below ambient, with air velocities of 50 to 100 ft/min. Performance of the original design is

Figure 73. ERL's Prototype Greenhouse with Cool
Tower in Foreground

acceptable about 80% of the time. Note that on figure 74 there is an occasional morning during which the airflow is not self-starting, and the stagnated condition causes a temporary rise in temperature until the early afternoon when the flow starts and the temperature drops. Data show that this occurs when the humidity is higher and the downdraft chimney is less effective. Analysis of wind pressure coefficients and the data has shown that a long, rectangular-shaped intake chimney is not effective when the direction of the wind is toward the narrow side of the tower. Future downdraft chimneys should be built square rather than rectangular for optimum performance.

During the spring of 1987 the height of the solar chimney was raised from 15 feet to 25 feet (figure 75), in order to correct the difficulty of reverse flow during morning hours. Now both the downdraft and updraft towers are equal in height, causing the flow to move in the proper direction during the previously critical times when the humidity was higher, or when the wind was impinging on the narrow side of the tower.

Greenhouse performance data for the summer of 1987 can be found in figures 76 to 79. The data show that after the solar chimney was raised, the problem of stagnation and reverse flow that was experienced during the previous summer did not recur. On August 3, 1987 (figure 78) the performance graph shows that temperatures inside the greenhouse rose to 7°F above the ambient during a time when the pump was being serviced and the pads were dry. It is significant to note that on a clear summer day without the cooling system in operation, temperatures inside the greenhouse do not exceed 110°F, while ambient temperatures were 103°F; this is due to the natural ventilation provided by the two chimneys. A conventional greenhouse with a cooling failure would most likely experience maximum temperatures near 140°F, which would severely damage most greenhouse crops. Natural draft cooling systems have a higher reliability as a plant life-support system, since crops in a natural draft greenhouse are more likely to survive a power failure or a mechanical breakdown.

Drawing A-13 (appendix) is the authors' concept of the next generation of natural-draft-cooled greenhouses. The new design has been shortened to 75 feet instead of 100 to give it a lower Δt across the greenhouse. Another difference in the new design is that the towers are square instead of rectangular as in our prototype. The new design has a rigid "X" baffle that has extended wings on

COOL TOWER GREENHOUSE PERFORMANCE

June, 1986

Figure 74. Greenhouse With 15 Foot Exhaust Tower

Figure 75. Greenhouse Solar Chimney Extended to 25 ft. Tall; 1987

COOL TOWER GREENHOUSE PERFORMANCE DATA

78

June 26 to July 5, 1987

Figure 76. Greenhouse With 25 Foot Exhaust Tower

COOL TOWER GREENHOUSE PERFORMANCE DATA

July 6 to 16, 1987

Figure 77. Greenhouse With 25 Foot Exhaust Tower

COOL TOWER GREENHOUSE PERFORMANCE DATA

79

Figure 78. Greenhouse With 25 Foot Exhaust Tower

COOL TOWER GREENHOUSE PERFORMANCE DATA

Figure 79. Greenhouse With 25 Foot Exhaust Tower

the corners to increase wind catchment area; although this could be replaced with cloth "sail" type of barometric or gravity dampers, similar to those used in some of the ancient middle eastern wind towers. The cloth type is hung from the top of the tower and prevents wind from leaving the leeward side of the tower by closing it off during windy conditions. This design should work favorably for any of the locations mentioned in the section on economics, or any place with similar wet and dry bulb temperatures.

RESIDENTIAL COOLING

The test structure chosen for this work is a well-insulated frame building with 1000 square feet of floor space (figures 3 and 4) and is part of ERL'S Passive Solar Village. The structure was retrofitted with a 6 ft by 6 ft by 25 feet tall downdraft evaporative cooling tower. The tower was built of 4-inch-thick frame walls with 1 inch of Styrofoam® insulation on the inside. At the top a 4-inch-thick wetted cellulose pad was used to cool the air. A plywood "X" baffle in the top acts to catch the wind and direct it downward. Two conventional 90-watt evaporative cooler pumps regulate water over the pads from a sump at the base of the pads. Make-up water is added and regulated with a float valve. Vertical pads were chosen over horizontal pads primarily because of the reduction in pumping requirements. A horizontal pad arrangement would require a larger pump with a sump at the base of the tower. Earlier consideration was given to a fog/mist type of system for humidification and cooling, but the idea was rejected due to the high pumping energy and control problems.

The solar chimney located on the opposite end of the house is also built of wood frame and plywood siding, but without insulation, and measures 11 ft by 4 ft by 25 ft tall. The entire roof and attic space is used as a solar collector to assist the solar chimney. All of the air from the building is exhausted through the ceiling into the attic, where it makes two passes due to a baffle down the center of the ridge (see figure 5) before exiting through the solar chimney. See figures A-3 through A-5 for construction details of the downdraft tower and solar chimney.

Performance data for this test structure were quite acceptable throughout the summer of 1985. A comfort analysis on the cooling of this building was discussed by Cunningham and Thompson (1986). The inside air temperature never exceeded 78°F during the summer, although the outside ambient temperature rose

to 110°F. Data for this structure are shown in figures 80 through 82. Figure 15 also shows a cool tower operating on a residence in Tucson, as previously described.

CONCLUSIONS

During this program the cooling and ventilating of a building and greenhouse using natural draft towers was demonstrated and data collected relating to their performance. Methods for designing and predicting the performance of the towers, as well as cost information, have been presented in this report.

The evaporatively cooled downdraft tower appears to be a relatively low-cost source of cooling which has apparently been overlooked or unappreciated in the past. In addition to the cooling of buildings, the towers have been used to cool wind-sheltered outdoor areas. A local restaurant plans to test them for cooling outside dining areas. Figure 83 illustrates a concept under consideration by the city of Phoenix for a civic plaza using towers over 100 feet tall.

Those readers considering the use of natural draft towers should keep their limitations in mind. As with other evaporative coolers, they consume water; however, the usage can be reduced with internal gravity dampers. Improper location of the ventilation air outlet relative to the wind direction can result in poor or unsatisfactory tower performance. When used to cool outdoor areas, one should appreciate that the tower air velocity is feeble relative to a modest breeze; even an area well sheltered from the wind may be uncomfortable under some conditions. However, when the system is properly designed and constructed, natural draft towers provide quiet, low-cost cooling with very little maintenance.

There remains considerable research to be performed. Indeed, much data collected during this program needs further analysis; computerized data collection often generates more information than can be examined in a reasonable time frame. Other publications resulting from this work can be expected in the near future. More research is needed to reliably predict wind and tower/structure performance, possibly in a large wind tunnel. Temperatures in the prototype greenhouse tested in this program were too high for most crops; further work is needed in this area. It is possible that additional research could eliminate the need for the recirculation pump.

COOL TOWER PERFORMANCE DATA

Figure 80. ERL's Residential Prototype Performance Data — June, 85.

COOL TOWER PERFORMANCE DATA

Figure 81. ERL's Residential Prototype Performance Data — July, 85.

COOL TOWER PERFORMANCE DATA

Figure 82. ERL's Residential Prototype Performance Data - August, 85.

Figure 83. Proposed Cool Towers for Downtown Phoenix, Arizona

APPENDIX A

APPENDIX A

Tests to Determine the Baffle Resistance to Airflow

Following literature surveys, which failed to reveal correlations for the pressure drop across the X-baffle used in the towers, or similar geometries, bench-scale tests were performed with rigid, smooth, fiberboard inserts in the tee of a 6-inch diameter, schedule 40 PVC pipe, as shown in figure A-1. The baffle actually extended one inch beyond the tee, into the connecting leg. Four series of tests were performed, two with flow parallel to one leg of the baffle, simulating the case of wind flow diagonal to the tower face, and two with flow into open angle of the baffle, for the case of flow perpendicular to the tower. In each of these geometries, airflow and pressure drop were measured for the cases of a 90° turn and for 180° through flow.

Simulates Flow Diagonal to Tower

Simulates Flow Normal to Tower Face

Figure A-1. Baffle Test Set-up

In correlating the data, information from Perry and Chilton (1973) was used for contraction and enlargement losses:

$$\text{For contraction: } \Delta p = (\rho V_s^2 / 2g_c) [2 + (V_l/V_s)] [1 - (V_l/V_s)] / 4 \quad (\text{A-I})$$

$$\text{For enlargement: } \Delta p = (\rho V_s^2 / 2g_c) [1 - (V_l/V_s)]^2 \quad (\text{A-II})$$

where V_s and V_l are the velocities in the smaller and larger conduits, respectively. Equation A-I resulted from fitting tabular data from Perry and Chilton (1973). Analysis of the data from the 90° turn cases indicated that the pressure drop across the baffle could be represented as:

$$\Delta p = 1.3(\rho V_s V_l / 2g_c) \quad (\text{A-III})$$

Note that if $V_s = V_l$, the expression is identical to that for flow through a 90° square or miter ell, op.cit. This expression was used for flow across the baffles entering and leaving the dead leg in the through flow case, with contraction and enlargement losses estimated as previously explained. Friction losses were negligible in these tests. The expression for the pressure drop during flow reversal in the dead leg is:

$$\Delta p = 7(\rho / 2g_c)(Q/A_p)^2 \quad (\text{A-IV})$$

where Q is the Volumetric airflow rate and A_p is the area of the conduit in which flow reversal occurs. The pressure drop and flow relationships for the two cases are:

$$\text{For the 90° turn: } \Delta p = (\rho / 2g_c) [(1.3V_s V_l) + (V_s - V_l)^2] = (\rho V_l^2 / 2g_c) \{ (1.3V_s/V_l) + [(V_s/V_l) - 1]^2 \} \quad (\text{A-V})$$

$$\text{or } K_1 = (1.3A_l/A_s) + [(A_l/A_s) - 1]^2 \quad (\text{A-VI})$$

if $A_l/A_s = 2$ (for $\rightarrow +$)*, $K_1 = 3.6$
or if $(A_l/A_s = 4$ (for $\rightarrow \downarrow$ x), $K_1 = 14.2$

* See flow diagram in figure A-1.

For the flow through case: $\Delta p = (\rho/2g_c)\{(1.3V_sV_1)+(V_s-V_1)^2+7(Q/A_1)^2+[(2+V_1/V_s)(1-V_1/V_s)/4]+(1.3V_s/V_1)\}$ (A-VII)

or $K_1 = 7+(2.6A_1/A_s)+[(A_1/A_s)-1]^2+0.25(1+2A_1/A_s)[A_1/A_s]-1$ (A-VIII)
 if $A_1/A_s = 2$ (for $\rightarrow + \rightarrow$), $K_1 = 14.45$
 or, if $A_1/A_s = 4$ (for $\rightarrow x \rightarrow$), $K_1 = 33.15$

Figure A-2 shows the results of these tests. The velocity is that of air in the 6-inch line entering the tee; while the lines represent the K_1 values, computed as described. Future work should include similar tests in which a portion of the flow is diverted after a 90° turn while the remainder flows through the baffle and out the rear. Wind tunnel tests should also be performed with a geometry more nearly approximating the actual baffle-tower combination.

Figure A-2

APPENDIX B

APPENDIX B

Wind Flow Through Low Resistance Surfaces

Early in these studies there was considerable uncertainty regarding the applicability of wind pressure coefficients to porous, low-resistance media, such as evaporative cooling pads or screens. For example, in the case of Celdek® (mfg. Munters, Fort Meyers, FL) pressure drop curves from the manufacturer's data were fitted closely by the equation:

$$\Delta p = K_p(\rho V^2/2g_c) \text{ where } K_p = 12.87x_p \quad (\text{B-I})$$

where V is the superficial air velocity through a pad of x_p ft thickness, ρ being the air density, while K_p is the loss coefficient. If a panel is mounted normal to a wind stream with velocity V_w , with a pressure coefficient difference between the front and rear of the panel of ΔC_{wp} , then:

$$K_p(\rho V^2/2g_c) = \Delta C_{wp}(\rho V_w^2/2g_c), \text{ or } V = (\Delta C_{wp}/K_p)^{1/2} V_w \quad (\text{B-II})$$

Note that from equation B-II, if $x_p \rightarrow 0$, then $V \rightarrow \infty$, clearly an impossible situation. For screens, Idel'chik (1960) gives:

$$K_s = 1.3(1-f) + [(1/f)-1]^2 \quad (\text{B-III})$$

where f is the fraction of open area of the screen. If the screen is treated in the same manner as the panel of evaporative cooling media, then

$$V = (\Delta C_{wp}/K_s)^{1/2} V_w, \text{ and a problem again arises when } f \rightarrow 1.$$

After some consideration, it appears that the pressure differential which is developed across the panel, Δp , is not given by $\Delta C_{wp}(\rho V_w^2/2g_c)$ but rather by

$$\Delta p = \Delta C_{wp}[(\rho V_w^2/2g_c) - (\rho V^2/2g_c)] \quad (\text{B-IV})$$

That is, the pressure differential developed depends on the velocity head of the wind less the velocity head of the air passing through the porous media, rather than the velocity head of the wind alone. Then equation B-II becomes:

$$V/V_w = [\Delta C_{wp}/(K + \Delta C_{wc})]^{1/2} \quad (B-V)$$

where K can be either K_p or K_s , depending on the surface.

This expression was tested in a flow laboratory using four six-inch-diameter disks: one solid, and three galvanized circular screens of mesh sizes 18 (insect screen), 8 and 4 per inch. The screens were placed in a six-inch-diameter line and their K values determined by measuring the pressure drop across the screen at varying airflow rates. The disks were then mounted in a free air stream and the ratio V/V_w determined for three different values for V_w . There was considerable variation in the velocity behind the disks caused by the eddies present, and the results were averaged. The solid disk was used to determine ΔC_{wp} , which was found to be 1.51, very near the literature value of 1.5 given by Newberry, et al. (1974). The results are summarized in Table B-1, and indicate that the correction described by equation B-V is approximately correct. However, it is not clear how the correction should be used if suction is applied to one side of the porous surface in addition to the wind pressure, as would occur in an operating downdraft tower.

Table B-I
FLOW THROUGH SCREENS IN AN AIR STREAM

Mesh	K	K, calculated	V/V_w	V/V_w , calculated	
<u>Size</u>	<u>Experimental</u>	<u>Equation B-III</u>	<u>Measured</u>	<u>Equation B-V</u>	<u>Equation B-II</u>
18	0.68	0.66	0.77	0.83	1.51
8	0.51	0.48	0.87	0.86	1.77
4	0.36	0.35	0.92	0.90	2.10

APPENDIX C

Construction Drawings

Figure A-4. ERL Prototype Cooling System Details

Figure A-5. Pad Mounting Details

Figure A-8. ERL Prototype Greenhouse Modification Details

Figure A-9. ERL Prototype Greenhouse Modification Details

Figure A-11. ERL Prototype Greenhouse Modification Details

Figure A-12. ERL Prototype Greenhouse Modification Details

Figure A-13. Proposed Layout For a Natural Draft Greenhouse

REFERENCES

- Agarwal, V. K. and D. C. Larson. 1981. Calculation of the Top Loss Coefficient of a Flat Plate Solar Collector. *Solar Energy*, Vol. 27, pp. 69-71.
- American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc. ASHRAE Handbook and Product Director, 1979 Fundamentals. New York, N.Y.: ASHRAE, 1978 pp. 31.25, 31.3, 5.4., 26.1-26.13.
- Aynsley, R. M., W. Melbourne, and B. J. Vickery. 1977. *Architectural Aerodynamics*. Applied Science Publishers, p. 203-217.
- Bahadori, M. N. 1978. Passive Cooling Systems in Iranian Architecture. *Scientific American*, Vol. 238, pp. 144-154.
- Bahadori, M. N. 1979. Natural Cooling in Hot Arid Regions. *Solar Energy in Buildings*. A. A. Sayigh, editor, Academic Press, New York, pp. 198-225.
- Bahadori, M. N. 1981. Pressure Coefficients to Evaluate Airflow Patterns in Wind Towers, *Proc. Intl. Passive and Hybrid Cooling Conf.*, Vol. I, Miami Beach, Fla. International Solar Energy Society, pp. 206-210.
- Bahadori, M. N. 1985. An Improved Design of Wind Towers for Natural Ventilation and Passive Cooling. *Solar Energy*. Vol. 35, pp. 119-129.
- Cunningham, W. A. and T. L. Thompson. 1987. Passive Greenhouse Cooling with Natural Draft Cooling Towers in Combination with Solar Chimneys. *Proceedings Twentieth Congress National Agricultural Plastics Associations*, Portland, Oregon.
- Cunningham, W. A. and T. L. Thompson. 1986. Passive Cooling with Natural Draft Cooling Towers in Combination with Solar Chimneys. *Proceedings Passive Low Energy Architecture (PLEA) 1986*, Pecs, Hungary.

Duffie, J. A. and W. A. Beckman. 1974. Solar Energy Thermal Processes. John Wiley & Sons, New York, p. 142, 147, 108-115, 164.

Handa, K. 1979. Wind Induced Natural Ventilation. Stockholm, Sweden: Swedish Council for Building Research.

Happel, J. 1958. Chemical Process Economics. New York: John Wiley & Sons, Inc., pp. 4-6.

Idel'chik, I. E. 1960. Handbook of Hydraulic Resistance, Gosudarstvennoe Energeticheskoe Izdatel'stvo, Moskva-Leningrad. Available in English from NTIS. U.S. Department of Commerce, Springfield, VA 22161. Document No. AEC-TR-6630. p. 327.

Karakatsanis, C., M. N. Bahadori, and B. J. Vickery. 1986. Evaluation of Pressure Coefficients and Estimation of Air Flow Rates in Buildings Employing Wind Towers. Solar Energy, Vol 37, pp. 363-373.

Kays, W. M. and A. L. London. 1958. Compact Heat Exchangers. McGraw Hill Book Co., Inc., New York, N.Y. p. 11.

King Faisal University and the University of Arizona. 1984. Passive Cooling Experimental Facility Design Analysis Study. Vol. I, Design Review Report. Soleras Subcontract No. 132-7370-11. pp. 72-92.

Klein, S. A. 1973. The Effects of Thermal Capacitance Upon the Performance of Flat-Plate Solar Collectors. M. S. Thesis, University of Wisconsin.

Moody, C. D., T. L. Thompson, and J. F. Peck. 1978. The Downdraft Chimney: Passive Evaporative Cooling for the Southwest. Tucson, AZ: Environmental Research Laboratory, University of Arizona.

Morrison, G. L. and D. B. J. Ranatunga. 1980. Thermosyphon Circulation in Solar Collectors. Solar Energy. Vol. 24, pp. 191-198.

Munters Corporation, P. O. Box 6428, Ft. Myers, Florida 33901.

Newberry, W. C. et al. 1974. Wind Loading Handbook. London: Department of the Environment, Building Research Establishment. pp. 26-27.

Parker, B. F. 1979. Derivation of Efficiency and Loss Factors for Solar Air Heaters. SUN II, Vol. I, Proceedings of the International Solar Energy Society, Silver Jubilee Congress, Atlanta, GA. Pergamon Press, New York, N.Y., pp. 244-246.

Peck, J. F. 1983. Design and Construction of a Passive Cooling Experimental Facility for a Hot/Air Climate. Technical Information Center, Office of Scientific and Technical Information, U. S. Dept. of Energy DOE/SF/10816-T5 (DE84002343), Contract No. AC03-80SF10816.

Perry, R. H. and C. H. Chilton., ed. 1973. Chemical Engineers' Handbook. 5th Ed. McGraw-Hill Book Co., New York, N.Y. pp. 5-33, 5-34.

Phillips, W. F. 1980. Heat Exchanger Effectiveness for Solar Collectors. Solar Energy, Vol. 24, pp. 601-602.

Watt, J. R. 1986. Evaporative Air Conditioning Handbook, Second Edition. New York: Chapman & Hall, pp. 283-299.

Zambrano, W. and S. Alvarado. 1984. Design, Construction and Testing of a Chimney that Reduces Dangerous Temperatures in a Radiative Convective Solar Dryer. Solar Energy, Vol. 32, No. 5, pp. 581-584.

END

**DATE
FILMED**

8 / 25 / 93