METHODOLOGY OF DOSE CALCULATION FOR THE SRS SAR (U)

UNCLASSIFIED

Derivative
Classifier:

C W Wiest
(Name)

(Guide and Topic or Source Document)

DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION

Reviewing
Official:

Kevin R. O'Kula
Kevin R. O'Kula, Manager
Source Term Evaluation Group/RSRS

Date:

7-19-91

JUL 24 1992

MASTER

Westinghouse Savannah River Company
Savannah River Laboratory
Aiken, SC 29808

SAVANNAH RIVER SITE
PREPARED FOR THE U.S. DEPARTMENT OF ENERGY UNDER CONTRACT NO. DE-AC09-89SR18035

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared by Westinghouse Savannah River Company (WSRC) for the United States Department of Energy under Contract DE-AC09-88SR18035 and is an account of work performed under that Contract. Neither the United States, the United States Department of Energy nor WSRC, nor any of their employees, make any warranty, expressed or implied, or assume any legal liability of responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed herein, or represents that its use will not infringe privately owned rights. Reference herein to any specific commercial product process or service by trade name, mark, manufacturer, or otherwise does not necessarily constitute or imply endorsement, recommendation, or favoring of same by WSRC or by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

SARM
Safety Analysis and
Risk Management

WSRC-TR-91-191

Key Words:

K Reactor Operation Safety Analysis Report (SAR) Design Basis Accidents (DBAs) NRC 145-2 Code 99.5% & 50% Doses Fission Products Tritium
--

Retention: Lifetime

METHODOLOGY OF DOSE CALCULATIONS
FOR THE SRS SAR (U)

by

J. B. Price

Issued: July 1991

SRL

SAVANNAH RIVER LABORATORY, AIKEN, SC 29808
Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

PREPARED FOR THE U.S. DEPARTMENT OF ENERGY UNDER CONTRACT NO. DE-AC09-89SR18035

Kenneth O'Kula
K. R. O'Kula, Reviewing Official

7-19-91

Date

Document:

WSRC-TR-91-191

Title:

METHODOLOGY OF DOSE CALCULATIONS
FOR THE SRS SAR (U)

Revision Number:

0

Approvals

<i>J.B. Price</i>	
J.B. PRICE, AUTHOR	DATE
<i>M.M. Pendergast</i>	<i>7/19/91</i>
M. M. PENDERGAST, TECHNICAL REVIEWER	DATE
<i>Kenneth O'Kula</i>	<i>7/19/91</i>
K. R. O'KULA, MANAGER	DATE
<i>D.D. Hatcher for M.J.H.</i>	<i>9/27/91</i>
M.J. HITCHLER, RESEARCH MANAGER	DATE

Table of Contents

	Introduction and Summary	1
1	Dose Calculation Methodology and Assumptions	1
1.1	Sources of Radioactivity Releases	2
1.2	Method of Analysis for Propagation and Dose	4
1.3	Dose Calculations-Airborne Release	7
1.4	Dose Calculations-Waterborne Release	8
2	Description of Accidents with Radiological Consequences	9
2.1	Radiological Consequences of the LOPA	9
2.2	Radiological Consequences of the LOCA	11
2.3	Radiological Consequences of the Fuel Handling Accident	13
2.4	Radiological Consequences of a 3% Core Melt Accident	13
2.5	Radiological Consequences of a Heat Exchanger Tube Rupture	14
2.6	Radiological Consequences of Moderator Spill Accidents	15
2.7	Dose to Personnel on the SRS	16
2.7.1	Dose to Personnel in the Reactor Area	17
2.7.1.1	Dose During Evacuation	17
2.7.1.2	Dose in the Reactor Building	18
2.7.2	Dose to Personnel Away from the Reactor	18

Table of Contents
(Continued)

		<u>Page</u>
2.7.2.1	Doses from the Three Percent Core Release Accident	18
2.7.2.2	Dose from a Moderator Spill Accident	19
3.0	Quality Assurance of Dose Calculations	19
3.1	Calculational Models for Dose	19
3.1.1	Calculation of Dose from Tritium and Iodine	20
3.1.2	Calculation of Shine Dose from Noble Gases and Iodine	20
3.2	Source of Radioactivity	21
	References	22-23
	Tables	24-36

INTRODUCTION AND SUMMARY

The Savannah River Site (SRS) Safety Analysis Report (SAR) covering K reactor operation assesses a spectrum of design basis accidents. The assessment includes estimation of the dose consequences from the analyzed accidents. This report discusses the methodology used to perform the dose analysis reported in the SAR and also includes the quantified doses. Doses resulting from postulated design basis reactor accidents in Chapter 15 of the SAR are discussed, as well as an accident in which three percent of the fuel melts. Doses are reported for both atmospheric and aqueous releases.

The methodology used to calculate doses from these accidents as reported in the SAR is consistent with NRC guidelines and industry standards. The doses from the design basis accidents for the SRS reactors are below the limits set for commercial reactors by the NRC and also meet industry criteria.

A summary of doses for various postulated accidents is provided in Table 1.

DISCUSSION

1. Dose Calculation Methodology And Assumptions

This section describes the methods, assumptions and parameters used in analyzing the radiological consequences of postulated accidents and releases considered in the K reactor operation SAR (Ref. 1). Doses are calculated with the NRC145-2 code for airborne releases and LADTAP2 code for waterborne releases. These codes are described in greater detail elsewhere in this report.

Calculated doses are based on:

- (1) Radiological source term - The fission product and tritium released are determined from accident analysis of each design basis accident;
- (2) Atmospheric or liquid transport of the atmospheric plume or liquid discharge - The calculational procedures and pertinent meteorological/river data assess the transport of radioactivity; and

- (3) Uptake of transported activity by an individual at the plant boundary - This calculation requires specifying a reference individual parameters, dose conversion factors and other parameters related to the dose from particular isotopes.

The dose is based on regulatory guidance for both duration of and assumed meteorological conditions. The assumptions and procedures used for each of these steps are described in the following sections. Additional detail is given elsewhere in References 2, 3 and 4. Sections 1.1 through 1.3 describe the calculational method for airborne releases. Section 1.4 provides the methodology for the waterborne pathway of exposure.

1.1 Sources of Radioactivity Releases

The sources of radioactivity considered are tritium in the moderator, fission products in the fuel, and tritium in the lithium-bearing components contained in the reactor. The types of postulated accidents included are moderator flooding events, moderator spills, process water heat exchanger tube ruptures and assembly melting accidents.

The prevalent radioactive isotope released in most design basis accidents is tritium contained in the moderator. The tritium is produced in the moderator as a result of neutron capture by deuterium. It is assumed that the moderator contains five million curies of tritium which is 40 to 50 percent higher than the levels observed during recent reactor operations and about twenty percent higher than the maximum value ever observed in the history of SRS reactor operation. The current Technical Specifications, item 3.4.5.1, permit reactor operations with up to 2.0×10^7 counts per minute per milliliter. The assumed distribution of radioisotopes that could be in the moderator is shown in Table 2. In this analysis, it is assumed that two percent of the tritium is released by evaporation in the first two hours and twenty-five percent over the next thirty days. The other radioisotopes are less volatile and are assumed to remain in solution.

If any fuel or target assemblies melt, fission products become available for release. Depending on the type of assemblies melting and the accident circumstances, the radioactivity released would include noble gases (xenon and krypton), iodine, tritium, and

radioactive particulates (fission products, Co-60, Pu-239, etc.). The concentration of these isotopes in the core is a function of reactor power, which is assumed to be 3,000 MW for dose calculations. Expected operating power for SRS reactors for the immediate future is expected to be less than fifty percent of the 3,000 MW basis. This conservatism results in calculated doses from the dropped assembly accident (or any other core melting accident) that are twice as large as a reactor power of 1500 MW would produce.

The total inventory of noble gases at shutdown is over 600 million curies; the total inventory for iodine is over 700 million curies as shown in Table 3. The total inventory of all fission products at shutdown is a little more than seven times the total of iodine and noble gases combined. Some of these isotopes decay rapidly following shutdown and, depending on the expected accident sequence, most isotopes do not contribute significantly to potential doses. Table 3 also indicates that there are minor differences in the halogen and noble gas inventory between E/D and uniform charges.

Tritium is also present in the lithium-containing assemblies and control rods. Radioactive particulates include C & I, actinides (Pu, U, etc.), cesium compounds and other fission products besides the noble gases and halogens. The particulates would be captured by the HEPA filters. The amount of particulates that are expected to penetrate the filters (0.05%) would not contribute significantly to the estimated dose.

There are two postulated releases involving fuel melting: the dropped assembly and the three percent core melt. For the release from a single assembly dropped during discharge, a period of 5 hours is assumed to occur from reactor shutdown until the discharge from the core. Because the dropped assembly melts in dry conditions, 100% of the iodine and 100% of the noble gas are assumed to be released into the process room. One percent of the particulates is assumed released. The 3% core melt is the maximum credible release evaluated in the SAR (Appendix A). The release is 100% noble gas, 50% iodine, and 1% particulates. The release is to the process room from the reactor tank.

Airborne Activity Confinement System (AACS)

The AACS contains a series of air filters in the ventilation system immediately upstream of the stack. Air flows from both the process

room and the below-grade areas of the reactor building through a demister, HEPA filters to remove particulates and charcoal or carbon filters to remove iodine. Airflow is maintained at a high rate (100,000 CFM) to ensure cooling of the filters after they have captured radioactivity.

Radioactive isotopes released into the reactor building are filtered by the AACS before being discharged through a 200-foot stack. Based on SRS experiments and NRC Regulatory Guide 1.3, it is assumed that 50 percent of the iodine in the melted fuel becomes airborne and remains airborne because of the air velocity. The iodine which is released from the stack is the amount that bypasses the charcoal filters plus the amount that desorbs from the charcoal. Desorption from the charcoal varies depending on the length of time the charcoal has been in service as is shown in Table 4. Technical specifications require that the maximum service of the charcoal is 18 months. For dose estimates, a charcoal age of 19 months is assumed which adds a conservative margin to the calculations.

Based on ASTM D3803 for filter efficiency for iodine for NRC licensed reactors, a total filtration efficiency of 99 percent is assumed, which includes filter bypass and desorption. Using this assumption results in an estimated release of iodine for the first two hours that is larger by a factor of about five than measured desorption (see Tables 1-3) but underestimates the release after about three days. At thirty days the desorbed amount is 6.7% of the iodine retained on the filter. The basis for the current SAR dose assessment uses a filter efficiency of 99% for 2 hours, then uses actual desorption data for the type of carbon filter for longer periods. This basis implements recommendations made after DOE review of the confinement system in 1990 (D. F. Knuth, et al., Review of the Savannah River Site Reactor Confinement System, DOE Report 3143 (February 28, 1990).

1.2 Methods of Analysis for Transport and Dose Analysis

The radioactive isotopes released from the stack form a plume that disperses depending on the wind speed, direction, and variability. The frequency of particular wind speeds and directions was collected at weather towers near the reactors and averaged to indicate the probability of conditions at an averaging time of 60 minutes or two hours. A five-year period containing data for 1982-1986 inclusive was used in calculations.

Using the meteorological data, a Gaussian plume assumption, and the algorithm recommended in NRC Regulatory Guide 1.145, relative concentrations were calculated for meteorological conditions not exceeded 99.5 and 50 percent of the time. The relative downwind concentration factors are given in Table 5.

To standardize calculations as much as possible, the NRC has suggested an analysis technique for a release that occurs during a short period. The release from the stack is assumed to propagate as a Gaussian plume and the irradiation of an individual is treated as a time-integrated calculation.

Unfavorable wind conditions are also assumed. These stable, slow (1 to 4 m/sec) winds would transport the releases to the plant boundary in about one hour. Releases in higher wind-speed conditions would reach the boundary sooner but would be more dispersed and result in lower offsite doses.

The methodology (based on NRC Regulatory Guide 1.3) assumes a continuous plume and does not account for a traveling wave front. The irradiation period begins when the radioactive material is released. Decay during the exposure is not included in the calculation. For a 30-day exposure the iodine, which would be desorbing from the filters, is assumed to have decayed for 15 days before irradiation occurs. Noble gases do not cause any dose after two hours, because they are purged by the AACS from the reactor building within two hours for expected accidents.

The downwind concentrations of iodine, tritium, particulates and noble gases are calculated according to an integral technique using the computer code NRC-145-2. (Ref. 3) This code was developed at the SRS and uses a Gaussian plume model based on Regulatory Guide 1.145.

The meteorological data used in the dose calculations were collected from 1982 through 1986 in accordance with NRC Regulatory Guide 23. These data were obtained at towers near P and K reactors. The meteorological data from each tower are averaged for two-hour periods and sorted into 16 sectors, 6 wind speeds, and 7 stability classes. (Stability classes are based on the standard deviation of the mean wind azimuth.)

Doses are computed by two methods in accordance with Regulatory Guide 1.145. The first method computes, for all 16 sectors around the perimeter of the SRS, a dose that would be exceeded only 5 percent of the time. The result is referred to as the 95th percentile value. The second method calculates a dose for conditions not exceeded 99.5% of the time by calculating doses for each of sixteen sectors and computing the percentage of occurrence based on the number of calculations for the entire perimeter. The maximum of the 99.5% doses from the 16 sectors is then compared to the 95th percentile dose for the whole site, and the higher of the two values is reported.

The doses in tables in this report that are not exceeded 99.5 percent of the time use the second method and are for a particular sector. For the SRS, the second method (99.5th percentile) calculates doses at the site boundary that are about a factor of two higher than the value obtained with the first method (95th percentile whole site). The 99.5th percentile doses approximate whole site percentiles of 98.0 to 99.4. The fact that these equivalent whole-site percentiles are near 99.5 means that the meteorological data are very asymmetric for the stability classes and wind speeds that produced the highest doses.

The doses reported for conditions not exceeded 50 percent of the time use the first method mentioned above and are based on doses calculated for the entire site.

Corrections for topography and jet rise of the released plume are applied. The topography correction is prescribed by Regulatory Guide 1.145 and reduces the effective stack height when the downwind terrain is higher than the ground level elevation at the point of release.

The jet rise of the plume occurs because the exhaust fans (continuously online) impart a momentum to the gases going up the stack and increase the effective height of the release point. The model for jet rise that is included in the NRC 145-2 computer code is described in Reference 3. The jet rise used in the calculations is based on a normal flow out the stack of 100,000 cubic feet per minute. Technical Specifications allow operation for limited periods of time with only 40,000 cubic feet per minute.

The effect of fumigation, a condition that depresses downwind plume elevation to below the release height, is not included. The long

distance from the release point to the site boundary makes local fumigation insignificant. Wind shear has no effect on atmospheric mixing at distances corresponding to the plant boundary. Wet deposition of radioactivity during the occurrence of rainfall is not modeled in NRC 145-2.

The relative downwind concentration factors given in Table 5 are obtained by dividing the downwind concentration of an isotope in Ci/m^3 by the release rate at the stack (Ci/sec) without regard to subsequent dose effects.

1.3 Dose Calculations-Airborne Releases

Radioactive releases from postulated design basis accidents are transported in the atmosphere based on the above techniques. Dose calculations are made using the inhalation dose factors established for a standard individual by ICRP-30.

The dose due to tritium includes whole body contributions from inhalation and skin absorption. The release time and the exposure time are assumed to be equal.

The effective dose equivalent (EDE) is composed of an inhalation component from iodine and tritium and a skyshine component from the gamma emission of the noble gases and iodine. The inhalation component is computed by multiplying the relative concentration by the source strength, breathing rate, and dose conversion factor. Skin absorption is included in determining the dose from tritium.

The dose equivalent is computed by multiplying the dose factor (rem/Ci) times the source (Ci) times the breathing rate (m^3/sec) times the dilution factor (sec/m^3) as explained in Section 4. The dilution factor is the calculated downwind dilution based on local meteorology. The breathing rate for the standard man is $3.47 \times 10^{-4} \text{ m}^3/\text{sec}$. The dose conversion factors are based on information presented in ICRP-30. Table 6 shows these dose factors for tritium and the radioiodines. The thyroid dose does not include the dose received by the whole body.

The model used for the noble gas contribution to dose is explained in Appendix B of Reference 3. It is a subroutine called ERGAM in the computer code NRC-145-2. The method is based on irradiation of a

subject on the ground by a source of radioactivity passing overhead. The dose to the individual from the finite source is integrated to find the total dose. Build-up factors contribute to the air absorption of radiation; they are based on the assumption of 1-MeV gamma rays. ERGAM uses the same meteorology and terrain correction values as the inhalation dose calculation. A finite cloud meteorological model is used. The source released is based on the percentage of the core inventory that melts.

1.4 Dose Calculations-Waterborne Releases

Accidents in which liquid releases occur have the potential to discharge radioactive materials to the surface streams of SRS or into the groundwater with eventual emergence into the surface streams. All surface streams on the SRS empty into the Savannah River along the western border of SRS.

The waterborne release into the Savannah River can expose the public to radioactivity through five pathways; drinking water, fish consumption, exposure on the shore, swimming and boating. The computer code LADTAP2 (Ref. 5) calculates the maximum dose for an individual exposed to the extent assumed in Table 7 at the downstream end of Steel Creek near the southern boundary of SRS. The code implements guidance contained in U.S. NRC Regulatory Guide 1.109 for radioactive discharge (Reference 6).

The calculation in LADTAP2 is based on the expected dilution that should occur as surface water from SRS enters the river. The drinking water pathway is the most significant followed by fish consumption.

In the accidents described below a LADTAP2 analysis was made to calculate the dose to an individual drinking water from the Savannah River immediately downstream of Steel Creek. The water ingestion is assumed to occur for a short period following an accident in which radioactivity flows into the river (Ref. 7). The total dose from all liquid pathways is about twice the dose from drinking water pathway alone, based on calculations using LADTAP2.

For the design basis accidents that could occur the only radioactive isotope that can become waterborne in sufficient quantity to cause a significant dose is the tritium in the reactor moderator. Small quantities of other isotopes could be present in the moderator during

normal operation (See Table 2), but only tritium has the potential to cause a significant dose.

For certain spills of moderator the tritium and other isotopes could seep into the ground. This could occur if moderator was spilled directly on the ground.

Based on experience in observing groundwater flow under the SRS about one fourth of the spilled liquid is expected to reach the surface streams in 3 years.

2. Description of Accidents with Radiological Consequences

Only a subset of the accidents discussed in Chapter 15 of the SAR have radiological consequences. This section discusses each accident with a finite dose consequence.

2.1 Radiological Consequences of the Loss-of Pumping Accident (LOPA)

The LOPA results from a very large cooling water leak inside the reactor building that floods the process water pump motors; this is followed by cooling of the reactor core by ECS injection and flow of the water injected out the vacuum breakers and U tube into the reactor building. The analysis presented in the SAR shows that there are adequate margins so that no fuel damage is assured. Thus the only radioactivity released is that contained in the moderator, which is mostly tritium (Table 2).

The ECS flow would drive most of the D₂O out of the reactor tank. Approximately the first 560,000 gallons of ECS flow will be contained in the closed 60,000 and 500,000 gallon tanks. Any additional water is directed into the lined and covered 50 million gallon retention basin. However, because the basin liner and cover are not considered to be safety qualified, no credit is taken for these features in the analysis of the consequences of accidents. The 60,000 and 500,000 gallon tanks are vented back to the reactor building and exhausted through the AACS filters to the 200 foot stack.

With an ECS flow assumed to average 9,500 gpm over a several day period, the water storage would be exceeded in less than 4 days and would start to flow to the river. It is expected that all moderator radioactivity would be contained in the 60,000 and 500,000 gallon

tanks with minimum overflow to the 50 million gallon basin or to the drainage creeks and the river. Thus the only radioactivity released is from evaporation (including diffusion) from the water surface which is vented back to the reactor building, filtered by the AACS filters and released through the 200 foot stack.

About two percent of the water could evaporate in the first two hours and about twenty-five percent during the first 30 days. This same fraction of tritium would also evaporate and, since it is not removed by the AACS, would be discharged through the 200 foot stack (Ref. 1). Because of the expected dilution in the LOPA, it is unlikely that 2% of the tritium would evaporate and be passed out the stack in 2 hours. If 2% of the moderator tritium did evaporate, the dose at the boundary would be 10 mrem as effective dose equivalent for 99.5% meteorological conditions. In 30 days the dose would be 3 mrem if 25% of the moderator tritium (1.25 MCi) evaporated. The estimated off-site doses are an extremely small fraction of the dose in criterion 10 CFR Part 100, which is 25 rem.

Under the worst expected accident conditions a ruptured cooling water header could flood the lower section of the 105 Building with cooling water filling the 60,000 and 500,000 gallon tanks. The moderator could then be forced out of the reactor tank later in the accident so that it mixes with the cooling water in the lower level of the 105 Building. Under the worst expected mixing conditions about 60 percent of the moderator (28,900 gallons) would remain in the 105 Building until the 50 million gallon basin was filled.

Subsequent ECS flow could force the mix of cooling water and as much as 60 percent of the moderator out of the 105 Building after the 50 million gallon basin was filled. In this case the water release would be to the outfall and eventually the river. A LADTAP2 analysis of release of this quantity of moderator to the Savannah River showed that the maximum expected dose from drinking one liter per day of river water would be about 19 mrem. Based on analyses of annual releases using the LADTAP2 code, the dose from eating fish and swimming would increase the estimated dose by about a factor of two.

If the basin liner is assumed to leak, tests have shown that approximately one-quarter of the inventory released to the basin would reach the K Area surface streams and flow to the river in

about three years. An analysis shows that the expected dose from drinking normal amounts of river water would be about 3 mrem.

Table 7 contains the assumptions used in the LADTAP2 analysis of the LOPA liquid release.

2.2 Radiological Consequences of the Loss-of-Coolant-Accident (LOCA)

As described in SAR section 15.6, the LOCA results from a large process system leak inside the reactor building followed by cooling of the reactor core by ECS injection and flow of the water injected out the break into the reactor building. The LOCA analysis shows that operation with the Transient Protection Limit indicates no fuel damage. Thus the radioactivity released is that contained in the moderator and gas plenum which is assumed to be the maximum allowed by Technical Specification limits.

The ECS flow should drive most of the D₂O out of the reactor tank. The first approximately 560,000 gallons should be contained in the closed 60,000 and 500,000 gallon tanks. Any additional water is diverted into the lined and covered 50 million gallon retention basin. The 500,000 tank and the 60,000 gallon tank are vented back to the reactor building and exhausted through the AACS filters to the 200 foot stack.

With an ECS flow assumed to average 9,500 gpm over a several day period, the water storage would be exceeded in less than 4 days, and water would start to flow to the river. It is assumed that all moderator radioactivity is contained in the 60,000 and 500,000 gallon tanks with minimum overflow to the 50 million gallon basin or to the drainage creeks and the river. Thus the only radioactivity released is from evaporation from the water surface which is vented back to the reactor building, filtered by the AACS filters and released through the 200 foot stack.

It is assumed that about 2 percent of the water would evaporate in the first two hours and about 25 percent over the next 30 days. This same fraction of tritium would also evaporate and be conveyed by the AACS and discharged out the 200 foot stack. The other isotopes in the moderator (Table 2) are either non-volatile or would remain in solution in the moderator.

The effective dose equivalent (EDE) at the SRS boundary for the first two hours is 10 mrem and for 30 days the (EDE) is 3 mrem for 99.5% conditions. This analysis shows that the off-site doses are an extremely small fraction of the reference dose in 10 CFR Part 100 which is 25 rem for the whole body (EDE). There is no thyroid dose from tritium. Doses due to tritium evaporation for the LOCA and LOPA are listed as a function of distance in Table 8.

In the late stages of the DEGB LOCA, some tritium-bearing components would not be cooled sufficiently to preclude tritium release. The entire inventory of tritium from these non-fuel components would comprise a 6.6 MCi release to the AACS for atmospheric discharge. The EDE at the SRS boundary for a two-hour exposure is 0.67 rem.

2.3 Radiological Consequences of the Fuel Handling Accident

As discussed in SAR section 15.7.1, the fuel handling accident is assumed to occur after a fuel assembly has been removed from the core, but before it has been placed in a designated location in the disassembly basin. The fuel handling accident would not impact the integrity of the core. Fuel handling is performed with the charge and discharge machines, which are operated remotely from the crane control room because of the radiation levels in the process room. The discharging operation consists of taking an assembly from the reactor and placing it in a conveyor for transfer to the disassembly basin.

The first step in fuel handling is shutdown of the reactor for the time specified in the Technical Specifications and the Core Shutdown Report which is assumed to be 5 hours. A discharge crane lifts each assembly from the reactor, carries it across the process room and lowers it into a discharge canal.

The fuel handling accident assumes the dropping of an irradiated assembly onto the process room floor. The process room spray system would normally be manually activated by the operators to cool a hot assembly if the assembly is dropped. For this analysis, the dropped fuel assembly is assumed to fall to a position such that the process room spray system cannot adequately cool the assembly, so the assembly melts.

The 3 percent melt source term is based on the reactor core inventory at the end of cycle for a mixed-lattice charge operating at 3000 MW; a uniform charge has almost the same content for dose dominant isotopes (Table 3). Fuel damage in the core could result in the release of all noble gases and other radioactive isotopes into the process room. Experiments have shown that the sequence of release of fission products can occur in as little as 15 minutes. Fifty-percent of the iodine in the affected core material is assumed to become airborne in the process room, pass through the AACS filters and be released from the stack. The release of iodides is considered unlikely because they should remain in solution in the moderator (Ref. 8).

The doses resulting from this accident are estimated using the methods described in Section 1. For this accident, the dose from particulates is not included, because it is less than 1% of the total dose.

The calculated effective dose equivalent and thyroid doses for this accident are given in Tables 10 and 11, respectively. Decay is not included in the EDE. The thyroid doses for a 30-day exposure include 15 days of decay.

2.5 Radiological Consequences of a Heat Exchanger Tube Rupture

The heat exchanger tube rupture described in SAR section 15.6.1, assumes a 100 gpm leak of moderator to the cooling water lasting for four hours. The total loss of moderator would be about 24,000 gallons or 48 percent of the moderator inventory. This is conservative because such a loss of moderator would drop the moderator level and scram the reactor in about 5 minutes and the operators would be required to trip the AC motors on the process water pumps which would reverse the flow from the broken heat exchanger tube.

It is assumed that 5 million curies of tritium are contained in the moderator in addition to the other fission and corrosion products in Table 2.

The activity released through the break to the cooling water would be diluted with 170,000 gallons per minute of cooling water before flowing to the creek and then to the river. Additional radioactive isotopes contained in the moderator would be released to the process

room as the flow through the break reverses and the moderator flows through the vacuum breakers. This activity, if it evaporated, would pass through the AACS and be discharged from the stack. The radiological consequences of the airborne release from this source would be much less than that indicated for the LOPA and LOCA accidents (10 mrem in 2 hours).

An analysis of the radiological consequences of the release to the river was made using the LADTAP2 code described above. The assumptions used in the analysis are shown in Table 7. For this analysis, a low river flow of 3900 ft³/sec was used. The dose calculated for an adult individual located downstream from the point of complete river mixing was 16 mrem from drinking average amounts of water taken from the river. Based on analyses of annual releases using the LADTAP2 code, the dose from eating fish and swimming would increase the estimated dose by about a factor of two. However, the travel time of the contaminated water to the site boundary is in excess of 3 days and allows time for warnings downstream to prevent exposure.

2.6 Radiological Consequences of Moderator Spill Accidents

The accident considered in SAR Section 15.7.2 is spilling of a fraction of the radioactivity present in the moderator due to leaks in systems outside the reactor building, such as the distillation system. It is assumed for the analysis that 10 percent of the radioactivity in the moderator is spilled on the ground in the reactor area. Plant operating data indicate that the assumed 10 percent spill is approximately a factor of five greater than the largest moderator spill experienced in the reactor areas at the Savannah River Site. For this analysis, it is assumed that the moderator contains 5 million curies of tritium and other isotopes as discussed above. A 10 percent spill is a spill of 500,000 curies of tritium.

The expected evaporation of tritium for the worst expected conditions is 2% in 2 hours and 25% in 30 days of the total spilled. The other radionuclides assumed to be in the coolant are not volatile or are in solution and would not evaporate. Doses to individuals as a function of distance from the release point and the assumed meteorological conditions are tabulated in Table 12. The resultant EDE doses at the boundary assuming 99.5 percent meteorological conditions are much lower than the 10 CFR 100 reference value of 25 rem.

Small spills are managed by the reactor area radiological procedures. In most cases only a small fraction of the moderator tritium would be released to the atmosphere. Larger spills may be released ultimately to surface waters in the reactor area, or to the groundwater.

The consequence of all of the moderator that is spilled being discharged in liquid pathways was evaluated using the isotopes and assumptions shown in Tables 2 and 7. The LADTAP2 computer code assumes that the radioactivity is deposited directly in the river with no radioactive decay. Doses were calculated for an adult assumed to reside at the river. The water pathway doses assume complete mixing in the river and include ingestion of fish, drinking water, and recreation activity pathways. Because the release would occur over an extended period of time, a river flow of 10,000 cfs was assumed.

The dose from drinking one liter of water per day is the most realistic of the various pathway doses and is about 4 mrem. Based on analyses of annual releases using the LADTAP2 code, the dose from eating fish and swimming would increase the estimated dose by about a factor of two.

If the moderator is not spilled directly to a surface stream, but instead to groundwater, site data indicate that approximately 25 percent of the tritium and spilled radionuclides seeping into groundwater could reach surface streams in about three years. This period would allow some decay of the tritium and significant decay of the other isotopes assumed to be in the moderator, as shown in the third column of Table 2. However, decay was not included in the dose analysis because the spill could reach the river directly from surface runoff.

The estimated doses from the assumed moderator spill accidents are well within DOE Order 5400.5 guidelines.

2.7 Dose to Personnel on the SRS

The radioactive material released after a reactor accident can be dispersed over the SRS, exposing personnel to radiation. The personnel dose was calculated at various locations for exposure to radiation from noble gases, iodine, tritium and particulates. The

accidents considered in sections 3.1 to 3.6 with the exception of 3.5 (waterborne exposure) could irradiate personnel on the site.

2.7.1 Dose to the Personnel in the Reactor Area

Doses in the reactor areas are potentially the largest of any on the SRS. Doses should be minimized by personnel being directed to either assemble in the reactor building or evacuate the area, as current procedures require (Ref. 9). Doses were previously calculated for both situations (Ref. 10).

Most personnel in the reactor area are to evacuate along one of two designated routes to a location outside the reactor area for further evacuation by vehicle. A public address announcement from the 105 Building control room will designate which evacuation route is to be used (Ref. 9). Selection of a route is based on local wind direction as indicated by instruments in the control room. Personnel exit the reactor area through the nearest crash gate away from the direction of the plume.

2.7.1.1 Dose During Evacuation

The irradiation of personnel during a planned evacuation away from the plume was calculated. In case the evacuation does not proceed as planned, the irradiation of personnel was also calculated for an evacuation under the plume, which is the worst case. Table 13 indicates the effective dose equivalent for each case.

When personnel evacuate away from the plume, exposure decreases as they move farther away. For this situation, the dose cannot be calculated easily, because the available codes only calculate the dose immediately below the plume. An upper limit calculation was made that indicates the maximum dose personnel could receive during their evacuation. The upper bounding dose assumed that the release was at height equal to the distance from the plume centerline to the closest evacuation path. This upper bounding dose represents the maximum expected for planned evacuation because the plume should be farther from personnel as they continue to move away from the reactor area. The upper bounding dose is reported in Table 13 as "evacuation effective."

The dose for the worst-case condition, evacuation under the plume, was calculated by assuming the exposure occurred 0.5 miles from the

reactor for a two hour period. The dose at 0.5 miles represents the maximum dose that could occur to personnel evacuating along a route from the reactor to the pick-up point. The dose for a two-hour exposure for a plume overhead is reported in Table 13 as "evacuation not effective."

2.7.1.2 Dose in the Reactor Building

The dose inside the reactor building is insignificant in the lunchroom and the control room for radiation from either inside the process room or from the filter compartments. In all cases, several feet of concrete shielding limit the dose rate to less than 0.5 mrem/hr (Ref. 10).

Radiation in the reactor building affects personnel only if the air intake system brings radioactivity into the building personnel areas. When the wind is blowing from the stack toward the actuator tower, the relative concentration is high on the downwind side of the tower where the building air intakes are located. This is a "building wake" effect. Control room personnel monitor their exposure to avoid excessive dose.

2.7.2 Dose to Personnel Away from the Reactor

For a three percent core release accident the (EDE) and thyroid doses were calculated for a two hour exposure period. For a moderator spill accident, the (EDE) for very unlikely meteorology was calculated. The doses were calculated for concentric rings centered on K Reactor at distances of 0.5, 1.0, 1.5, 2, and 4 miles and at the SRS boundary. Calculations were made at each distance for sixteen 22.5° sectors around the site perimeter; the maximum value of the 16 directions is reported. The same direction is not necessarily the maximum dose sector for increasing radii.

2.7.2.1 Doses from the Three Percent Core Release Accident

Tables 10 and 11 indicate the maximum whole-body (EDE) and thyroid doses for very unlikely and typical conditions at each of the six distances. For distances outside the reactor area, the (EDE) is less than the 25-rem reactor siting criteria (Table 10).

The thyroid doses were calculated at the same locations as the whole-body doses and for a two-hour exposure. All thyroid doses

are less than 30 rem; this is considerably below the 300 rem NRC siting criteria. Table 11 lists the maximum thyroid doses in very unlikely (99.5%) and typical (50%) meteorological conditions at each concentric ring for two-hour and 30-day exposure periods.

2.7.2.2 Dose from a Moderator Spill Accident

The inhalation of tritium released after a 10% moderator spill accident for very unlikely and typical conditions was assumed to calculate the EDE. Table 12 lists doses at various distances for two hour and 30 day exposures. The 25 rem whole-body dose siting criterion was not approached. The liquid pathway doses discussed in sections 2.1, 2.2, 2.5 and 2.6 are not applicable for personnel on the site.

3.0 Quality Assurance of Dose Calculations

The procedure used to calculate doses for the SAR and similar documents was developed in 1982 through the efforts of a committee of experts that was assembled from SRL to comprehensively review the dose calculation procedures and verify the calculation for use in the reactor SAR. The procedure was based on NRC Guidelines, especially 1.3 and 1.145; the guidelines were applied to SRS conditions as deemed appropriate. The procedure began with qualification of the meteorological database (Ref. 11). A five year period (1975-1979) of wind data from P, K and C reactor areas was checked for errors and put into a form for use in the dose code (Ref. 10). The database used in recent years has been from the five year period of 1982 to 1986. A code, NRC-145-2, was developed by programming the algorithm in NRC Regulatory Guide 1.145; an option was included to allow a finite cloud irradiation for gamma shine instead of the method in Regulatory Guides 1.109 and 1.3. This finite cloud approximation was chosen by the committee as preferable for whole body dose (EDE) calculations; which are dominated by direct radiation from noble gases. For inhalation and contact doses a semi-infinite cloud model is used.

3.1 Calculational Models For Dose

The models used for the airborne dose determination are summarized below (Ref. 2).

3.1.1 Calculation of Dose From Tritium and Iodine

The dose from tritium includes whole body contributions from inhalation and skin absorption. The release time and the exposure time are assumed to be equal.

The equation for the effective dose equivalent is:

$$\text{Effective Dose Equivalent (EDE)} = \text{dose factor} \left(\frac{\text{rem}}{\text{Ci}} \right) \times \text{source (Ci)}$$

$$\times \text{breathing rate} \left(\frac{\text{m}^3}{\text{sec}} \right) \times \text{dilution factor, } \frac{X}{Q} \left(\frac{\text{sec}}{\text{m}^3} \right)$$

The dilution factor is the calculated downwind dilution based on local meteorology. The breathing rate is usually $3.47 \times 10^{-4} \text{ m}^3/\text{sec}$ as specified by NRC guidelines. The dose factor is based on values presented in ICRP-30.

The inhalation dose from iodine is calculated using the algorithm above with a dose factor appropriate for each iodine isotope. The inhaled iodine isotopes migrate to the thyroid and are the contributors to the thyroid dose. The dose to the thyroid does not include the dose to the whole body.

3.1.2 Calculation of Shine Dose From Noble Gases And Iodine

The model used for the shine contribution to dose is explained in Appendix B of Ref 3. It is a subroutine called ERGAM in the computer code NRC-145-2. The method is based on irradiation of a subject on the ground by a source of radioactivity passing overhead. The dose to the individual from the finite source is integrated to find the total dose. Build-up factors contribute to the air absorption of radiation; they are based on the assumption of 1-MeV gamma rays.

ERGAM uses the same meteorology and terrain values as the inhalation dose calculation. A finite cloud meteorological model is used; this is the appropriate model for exposure conditions on the SRS (Ref. 12). The source released is based on the percentage of the core inventory that melts. Noble gases provide almost the entire shine dose; a small amount of dose is from iodine.

3.2 Source of Radioactivity

A source term for a stack release was developed by calculating the isotope content of a late-stage Mark 16-31 charge using the SHIELD code system. A mixed lattice charge was used because it is the appropriate charge in calculating dose from the misloading accident (3% melt); the activity content of a Mark 22 charge is similar for the 3,000 MW power level. Tritium in the mixed lattice charge is assumed to be 65 MCi to simulate the tritium content of a Mark 22 charge. The isotope content in this (Ref. 13) charge and in the moderator was used to estimate the isotopes that would be released for the design basis accidents: (a) moderator spill resulting from LOCA, LOPA or heat exchanger tube leak; (b) melting of a dropped fuel assembly; (c) a misloading accident (3% of core). The noble gases and tritium were assumed to be released promptly and passed out the stack. The iodines and particulates were assumed to be held on filters. Iodines are released later according to expected desorption, but in 2 hours 1% of the iodines reaching the filter are assumed to be released.

Currently the iodides, cesium isotopes, actinides and other particulates are assumed to remain in solution in accidents in wet conditions, such as misloading, LOCA, LOPA, etc., (Ref. 8). The only accident considered that occurs in dry conditions is the dropped assembly accident. The iodides, cesium and particulates contribute only a few percent of the dose from a melting accident.

The calculation procedure combined meteorological data with the expected stack release of the source term. The movement of this release is propagated across the SRS to calculate the resulting dose for the distribution of expected conditions. Dose conversion factors from ICRP-30 were used to determine dose (Ref. 14).

For future SAR dose calculations the code AXAIR 89Q will be used. NRC-145-2 will be retired in FY 1991 per Safety Analysis and Risk Management code certification plan.

REFERENCES

1. Westinghouse Savannah River Company, **K Reactor SAR Chapter 15**, WSRC-SA-100003 (July 1991).
2. Price, J. B., "Calculational Method for Accidental Airborne Release and Resultant Dose from SRS Reactors" DPST-83-844, (August 23, 1983).
3. Pendergast, M. M., "NRC-145-2, a Computer Code to Assess Dose From Accidental Pollutant Releases", DP-1646, May 1983.
4. NRC Regulatory Guide 1.145, Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants, August 1979.
5. Strenge, D. L., Peloquin, R. A., Whelan, G., Wangler, M. E., LADTAP2, Technical Reference and User's Guide, NUREG CR-4013, PNL-5270, April 1986.
6. U.S. Nuclear Regulatory Commission. U.S. NRC. Regulatory Guide 1.109 "Calculation of Annual Doses to Man From Routine Releases of Reactor Effluents For the Purpose of Evaluating Compliance with 10CFR 50, App. I," (Rev. 1, October, 1977).
7. Marter, W. L., Radiological Consequences of Heat Exchanger Tube Break-Revised Source Terms, SRL-ETS-900385, August 28, 1990.
8. Hyder, M. L., Iodine Retention in the SRS Reactors: Basis, Performance and Requirements (U), WSRC-TR-90-77, January 31, 1990.
9. DPSOL-100-4005-P/K/L, Area Emergency - Area Emergency Coordinator Rev. 26, March 5, 1987.
10. Price, J. B., Onsite Radiation Dose from Postulated Reactor Accidents, DPST-86-204, January 15, 1986.
11. Garrett, A. J., and D. D. Hoel, "Preparation of Meteorological Data for Dose Calculations in 1982 SRS SAR", DPST-82-512, June 4, 1982.

REFERENCES (Continued)

12. Price, J. B., Use of Finite Cloud Model Versus Semi-infinite Model for Dose Calculation-SAR 1991, SRL-STE-910055, August 23, 1991.
13. Evans, A. F., Noble Gas and Halogen Source Terms for the SRS Reactor Safety Analysis Report, DPST-82-745, August 6, 1982.
14. DOE/EH-0071, Internal Dose Conversional Factors for Calculations of Dose to the Public, U. S. Department of Energy, July 1988. Derived from ICRP-30, limits for Intakes of Radionuclides by Workers, International Committee on Radiation Protection, July 1978.
15. Pillinger, W. L., Radioiodine Releases from Carbon Filter Desorption for Dose Calculations in Reactor SAR, DPST-82-960, Oct. 29, 1982.

TABLE 1

SUMMARY OF EFFECTIVE DOSE EQUIVALENT AT SRS BOUNDARY
FOR AIRBORNE AND LIQUID RELEASES

<u>Accident</u>	Effective Dose Equivalent (rem)	
	<u>Airborne Release</u>	<u>Liquid Release</u>
3% Core Melt	4.0	0
Dropped Assembly	.025	0
LOPA	.010	.019
LOCA	.010	0
-Gamma Heating Phase	.67	-
Moderator Spill	.004	.004
Heat Exchanger Tube Rupture	<.010	.016

The airborne releases are for 2 hours and conditions not exceeded 99.5% of the time. Reactor power is assumed to be 3000 MW.

TABLE 2
ASSUMED LEVELS FOR MODERATOR ACTIVITY CONCENTRATION

Radionuclide	Initial Activity ($\mu\text{Ci/ml}$)	Activity Decayed by Three Years ($\mu\text{Ci/ml}$)
Na-24	6.01E+00	0.00E+00*
Sr-91	2.51E-01	0.00E+00
Sr-92	4.54E-01	0.00E+00
Ba-140	4.41E-02	0.00E+00
U-237	1.09E-03	0.00E+00
Np-238	1.15E-03	0.00E+00
Np-239	1.09E+00	0.00E+00
Pu-238	1.09E-05	1.07E-05
Pu-239	3.28E-06	1.38E-06
Cm-242	2.19E-06	2.06E-08
Cm-244	1.09E-06	9.75E-07
Cr-51	1.09E-02	1.37E-14
I-131	1.09E-02	0.00E+00
Zr-95	1.09E-02	7.70E-08
Ce-141	3.28E-02	2.34E-12
Ce-143	9.30E-02	9.46E-12
Fe-59	1.09E-03	4.42E-11
Co-60	5.46E-04	3.69E-04
Co-58	1.09E-06	2.40E-11
Cs-137	1.09E-06	1.02E-06
Ce-144	1.09E-01	7.58E-03
La-140	1.15E-01	0.00E+00
Ru-103	1.15E-01	4.91E-10
Nb-95	1.09E-01	0.00E+00
Zn-65	1.09E-01	4.86E-03
Sr-89	1.09E-01	3.23E-08
Cs-134	1.09E-01	3.99E-02
Mn-54	1.09E-01	9.63E-03
Sb-124	1.09E-01	3.64E-07
S-35	1.64E-04	2.72E-08
P-32	3.28E-04	0.00E+00
<hr/>		
Non-Tritium Total	9.01E+00	6.24E-02
Tritium	2.64E+04	2.23E+04

* All entries $<1.00\text{E}-20$ are set equal to $0.00\text{E}+00$.

TABLE 3
CORE INVENTORY OF FISSION PRODUCTS WHICH
ARE MAJOR CONTRIBUTORS TO 2 HOUR OFFSITE DOSE
Basis: 3,000 MW Reactor Operation

<u>Isotope</u>	<u>Half Life</u>	<u>Inventory (MCi)</u>	
		<u>E/D</u>	<u>Uniform</u>
I-131	8.04 d	74	74
I-132	2.28 h	113	111
I-133	20.8 h	174	176
I-134	52.6 m	181	199
I-135	6.58 h	164	165
Total Iodines		706	725
Kr-87	76 m	35	64
Kr-88	2.8 h	73	90
Xe-133	5.3 d	167	175
Xe-133m	2.2 d	24	25
Xe-135	9.16 h	20	16
Xe-135m	15.3 m	30	29
Xe-137		143	156
Xe-138		152	161
Total Noble Gases		644	716

m - minutes

h - hours

d - days

Note: The isotope amounts are from reference 13.

TABLE 4

CUMULATIVE RELEASE FRACTIONS FOR IODINE
LOADED ON CONFINEMENT SYSTEM CARBON BEDS
DUE TO RADIOLYTIC DESORPTION MECHANISMS

Time After Loading, (Hours)	Cumulative Fraction of Iodine Released as a Function of Carbon Age, (Months)			
	<u>6</u>	<u>14</u>	<u>19</u>	<u>30</u>
0	0.00050	0.00050	0.00050	0.00050
1	0.00073	0.00084	0.00140	0.00220
2	0.00084	0.00116	0.00190	0.00400
3	0.00093	0.00138	0.00230	0.00503
4	0.00102	0.00156	0.00256	0.00575
5	0.00108	0.00171	0.00280	0.00630
9	0.00130	0.00200	0.00341	0.00760
18	0.00178	0.00248	0.00422	0.00963
24	0.00210	0.00280	0.00476	0.01053
48	0.00338	0.00408	0.00722	0.01593
72	0.00465	0.00535	0.00908	0.02133
96	0.00593	0.00663	0.01124	0.02673
120	0.00721	0.00791	0.01340	0.03213

Note: Data includes 0.05 percent instantaneous filter bypass and observed desorption rates for GX-176 carbon service aged in the SRS confinement system. Values given are fractions of the filter inventory, not core inventory. The filter inventory is assumed to be 50 percent of the iodine released from the core. Source: reference 15.

TABLE 5

ATMOSPHERIC DILUTION

X/Q Values for 2 hours and 30 days

Distance (Miles)	2 Hours X/Q *10 ⁶ (sec/m ³)		30 days X/Q *10 ⁶ (sec/m ³)	
	<u>99.5%</u>	<u>50%</u>	<u>99.5%</u>	<u>50%</u>
0.5	6.21	1.901	0.720	0.221
1.0	4.40	1.713	0.465	0.181
1.5	4.08	1.747	0.295	0.126
2.0	3.87	1.386	0.244	0.088
4.0	4.01	0.631	0.165	0.026
Boundary	2.96	0.273	0.076	0.007

X/Q's were calculated from meteorology measured at K reactor from 1982 through 1986. Percentages (99.5%, 50%) refer to the percent of time for which meteorological conditions are not exceeded.

TABLE 6
INHALATION DOSE FACTORS

(Rem/Ci inhaled)		
<u>Nuclide</u>	<u>Effective Dose Equivalent</u>	<u>Thyroid</u>
H-3	9.5×10	9.5×10
I-131	3.2×10^4	1.1×10^6
I-132	3.3×10^2	6.3×10^3
I-133	5.4×10^2	1.8×10^5
I-134	1.1×10^2	1.1×10^3
I-135	1.1×10^3	3.1×10^4

Note: Adult dose commitment factors from ICRP-30 (Ref. 14).

TABLE 7

INPUT DATA FOR RADIOLOGICAL CONSEQUENCES ASSESSMENT
FOR LIQUID PATHWAY RELEASE

Analysis Methodology	LADTAP2 Computer Code
River Volumetric Flow Rate	3900 ft ³ /second
Dose Factors	ICRP 30
Adult Exposure Parameters	
Drinking Water Consumption	1 liter/day
Fish Consumption	19 kg/year
Shoreline Exposure	20 hours/year
Swimming	10 hours/year
Boating	60 hours/year

TABLE 8
LOCA/LOPA ACCIDENT EFFECTIVE DOSE EQUIVALENT
(Millirem)

Distance Miles	Frequency of Occurrence			
	99.5%		50%	
	0-2 Hr.	0-30 Days	0-2 Hr.	0-30 Days
0.5	21	30	6	9
1.0	15	19	6	8
1.5	14	12	6	5
2.0	13	10	5	4
4.0	13	7	2	1
Boundary	10	3	1	<1

TABLE 9

RADIATION DOSE TO A PERSON AT THE SRS SITE
BOUNDARY FOLLOWING A DROPPED ASSEMBLY ACCIDENT (a)

Operating and Meteorological Conditions (b)	Calculated Dose, Rem			
	EDE (2-hr)	Thyroid (2-hr)	EDE (30-days)	Thyroid (30-days)
Reference values (c)	25	300	25	300
Typical	.002	.038	<.001	<.001
Very unlikely	.025	.353	.001	<.001

EDE = effective dose equivalent

(a) One assembly melted.

(b) Typical conditions are 3,000 MW reactor power, average (50 percent meteorology, and 19-month service age carbon filters.

Very unlikely conditions are reactor power of 3,000 MW, very unfavorable meteorology as specified in RG 1.145 (95 percent site, 99.5 percent worst sector), and 19-month aged carbon filter. 1% of the iodine that reached the filter passes out the stack in 2 hours. In 30 days 6.7% of the iodine reaching the filter is released out the stack. 100% of iodine in the melted assembly is assumed to become airborne. The thyroid dose in 30 days includes 15 days of decay; decay is not included in the other doses.

(c) NRC Reactor Siting Criteria, 10 CFR 100, September 1978.

TABLE 10
3 % CORE MELT
EFFECTIVE DOSE EQUIVALENT

3,000 MW Core Power, 19 month age for carbon filters
1% iodine released from filters in 2 hours
6.7% iodine released from filters in 30 days
No decay is included.

<u>Distance</u> <u>(Miles)</u>	2 Hour Release Dose (rem)	
	Percent Time Dose Not Exceeded	
	<u>99.5%</u>	<u>50%</u>
0.5	26.8*	16.2
1.0	22.1	10.4
1.5	18.7	7.1
2.0	16.8	5.2
4.0	8.8	2.1
Boundary	4.0	.32
*95% Whole Site is greater than 99.5% maximum sector.		
<u>Distance</u> <u>(Miles)</u>	30 Day Release Dose (Rem)	
	Percent of Time Dose Not Exceeded	
	<u>99.5%</u>	<u>50%</u>
0.5	4.2	3.0
1.0	3.2	1.7
1.5	1.8	.81
2.0	1.4	.52
4.0	.50	.135
Boundary	.14	.013

TABLE 11
3 % CORE MELT
THYROID DOSES

3,000 MW Core Power, 19 month age for carbon filters
1% iodine release from filters in 2 hours
6.7% iodine release from filters in 30 days, including 15
days of decay

Distance (Miles)	2 Hour Release Dose (rem)	
	Percent Time Dose Not Exceeded	
	<u>99.5%</u>	<u>50%</u>
0.5	29.6	9.6
1.0	20.7	8.4
1.5	18.3	8.2
2.0	17.3	6.7
4.0	16.9	3.0
Boundary	11.4	1.2
Distance (Miles)	30 Day Release Dose (rem)	
	Percent of Time Dose Not Exceeded	
	<u>99.5%</u>	<u>50%</u>
0.5	.118	.038
1.0	.075	.031
1.5	.045	.020
2.0	.037	.014
4.0	.024	.004
Boundary	.010	.001

Dose to the whole body is not included in computing thyroid dose.

TABLE 12

AIRBORNE RELEASE EFFECTIVE DOSE EQUIVALENT TO AN
INDIVIDUAL FROM A 10% MODERATOR SPILL

	Effective Dose Equivalent (mrem)			
	<u>2 hours</u>		<u>30 days</u>	
<u>DISTANCE</u> <u>FROM RELEASE STACK</u>	METEOROLOGICAL CONDITIONS			
	<u>99.5%</u>	<u>50%</u>	<u>99.5%</u>	<u>50%</u>
0.5	1.5	3.1	2.8	6
1.0	1.5	1.4	1.3	1
1.5	1.1	1.0	7.5	<1
2.0	1.0	<1	5.2	<1
4.0	6.7	<1	2.3	<1
Boundary	3.5	<1	1.1	<1

10 CFR 100 Reference Value 25,000 25,000 25,000 25,000

The tritium is assumed to be released near the ground in the K reactor area.

TABLE 13

MAXIMUM EFFECTIVE DOSE EQUIVALENT DURING EVACUATION
FROM REACTOR AREAS

	Effective Dose Equiv. (rem)
Plume dispersing opposite direction of evacuation with evacuation effective	1
Plume overhead during evacuation with evacuation not effective	21

(Doses are for wind conditions not exceeded 99.5% of the time.)

METHODOLOGY OF DOSE CALCULATION FOR THE SRS SAR (U)

DISTRIBUTION LIST (31)

S. K. Bhatnager, DOE/ONS - Germantown
P. Neogy, Brookhaven National Laboratory

H. S. Ozmelek, 703-41A

B. Culp, 703-41A

G. H. Clare, 742-3A

P. W. Dickson, 703-A

A. F. McFarlane, 703-A

~~J. A. Bazzano, 742-3A~~

M. J. Hitchler, 773-A

F. Beranek, 773-A

K. R. O'Kula, 773-41A

D. A. Sharp, 773-41A

D. J. Baker, 773-41A

D. A. Busch, 773-53A

T. G. Clark, 706-16C

V. S. O'Block, 773-53A

D. Leach, 773-54A

F. Pickering, 703-14C

E. P. Rahe, Jr., 703-A

R. J. Skwarek, 773-53A

T. V. Crawford, 773-A

T. E. Britt, 676-14T

W. L. Marter, 773-42A

M. M. Pendergast, 735-A

J. C. Huang, 773-42A

J. B. Price, 676-9T

J. M. East, 773-41A

A. A. Simpkins, 773-41A

SRL Records (2), 773-A

STE File, 773-41A

END

**DATE
FILMED**

9 / 11 / 92