LA-6813-MS

Informal Report

UC-79p (Base Technology)

Issued: June 1977

**A Bayesian Zero-Failure (BAZE) Reliability
Demonstration Testing Procedure for Components of
Nuclear Reactor Safety Systems**

R. A. Waller
H. F. Martz*

*Visiting Staff Member. Texas Tech University, Lubbock, TX 79409.

los alamos
scientific laboratory
of the University of California
LOS ALAMOS, NEW MEXICO 87545

An Affirmative Action/Equal Opportunity Employer

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

This work was supported by the US Energy Research and Development Administration, Division of Reactor Development and Demonstration, and Office of Naval Research Contract N00014-75-C-0832.

Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161
Price: Printed Copy \$5.00 Microfiche \$3.00

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.

TABLE OF CONTENTS

NOTATION	iv
ABSTRACT	vii
I. INTRODUCTION	1
II. BAYESIAN RELIABILITY DEMONSTRATION TESTING . . .	5
III. SELECTING A GAMMA PRIOR DISTRIBUTION	8
IV. BAYESIAN ZERO-FAILURE (BAZE) RELIABILITY DEMONSTRATION TESTING	13
V. EXAMPLE	23
VI. PRIOR DISTRIBUTIONS AND ANALYSIS FOR SELECTED COMPONENTS OF NUCLEAR REACTOR SAFETY SYSTEMS . .	31
VII. SUGGESTED BAZE TEST PLANS FOR SELECTED COMPONENTS OF NUCLEAR REACTOR SAFETY SYSTEMS	33
ACKNOWLEDGMENTS.	43
REFERENCES	52
APPENDIX A. Some Useful Figures and Tables for the BAZE Procedure	54
APPENDIX B. A Procedure for Selecting a Gamma Prior Distribution	70

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, process disclosed, or represents that its use would not infringe privately owned rights.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

NOTATION

a	- prior shape parameter
b	- prior scale parameter
b_0	- reference prior scale parameter
BAZE	- <u>B</u> ayesian <u>Z</u> ero-Failure
BWR	- Boiling Water Reactor
CRBR	- Clinch River Breeder Reactor
ERDA	- Energy Research and Development Administration
f/h	- failures per hour
$f(\lambda)$	- prior probability density function of the failure-rate λ
$f(\lambda 0 \text{ failures})$	- posterior probability density function of the failure-rate λ conditional on 0 observed failures in a test of nt unit-hours
γ	- posterior assurance
$(1.0-\gamma)$	- posterior risk
$I(a,x)$	- incomplete gamma function - $\int_0^x y^{a-1} e^{-y} dy$
k	- discrimination ratio (λ_1/λ_0)
λ	- failure-rate
λ_0	- specified failure-rate
λ_1	- criterion failure-rate ($k\lambda_0$)
λ^*, λ_*	- generic failure-rate

LL	- 50(1-p ₀)th percentile of a gamma prior distribution; lower prior limit
LMFBR	- Liquid Metal Fast Breeder Reactor
MFR	- Median Failure Rate
MTTF	- Mean Time to Failure
n	- number of test units
n ₀	- required number of test units
nt	- unit-hours of testing
(nt) ₀	- required unit-hours of testing
P ₀	- prior assurance
P(·)	- probability
P(x failures λ)	- conditional probability of x failures in a test of nt unit-hours with an underlying failure-rate of λ for each item
P(0 failures)	- unconditional probability of passing the BAZE test; unconditional probability of 0 failures in a test of nt unit-hours
P(0 failures λ _* ≤ λ ≤ λ*)	- conditional probability of passing the BAZE test; conditional probability of 0 failures in a test of nt unit-hours
P(x failures)	- unconditional probability of x failures in a test of nt unit-hours
P(λ _* ≤ λ ≤ λ* x failures)	- conditional probability that the failure-rate is contained in the interval [λ _* , λ*] given x failures in a test of nt unit-hours

POC	- Posterior Operating Characteristic
PWR	- Pressurized Water Reactor
θ_{γ}	- 100(γ)th percentile of the standard gamma distribution
t_0	- required test duration
t	- test duration
UL	- 50($1+p_0$)th percentile of a gamma prior distribution; upper prior limit
X	- failure-time random variable

A BAYESIAN ZERO-FAILURE (BAZE) RELIABILITY DEMONSTRATION
TESTING PROCEDURE FOR COMPONENTS OF NUCLEAR
REACTOR SAFETY SYSTEMS

Abstract

A Bayesian-Zero-Failure (BAZE) reliability demonstration testing procedure is presented. The method is developed for an exponential failure-time model and a gamma prior distribution on the failure-rate. A simple graphical approach using percentiles is used to fit the prior distribution. The procedure is given in an easily applied step-by-step form which does not require the use of a computer for its implementation. The BAZE approach is used to obtain sample test plans for selected components of nuclear reactor safety systems.

I. INTRODUCTION

Most government and military contracts for hardware development include a numerical reliability requirement in the specifications. For example, a certain recent contract required an overall system failure-rate no larger than 11.64×10^{-6} f/h. In addition, most contracts require quantitative demonstrated assurance that such a requirement has been met. MIL-STD-781C[†] provides a standard which can be used to demonstrate such a requirement for times-to-failure that are exponentially distributed. The standard may be used for preproduction (qualification) tests, as well as production reliability acceptance (demonstration) tests. A typical reliability demonstration statement is that a failure-rate requirement of X failures/h be demonstrated with Y% confidence.

The purpose of this report is to develop a Bayesian reliability demonstration testing procedure for exponentially distributed failure times which can be easily and effectively used to demonstrate component/subsystem/system reliability conformance to stated requirements. The procedure will also be used to develop suggested test plans for various components used in nuclear power reactor safety systems. This procedure may be used to verify specified and projected component failure-rates in LMFBR safety systems. However, the procedure is a general one and its use is not restricted to nuclear power

[†]MIL-STD-781C "Reliability Qualification and Production Acceptance Tests: Exponential Distribution," Washington, D.C.: U.S. Government Printing Office, (Draft), August, 1976.

safety systems. It may also be used to demonstrate reliability for such equipment categories as ground equipment, shipboard equipment, avionic equipment, weapons systems, and surveillance equipment.

Over the past two decades numerous classical reliability demonstration testing methods have been devised for various failure-time distributions. Classical demonstration test plans for components having an exponential failure-time distribution (constant failure-rate) may be fixed time (Type I Censoring), fixed number of failures (Type II Censoring), or sequential tests. In addition, such tests may be conducted either with or without the replacement of failed items when failures occur during the test. One example of a classical procedure is MIL-STD-781C which gives various test procedures derived under the assumption of a constant failure-rate. These tests are based on various levels of producer's and consumer's risk, design ratios, and the confidence level of the test. In these tests, a simple statistical hypothesis of the form

$$H: \lambda = \lambda_0 \text{ (specified failure-rate)}$$

$$A: \lambda = \lambda_1 \text{ (maximum acceptable failure-rate)}$$

is tested, where λ is the (unknown) failure-rate of the device and $\lambda_1 > \lambda_0$. The producer's risk is the probability that, if H is true, A will be accepted, while the consumer's risk is the probability that, if A is true, H will be accepted. The design

ratio is defined as the ratio of λ_1 to λ_0 . The text by Mann, Schafer, and Singpurwalla (1974) gives an excellent discussion of the basis upon which these and other classical test plans have been developed.

In practice, it is often the case that the reliability parameters of interest, such as MTTF, reliable life, failure-rate, etc., most realistically should be treated as random variables and not as constant values. The statistical distribution which expresses the true underlying variation in the parameter is called the prior distribution of the parameter (when treated as a random variable). This approach has been taken in previous reactor safety analyses, such as the Rasmussen study.* In that study, the prior distribution for the reactor component failure-rates was taken to be the log-normal distribution.** Such an approach permits the reliability quantity of interest to vary randomly due to such factors as environmental effects, plant-to-plant differences, maintenance effects, and different operational demands.

By treating the parameter as a random variable, a Bayesian approach may be considered. The main advantage of the Bayesian approach is that the resulting estimates are computed from all available information, and not just narrowly defined test data

*WASH 1400 Appendix III

**Ibid., p. II-40

of precise content. Rather, there exist two sources of information regarding the Bayesian procedure. One source of information, the so-called "prior information," expresses the sum total of engineering judgment and belief concerning the underlying prior distribution of the parameter of interest. It is precisely this distribution which expresses the inherent variability of the parameter itself. The other source of information is the statistical model used to describe either the time-to-failure data or the test results themselves. Both sources of information are combined via Bayes Theorem [see Waller and Martz (1975)] to produce a statement such that the probability that the failure-rate does not exceed the specified value is Y%.

Such an approach is particularly applicable for deriving test plans for demonstrating the component failure rates of proposed nuclear reactors. The reason for this is that failure data are becoming available for similar components in use in existing power reactor systems throughout the world. These data, which are continuously being compiled and reported in numerous data base systems, represent the "prior information" for similar components to be used in advanced reactor systems, such as LMFBR systems.

The resulting Bayesian test plans are generally resource-effective, due to the use of all available information and judgment concerning the parameter of interest. If the prior information supports an adequately reliable component, then less testing will usually be required compared to the classical case.

If the opposite is true, then more testing may be required. A general introduction to the use of Bayesian methods in reliability is given by Waller and Martz (1975). (1976a), (1976b).

A brief review of Bayesian reliability demonstration procedures is given in Section II. A procedure for choosing the prior distribution is presented in Section III. The BAZE procedure is developed in Section IV. Section V contains an example illustration of the method, as well as an examination of the sensitivity of the results to the chosen prior distribution. Appropriate prior distributions are fitted to various components used in nuclear power systems in Section VI. Section VII presents a selection of sample BAZE test plans for these reactor components.

II. BAYESIAN RELIABILITY DEMONSTRATION TESTING

The state of the art of Bayesian reliability demonstration test procedures will now be reviewed. One of the earliest references to Bayesian reliability demonstration plans is that of Bonis (1966). Since that time numerous Bayesian schemes have been developed. Easterling (1970) presented a somewhat modified Bayesian demonstration procedure. Schafer and Singpurwalla (1970) developed a sequential Bayes procedure for obtaining required test plans. Schafer (1969), (1971), and (1973) has considered three types of Bayesian plans: (1) Bayesian fixed time tests, (2) mixed Bayesian/classical, and (3) Bayesian sequential tests. Following along these same lines, Goel et al., (dates

unknown) developed Bayesian plans for slightly different criteria. Blumenthal (1973) has also developed Bayesian test plan procedures. Guild (1968), (1973) has developed what he refers to as "median failure rate" (MFR) reliability demonstration plans. Other Bayesian plans have also been considered by Balaban (1969), (1975) and Ramos (1970). Joglekar (1975) discusses several of these Bayesian testing schemes. Recently, Goel and Joglekar [1976] have prepared a comprehensive account of the state of the art of Bayesian reliability acceptance sampling. This five-part series provides an excellent introduction to the subject.

One of the major problems with most Bayesian test plans is the relative difficulty in obtaining a desired plan in practice. This is due to the presence of additional prior parameters, as well as the relative complexity of the method. For example, most of the above Bayesian plans are derived for a constant failure-rate model and a gamma prior distribution on the failure-rate [see Waller and Martz (1975)].

The gamma prior distribution is the natural conjugate prior distribution for the constant failure-rate model. Schafer (1969) investigated data from 32 different equipments and found that in 29 cases a gamma prior distribution adequately fit the data. Others have likewise observed the suitability and versatility of the gamma prior distribution. For these reasons it is also considered here. However, it is frequently not an easy task to

identify an appropriate gamma prior distribution and, once this has been done, to obtain the required test plan. The choice of test plan criteria, e.g., the consumer and producer risks that are to be controlled, can also complicate the determination of the required plan. Certain criteria yield plans that are simple to determine. One of the easiest of the above Bayesian procedures to use in practice is that given by Guild (1973). A more general version of this procedure is developed in Section IV for use here. An earlier version of this BAZE procedure was presented by Martz and Waller (1976c). The current BAZE procedure contains a more useful and practical procedure for selecting the prior distribution, which has been incorporated into the BAZE procedure itself. The new procedure also contains a simple method for examining the sensitivity of the resultant BAZE test plan to the chosen prior distribution. This serves to make the method more useful in practice.

Three somewhat distinctive aspects of the procedure should be mentioned before we begin the development. First, the criterion upon which the procedure is based is simple, pertinent, and easy to grasp. Second, the fitting of the prior distribution is an integral part of the procedure and is based on the use of information regarding two percentiles of this distribution. Third, the procedure is straightforward and easy to apply in practice, with only a few simple graphs and tables and pocket calculator required. Together these provide a useful Bayesian procedure for a large variety of applications.

III. SELECTING A GAMMA PRIOR DISTRIBUTION

We assume that the time-to-failure of interest is an exponentially distributed random variable with failure-rate parameter λ . For Bayesian analyses in this model, the family of gamma distributions with probability density functions given by

$$f(\lambda) = \frac{b^a}{\Gamma(a)} \lambda^{a-1} e^{-b\lambda}, \quad \lambda, a, b > 0 \quad (1)$$

provides conjugate prior models for λ . In practice, an engineer must select a member of this family as the prior distribution to be used in determining the BAZE test plan to be discussed in the next section. The selection of a particular prior distribution is accomplished by identifying values for the prior shape parameter a and prior scale parameter b . The parameter a can be further interpreted as the number of pseudo failures in a prior life test of duration b pseudo hours. The mean and variance of λ are given by (a/b) and (a/b^2) , respectively.

Some additional benefits in using a gamma prior distribution are as follows:

a. The two parameters give sufficient flexibility to model a variety of shapes of prior distributions likely to be encountered in practice. The following indicate the possible shape characteristics of a conjugate gamma prior distribution.

b>0	L-shaped or decreasing	Exponential	Unimodal with mode at b(a-1)
	0<a<1	a=1	a>1

b. The positive skewness can account for general behaviors of assessed data in which less likely but large deviations may occur (such as abnormally high failure-rates due to batch defects, environmental degradation, and other outlier causing effects).

c. In practice, the gamma family often satisfactorily fits observed data [see Schafer (1969)].

d. The positively skewed nature of the gamma family provides a protective, positive-type bias which is retained when the distribution is propagated by means of a Bayesian analysis.

A simple method for determining values for a and b will now be described. The method requires an engineer to provide upper and lower percentile values. Once these are given, a simple graphical or table look up, in addition to a few simple calculations, yields the corresponding values of a and b.

The engineer must provide two values of the failure-rate λ , referred to as the lower prior limit (LL) and upper prior limit (UL), such that

$$P(\lambda < LL) = P(\lambda > UL) = (1.0-p_0)/2, \quad (2)$$

where p_0 is required to be equal to one of the values 0.95, 0.90, or 0.80, and where $LL < UL$. That is, LL and UL are specified such that there is an equal $50(1.0-p_0)\%$ chance that the true (unknown) failure-rate is either less than LL or greater than UL , respectively. Thus LL and UL are the respective $50(1.0-p_0)$ th and $50(1.0+p_0)$ th percentiles of the prior gamma distribution. For example, suppose that an engineer's best prior judgement or belief is that $P(\lambda < 1.0 \times 10^{-7} \text{ f/h}) = 5\%$ and that $P(\lambda > 1.0 \times 10^{-5} \text{ f/h}) = 5\%$. Thus $(1.0-p_0)/2 = 0.05$, $p_0 = 0.90$, $LL = 1.0 \times 10^{-7} \text{ f/h}$, and $UL = 1.0 \times 10^{-5} \text{ f/h}$. The quantity $100p_0\%$ is the prior assurance that the interval (LL, UL) contains the failure-rate of interest. Since engineers are increasingly becoming accustomed to working with 5% error probabilities, it is likely that $p_0 = 0.90$ will normally be used. However, 80% and 95% prior assurances can also be used. For example, in the Rasmussen study (WASH-1400), 90% prior assurance was considered. If the prior assurance is free to be selected, it is recommended that $p_0 = 0.90$ be used. In this case, LL and UL become the lower and upper prior 5% bounds, respectively, on the failure-rate.

A mathematical justification of the procedure to be described is given in Appendix B. A step-by-step outline of the procedure is as follows:

- Step 1: Specify the values of LL, UL, and $p_0 = 0.80, 0.90, \text{ or } 0.95$ that represent the totality of your best judgement and belief about the failure-rate λ of interest. These values are selected in accordance with (2).
- Step 2: Compute the value of $\log_{10} (UL/LL)$.
- Step 3: For the value of p_0 chosen in Step 1 and the value of $\log_{10} (UL/LL)$ calculated in Step 2, read the required value of shape parameter a from Figure A1 (see Appendix A).
- Step 4: For the value of p_0 from Step 1 and for the value of a found in Step 3, read the value of b_0 from Figure A2 (see Appendix A).
- Note: Table A2 (see Appendix A) may be used in lieu of Figure A2 to obtain b_0 , depending upon which is more convenient to use. If necessary, interpolate in Table A2.
- Step 5: For the value of LL from Step 1 and the value of b_0 from Step 4, calculate the required value of the scale parameter b according to

$$b = b_0 (1.0 \times 10^{-6} f/h) / LL.$$

Let us illustrate this procedure by means of an example.

Example: For a certain component of interest, suppose it is believed that the failure-rate λ is such that $P(\lambda < 1.0 \times 10^{-7} \text{ f/h}) = 5\%$ and $P(\lambda > 1.0 \times 10^{-5} \text{ f/h}) = 5\%$. It is required to identify the particular gamma distribution which is consistent with this belief.

Step 1: $LL = 1.0 \times 10^{-7} \text{ f/h}$, $UL = 1.0 \times 10^{-5} \text{ f/h}$, and $p_0 = 0.90$.

Step 2: $\log_{10}(UL/LL) = \log_{10}(10^2) = 2.0$.

Step 3: From Figure A1, for $p_0 = 0.90$ and $\log_{10}(UL/LL) = 2.0$, we find $a = 0.84$.

Step 4: For $a = 0.84$ and $p_0 = 0.90$, Table A2 yields $b_0 = 2.6723 \times 10^4 \text{ h}$.

Step 5: The required scale parameter b becomes

$$b = \frac{(2.6723 \times 10^4 \text{ h})(1.0 \times 10^{-6} \text{ f/h})}{(1.0 \times 10^{-7} \text{ f/h})}$$

$$= 2.6723 \times 10^5 \text{ h}.$$

By means of the incomplete gamma function code INCGAM (written by D.E. Amos and S.L. Daniel of Sandia Laboratories, Albuquerque, NM, November 1974), the actual tail-area probabilities for a gamma distribution with parameters $a = 0.84$, $b = 2.6723 \times 10^5 \text{ h}$ are 0.05, as desired. However, this is not always the case. Due to numerical and round-off errors, the upper tail area may not be exactly equal to $(1 - p_0)/2$. In Step 5, the denominator of the expression for b was LL . This

was done to insure that the lower tail area will always be $(1-p_0)/2$, while the upper tail area may depart somewhat from the desired value $(1-p_0)/2$. We chose to hold the lower tail area fixed because of the positively skewed nature of the gamma distribution.

One final note concerns the usefulness of Figures A1 and A2 in practice. The effective range of values of a considered in Figures A1 and A2 is between 0.25 and 10.0. Experience with fitting gamma prior distributions to failure-rate data indicates that this range should contain nearly all situations likely to be encountered in practice. This range is consonant with ratios of UL to LL roughly between 0.3 and 4.0 orders of magnitude (powers of 10).

IV. BAYESIAN ZERO-FAILURE (BAZE) RELIABILITY DEMONSTRATION TESTING

The BAZE reliability demonstration procedure was developed by Martz and Waller (1976c). This procedure is given here in an expanded form which includes the procedure for fitting a gamma prior distribution, described in the preceding section, and other features as well.

This section describes how to construct and apply Bayesian fixed time demonstration test plans of the replacement type, called BAZE plans, for systems/subsystems/components having a constant failure-rate. The BAZE procedure is appropriate for testing time-dependent chance failure mechanisms.

To begin, consider a device, henceforth referred to as a "component," having an exponential failure time distribution with failure-rate λ . Thus, the failure-time random variable X of this component is assumed to follow the well-known exponential probability density function given by

$$f(x|\lambda) = \lambda e^{-\lambda x}, \quad x \geq 0, \quad \lambda > 0. \quad (3)$$

As mentioned earlier, it is assumed here that the prior distribution of λ is the natural conjugate gamma distribution with probability density function given by

$$f(\lambda) = \frac{b^a}{\Gamma(a)} \lambda^{a-1} e^{-b\lambda}, \quad \lambda, a, b > 0, \quad (4)$$

where a is the prior shape parameter and b is the prior scale parameter.

The test plans considered here assume that n identical components are tested each for a prespecified length of time t , the test duration. The quantities n and t are to be determined consistent with the following statistical test criterion. The test criterion is as follows: if no failures occur, the test is passed, while if one or more failures occur, the test is failed. Thus the test is terminated either at the prespecified test time t or at the time of the first component failure, whichever occurs first. Such "zero-failure" test plans usually require the smallest unit-hour test combination nt for a stated confidence, and are thus test resource-effective. In addition,

by restricting consideration to zero-failures, such test plans are easy to obtain. Now the probability of obtaining exactly zero failures during the test is given by

$$P(0 \text{ failures} | \lambda) = e^{-nt\lambda}. \quad (5)$$

The posterior distribution of λ is also a gamma distribution with scale parameter $(b + nt)$ and shape parameter a . Thus, conditional on zero failures in nt unit-hours of testing, the posterior probability density function of λ becomes

$$f(\lambda | 0 \text{ failures}) = \frac{(b+nt)^a}{\Gamma(a)} \lambda^{a-1} e^{-(b+nt)\lambda}. \quad (6)$$

In order to find the required unit-hour test combination nt , some criterion regarding the desired confidence level of the demonstration test must be given. The plans presented here satisfy the posterior risk criterion given by

$$P(\lambda \leq k\lambda_0 | 0 \text{ failures}) = \gamma, \quad (7)$$

where $P(\cdot)$ is a probability function. Here λ_0 is the specified failure-rate. If we define $\lambda_1 \equiv k\lambda_0$, then λ_1 is referred to as the test criterion failure-rate and k is known as the discrimination ratio. The test criterion in (7) is interpreted as follows. In a test that is passed, i.e., zero failures occur, the probability is $100\gamma\%$ that the component failure-rate does not exceed $(k\lambda_0)$. Here $(1.0-\gamma)$ will be referred to as the posterior risk and γ will

be referred to as the posterior assurance. The word "posterior" denotes that the assurance pertains to tests which have been passed. Of course, values of γ and k are required in order to determine the required test plan. More will be said about the selection of these values later.

Recall that the test procedure requires that n items be placed on life test for t hours. If no failures occur, the test is passed. Now, if the test is passed, it may be claimed that a failure-rate not exceeding $(k\lambda_0)$ has been demonstrated with $100\gamma\%$ posterior assurance. If a single failure occurs, the test is failed, and the forgoing claim cannot be made.

The BAZE procedure described requires specification of values for the following five quantities:

- LL(lower prior limit)
- UL(upper prior limit)
- p_0 (the prior assurance)
- λ_1 (the criterion failure-rate)
- γ (the posterior assurance).

It is noted that the criterion failure-rate λ_1 may be equal to the specified failure-rate λ_0 . In this case $k=1$; otherwise, $k \neq 1$. The procedure is developed by writing

$$\begin{aligned}
 p(\lambda \leq \lambda^* | 0 \text{ failures}) &= \int_0^{\lambda^*} \frac{(b+nt)^a}{\Gamma(a)} \lambda^{a-1} e^{-(b+nt)\lambda} d\lambda \\
 &= \frac{I(a, [b+nt]\lambda^*)}{\Gamma(a)}, \quad (8)
 \end{aligned}$$

where $I(a, x)$ is the widely studied incomplete gamma function defined by

$$I(a, x) = \int_0^x y^{a-1} e^{-y} dy. \quad (9)$$

Tables and computer routines for evaluating this function are widely available for use in our development. Hence, when LL , UL , p_0 , γ , and λ_1 are specified, the step-by-step procedure for obtaining the required BAZE test plan is as follows:

Step 1: For the specified values of LL and UL , compute the value of $\log_{10}(UL/LL)$.

Step 2: For $p_0 = 0.80, 0.90, \text{ or } 0.95$, and the value of $\log_{10}(UL/LL)$ from Step 1, obtain the value of the prior shape parameter a from Figure A1 (Appendix A).

Step 3: For p_0 and the value of a from Step 2, obtain the value of b_0 from either Figure A2 or Table A2.

Step 4: For the value of LL and b_0 from Step 3, calculate the value of the prior scale parameter b , in appropriate time units, according to

$$b = b_0 (1.0 \times 10^{-6} \text{ f/h}) / LL.$$

Step 5: Obtain the value of θ_γ from Table A1 (Appendix A) for the value of a found in Step 2 and γ . Note: Table A1 may be used directly for $a = 0.0001$

(0.0001) 0.01 (0.001) 0.10 (0.01) 1.0 (0.1) 5.0
 (0.5) 10.0 (1.0) 50.0 and $\gamma = 0.99, .975, .95,$
 $.90, .85, .80, .75, .70, .60, .50$. For other
 values of a and/or γ , either interpolate in Table
 A1 or solve the equation given by

$$\int_0^{\theta_\gamma} \gamma \lambda^{a-1} e^{-\lambda} d\lambda - \gamma \Gamma(a) = 0$$

for θ_γ . It is mentioned here that in constructing
 Table A1 the incomplete gamma function in the above
 equation was numerically calculated by use of the
 code INCGAM, written by D.E. Amos and S.L. Daniel
 of Sandia Laboratories, Albuquerque, NM, November
 1974. The above equation was solved on a CDC 6600
 computer by use of the root-solving code ZEROIN,
 written by L.F. Shampine and H.A. Watts, also of
 Sandia Laboratories, September 1970.

Step 6: With λ_1 and the θ_γ value from Step 5, and the value
 of b from Step 4, solve for the required BAZE unit-
 hours of test $(nt)_0$ given by

$$(nt)_0 = (\theta_\gamma - b\lambda_1)/\lambda_1.$$

Note: Negative values of $(nt)_0$ can occur. A nega-
 tive value of $(nt)_0$ can be interpreted as a demon-
 stration of the failure-rate λ_1 , at the stated
 posterior assurance level, without the need for
 further testing. This situation occurs whenever

the prior distribution satisfactorily meets the assurance requirement.

Step 7: Calculate the sensitivity of the final plan and the posterior assurance to errors in the prior assurance, as well as the sensitivity of the final plan to errors in the posterior assurance and criterion failure-rate (cf Section V. Example).

Step 8: Identify the final plan to be used based on the results of the sensitivity analysis conducted in Step 7 and the unconditional probability of passing the test [from (10) or (11) below].

Step 9: The required test duration t_0 and number of test units n_0 is given by any pair of values satisfying $n_0 t_0 = (nt)_0$, where $(nt)_0$ is the required unit-hours of test from Step 8 and n_0 is a positive integer. The values n_0 and t_0 are selected by outside considerations, such as test time constraints and the number of test units available.

It is noted here that if $a = 1$, $b = 0$, and $\gamma = 0.50$, then the BAZE test plan is exactly the same as the classical test plan. If $a = 1$ and $\gamma = 0.50$, then the BAZE test plan will always require less unit-hours of testing, depending upon the magnitude of b .

For a specified fixed value of a , the required BAZE unit-hours of test decreases as γ decreases, b increases, or k increases. Consequently, for given values of a and b , an opportunity is

present for the test designer to trade between decreasing testing costs [decreasing $(nt)_0$] and decreasing test assurance [decreasing γ and/or increasing λ_1]. Such tradeoffs are illustrated in Section V.

Suppose that high-reliability components with failure-rate on the order of magnitude of 10^{-6} f/h are being considered. If the prior mean is in this range, then it is true that as the spread between LL and UL increases both a and b will generally decrease. This is seen in Figures A1 and A2. In fact, in situations such as this, a will frequently be less than one. This situation occurs whenever the prior variance is quite large, i.e., whenever the prior distribution is diffuse [see Waller and Martz (1975)]. Such situations frequently occur in reliability and this fact has motivated the fine grid of a values less than one considered in Table A1.

A quantity of particular interest to the producer is the unconditional probability of passing the test when using a test plan with (nt) unit-hours of test. The unconditional probability of not passing the test is, in some sense, the "producer's risk" of the BAZE procedure. The probability of passing the test must be sufficiently large in order that the producer be willing to conduct the test. This probability also conveys to the consumer the likelihood that the required posterior assurance will be realized. This probability is given by

$$P(\text{Passing the Test}) \equiv P(0 \text{ failures}) = [b/(b+nt)]^a. \quad (10)$$

Related to this quantity is the conditional probability of passing the test when it is known that the true (unknown) failure-rate λ lies within a given interval $[\lambda_*, \lambda^*]$, where $0 \leq \lambda_* < \lambda^* \leq \infty$.

In this case we have

$$P(\text{Passing the Test} | \lambda_* \leq \lambda \leq \lambda^*) = \left(\frac{b}{b+nt} \right)^a \left[\frac{I(a, [nt+b]\lambda^*) - I(a, [nt+b]\lambda_*)}{I(a, b\lambda^*) - I(a, b\lambda_*)} \right], \quad (11)$$

where $I(a, x)$ is defined in (9). It is also noted that, if $\lambda_* = 0$ and $\lambda^* = \infty$, then the conditional probability of passing the test given in (11) reduces to the unconditional probability given in (10). In practice, an interval $[\lambda_*, \lambda^*]$ which is certain to contain the failure-rate can frequently be identified. If this can be done, the (11) should be used in place of (10).

What posterior assurance do we have about the failure-rate if one or more failures occur during the test, i.e., if the test is failed? Suppose that failed items are replaced as they occur during the test. Then

$$P(x \text{ failures} | \lambda) = \frac{e^{-nt\lambda} (nt\lambda)^x}{x!}, \quad x = 0, 1, \dots, \quad (12)$$

and the posterior probability density function of λ becomes

$$f(\lambda | x \text{ failures}) = \frac{(b+nt)^{a+x}}{\Gamma(a+x)} \lambda^{a+x-1} e^{-(b+nt)\lambda}. \quad (13)$$

Now, for any specified interval $[\lambda_*, \lambda^*]$, where $0 \leq \lambda_* < \lambda^* \leq \infty$, we have

$$P(\lambda_* \leq \lambda \leq \lambda^* | x \text{ failures}) = \frac{1}{\Gamma(a+x)} \left[I(a+x, [b+nt]\lambda^*) - I(a+x, [b+nt]\lambda_*) \right]. \quad (14)$$

In particular, we have

$$P(\lambda \leq k\lambda_0 | x \text{ failures}) = I(a+x, [b+nt]k\lambda_0) / \Gamma(a+x). \quad (15)$$

It is observed that, if $x = 0$, then (15) is equal to the specified posterior assurance γ . For the criterion failure-rate $(k\lambda_0)$, as x increases (15) becomes smaller than γ . Thus, as more failures occur, we have less posterior assurance about the failure-rate not exceeding the criterion value.

Also, the unconditional probability of obtaining exactly x failures in a test of nt unit-hours duration is

$$P(x \text{ failures}) = \frac{b^a (nt)^x \Gamma(a+x)}{\Gamma(a) \Gamma(x+1) (nt+b)^{a+x}}. \quad (16)$$

The statistical performance characteristics of the chosen plan are completely summarized by means of the posterior operating characteristic (POC) curve. This curve is obtained by plotting $P(\lambda \leq \lambda^* | 0 \text{ failures})$ as a function of λ^* . Unlike classical OC curves, the POC curve is a cumulative distribution function. This probability may be computed from (8).

We cannot emphasize enough that both the consumer and producer must be willing to pay the price for increasing assurance of small failure-rates by increasing the unit-hours of testing. This will be illustrated in the example in the next section.

V. EXAMPLE

In order to fully illustrate the BAZE procedure, consider the following example. Consider a certain component whose random failure-rate is required to be demonstrated. How many unit-hours of testing with no countable failures are required in order to be able to claim that $P(\lambda \leq 2.0 \times 10^{-6} \text{ f/h}) \geq 0.70$, after the test has been passed? From past experience and engineering judgement, suppose it is believed that

$$P\{\lambda \leq 8.5 \times 10^{-8} \text{ f/h}\} = P\{\lambda \geq 4.8 \times 10^{-6} \text{ f/h}\} = 5\%.$$

Thus $\lambda_1 = \lambda_0 = 2.0 \times 10^{-6} \text{ f/h}$, $\gamma = 0.70$, $LL = 8.5 \times 10^{-8} \text{ f/h}$, $UL = 4.8 \times 10^{-6} \text{ f/h}$, and $p_0 = 0.90$. Following the step-by-step procedure in the preceding section yields the following results:

Step 1: $\log_{10}(UL/LL) = 1.75$.

Step 2: For $\log_{10}(UL/LL) = 1.75$ and $p_0 = 0.90$, we read $a = 1.0$ from Figure A1.

Step 3: For $p_0 = 0.90$ and $a = 1.0$, we obtain $b_0 = 5.1293 \times 10^4 \text{ h}$ from Table A2.

Step 4: For $LL = 8.5 \times 10^{-8} \text{ f/h}$ and $b_0 = 5.1293 \times 10^4 \text{ h}$, we calculate

$$\begin{aligned} b &= (5.1293 \times 10^4 \text{ h}) (1.0 \times 10^{-6} \text{ f/h}) / (8.5 \times 10^{-8} \text{ f/h}) \\ &= 603.44 \times 10^3 \text{ h}. \end{aligned}$$

Step 5: For $a = 1.0$ and $\gamma = 0.70$, we obtain $\theta_{0.70} = 1.203973$ from Table A1.

Step 6: For $\lambda_1 = 2.0 \times 10^{-6} \text{ f/h}$, $\theta_{0.70} = 1.203973$, and $b = 0.60 \times 10^6 \text{ h}$, the required BAZE unit-hours of test $(nt)_0$ are calculated to be

$$(nt)_0 = [1.203973 - (0.60 \times 10^6 \text{ h})(2.0 \times 10^{-6} \text{ f/h})] / (2.0 \times 10^{-6} \text{ f/h})$$

$$= 1987 \text{ unit-hours.}$$

The POC curve for this plan is plotted in Figure 1.

Step 7: Let us first examine the sensitivity of the BAZE plan to changes in the posterior assurance γ and criterion failure-rate λ_1 . We express the varying criterion failure-rate λ_1 as a function of k according to $\lambda_1 = k\lambda_0 = k(2.0 \times 10^{-6} \text{ f/h})$. Table I gives the resultant test plan as a function of a selected grid of values of k and γ . The plan $(nt)_0 = 1987$ unit-hours is indicated in table for $k = 1.0$ and $\gamma = 0.70$. It is clearly observed that the required unit-hours of test increase as γ increases and k decreases. It is observed that the optimal test plan is quite sensitive to increasing γ and also somewhat sensitive to decreasing k , for the range of k indicated. The "zeros" indicate those situations in which the prior distribution is sufficient to guarantee that the risk is at or below the specified level, without the need for additional testing.

Fig. 1. The POC curve for Test Plan $(nt)_0 = 1987$ Unit-Hours of Test.

TABLE I

REQUIRED UNIT-HOURS OF TESTING FOR
SELECTED VALUES OF k AND γ
($a = 1.0, b = 0.60 \times 10^6$)

γ	k										
	.5	.6	.7	.8	.9	1.0	1.1	1.2	1.3	1.4	1.5
.995	4005175	3237642	2699407	2278231	1953429	1702595	1493259	1319521	1171219	1044704	935057
.975	3348579	2474656	2034914	1745549	1449377	1244440	1076763	937833	815500	717457	624526
.950	2395732	1895443	1539009	1272333	1064246	897856	761646	648222	552205	469904	390577
.900	1738585	1318321	1044704	838116	673214	551293	446630	359410	285018	223552	167528
.850	1297125	989933	755086	585700	453956	346560	262327	194457	124652	77543	32373
.800	1079439	741198	549599	405899	294132	204719	131552	70599	19015	0	0
.750	788294	555245	390210	266434	170163	93147	30134	0	0	0	0
.700	563973	403311	259981	152483	68874	1987	0	0	0	0	0
.600	316291	163574	54494	0	0	0	0	0	0	0	0
.500	93147	0	0	0	0	0	0	0	0	0	0

Let us now determine the sensitivity of the BAZE plan to changes in the prior assurance. Suppose that, regarding the prior distribution, each tail area is actually 2.5%, rather than 5%, as we have assumed. Applying Steps 1-4 for $p_0 = 0.95$ yields $a = 1.36$ and $b = 929.70 \times 10^3 h$. Table II gives the resultant BAZE test plan for the same set of values of γ and k used in Table I. Table III gives the percentage change in the BAZE plans of Table II relative to the "nominal" plans given in Table I. It is observed from Table III that the BAZE plans are somewhat sensitive to a 100% error (assumed 5% when, in fact, 2.5%) in the tail areas of the prior distribution. Now, if $a = 1.36$ and $b = 929.70 \times 10^3 h$, the "actual" posterior assurance of the plan $(nt)_0 = 1987$ unit-hours is easily computed from (8) to be 75%, rather than 70% as required. Thus, we unknowingly would have more posterior assurance than required. Similarly, for any other BAZE test plan in Table I, we could compute the "true" posterior assurance relative to this "error" in fitting the prior distribution. Similarly, Tables IV and V consider the case where the actual tail areas of the gamma prior are 10%, instead of 5%, as assumed. From Table V, it is observed that the BAZE plans are fairly insensitive to this 100% error in the prior tail-area

TABLE II. Required Unit-Hours of Testing for Selected Valued of k and γ
(a = 1.36, b = 929.70 x 10³h)

$\gamma \backslash k$	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5
0.990	3466755.	2833963.	2351965.	2042971.	1779308.	1568377.	1395798.	1251982.	1130290.	1025994.	935586.
0.975	2619141.	2126785.	1775815.	1512558.	1307856.	1144070.	1010064.	898393.	803901.	722908.	652714.
0.950	1986835.	1600696.	1324832.	1118021.	957131.	823418.	723107.	635348.	561091.	497441.	442279.
0.900	1369130.	1085942.	883665.	731957.	613962.	519565.	442332.	377972.	323512.	276832.	236377.
0.850	1016911.	792426.	632080.	511819.	418284.	343456.	282232.	231213.	188043.	151040.	118971.
0.800	772714.	588929.	457653.	359196.	282619.	221357.	171234.	129465.	94121.	63825.	37572.
0.750	587545.	434621.	325390.	243466.	179747.	128713.	87066.	52311.	22902.	0.	0.
0.700	439706.	311422.	219790.	151066.	97615.	54853.	19867.	0.	0.	0.	0.
0.600	214583.	123903.	59059.	10427.	0.	0.	0.	0.	0.	0.	0.
0.500	46631.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.

TABLE III. Percentage Change in the BAZE Plans of Table II
Relative to Table I

$\gamma \backslash k$	.5	.6	.7	.8	.9	1.0	1.1	1.2	1.3	1.4	1.5
.990	13.443%	12.468%	11.431%	10.3	9.146%	7.883%	6.527%	5.068%	3.495%	1.792%	0.056%
.975	15.240	14.037	12.733	11.314	9.764	8.065	6.194	4.124	1.820	0.760	3.667
.950	17.068	15.595	13.958	12.128	10.069	7.735	5.066	1.986	1.609	5.860	10.964
.900	19.585	17.658	15.415	12.770	9.607	5.775	0.962	5.164	13.271	24.502	41.096
.850	21.602	19.217	16.290	12.614	7.858	1.465	7.587	21.392	45.026	94.782	267.49
.800	23.451	20.544	16.730	11.506	3.915	8.127	30.154	83.378	394.98		
.750	25.277	21.724	16.612	8.621	5.632	38.247	188.93				
.700	27.190	22.704	15.459	0.929	41.730	2660.6					
.600	32.155	24.254	8.377								
.500	46.718										

TABLE IV. Required Unit-Hours of Testing for Selected Values of k and γ

$$(a = 0.67, b = 330.68 \times 10^3 \text{ h})$$
[illegible]

TABLE V. Percentage Change in the BAZE Plans of Table IV
Relative to Table I

[illegible]

probabilities. If $a = 0.67$ and $b = 330.68 \times 10^3 h$, the actual posterior assurance of the plan $(nt)_0 = 1987$ unit-hours is 66%, as compared to the desired value of 70%. In this case, we have less posterior assurance than required.

Step 8: The unconditional probability of passing the test $(nt)_0 = 1987$ unit-hours is calculated from (10) as

$$\begin{aligned} P(\text{Passing the Test}) &= [(0.60 \times 10^6) / (0.60 \times 10^6 + 1987)] \\ &= 0.9967. \end{aligned}$$

Table VI gives the unconditional probability of passing the corresponding test given in Table I. In practice, tables such as Table VI are useful to the producer in selecting the final test plan. From the results of Step 7 and this step, the final plan to be used is $(nt)_0 = 1987$ unit-hours of test.

Step 9: A single component may be tested for 1987 hours; five components for 397.4 hours; ten components for 198.7 hours; etc. If no failures occur, it may be claimed that a failure-rate of $2.0 \times 10^{-6} f/h$ or less has been demonstrated with 70% assurance.

At this point the question can be raised; namely, how many unit-hours of testing are required when using an alternate classical (standard non-Bayesian) procedure? By judicious choice of producer and/or consumer risks, it is possible to "show" that classical test plans result in either larger or smaller total unit-hours of testing. Thus, a person advocating a purely classical approach could "show" that his procedure results in

TABLE VI

THE UNCONDITIONAL PROBABILITIES OF PASSING
THE CORRESPONDING TESTS IN TABLE I

y	k										
	.5	.6	.7	.8	.9	1.0	1.1	1.2	1.3	1.4	1.5
.990	.130	.156	.182	.208	.235	.261	.237	.313	.339	.365	.391
.975	.163	.195	.228	.260	.293	.325	.358	.390	.423	.455	.488
.950	.200	.240	.280	.320	.361	.401	.441	.481	.521	.561	.601
.900	.261	.313	.365	.417	.469	.521	.573	.625	.677	.730	.782
.850	.316	.380	.443	.506	.569	.633	.696	.759	.822	.886	.949
.800	.373	.447	.522	.596	.671	.746	.820	.895	.959	1.000	1.000
.750	.433	.519	.606	.692	.779	.866	.952	1.000	1.000	1.000	1.000
.700	.498	.598	.698	.797	.897	1.000	1.000	1.000	1.000	1.000	1.000
.600	.655	.786	.917	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
.500	.866	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000

less testing. On the other hand, a "Bayesian" can "show" the opposite to be the case. The correct answer lies in recognizing that the two procedures cannot be directly compared, due to the basic underlying philosophical difference regarding the interpretation of the failure-rate λ . In the classical approach, the failure-rate is a non-random (unknown) constant, while in the Bayesian approach it is an (unknown) value of a random variable. The proper procedure to be used should be based on this fact alone, and not on the basis of which procedure yields the smallest amount of testing. In some cases, the classical procedure will require less testing; in others, the BAZE procedure will require less. Since nuclear reactor components exhibit failure-rates which appear to be random, a Bayesian procedure, such as described here, should be used.

VI. PRIOR DISTRIBUTIONS AND ANALYSIS FOR SELECTED COMPONENTS OF NUCLEAR REACTOR SAFETY SYSTEMS

Table III 2-1 in Appendix III of the WASH 1400 Reactor Safety Study (1975) contains assessed estimates of the failure-rates of selected components of PWR and BWR safety systems. Upper and lower bounds, as well as the median, were computed from best available data for these failure-rates. The approach used there was also a Bayesian one and the random component failure-rates were assumed to follow a log-normal prior distribution. It is remarked here that the log-normal distribution is also a two-parameter positively skewed distribution similar to the gamma distribution used here. Although failure-rates were given on a

per demand and per hour basis, depending upon the failure mode, only the time-dependent failure modes whose failure-rates are given on a per hour basis will be considered here. The upper and lower bounds were computed to be 5% bounds, respectively. That is, the probability that the given interval contains the failure-rate for any particular system is 90%. Thus $p_0 = 0.90$. These bounds are reproduced in Table VII for these same components and corresponding failure modes. If available, failure-rates corresponding to US nuclear operational experience are also given.

Gamma prior distributions have been fitted to these data by means of the procedure outlined in Section III. These prior distributions may be used in future test programs, such as those required in demonstrating the safety and reliability of planned LMFBR systems. The corresponding gamma parameters a and b , as well as the prior mean and variance, are given in Table VII. It is observed that there are only three different "shapes" of gamma priors present; namely, $a = 0.50, 0.84$, and 2.45 . This is due to the fact that the ratio of UL to LL takes on only three different order of magnitude values; namely, 3, 2, or 1. The priors corresponding to $a = 0.50$ and 0.84 are quite diffuse; that is, the prior-variance is quite large for these priors.

Table VII also presents certain probabilities of interest associated with the corresponding fitted gamma prior distributions. The quantities P_1, P_2, P_3, P_4 , and P_5 in Table VII represent the probabilities defined by

- $P_1 \equiv \text{Prob. } (\lambda \leq \text{Prior Mean}),$
- $P_2 \equiv \text{Prob. } (\lambda \leq \text{Median of a Log-Normal Prior}),$
- $P_3 \equiv \text{Prob. } (\lambda \leq \text{US Nuclear Operating Experience Value}),$
- $P_4 \equiv \text{Prob. } (\lambda \leq \text{Lower 5\% Limit}),$
- $P_5 \equiv \text{Prob. } (\lambda \geq \text{Upper 5\% Limit}).$

These probabilities were calculated by means of the incomplete gamma function code, INCGAM, mentioned in Section III. Since the values of P_2 in Table VII are all less than 0.5, the gamma prior distributions tend to favor somewhat larger failure-rates than a log-normal distribution with the same 5% tail-area probabilities. The gamma approach is slightly conservative. Further, the values of P_4 and P_5 are included as a check on the accuracy of the procedure used to fit the gamma priors. The P_4 values are all 5%, to three decimal places, while the values of P_5 deviate somewhat from the desired value of 5% for $a = 0.50$ and 2.45 . This departure is due to errors in reading and interpolating earlier, and slightly less accurate, versions of Figure A1 and Table A2, respectively.

VII. SUGGESTED BAZE TEST PLANS FOR SELECTED COMPONENTS OF NUCLEAR REACTOR SAFETY SYSTEMS

The purpose of this section is to propose several possible BAZE test plans for a few typical components selected from Table VII. It is emphasized that the plans given here are not

TABLE VII. Gamma Prior Distributions for Selected Components of Nuclear Power Reactor Safety Systems

Component	Failure Mode	Assessed Prior Failure Rates ¹			US Nuclear Operating Experience ¹	a	b ²	Prior Mean ¹	Prior Variance ³	P ₁	P ₂	P ₃	P ₄	P ₅
		Lower 5% Limit (LL)	Median	Upper 5% Limit (UL)										
Electric Clutch	Premature Open	1x10 ⁻⁷	1x10 ⁻⁶	1x10 ⁻⁵	NA	0.84	26.72x10 ⁴	3.14x10 ⁻⁶	1.18x10 ⁻¹¹	0.64	0.31	NA	0.050	0.050
Instrumentation (Amplification, Annunciators, Transducers, Combination)	Failure to Operate	1x10 ⁻⁷	1x10 ⁻⁶	1x10 ⁻⁵	1x10 ⁻⁶	.84	26.72x10 ⁴	3.14x10 ⁻⁶	1.18x10 ⁻¹¹	.64	.31	.31	.050	.050
Mechanical Clutch	Failure to Open	3x10 ⁻⁸	3x10 ⁻⁷	3x10 ⁻⁶	NA	.84	89.08x10 ⁴	9.43x10 ⁻⁷	1.06x10 ⁻¹²	.64	.31	NA	.050	.050
Electric Motor	Failure to Run	3x10 ⁻⁶	1x10 ⁻⁵	3x10 ⁻⁵	1x10 ⁻⁶	2.45	18.32x10 ⁴	1.34x10 ⁻⁵	7.30x10 ⁻¹¹	.59	.42	.004	.050	.049
Electric Motor; Pumps	Failure to Run (Extreme Envir.)	1x10 ⁻⁴	1x10 ⁻³	1x10 ⁻²	NA	.84	26.72x10 ¹	3.15x10 ⁻³	1.18x10 ⁻⁵	.64	.31	NA	.050	.050
Relays	Failure NO Contact to Close	1x10 ⁻⁷	3x10 ⁻⁷	1x10 ⁻⁶	1x10 ⁻⁶	2.45	549.63x10 ⁴	4.46x10 ⁻⁷	8.11x10 ⁻¹⁴	.59	.36	.95	.050	.049
	Short Across NO/NC Contact	1x10 ⁻⁹	1x10 ⁻⁸	1x10 ⁻⁷	1x10 ⁻⁶	.84	26.72x10 ⁶	3.14x10 ⁻⁸	1.18x10 ⁻¹⁵	.64	.31	1.00	.050	.050
	Open NC Contact	3x10 ⁻⁸	1x10 ⁻⁷	3x10 ⁻⁷	1x10 ⁻⁶	2.45	18.32x10 ⁶	1.34x10 ⁻⁷	7.30x10 ⁻¹⁵	.59	.42	1.00	.050	.049

¹ (F/h) ² (h) ³ (F²/h²)

TABLE VII. Gamma Prior Distributions for Selected Components of Nuclear Power Reactor Safety Systems
(Continued)

Component	Failure Mode	Assessed Prior Failure Rates ¹			US Nuclear Operating Experience ¹	a	b ²	Prior Mean ¹	Prior Variance ³	P ₁	P ₂	P ₃	P ₄	P ₅
		Lower 5% Limit (LL)	Median	Upper 5% Limit (UL)										
Switches;	Contacts Short	1x10 ⁻⁹	1x10 ⁻⁸	1x10 ⁻⁷	3x10 ⁻⁸	.84	26.72x10 ⁶	3.14x10 ⁻⁸	1.18x10 ⁻¹⁵	0.64	0.31	0.63	0.050	0.050
Valves (MOV);	External Leak or Rupture													
Valves (AOV)	External Leak or Rupture													
Circuit Breakers;	Premature Transfer	3x10 ⁻⁷	1x10 ⁻⁶	3x10 ⁻⁶	1x10 ⁻⁶	2.45	18.32x10 ⁵	1.34x10 ⁻⁶	7.30x10 ⁻¹³	.59	.42	.42	.050	.049
Transformers;	Open Circuit													
Transformers	Short													
Fuses	Premature Open	3x10 ⁻⁷	1x10 ⁻⁶	3x10 ⁻⁶	NA	2.45	18.32x10 ⁵	1.34x10 ⁻⁶	7.30x10 ⁻¹³	.59	.42	NA	.050	.049
Wires	Open	1x10 ⁻⁶	3x10 ⁻⁶	1x10 ⁻⁵	1x10 ⁻⁶	2.45	54.36x10 ⁴	4.46x10 ⁻⁶	8.11x10 ⁻¹²	.59	.36	.05	.050	.049
	Short to GND	3x10 ⁻⁸	3x10 ⁻⁷	3x10 ⁻⁶	1x10 ⁻⁷	.84	89.08x10 ⁴	9.43x10 ⁻⁷	1.06x10 ⁻¹²	.64	.31	.13	.050	.050
Wires; Valves (VACUUM); Valves (TEST)	Short to PWR Rupture Rupture	1x10 ⁻⁹	1x10 ⁻⁸	1x10 ⁻⁷	NA	.84	26.72x10 ⁶	3.14x10 ⁻⁸	1.18x10 ⁻¹⁵	.64	.31	NA	.050	.050

TABLE VII. Gamma Prior Distributions for Selected Components of Nuclear Power Reactor Safety Systems.
(Continued)

Component	Failure Mode	Assessed Prior Failure Rates ¹			US Nuclear Operating Experience ¹	a	b ²	Prior Mean ¹	Prior Variance ³	P ₁	P ₂	P ₃	P ₄	P ₅
		Lower 5% Limit (LL)	Median	Upper 5% Limit (UL)										
Solid State Devices	Fails to Function (Hi PWR Apps.)	3x10 ⁻⁷	3x10 ⁻⁶	3x10 ⁻⁵	1x10 ⁻⁶	.84	89.08x10 ³	9.43x10 ⁻⁶	1.06x10 ⁻¹⁰	.64	.31	.13	.050	.050
	Shorts (Hi PWR Apps.); Fails to Function (Low PWR Apps.)	1x10 ⁻⁷	1x10 ⁻⁶	1x10 ⁻⁵	1x10 ⁻⁷	.84	26.72x10 ⁴	3.14x10 ⁻⁶	1.18x10 ⁻¹¹	.64	.31	.05	.050	.050
	Shorts (Low PWR Apps.)	1x10 ⁻⁸	1x10 ⁻⁷	1x10 ⁻⁶	NA	.84	26.72x10 ⁵	3.14x10 ⁻⁷	1.18x10 ⁻¹³	.64	.31	NA	.050	.050
Pumps	Failure to Run (Normal Envir)	3x10 ⁻⁶	3x10 ⁻⁵	3x10 ⁻⁴	3x10 ⁻⁶	.84	89.08x10 ²	9.43x10 ⁻⁵	1.06x10 ⁻⁸	.64	.31	.05	.050	.050
Valves (Check)	Reverse Leak	1x10 ⁻⁷	3x10 ⁻⁷	1x10 ⁻⁶	NA	2.45	549.63x10 ⁴	4.46x10 ⁻⁷	8.11x10 ⁻¹⁴	.59	.36	NA	.050	.049
	External Leaks-Ruptures	1x10 ⁻⁹	1x10 ⁻⁸	1x10 ⁻⁷	3x10 ⁻⁸	.84	26.72x10 ⁶	3.14x10 ⁻⁸	1.18x10 ⁻¹⁵	.64	.31	.63	.050	.050

TABLE VII. Gamma Prior Distributions for Selected Components of Nuclear Power Reactor Safety Systems
(Continued)

Components	Failure Mode	Assessed Prior Failure Rates ¹			US Nuclear Operating Experience ¹	a	b ²	Prior Mean ¹	Prior Variance ³	P ₁	P ₂	P ₃	P ₄	P ₅
		Lower 5% Limit (LL)	Median	Upper 5% Limit (UL)										
Values (Relief)	Premature Open/Hr.	3x10 ⁻⁶	1x10 ⁻⁵	3x10 ⁻⁵	1x10 ⁻⁵	2.45	18.32x10 ⁴	1.34x10 ⁻⁵	7.30x10 ⁻¹¹	0.59	0.42	0.42	0.050	0.049
Pipes > 3" (Hi Quality)	Rupture (Section)	3x10 ⁻¹²	1x10 ⁻¹⁰	3x10 ⁻⁹	1x10 ⁻¹⁰	.50	655.36x10 ⁶	7.63x10 ⁻¹⁰	1.16x10 ⁻¹⁸	.68	.28	.28	.050	.047
Pipes < 3"	Rupture	3x10 ⁻¹¹	1x10 ⁻⁹	3x10 ⁻⁸	1x10 ⁻⁹	.50	655.36x10 ⁵	7.63x10 ⁻⁹	1.16x10 ⁻¹⁶	.68	.28	.28	.050	.047
Gaskets	Leak	1x10 ⁻⁷	3x10 ⁻⁶	1x10 ⁻⁴	1x10 ⁻⁶	.50	19.66x10 ³	2.54x10 ⁻⁹	1.29x10 ⁻⁹	.68	.27	.16	.050	.047
Flanges, Closures, Elbows	Leak/Rupture	1x10 ⁻⁸	3x10 ⁻⁷	1x10 ⁻⁵	NA	.50	19.66x10 ⁴	2.54x10 ⁻⁶	1.29x10 ⁻¹¹	.68	.27	NA	.050	.047
Welds	Leak	1x10 ⁻¹⁰	3x10 ⁻⁹	1x10 ⁻⁷	NA	.50	19.66x10 ⁶	2.54x10 ⁻⁸	1.29x10 ⁻¹⁵	.68	.27	NA	.050	.047
Diesel (Complete Plant)	Failure to Run	3x10 ⁻⁴	3x10 ⁻³	3x10 ⁻²	1x10 ⁻³	.84	89.08x10 ⁰	9.43x10 ⁻³	1.06x10 ⁻⁴	.64	.31	.13	.050	.050
Diesel (Engine Only)	Failure to Run	3x10 ⁻⁵	3x10 ⁻⁴	3x10 ⁻³	NA	.84	89.08x10 ¹	9.43x10 ⁻⁴	1.06x10 ⁻⁶	.64	.31	NA	.050	.050
Batteries, Power Supplies	NO/Output	1x10 ⁻⁶	3x10 ⁻⁶	1x10 ⁻⁵	3x10 ⁻⁷	2.45	54.96x10 ⁴	4.46x10 ⁻⁶	8.11x10 ⁻¹²	.59	.36	.003	.050	.049
Instrumentation (Amplification, Annunciators, Transducers, Combination)	Shift Calibration	3x10 ⁻⁶	3x10 ⁻⁵	3x10 ⁻⁴	1x10 ⁻⁴	.84	89.08x10 ²	9.43x10 ⁻⁵	1.06x10 ⁻⁸	.64	.31	.66	.050	.050

to be considered an exhaustive set or the sole source for the final selection. The final selection rests with the producer in conjunction with the consenting agreement of the consumer. It may be necessary or desirable to alter the prior distributions given in Table VII for numerous possible reasons. Such alterations will result in different test plans from those proposed here.

Before such BAZE test plans can be used in practice, several things must be considered. First, the life cycle of each component must be identified. This includes establishing the environments and operating conditions to which each component is exposed during the various phases of its existence. This also includes defining the duty cycle for the operational phases. Such practical details surrounding the implementation of these BAZE plans will not be addressed here. This would ordinarily be considered in the contractor's reliability program plan.

We shall restrict our consideration to three "typical" components given in Table VII; namely, electric clutches ($a = 0.84$), electric motors ($a = 2.45$), and the category of flanges, closures, and elbows ($a = 0.50$). The specified failure-rate λ_0 will be taken to be the corresponding value of λ according to the US nuclear operating experience given in Table VII. If such values are not available, as indicated in Table VII, then λ_0 will be taken to be the assessed median prior failure-rate. Once a reliability, risk, or safety analysis program is under way, the

value of λ_0 is a contract specification which may differ from the values considered here.

First, consider the electric clutch in Table VII. The BAZE procedure described in Section IV was applied to this component in conjunction with its fitted prior given in Table VII. Table VIII presents the resulting required unit-hours of testing for selected values of the discrimination ratio (λ) and the posterior assurance (γ). For example, for $k = 5$ and $\gamma = 0.90$, it would require $(nt)_0 = [2.018547 - (26.72 \times 10^4) (5) (1.0 \times 10^{-6})] / [(5) (1.0 \times 10^{-6})] = 136,510$ unit-hours of electric clutch testing without a failure in order to demonstrate a failure-rate of 5.0×10^{-6} f/h with 90% assurance. Table IX gives the unconditional probabilities of passing the corresponding tests given in Table VIII. The unconditional probability of passing the above test is 70.7%.

Similarly, Tables X and XI give the required BAZE unit-hours of testing and unconditional probabilities of passing the test for the case of an electric motor in a normal (nonextreme) environment. Likewise, Tables XII and XIII consider the category of flanges, closures, and elbows, with respect to leak or rupture failure modes.

Now let us consider the sensitivity of the BAZE procedure for each of these three component categories to errors in the tail-area probabilities. The procedure follows the example in Section V. Table XIV gives the fitted gamma prior distributions for these three components for actual prior probabilities of being

TABLE VIII. Required BAZE Unit-Hours of Testing for the Electric Clutch ($a = 0.84$, $b = 26.72 \times 10^4$ h)

[illegible]

TABLE IX. The Unconditional Probabilities of Passing the Corresponding Tests in Table VIII

[illegible]

TABLE X. Required BAZE Unit-Hours of Testing for the
Electric Motor ($a = 2.45$, $b = 18.32 \times 10^4 h$)

	1.0	3.0	5.0	7.0	9.0	11.0	13.0	15.0	17.0	19.0	21.0
0.000	0.04490E	061.22617E	066.62421E	054.20815E	052.86599E	052.01173E	051.42039E	050.86736E	046.55120E	043.93319E	041.41347E
0.075	0.15669E	060.31029E	054.85337E	052.94327E	051.88210E	051.20681E	050.73929E	049.96457E	041.34286E	040.0	0.0
0.150	0.24941E	057.09337E	053.62322E	051.99316E	051.14312E	050.02192E	042.27701E	040.0	0.0	0.0	0.0
0.225	0.33535E	054.89649E	052.20509E	051.05164E	050.10830E	043.04309E	020.0	0.0	0.0	0.0	0.0
0.300	0.45365E	053.62432E	051.44209E	050.06638E	040.0	0.0	0.0	0.0	0.0	0.0	0.0
0.375	0.18569E	052.73099E	050.05789E	041.23564E	040.0	0.0	0.0	0.0	0.0	0.0	0.0
0.450	0.75594E	052.04395E	054.93569E	040.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.525	0.12724E	051.48775E	051.59847E	040.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.600	0.53155E	054.22518E	040.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.675	0.56162E	050.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE XI. The Unconditional Probabilities of Passing the
Corresponding Tests in Table X.

	1.0	3.0	5.0	7.0	9.0	11.0	13.0	15.0	17.0	19.0	21.0
0.000	0.000	0.007	0.024	0.054	0.100	0.163	0.245	0.348	0.473	0.621	0.794
0.075	0.001	0.012	0.042	0.096	0.177	0.289	0.436	0.619	0.841	1.000	1.000
0.150	0.001	0.021	0.072	0.165	0.305	0.498	0.750	1.000	1.000	1.000	1.000
0.225	0.003	0.041	0.164	0.329	0.609	0.896	1.000	1.000	1.000	1.000	1.000
0.300	0.005	0.069	0.241	0.550	1.000	1.000	1.000	1.000	1.000	1.000	1.000
0.375	0.007	0.107	0.374	0.852	1.000	1.000	1.000	1.000	1.000	1.000	1.000
0.450	0.011	0.159	0.557	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
0.525	0.016	0.233	0.815	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
0.600	0.033	0.448	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
0.675	0.071	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000

below and above LL and UL, respectively, the tail-area probabilities, of 2.5%, 5%, and 10%. Table XV gives the BAZE test plans for the electric clutch when the tail area probabilities are 2.5% instead of 5%. Table XVI gives the percentage change in the plans of Table XV relative to the "nominal" plans of Table VIII. Similarly, Tables XVII and XVIII correspond to Tables XV and XVI except that the tail-area probabilities are 10%. It is observed from Tables XVI and XVIII that the BAZE plans for the electric clutch are fairly sensitive to the tail-area probabilities in the gamma prior distribution. Similarly, Tables XIX-XXII and Tables XXIII-XXVI correspond to Tables XV-XVIII for the case of the electric motor and flanges, closures, and elbows, respectively. Again, the BAZE plans for these components are observed to be fairly sensitive to the tail-area probabilities.

Finally, similar BAZE test plans could be developed for the remaining components in Table VII. The BAZE procedure appears to be a practical means of conducting Bayesian reliability demonstration testing. The main advantage over other Bayesian procedures is its ease of application. A few simple tables and figures, which are included, and a pocket calculator are all that is required. The practical utility of the procedure appears to be evident.

ACKNOWLEDGMENTS

The authors wish to thank Ms. Myrle Johnson for her help in computing and constructing Figures A1 and A2, as well as Tables

A1 and A2. Ms. Carla McInteer also assisted in the computation of Table A1. We also wish to thank Mrs. Terry Wilson for her excellent and painstaking typing of this report.

TABLE XIV. Gamma Prior Distributions for Selected Tail-Area Probabilities for the Electric Clutch, Electric Motor, and Flanges, Closures, and Elbows

Component	Tail-Area Probability(%)	P ₀	a	b	Prior Mean	Prior Variance	P ₁	P ₂	P ₃	P ₄	P ₅
Electric Clutch	2.5	0.95	1.13	4.10x10 ⁵ h	2.76x10 ⁻⁶	6.72x10 ⁻¹²	0.63	0.28	-	0.025	0.022
	5	.90	.84	26.72x10 ⁴ h	3.14x10 ⁻⁶	1.18x10 ⁻¹¹	.64	.31	-	.050	.050
	10	.85	.60	18.87x10 ⁴ h	3.18x10 ⁻⁶	1.69x10 ⁻¹⁰	.67	.38	-	.103	.068
Electric Motor	2.5	.95	3.38	2.62x10 ⁵ h	1.29x10 ⁻⁵	4.92x10 ⁻¹¹	.57	.40	0.001	.025	.024
	5	.90	2.45	18.32x10 ⁴ h	1.34x10 ⁻⁵	7.30x10 ⁻¹¹	.59	.41	.004	.050	.049
	10	.85	1.59	1.11x10 ⁵ h	1.43x10 ⁻⁵	1.29x10 ⁻¹⁰	.61	.44	.020	.100	.095
Flanges, Closures, Elbows	2.5	.95	.67	34.93x10 ⁴ h	1.92x10 ⁻⁶	5.49x10 ⁻¹²	.66	.23	-	.025	.014
	5	.90	.50	19.66x10 ⁴ h	2.54x10 ⁻⁶	1.29x10 ⁻¹¹	.68	.27	-	.050	.047
	10	.85	.35	100.34x10 ³ h	3.49x10 ⁻⁶	3.48x10 ⁻¹¹	.71	.33	-	.100	.101

TABLE XV. Required BAZE Unit-Hours of Testing for the Electric Clutch (a = 1.13, b = 4.10x10⁵h)

γ \ k	1.0	2.0	3.0	4.0	5.0	6.0	7.0	8.0	9.0	10.0	11.0
0.990	4.40773E-06	2.03852E-05	1.22235E-06	8.14259E-05	5.69437E-05	4.06173E-05	2.89576E-05	2.02129E-05	1.34115E-05	7.97034E-06	3.51855E-06
0.975	3.56642E-06	1.56821E-05	9.08006E-06	5.79105E-05	3.81284E-05	2.49403E-05	1.55203E-05	8.45523E-06	2.96021E-06	0.0	0.0
0.950	2.83247E-06	1.21123E-05	6.77822E-06	4.00617E-05	2.38493E-05	1.35411E-05	5.32095E-06	0.0	0.0	0.0	0.0
0.900	2.11421E-06	8.52103E-06	4.31402E-06	2.21052E-05	9.48412E-06	1.07010E-05	0.0	0.0	0.0	0.0	0.0
0.850	1.69117E-06	6.40505E-06	2.90390E-06	1.15293E-05	5.2341E-06	0.0	0.0	0.0	0.0	0.0	0.0
0.800	1.30221E-06	4.89604E-06	1.85736E-06	8.99023E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.750	1.15363E-06	3.71016E-06	1.11211E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.700	9.6035E-07	2.75018E-06	6.66786E-07	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.600	6.51846E-07	1.2923E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.500	4.09573E-07	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE XVI. Percentage Change in the BAZE Plans of Table XV
Relative to Table VIII

$\gamma \backslash k$	1.0	2.0	3.0	4.0	5.0	6.0	7.0	8.0	9.0	10.0	11.0
.990	3.605%	7.732%	12.503%	18.080%	24.688%	32.641%	42.397%	54.647%	70.467%	91.768%	
.975	4.643	10.170	16.859	25.120	35.581	49.256	67.894	94.798			
.950	5.924	13.326	22.836	35.504	53.220	79.746					
.900	8.154	19.243	35.203	60.142							
.850	10.424	25.901	51.278								
.800	12.962	34.224	75.516								
.750	15.945	45.450									
.700	19.596	61.882									
.600	30.438										
.500	52.469										

TABLE XVII. Required BAZE Unit-Hours of Testing for the Electric Clutch ($a = 0.60$, $b = 18.87$
 $\times 10^4 h$)

$\gamma \backslash k$	1.0	2.0	3.0	4.0	5.0	6.0	7.0	8.0	9.0	10.0	11.0
.990	4.75833E	10.225982E	15.144354E	20.153556E	25.79777E	32.27472E	39.51787E	47.423429E	55.55415E	63.51034E	72.56485E
.975	3.76772E	8.178951E	12.113011E	16.800405E	22.52584E	29.73703E	37.76503E	46.35852E	55.250902E	64.06942E	73.70974E
.950	3.05377E	6.5143254E	9.8392122E	13.621916E	18.459793E	24.351711E	31.274509E	39.216608E	48.171574E	57.35547E	66.50575E
.900	2.3355E	5.07349E	7.6452702E	10.442351E	13.816141E	18.32001E	23.71901E	30.26826E	38.17673E	46.37206E	54.37733E
.850	1.91247E	4.061985E	6.0511690E	8.336592E	10.31534E	13.61495E	17.11467E	22.39463E	28.47634E	34.14171E	40.31552E
.800	1.61051E	3.412934E	5.041136E	6.8261107E	8.5171142E	10.411168E	12.83293E	16.22011E	20.12121E	24.0	28.0
.750	1.37493E	2.93116E	4.32511E	5.822298E	7.124026E	8.719053E	10.46760E	12.75404E	15.0	18.0	21.0
.700	1.18138E	2.496318E	3.67970E	4.83819E	5.85337E	7.096392E	8.401932E	10.0	12.0	14.0	16.0
.600	1.71155E	3.42223E	5.165249E	7.67616E	12.36693E	18.0	24.0	30.0	36.0	42.0	48.0
.500	6.30274E	12.21597E	18.44911E	24.61934E	30.0	36.0	42.0	48.0	54.0	60.0	66.0

TABLE XVIII. Percentage Change in the BAZE Plans of Table XVII Relative to Table VIII

$\frac{k}{y}$	1.0	2.0	3.0	4.0	5.0	6.0	7.0	8.0	9.0	10.0	11.0
.990	1.982%	4.250%	6.873%	9.938%	13.571%	17.944%	23.307%	30.041%	38.748%	50.447%	66.995%
.975	2.552	5.591	9.268	13.809	19.560	27.077	37.323	52.112	75.329	117.045	214.011
.950	3.257	7.325	12.553	19.518	29.256	43.838	68.074	116.293	258.907	13989.32	
.900	4.482	10.578	19.352	33.061	57.504	113.400	370.915				
.850	5.731	14.238	28.189	55.258	130.376	1391.562					
.800	7.125	18.814	41.513	104.634	1193.18						
.750	8.765	24.985	65.202	334.096							
.700	10.772	34.018	121.190								
.600	16.732	77.740									
.500	28.843	3163.88									

TABLE XIX. Required BAZE Unit-Hours of Testing for the Electric Motor ($a = 3.38$, $b = 2.62 \times 10^5 h$)

$\frac{k}{y}$	1.0	3.0	5.0	7.0	9.0	11.0	13.0	15.0	17.0	19.0	21.0
.99	4.63503E-08	1.37034E-06	7.17407E-05	4.37576E-05	2.82115E-05	1.83185E-05	1.14695E-05	5.44690E-06	2.60609E-06	0.0	0.0
.975	3.69442E-08	1.05691E-06	5.29294E-05	3.03203E-05	1.77662E-05	9.78744E-06	4.23399E-06	1.76125E-06	0.0	0.0	0.0
.95	2.9847E-08	8.19822E-06	3.86493E-05	2.01209E-05	9.2741E-06	3.21697E-06	0.0	0.0	0.0	0.0	0.0
.9	2.26221E-08	5.79432E-06	2.42841E-05	9.86008E-06	1.84674E-06	0.0	0.0	0.0	0.0	0.0	0.0
.85	1.03917E-08	4.3839E-06	1.59234E-05	3.81672E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0
.75	1.54721E-08	3.7736E-06	9.78419E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
.6	1.3163E-08	2.59211E-06	5.17265E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
.5	1.10803E-08	1.94679E-06	1.20071E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
.4	7.99845E-09	1.15688E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
.3	5.57573E-09	1.11912E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE XX. Percentage Change in the BAZE Plans of Table XIX Relative to Table X

$\gamma \backslash k$	1.0	3.0	5.0	7.0	9.0	11.0	13.0	15.0	17.0	19.0	21.0
.990	1.958%	6.427%	11.896%	18.726%	27.496%	39.170%	55.478%	79.859%			
.975	2.494	8.464	16.236	26.773	41.868	65.297					
.950	3.159	11.109	22.366	39.536	68.934						
.900	4.293	16.093	35.735	74.931							
.850	5.420	21.739	54.643								
.800	6.646	28.854	86.996								
.750	8.044	38.553									
.700	9.696	52.966									
.600	14.246										
.500	22.125										

TABLE XXI. Required BAZE Unit-Hours of Testing for the Electric Motor ($a = 1.59$, $b = 1.11 \times 10^5 h$)

$\gamma \backslash k$	1.0	3.0	5.0	7.0	9.0	11.0	13.0	15.0	17.0	19.0	21.0
.990	4.78613E	61.52134E	90.68497E	155.88576E	254.33115E	393.34105E	552.65695E	752.15469E	951.77061E	1.46739E	1.22192E
.975	3.84542E	61.20781E	90.60284E	154.54203E	251.28602E	392.48674E	551.93340E	751.52761E	951.21731E	1.467326E	1.22192E
.950	3.13147E	60.69822E	90.37493E	153.52209E	250.49274E	391.83770E	551.38420E	751.05164E	950.97333E	1.46732E	1.22192E
.900	2.41321E	60.73142E	90.39384E	152.49601E	251.69467E	391.18473E	550.31597E	750.72804E	950.74827E	1.46730E	1.22192E
.850	1.99017E	60.59930E	90.309234E	151.89167E	251.22463E	390.00154E	549.06285E	750.90780E	950.25983E	1.46730E	1.22192E
.800	1.68921E	60.88716E	90.248842E	151.46030E	250.89121E	389.25645E	548.74007E	750.94725E	950.0	1.46730E	1.22192E
.750	1.45263E	60.41211E	90.201726E	151.12376E	250.27369E	389.11484E	549.27940E	750.0	950.0	1.46730E	1.22192E
.700	1.25933E	60.45674E	90.16307E	150.47193E	249.12261E	388.35487E	548.0	750.0	950.0	1.46730E	1.22192E
.600	9.57446E	52.42949E	90.10136E	150.06923E	246.99293E	380.0	548.0	750.0	950.0	1.46730E	1.22192E
.500	7.58514E	51.62191E	90.29147E	146.08192E	237.9	380.0	548.0	750.0	950.0	1.46730E	1.22192E

TABLE XXII. Percentage Change in the BAZE Plans of Table XXI Relative to Table X

$\gamma \backslash k$	1.0	3.0	5.0	7.0	9.0	11.0	13.0	15.0	17.0	19.0	21.0
.990	1.785%	5.888%	10.899%	17.157%	25.193%	35.8909%	50.831%	73.171%	110.209%	183.567%	398.053%
.975	2.285	7.755	14.876	24.530	38.361	59.821	97.661	182.114	537.658		
.950	2.894	10.179	20.493	36.224	63.160	119.895	317.082				
.900	3.934	14.745	32.742	68.655	175.742	23725.8					
.850	4.966	19.918	50.066	142.508							
.800	6.089	26.437	79.710	584.312							
.750	7.370	35.324	146.282								
.700	8.884	48.530	451.682								
.600	13.052	115.981									
.500	20.272										

TABLE XXII. Required BAZE Unit-Hours of Testing for the Flanges, Closures and Elbows
($a = 0.67$, $b = 34.93 \times 10^4 h$)

k	1.0	4.0	7.0	10.0	13.0	16.0	19.0	22.0	25.0	28.0	31.0
0.990	1.59741E-07	1.73156E-05	1.98252E-04	1.20304E-03	6.06350E-03	6.70915E-03	5.69829E-03	3.92675E-03	3.03638E-03	2.33689E-03	1.77263E-03
0.975	1.20368E-07	1.94772E-05	1.53471E-04	6.69506E-04	6.65166E-03	5.74954E-03	3.44808E-03	2.50157E-03	1.78222E-03	1.21702E-03	7.61211E-04
0.950	1.04589E-07	1.35276E-05	1.19473E-04	4.731522E-04	4.02101E-03	3.26213E-03	2.19554E-03	1.41983E-03	9.30287E-04	6.67077E-04	4.00000E-04
0.900	4.06471E-08	1.75420E-05	3.52702E-05	1.92102E-04	2.97932E-03	1.76576E-03	9.35431E-04	3.31554E-04	0.0	0.0	0.0
0.850	6.65459E-08	1.40167E-05	6.51257E-05	3.51090E-04	1.69461E-03	8.4436E-04	1.93263E-04	0.0	0.0	0.0	0.0
0.800	3.6486E-08	1.1504E-05	5.7466E-05	2.50436E-04	1.12035E-03	5.55350E-04	0.0	0.0	0.0	0.0	0.0
0.750	4.8628E-08	5.3777E-06	3.95236E-05	1.71911E-04	5.16312E-04	0.0	0.0	0.0	0.0	0.0	0.0
0.700	4.21748E-08	7.92396E-06	3.63597E-05	1.07378E-04	1.99090E-04	0.0	0.0	0.0	0.0	0.0	0.0
0.600	3.19019E-08	5.35572E-06	1.56341E-05	4.64884E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0.500	2.38761E-08	3.3678E-06	4.09729E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE XXIV. Percentage Change in the BAZE Plans of Table XXIII Relative to Table XII

$\frac{k}{y}$	1.0	4.0	7.0	10.0	13.0	16.0	19.0	22.0	25.0	28.0	31.0
.990	1.406%	5.946%	11.040%	16.795%	23.348%	30.877%	39.620%	49.8	42%	76.991%	95.369%
.975	1.868	8.051	15.277	23.833	34.124	46.737	62.558	82.990			
.950	2.461	10.876	21.266	34.420	51.606	75.018					
.900	3.541	16.407	34.117	60.042	100.000	100.000					
.850	4.688	22.899	51.450	100.000							
.800	6.010	31.309	78.533								
.750	7.601	43.041	100.000								
.700	9.581	60.841									
.650	15.519	100.000									
.500	27.189										

TABLE XXV. Required BAZE Unit-Hours of Testing for the Flanges, Closures and Elbows
($a = 0.35$, $b = 100.34 \times 10^3 h$)

$\frac{k}{y}$	1.0	4.0	7.0	10.0	13.0	16.0	19.0	22.0	25.0	28.0	31.0
0.990	1.62231E 07	1.98052E 08	2.23150E 08	2.53200E 08	2.815531E 08	3.0919875E 08	3.3758708E 08	3.641635E 08	3.8952598E 08	4.1482640E 08	4.3925223E 08
0.975	1.30877E 07	1.19668E 08	1.4170367E 08	1.6121847E 08	1.7814125E 08	1.931913E 08	2.0693768E 08	2.199117E 08	2.3182E 08	2.42662E 08	2.52081E 08
0.950	1.07279E 07	1.01172E 08	1.2144359E 08	1.380481E 08	1.531061E 08	1.6575173E 08	1.769513E 08	1.86943E 08	1.95809E 08	2.03668E 08	2.108312E 08
0.900	8.31367E 06	8.00310E 07	1.0166E 08	1.141061E 08	1.2546892E 08	1.35536E 08	1.42503E 08	1.482115E 08	1.5236221E 08	1.55160E 08	1.57108E 08
0.850	6.90355E 06	6.65164E 07	8.216E 07	9.60049E 07	1.0840421E 08	1.1937433E 08	1.268286E 08	1.314019E 08	1.3479816E 08	1.374999E 08	1.39592E 08
0.800	5.8972E 06	5.397E 07	6.756426E 07	8.099356E 07	9.363995E 07	1.05274495E 08	1.15310E 08	1.22257E 08	1.2739554E 08	1.313851E 08	1.3431232E 08
0.750	5.1117E 06	4.2269E 07	5.44246E 07	6.420870E 07	7.30591E 07	8.0225416E 08	8.5173981E 08	8.86574E 08	9.08144E 08	9.2666E 08	9.427924E 08
0.700	4.46644E 06	3.64136E 07	4.52157E 07	5.36338E 07	6.05951E 07	6.65004E 08	7.140017E 08	7.527241E 08	7.812331E 08	8.0027593E 08	8.1969755E 08
0.600	3.43914E 06	2.84532E 07	3.40531E 07	4.03634E 07	4.6171928E 07	5.120878E 08	5.59488E 08	6.05459E 08	6.412395E 08	6.670702E 08	6.913037E 08
0.500	2.63157E 06	2.182638E 07	2.689933E 07	3.172051E 07	3.639807E 07	4.04044E 08	4.34448E 08	4.583378E 08	4.7693642E 08	4.900000E 08	5.000000E 08

TABLE XXVI. Percentage Change in the BAZE Plans of Table XXV Relative
to Table XII

$\gamma \backslash k$	1.0	4.0	7.0	10.0	13.0	16.0	19.0	22.0	25.0	28.0	31.0
.990	.886%	3.749%	6.960%	10.588%	14.718%	19.465%	24.976%	31.453%	39.174%	48.534%	60.119%
.975	1.177	5.075	9.630	15.024	21.511	29.462	39.436	52.316	69.589	93.966	130.963
.950	1.551	6.856	13.406	21.698	32.532	47.290	65.576	101.950	161.789	300.266	969.386
.900	2.232	10.343	21.507	37.849	64.060	112.945	236.345	1150.678			
.850	2.955	14.435	32.433	64.702	139.360	499.809					
.800	3.789	19.737	49.506	124.804	689.503						
.750	4.792	27.133	81.251	401.910							
.700	6.040	38.354	162.711								
.600	9.783	97.690									
.500	17.139										

REFERENCES

1. Balaban, H., "A Bayesian Approach to Reliability Demonstration," Annals of Assurance Sciences, Vol. 8, 1969, pp. 497-506.
2. Balaban, H., "Reliability Demonstration: Purposes, Practices, and Value," Proceedings of the 1975 Annual Reliability and Maintainability Symposium, Washington, D.C., 1975, pp. 246-248.
3. Blumenthal, S., "Reliability Demonstration," Technical Report No. 183, Department of Operations Research, Cornell University, Ithaca, NY, May 1973.
4. Bonis, A.J., "Bayesian Reliability Demonstration Plans," Reliability and Maintainability Conference, Vol. 5, 1966, pp. 861-870.
5. Easterling, R.G., "On the Use of Prior Distributions in Acceptance Sampling," Annals of Reliability and Maintainability, Vol. 9, 1970, pp. 31-35.
6. Goel, A.L. and Joglekar, A.M., "Reliability Acceptance Sampling Plans Based Upon Prior Distribution," Technical Reports 76-1 to 76-5, Department of Industrial Engineering and Operations Research, Syracuse University, Syracuse, NY, March 1976.
7. Goel, A.L. et al., "Reliability Demonstration Plans Using Prior Distribution," Technical Report, Department of Industrial Engineering and Operations Research, Syracuse University, Syracuse, NY.
8. Goel, A.L. et al., "Graphical Design of Reliability Demonstration Plans Based upon Prior Distribution," Technical Report, Department of Industrial Engineering and Operations Research, Syracuse University, Syracuse, NY.
9. Guild, R.D., "Bayesian MFR Life Test Sampling Plans," Journal of Quality Technology, Vol. 5, 1973, pp. 11-15.
10. Guild, R.D., "Reliability Testing and Equipment Design Using Bayesian Models," Unpublished Ph.D. Dissertation, Northwestern University, Evanston, IL, 1968.
11. Joglekar, A.M., "Reliability Demonstration Based on Prior Distribution - Sensitivity Analysis and Multi Sample Plans," Proceedings of the 1975 Annual Reliability and Maintainability Symposium, Washington, D.C., 1975, pp. 251, 252.

12. Mann, N.R., Schafer, R.E., and Singpurwalla, N.D., Methods for Statistical Analysis of Reliability and Life Data, Wiley, Inc., 1974.
13. Martz, H.F. and Waller, R.A., "The Basics of Bayesian Reliability Estimation from Attribute Test Data," Report No. LA-6126, Los Alamos Scientific Laboratory, 1976a.
14. Martz, H.F. and Waller, R.A., "Handbook of Bayesian Reliability Estimation Methods," Report No. LA-6572-MS, Los Alamos Scientific Laboratory, 1976b.
15. Martz, H.F. and Waller, R.A., "A Bayesian Zero-Failure (BAZE) Reliability Demonstration Testing Procedure and Its Application to a Rankine Dynamic Radioisotope Power Conversion System," Report No. LA-6421-MS, Los Alamos Scientific Laboratory, 1976c.
16. MIL-STD-781C, Reliability Tests: Exponential Distribution, U.S. Government Printing Office, Washington, D.C.
17. Ramos, J.R., "Development of Bayesian Life Test Sampling Plans Assuming a Failure Rate with a Gamma Prior Distribution," Unpublished M.S. Thesis, The Pennsylvania State University, University Park, PA, 1970.
18. Schafer, R.E., "Bayesian Reliability Demonstration: Phase I--Data for the A Priori Distribution," RADC-TR-69-389, 1969.
19. Schafer, R.E., "Bayesian Reliability Demonstration: Phase III--Development of Test Plans," RADC-TR-73-139, 1973.
20. Schafer, R.E. and Sheffield, T.S., "Bayesian Reliability Demonstration: Phase II--Development of a Prior Distribution," RADC-TR-71-209, DDC AD-732283, 1971.
21. Schafer, R.E. and Singpurwalla, N.D., "A Sequential Bayes Procedure for Reliability Demonstration," Naval Research Logistics Quarterly, Vol. 17, 1970, pp. 55-67.
22. Waller, R.A. and Martz, H.F., "Bayesian Reliability Estimation: State of the Art for the Time-Dependent Case," Report No. LA-6003, Los Alamos Scientific Laboratory, 1975.
23. WASH 1400 (NUREG 75/014) REACTOR SAFETY STUDY. An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants (Appendix III. Failure Data), U.S. Nuclear Regulatory Commission, October, 1975.

APPENDIX A. Some Useful Figures and Tables for the BAZE Procedure

Figure A1. Gamma Shape Parameter a as a Function of $\log_{10} (UL/LL)$

Figure A2. Gamma Reference Scale Parameter b_0 As a Function of the Shape Parameter a

Table A1. Values of θ_γ for Selected Values of Prior Shape Parameter (a) and Posterior Assurance (γ)

Table A2. Gamma Reference Scale Values b_0 for Selected Values of Shape Parameter (a) and Prior Assurance (p_0)

Fig. A1. Gamma Shape Parameter α as a Function of $\log_{10} (UL/LL)$.

Fig. A2. Gamma Reference Scale Parameter b_0 as a Function of the Shape Parameter a .

TABLE A1. VALUES OF θ_y FOR SELECTED VALUES OF PRIOR SHAPE PARAMETER (α) AND POSTERIOR ASSURANCE (γ)

α	0.99	0.975	0.95	0.90	0.85	γ	0.80	0.75	0.70	0.60	0.50
0.001	1.2427E-44	6.5447E-111	8.1261E-149	7.6988E-149	7.2707E-149	6.8431E-149	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.002	0.4211E-23	5.9245E-56	2.3303E-112	7.6988E-149	7.2707E-149	6.8431E-149	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.003	1.5595E-15	1.2530E-37	3.1245E-75	7.6988E-149	7.2707E-149	6.8431E-149	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.004	0.7877E-12	1.6239E-24	1.1441E-56	2.2685E-115	7.2707E-149	6.8431E-149	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.005	0.7466E-09	5.7376E-23	1.5727E-45	7.1609E-92	3.8666E-142	6.8431E-149	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.006	2.9844E-04	2.6539E-19	4.1899E-38	3.0694E-77	1.3014E-118	6.8431E-149	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.007	2.2665E-07	1.1012E-16	8.4362E-33	2.4084E-66	8.3073E-102	2.0265E-139	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.008	1.4641E-06	1.0124E-14	8.0184E-29	3.5708E-58	3.3343E-89	4.0934E-122	6.4154E-149	6.4154E-149	5.9877E-149	5.1323E-149	4.2769E-149
0.009	7.9407E-06	3.6384E-12	9.9501E-26	8.0907E-52	2.1194E-79	1.1799E-108	8.4863E-126	8.4863E-126	5.9877E-149	5.1323E-149	4.2769E-149
0.010	2.9253E-05	5.6793E-12	2.9734E-23	9.6217E-47	1.4744E-71	6.9129E-98	6.4705E-126	6.4705E-126	5.9877E-149	5.1323E-149	4.2769E-149
0.011	6.4447E-05	5.6747E-11	3.1510E-21	1.4194E-42	3.5468E-65	4.4633E-80	1.4755E-114	1.4755E-114	5.9877E-149	5.1323E-149	4.2769E-149
0.012	1.9895E-04	3.8630E-10	1.1347E-19	4.1544E-39	8.3543E-60	9.8040E-82	4.3066E-105	4.3066E-105	5.9877E-149	5.1323E-149	4.2769E-149
0.013	6.6487E-04	1.9577E-09	4.1124E-18	3.5622E-36	2.8419E-55	1.5982E-75	4.3940E-97	4.3940E-97	5.9877E-149	5.1323E-149	4.2769E-149
0.014	9.2487E-04	6.8700E-09	4.8882E-17	1.1638E-31	2.1615E-51	3.3758E-70	3.2201E-90	3.2201E-90	5.9877E-149	5.1323E-149	4.2769E-149
0.015	6.9224E-04	2.6278E-08	7.9234E-16	1.7574E-31	4.9463E-48	1.3905E-65	2.8668E-84	2.8668E-84	5.9877E-149	5.1323E-149	4.2769E-149
0.016	1.8224E-03	7.5777E-08	6.7163E-15	1.4174E-29	4.3323E-45	1.5175E-61	4.6045E-79	4.6045E-79	5.9877E-149	5.1323E-149	4.2769E-149
0.017	1.4524E-03	1.9145E-07	4.2747E-14	6.8195E-24	1.7047E-42	5.5467E-58	1.8053E-74	1.8053E-74	5.9877E-149	5.1323E-149	4.2769E-149
0.018	2.1103E-03	3.1794E-07	2.3664E-13	2.1347E-26	3.4533E-40	8.1483E-55	2.1855E-70	2.1855E-70	5.9877E-149	5.1323E-149	4.2769E-149
0.019	2.4444E-03	9.1023E-07	1.0697E-12	4.6461E-25	4.0000E-38	5.5555E-52	1.9348E-67	1.9348E-67	5.9877E-149	5.1323E-149	4.2769E-149
0.020	3.7684E-03	1.7574E-06	4.0910E-12	7.4554E-24	2.4807E-36	1.9725E-49	1.9084E-63	1.9084E-63	5.9877E-149	5.1323E-149	4.2769E-149
0.021	4.7164E-03	3.2672E-06	1.3876E-11	9.1366E-23	1.4805E-34	4.0035E-47	1.8001E-60	1.8001E-60	5.9877E-149	5.1323E-149	4.2769E-149
0.022	5.7704E-04	5.5523E-06	4.4118E-11	8.9381E-22	4.6537E-33	5.0130E-45	9.1153E-58	9.1153E-58	5.9877E-149	5.1323E-149	4.2769E-149
0.023	7.1497E-03	9.3227E-06	1.1608E-10	7.1710E-21	1.5154E-31	4.1243E-43	2.6850E-55	2.6850E-55	5.9877E-149	5.1323E-149	4.2769E-149
0.024	8.5164E-03	1.5796E-05	2.9400E-10	4.8836E-20	2.1954E-30	3.3496E-41	4.0246E-53	4.0246E-53	5.9877E-149	5.1323E-149	4.2769E-149
0.025	1.0203E-02	2.2494E-05	6.9123E-10	2.8003E-19	3.2944E-29	9.6874E-40	5.9527E-51	5.9527E-51	5.9877E-149	5.1323E-149	4.2769E-149
0.026	1.2033E-02	3.2191E-05	1.5222E-09	1.6105E-18	4.0149E-28	3.0093E-38	4.9761E-50	4.9761E-50	5.9877E-149	5.1323E-149	4.2769E-149
0.027	1.3774E-02	4.7636E-05	3.1606E-09	6.3542E-18	4.0648E-27	7.2058E-37	2.9949E-47	2.9949E-47	5.9877E-149	5.1323E-149	4.2769E-149
0.028	1.5744E-02	6.6593E-05	6.2294E-09	1.5607E-17	3.4897E-26	1.3791E-35	1.3445E-45	1.3445E-45	5.9877E-149	5.1323E-149	4.2769E-149
0.029	1.7904E-02	9.0966E-05	1.1710E-08	9.3730E-17	2.5426E-25	2.1533E-34	4.6562E-44	4.6562E-44	5.9877E-149	5.1323E-149	4.2769E-149
0.030	2.0149E-02	1.2171E-04	2.1131E-08	3.1470E-16	1.6725E-24	2.7993E-33	1.2710E-42	1.2710E-42	5.9877E-149	5.1323E-149	4.2769E-149
0.031	2.2494E-02	1.5981E-04	3.6643E-08	9.7711E-16	5.2014E-24	3.0841E-32	2.8029E-41	2.8029E-41	5.9877E-149	5.1323E-149	4.2769E-149
0.032	2.5957E-02	2.0630E-04	6.1530E-08	2.8206E-15	9.9417E-23	2.9247E-31	5.0945E-40	5.0945E-40	5.9877E-149	5.1323E-149	4.2769E-149
0.033	3.0521E-02	2.6223E-04	1.0002E-07	7.6686E-15	2.3030E-22	2.9247E-30	7.7673E-39	7.7673E-39	5.9877E-149	5.1323E-149	4.2769E-149
0.034	3.6181E-02	3.2865E-04	1.5400E-07	1.2693E-14	9.8037E-21	1.7684E-29	1.0897E-36	1.0897E-36	5.9877E-149	5.1323E-149	4.2769E-149
0.035	4.2937E-02	4.0661E-04	2.4315E-07	1.7533E-14	3.8419E-21	1.1534E-28	1.1318E-35	1.1318E-35	5.9877E-149	5.1323E-149	4.2769E-149
0.036	5.0764E-02	4.9721E-04	3.6535E-07	1.0970E-13	1.3958E-20	6.7788E-28	1.1102E-35	1.1102E-35	5.9877E-149	5.1323E-149	4.2769E-149
0.037	5.9684E-02	6.0141E-04	5.3702E-07	2.4179E-13	4.2779E-20	3.6253E-27	9.6253E-35	9.6253E-35	5.9877E-149	5.1323E-149	4.2769E-149
0.038	6.9744E-02	7.2029E-04	7.3515E-07	5.1179E-13	1.5021E-19	1.7703E-24	4.4843E-32	4.4843E-32	5.9877E-149	5.1323E-149	4.2769E-149
0.039	8.1737E-02	8.5747E-04	1.0735E-06	1.0424E-12	4.4978E-19	7.9797E-26	5.1894E-33	5.1894E-33	5.9877E-149	5.1323E-149	4.2769E-149
0.040	9.5764E-02	1.0354E-03	1.5193E-06	1.2749E-18	1.2749E-18	3.3361E-25	3.2814E-32	3.2814E-32	5.9877E-149	5.1323E-149	4.2769E-149
0.041	1.1055E-02	1.1735E-03	2.0774E-06	3.4944E-12	3.4347E-18	1.3007E-24	1.8963E-31	1.8963E-31	5.9877E-149	5.1323E-149	4.2769E-149
0.042	1.2697E-02	1.3547E-03	2.7984E-06	7.1809E-12	8.4247E-18	4.7534E-24	1.0081E-30	1.0081E-30	5.9877E-149	5.1323E-149	4.2769E-149
0.043	1.4584E-02	1.5648E-03	3.7179E-06	1.2870E-11	2.1708E-17	1.6395E-23	4.0593E-30	4.0593E-30	5.9877E-149	5.1323E-149	4.2769E-149
0.044	1.6831E-02	1.7844E-03	4.8761E-06	2.2402E-11	5.1255E-17	5.3197E-23	2.2684E-29	2.2684E-29	5.9877E-149	5.1323E-149	4.2769E-149
0.045	1.9474E-02	2.0341E-03	6.3145E-06	3.8240E-11	1.1644E-16	1.6426E-22	9.6907E-29	9.6907E-29	5.9877E-149	5.1323E-149	4.2769E-149
0.046	2.2494E-02	2.2994E-03	8.0949E-06	6.3034E-11	2.5541E-16	4.8257E-22	3.8937E-28	3.8937E-28	5.9877E-149	5.1323E-149	4.2769E-149
0.047	2.5844E-02	2.5844E-03	1.0265E-05	1.0360E-10	5.4714E-16	1.3547E-22	1.4733E-27	1.4733E-27	5.9877E-149	5.1323E-149	4.2769E-149
0.048	2.9494E-02	2.9494E-03	1.2884E-05	1.6520E-10	1.1134E-15	3.6429E-21	5.2738E-26	5.2738E-26	5.9877E-149	5.1323E-149	4.2769E-149
0.049	3.3444E-02	3.3444E-03	1.6024E-05	2.2221E-10	2.2221E-15	4.9083E-21	7.7921E-26	7.7921E-26	5.9877E-149	5.1323E-149	4.2769E-149
0.050	3.7774E-02	3.7774E-03	1.9762E-05	3.0774E-10	4.3144E-14	2.3394E-20	5.7749E-24	5.7749E-24	5.9877E-149	5.1323E-149	4.2769E-149

TABLE A1 (CONTINUED)

α	0.99	0.975	0.95	0.90	0.85	γ	0.80	0.75	0.70	0.60	0.50
0.0051	0.05393	0.03953	2.167E-05	6.012E-10	0.160E-15	5.612E-20	1.792E-25	1.792E-25	2.380E-31	1.780E-44	5.316E-60
0.0052	0.09003	0.04351	2.932E-05	8.945E-10	1.504E-14	1.302E-19	5.303E-24	5.303E-24	9.182E-31	1.254E-43	7.257E-59
0.0053	0.02635	0.04772	3.532E-05	1.311E-09	2.716E-14	2.972E-19	1.501E-24	1.501E-24	3.452E-30	7.812E-43	8.912E-58
0.0054	0.09286	0.05216	4.225E-05	1.893E-09	4.793E-14	6.381E-19	4.117E-24	4.117E-24	1.633E-29	4.674E-42	1.011E-56
0.0055	0.09954	0.05683	5.020E-05	2.702E-09	8.282E-14	1.352E-19	1.083E-23	1.083E-23	3.866E-29	2.601E-41	1.061E-55
0.0056	0.10338	0.06173	5.934E-05	3.804E-09	1.404E-13	2.742E-18	2.755E-23	2.755E-23	1.231E-28	1.366E-40	9.907E-55
0.0057	0.10735	0.06687	6.970E-05	5.294E-09	2.332E-13	5.610E-18	6.793E-23	6.793E-23	3.743E-28	4.760E-40	8.691E-54
0.0058	0.11143	0.07223	8.140E-05	7.283E-09	3.821E-13	1.105E-18	1.626E-22	1.626E-22	1.670E-27	3.173E-39	7.073E-53
0.0059	0.11561	0.07783	9.458E-05	9.930E-09	6.145E-13	2.113E-17	3.761E-22	3.761E-22	3.194E-27	1.412E-38	5.327E-52
0.0060	0.11989	0.08366	1.093E-04	1.334E-08	9.726E-13	3.979E-17	8.478E-22	8.478E-22	5.593E-27	5.979E-38	3.800E-51
0.0061	0.12423	0.08971	1.258E-04	1.779E-08	1.516E-12	7.321E-17	1.869E-22	1.869E-22	2.789E-26	2.414E-37	3.525E-50
0.0062	0.12863	0.09599	1.449E-04	2.354E-08	2.330E-12	2.389E-16	3.981E-21	3.981E-21	5.825E-26	9.312E-37	1.574E-49
0.0063	0.129708	0.10249	1.643E-04	3.079E-08	3.533E-12	2.389E-16	8.314E-21	8.314E-21	1.458E-25	3.447E-36	9.311E-49
0.0064	0.13356	0.10921	1.866E-04	3.994E-08	5.282E-12	4.083E-16	1.679E-21	1.679E-21	3.532E-25	1.223E-35	5.195E-48
0.0065	0.137207	0.11615	2.113E-04	5.152E-08	7.816E-12	6.958E-16	3.397E-20	3.397E-20	8.328E-25	4.178E-35	2.750E-47
0.0066	0.14059	0.12331	2.379E-04	6.587E-08	1.147E-11	1.174E-15	6.630E-19	6.630E-19	1.912E-24	1.347E-34	1.393E-46
0.0067	0.14471	0.13068	2.672E-04	8.360E-08	1.640E-11	1.936E-15	1.271E-19	1.271E-19	4.255E-24	4.364E-34	6.635E-46
0.0068	0.14863	0.13827	2.991E-04	1.053E-07	2.350E-11	3.162E-15	2.790E-19	2.790E-19	9.376E-24	1.339E-33	1.331E-45
0.0069	0.152214	0.14606	3.337E-04	1.319E-07	3.331E-11	5.091E-15	4.412E-19	4.412E-19	2.055E-23	3.971E-33	3.032E-45
0.0070	0.155963	0.15405	3.712E-04	1.640E-07	4.664E-11	8.042E-15	6.001E-19	6.001E-19	4.187E-23	1.154E-32	5.591E-44
0.0071	0.159708	0.16224	4.116E-04	2.024E-07	6.462E-11	1.263E-14	1.426E-18	1.426E-18	1.603E-23	3.202E-32	2.255E-43
0.0072	0.163550	0.17064	4.551E-04	2.492E-07	8.891E-11	1.959E-14	2.507E-18	2.507E-18	1.787E-22	8.700E-32	8.753E-43
0.0073	0.167189	0.17922	5.018E-04	3.046E-07	1.211E-10	2.992E-14	4.335E-18	4.335E-18	3.407E-22	2.297E-31	3.272E-42
0.0074	0.170322	0.18500	5.519E-04	3.702E-07	1.637E-10	4.520E-14	7.386E-18	7.386E-18	6.585E-22	5.921E-31	1.180E-41
0.0075	0.174550	0.19696	6.054E-04	4.477E-07	2.193E-10	6.770E-14	1.240E-17	1.240E-17	1.254E-21	1.456E-31	4.117E-41
0.0076	0.178372	0.20411	6.625E-04	5.380E-07	2.917E-10	1.001E-13	2.051E-17	2.051E-17	3.525E-21	3.625E-30	1.369E-40
0.0077	0.18288	0.21544	7.232E-04	6.445E-07	3.452E-10	1.467E-13	3.593E-17	3.593E-17	7.813E-21	2.041E-29	4.542E-40
0.0078	0.18597	0.22494	7.873E-04	7.689E-07	5.046E-10	2.128E-13	5.428E-17	5.428E-17	1.391E-20	4.675E-27	4.438E-39
0.0079	0.18949	0.23462	8.564E-04	9.121E-07	6.573E-10	3.052E-13	8.651E-17	8.651E-17	2.451E-20	1.069E-28	1.372E-38
0.0080	0.193192	0.24446	9.290E-04	1.077E-06	8.502E-10	4.342E-13	1.360E-16	1.360E-16	4.251E-20	2.392E-28	3.872E-38
0.0081	0.196478	0.25447	1.005E-03	1.263E-06	1.092E-09	6.137E-13	2.126E-16	2.126E-16	4.251E-20	2.392E-28	3.872E-38
0.0082	0.20056	0.26454	1.086E-03	1.490E-06	1.394E-09	8.580E-13	3.279E-16	3.279E-16	7.273E-20	1.055E-27	1.097E-37
0.0083	0.204225	0.27497	1.171E-03	1.733E-06	1.772E-09	1.194E-12	5.001E-16	5.001E-16	1.238E-19	4.932E-28	3.045E-37
0.0084	0.207885	0.28546	1.261E-03	2.013E-06	2.237E-09	1.642E-12	7.562E-16	7.562E-16	2.093E-19	1.064E-27	8.230E-37
0.0085	0.211535	0.29609	1.354E-03	2.339E-06	2.809E-09	2.247E-12	1.131E-15	1.131E-15	3.774E-19	4.625E-27	2.719E-36
0.0086	0.215178	0.30687	1.454E-03	2.702E-06	3.507E-09	3.043E-12	1.673E-15	1.673E-15	5.520E-19	9.036E-27	5.691E-36
0.0087	0.218409	0.31780	1.558E-03	3.112E-06	4.361E-09	4.052E-12	2.460E-15	2.460E-15	8.432E-19	1.788E-26	1.414E-35
0.0088	0.222431	0.32886	1.665E-03	3.579E-06	5.335E-09	5.497E-12	3.581E-15	3.581E-15	1.412E-18	3.483E-26	3.503E-35
0.0089	0.226442	0.34007	1.774E-03	4.085E-06	6.637E-09	7.306E-12	5.181E-15	5.181E-15	2.277E-18	6.893E-26	8.489E-35
0.0090	0.229443	0.35140	1.891E-03	4.637E-06	8.131E-09	9.647E-12	7.420E-15	7.420E-15	3.476E-18	1.266E-25	2.017E-34
0.0091	0.232734	0.36287	2.020E-03	5.249E-06	9.917E-09	1.288E-11	1.054E-14	1.054E-14	5.374E-18	2.334E-25	4.702E-34
0.0092	0.236314	0.37446	2.149E-03	6.011E-06	1.204E-08	1.654E-11	1.480E-14	1.480E-14	8.204E-18	4.111E-25	1.076E-33
0.0093	0.239418	0.38618	2.281E-03	6.799E-06	1.456E-08	2.148E-11	2.081E-14	2.081E-14	1.181E-17	7.905E-25	2.420E-33
0.0094	0.243461	0.39801	2.420E-03	7.679E-06	1.754E-08	2.775E-11	2.892E-14	2.892E-14	1.891E-17	1.418E-24	5.349E-33
0.0095	0.247488	0.40997	2.564E-03	8.632E-06	2.103E-08	3.561E-11	3.992E-14	3.992E-14	2.804E-17	2.513E-24	1.123E-32
0.0096	0.251103	0.42203	2.712E-03	9.690E-06	2.515E-08	4.542E-11	5.473E-14	5.473E-14	4.141E-17	4.001E-24	2.445E-32
0.0097	0.254548	0.43421	2.867E-03	1.0842E-05	2.994E-08	5.781E-11	7.425E-14	7.425E-14	6.042E-17	7.616E-24	5.235E-32
0.0098	0.258061	0.44650	3.026E-03	1.212E-05	3.553E-08	7.311E-11	1.003E-13	1.003E-13	8.806E-17	1.303E-23	1.0851E-31
0.0099	0.261563	0.45889	3.192E-03	1.351E-05	4.201E-08	9.204E-11	1.357E-13	1.357E-13	1.270E-16	2.374E-23	2.170E-31
0.0100	0.265053	0.47138	3.362E-03	1.503E-05	4.951E-08	1.153E-10	1.815E-13	1.815E-13	3.698E-23	4.465E-23	4.465E-23

TABLE A1 (CONTINUED)

α	0.99	0.975	0.95	0.90	0.85	0.80	0.75	0.70	0.60	0.50
0.110	.299307	.060131	5.3753E-03	3.9217E-05	2.1715E-07	8.7746E-10	2.4840E-12	4.604E-15	3.8474E-21	2.4370E-26
0.120	.332376	.073864	7.9546E-03	8.7125E-05	7.4444E-07	4.7761E-09	2.190E-11	6.998E-14	1.8458E-19	4.6531E-26
0.130	.368275	.088128	1.1094E-02	1.7147E-04	2.1116E-06	1.9921E-08	1.3908E-10	6.894E-13	1.8427E-18	3.4908E-24
0.140	.395542	.102761	1.4771E-02	3.0621E-04	5.1616E-06	6.7942E-08	4.862E-10	4.892E-12	9.090E-17	1.7871E-22
0.150	.424727	.117634	1.8950E-02	5.0627E-04	1.1209E-05	1.9478E-07	2.6631E-09	2.678E-11	9.254E-16	4.8524E-21
0.160	.453386	.132646	2.3591E-02	7.8611E-04	2.2044E-05	4.992E-07	8.837E-09	1.1847E-10	7.742E-15	8.7220E-20
0.170	.481076	.147718	2.8440E-02	1.1544E-03	4.0136E-05	1.1344E-06	1.549E-08	4.4001E-10	5.047E-14	1.1161E-18
0.180	.507454	.162790	3.4083E-02	1.6349E-03	6.8320E-05	2.3540E-06	6.5261E-08	1.4154E-09	2.693E-13	1.0760E-17
0.190	.533774	.177815	3.9849E-02	2.2341E-03	1.0998E-04	4.5240E-06	1.5147E-07	4.0115E-09	1.2017E-12	8.1726E-17
0.200	.558886	.192756	4.5610E-02	2.9497E-03	1.6883E-04	8.1451E-06	3.2319E-07	1.0264E-08	4.6127E-12	5.0687E-16
0.210	.583237	.207587	5.2224E-02	3.7907E-03	2.4880E-04	1.3867E-05	6.4162E-07	2.4014E-08	1.5578E-11	2.6823E-15
0.220	.606873	.222286	5.8770E-02	4.7714E-03	3.5401E-04	2.2446E-05	1.1967E-06	5.2011E-08	4.7104E-11	1.1855E-14
0.230	.629833	.236837	6.5506E-02	5.8950E-03	4.8855E-04	3.4943E-05	2.1151E-06	1.0534E-07	1.2937E-10	4.646E-14
0.240	.652160	.251230	7.2409E-02	7.1472E-03	6.5644E-04	5.2468E-05	3.5649E-06	2.0116E-07	3.2666E-10	1.6401E-13
0.250	.673484	.265454	7.9454E-02	8.5337E-03	8.152E-04	7.6168E-05	5.7623E-06	3.681E-07	7.6597E-10	5.2117E-13
0.260	.695041	.279506	8.6620E-02	1.0008E-02	1.1074E-03	1.0747E-04	8.9775E-06	6.3201E-07	1.6821E-09	1.5150E-12
0.270	.715600	.293382	9.3880E-02	1.1724E-02	1.3974E-03	1.4779E-04	1.3536E-05	1.0513E-06	3.4851E-09	4.0699E-12
0.280	.735770	.307079	.101240	1.3511E-02	1.7345E-03	1.9870E-04	1.9820E-05	1.6865E-06	8.851E-09	1.0189E-11
0.290	.755664	.320597	.108662	1.5423E-02	2.1213E-03	2.6177E-04	2.8267E-05	2.6187E-06	1.2870E-08	2.3944E-11
0.300	.774566	.333936	.116138	1.7457E-02	2.5601E-03	3.3860E-04	3.9380E-05	3.9490E-06	2.3170E-08	5.3355E-11
0.310	.793296	.347097	.123659	1.9606E-02	3.0528E-03	4.3908E-04	5.3699E-05	5.7995E-06	4.0162E-08	1.1209E-10
0.320	.811612	.360083	.131212	2.1895E-02	3.6011E-03	5.3908E-04	7.1824E-05	8.3156E-06	4.7267E-08	2.2562E-10
0.330	.829533	.372895	.138788	2.4235E-02	4.2060E-03	6.6783E-04	9.4343E-05	1.1464E-05	1.0920E-07	4.3531E-10
0.340	.847076	.385536	.146381	2.6706E-02	4.8768E-03	8.1520E-04	1.2208E-04	1.6045E-05	1.7231E-07	8.0806E-10
0.350	.864259	.398009	.153981	2.9274E-02	5.5892E-03	9.8434E-04	1.5560E-04	2.1670E-05	2.6490E-07	1.4480E-09
0.360	.881098	.410317	.161582	3.1930E-02	6.3685E-03	1.1763E-03	1.9567E-04	2.8783E-05	3.9764E-07	2.5120E-09
0.370	.897407	.422463	.169179	3.4675E-02	7.2064E-03	1.3922E-03	2.3044E-04	3.7451E-05	5.8197E-07	4.2302E-09
0.380	.913801	.434451	.176768	3.7502E-02	8.1028E-03	1.6333E-03	2.9848E-04	4.8562E-05	8.4047E-07	6.9311E-09
0.390	.929493	.446284	.184342	4.0407E-02	9.0573E-03	1.9007E-03	3.6273E-04	6.1824E-05	1.1873E-06	1.1073E-08
0.400	.945295	.457965	.191899	4.3394E-02	1.0069E-02	2.1953E-03	4.3655E-04	7.7771E-05	1.6884E-06	1.7282E-08
0.410	.960618	.469498	.199435	4.6430E-02	1.1138E-02	2.5181E-03	5.2074E-04	9.6744E-05	2.2526E-06	2.6333E-08
0.420	.975675	.480886	.206947	4.9541E-02	1.2264E-02	2.8647E-03	6.1595E-04	1.1910E-04	3.0333E-06	3.9504E-08
0.430	.990474	.492133	.214433	5.2713E-02	1.3444E-02	3.2508E-03	7.2298E-04	1.4523E-04	4.0280E-06	5.8032E-08
0.440	1.005026	.503242	.221890	5.5947E-02	1.4678E-02	3.6621E-03	8.4244E-04	1.7550E-04	5.2807E-06	8.3775E-08
0.450	1.019340	.514216	.229316	5.9223E-02	1.5966E-02	4.1039E-03	9.7504E-04	2.1032E-04	6.8404E-06	1.1899E-07
0.460	1.033425	.525058	.236710	6.2555E-02	1.7305E-02	4.5767E-03	1.1215E-03	2.5007E-04	8.7419E-06	1.6544E-07
0.470	1.047288	.535772	.244069	6.5933E-02	1.8695E-02	5.0807E-03	1.2823E-03	2.9417E-04	1.1104E-05	2.2933E-07
0.480	1.060938	.546361	.251394	6.9355E-02	2.0135E-02	5.6162E-03	1.4581E-03	3.3939E-05	1.3939E-05	3.1233E-07
0.490	1.074382	.556827	.258682	7.2817E-02	2.1622E-02	6.1833E-03	1.6494E-03	4.0301E-04	1.7334E-05	4.1971E-07
0.500	1.087627	.567174	.265932	7.6317E-02	2.3156E-02	6.7820E-03	1.8547E-03	4.8454E-04	2.1346E-05	5.5739E-07
0.510	1.100680	.577404	.273145	7.9820E-02	2.4735E-02	7.4124E-03	2.0805E-03	5.7306E-04	2.6130E-05	7.3204E-07
0.520	1.113547	.587520	.280319	8.3420E-02	2.6359E-02	8.0744E-03	2.3213E-03	6.7402E-04	3.1705E-05	9.5144E-07
0.530	1.126235	.597525	.287454	8.7018E-02	2.8025E-02	8.7674E-03	2.5793E-03	7.0047E-04	3.8192E-05	1.2255E-06
0.540	1.138747	.607459	.294549	9.0644E-02	2.9732E-02	9.4967E-03	2.8550E-03	7.9413E-04	4.5690E-05	1.5813E-06
0.550	1.151092	.617213	.301605	9.4243E-02	3.1480E-02	1.0244E-02	3.1480E-03	8.9424E-04	5.4301E-05	1.9733E-06
0.560	1.163273	.626900	.308620	9.7971E-02	3.3266E-02	1.1035E-02	3.4607E-03	1.0072E-03	6.4154E-05	2.4732E-06
0.570	1.175294	.636486	.315595	1.01668A	3.5089E-02	1.1853E-02	3.7913E-03	1.1272E-03	7.5154E-05	3.0784E-06
0.580	1.187163	.645973	.322530	.10538A	3.6948E-02	1.2700E-02	4.1405E-03	1.2568E-03	8.8014E-05	3.7984E-06
0.590	1.19882	.655364	.329425	.109132	3.8843E-02	1.3577E-02	4.5087E-03	1.3861E-03	1.0224E-04	4.6517E-06
0.600	1.210456	.664660	.336278	.11287A	4.0770E-02	1.4484E-02	4.8960E-03	1.5455E-03	1.1821E-04	5.6622E-06

TABLE A1 (CONTINUED)

α	0.99	0.975	0.95	0.90	0.85	γ	0.80	0.75	0.70	0.60	0.50
0.910	1.221490	.673855	.343092	.116644	4.2731E-02	1.5201E-02	5.3025E-03	1.7053E-03	1.7053E-03	1.3604E-04	6.9481E-06
0.920	1.233187	.682979	.349866	.120427	4.4722E-02	1.6384E-02	5.7282E-03	1.8757E-03	1.8757E-03	1.5684E-04	8.2320E-06
0.930	1.244451	.692005	.356599	.124222	4.6743E-02	1.7377E-02	6.1734E-03	2.0707E-03	2.0707E-03	1.7774E-04	9.8341E-06
0.940	1.255386	.700944	.363293	.128023	4.8794E-02	1.8397E-02	6.6379E-03	2.2694E-03	2.2694E-03	2.0193E-04	1.1692E-05
0.950	1.266295	.709800	.369947	.131845	5.0872E-02	1.9455E-02	7.1195E-03	2.4532E-03	2.4532E-03	2.2849E-04	1.3823E-05
0.960	1.277461	.718573	.376562	.135671	5.2976E-02	2.0519E-02	7.6253E-03	2.6484E-03	2.6484E-03	2.5759E-04	1.6260E-05
0.970	1.287769	.727265	.383137	.139504	5.5107E-02	2.1519E-02	8.1814E-03	2.8545E-03	2.8545E-03	2.9034E-04	1.9034E-05
0.980	1.298300	.735878	.389674	.143345	5.7262E-02	2.2455E-02	8.6902E-03	3.1433E-03	3.1433E-03	3.2344E-04	2.2179E-05
0.990	1.308739	.744414	.396172	.147192	5.9441E-02	2.3897E-02	9.2916E-03	3.4533E-03	3.4533E-03	3.6151E-04	2.5729E-05
0.900	1.319167	.752874	.402632	.151044	6.1643E-02	2.5073E-02	9.9222E-03	3.6684E-03	3.6684E-03	4.0214E-04	2.9723E-05
0.910	1.329888	.761260	.409054	.154900	6.3866E-02	2.6273E-02	1.0342E-02	3.9299E-03	3.9299E-03	4.4604E-04	3.4198E-05
0.920	1.339404	.769574	.415438	.158760	6.6111E-02	2.7496E-02	1.1050E-02	4.2114E-03	4.2114E-03	4.9334E-04	3.9194E-05
0.930	1.349417	.777816	.421785	.162623	6.8375E-02	2.8743E-02	1.1688E-02	4.5122E-03	4.5122E-03	5.4413E-04	4.4754E-05
0.940	1.359332	.785988	.428095	.166489	7.0659E-02	3.0013E-02	1.2344E-02	4.8253E-03	4.8253E-03	5.9856E-04	5.0420E-05
0.950	1.369148	.794093	.434369	.170354	7.2962E-02	3.1304E-02	1.3014E-02	5.1510E-03	5.1510E-03	6.5684E-04	5.7739E-05
0.960	1.378870	.802130	.440607	.174221	7.5282E-02	3.2617E-02	1.3714E-02	5.4894E-03	5.4894E-03	7.1901E-04	6.5255E-05
0.970	1.388499	.810102	.446809	.178068	7.7619E-02	3.3951E-02	1.4423E-02	5.8409E-03	5.8409E-03	7.8524E-04	7.3517E-05
0.980	1.398037	.818009	.452975	.181955	7.9972E-02	3.5304E-02	1.5152E-02	6.2051E-03	6.2051E-03	8.5564E-04	8.2575E-05
0.990	1.407486	.825854	.459106	.185821	8.2341E-02	3.6681E-02	1.5894E-02	6.5821E-03	6.5821E-03	9.3040E-04	9.2477E-05
0.900	1.416849	.833636	.465203	.189684	8.4725E-02	3.8075E-02	1.6664E-02	6.9721E-03	6.9721E-03	1.0049E-03	1.0324E-04
0.910	1.426127	.841358	.471266	.193549	8.7123E-02	3.9480E-02	1.7446E-02	7.3740E-03	7.3740E-03	1.0813E-03	1.1503E-04
0.920	1.435323	.849020	.477294	.197410	8.9534E-02	4.0921E-02	1.8245E-02	7.7806E-03	7.7806E-03	1.1617E-03	1.2778E-04
0.930	1.444437	.856624	.483289	.201268	9.1959E-02	4.2371E-02	1.9061E-02	8.2192E-03	8.2192E-03	1.2460E-03	1.4159E-04
0.940	1.453472	.864171	.489251	.205123	9.4396E-02	4.3839E-02	1.9914E-02	8.6740E-03	8.6740E-03	1.3240E-03	1.5651E-04
0.950	1.462429	.871661	.495181	.208974	9.6844E-02	4.5355E-02	2.0744E-02	9.1502E-03	9.1502E-03	1.4060E-03	1.7260E-04
0.960	1.471311	.879096	.501077	.212822	9.9304E-02	4.6827E-02	2.1610E-02	9.5820E-03	9.5820E-03	1.4915E-03	1.8951E-04
0.970	1.480119	.886477	.506942	.216664	.101775	4.8345E-02	2.2491E-02	1.0062E-02	1.0062E-02	1.5745E-03	2.0851E-04
0.980	1.488852	.893805	.512755	.220506	.104356	4.9800E-02	2.3369E-02	1.0544E-02	1.0544E-02	1.6574E-03	2.2844E-04
0.990	1.497515	.901080	.518577	.224341	.106746	5.1149E-02	2.4302E-02	1.1060E-02	1.1060E-02	1.7404E-03	2.4977E-04
0.900	1.506107	.908304	.524348	.228171	.109246	5.2594E-02	2.5230E-02	1.1577E-02	1.1577E-02	1.8240E-03	2.7256E-04
0.910	1.514632	.915477	.530088	.231994	.111755	5.3974E-02	2.6174E-02	1.2107E-02	1.2107E-02	1.9075E-03	2.9687E-04
0.920	1.523189	.922691	.535799	.235815	.114372	5.5168E-02	2.7133E-02	1.2650E-02	1.2650E-02	2.0052E-03	3.2274E-04
0.930	1.531800	.929876	.541479	.239629	.116977	5.7776E-02	2.8106E-02	1.3205E-02	1.3205E-02	2.1052E-03	3.5025E-04
0.940	1.539407	.936703	.547110	.243439	.119330	5.9397E-02	2.9093E-02	1.3772E-02	1.3772E-02	2.2084E-03	3.7945E-04
0.950	1.548070	.943484	.552752	.247239	.121870	6.1042E-02	3.0095E-02	1.4352E-02	1.4352E-02	2.3131E-03	4.1039E-04
0.960	1.556271	.950177	.558345	.251035	.124416	6.2644E-02	3.1110E-02	1.4937E-02	1.4937E-02	2.4207E-03	4.4315E-04
0.970	1.564412	.957506	.563909	.254825	.126969	6.4334E-02	3.2139E-02	1.5547E-02	1.5547E-02	2.5314E-03	4.7777E-04
0.980	1.572492	.964349	.569445	.258604	.129528	6.6111E-02	3.3182E-02	1.6162E-02	1.6162E-02	2.6441E-03	5.1431E-04
0.990	1.580514	.971149	.574954	.262385	.132093	6.7875E-02	3.4238E-02	1.6789E-02	1.6789E-02	2.7595E-03	5.5283E-04
1.000	1.588478	.977905	.580335	.266155	.134663	6.9390E-02	3.5306E-02	1.7424E-02	1.7424E-02	2.8844E-03	5.9339E-04
1.010	1.596515	.984631	.585666	.269921	.137241	7.0905E-02	3.6365E-02	1.8072E-02	1.8072E-02	3.0177E-03	6.3592E-04
1.020	1.604905	.991355	.590955	.273684	.139844	7.2421E-02	3.7424E-02	1.8733E-02	1.8733E-02	3.1544E-03	6.8045E-04
1.030	1.613702	.998088	.596206	.277441	.142469	7.3938E-02	3.8483E-02	1.9407E-02	1.9407E-02	3.2955E-03	7.2692E-04
1.040	1.622937	.100000	.601418	.281191	.145116	7.5456E-02	3.9542E-02	2.0092E-02	2.0092E-02	3.4411E-03	7.7542E-04
1.050	1.632601	.100915	.606700	.284937	.147786	7.6974E-02	4.0601E-02	2.0787E-02	2.0787E-02	3.5914E-03	8.2592E-04
1.060	1.642704	.101826	.611944	.288679	.150479	7.8496E-02	4.1660E-02	2.1492E-02	2.1492E-02	3.7455E-03	8.7842E-04
1.070	1.653247	.102733	.617154	.292416	.153196	7.9999E-02	4.2719E-02	2.2207E-02	2.2207E-02	3.9034E-03	9.3292E-04
1.080	1.664320	.103636	.622331	.296148	.155936	8.1492E-02	4.3755E-02	2.2932E-02	2.2932E-02	4.0652E-03	9.8942E-04
1.090	1.675923	.104535	.627484	.300000	.158700	8.2974E-02	4.4790E-02	2.3665E-02	2.3665E-02	4.2310E-03	1.0479E-03
1.100	1.688056	.105429	.632615	.303879	.161489	8.4446E-02	4.5832E-02	2.4407E-02	2.4407E-02	4.4014E-03	1.1119E-03
1.110	1.699719	.106318	.637728	.307784	.164304	8.5900E-02	4.6881E-02	2.5158E-02	2.5158E-02	4.5764E-03	1.1779E-03
1.120	1.711902	.107202	.642814	.311716	.167146	8.7354E-02	4.7936E-02	2.5914E-02	2.5914E-02	4.7555E-03	1.2459E-03
1.130	1.724605	.108081	.647884	.315684	.170016	8.8800E-02	4.8997E-02	2.6675E-02	2.6675E-02	4.9387E-03	1.3159E-03
1.140	1.737828	.108955	.652928	.319688	.172916	9.0240E-02	4.9999E-02	2.7441E-02	2.7441E-02	5.1260E-03	1.3879E-03
1.150	1.751571	.109824	.657946	.323728	.175846	9.1674E-02	5.0999E-02	2.8212E-02	2.8212E-02	5.3174E-03	1.4619E-03
1.160	1.765834	.110688	.662938	.327804	.178806	9.3094E-02	5.1999E-02	2.8988E-02	2.8988E-02	5.5128E-03	1.5379E-03
1.170	1.780617	.111547	.667904	.331916	.181796	9.4500E-02	5.2999E-02	2.9769E-02	2.9769E-02	5.7122E-03	1.6159E-03
1.180	1.795920	.112401	.672844	.336064	.184816	9.5900E-02	5.3999E-02	3.0555E-02	3.0555E-02	5.9156E-03	1.6959E-03
1.190	1.811743	.113250	.677758	.340258	.187866	9.7300E-02	5.4999E-02	3.1346E-02	3.1346E-02	6.1228E-03	1.7779E-03
1.200	1.828086	.114094	.682646	.344498	.190946	9.8700E-02	5.5999E-02	3.2142E-02	3.2142E-02	6.3340E-03	1.8619E-03
1.210	1.844949	.114933	.687509	.348784	.194056	1.0000E-01	5.6999E-02	3.2942E-02	3.2942E-02	6.5492E-03	1.9479E-03
1.220	1.862332	.115767	.692346	.353116	.197196	1.0100E-01	5.7999E-02	3.3746E-02	3.3746E-02	6.7684E-03	2.0359E-03
1.230	1.879235	.116596	.697158	.357494	.200366	1.0200E-01	5.8999E-02	3.4554E-02	3.4554E-02	6.9916E-03	2.1259E-03
1.240	1.896658	.117420	.701944	.361918	.203566	1.0300E-01	5.9999E-02	3.5366E-02	3.5366E-02	7.2178E-03	2.2179E-03
1.250	1.914591	.118239	.706704	.366388	.206796	1.0400E-01	6.0999E-02	3.6182E-02	3.6182E-02	7.4470E-03	2.3119E-03
1.260	1.933034	.119053	.711438	.370904	.210056	1.0500E-01	6.1999E-02	3.6999E-02	3.6999E-02	7.6792E-03	2.4079E-03
1.270	1.951987	.119862	.716148	.375466	.213346	1.0600E-01	6.2999E-02	3.7816E-02	3.7816E-02	7.9144E-03	2.5059E-03
1.280	1.971450	.120666	.720834	.380074	.216666	1.0700E-01	6.3999E-02	3.8634E-02	3.8634E-02	8.1526E-03	2.6059E-03
1.290	1.991423	.121465	.725496	.384728	.220006	1.0800E-01	6.4999E-02	3.9452E-02	3.9452E-02	8.3938E-03	2.7079E-03
1.300	2.011906	.122259	.730134	.389378	.223376	1.0900E-01	6.5999E-02	4.0270E-02	4.0270E-02	8.6380E-03	2.8119E-03
1.310	2.032899	.123048	.734748	.394024	.226776	1.1000E-01	6.6999E-02	4.1088E-02	4.1088E-02	8.8852E-03	2.9179E-03
1.320	2.054402	.123832	.739328	.398666	.230206	1.1100E-01	6.7999E-02	4.1906E-02	4.1906E-02	9.1354E-03	3.0259E-03
1.330	2.076415	.124611	.743874	.403304	.233666	1.1200E-01	6.8999E-02	4.2724E-02	4.2724E-02	9.3876E-03	3.1359E-03
1.340	2.098938	.125385	.748386	.407938	.237146	1.1300E-01	6.9999E-02	4.3542E-02	4.3542E-02	9.6428E-03	3.2479E-03
1.350	2.121971	.126154	.752866	.412568	.240646	1.1400E-					

TABLE A1 (CONTINUED)

α	0.99	.975	0.95	0.90	0.85	γ	0.80	0.75	0.70	0.60	0.50
.2100	2.251244	1.554388	1.068149	.665041	.417000	.283606	.195062	.133922	.086630	.024714	
.2200	2.298758	1.596493	1.104856	.664630	.441326	.283606	.211366	.147027	.096589	.029007	
.2300	2.344469	1.637511	1.140712	.663699	.445379	.323526	.227743	.160319	.103509	.032907	
.2400	2.389980	1.677528	1.175781	.662270	.449164	.343355	.244169	.173768	.108540	.035503	
.2500	2.433885	1.716618	1.210115	.660393	.452697	.363085	.260626	.187348	.109236	.037674	
.2600	2.476787	1.754817	1.243767	.658064	.455954	.382709	.277098	.201039	.110236	.039105	
.2700	2.518497	1.792275	1.276777	.655322	.458975	.402282	.293571	.214821	.112902	.040686	
.2800	2.557743	1.828956	1.309187	.652190	.461755	.421622	.310034	.228678	.115900	.042480	
.2900	2.594963	1.864938	1.341034	.648679	.464304	.440906	.326480	.242597	.119150	.044607	
.3000	2.630491	1.900254	1.372350	.645322	.466735	.459926	.342899	.256565	.122407	.047045	
.3100	2.664813	1.934974	1.403167	.641811	.468735	.479126	.359288	.270572	.126114	.049833	
.3200	2.701671	1.969104	1.433511	.638074	.470532	.498462	.375640	.284609	.130168	.053036	
.3300	2.735470	2.002688	1.463349	.634237	.472328	.516884	.391951	.298669	.134500	.056687	
.3400	2.769363	2.035755	1.492884	.630306	.474029	.535593	.408820	.312745	.139130	.060708	
.3500	2.802654	2.068333	1.521958	.626272	.475641	.554190	.424442	.326831	.144088	.065149	
.3600	2.836254	2.100447	1.550651	.622106	.477191	.572477	.440516	.340922	.149315	.070000	
.3700	2.869740	2.132122	1.578981	.617801	.478684	.591057	.456574	.355013	.154822	.075266	
.3800	2.903210	2.163319	1.606966	.613304	.479804	.609331	.472814	.369102	.160610	.080965	
.3900	2.936632	2.194427	1.634621	.608637	.480814	.627502	.488836	.383184	.166784	.087107	
.4000	3.000097	2.224716	1.661962	.603843	.481912	.645571	.504806	.397257	.173308	.093708	
.4100	3.063349	2.254463	1.689002	.600014	.482941	.663414	.520724	.411319	.180719	.100767	
.4200	3.066400	2.284604	1.715755	.595919	.483914	.681415	.536589	.425367	.188900	.108200	
.4300	3.098966	2.314605	1.742232	.591652	.484801	.699194	.552902	.439400	.197811	.116095	
.4400	3.131145	2.343308	1.768445	.587219	.485614	.716481	.569163	.453414	.207079	.124910	
.4500	3.153012	2.371998	1.794404	.582659	.486325	.734478	.583871	.467414	.216716	.134110	
.4600	3.194522	2.400517	1.820120	.577926	.486956	.751987	.599299	.481391	.226807	.143700	
.4700	3.225708	2.428767	1.845502	.573173	.487522	.769411	.615135	.495351	.237267	.153680	
.4800	3.256584	2.456747	1.870058	.568352	.488037	.786751	.630690	.509284	.248119	.164019	
.4900	3.287160	2.484470	1.895898	.563570	.488511	.804009	.646196	.523022	.259381	.174813	
.5000	3.317448	2.511933	1.920729	.558734	.488925	.821187	.661652	.537097	.271019	.186074	
.5100	3.347460	2.539177	1.945359	.553845	.489288	.838288	.677059	.550968	.283180	.197810	
.5200	3.377294	2.566180	1.969794	.548914	.489593	.855313	.692419	.564815	.295745	.210019	
.5300	3.406661	2.592659	1.994042	.543945	.489846	.872264	.707731	.578641	.308754	.222745	
.5400	3.435930	2.619524	2.018103	.538931	.490043	.889143	.722997	.592441	.322022	.235982	
.5500	3.464928	2.645860	2.041999	.533870	.490191	.905814	.738216	.606214	.335814	.249706	
.5600	3.493495	2.672036	2.065720	.528766	.490291	.922690	.753391	.619971	.349966	.263933	
.5700	3.522238	2.697997	2.089276	.523619	.490346	.939363	.768521	.633701	.364511	.278678	
.5800	3.550553	2.723769	2.112674	.518430	.490359	.955969	.783608	.647407	.379441	.293919	
.5900	3.578676	2.749360	2.135918	.513393	.490333	.972512	.798652	.661089	.394681	.309694	
.6000	3.605589	2.774733	2.159043	.508314	.490266	.988992	.813654	.674748	.410440	.325940	
.6100	3.633433	2.800016	2.181941	.503206	.490164	1.005411	.828614	.688383	.426744	.342686	
.6200	3.661426	2.825691	2.204769	.498061	.490034	1.021870	.843533	.702995	.442995	.359933	
.6300	3.689412	2.850906	2.227441	.492851	.489870	1.038470	.858444	.718144	.459244	.377680	
.6400	3.716318	2.874764	2.249980	.487604	.489717	1.054314	.873253	.732944	.474444	.395933	
.6500	3.743299	2.899370	2.272389	.482314	.489568	1.070502	.888055	.747294	.489683	.414680	
.6600	3.770109	2.923827	2.294673	.477014	.489420	1.086635	.902845	.762094	.504913	.433925	
.6700	3.796754	2.948141	2.316835	.471714	.489271	1.102714	.917545	.776904	.520144	.453670	
.6800	3.823238	2.972314	2.338878	.466414	.489122	1.118742	.932235	.791714	.535383	.472915	
.6900	3.849565	2.996352	2.360806	.461114	.488973	1.134718	.946889	.806523	.550613	.492660	
.7000	3.875739	3.020256	2.382620	.455814	.488824	1.150644	.961507	.821264	.565843	.512905	

TABLE A1 (CONTINUED)

ϕ	0.99	0.975	0.95	0.90	0.85	γ	0.75	0.70	0.60	0.50
0.7100	3.901764	3.044032	2.404325	1.772899	1.416732	1.165522	.976091	.823473	.589776	.416733
0.7200	3.927444	3.067681	2.425922	1.795368	1.434024	1.183351	.990641	.838860	.601053	.426062
0.7300	3.953383	3.091207	2.447415	1.813366	1.451254	1.198133	1.005157	.850226	.612331	.435412
0.7400	3.979885	3.114614	2.468806	1.832864	1.468424	1.213869	1.019640	.863571	.624609	.444780
0.7500	4.006452	3.137904	2.490098	1.852130	1.485533	1.229561	1.034091	.876896	.634958	.454147
0.7600	4.029787	3.161080	2.511292	1.870899	1.502585	1.245208	1.048511	.890199	.646165	.463571
0.7700	4.054995	3.184144	2.532292	1.889594	1.519580	1.260811	1.062899	.903443	.657444	.472993
0.7800	4.080078	3.207100	2.553399	1.908214	1.536519	1.276313	1.077256	.916747	.668721	.482430
0.7900	4.105038	3.229949	2.574315	1.926773	1.553403	1.291892	1.091583	.929991	.679996	.491893
0.8000	4.129979	3.252595	2.595144	1.945258	1.570234	1.307371	1.105881	.943215	.691271	.501351
0.8100	4.154803	3.275339	2.615885	1.963677	1.587013	1.322810	1.120149	.956420	.702545	.510834
0.8200	4.179214	3.297884	2.636542	1.982031	1.603741	1.338209	1.134388	.969607	.713816	.520330
0.8300	4.203112	3.320331	2.657117	2.000321	1.620418	1.353570	1.148600	.982774	.725066	.529840
0.8400	4.2268102	3.342684	2.677610	2.018547	1.637045	1.368894	1.162784	.995923	.736355	.539362
0.8500	4.2522384	3.364944	2.698024	2.036713	1.653626	1.384180	1.176940	1.009054	.747621	.548897
0.8600	4.276562	3.387113	2.718360	2.054814	1.670159	1.399429	1.191070	1.022164	.758884	.558444
0.8700	4.300838	3.409192	2.738621	2.072864	1.686644	1.414643	1.205173	1.035261	.770146	.568003
0.8800	4.324613	3.431185	2.758807	2.090852	1.703086	1.429666	1.219250	1.048334	.781405	.577572
0.8900	4.348490	3.453092	2.776920	2.108784	1.719483	1.444966	1.233302	1.061398	.792661	.587152
0.9000	4.372370	3.474915	2.798961	2.126660	1.735835	1.460076	1.247328	1.074441	.803915	.596743
0.9100	4.395956	3.496656	2.818932	2.144482	1.752145	1.475153	1.261330	1.087467	.815166	.606344
0.9200	4.419550	3.518317	2.838835	2.162250	1.768412	1.490198	1.275308	1.100474	.826415	.615954
0.9300	4.443052	3.539898	2.858670	2.179966	1.784638	1.505210	1.289261	1.113448	.837660	.625574
0.9400	4.466460	3.561402	2.878439	2.197630	1.800823	1.520190	1.303191	1.126445	.848902	.635202
0.9500	4.489793	3.582830	2.898144	2.215243	1.816959	1.535140	1.317098	1.139405	.860142	.644839
0.9600	4.513034	3.604184	2.917784	2.232808	1.833075	1.550058	1.330981	1.152350	.871378	.654485
0.9700	4.536191	3.625464	2.937362	2.250323	1.849142	1.564947	1.344843	1.165278	.882611	.664139
0.9800	4.559264	3.646673	2.956879	2.267790	1.865172	1.579806	1.358682	1.178192	.893841	.673801
0.9900	4.582257	3.667811	2.976335	2.285211	1.881154	1.594636	1.372499	1.191090	.905067	.683470
1.0000	4.605170	3.688879	2.995732	2.302585	1.897120	1.609438	1.386294	1.203973	.916291	.693147
1.0100	4.630007	3.696009	3.018665	2.317953	2.054791	1.725974	1.523133	1.320216	1.028337	.796295
1.0200	4.654810	3.697368	3.037263	2.332386	2.209386	1.900089	1.650130	1.458746	1.140034	.887936
1.0300	4.679612	3.698729	3.055849	2.346840	2.361325	2.042103	1.791513	1.584312	1.251383	.985999
1.0400	4.699504	3.699582	3.073515	2.360944	2.510947	2.182274	1.923476	1.708839	1.362399	1.084372
1.0500	4.719334	3.699520	3.090765	2.375694	2.658524	2.320814	2.054173	1.832435	1.473083	1.182987
1.0600	4.739161	3.699516	3.097940	2.382184	2.804280	2.457898	2.183735	1.955190	1.583468	1.281796
1.0700	4.758987	3.699511	3.105111	2.388742	2.948404	2.593675	2.312273	2.077183	1.693566	1.380762
1.0800	4.778812	3.699508	3.112282	2.395288	3.091050	2.728265	2.439884	2.198480	1.803395	1.479057
1.0900	4.798637	3.699504	3.119453	2.401835	3.232358	2.861780	2.566647	2.319141	1.912973	1.579050
1.1000	4.818462	3.699500	3.126624	2.408382	3.372440	2.994308	2.692635	2.439216	2.023113	1.678347
1.1100	4.838287	3.699496	3.133795	2.414929	3.511401	3.125932	2.817907	2.558751	2.131432	1.777712
1.1200	4.858112	3.699492	3.140966	2.421476	3.650324	3.256717	2.942518	2.677785	2.240341	1.877141
1.1300	4.877937	3.699488	3.148137	2.428023	3.789259	3.387299	3.066517	2.796353	2.349054	1.976425
1.1400	4.897762	3.699484	3.155308	2.434570	3.928190	3.518020	3.189945	2.914888	2.457881	2.075710
1.1500	4.917587	3.699480	3.162479	2.441117	4.067121	3.648637	3.312840	3.032216	2.566934	2.175730
1.1600	4.937412	3.699476	3.169650	2.447664	4.206052	3.779248	3.435236	3.149562	2.675987	2.275339
1.1700	4.957237	3.699472	3.176821	2.454211	4.344983	3.909769	3.557164	3.266552	2.785040	2.374980
1.1800	4.977062	3.699468	3.183992	2.460758	4.483914	4.040280	3.679652	3.383203	2.894093	2.474650
1.1900	4.996887	3.699464	3.191163	2.467305	4.622845	4.171199	3.799724	3.499536	2.997774	2.574344
1.2000	5.016712	3.699460	3.198334	2.473852	4.761776	4.302110	3.920030	3.615550	3.105379	2.674061

TABLE A1 (CONTINUED)

α	0.99	0.975	0.95	0.90	0.85	γ	0.80	0.75	0.70	0.60	0.50
3.1000	8.574519	7.382939	6.44977	5.450843	4.854271	4.404393	4.040710	3.731314	3.212857	3.212857	2.773797
3.2000	8.741913	7.540188	6.593303	5.589691	4.984944	4.529312	4.160664	3.846789	3.320213	3.320213	2.873551
3.3000	8.908206	7.695479	6.740820	5.735901	5.115098	4.653811	4.280279	3.952007	3.427453	3.427453	2.973322
3.4000	9.073433	7.851864	6.887563	5.872497	5.244759	4.771799	4.399579	4.076978	3.54582	3.54582	3.073107
3.5000	9.237654	8.006381	7.033568	6.005518	5.373948	4.901625	4.519574	4.191715	3.641604	3.641604	3.172907
3.6000	9.400913	8.160075	7.178876	6.143985	5.502689	5.024977	4.637277	4.306229	3.748524	3.748524	3.272717
3.7000	9.563252	8.318978	7.323508	6.278921	5.631001	5.147980	4.755703	4.405330	3.855346	3.855346	3.372538
3.8000	9.724709	8.465125	7.467498	6.413355	5.758900	5.270650	4.873863	4.534621	3.962074	3.962074	3.472370
3.9000	9.885325	8.615545	7.610376	6.547301	5.886407	5.393001	4.991767	4.648519	4.068712	4.068712	3.572211
4.0000	10.045118	8.767274	7.753657	6.680783	6.013537	5.515046	5.109430	4.762229	4.175243	4.175243	3.672061
4.1000	10.204140	8.917333	7.895974	6.813819	6.143305	5.637796	5.226851	4.875757	4.281728	4.281728	3.771918
4.2000	10.362412	9.065751	8.037546	6.945426	6.266724	5.756266	5.344051	4.989110	4.388118	4.388118	3.871783
4.3000	10.519365	9.215550	8.178691	7.078618	6.392811	5.879458	5.461033	5.102295	4.494426	4.494426	3.971656
4.4000	10.674814	9.363754	8.319335	7.210415	6.518569	6.003392	5.577805	5.215319	4.600659	4.600659	4.071533
4.5000	10.828398	9.511386	8.459489	7.341828	6.644020	6.121073	5.694376	5.328186	4.706820	4.706820	4.171417
4.6000	10.979835	9.658461	8.599174	7.472874	6.769170	6.241509	5.810751	5.440905	4.812911	4.812911	4.271305
4.7000	11.129445	9.805005	8.738404	7.603558	6.894031	6.361711	5.926936	5.553474	4.918937	4.918937	4.371201
4.8000	11.277752	9.951026	8.877196	7.733902	7.018612	6.481687	6.043944	5.659004	5.024882	5.024882	4.471100
4.9000	11.425174	10.094550	9.015564	7.863905	7.142921	6.601438	6.158772	5.778199	5.130786	5.130786	4.571002
5.0000	11.570426	10.241591	9.153519	7.993589	7.266964	6.720979	6.274431	5.890363	5.236618	5.236618	4.670909
5.1000	11.714488	10.387569	9.291674	8.127505	7.383548	6.835710	6.385037	5.993336	5.343916	5.343916	4.770499
5.2000	11.857887	10.533032	9.426674	8.256674	7.494657	6.945993	6.492702	6.095551	5.449191	5.449191	4.869162
5.3000	11.999812	10.676804	9.560965	8.381988	7.600988	7.055993	6.591953	6.191786	5.549578	5.549578	4.967836
5.4000	12.140421	10.819236	9.693296	8.503272	7.703121	7.163384	6.684667	6.282661	5.649638	5.649638	5.066430
5.5000	12.279763	10.960025	9.824789	8.621356	7.800504	7.265329	6.774431	6.368611	5.749691	5.749691	5.164930
5.6000	12.417832	11.100115	9.951115	8.737915	7.898529	7.362544	6.864431	6.454431	5.849691	5.849691	5.263430
5.7000	12.554656	11.239357	10.073357	8.854646	7.994514	7.450728	6.949431	6.539431	5.939691	5.939691	5.361930
5.8000	12.690256	11.373192	10.193646	8.970712	8.089514	7.537274	7.034431	6.624431	6.029691	6.029691	5.460430
5.9000	12.824645	11.507176	10.307176	9.086192	8.184427	7.624427	7.119431	6.709431	6.119691	6.119691	5.558930
6.0000	12.957810	11.640213	10.420591	9.195991	8.278793	7.710752	7.204431	6.804431	6.209691	6.209691	5.657430
6.1000	13.089814	11.772822	10.533222	9.306642	8.371228	7.800727	7.289431	6.899431	6.304691	6.304691	5.755930
6.2000	13.220645	11.904521	10.645213	9.416233	8.463237	7.889431	7.374431	6.994431	6.404691	6.404691	5.854430
6.3000	13.350256	12.035213	10.756213	9.526233	8.554237	7.978431	7.459431	7.089431	6.504691	6.504691	5.952930
6.4000	13.478729	12.164845	10.866571	9.636571	8.644734	8.067311	7.544431	7.184431	6.604691	6.604691	6.051430
6.5000	13.606105	12.293398	10.978857	9.748964	8.734734	8.155734	7.629431	7.279431	6.704691	6.704691	6.149930
6.6000	13.732481	12.421845	11.091125	9.861281	8.824734	8.246237	7.714431	7.374431	6.804691	6.804691	6.248430
6.7000	13.857859	12.549233	11.203184	9.973580	8.914734	8.334734	7.804431	7.469431	6.904691	6.904691	6.346930
6.8000	13.982233	12.676571	11.315184	10.085845	9.004734	8.424734	7.894431	7.564431	7.004691	7.004691	6.445430
6.9000	14.106610	12.803933	11.427184	10.198125	9.094734	8.514734	7.984431	7.659431	7.104691	7.104691	6.543930
7.0000	14.230985	12.931281	11.539184	10.310404	9.184734	8.604734	8.074431	7.754431	7.204691	7.204691	6.642430
7.1000	14.355360	13.058624	11.650184	10.422681	9.274734	8.694734	8.164431	7.849431	7.304691	7.304691	6.740930
7.2000	14.479735	13.185966	11.761184	10.534959	9.364734	8.784734	8.254431	7.939431	7.404691	7.404691	6.839430
7.3000	14.604110	13.313308	11.872184	10.647233	9.454734	8.874734	8.344431	8.029431	7.504691	7.504691	6.937930
7.4000	14.728485	13.440645	11.983184	10.759510	9.544734	8.964734	8.434431	8.119431	7.604691	7.604691	7.036430
7.5000	14.852860	13.567981	12.094184	10.871787	9.634734	9.054734	8.524431	8.209431	7.704691	7.704691	7.134930
7.6000	14.977235	13.695318	12.205184	10.984064	9.724734	9.144734	8.614431	8.299431	7.804691	7.804691	7.233430
7.7000	15.101610	13.822655	12.316184	11.096341	9.814734	9.234734	8.704431	8.389431	7.904691	7.904691	7.331930
7.8000	15.225985	13.950000	12.427184	11.208618	9.904734	9.324734	8.794431	8.479431	8.004691	8.004691	7.430430
7.9000	15.350360	14.077335	12.538184	11.320895	10.004734	9.414734	8.884431	8.569431	8.104691	8.104691	7.528930
8.0000	15.474735	14.204671	12.649184	11.433172	10.104734	9.504734	8.974431	8.659431	8.204691	8.204691	7.627430
8.1000	15.599110	14.332008	12.760184	11.545449	10.204734	9.594734	9.064431	8.749431	8.304691	8.304691	7.725930
8.2000	15.723485	14.459345	12.871184	11.657726	10.304734	9.684734	9.154431	8.839431	8.404691	8.404691	7.824430
8.3000	15.847860	14.586681	12.982184	11.769999	10.404734	9.774734	9.244431	8.929431	8.504691	8.504691	7.922930
8.4000	15.972235	14.714018	13.093184	11.882276	10.504734	9.864734	9.334431	9.019431	8.604691	8.604691	8.021430
8.5000	16.096610	14.841355	13.204184	11.994553	10.604734	9.954734	9.424431	9.109431	8.704691	8.704691	8.119930
8.6000	16.220985	14.968691	13.315184	12.106830	10.704734	10.044734	9.514431	9.199431	8.804691	8.804691	8.218430
8.7000	16.345360	15.096026	13.426184	12.219107	10.804734	10.134734	9.604431	9.289431	8.904691	8.904691	8.316930
8.8000	16.469735	15.223363	13.537184	12.331384	10.904734	10.224734	9.694431	9.379431	9.004691	9.004691	8.415430
8.9000	16.594110	15.350700	13.648184	12.443661	11.004734	10.314734	9.784431	9.469431	9.104691	9.104691	8.513930
9.0000	16.718485	15.478037	13.759184	12.555938	11.104734	10.404734	9.874431	9.559431	9.204691	9.204691	8.612430
9.1000	16.842860	15.605374	13.870184	12.668215	11.204734	10.494734	9.964431	9.649431	9.304691	9.304691	8.710930
9.2000	16.967235	15.732711	13.981184	12.780492	11.304734	10.584734	10.054431	9.739431	9.404691	9.404691	8.809430
9.3000	17.091610	15.860048	14.092184	12.892769	11.404734	10.674734	10.144431	9.829431	9.504691	9.504691	8.907930
9.4000	17.215985	15.987385	14.203184	13.005046	11.504734	10.764734	10.234431	9.919431	9.604691	9.604691	9.006430
9.5000	17.340360	16.114722	14.314184	13.117323	11.604734	10.854734	10.324431	10.009431	9.704691	9.704691	9.104930
9.6000	17.464735	16.242059	14.425184	13.229600	11.704734	10.944734	10.414431	10.099431	9.804691	9.804691	9.203430
9.7000	17.589110	16.369396	14.536184	13.341877	11.804734	11.034734	10.504431	10.189431	9.904691	9.904691	9.301930
9.8000	17.713485	16.496733	14.647184	13.454154	11.904734	11.124734	10.594431	10.279431	10.004691	10.004691	9.400430
9.9000	17.837860	16.624070	14.758184	13.566431	12.004734	11.214734	10.684431	10.369431	10.104691	10.104691	9.498930
10.0000	17.962235	16.751407	14.869184	13.678708	12.104734	11.304734	10.774431	10.459431	10.204691	10.204691	9.597430
10.1000	18.086610	16.878744	14.980184	13.790985	12.204734	11.394734	10.864431	10.549431	10.304691	10.304691	9.695930
10.2000	18.210985	16.999981	15.091184	13.903262	12.304734	11.484734	10.954431	10.639431	10.404691	10.404691	9.794430
10.3000	18.335360	17.121218	15.202184	14.015539	12.404734	11.574734	11.044431	10.729431	10.504691	10.504691	9.892930
10.4000	18.459735	17.242455	15.313184	14.127816	12.504734	11.664734	11.134431	10.819431	10.604691	10.604691	9.991430
10.5000	18.584110	17.363692	15.424184	14.240093	12.604734	11.754734	11.224431	10.909431	10.704691	10.704	

TABLE A1 (CONTINUED)

a	y									
	0.99	.975	0.95	0.90	0.85	0.80	0.75	0.70	0.60	0.50
31.0000	45.400776	42.826876	40.690505	38.315117	35.764887	35.562657	34.552154	33.661009	32.090473	30.467311
32.0000	46.608444	44.002030	41.837637	39.429823	37.857699	36.638052	35.612575	34.707970	33.113172	31.667291
33.0000	47.812869	45.174458	42.982466	40.542744	38.949060	37.712247	36.672057	35.754229	34.135515	32.667272
34.0000	49.014226	46.344288	44.125085	41.653939	40.039020	38.785329	37.730619	36.799770	35.157496	33.667258
35.0000	50.212588	47.511599	45.265616	42.763521	41.127677	39.857326	38.788329	37.844639	36.179174	34.667230
36.0000	51.408187	48.676511	46.404120	43.871508	42.215054	40.928296	39.845226	38.888883	37.200535	35.667222
37.0000	52.601029	49.839183	47.540735	44.978029	43.301215	41.998286	40.901293	39.932480	38.221599	36.667205
38.0000	53.791297	50.999632	48.675488	46.083084	44.386209	43.067307	41.956629	40.975497	39.242375	37.667198
39.0000	54.979045	52.157977	49.808471	47.186744	45.470082	44.135427	43.011231	42.017964	40.262888	38.667178
40.0000	56.164393	53.314291	50.939746	48.289090	46.552879	45.202675	44.065116	43.059856	41.283126	39.667166
41.0000	57.347484	54.468656	52.069372	49.396155	47.634639	46.269059	45.118356	44.101228	42.303114	40.667153
42.0000	58.528289	55.621137	53.197424	50.490013	48.715385	47.334670	46.170926	45.142096	43.322840	41.667142
43.0000	59.706962	56.771796	54.323951	51.588637	49.795186	48.399482	47.222881	46.182505	44.342367	42.667131
44.0000	60.883584	57.920722	55.449005	52.686107	50.874063	49.483514	48.274212	47.222420	45.361649	43.667121
45.0000	62.058173	59.067953	56.572638	53.782505	51.952057	50.526864	49.324967	48.251888	46.380712	44.667110
46.0000	63.230868	60.213551	57.694899	54.877815	53.029132	51.589485	50.375165	49.300905	47.399561	45.667100
47.0000	64.401640	61.357533	58.815428	55.972092	54.105397	52.651420	51.424800	50.339508	48.418206	46.667091
48.0000	65.570640	62.500050	59.935454	57.065355	55.180848	53.712694	52.473897	51.377691	49.436650	47.667082
49.0000	66.737841	63.641014	61.053858	58.157640	56.255501	54.773339	53.522507	52.415459	50.454918	48.667073
50.0000	67.903375	64.786609	62.171059	59.249005	57.329410	55.833358	54.570622	53.452881	51.472973	49.667065

TABLE A2. Gamma Reference Scale Values b_0 for Selected Values of Shape Parameter (a) and Prior Assurance (P_0)

a/P_0	0.95	0.90	0.80
0.01	3.5227E-155	4.4655E-125	5.6607E-95
0.02	4.5019E-75	5.0687E-60	5.7068E-45
0.03	2.2797E-48	2.4673E-38	2.6702E-28
0.04	5.1503E-35	1.7282E-27	5.7988E-20
0.05	5.3157E-27	5.5739E-21	5.8446E-15
0.06	1.1726E-21	1.2199E-16	1.2691E-11
0.07	7.7079E-18	1.5394E-13	3.0746E-09
0.08	5.6375E-15	3.2656E-11	1.8916E-07
0.09	9.5383E-13	2.1098E-09	4.6669E-06
0.10	5.7917E-11	5.9307E-08	6.0730E-05
0.11	1.6690E-09	9.1013E-07	4.9629E-04
0.12	2.7502E-08	8.8704E-06	2.8611E-03
0.13	2.9479E-07	6.0971E-05	1.2611E-02
0.14	2.2538E-06	3.1852E-04	4.5014E-02
0.15	1.3150E-05	1.3360E-03	1.3573E-01
0.16	6.1598E-05	4.6882E-03	3.5682E-01
0.17	2.4079E-04	1.4204E-02	8.3786E-01
0.18	8.0955E-04	3.8074E-02	1.7907E+00
0.19	2.3972E-03	9.2062E-02	3.5355E+00
0.20	6.3725E-03	2.0392E-01	6.5255E+00
0.21	1.5443E-02	4.1900E-01	1.1368E+01
0.22	3.4551E-02	8.0682E-01	1.8841E+01
0.23	7.2112E-02	1.4684E+00	2.9900E+01
0.24	1.4163E-01	2.5435E+00	4.5682E+01
0.25	2.6366E-01	4.2186E+00	6.7501E+01
0.26	4.6815E-01	6.7327E+00	9.6835E+01
0.27	7.9697E-01	1.0384E+01	1.3531E+02
0.28	1.3067E+00	1.5534E+01	1.8469E+02
0.29	2.0715E+00	2.2611E+01	2.4685E+02
0.30	3.1857E+00	3.2110E+01	3.2372E+02
0.31	4.7668E+00	4.4597E+01	4.1734E+02
0.32	6.9577E+00	6.0702E+01	5.2976E+02
0.33	9.9288E+00	8.1121E+01	6.6303E+02
0.34	1.3880E+01	1.0661E+02	8.1924E+02
0.35	1.9041E+01	1.3798E+02	1.0004E+03
0.36	2.5675E+01	1.7610E+02	1.2036E+03
0.37	3.4074E+01	2.2186E+02	1.4457E+03
0.38	4.4566E+01	2.7622E+02	1.7135E+03
0.39	5.7506E+01	3.4015E+02	2.0140E+03
0.40	7.3283E+01	4.1465E+02	2.3489E+03
0.41	9.2314E+01	5.0074E+02	2.7197E+03
0.42	1.1504E+02	5.9945E+02	3.1280E+03
0.43	1.4194E+02	7.1180E+02	3.5752E+03
0.44	1.7351E+02	8.3884E+02	4.0627E+03
0.45	2.1026E+02	9.8160E+02	4.5917E+03
0.46	2.5272E+02	1.1411E+03	5.1633E+03
0.47	3.0146E+02	1.3183E+03	5.7786E+03
0.48	3.5703E+02	1.5142E+03	6.4365E+03
0.49	4.2003E+02	1.7298E+03	7.1438E+03
0.50	4.9103E+02	1.9661E+03	7.8954E+03
0.51	5.7065E+02	2.2238E+03	8.6938E+03
0.52	6.5947E+02	2.5039E+03	9.5397E+03
0.53	7.5810E+02	2.8073E+03	1.0434E+04
0.54	8.6715E+02	3.1347E+03	1.1376E+04
0.55	9.8723E+02	3.4869E+03	1.2367E+04
0.56	1.1189E+03	3.8647E+03	1.3407E+04
0.57	1.2628E+03	4.2688E+03	1.4496E+04
0.58	1.4196E+03	4.6997E+03	1.5635E+04
0.59	1.5897E+03	5.1582E+03	1.6823E+04
0.60	1.7737E+03	5.6448E+03	1.8060E+04

Table A2 (Continued)

a/p_0	0.95	0.90	0.80
0.61	1.9723E+03	6.1602E+03	1.9348E+04
0.62	2.1859E+03	6.7047E+03	2.0685E+04
0.63	2.4152E+03	7.2789E+03	2.2071E+04
0.64	2.6605E+03	7.8833E+03	2.3506E+04
0.65	2.9225E+03	8.5182E+03	2.4991E+04
0.66	3.2016E+03	9.1840E+03	2.6525E+04
0.67	3.4982E+03	9.8811E+03	2.8108E+04
0.68	3.8130E+03	1.0610E+04	2.9739E+04
0.69	4.1462E+03	1.1370E+04	3.1418E+04
0.70	4.4983E+03	1.2163E+04	3.3145E+04
0.71	4.8698E+03	1.2988E+04	3.4921E+04
0.72	5.2610E+03	1.3846E+04	3.6743E+04
0.73	5.6722E+03	1.4737E+04	3.8612E+04
0.74	6.1040E+03	1.5660E+04	4.0528E+04
0.75	6.5565E+03	1.6616E+04	4.2491E+04
0.76	7.0302E+03	1.7606E+04	4.4499E+04
0.77	7.5253E+03	1.8629E+04	4.6552E+04
0.78	8.0421E+03	1.9685E+04	4.8651E+04
0.79	8.5809E+03	2.0775E+04	5.0794E+04
0.80	9.1420E+03	2.1898E+04	5.2932E+04
0.81	9.7256E+03	2.3054E+04	5.5213E+04
0.82	1.0332E+04	2.4244E+04	5.7488E+04
0.83	1.0961E+04	2.5467E+04	5.9806E+04
0.84	1.1614E+04	2.6723E+04	6.2166E+04
0.85	1.2289E+04	2.8013E+04	6.4569E+04
0.86	1.2989E+04	2.9336E+04	6.7013E+04
0.87	1.3712E+04	3.0692E+04	6.9498E+04
0.88	1.4459E+04	3.2082E+04	7.2024E+04
0.89	1.5229E+04	3.3504E+04	7.4590E+04
0.90	1.6024E+04	3.4959E+04	7.7197E+04
0.91	1.6843E+04	3.6448E+04	7.9842E+04
0.92	1.7687E+04	3.7968E+04	8.2527E+04
0.93	1.8555E+04	3.9522E+04	8.5251E+04
0.94	1.9447E+04	4.1107E+04	8.8012E+04
0.95	2.0364E+04	4.2725E+04	9.0812E+04
0.96	2.1305E+04	4.4375E+04	9.3649E+04
0.97	2.2271E+04	4.6057E+04	9.6522E+04
0.98	2.3262E+04	4.7771E+04	9.9432E+04
0.99	2.4278E+04	4.9516E+04	1.0238E+05
1.00	2.5318E+04	5.1293E+04	1.0536E+05
1.05	3.0891E+04	6.0643E+04	1.2079E+05
1.10	3.7082E+04	7.0752E+04	1.3705E+05
1.15	4.3888E+04	8.1594E+04	1.5410E+05
1.20	5.1301E+04	9.3145E+04	1.7190E+05
1.25	5.9311E+04	1.0538E+05	1.9039E+05
1.30	6.7908E+04	1.1827E+05	2.0956E+05
1.35	7.7079E+04	1.3179E+05	2.2935E+05
1.40	8.6810E+04	1.4593E+05	2.4974E+05
1.45	9.7087E+04	1.6064E+05	2.7069E+05
1.50	1.0790E+05	1.7592E+05	2.9219E+05
1.55	1.1923E+05	1.9174E+05	3.1419E+05
1.60	1.3106E+05	2.0808E+05	3.3669E+05
1.65	1.4338E+05	2.2492E+05	3.5965E+05
1.70	1.5618E+05	2.4225E+05	3.8306E+05
1.75	1.6944E+05	2.6003E+05	4.0689E+05
1.80	1.8314E+05	2.7827E+05	4.3113E+05
1.85	1.9729E+05	2.9693E+05	4.5575E+05
1.90	2.1186E+05	3.1601E+05	4.8075E+05
1.95	2.2683E+05	3.3549E+05	5.0611E+05
2.00	2.4221E+05	3.5536E+05	5.3181E+05

Table A2 (Continued)

a/p_0	0.95	0.90	0.80
2.05	2.5797E+05	3.7560E+05	5.5784E+05
2.10	2.7411E+05	3.9621E+05	5.8419E+05
2.15	2.9062E+05	4.1716E+05	6.1085E+05
2.20	3.0748E+05	4.3845E+05	6.3780E+05
2.25	3.2469E+05	4.6007E+05	6.6504E+05
2.30	3.4224E+05	4.8201E+05	6.9255E+05
2.35	3.6011E+05	5.0425E+05	7.2032E+05
2.40	3.7830E+05	5.2679E+05	7.4835E+05
2.45	3.9680E+05	5.4963E+05	7.7663E+05
2.50	4.1561E+05	5.7274E+05	8.0515E+05
2.55	4.3470E+05	5.9612E+05	8.3391E+05
2.60	4.5409E+05	6.1977E+05	8.6288E+05
2.65	4.7375E+05	6.4368E+05	8.9208E+05
2.70	4.9369E+05	6.6784E+05	9.2149E+05
2.75	5.1389E+05	6.9224E+05	9.5110E+05
2.80	5.3435E+05	7.1688E+05	9.8092E+05
2.85	5.5507E+05	7.4175E+05	1.0109E+06
2.90	5.7603E+05	7.6685E+05	1.0411E+06
2.95	5.9723E+05	7.9216E+05	1.0715E+06
3.00	6.1867E+05	8.1769E+05	1.1021E+06
3.05	6.4034E+05	8.4343E+05	1.1328E+06
3.10	6.6224E+05	8.6937E+05	1.1637E+06
3.15	6.8435E+05	8.9551E+05	1.1948E+06
3.20	7.0668E+05	9.2184E+05	1.2260E+06
3.25	7.2922E+05	9.4837E+05	1.2574E+06
3.30	7.5197E+05	9.7507E+05	1.2889E+06
3.35	7.7492E+05	1.0020E+06	1.3206E+06
3.40	7.9807E+05	1.0290E+06	1.3525E+06
3.45	8.2141E+05	1.0563E+06	1.3844E+06
3.50	8.4493E+05	1.0837E+06	1.4166E+06
3.55	8.6865E+05	1.1112E+06	1.4488E+06
3.60	8.9255E+05	1.1390E+06	1.4812E+06
3.65	9.1662E+05	1.1669E+06	1.5137E+06
3.70	9.4087E+05	1.1949E+06	1.5464E+06
3.75	9.6529E+05	1.2231E+06	1.5791E+06
3.80	9.8988E+05	1.2515E+06	1.6120E+06
3.85	1.0146E+06	1.2800E+06	1.6450E+06
3.90	1.0396E+06	1.3086E+06	1.6782E+06
3.95	1.0646E+06	1.3374E+06	1.7114E+06
4.00	1.0899E+06	1.3663E+06	1.7448E+06
4.05	1.1153E+06	1.3954E+06	1.7782E+06
4.10	1.1408E+06	1.4246E+06	1.8118E+06
4.15	1.1665E+06	1.4539E+06	1.8455E+06
4.20	1.1923E+06	1.4833E+06	1.8793E+06
4.25	1.2183E+06	1.5129E+06	1.9132E+06
4.30	1.2444E+06	1.5426E+06	1.9472E+06
4.35	1.2706E+06	1.5724E+06	1.9812E+06
4.40	1.2970E+06	1.6023E+06	2.0154E+06
4.45	1.3235E+06	1.6324E+06	2.0497E+06
4.50	1.3502E+06	1.6626E+06	2.0841E+06
4.55	1.3770E+06	1.6928E+06	2.1185E+06
4.60	1.4039E+06	1.7232E+06	2.1531E+06
4.65	1.4309E+06	1.7537E+06	2.1877E+06
4.70	1.4581E+06	1.7843E+06	2.2225E+06
4.75	1.4853E+06	1.8150E+06	2.2573E+06
4.80	1.5127E+06	1.8459E+06	2.2922E+06
4.85	1.5403E+06	1.8768E+06	2.3272E+06
4.90	1.5679E+06	1.9078E+06	2.3622E+06
4.95	1.5956E+06	1.9389E+06	2.3974E+06
5.00	1.6235E+06	1.9701E+06	2.4326E+06

Table A2 (Continued)

a/p_0	0.95	0.90	0.80
5.05	1.6515E+06	2.0015E+06	2.4679E+06
5.10	1.6795E+06	2.0329E+06	2.5033E+06
5.15	1.7077E+06	2.0644E+06	2.5387E+06
5.20	1.7360E+06	2.0960E+06	2.5742E+06
5.25	1.7644E+06	2.1277E+06	2.6098E+06
5.30	1.7929E+06	2.1594E+06	2.6455E+06
5.35	1.8215E+06	2.1913E+06	2.6813E+06
5.40	1.8502E+06	2.2232E+06	2.7171E+06
5.45	1.8790E+06	2.2553E+06	2.7529E+06
5.50	1.9079E+06	2.2874E+06	2.7889E+06
5.55	1.9369E+06	2.3196E+06	2.8249E+06
5.60	1.9659E+06	2.3519E+06	2.8610E+06
5.65	1.9951E+06	2.3843E+06	2.8971E+06
5.70	2.0244E+06	2.4167E+06	2.9333E+06
5.75	2.0538E+06	2.4492E+06	2.9696E+06
5.80	2.0832E+06	2.4818E+06	3.0060E+06
5.85	2.1128E+06	2.5145E+06	3.0423E+06
5.90	2.1424E+06	2.5473E+06	3.0788E+06
5.95	2.1721E+06	2.5801E+06	3.1153E+06
6.00	2.2019E+06	2.6130E+06	3.1519E+06
6.05	2.2318E+06	2.6460E+06	3.1885E+06
6.10	2.2617E+06	2.6790E+06	3.2252E+06
6.15	2.2918E+06	2.7122E+06	3.2620E+06
6.20	2.3219E+06	2.7454E+06	3.2988E+06
6.25	2.3521E+06	2.7786E+06	3.3356E+06
6.30	2.3824E+06	2.8119E+06	3.3726E+06
6.35	2.4128E+06	2.8453E+06	3.4095E+06
6.40	2.4433E+06	2.8788E+06	3.4465E+06
6.45	2.4738E+06	2.9123E+06	3.4836E+06
6.50	2.5044E+06	2.9459E+06	3.5208E+06
6.55	2.5351E+06	2.9796E+06	3.5579E+06
6.60	2.5658E+06	3.0133E+06	3.5952E+06
6.65	2.5966E+06	3.0471E+06	3.6324E+06
6.70	2.6275E+06	3.0810E+06	3.6698E+06
6.75	2.6585E+06	3.1149E+06	3.7072E+06
6.80	2.6895E+06	3.1488E+06	3.7446E+06
6.85	2.7206E+06	3.1829E+06	3.7821E+06
6.90	2.7518E+06	3.2170E+06	3.8196E+06
6.95	2.7831E+06	3.2511E+06	3.8572E+06
7.00	2.8144E+06	3.2853E+06	3.8948E+06
7.05	2.8457E+06	3.3196E+06	3.9324E+06
7.10	2.8772E+06	3.3539E+06	3.9701E+06
7.15	2.9087E+06	3.3883E+06	4.0079E+06
7.20	2.9403E+06	3.4227E+06	4.0457E+06
7.25	2.9719E+06	3.4572E+06	4.0835E+06
7.30	3.0036E+06	3.4918E+06	4.1214E+06
7.35	3.0354E+06	3.5264E+06	4.1593E+06
7.40	3.0672E+06	3.5610E+06	4.1973E+06
7.45	3.0991E+06	3.5957E+06	4.2353E+06
7.50	3.1311E+06	3.6305E+06	4.2734E+06
7.55	3.1631E+06	3.6653E+06	4.3115E+06
7.60	3.1952E+06	3.7001E+06	4.3496E+06
7.65	3.2273E+06	3.7351E+06	4.3878E+06
7.70	3.2595E+06	3.7700E+06	4.4260E+06
7.75	3.2917E+06	3.8050E+06	4.4643E+06
7.80	3.3240E+06	3.8401E+06	4.5026E+06
7.85	3.3564E+06	3.8752E+06	4.5409E+06
7.90	3.3888E+06	3.9104E+06	4.5793E+06
7.95	3.4213E+06	3.9456E+06	4.6177E+06
8.00	3.4538E+06	3.9808E+06	4.6561E+06

Table A2 (Continued)

a/p_0	0.95	0.90	0.80
8.05	3.4864E+06	4.0161E+06	4.6946E+06
8.10	3.5191E+06	4.0515E+06	4.7331E+06
8.15	3.5518E+06	4.0869E+06	4.7717E+06
8.20	3.5845E+06	4.1223E+06	4.8103E+06
8.25	3.6173E+06	4.1578E+06	4.8489E+06
8.30	3.6502E+06	4.1933E+06	4.8876E+06
8.35	3.6831E+06	4.2289E+06	4.9263E+06
8.40	3.7160E+06	4.2645E+06	4.9650E+06
8.45	3.7490E+06	4.3002E+06	5.0038E+06
8.50	3.7821E+06	4.3359E+06	5.0426E+06
8.55	3.8152E+06	4.3716E+06	5.0814E+06
8.60	3.8484E+06	4.4074E+06	5.1203E+06
8.65	3.8816E+06	4.4433E+06	5.1592E+06
8.70	3.9148E+06	4.4791E+06	5.1982E+06
8.75	3.9481E+06	4.5150E+06	5.2371E+06
8.80	3.9815E+06	4.5510E+06	5.2761E+06
8.85	4.0149E+06	4.5870E+06	5.3152E+06
8.90	4.0483E+06	4.6230E+06	5.3542E+06
8.95	4.0818E+06	4.6591E+06	5.3933E+06
9.00	4.1154E+06	4.6952E+06	5.4325E+06
9.05	4.1490E+06	4.7314E+06	5.4716E+06
9.10	4.1826E+06	4.7676E+06	5.5108E+06
9.15	4.2163E+06	4.8038E+06	5.5500E+06
9.20	4.2500E+06	4.8401E+06	5.5893E+06
9.25	4.2838E+06	4.8764E+06	5.6286E+06
9.30	4.3176E+06	4.9127E+06	5.6679E+06
9.35	4.3514E+06	4.9491E+06	5.7072E+06
9.40	4.3853E+06	4.9856E+06	5.7466E+06
9.45	4.4193E+06	5.0220E+06	5.7860E+06
9.50	4.4533E+06	5.0585E+06	5.8255E+06
9.55	4.4873E+06	5.0950E+06	5.8649E+06
9.60	4.5214E+06	5.1315E+06	5.9044E+06
9.65	4.5555E+06	5.1682E+06	5.9439E+06
9.70	4.5896E+06	5.2048E+06	5.9835E+06
9.75	4.6238E+06	5.2415E+06	6.0230E+06
9.80	4.6580E+06	5.2782E+06	6.0626E+06
9.85	4.6923E+06	5.3150E+06	6.1023E+06
9.90	4.7266E+06	5.3518E+06	6.1419E+06
9.95	4.7610E+06	5.3886E+06	6.1816E+06
10.00	4.7954E+06	5.4254E+06	6.2213E+06

APPENDIX B. A Procedure for Selecting a Gamma Prior Distribution

It is required to find a and b which satisfies

$$\int_{LL}^{UL} \frac{b^a}{\Gamma(a)} x^{a-1} e^{-bx} dx = p_0, \quad (B1)$$

where

$$\int_0^{LL} \frac{b^a}{\Gamma(a)} x^{a-1} e^{-bx} dx = \int_{UL}^{\infty} \frac{b^a}{\Gamma(a)} x^{a-1} e^{-bx} dx = (1-p_0)/2.$$

Letting $y = x/LL$ in (B1), we have

$$\int_1^{UL/LL} \frac{(bLL)^a}{\Gamma(a)} y^{a-1} e^{-(bLL)y} dy = p_0. \quad (B2)$$

Since b is a scale parameter, set $bLL=1$, and solve (B2) for the shape parameter a . Thus a depends only upon the value of UL/LL , or equivalently, $\log(UL/LL)$. Once a has been numerically determined, we can solve (B2) for a temporary value of b , say b_0 , corresponding to a temporary lower limit of, say, $1.0 \times 10^{-6} \text{ f/h}$. Since b is a scale parameter, we know that

$$bLL = b_0 (1.0 \times 10^{-6})$$

from which

$$b = b_0 (1.0 \times 10^{-6} \text{ f/h}) / LL.$$

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

The BAZE approach is used to obtain sample test plans
for selected components of nuclear reactor safety systems.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER LA- 6813-MS	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) A Bayesian Zero-Failure (BAZE) Reliability Demonstration Testing Procedure for Components of Nuclear Reactor Safety Systems		5. TYPE OF REPORT & PERIOD COVERED Technical Report
7. AUTHOR(s) H.F. Martz, Jr. and R.A. Waller		6. PERFORMING ORG. REPORT NUMBER
9. PERFORMING ORGANIZATION NAME AND ADDRESS Department of Industrial Engineering Texas Tech University Lubbock, TX 79409		8. CONTRACT OR GRANT NUMBER(s) N00014-75-C-0832
11. CONTROLLING OFFICE NAME AND ADDRESS Office of Naval Research Statistics and Probability Program; Code 436 Arlington, VA 22217		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS (NR 042-320)
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE March 31, 1977
		13. NUMBER OF PAGES 83
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Bayesian analysis Nuclear Reactor Demonstration Testing Safety Analysis Reliability Component Testing Prior Distribution		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) A Bayesian-Zero-Failure (BAZE) reliability demonstration testing procedure is presented. The method is developed for an exponential failure-time model and a gamma prior distribution on the failure-rate. A simple graphical approach using percentiles is used to fit the prior distribution. The procedure is given in an easily applied step-by-step form which does not require the use of a computer for its implementation.		

DD FORM 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

The BAZE approach is used to obtain sample test plans
for selected components of nuclear reactor safety systems.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)