MASTER

H. E. Khalifa

Brown University

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any legal warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

The heat rejection temperature in a vapor power cycle is determined primarily by the temperature of the available cooling medium. The cooling medium, be it water or air, exists at ambient temperatures that exhibit pronounced seasonal variations. The thermal efficiency of a power cycle improves with a lower heat rejection temperature and vice versa. It can be shown by simple thermodynamic arguments that the thermal efficiency is more sensitive to changes in the heat rejection temperature than it is to equal changes in the heat addition temperature. It is also known that the effect of a certain change in the heat rejection temperature on cycle efficiency is greater for lower heat addition temperatures. This indicates that the effect of seasonal fluctuations in the heat rejection temperature on the performance of low temperature power cycles, such as those applied

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

in the utilization of geothermal energy, will be considerably more significant than it is in large fossil fuel steam power plants. In the first case maximum temperatures of only 150-250°C are expected whereas in the latter maximum temperatures as high as 600°C have been applied.

In this report, we analyze the effect of seasonal fluctuations in ambient temperatures on the performance of low-temperature power cycles, particularly those of the binary fluid variety suggested for the utilization of geothermal energy. The analysis is carried out in two stages; in the first stage, the ideal case is considered. In this case we study, in an analytical manner, the influence of sinusoidal variations of the heat rejection temperature on the ideal work available from a steady flow of a geothermal brine delivered to the power plant under constant wellhead conditions. Such an ideal case helps to clarify the general trends as well as to establish the relative significance of the significant operating factors. In the second stage we introduce an approximate method for analyzing the actual cases. The performance of the actual cycle at the design point is determined from that of the corresponding ideal cycle through the introduction of a utilization efficiency. The incremental change in the output due to a change in the sink temperature is obtained by treating the constant temperature heat rejection process in the actual cycle as a perturbation superimposed on that at the design point. The approximations include an assumption of a constant temperature difference in the low temperature end of the primary heat exchanger, an implicit assumption of a near-isentropic expansion in the last stage of the turbine and an assumption of a straight liquid saturation line on the T-s diagram.

a) Ideal case

Consider a geofluid at T_b (constant) fed to the heat exchanger of a binary-fluid system and reinjected at T_r . Assume also that the sink temperature is a known function of time given by

$$T_o = T_o(t) . \quad (1)$$

The maximum ideal work that can be obtained from this geofluid is given by (see Fig. 1)

$$W^o(t) = h_b - h_o(t) - T_o(t) (s_b - s_o) . \quad (2)$$

For an incompressible fluid with a constant specific heat, this becomes

$$W^o(t) = c \left\{ T_b - T_o(t) - T_o(t) \ln [T_b/T_o(t)] \right\} . \quad (3)$$

The heat exchanger has to be designed with a finite temperature difference for economic reasons. In view of this limitation, we introduce a new definition of the maximum work

$$\bar{W}^o(t) = c \left\{ T_b - T_r(t) - T_o(t) \ln [T_b/T_r(t)] \right\} . \quad (4)$$

The nature of the dependence of T_r on time is determined by the design of the heat exchanger as well as by $T_o(t)$ itself. Assuming that the heat exchanger receives the same amount of brine, $\dot{m}_b$, regardless of the time of the year, we may write that

$$\dot{m}_b c_b (T_b - T_r) = \dot{m} c (T_f - T_o) , \quad (5)$$

and that

$$\dot{m}_b c_b (T_b - T_r) = AU(T_r - T_o) , \quad (6)$$

where U is the overall heat transfer coefficient and A is the surface area of the heat exchanger. Solving eqn. (6) for T_r we obtain

$$T_r(t) = [AU T_o(t) + \dot{m}_b c_b T_b] / (AU + \dot{m}_b c_b) . \quad (7)$$

Assuming that $T_{ro} - T_{oo} = \delta$ at the datum point, we have

$$AU = \dot{m}_b c_b \left[T_b - \delta - T_{oo} \right] / \delta . \quad (8)$$

Therefore,

$$T_r(t) = \left\{ T_b \delta + \left[T_b - \delta - T_{oo} \right] T_o(t) \right\} / \left(T_b - T_{oo} \right) . \quad (9)$$

If this is substituted into equation (4) we obtain the dependence of $\bar{W}^o(t)$ on t . The time-averaged maximum work output $\bar{W}_a^o$ can be obtained by

$$\bar{W}_a^o = \frac{1}{\tau} \int_0^\tau \bar{W}^o(t) dt , \quad (10)$$

where τ is the duration of an ambient temperature cycle (i.e. one year).

We define the seasonal work fluctuation factor σ as

$$\sigma_o^+ = \bar{W}_{\max}^o / \bar{W}_o^o , \quad (11)$$

and

$$\sigma_o^- = \bar{W}_{\min}^o / \bar{W}_o^o , \quad (12)$$

where $\bar{W}_o^o$ is the ideal work at the datum point (T_{oo}).

Example:

Sinusoidal temperature variation:

$$T_o(t) = T_{oo} + \theta \cos (2\pi t / \tau) . \quad (13)$$

$$\bar{W}_a^o = \frac{c}{\tau} \left\{ T_b \tau - I_1 - I_2 \right\} , \quad (14)$$

where

$$I_1 = \int_0^\tau T_r(t) dt = (\delta + T_{oo}) \tau,$$

or

$$I_1 = \tau T_{ro} . \quad (15)$$

On the other hand

$$I_2 = \int_0^\tau dt T_o(t) \ln T_b - \int_0^\tau dt T_o(t) \ln T_r(t),$$

that is

$$I_2 = \tau T_{oo} \ln T_b - I, \quad (16)$$

where

$$\begin{aligned} I &= \int_0^\tau T_o(t) \ln T_r(t) dt \\ &= \int_0^\tau T_{oo} \ln T_r(t) dt + \int_0^\tau \theta \cos \frac{2\pi t}{\tau} \ln T_r(t) dt . \end{aligned} \quad (17)$$

Writing eqn. (9) in the short-hand notation

$$T_r(t) = \alpha + \beta \cos 2\pi t/\tau \quad (9a)$$

and substituting into (17), the first term on the RHS reduces to

$$T_{oo} \tau \ln \left[\left(\alpha + \sqrt{\alpha^2 - \beta^2} \right) / 2 \right] , \quad (18)$$

where

$$\alpha \equiv T_{ro} \quad (19)$$

and

$$\beta \equiv \left[\theta \left(T_b - T_{ro} \right) / \left(T_b - T_{oo} \right) \right] < \alpha . \quad (20)$$

The second integral on the RHS of eqn. (17) reduces to

$$\theta \tau \left[\alpha - \sqrt{\alpha^2 - \beta^2} \right] / \beta . \quad (21)$$

Combining (18) and (21) we obtain

$$I = \tau \left\{ T_{oo} \ln \left[\frac{\alpha + \sqrt{\alpha^2 - \beta^2}}{2} \right] + \theta \left[\frac{\alpha - \sqrt{\alpha^2 - \beta^2}}{\beta} \right] \right\} . \quad (22)$$

Thus I_2 is given by

$$I_2 = \tau \left\{ T_{oo} \ln \left[2T_b / \left(\alpha + \sqrt{\alpha^2 - \beta^2} \right) \right] - \theta \left[\alpha - \sqrt{\alpha^2 - \beta^2} \right] / \beta \right\} . \quad (23)$$

The season-averaged available work is thus given by

$$\bar{W}_a^o = c \left\{ T_b - T_{ro} - T_{oo} \ln \left[2T_b / \left(\alpha + \sqrt{\alpha^2 - \beta^2} \right) \right] + \theta \left[\alpha - \sqrt{\alpha^2 - \beta^2} \right] / \beta \right\} . \quad (24)$$

It should be noted that for $T_o(t)$ equal to a constant, that is for $\theta \equiv 0$, the quantity β vanishes identically and the season-averaged available work will reduce to

$$\bar{W}_a^o = c \left\{ T_b - T_{ro} - T_{oo} \ln \left(T_b / T_{ro} \right) \right\} , \quad (25)$$

that is to

$$\bar{W}_a^o = \bar{W}_o^o \text{ at } \theta = 0$$

as expected. We define the season-averaged work correction factor, $\bar{\gamma}$, as

$$\bar{\gamma} = \bar{W}_a^o / \bar{W}_o^o \quad (26)$$

Substituting from the eqns. (24) and (25) we obtain

$$\bar{\gamma} = 1 + c \left\{ \theta \frac{\alpha}{\beta} \left[1 - \sqrt{1 - \beta^2 / \alpha^2} \right] + T_{oo} \ln \left[\left(1 + \sqrt{1 - \beta^2 / \alpha^2} \right) / 2 \right] \right\} / \bar{W}_o^o \quad (27)$$

An interesting case is the ideal case in which δ is zero, that is $T_r = T_o$.

In this case the quantity β reduces to θ and

$$\bar{\gamma}^o = 1 + c T_{oo} \left\{ \left[1 - \sqrt{1 - \theta^2 / T_{oo}^2} \right] + \ln \left[\left(1 + \sqrt{1 - \theta^2 / T_{oo}^2} \right) / 2 \right] \right\} / \bar{W}_o^o \quad (28)$$

with

$$\bar{W}_o^o = c \left\{ T_b - T_{oo} - T_{oo} \ln T_b / T_{oo} \right\} \quad (28a)$$

Figure 2 presents the dependence of $\bar{\gamma}$ on θ with T_b as a parameter for $T_{oo} = 298.15K$ (25°C). Our calculations show that the factor $\bar{\gamma}$ is almost independent of δ ; changing the value of δ from 0°C to 20°C produces a negligible change in γ . It can be seen that even for a seasonal change in the sink temperature of $\pm 25^\circ C$ the time-averaged ideal work does not differ from the work output at the design point ($\bar{W}_o^o$) by more than 2.6% when the brine temperature, T_b , is only 150°C. For $T_b = 250^\circ C$ this difference amounts to less than 1%. The work loss associated with an increase in the sink temperature is more than compensated by the work gain associated with an equal decrease in the sink temperature. This results in values of γ that are always greater than unity.

Figure 3 shows a chronogram of the sink temperature $T_o(t)$ and the normalized ideal work

$$\gamma(t) = \bar{W}^o(t) / \bar{W}_o^o \quad \text{for } \theta = 20^\circ C.$$

The seasonal work fluctuation factors $\sigma_o^{+,-}$ defined by eqns. (11, 12) can be obtained from eqn. (4) by finding the minimum and the maximum of this equation. Obviously, the work will be minimum where the sink temperature is maximum and vice versa; namely

$$\bar{W}_{\max}^o = c \left\{ T_b - T_{ro} + \beta - (T_{oo} - \theta) \ln \left[T_b / (T_{ro} - \beta) \right] \right\}, \quad (29)$$

and

$$\bar{W}_{\min}^o = c \left\{ T_b - T_{ro} - \beta - (T_{oo} + \theta) \ln \left[T_b / (T_{ro} + \beta) \right] \right\}. \quad (30)$$

The total work fluctuation factor $\sigma_o = \sigma_o^+ + \sigma_o^-$ is given by

$$\sigma_o = \frac{2\beta + 2\theta \ln T_b + \ln \left[\frac{(T_{oo} - \theta)}{(T_{ro} - \beta)} / \frac{(T_{oo} + \theta)}{(T_{ro} + \beta)} \right]}{T_b - T_{ro} - T_{oo} \ln T_b / T_{ro}}. \quad (31)$$

Figure 4 shows a plot of σ_o^+ and σ_o^- as a function of θ for $T_b = 150, 200$ and 250°C . In all cases T_{oo} was taken as 298.15K (25°C) and δ as 10°C . The area between σ_o^+ and σ_o^- indicates the total range of output fluctuation. The lower curve (σ_o^-) can be thought of as a measure of the firm output of the plant. It can be seen that for a brine temperature of 200°C and a sink temperature fluctuation of $\pm 15^\circ\text{C}$, the firm output is only 82% of the reference output. Under the same conditions the maximum output amounts to nearly 1.2 times the reference output.

b. Approximate analysis of actual systems:

In an actual system, the entropy production in the various components results in a lower work output for the same amount of heat added. Put differently, the amount of heat rejected at the sink temperature is higher in an actual system than in an ideal one receiving the same amount of heat.

This means that a change in the sink temperature will have a more pronounced effect on an actual system than it has on an ideal system. Introducing the utilization efficiency η_u , we write

$$W_o = \eta_u \bar{W}_o^o \quad (32)$$

at the datum point. The heat rejected at the datum point is given by

$$Q_{Ro} = Q_{Ao} - \eta_u \bar{W}_o^o = \bar{W}_o^o (1 - \eta_u) + \bar{Q}_{Ro}^o, \quad (33)$$

where Q_{Ao} designates the heat added and $\bar{Q}_{Ro}^o$ is the amount of heat rejected by the ideal system at the datum point. A perturbation in the sink temperature results in different values of $\bar{W}_o^o$, $\bar{Q}_{Ro}^o$ and η_u as would be expected. Examination of eqns. (6, 9a) reveals that the fluctuations in the temperature difference in the heat exchanger are about one order of magnitude smaller than the fluctuations in the sink temperature. This is expressed by

$$\left[T_r(t) - T_o(t) \right] / \delta = 1 - \theta \cos (2\pi t / \tau) / (T_b - T_{oo}) . \quad (34)$$

Again, owing to the near constancy of AU we obtain

$$\frac{Q_A}{Q_{Ao}} \approx 1 - \theta \cos (2\pi t / \tau) / (T_b - T_{oo}) . \quad (35)$$

On the other hand, the amount of work gained (or lost) because of a decrease (or an increase) in the sink temperature is represented by the shaded area on the T-s diagram of Fig. 5. This area is given approximately by

$$\Delta W \approx \left[T_{oo} - T_o(t) \right] \Delta S_o + C_W \left\{ T_{oo} - T_o(t) - T_o(t) \ln \left[T_{oo} / T_o(t) \right] \right\}^{\#} , \quad (36)$$

[#]The approximation stems from the inherent assumption of constant specific heat which is justified in the low temperature range. It is also assumed that the liquid saturation line is straight.

where ΔS_o represents the total drop in the entropy of the working fluid upon condensation at the datum point and C_w is the water equivalent of the working fluid. The quantity ΔS_o can be computed from

$$T_{oo} \Delta S_o = Q_{Ro} = Q_{Ao} - \eta_u \bar{W}_o^o = \bar{W}_o^o (1 - \eta_u) + \bar{Q}_{Ro}^o, \quad (37)$$

in which we made use of eqn. (33). The utilization efficiency η_u at the datum point can be calculated after optimizing the cycle parameters.

The work fluctuation factor $\gamma(t)$ is given by

$$\gamma(t) = 1 + \Delta W / W_o, \quad (38)$$

which can be expressed in terms of T_b , $T_r(t)$, $T_o(t)$, C_w/c and η_u by means of eqns. (36-38). This yields

$$\begin{aligned} \gamma(t) = 1 + & \left[\frac{T_{oo} - T_o(t)}{T_{oo}} \right] \left\{ \left[\frac{T_b - T_{ro}}{T_{oo}} \right] (1 - \eta_u) + \eta_u \frac{T_o(t)}{T_{oo}} \ln \left[\frac{T_b}{T_{ro}} \right] \right\} / T_{oo} \\ & + \left\{ T_{oo} - T_o(t) - T_o(t) \ln \left[\frac{T_{oo}}{T_o(t)} \right] \right\} / \left[\eta_u \left\{ T_b - T_{ro} - T_{oo} \ln \left(\frac{T_b}{T_{ro}} \right) \right\} \right]. \quad (39) \end{aligned}$$

In this equation we assumed that the temperature difference is nearly constant in the low temperature end of the heat exchanger, consequently C_w/c could be taken as unity. It is worth mentioning that, upon putting $\eta_u = 1$ and $T_{ro} = T_{oo}$, eqn. (39) reproduces the values computed from eqn. (3) to within 1%. The maximum and minimum values of γ ; $\sigma^{+,-}$ are plotted as a function of θ in Fig. 6 for the case $\eta_u = 0.6$ and $T_b = 200^\circ\text{C}$. The corresponding ideal curve from Fig. 4 is also reproduced for comparison. It can be seen that in the actual cycle, sink temperature fluctuations can produce up to twice the work fluctuations in the ideal case, the effect being more pronounced in the work loss at higher sink temperatures than in the work gain at the lower sink temperatures. For the example cited, a

temperature fluctuation of $\pm 15^{\circ}\text{C}$ produces an 18% work loss in the ideal case and more than a 31% work loss in the actual case. A drop in the sink temperature of 15°C , however, results in a gain of about 20% and 33% in the ideal and actual cases, respectively. It can also be noticed that the positive amplitude of the work fluctuations is not much different from the negative one. This should lead to a near cancellation of the effect of the seasonal temperature fluctuations as was shown analytically for the ideal case.

c. Choice of the design point

So far, we have expressed the various fluctuation parameters as non-dimensional quantities normalized with respect to the output of the cycle at a datum point. This datum point was chosen as the average sink temperature, T_{oo} , for convenience. Naturally, this datum cannot be chosen as the design point if a dependable output is to be guaranteed owing to the considerable loss of output effected by an increase in the sink temperature above the datum. For power plants employing cooling towers, it is customary to design the plant for a wet-bulb temperature that is not exceeded more 5% of the time during the summer (June-September)*. This will have the effect of placing the design output very close to the firm (dependable) output previously defined. For the sinusoidal variation in sink temperature considered in this report, the design sink temperature T_{od} nearly coincides with the maximum sink temperature $T_{oo} + \theta$ owing to the flatness of the cosine curve at its extrema. If we normalize the various quantities with respect to the design output W_d^o rather than the

*See Marks': Standard Handbook for Mechanical Engineers, 7th ed. pp. 9-94.

datum value W_0^0 we obtain values of $\gamma(t)$, $\bar{\gamma}$ and σ_0^{+0} that are modified by a multiplicative factor

$$\lambda = 1/\sigma_0^- \quad (40)$$

This modification results in a much more pronounced effect of the sink temperature fluctuations. For example, at $T_b = 200^\circ\text{C}$ and $\theta = 15^\circ\text{C}$, the work correction factor of Fig. 2 will increase from 1.005 to 1.218; that is an average output that is 21% higher than the design output. The maximum work for the same case will be 45% higher than the design work (the firm output). The Chronograph of Fig. 3 will show a unidirectional fluctuations of the output with respect to the design work, i.e. $\gamma(t)$ will always be greater than unity. For the actual system analyzed in an approximate manner in the report, the maximum work at $\theta = 15^\circ\text{C}$ will be about 94% higher than the design work. The average output over one year will exceed the design output by as much as 46% at the same value of θ . Figure 7 depicts the dependence of σ_d^+ on θ . It is noted that due to the choice of the normalization factor, W_d^0 , σ_d^- is unity for all values of θ .

d. Conclusions

The simple analysis of the previous sections indicates that sink temperature fluctuations has a drastic effect on the output of low-temperature power cycles. The severe fluctuations in the output are likely to have a strong influence on the design and optimization studies of such cycles. The impact of this on the economies of electric power generation from geothermal resources should be carefully assessed before choosing among possible energy-conversion systems.

Figure 1

Figure 2

Figure 3

Figure 4

Figure 5

Figure 6

Figure 7