Process Energy Reliability Requirements for Selected Industries

William G. Sullivan
Thomas M. West

MASTER

OAK RIDGE NATIONAL LABORATORY

OPERATED BY UNION CARBIDE CORPORATION FOR THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road, Springfield, Virginia 22161
Price: Printed Copy \$4.50; Microfiche \$2.25

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Energy Research and Development Administration/United States Nuclear Regulatory Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Contract No. W-7405-eng-26

Engineering Technology Division

PROCESS ENERGY RELIABILITY REQUIREMENTS
FOR SELECTED INDUSTRIES

William G. Sullivan
Thomas M. West

Date Published: September 1976

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

84

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

CONTENTS

	<u>Page</u>
ACKNOWLEDGMENTS	iv
ABSTRACT	1
INTRODUCTION	1
SOURCES AND COSTS OF INDUSTRIAL PROCESS ENERGY	4
STUDY RESULTS FOR THE CHEMICAL INDUSTRY	8
STUDY RESULTS FOR PETROLEUM REFINERIES	23
STUDY RESULTS FOR PRIMARY METALS INDUSTRIES	32
CONCLUSIONS OF THE STUDY	39
REFERENCES	41
APPENDIX A	43

ACKNOWLEDGMENTS

The authors wish to thank Otto H. Klepper of the Engineering Technology Division for his thoughtful suggestions regarding the preparation of this report. We would also like to acknowledge the industrial contributors that provided our data and checked the manuscript for its accuracy.

PROCESS ENERGY RELIABILITY REQUIREMENTS FOR SELECTED INDUSTRIES

William G. Sullivan*

Thomas M. West**

ABSTRACT

The purpose of this study was to obtain estimates of process energy reliability experience for selected plants in these industries: chemicals and allied products, petroleum refining and primary metals. Twenty-nine responses to the mail-out questionnaire were returned, and data for 1973-74 were analyzed with respect to steam generator characteristics, types of fuels used, amounts of electrical energy purchased or sold, and reliabilities of the steam-supply system. Reliability referred to the percentage of clock time that sufficient amounts of steam energy were available to permit desired production quotas to be met at a particular plant. For the 17 chemical industries, study results showed that reliabilities ranged from 100 to 89%, and the average value was 98%. The nine petroleum refineries experienced an average steam-supply system reliability of 92%, with individual refinery reliabilities ranging from 100 to 70%. Finally, there were only three primary metals companies represented in the study, and their process energy reliabilities were 100%.

INTRODUCTION

Industry consumes a large share of the total primary energy used in the United States. Natural gas and oil, the major industrial fuels, are becoming scarce and expensive. Therefore, there is a critical national need to develop alternative sources of industrial energy based on the more plentiful domestic fuels — coal and nuclear. An important aspect of any alternative industrial energy system is the reliability required during long-term operation, such that the expected service continuity would meet industrial needs.

The aim of this study was to quantify the reliability requirements of process energy systems in selected energy-intensive industries. This was accomplished by developing a questionnaire (see Appendix A) and sending

*University of Tennessee, Knoxville, Tennessee.

**Presently located at Oregon State University, Corvallis, Oregon.

it to 65 companies in the following major industries: chemicals and allied products (S.I.C.28), petroleum refining and related industries (S.I.C.29), and primary metals industries (S.I.C.33). A detailed analysis of 29 responses to the questionnaire was performed and is reported in subsequent sections.

The combined energy consumption of these three industries accounts for approximately 50% of total industrial energy usage.¹ Because roughly 40% of all energy in the United States is consumed each year by industrial processes, the chemical, petroleum refining, and primary metals industries represent 20% of this nation's total energy requirements.²

Analysis of questionnaire responses was focused on quantifying the reliability of process steam systems in these three industries since classification of primary end-uses of fuels in industry indicates that a major fraction of industrial fuel is used to raise process steam. From Table 1 it can be seen that 67% of all fuels consumed by the chemical industry are used to generate steam, while for the petroleum and primary metals industries the percentages are 36 and 21 respectively. Petroleum products represent over one half of industrial fuels; thus, substitution of alternative energy sources could save appreciable quantities of rapidly diminishing supplies of oil and natural gas.

For purposes of this study, reliability is defined to be the fraction of scheduled production time at a company that the production facility is in an "up" condition. This condition exists when the available capacity of the steam supply system equals or exceeds process energy requirements at the planned production level (i.e., "desired production level") that has been established independent of energy availability.

Reliability, as defined above, is a term that reflects the "consumer's" viewpoint in a corporate energy supply-demand relationship. From the "producer's" viewpoint (i.e., the power and steam generation group), the term availability is used to represent the percent of clock time in a continuous operation that individual boilers and/or reactors produce steam. Thus when reliability requirements of a company can be met or exceeded by the overall availability of its energy system, scheduled production levels are unaffected, and the facility is in an "up" condition.

Table 1. Fuel distribution to combustion process (1971 data)

Industry/fuel	Steam generation		Process heater or furnace (%)	Other (%)	Total energy $\text{kJ} \times 10^{12}/\text{year}$ ($\text{Btu} \times 10^{12}/\text{year}$)
	Under 1379 kPa (200 psia) (%)	Over 1379 kPa (200 psia) (%)			
Chemicals:					
All fuels	7	60	15	18	2279 (2160)
Oil and gas only	8	64	7	21	1720 (1630)
Petroleum:					
All fuels	1	35	57	7	2870 (2720)
Oil and gas only	1	38	53	8	1488 (1410)
Primary metals:					
All fuels	-	21	3	76	3661 (3470)
Oil and gas only	-	35	6	59	1403 (1330)

Source: Evaluation of New Energy Sources for Process Heat, Final Report of
N.S.F. Grant No. OEP 74-18055, Prepared by the Dow Chemical Company
(Midland, Michigan), September 1975, p. 39.

It is believed that realistic industrial energy reliability requirements can be derived from industry operating experience that is acquired in the present survey. A follow-on study will then utilize these reliability estimates in determining feasible combinations of nuclear and/or nuclear-fossil systems capable of meeting current reliability levels in the three industries being considered.

SOURCES AND COSTS OF INDUSTRIAL PROCESS ENERGY

In the past, high steam supply availability has been relatively easy to obtain through the installation of multiple gas- and/or oil-fired boilers. Such installations were relatively inexpensive because the cost of providing high availability through excess capacity was considerably less than the cost of curtailed production resulting from insufficient steam. However, with increasing economies of scale, larger boiler installations and uncertainties concerning the availability of gas and oil, costs of providing high availability steam through the use of multiple (and redundant) boilers is becoming a point of concern.

Some idea of the economic attractiveness of nuclear-fueled steam generators can be obtained when their steam costs are compared with those of conventional fossil processes. A generalized comparison of costs shows that current coal-fired systems provide steam in the neighborhood of \$1.61 to \$1.94 per million kilojoules (\$1.53 to \$1.84 per million Btu).³ Steam production with residual oil as fuel (at a conservative \$57/m³, or \$9/bbl) costs approximately \$2.37 per million kilojoules (\$2.25 per million Btu) based on standard assumptions concerning industrial financing, plant life, taxes, etc.⁴ These costs of generating steam can be compared with those for various nuclear units shown in Table 2. While these data are based on 1974 economic parameters, they still provide a valid basis for purposes of comparison. For each of these basic types of nuclear steam generators, representative operating characteristics are summarized in Table 3. In view of current projections concerning price escalations of fossil fuels, the economics of nuclear steam generators have tended to become more favorable relative to conventional systems. In this regard, estimates of future fuel costs are shown in Fig. 1.

Table 2. Estimated cost of process steam from different size nuclear units (1974 cost basis)

	CNSG (Small PWR)	PWR		HTGR	
Unit size, MW(t)	313	1875	3750	1000	3140
Capital cost					
Millions of dollars	63	174	268	148	287
Dollars/kW(t)	201	93	72	148	91
Levelized steam production cost,* cents/million kJ (cents/million Btu)					
Fixed charges	199(189)	91(86)	70(66)	146(138)	90(85)
O&M costs	24(23)	6(6)	4(4)	13(12)	5(5)
Fuel costs	<u>57(54)</u>	<u>38(36)</u>	<u>36(34)</u>	<u>49(46)</u>	<u>42(40)</u>
Subtotal	281(266)	135(128)	110(104)	207(196)	137(130)
Isolation loop	5(5)	5(5)	5(5)	5(5)	5(5)
Transportation	<u>37(35)</u>	<u>37(35)</u>	<u>37(35)</u>	<u>37(35)</u>	<u>37(35)</u>
TOTAL	323(306)	177(168)	152(144)	249(236)	179(170)

*Based on 80% plant factor and industrial ownership with a fixed charge rate of 22.2%.

Source: D. B. Trauger, L. L. Bennett, and H. I. Bowers, "Nuclear Reactor Process Heat Capabilities, Potential and Economics," Proceedings of the First National Topical Meeting on Nuclear Process Heat Applications, Los Alamos, New Mexico, October 1974, p. 27.

Table 3. Representative operating characteristics
of typical reactors

	CNSG	PWR	BWR	HTGR*
Vendors	Babcock & Wilcox	Westinghouse	General Electric	General Atomic
Reactor output, MW(t)	313	3817	3833	4000
Steam production, kg/s lb/hr	157.5 1.25×10^6	2129.4 16.9×10^6	2079.0 16.5×10^6	1348.2 10.7×10^6
Steam pressure, kPa psia	4826.5 700	7584.5 1100	6791.6 985	17,340.9 2515
Steam temperature, °C °F	287 548	293 559	284 543	513 955

*Proposed.

Source: E. L. Cox, "Design and Operation of Nuclear Power Plants for Process Heat Application," Proceedings of the First National Topical Meeting on Nuclear Process Heat Applications, Los Alamos, New Mexico, October 1974, p. 90.

ORNL-DWG 76-10576

Source: An Analysis of Current Trends in Nuclear and Fossil Powered Generation Costs. Merrill J. Whitman, Energy Research and Development Administration, Washington, D. C. (June 1975).

Fig. 1. Average annual cost of fuels burned for electrical generation in the United States 1952-1984 (constant 1975 dollars).

STUDY RESULTS FOR THE CHEMICAL INDUSTRY

A large percentage of responses to the questionnaire (17 out of 29, or 59%) came from the chemical industry. These 17 plants represented a total steam consumption of 1741 kg/s (13.819×10^6 lb/hr), or an equivalent of 127.71×10^{12} kJ/year (121.05×10^{12} Btu/year).^{*} By utilizing 1971 data as a basis of comparison, it is possible to determine the extent to which the 17 plants in the survey represent total chemical industry steam consumption:⁵

Total average hourly steam consumption by the 17 plants = 1741 kg/s
(13.819×10^6 lb/hr).

Total average kJ equivalent = (1741 kg/s) $\times$ (3.1536×10^7 s/year)
 $\times$ (2326.23 kJ/kg) = 127.71×10^{12} kJ/year

[or ($13.819 \times 10^6 \frac{\text{lb}}{\text{hr}}$) $\times$ 8760 $\frac{\text{hr}}{\text{year}}$ $\times$ 1000 $\frac{\text{Btu}}{\text{hr}}$ = $121.05 \times 10^{12} \frac{\text{Btu}}{\text{year}}$].

Estimated industry-wide equivalent fuel consumption for steam production in 1971 (see Table 1 and ref. 5) is 75% of all fuel energy:

$0.75 (2279 \times 10^{12} \text{ kJ/year}) = 1709 \times 10^{12} \text{ kJ/year}$ [$1620 \times 10^{12} \text{ Btu/year}$].

Sample size, or representativeness, of the 17 plants in the survey =

$$\frac{127.71 \times 10^{12}}{1709 \times 10^{12}} (100) \approx 7.5\%.$$

Respondents to the questionnaire were requested to provide data from plants that consumed large amounts of process steam. For this reason the 17 chemical plants represent approximately 7.5% of total industry steam production, which is believed to be a "good" sample for purposes of this study. While a comparison of 1973 to 1974 sample data with 1971 industry-wide data does not provide a highly accurate measure of how well the 17 plants represent the chemical industry, it does, nevertheless, give a rough indication of the "cross-section" of steam production and consumption patterns reported here.

* A conservative conversion factor of 2326.23 kJ/kg (1000 Btu/lb of steam) was used because of considerable variation in steam temperatures and pressures.

Energy consumption data for the 17 plants are shown in Table 4. Because this study is centered on various aspects of industrial steam requirements, chemical plants have been numbered in order of decreasing total steam production in Table 4. This identification number is used throughout this section to ensure the anonymity of the respondent. From Table 4 it can be seen that the 17 plants produced steam in amounts ranging from a high of 424.6 kg/s to a low of 8.2 kg/s (3,370,000 to 65,000 lb of steam/hr). The average steam consumption at a "typical" plant was 102.4 kg/s (812,880 lb/hr).

The second column of Table 4 indicates the total rate of energy consumption, including purchased electrical energy and/or steam energy. To maintain a single basis of comparison throughout the study, electrical energy expressed in kilowatts (kW) was converted to a rate of steam flow by this relationship:

$$1 \text{ kW} = 0.000428 \text{ kg/s} \quad (1 \text{ kW} = 3.4 \text{ lb of steam/hr and} \\ 294 \text{ kW} \approx 1000 \text{ lb of steam/hr}) .$$

Total consumption of steam, in pounds per hour, is given in the third column of Table 4. (See footnote at bottom of Table 4 to convert pounds of steam per hour to kg/s.) Numbers of this column include steam produced at a central boiler station, at waste heat recovery boilers and by exothermic reactors. It is interesting to note that even though most of the chemical plants in the sample are relatively large in terms of their steam consumption, a sizable fraction of their steam-supply systems is located at one central boiler station. This is apparent from the fourth column of Table 4. In fact, only four chemical plants have more than 15% of their steam requirements provided from noncentralized facilities. As seen in the last column of this table, steam used for process heat applications accounts for at least half of all steam consumption at 10 of the 17 plants.

A general summary of the types of fuel utilized and boiler capacities at each plant is provided in Table 5. The number of coal-burning boilers, for example, at plant 9 is seven, and their combined nameplate capacity (shown in parentheses) is 140 kg/s (1,117,000 lb of steam per hour). Total breakout of fuel by type for the 17 plants, according to nameplate capacities, is: natural gas, 30.4%; coal, 38.5%; oil, 20.7%, and other, 10.4%. The "other" category includes process heat recovery units, and larger chemical plants tend to produce appreciable amounts of steam by this means.

Table 4. Energy production and consumption data for seventeen chemical plants in the survey
(Most data for the period, July 1, 1973-June 30, 1974)

Plant	Total energy consumption rate (electrical, steam and other) in equivalent steam flow, lb/hr	Total steam production rate, lb/hr	Steam energy con- sumption as a percent of total energy consumption	Steam energy generated at central plant as percent of total steam energy	Steam energy for direct process heat as percent of total steam energy
1	3.370×10^6 (40 kW purchased, 93,000 kW self-generated)	3.37×10^6	100.0	99.2	86.5
2	2.089×10^6 (55,555 kW purchased, 0 kW self-generated)	1.90×10^6	90.1	73.4	50.0
3	1.412×10^6 (24,000 kW purchased, 0 kW self-generated)	1.33×10^6	94.2	30.0	22.6
4	2.203×10^6 (39,040 kW purchased, 0 kW self-generated)	1.17×10^6	53.1	80.3	96.6
5	1.525×10^6 (64,600 kW purchased, 0 kW self-generated)	1.16×10^6	76.1	89.2	31.0
6	1.009×10^6 (14,000 kW purchased, 0 kW self-generated)	9.61×10^5	95.2	97.9	18.7
7	1.009×10^5 (5000 kW purchased, 25,500 kW self-generated)	5.17×10^5	90.9	100.0	86.0
8	1.291×10^5 (7700 kW purchased, 0 kW self-generated)	5.65×10^5	43.8	58.4	0.0
9	7.892×10^5 (2700 kW purchased, 14,000 kW self-generated)	5.50×10^5	67.7	100.0	83.0
10	5.610×10^5 (12,000 kW purchased, 10,500 kW self-generated)	5.20×10^5	92.7	100.0	Not available
11	9.043×10^5 (79,500 kW purchased, 21,100 kW self-generated)	4.80×10^5	53.1	100.0	22.9
12	4.020×10^5 (30,000 kW purchased, 0 kW self-generated)	2.7×10^5	67.2	100.0	88.9
13	2.237×10^5 (14,300 kW purchased, 0 kW self-generated)	1.75×10^5	78.2	91.4	68.6
14	1.749×10^5 (2630 kW purchased, 2700 kW self-generated)	1.6×10^5	94.9	100.0	60.2
15	1.642×10^5 (13,000 kW purchased, 0 kW self-generated)	1.2×10^5	73.1	100.0	62.5
16	1.114×10^5 (3350 kW purchased, 0 kW self-generated)	1.0×10^5	89.8	100.0	15.0
17	1.373×10^5 (21,250 kW purchased, 0 kW self-generated)	6.5×10^4	47.3	100.0	67.7

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

Table 5. Summary of numbers of boilers and their associated nameplate capacities
(10^3 lb of steam/hr) for seventeen chemical plants in the survey

Plant and location	Primary fuel source			
	Natural gas	Coal	Oil	Other
1 (Southeast)	-	19 (4360)	-	-
2 (Gulf Coast)	5 (1790)	-	-	5 (650)
3 (Northeast)	-	-	3 (800)	-
4 (Southeast)	-	-	5 (940)	23 (835)
5 (Gulf Coast)	7 (1700)	-	-	1 (400)
6 (Gulf Coast)	5 (1200)	-	-	1 (20)
7 (Northeast)	-	7 (1117)	1 (100)	-
8 (Gulf Coast)	3 (690)	-	-	-
9 (Northeast)	1 (50)	7 (660)	3 (300)	-
10 (Northeast)	-	4 (805)	-	-
11 (Northeast)	-	-	3 (525)	-
12 (Northeast)	-	-	4 (360)	-
13 (Northeast)	-	-	2 (200)	1 (20)
14 (Northeast)	-	1 (65)*	3 (320)	-
15 (Northeast)	-	1 (45)*	4 (300)	-
16 (Midwest)	1 (72)	2 (120)	-	1 (15)
17 (Northeast)	3 (144)	-	-	-
TOTAL	Numbers 25 (5646)	41 (7172)	28 (3845)	32 (1940)
	Percentages 19.8 (30.4)	32.6 (38.5)	22.2 (20.7)	25.4 (10.4)

*These boilers were on standby and not used during the survey period.

NOTE: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

When these results are compared with those of a nationwide study conducted by the Stanford Research Institute (SRI),⁶ it is discovered that there are appreciable differences in fuel consumption patterns:

	SRI study (1971) ⁷ (%)	Present survey (1975) (%)
Natural gas	68	30.4
Coal and coke	22	38.5
Oil	10	20.7
Other	-	10.4

While these differences are possibly due to sampling error, they are most likely caused by the fact that 12 of the 17 plants are located in the Northeast and Southeast (see Table 5) and therefore have relatively easy access to Appalachian coal sources. Furthermore, differences may be partly due to recent federal efforts at limiting the use of natural gas and imported fuel oil.

Summaries of detailed steam boiler data are given in Tables 6 and 7. Of the steam-generation units included in the survey, a significant number of them appear to be likely candidates for replacement in the near future. Over 60% of the units have been in use for at least 10 years, and more than 40% have been in use for over 20 years. However, further analysis reveals that most of the larger boilers (i.e., at least 31.5 kg/s or 250,000 lb of steam per hour) operating at temperatures and pressures in excess of 288°C (550°F) and 4137 kPa (600 psig) have been in service for 10 years or less. These data support the general observation made earlier that many companies believe that for a given level of steam requirement the economic advantages obtained through installation of larger steam-generating systems outweigh the higher reliability obtained through utilization of many smaller boilers with equivalent capacity. While a study of forced outage rate as a function of unit size was not included as part of this survey, the interested reader can find additional information in publication number 75-50 of the Edison Electric Institute.⁸

The prospects of using light water reactors (LWRs) to replace existing steam supply systems at chemical plants included in this survey appear good.

Table 6. Boiler pressure breakouts for seventeen chemical plants in survey

Capacity (10 ³ lb of steam/hr)	Under 250	Pressure, psig 251-600		601-1000	Over 1000	Totals
Under 100	1 (1 yr)	1 (3 yr)	3 (14 yr)	2 (35 yr)		27 (21.1 yr)
	1 (28 yr)	8 (34 yr)		5 (- yr)		
	3 (14 yr)	2 (11 yr)		1 (14 yr)		5 (- yr)
	1 (8 yr)	2 (30 yr)				
	2 (4 yr)					
100-250			1 (37 yr)			
	1 (23 yr)	1 (3 yr)	4 (35 yr)	4 (38 yr)	2 (23 yr)	
	1 (18 yr)	1 (17 yr)	5 (8 yr)	2 (34 yr)	5 (7 yr)	45 (20.0 yr)
	1 (12 yr)	2 (24 yr)	2 (22 yr)	1 (30 yr)	4 (1 yr)	
		2 (5 yr)	2 (47 yr)	3 (27 yr)	1 (-yr)	1 (-yr)
251-500		1 (10 yr)		2 (14 yr)	4 (-yr)	3 (14 yr)
		1 (15 yr)		5 (6 yr)	1 (11 yr)	1 (5 yr)
				3 (9 yr)		
Over 500				1 (7 yr)		1 (7 yr)
TOTALS	11 (12.7 yr)	38 (22.6 yr)		36 (16.8 yr) 10 (- yr)	4 (11.8 yr)	89 (18.5 yr) 10 (- yr)

Note 1: Average age of boilers in parentheses, where (-) indicates that data were not available.

Note 2: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s and multiply pressure in lb/in.² by 6.895 to get kPa.

Table 7. Boiler temperature breakouts for seventeen chemical plants in survey

Capacity (10 ³ lb of steam/hr)	Temperature (°F)					
	Under 400	401-550	551-700			Over 700
Under 100	1 (1 yr)	4 (35 yr)	1 (3 yr)	1 (14 yr)		3 (33 yr)
	1 (28 yr)	3 (14 yr)	2 (11 yr)	1 (8 yr)		2 (35 yr)
	3 (14 yr)		2 (30 yr)	2 (4 yr)		1 (- yr)
100 - 250	1 (23 yr)	3 (6 yr)	2 (1 yr)	2 (34 yr)	3 (35 yr)	2 (24 yr)
	1 (18 yr)	1 (17 yr)	1 (3 yr)	1 (30 yr)	2 (8 yr)	9 (- yr)
	1 (12 yr)	2 (35 yr)	2 (5 yr)	3 (27 yr)	2 (22 yr)	5 (8 yr)
		2 (47 yr)	4 (38 yr)	2 (23 yr)	1 (37 yr)	2 (1 yr)
251 - 500						5 (14 yr)
			1 (10 yr)			5 (6 yr)
			1 (15 yr)			3 (9 yr)
						1 (5 yr)
Over 500						1 (7 yr)
Total	8 (15.5 yr)	15 (25.4 yr)	36 (20.4 yr)			40 (10.2 yr)

14

Note 1: Average age of boilers in parentheses, where (-) indicates that data were not available.

Note 2: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s and determine temperature in degrees Celsius as follows, $t_C = (t_F - 32) \div 1.8$.

This statement is based on the findings of a Dow Chemical Company study⁹ of five major industries representing 75% of the total industrial steam consumption in the United States: Paper (S.I.C.26), Chemicals (S.I.C.28), Petroleum (S.I.C.29), Rubber (S.I.C.30), and Primary Metals (S.I.C.33).

In the Dow report this conclusion was drawn relative to steam temperature requirements for industrial processes:

"Process steam applications within the industries studied involve temperatures from about 100°F up to about 450°F. Although steam is often produced at temperatures above 450°F, the high temperature/high pressure steam is first used for electrical power generation and then extracted at lower pressures for process heat. Also, much of the steam use in the 450°F temperature range is in turbines or reciprocating engines, driving pumps, compressors, etc. These applications can and often will be converted to electrical drive as steam costs increase. Thus, we estimate that at least 85% of the industrial steam heat requirement is below 400°F and within the range available from conventional nuclear light water reactors."

A means of producing process steam in quantities that match the needs of several of the larger chemical plants listed in Table 4 is with the Consolidated Nuclear Steam Generator (CNSG). The CNSG is a special-purpose pressurized water reactor rated at 313 MW(t) that has been developed by the Babcock and Wilcox Company. Major reactor parameters of interest were shown earlier in Table 3.

Many of the chemical plants use steam in a number of sequential steps, each of which removes a portion of the thermal energy available. As noted above in the Dow study, the first step in some of these operations is frequently the generation of electrical power. This could also be accomplished by utilizing lower-pressure turbines as is done in commercial LWR power stations. Additionally, if high temperature steam is required for a limited number of applications, a fossil or by-product fueled superheat boiler could be included as part of the CNSG steam-generation system.

From Table 4 it can be seen that six of the 17 chemical plants generate a large fraction of their electrical power requirements. This may partially explain the preponderance of high boiler temperatures shown in Table 7 and the difference between results of the present study and the Dow statement above.

The most important information from questionnaire responses concerned the overall reliability of steam-supply systems at the 17 chemical plants.

In view of the definition of reliability given earlier (page 2), an analysis was made of safety margins (on-line steam-generating capacity less actual steam production) and percent of clock time that each plant was unable to meet scheduled steam production. Information regarding these two indicators of reliability was taken directly from questionnaire responses.

Results of analyzing data in Sections 1 and 2 of the questionnaire are presented in Table 8. Safety margins at each plant were determined by subtracting line D of Table 8 from line B. A more realistic evaluation of the safety margin is (B-E), but in most responses to the questionnaire no distinction was made between lines D and E.

Interesting characteristics of the safety margin are calculated in lines H and J of Table 8. Line H indicates that margins of safety, expressed as percentages of actual steam usage, are on the average about 44%. They range from 4.2 to 141.0%. From line J it can be seen that safety margins as a percentage of the largest on-line steam-generator range from 11.4 to 140.0%. Eleven out of 17 plants had safety margins that were 80% or more of the largest on-line unit. This indicates that high reliability has been sought at the expense of having considerable amounts of excess capacity available.*

The "unreliabilities" of steam-supply systems were computed in two parts: (1) as a percent of clock time that the system was unable to meet scheduled steam production because of equipment outages, and (2) as a percent of clock time that scheduled steam production was curtailed due to nonequipment related outages (planned and unplanned). As can be seen from line N of Table 8, the overall reliability of steam-supply systems (one minus the unreliability shown in line N) ranges from 100 to 89%. Notice that downtime caused by vacation and/or turnaround is excluded from the unreliability in line N.

To highlight pertinent information regarding unreliabilities of steam-supply systems now in operation, a summary of Table 8 has been prepared

* Plant No. 11 has a small safety margin and a highly reliable steam-supply system because a sizable fraction of its capacity is operated in parallel with a nearby electrical utility company. This arrangement works to the advantage of both companies.

Table 8. Process steam system capacity, consumption rate and reliability for chemical plants in the survey

Item of data	Plant											
	1	2	3*	4	5	6	7	8	9	10	11	12
A. Average installed capacity, 10 ³ lb of steam/hr	4360	2440	800	1595	1700	1200	1220	690	780	805	525	360
B. Average on-line capacity, 10 ³ lb of steam/hr	3700	2320	758	1450	1475	1190	1155	659	670	764	500	330
C. Average on-line capacity, as percentage of A.	84.8	95.1	94.8	91.0	86.8	99.2	94.7	95.5	85.9	94.9	95.2	91.7
D. Average actual steam usage, 10 ³ lb of steam/hr	3300	1900	390	1170	1160	960	917	565	550	520	480	270
E. Average scheduled steam usage, 10 ³ lb/hr	3300	1900	400	1203	1230	960	917	580	600	530	480	280
F. Average actual steam usage, as percentage of B	89.2	81.9	51.5	80.7	78.6	80.7	79.4	85.7	82.1	68.1	96.0	84.8
G. Average safety margin, Item B - Item D	400	420	368	280	315	230	238	94	120	244	20	50
H. Average safety margin, as percentage of D	12.1	22.1	94.4	23.9	27.2	24.0	25.9	16.6	21.8	46.9	4.2	18.5
I. Largest unit on-line (i) 10 ³ lb of steam/hr (ii) avg. percentage of B	430 11.6	400 17.2	400 52.8	200 13.8	550 37.3	250 21.0	267 23.1	230 34.9	125 18.7	350 45.8	175 35.0	100 30.3
J. Safety margin as percentage of largest unit on-line (I)	93.0	105.0	92.0	140.0	57.3	100.0	89.0	40.9	96.0	69.7	11.4	50.0
K. Percent of time steam supply unable to meet scheduled requirements (E) due to random equipment outages	0.8	0	0	2.4	9.0	0	0.8	0	3.8	6.8	0	0
L. Percent of time scheduled steam production (E) was curtailed due to nonequipment related outages	0	0.5	1.4	0	2.0	0.5	0	1.2	2.0	0	0	1.2
M. Percent of time plant was completely shut down for scheduled vacation or plant turnaround	0	0	0	0	0	0	0	2.5	1.0	1.1	0	3.8
N. Total percent of time scheduled steam production was curtailed (item K + item L)	0.8	0.5	1.4	2.4	11.0	0.5	0.8	1.2	5.8	6.8	0	1.2

*Steam data available only for central power plant.

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

Table 8. (continued)

Item of data	Plant				
	13	14	15	16	17
A. Average installed capacity, 10 ³ lb of steam/hr	220	320**	300***	192	144
B. Average on-line capacity, 10 ³ lb of steam/hr	212	265	280	175	136
C. Average on-line capacity, as percentage of A	96.2	82.8	93.3	91.1	94.4
D. Average actual steam usage, 10 ³ lb of steam/hr	175	164	116	100	65
E. Average scheduled steam usage, 10 ³ lb/hr	175	164	116	100	65
F. Average actual steam usage, as percentage of B	82.5	61.9	41.4	57.1	47.8
G. Average safety margin, Item B - Item D	37	101	164	75	71
H. Average safety margin, as percentage of D	21.1	61.6	141.0	75.0	109.2
I. Largest unit on-line (i) 10 ³ lb of steam/hr (ii) avg. percentage of B	100 47.2	125 47.2	150 53.6	72 41.1	60 44.1
J. Safety margin as percentage of largest unit on-line (I)	37.0	80.8	109.0	104.2	118.3
K. Percent of time steam supply unable to meet scheduled re- quirements (E) due to random equipment outages	0	0	0	0.2	0
L. Percent of time scheduled steam production (E) was cur- tailed due to nonequipment related outages	0	0	0	0.8	0
M. Percent of time plant was completely shut down for scheduled vacation or plant turnaround	3.8	3.8	3.8	2.2	0
N. Total percent of time sched- uled steam production was cur- tailed (item K + item L)	0	0	0	1.0	0

**Does not include 65,000 lb/hr standby boiler.

***Does not include 45,000 lb/hr standby boiler.

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

and is included as Table 9. Here there are four parameters of the unreliability of a plant: two are related to the safety margin and the others are related to failure of the steam source in meeting scheduled requirements for steam. On the average the unreliability was about 2.0%, but 9 of the 17 plants were able to meet scheduled demand for steam better than 99% of the time (unreliabilities less than 1.0%). On the other hand, three plants were not able to meet scheduled steam requirements better than 95% of the time. Thus plants in the survey tended to be divided into two groups; namely, highly reliable and "medium" reliable.

Reasons for these two groupings can be clearly seen by referring to Table 10. In this table the magnitude and duration of loss in capacity are described for the 17 plants. A qualitative rating of the severity of the outage is given in column 3. Here a "1" represents the ideal condition of no production curtailment due to boiler outages and a "0" indicates a total plant shutdown.

The smaller plants (12, 13, 14, 15, and 16) have a policy of complete shutdown during vacation periods, whereas the larger plants do not. From lines G and J of Table 9, it could not be concluded that smaller steam users had less reliable steam-supply systems than the larger plants because of the fact that their safety margins were proportionately less. If vacation periods had been included as "planned, nonequipment related outages" in computing line N of Table 9, the average reliability of all plants would have been 96.7%. However, if vacation time is neglected Table 9 shows that sources of process steam are on the average 98% reliable based on results of the present survey. This translates into the following statement: "On the average, product losses (production curtailments) due to steam outages occur for 7 days each year." From another viewpoint it might be said that all products met their sales plans except for 7 days production because of interruptions in a continuous supply of steam energy. Judging from Tables 8 and 9, an economic target level of 2 days (or less) of curtailed production per year could be viewed as an "ideal" criterion to be met by steam supply systems in large chemical plants. This corresponds to a 99.5% reliable supply of steam.

Table.9. Summary of reliability measures for seventeen chemical plants in survey

Reliability measure	Plant								
	1	2	3	4	5	6	7	8	9
Line K Percent of time steam-supply system <u>unable</u> to meet scheduled production due to random <u>equipment</u> failures	0.8	0	0	2.4	9.0	0	0.8	0	3.8
Line L Percent of time steam-supply system <u>unable</u> to meet scheduled production due to <u>nonequipment</u> related outages (planned and unplanned) not including vacation	0	0.5	1.4	0	2.0	0.5	0	1.2	2.0
Line N Total time (percent) steam-supply system <u>unable</u> to meet scheduled production	0.8	0.5	1.4	2.4	11.0	0.5	0.8	1.2	5.8
Line G Average safety margin (10^3 lb steam/hr)--average on-line capacity minus average steam demand	400	420	368	280	315	230	238	94	120
Line J Average safety margin as percent of largest boiler on-line	93.0	105.0	92.0	140.0	57.3	100.0	89.0	40.9	96.0

Table 9. (continued)

Reliability measure	Plant								Average for 17 plants
	10	11	12	13	14	15	16	17	
Line K Percent of time steam-supply system <u>unable</u> to meet scheduled production due to random <u>equip-</u> <u>ment</u> failures	6.8	0	0	0	0	0	0.2	0	1.40%
Line L Percent of time steam-supply system <u>unable</u> to meet scheduled production due to <u>nonequipment</u> <u>related</u> outages (planned and unplanned, not including vacation	0	0	1.2	0	0	0	0.8	0	0.56%
Line N Total time (percent) steam-supply system <u>unable</u> to meet scheduled production	6.8	0	1.2	0	0	0	1.0	0	1.96%
Line G Average safety margin (10^3 lb steam/hr)--average on-line capacity minus average steam demand	244	20	50	37	101	164	75	71	189.8×10^3
Line J Average safety margin as percent of largest boiler on-line	69.7	11.4	50.0	37.0	80.8	109.0	104.2	118.3	82.0

Table 10. Number and severity of outages represented by lines K, L, and M of Table 8

Plant	Magnitude of capacity loss (lb steam/hr) and duration of the loss	Severity of outage, (Available capacity online during the outage ÷ line E)
1	Loss of approximately 8% of rated capacity due to boiler failures. Occurs 2-3 times/yr for 1 day each.	~0.95
2	Complete shutdown due to violent storms (averages 2 days/yr).	0
3	Down completely an average of 5 days/yr because of electrical failures.	0
4	Down 16 hr to zero capacity, down 40 hr to 1/3 of rated capacity and down 156 hr to 3/5 of rated capacity.	~0.50
5	Fourteen outages reported that resulted in curtailed, scheduled steam production. They range from 2% loss of rated capacity for a few hours to 100% loss for 8-9 days.	~0.60
6	Complete shutdown due to violent storms (average 2 days/yr).	0
7	Complete shutdowns due to random outages, operator mistakes (average 3 days/yr).	0
8	Nine day turnaround for entire plant once per year. Power losses and violent storms shut plant down an average of 4.5 days per year.	~0.05
9	Complete shutdowns for maintenance and labor dispute. Down 2 weeks to 70% of rated capacity due to accident.	~0.35
10	Complete shutdown for maintenance on 2 occasions per year (48 hours each). Down 5% or less of rated capacity for 25 days during the year surveyed (4 curtailments).	~0.9
11	No outages reported that curtailed scheduled steam production.	N/A
12	Complete shutdowns for two-week vacation (once/yr) and for random interruptions that average 4 days/yr.	0
13	Complete shutdown for two-week vacation (once/yr).	0
14	Complete shutdown for two-week vacation, once per year.	0
15	Complete shutdown for two-week vacation, once per year.	0
16	Complete shutdown for 8 days of vacation (2 separate occasions). An average of 3 days/yr curtailed production due to power failures and strikes.	~0.2
17	No outages reported that curtailed scheduled steam production.	N/A

STUDY RESULTS FOR PETROLEUM REFINERIES

Data were obtained for nine refineries (seven different petroleum companies) that in 1973 to 1974 had a total steam consumption of 1675 kg/s (13.293×10^6 lb/hr), which is equivalent to 122.85×10^{12} kJ/year (116.45×10^{12} Btu/year).^{*} To determine what percentage of total refinery steam consumption these nine refineries represent, data from the study were used in making the following estimate:

$$\begin{aligned} \text{Total average kJ equivalent} &= (1675 \text{ kg/s}) \times (3.1536 \times 10^7 \text{ s/year}) \\ &\times (2326.23 \text{ kJ/kg}) = 122.87 \times 10^{12} \text{ kJ/year} [(13.293 \times 10^6 \text{ lb/year}) \\ &\times 8760 \text{ hr/year} \times 1000 \text{ Btu/lb} = 116.45 \times 10^{12} \text{ Btu/year}]. \end{aligned}$$

Estimated industry-wide fuel consumption for steam production in 1971 (ref. 5) = 1119×10^{12} kJ/year (1061×10^{12} Btu/year).

Projected increase for total use of heat and power by the industry is 1.8%/year over the 1971 to 1980 period (ref. 10), so estimated fuel consumption for steam production in 1973 to 1974 = $(1119 \times 10^{12} \text{ kJ/year}) \times (1.018)^3 = 1180 \times 10^{12} \text{ kJ/year}$.

Percent representation of the nine refineries in the survey =

$$\frac{122.87 \times 10^{12} \text{ kJ/year}}{1180 \times 10^{12} \text{ kJ/year}} (100) \approx 10.4\% .$$

A 10.4% sampling of refinery steam consumption in the present study is regarded as an excellent cross-section of the petroleum refining industry. Accordingly, credible conclusions concerning steam system reliabilities at refineries can be drawn from data submitted by the nine refineries. This energy-intensive industry accounts for approximately 9.4% of energy purchased by all manufacturing industries, so energy characteristics reported in this section represent around 1% of total manufacturing energy purchases.¹⁰

^{*}Again, a conservative conversion factor of 2326.23 kJ/kg (1000 Btu/lb of steam) was utilized because of considerable variation in refinery steam pressures and temperatures.

Energy consumption data for the refineries are included in Table 11. Here it can be seen that the total steam consumption rate varied from a high of 551.3 kg/s (4,375,000 lb/hr) to a low of 39.2 kg/s (311,000 lb/hr). The "average" refinery used 186.1 kg/s (1,477,000 lb of steam/hr). Because this study is primarily concerned with reliability aspects of steam production systems, refineries have been numbered in Table 11 in order of decreasing total steam usage rates.

The second column of Table 11 shows the rates of energy consumption at each refinery, including electrical and steam energy purchased or sold.* In addition, kilowatts of self-generated electrical power is listed. Four of the nine refineries generate substantial amounts of electricity. As in the case of the chemical companies, electrical energy expressed in kilowatts (kW) has been converted to an equivalent rate of steam flow by this relationship:

$$1 \text{ kW} = 0.000428 \text{ kg/s} \quad (1 \text{ kW} = 3.4 \text{ lb of steam/hr})$$

$$\text{and } 294 \text{ kW} \approx 1000 \text{ lb of steam/hr}).$$

This was done to provide a common base for comparing energy consumption patterns at the nine refineries.

Average total steam production rates are given in column 3 and calculated as a percentage of total energy consumed in column 4. Entries in columns 2 and 3 are averages for 1973 to 1974 and thus include periods of time when energy usage was curtailed for reasons that are identified later. Moreover, steam data in columns 2 to 4 include steam obtained from one or more central boiler stations and from waste heat recovery units. Column 5 lists the percentage of steam raised at the central boiler station(s). The percentage of steam energy used for process heating is shown in column 6.

A summary of types of fuel utilized and primary boiler capacities at each refinery is provided in Table 12. Also indicated is the general location of the refinery — most are situated east of the Mississippi River. The numbers in parentheses represent the nameplate capacities of boilers by fuel source. It can be seen that 25% of all boilers utilize fuel gas or natural gas, and these boilers burn 25% of all fuel based on nameplate capacities. On the other hand, 40% of the boilers use fuel oil and these boilers consume better than two-thirds of all fuel. None of the refineries

*See footnote, Table 11.

Table 11. Energy production and consumption data for nine refineries in the survey
(Most data for the period, July 1, 1973 - June 30, 1974)

Refinery	Total energy consumption rate (electrical, steam and other) in equivalent steam flow, lb/hr	Total steam production rate, lb/hr	Steam energy con- sumption as a percent of total energy consumption*	Steam energy generated at central plant as percent of total steam energy	Steam energy for direct process heat as percent of total steam energy
1	4.893×10^6 (145,000 kW purchased; 35,000 kW self-generated)	4.375×10^6	89.4	84.6	66.3
2	2.824×10^6 (7,000 kW purchased; 54,000 kW self-generated)	2.800×10^6	99.2	77.0	50.0
3	2.600×10^6 (800 kW sold) (48,800 kW self-generated)	1.870×10^6	71.9	64.2	89.6
4	4.355×10^6 (30,280 kW purchased; 24,500 kW self-generated)	1.012×10^6	23.2	42.4	25.0
5	1.207×10^6 (31,300 kW purchased; 0 kW self-generated)	1.100×10^6	91.1	62.7	61.8
6	0.886×10^6 (31,100 kW purchased; 0 kW self-generated)	0.780×10^6	88.0	73.1	57.7
7	0.919×10^6 (50,000 kW purchased; 0 kW self-generated)	0.749×10^6	81.5	60.6	68.8
8	0.554×10^6 (16,985 kW purchased; 0 kW self-generated)	0.496×10^6	89.5	75.0	60.0
9	1.034×10^6 (4,800 kW purchased; 0 kW self-generated)	0.311×10^6	30.1	78.8	50.2

*According to ref. 11 (p. 56), approximately 60% of all fuel consumed by a petroleum refinery is for direct heating and 26% of all fuel is consumed in raising process steam. Only refineries Nos. 4 and 9 included fuels for direct firing in questionnaire responses, and their percentages in this column are close to those cited in ref. 11. Numbers in column 3 of Table 11 for the other 7 refineries represent the percentage of electrical plus steam energy that is consumed as process steam.

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

Table 12. Summary of numbers of boilers and their associated nameplate capacities
(10³ lb of steam/hr) for nine refineries in the survey

Refinery and location		Fuel gas* (and natural gas)	Fuel oil*	Waste heat recovery	Total
1 (Gulf Coast)		4 (360)	14 (4900)	12 (560)	30 (5820)
2 (Midwest)		---	13 (3065)	5 (650)	18 (3715)
3 (Northeast)		2 (876)	3 (1500)	Data not available	5 (2376)
4 (Gulf Coast)		3 (600)	---	2 (360)	5 (960)
5 (Northeast)	or	4 (927)	4 (927)	7 (?)	4 (927)
6 (Northeast)		1 (175)	2 (720)	5 (?)	3 (895)
7 (Northeast)		2 (430)	10 (350)	8 (?)	12 (780)
8 (Midwest)		7 (715)	---	Data not available	7 (715)
9 (Northeast)		7 (443)	---	Data not available	7 (443)
TOTAL	Numbers	28 (4063)	44 (10,998)	39 (1570)	111 (16,631)
	Percentages	25% (25%)	40% (66%)	35% (9%)	

*These are by-product fuels that are utilized to fire conventional boilers.

NOTE: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

now burn fuels more plentiful than fuel gas and fuel oil, although one of the refineries plans to add two large coal-fired boilers by 1980.

A detailed summary of boiler data for each refinery is provided in Tables 13 and 14. Boiler pressure and temperature data for refinery No. 8 were not available, so the totals in these two tables do not correspond to totals in Table 12. From Table 13 it can be seen that the majority of all boilers operate at pressures of 4137 kPa (600 psig) or less (52 out of 84 units, or 61.9%). Furthermore, the average age of all boilers is almost 25 years, with the highest average age being associated with boilers operating under 1723.8 kPa (250 psig).

In general, boilers at refineries are older than those at chemical plants included in this study. A large number of refinery boilers are candidates for replacement/retirement as petroleum companies attempt to improve fuel consumption efficiencies and reduce unit operating costs. In fact, one of the six major recommendations of the Energy Policy Project of the Ford Foundation, regarding refinery fuel savings, was to "improve efficiency of steam boilers and reduce steam losses in standby equipment."¹¹ At refineries in the survey, this statement appears to be particularly appropriate because 37 of the 84 boilers (44%) are older than 20 years and 26 (30%) are older than 30 years. It is interesting to observe that almost all of the newer and larger boilers (nameplate capacities over 31.5 kg/s, or 250,000 lb of steam/hr) are not yet 20 years old.

From Table 14 it can be seen that 42 of the 84 boilers (50%) generate steam in excess of 371°C (700°F), and 63 boilers (75%) produce steam at temperatures above 288°C (550°F). Another recommendation given in ref. 11 concerns use of high-temperature steam to generate by-product electricity in conjunction with production of process steam regardless of the electrical needs of the refinery. One of the refineries in the survey (No. 4) has an arrangement with a nearby power company in which a large fraction of its steam requirements is provided by the utility. However, no sales of by-product electricity to the utility were reported.

The applicability of light water reactors as replacements for existing steam generators at petroleum refineries appears promising for the reasons discussed on page 15. If a large fraction of steam requirements at 400°F and below could be met with an LWR, high-temperature steam

Table 13. Boiler pressure breakouts for nine refineries in the survey

Capacity (10 ³ lb of steam/hr)	Pressure, psig				Totals
	Under 250	251-600	601-1000	Over 1000	
Under 100	5 (15 yrs) 10 (55 yrs) 4 (44 yrs)	4 (39 yrs) 2 (15 yrs)	5 (10 yrs) 2 (26 yrs)	2 (5 yrs)	34 (32.3 yrs)
100 - 250	2 (28 yrs)	7 (46 yrs) 1 (19 yrs) 3 (12 yrs) 1 (6 yrs) 2 (4 yrs) 1 (5 yrs) 2 (25 yrs) 1 (32 yrs)	8 (16 yrs) 1 (12 yrs)		29 (23.2 yrs)
251 - 500		1 (4 yrs) 1 (15 yrs) 1 (16 yrs) 1 (2 yrs) 2 (19 yrs) 1 (10 yrs)	1 (10 yrs)	4 (5 yrs) 5 (26 yrs) 3 (19 yrs)	20 (15.1 yrs)
Over 500			1 (5 yrs)		1 (5 yrs)
TOTALS	21 (40.8 yrs)	31 (24.2 yrs)	18 (14.3 yrs)	14 (15.5 yrs)	84 (24.8 yrs)

Note 1: Average age of boilers in parentheses.

Note 2: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s and multiply pressure in lb/in.² by 5.895 to get kPa.

Table 14. Boiler temperature breakouts for nine refineries in the survey

Capacity (10 ³ lb of steam/hr)	Temperature, °F				Totals
	Under 400	401-550	551-700	Over 700	
Under 100	10 (55 yrs)	5 (15 yrs)	4 (39 yrs)	2 (5 yrs)	34
	4 (44 yrs)		2 (15 yrs)	5 (10 yrs)	
			2 (26 yrs)		
100 - 250		2 (28 yrs)	7 (46 yrs)	8 (16 yrs)	29
			3 (12 yrs)	2 (4 yrs)	
			1 (12 yrs)	2 (25 yrs)	
				1 (32 yrs)	
				1 (19 yrs)	
				1 (6 yrs)	
251 - 500				1 (5 yrs)	20
			1 (4 yrs)	4 (5 yrs)	
			1 (16 yrs)	2 (10 yrs)	
				5 (26 yrs)	
				5 (19 yrs)	
				1 (2 yrs)	
Over 500				1 (15 yrs)	1
				1 (5 yrs)	
TOTALS	14	7	21	42	84

Note 1: Average age of boilers in parentheses.

Note 2: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s and determine temperature in degrees Celsius as follows, $t_c^\circ = (t_F^\circ - 32) \div 1.8$.

requirements could perhaps be satisfied with fossil or by-product fueled superheat boilers.

Turning now to reliability considerations, much information was obtained from questionnaire responses regarding the reliability of steam-supply systems at the nine refineries. The definition of reliability given on page 2 was utilized to quantify (1) average safety margins as a percent of average steam usage, (2) safety margins as a percent of the largest on-line boiler, (3) percent of clock time that desired throughput was curtailed because of equipment-related outages (unplanned) of the steam-supply system, and (4) percent of clock time that desired throughput was reduced due to nonequipment related outages of the steam-supply system.

Results of analyzing data in Sections 1 and 2 of the questionnaire are given in Table 15. Safety margins at each refinery were found by subtracting line D of Table 15 from line B. It would have been better to have used scheduled (desired) steam demand in determining the safety margin, but none of the refinery respondents distinguished between actual steam consumption versus forecasted, or desired, steam consumption on the questionnaire.

Two interesting characteristics of the safety margin are computed in lines H and J of Table 15. Average margins (line H) ranged from 3.8% of steam consumption to 60.8%, with an average of around 29%. Expressed as a percent of the largest on-line boiler, safety margins ranged from 19.0 to 200% (line J). From line J it is seen that four of the nine refineries had safety margins that were 100% or better of the largest boiler. However, there is a large amount of excess capacity at all refineries because in most cases the largest unit on-line has a nameplate capacity of at least 31.5 kg/s, or 250,000 lb of steam/hr (seven of the nine refineries).

The "unreliabilities" of steam supply systems are calculated in lines K, L, and N of Table 15. The overall reliability of refinery steam-supply systems (100 minus the unreliability in line N) ranges from 100 to 69.9%, with an average value of 92.1% for all nine refineries.

From line N of Table 15, it can be seen that five refineries had steam-supply systems that were unreliable 5% or less of all clock time, and the other four refineries were unreliable 5% or more of the time. There appears to be little connection (i.e., low correlation) between

Table 15. Process steam system capacity, consumption rate and reliability for petroleum refineries in the survey

Item of data	Refinery								
	1	2	3	4*	5**	6	7	8	9
A. Average installed capacity 10 ³ lbs of steam per hr	5820	3715	2376	1140	1427	1145	1130	715	509
B. Average on-line capacity, 10 ³ lbs steam per hr	5450	3500	2250	1050	1250	1071	1070	646	500
C. Average on-line capacity, as percentage of A	93.6	94.2	94.7	92.1	87.6	93.5	94.7	90.4	98.2
D. Average actual steam usage, 10 ³ lbs of steam per hr	4375	2800	1870	1012	1100	780	749	496	311
E. Average scheduled steam usage, 10 ³ lbs per hr	4375	2800	1870	1012	1100	780	749	496	311
F. Average actual steam usage, as percentage of B	80.3	80.0	83.1	96.4	88.0	72.8	70.0	76.8	62.2
G. Average safety margin, Item B-Item D	1075	700	380	38	150	291	321	150	189
H. Average safety margin as percentage of D	24.6	25.0	20.3	3.8	13.6	37.3	42.9	30.2	60.8
I. Largest unit on-line (i) 10 ³ lb of steam per hr (ii) avg. percentage of B	550 10.1	350 10.0	500 22.2	200 19.1	287 23.0	470 43.9	280 26.2	440 68.1	135 27.0
J. Safety margin as percentage of largest unit on-line(I)	195.5	200.0	76.0	19.0	52.3	61.9	114.6	34.1	140.0
K. Percent of time steam supply system unable to meet sched- uled requirements (E) due to random equipment outages	5.8	0.8	8.3	0	30.1	17.3	3.8	1.4	0
L. Percent of time scheduled steam production (E) was curtailed due to non-equip- ment related outages	0	0	0.8	1.9	0	0.3	0.3	0	0
M. Percent of time refinery was completely shut down for scheduled vacation or plant turnaround	0	0	0	0	0	0	0	0	0
N. Total percent of time sched- uled steam production was curtailed (Item K + Item L)	5.8	0.8	9.1	1.9	30.1	17.6	4.1	1.4	0

*172,000 lb/hr purchased steam (nameplate capacity equals 180,000 lb steam/hr)

** 10,000 lb/hr purchased steam

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

large unreliabilities and low safety margins (lines N and J). It is suspected that the high age of standby boilers tends to obfuscate the notion that high safety margins lead to low unreliabilities. In general, the larger and newer refineries tend to have more reliable steam-supply systems. It can also be observed in line K that unscheduled boiler failures accounted for the majority of all curtailments in refinery throughput. Finally, to highlight information from Table 15 relevant to steam-supply system unreliability, a summary of this aspect of the survey is provided in Table 16.

Reasons for outages of any type are listed in Table 17. Here the magnitude of the loss and its approximate duration are indicated. Also the severity of outages, as an average, is shown for each refinery, where 0 represents total refinery shutdown given that there was an outage and 1 represents the ideal condition of no production curtailments due to equipment outages during the year survey (1973 to 1974).

Results of this study of steam-supply systems at petroleum refineries indicate that sources of steam ought to be at least 92% reliable based on an arithmetic average of individual reliabilities. Because there were two major groupings of refinery steam-supply system reliabilities (greater than 98% and less than 98%), another more representative figure such as the median reliability should be considered. The median is the point that divides responses into two halves, so the median unreliability here would be about 4.0%. That is, there are four unreliabilities smaller than 4% and four that are larger. Based on the median, steam-supply systems are about 96% reliable.

STUDY RESULTS FOR PRIMARY METALS INDUSTRIES

Only three responses to the questionnaire were received from companies in this industry. Two were from aluminum companies and one was from a steel company. The total rate of energy consumption for the three companies was 91.40×10^{12} kJ/year (86.63×10^{12} Btu/year) which is roughly equivalent to 1246.1 kg/s (9.89×10^6 lb steam/hr). According to ref. 5, the total energy in fuels used by primary metals industries in 1971 was 3661×10^{12} kJ (3470×10^{12} Btu). Thus the three companies in the survey comprised roughly 2.5% of total energy consumed in the primary metals industry.

Table 16. Summary of reliability measures for nine refineries in the survey

Reliability measure		Refinery									Averages for 9 refineries
		1	2	3	4	5	6	7	8	9	
Line K	Percent of time steam-supply system <u>unable</u> to meet scheduled production due to random <u>equipment</u> failures	5.8	0.8	8.3	0	30.1	17.3	3.8	1.4	0	7.50%
Line L	Percent of time steam-supply system <u>unable</u> to meet scheduled production due to <u>nonequipment</u> related outages (planned and unplanned) not including vacation	0	0	0.8	1.9	0	0.3	0.3	0	0	0.37%
Line N	Total time (percent) steam-supply system <u>unable</u> to meet scheduled production	5.8	0.8	9.1	1.9	30.1	17.6	4.1	1.4	0	7.87%
Line G	Average safety margin (10^3 lb steam/hr)--average on-line capacity minus average steam demand	1075	700	380	38	30	81	26	150	189	296.6×10^3
Line J	Average safety margin as percent of largest boiler on-line	195.5	200.0	76.0	19.0	10.5	17.2	9.3	34.1	140.0	78%

Table 17. Number and severity of outages represented
by lines K, L, and M of Table 15

Refinery	Magnitude of capacity loss (lb steam/hr) and duration of the loss	Severity of outage, (Available capacity on- line during the outage ÷ line E)
1	Loss of approximately 17% of total name- plate capacity for 3 weeks. The boiler outage (3 weeks) was a random outage.	~0.99
2	Random boiler malfunctions resulted in loss of around 20% of total nameplate capacity for 3 1-day outages per year (average)	~0.99
3	Loss of 33% of nameplate capacity for 1 month (scheduled boiler outage). A fire caused a total shutdown for 3 days.	~0.80
4	Total shutdown for 2 days because of storm, random boiler malfunctions caused a loss of roughly 1/3 of rated capacity for 5 days (average)	~0.75
5	Forced boiler outages (3) caused 1/3 loss in total capacity for 110 days	~0.70
6	Forced boiler outages (2) caused loss of about 50% of total capacity for 10 days equivalent	~0.75
7	Forced boiler outages (5) resulted in loss of 40% of total capacity for 13 days duration	~0.65
8	Two separate random boiler outages each resulted in a 33% loss of total capacity for 5 days (total) during the year	~0.90
9	One scheduled outage reported, no curtail- ment of scheduled production	1.00

Table 18 shows the breakout of total energy for production of steam. It is apparent that only a small fraction of total energy in these companies is consumed for purposes of generating steam. Two of the companies used a large amount of the steam that they did produce for process heat applications. The steel company required no steam for such uses but did use 50% of its steam for mechanical drivers.

Data included in Table 19 indicate that average boiler ages are fairly high and that most of the steam-generating capacity (about 74%) was rated in the 288 to 371°C (550 to 700°F) range. This tends to confirm the fact that process steam temperatures in primary metals companies are generally too high for light-water reactors (BWRs or PWRs) to produce. It is likely that high-temperature gas-cooled reactors and/or fossil-fueled steam generators could satisfy future process energy needs of a consortium of primary metal companies. However, lower temperature steam could be utilized by mechanical drivers with a corresponding loss in thermal efficiency.

Additional information regarding the production and consumption of steam at the three companies is provided in Table 20. Here it is observed that all steam-supply systems were 100% reliable during the survey period. This reflects conditions under which primary metals companies operate: they are not heavily dependent on steam to maintain their processes, and they cannot tolerate shutdowns or significant losses of electrical power.

With a sample size of only 2.5% (based on total energy consumed, not steam energy consumed) and three plants responding in the primary metals industry, it is felt that general conclusions about industry-wide steam consumption patterns and steam-supply system reliabilities would be inappropriate.

Table 18. Energy production and consumption data for three primary metals plants in the survey
(Most data for the period July 1, 1973 to June 30, 1974)

Plant	Total energy consumption rate (electrical, steam and other) in equivalent steam flow, lb/hr	Total steam production rate, lb/hr	Steam energy con- sumption as a percent of total energy consumption	Steam energy generated at central plant as percent of total steam energy	Steam energy for direct pro- cess heat as percent of to- tal steam energy
1	6.901×10^6 (77,000 kW purchased, 0 kW self-generated)	8.7×10^5	12.6	87.4	0
2	1.574×10^6 (278,188 kW purchased, 153,307 kW self-generated by hydroelectric generators)	9.76×10^4	6.2	100.0	89.4
3	1.414×10^6 (415,000 kW purchased, 0 kW self-generated)	3.4×10^3	0.2	100.0	100.0

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4} to get kg/s.

Table 19. Boiler temperature breakouts for three primary metals plants in the survey

Capacity (10 ³ lb steam/hr)	Temperature, °F			Over 700
	Under 400	400-550	551-770	
Under 100		14 (avg. age = 20 yrs)		
100 - 250			5 (avg. age = 28 yrs)	
251 - 500			2 (avg. age = 7 yrs)	
Over 500				
TOTAL		14 boilers with name- plate capa- city of 461,700 lb/hr	7 boilers with name- plate capa- city of 1,345,000 lb/hr	

Note: To convert to SI units, multiply steam flow in lb/hr by 1.26×10^{-4}
to get kg/s and determine temperature in degrees Celsius as follows,
 $t_C = (t_F - 32) \div 1.8$.

Table 20. Process steam system capacity, consumption rate and reliability for primary metal companies in the survey

Item of data	Plant		
	1	2	3
A. Average installed capacity, 10^3 lb of steam per hr	1345	458	3.4
B. Average on-line capacity, 10^3 lb of steam per hr	1130	383	3.4
C. Average on-line capacity, as percentage of A	84.0	83.6	100.0
D. Average actual steam usage, 10^3 lb of steam per hr	870	97.6	3.4
E. Average scheduled steam usage, 10^3 lb per hr	870	97.6	3.4
F. Average actual steam usage, as percentage of B	77.0	25.5	100.0
G. Average safety margin, Item B - Item D	260.0	285.4	0
H. Average safety margin, as percentage of D	29.9	292.4	0
I. Largest unit on-line			
(i) 10^3 lb of steam per hr	300	40	3.4
(ii) avg. percentage of B	26.5	10.4	100.0
J. Safety margin as percentage of largest unit on-line (I)	86.7	713.5	0
K. Percent of time steam supply system unable to meet scheduled requirements (E) due to random equipment outages	0	0	0
L. Percent of time scheduled steam production (E) was curtailed due to nonequipment related outages	0	0	0
M. Total percent of time scheduled steam production was curtailed (Item K + Item L)	0	0	0

CONCLUSIONS OF THE STUDY

In studies of alternative industrial process energy systems that may be feasible in the near future, the question is often raised about how reliable the energy source must be to satisfy industry's requirements. This study was initiated to gather information from three industries regarding process energy system reliabilities that were actually experienced during 1973 to 1974. Some basis for distinguishing between what companies stated that they would like to have concerning their "economic target levels" versus what they experienced during the survey period could then be established. It is believed the estimated reliability of the steam-supply system at companies studied represents a parameter in their operation that is at least minimally acceptable to them.* Thus results reported in previous sections should be viewed as "what actually happened" rather than "what should have happened" under ideal economic conditions. Furthermore, these results were obtained from some of the largest plants within the industries studied.

Based on process steam-system reliabilities obtained from data reported in the questionnaire, it is concluded that sources of process steam in the chemical industry are presently 98% reliable. That is, they are capable of meeting or exceeding forecasted steam production requirements on a continuous basis except for 7 days per year on the average. Individual plant reliabilities ranged from 100 to 89%, so there is considerable variation about the average reliability of 98%. These relatively high reliabilities were attained by excess on-line capacity. In fact, 11 of the 17 plants had excess capacity that was at least 80% of their largest boiler. From Table 9 (lines L and N) it can be concluded that about 30% of all steam curtailments resulted from nonequipment related outages.

Concerning the nine petroleum refineries in the survey, their average reliability was roughly 92%. This corresponds to 29 days of the year that

* Because the year studied (1973 to 1974) was only a "snapshot" of long-term performance, representatives of some companies stated that this particular year provided a highly favorable picture of their operations. Others commented that the 1973 to 1974 period was the worst year in their history relative to unscheduled equipment outages, violent storms, etc.

scheduled production at an average refinery had to be curtailed because of random boiler outages, operator errors, violent storms, etc. A very large fraction (roughly 95%) of steam production curtailments were due to equipment related outages. Perhaps this can be partially explained by recalling that the average age of refinery boilers was almost 25 years.

Probably a more representative estimate of actual reliability is given by the modal response which was 96%. This figure divides responses into two groups such that one group of refineries experienced reliabilities higher than 96% and the other group had reliabilities lower than 96%. Because the nine refineries in this study accounted for better than 10% of all steam produced at refineries in 1973 to 1974, it is believed that a 96% reliable steam supply system is quite reasonable as a representative industry-wide operating parameter.

Finally, reliabilities of process energy systems in the primary metals industry were found to be 100%. This means for the period 1973 to 1974 there were no interruptions in process energy that resulted in the curtailment of scheduled production. The sample size was small, and thus general conclusions appear to be inappropriate.

As a follow-on to this study, various combinations of nuclear steam systems and nuclear-fossil steam systems will be investigated that are capable of meeting or exceeding reliability levels required for applications in candidate industries. To accomplish this, three fundamental considerations must be taken into account: (1) the total amount of steam required under normal and maximum operating conditions by individual companies and/or industrial parks, (2) the cost and overall availabilities of alternative configurations of nuclear and fossil units that would satisfy stated industrial energy reliability requirements, and (3) the forced outage characteristics and load-shedding qualities of the nuclear steam-supply systems being evaluated (i.e., abruptness of load loss, time available to bring a backup unit on-line, and time needed to bring standby units into operation).

A basic input to the determination of optimum nuclear and/or fossil steam supply systems is information concerning continuity of the energy

supply from steam generators being considered for process heat applications. In the follow-on study, a principal concern will center on quantification of steam availability from nuclear steam generators in amounts necessary to satisfy industrial reliability requirements.

REFERENCES

1. Stanford Research Institute, Pattern of Energy Consumption in the United States, November 1971, prepared for the Office of Science and Technology.
2. T. D. Anderson et al., An Assessment of Industrial Energy Options Based on Coal and Nuclear Systems, ORNL-4995, Oak Ridge National Laboratory, July 1975, p. 1.
3. Ibid., p. 19.
4. Ibid., p. 20.
5. Evaluation of New Energy Sources for Process Heat, Final Report of N.S.F. Grant No. OEP74-18055, Prepared by the Dow Chemical Company, September 1975, p. 39.
6. Op. cit., Stanford Research Institute.
7. Ibid., p. 17.
8. Report on Equipment Availability for the Ten-Year Period, 1965-1974, Edison Electric Institute Publication No. 75-50, New York, November 1975.
9. The Potential Industrial Market for Process Heat from Nuclear Reactors, prepared for the Oak Ridge National Laboratory by Dow Chemical U.S.A. under subcontract No. 4384, ORNL/TM-5497, January 1976, p. 5.
10. Energy Consumption in Manufacturing, A report to the Energy Policy Project of the Ford Foundation, Ballinger Publishing Company, Cambridge, Massachusetts, 1974, p. 47.
11. E. P. Gyftopoulos et al., Potential Fuel Effectiveness in Industry, A Report to the Energy Policy Project of the Ford Foundation, Ballinger Publishing Company, Cambridge, Massachusetts, 1974, pp. 56-57.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX A

QUESTIONNAIRE ON ENERGY REQUIREMENTS
FOR PROCESS ENERGY INDUSTRIES

The purpose of this questionnaire is to obtain a representative sampling of various operating characteristics in selected energy intensive industries. Of particular importance is the collection of data concerning operations which utilize significant amounts of steam-supplied process heat. In our study "process heat" includes steam-supplied energy required for chemical reactions, drying operations, mechanical drivers, etc. Information concerning various operating parameters of the steam-supply systems being used in process energy industries is also of interest.

The questionnaire consists of two interrelated sections: (1) the formulation of a graphic display of past operating conditions, and (2) questions concerning various supplementary details about these conditions. The graphic display technique was chosen in the first section to facilitate the presentation of data in condensed form. It is realized that this format may require some rather general assumptions and numerical approximations, but please attempt to complete the form as best you can in view of your operating experience from mid-1973 to mid-1974 (or other convenient survey period).

Section 1 -- Steam-Supplied Process Heat Requirements**General Information:**

Company _____

Division _____

Location _____
_____Major Products At This Location

_____Respondent's Name and Position

Phone Number _____

A Graphical Approach to Data Collection:

In order to facilitate a more general understanding of what information is desired, an illustrative example is shown on the following page. This illustration is simply for demonstrative purposes and is not meant to be representative of any particular industry's conditions.

Line A - Total Installed Steam Generating Capacity -

This is the total nameplate capacity (in thousands of pounds per hour) of all currently installed and operable steam generating equipment operating under standard load conditions.

Line B - On-Line Steam Generating Capacity -

Amount shown in Line A minus that capacity which is

currently unavailable (on less than 24-hour notice) due to breakdown, routine or preventative maintenance, or fuel usage limitations or shortages.

Line C - Theoretical Steam Level Required to Meet "Most-Desirable" Production Level -

This most desirable level would be dictated by current marketing considerations and routine plant operating conditions. It is, in effect, a steam forecast based on anticipated market factors. Line C would be dependent upon all factors other than availability of steam supply during the survey period, i.e. raw material and labor availability, market demand, inventory levels and general business conditions.

Line D - Actual Level of Steam Used During Survey Period -

This line is a plot of total steam usage during the survey period from mid-1973 to mid-1974. Weekly averages are highly desirable, if available. Otherwise use monthly averages.

For the above items, the effect and duration of operating anomalies that may have occurred during the study period is of more importance than detailed characteristics of more or less standard operation. On the graph that follows, please provide the information defined as "Lines A - D" on the illustrative example. If you prefer, a tabular presentation of this information would be appropriate. Any notes you care to make regarding additions to capacity, plant shutdowns, reduced plant output due to lack of process heat, etc. would be quite helpful.

POUNDS OF STEAM (10^3 lb./hr.)

Section 2 -- Supplementary Information

The purpose of this section is to gather information that will help us interpret the data plotted on the preceding graph.

Please be as specific as you can when responding to the following questions.

- A. Total Installed Steam Generating Capacity is the total nameplate capacity of all currently installed and operative steam generating equipment in your plant.

Please fill in the tables below.

ENERGY SOURCE/UTILIZATION SUMMARY

(Assuming Nominal 100% Operating Conditions)

Electrical

Sources:	Purchased	_____ kW
	Self-Generated	_____ kW
	Total	_____ kW
Uses:	Heaters	_____ %
	Drivers	_____ %
	Utilities	_____ %
	Other	_____ %
		100 %

Steam

Sources:	Purchased	_____ lbs/hr.
	Self-Generated:	
	Central Steam Plant	_____ lbs/hr.
	Process Heat Recovery Units	_____ lbs/hr.
	Other Sources	
	_____	_____ lbs/hr.
	_____	_____ lbs/hr.
	Total	_____ lbs/hr.

Uses: Power Generation _____ lbs/hr.
 Drivers _____ lbs/hr.
 Direct Process Heat _____ lbs/hr.
 Other Applications _____ lbs/hr.

Other Energy Sources (list sources and specify units)

_____ (units)
 _____ (units)
 _____ (units)

Total _____

SUMMARY OF STEAM GENERATING CAPABILITY

<u>Boiler Size</u>	<u>Number</u>	<u>Average Age</u>	<u>Type of Fuel</u>	<u>Pressure (psig)</u>	<u>Temp. (°F)</u>
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Do you anticipate replacing some of your existing units?

If yes, what are the operating characteristics of the replacement
 (temp., pressure, capacity)? _____

If yes, what type of fuel will be used? _____

If yes, when will the new units be on-line? _____

- B. On-Line Steam Generating Capacity is total installed capacity minus capacity presently unavailable (e.g. on less than a 24-hour notice) because of unscheduled interruptions, routine or preventative maintenance, fuel shortages, etc.

Please list reasons why various steam supply systems were not available at times during the 52-week period plotted earlier.

1. Unscheduled (random) outages:

2. Outages known or schedulable 48 hours in advance:

3. List duration of the outage:

What is the minimum level of steam production capacity required to keep your company's processes in an operative (marginally) condition?

- C. Amount of Steam Required to Meet "Most Desirable" Production Level is determined largely by current marketing conditions and technical production decisions at your plant.

Please indicate on a 1-5 scale the average conditions that existed at your plant during the 52-week survey period.

	Excellent		Good		Poor
	↓		↓		↓
General Market Conditions	5	4	3	2	1
Market Conditions for your Primary Product	5	4	3	2	1
Market Conditions for Your Other Products	5	4	3	2	1
Raw Material Availability	5	4	3	2	1
Availability of Skilled Labor	5	4	3	2	1
Availability of Fuel	5	4	3	2	1

Do you think that the most desirable production level (or schedule) was limited by the amount of process heat provided by steam during the survey period? _____ If yes, why?

D. Actual Level of Steam Used for Process Heat is a direct result of actual production in the 52-week survey period.

Please answer these questions with reference to your overall plant operation.

1. If the total available steam supply unexpectedly fell (e.g. within a period of five minutes) to a level 10% below that required for maintaining production at the scheduled level and remained there for 4 hours, how would you classify the resulting condition? (Indicate Item Number) _____
 - i. Routine -- no real problem.
 - ii. Minor -- some adjustments necessary.
 - iii. Significant -- product loss and extra maintenance crews necessary.

iv. Major - considerable product loss and some system rework required.

v. Catastrophic -- very costly system-wide problems exist.

2. Same as (1) except steam supply was 20% lower. Which condition would prevail? _____
3. Same as (1) except steam supply was 40% lower. Which condition would prevail? _____
4. Same as (1), except a 10% loss within a period of 4-6 hours for 48 hours. Which condition would prevail? _____
5. Same as (1), except a 40% loss within a period of 4-6 hours for 48 hours. Which condition would prevail? _____
6. Does your operation have a general policy of (a) plant-wide or (b) product division-wide annual general shutdown for maintenance, equipment relocation operations, vacations, or product change-overs, etc. If so, please explain the degree of shutdown, length, and frequency of occurrence.

7. Has your operation been forced to completely shut down at any time in the past five years due to strikes, accidents, or natural occurrences such as floods, earthquakes, etc.?

Yes _____ No _____

If your answer is yes, please give a brief explanation.

INTERNAL DISTRIBUTION

1. T. D. Anderson	15. H. Postma
2. T. E. Cole	16. M. W. Rosenthal
3. W. E. Cooper	17. M. R. Sheldon
4. F. L. Culler	18. M. J. Skinner
5. J. G. Delene	19. I. Spiewak
6. G. G. Fee	20. J. J. Taylor
7. M. J. Goglia	21. D. B. Trauger
8. J. E. Jones	22. W. J. Wilcox
9-12. O. H. Klepper	23-24. Central Research Library
13. W. J. McCarthy, Jr.	25. Document Reference Section
14. M. Olszewski	26-28. Laboratory Records

EXTERNAL DISTRIBUTION

- 29-57. Industrial Contributors
58. S. L. Adams, Gulf States Utilities, P.O. Box 2951, Beaumont, Tex. 77704
59. Seymour Alpert, Electric Power Res. Inst., 3412 Hillview Ave., Palo Alto, Calif. 94304
60. R. W. Barnes, Dow Chemical Company, 2040 Dow Center, Midland, Mich. 48640
61. D. J. Blickwede, Bethlehem Steel Corp., Bethlehem, Pa. 18016
62. R. B. Fancher, Planning and Research, Pacific Gas and Electric Company, 77 Beale Street, San Francisco, Calif. 94106
63. M. W. Golay, Dept. of Nuclear Engineering, Massachusetts Institute of Technology, 138 Albany St., Cambridge, Mass. 02139
64. Leon Green, Jr., MITRE Corp., Westgate Research Park, McLean, Va. 22101
65. Tom Gross, Office of Conservation and Environment, Federal Energy Agency, 12 Pennsylvania Ave., Washington, D. C. 20461
66. A. E. Kakretz, Manager, Gas Reactor Development, General Electric Co., Fairfield, Conn. 06430
67. A. T. McMain, General Atomic Company, P.O. Box 81608, San Diego, Calif. 92138
68. M. J. McNelly, General Electric Co., 175 Curtner Ave., Mail Stop 540, San Jose, Calif. 95125
69. H. G. MacPherson, Dept. of Nuclear Engineering, University of Tennessee, Knoxville, Tenn. 37916
70. Capt. A. V. Nida, Research and Technology Division, U.S. Army Facilities Engineering Support Agency, Fort Belvoir, Va. 22060
71. J. G. Prather, Energy Research and Development Administration, 20 Massachusetts Ave., Washington, D. C. 20545
72. Col. W. F. Reilly, Chief, Engineering Division, U.S. Army Engineer Power Group, Ft. Belvoir, Virginia 22060

73. J. L. Renzetti, Naval Nuclear Power Unit, 13101 Pelfrey Lane,
Fairfax, Va. 22030
74. R. A. Shade, Boise Cascade Corp., One Jefferson Square, Boise,
Idaho 83728
75. W. R. Smith, Power Generation Group, Babcock and Wilcox,
P.O. Box 1260, Lynchburg, Virginia 24505
- 76-79. W. G. Sullivan, Dept. of Industrial Engineering, University of
Tennessee, Knoxville, Tenn. 37916
80. R. L. Thompson, Federal Energy Administration, 1200 Pennsylvania
Ave., Washington, D. C. 20461
81. Leonard Topper, Energy Research and Development Administration,
20 Massachusetts Ave., Washington, D. C. 20545
82. Seth Tuttle, Program Manager (SIA), National Science Foundation,
1800 G Street, Washington, D. C.
83. A. M. Weinberg, Oak Ridge Associated Universities, P.O. Box 117,
Oak Ridge, Tenn. 37830
84. R. W. Wendes, Amoco Oil Co., M.C. 1105, Box 6110Z, Chicago, Ill.
60680
85. T. W. West, Dept. of Industrial Engineering, University of Tennes-
see, Knoxville, Tenn. 37916
86. J. Crowley, United Engineers and Constructors, Inc., 1401 Arch
Street, Philadelphia, Pa. 19105
87. Director, Div. of Nuclear Research and Applications, Energy
Research and Development Administration, Washington, D.C. 20545
- 88-97. T. Beresovski, Div. of Nuclear Research and Applications, Energy
Research and Development Administration, Washington, D.C. 20545
98. K. O. Laughon, Div. of Nuclear Research and Applications, Energy
Research and Development Administration, Washington, D.C. 20545
99. Director, Reactor Division, ERDA-ORO
100. Research and Technical Support Division, ERDA-ORO
- 101-127. Technical Information Center, ERDA-ORO