ANL/FPP/TM-262

ANL/FPP/TM--262

DE92 017749

ARGONNE NATIONAL LABORATORY
9700 South Cass Avenue
Argonne, Illinois 60439

**ANL ITER HIGH-HEAT-FLUX BLANKET-MODULE
HEAT TRANSFER EXPERIMENTS**

by

Kenneth E. Kasza

Materials and Components Technology Division

Fusion Power Program

February 1992

MASTER

Work sponsored by
Office of Fusion Energy
U. S. Department of Energy

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	1
1 INTRODUCTION	1
2 BLANKET DESCRIPTION/ISSUES.....	2
3 GENERAL APPARATUS CONSIDERATIONS.....	8
4 DESCRIPTION OF APPARATUS.....	11
4.1 Layered Sandwich and Heater Sizing.....	12
4.2 Sandwich Loading.....	17
4.3 Cold-Wall Panel.....	17
4.4 Sandwich Heat Flow	20
5 TEST CONDITIONS.....	23
6 DATA ANALYSIS BASIS.....	24
7 CONCLUSIONS.....	31
REFERENCES.....	33

LIST OF FIGURES

		<u>Page</u>
Figure 1	Isometric drawing of blanket internals.....	3
Figure 2	Outboard blanket side module.....	4
Figure 3	Blanket configuration at midplane	5
Figure 4	Schematic representation of the first-wall and side-wall coolant channels of the inboard blanket.....	6
Figure 5	Test apparatus, under fabrication, which will simulate a unit cell of the blanket.....	9
Figure 6	Cross section of square-plate thin-foil electric heater	15
Figure 7	Water-cooled cold panel.....	19
Figure 8	Temperature distribution in vertical sandwich cut.....	21
Figure 9	Temperature isotherms on the faces of the Be block array; (a) hot face, (b) cold face.....	22

LIST OF TABLES

		<u>Page</u>
Table 1	Summary of ITER-recommended as-fabricated thermal and structural features for the outboard core-midplane position of the blanket	7
Table 2	Heater requirements	14
Table 3	Test parameters to be explored in the first phase of the program.....	23

ANL ITER HIGH-HEAT-FLUX BLANKET-MODULE HEAT TRANSFER EXPERIMENTS

Kenneth E. Kasza

ABSTRACT

An Argonne National Laboratory facility for conducting tests on multilayered slab models of fusion blanket designs is being developed; some of its features are described. This facility will allow testing under prototypic high heat fluxes, high temperatures, thermal gradients, and variable mechanical loadings in a helium gas environment. Steady and transient heat flux tests are possible. Electrical heating by a two-sided, thin stainless steel (SS) plate electrical resistance heater and SS water-cooled cold panels placed symmetrically on both sides of the heater allow achievement of global one-dimensional heat transfer across blanket specimen layers sandwiched between the hot and cold plates. The heat transfer characteristics at interfaces, as well as macroscale and microscale thermomechanical interactions between layers, can be studied in support of the ITER engineering design effort. The engineering design of the test apparatus has shown that it is important to use multidimensional thermomechanical analysis of sandwich-type composites to adequately analyze heat transfer. This fact will also be true for the engineering design of ITER.

1 INTRODUCTION

As part of an effort to develop an international thermonuclear experimental reactor (ITER), the U.S. has recently completed a conceptual design of an ITER blanket/shield. The international partners, U.S., Japan, the Soviet Union, and the European community, will embark upon a six-year engineering-design phase of ITER. The Argonne National Laboratory (ANL) high-heat-flux blanket-module heat transfer program will contribute to this effort. The objectives of this ITER program are to quantify the heat transfer performance of candidate blanket designs, measure the thermal-gap conductance between a stacked array of beryllium (Be) blocks and an adjacent stainless steel (SS) plate as

a function of several blanket design parameters, and furnish data for design validation. The change in the thermal-gap conductance due to deformation of the Be blocks is one of the tasks in this program.

The conceptual design of the ITER blanket is described in Ref. 1. The experimental test program and apparatus described in the following sections are based on addressing the critical heat transfer adequacy issue defined for the blanket design during the conceptual-design phase of ITER and on technical input from Y. Gohar, M. Billone, S. Majumdar, A. Stojimirovic, and G. Myers.

2 BLANKET DESCRIPTION/ISSUES

Figures 1-3 illustrate a representative design for the blanket. Both outboard (shown) and inboard regions of the blanket structure are of similar but not identical design. The inboard side has fewer layers of Be blocks. The layers of Be serve to control the temperature of the breeder layers and also act as a neutron multiplier for the breeder. The Be layers reside in a helium environment. The actual temperature distribution in the Be layers is a result of volumetric neutronic heating within the Be and heat transfer from the breeder layers. Figure 4 is a schematic representation of the first-wall/side-wall water-cooled panels of the inboard blanket. Water enters nominally at 60°C and leaves at 100°C.

Table 1 lists some thermal and structural features of the outboard core-midplane position of the blanket, including radial clearances δ , to accommodate blanket thermal expansion, and minimum toroidal clearances τ between blanket elements and side walls, to accommodate thermal and end-of-life swelling expansion. The remaining columns give code-predicted information on the thermal expansion of the elements and toroidal clearances. Expansion and clearance characteristics are important design aspects because they strongly influence heat transfer between blanket elements and thus element temperatures, as well as structural thermal-stress loading. The breeding elements must be maintained in a definite temperature range for efficient tritium recovery.

Calculations of thermomechanical characteristics of the blankets as shown in Table 1 are based on models developed by M. Billone, Ref. 1. The uncertainties

Fig. 1. Isometric drawing of blanket internals

Fig. 2. Outboard blanket side module

Fig. 3. Blanket configuration at midplane

Fig. 4. Schematic representation of the first-wall and side-wall coolant channels of the inboard blanket

Table 1. Summary of ITER-recommended as-fabricated thermal and structural features for the outboard core-midplane position of the blanket

Layer (DF)	Thickness, mm	Predicted ave. temp., ^a °C	Radial thermal expansion, mm	Min. toroidal clearance τ , mm
SS first wall	5	134	0.007	0.70
H ₂ O	4	60	---	---
SS back wall	5	154	0.009	0.90
Be (0.85)	34	341	0.214	11.6
SS clad	1	432	0.009	4.6
Li ₂ O (0.8)	8	509	0.109	14.7
SS clad	1	431	0.009	4.6
Be (0.85)	59	297	0.327	5.4
δ_1 clearance	0.70	---	---	---
SS coolant channel	2	108	0.002	0.4
H ₂ O	2	60	---	---
SS coolant channel	2	90	0.001	0.3
Be (0.65)	57	280	0.312	4.0
SS clad	1	441	0.009	4.7
Li ₂ O (0.80)	8	487	0.103	14.7
SS clad	1	438	0.009	4.7
Be (0.65)	71	275	0.386	3.2
δ_2 clearance	0.83	---	---	---
SS coolant channel	2	84	0.000	0.02
H ₂ O	2	60	---	---
SS coolant channel	2	60	0	0

^aUnder normal conditions.

in the conductance of the gaps between the SS plates and Be blocks strongly influence the performance predictions of the blanket design. The uncertainties are the result of complex interactions between structural (micro- and macroscale), thermal, and radiation factors. For example, Be deformation due to radiation and thermal expansion (which changes with time), along with macrostructural distortions from temperature gradients and coolant pressurization, causes gap changes and different thermal contact areas. Furthermore, local thermal distortion (curvature) of the individual Be blocks has also been shown [2] to exert an important influence on gap conductance. Therefore, to improve and validate blanket design calculations, we need better data on gap conductance and some of the thermal/mechanical-interaction factors that influence gap characteristics. Additionally other blanket designs, involving such features as Be sponge or Be pebble panels, will also be tested.

3 GENERAL APPARATUS CONSIDERATIONS

All of the complex factors influencing gap conductance will not be addressed in these experiments. Tests involving neutron heating are planned for latter stages of the ITER program. Hence, the Be blocks will not be subjected to radiation-induced swelling or to volumetric heating. Thus, the distortion of individual blocks will differ somewhat from the prototype condition, which influences the gap geometry and the extrapolation of the data to prototype behavior. Computer codes will be used to assess the importance of this loss in similitude.

The test apparatus under fabrication (Fig. 5) will simulate a unit cell of the blanket and consists of a single-layer array of Be blocks sandwiched between hot and cold SS plates. This represents a typical array of Be blocks in the blanket as shown in Fig. 1. The test apparatus is constructed symmetrically about an electrically heated hot plate (which represents the breeder plate) according to recommendations of the American Society for Testing and Materials (ASTM) [3-5] and according to work of the National Institute of Standards and Technology [6]. This design contributes to achieving highly one-dimensional heat transfer with minimal stray-heat loss, which is essential to calculating heat transfer properties and characteristics of the array with satisfactory accuracy. The test apparatus is described in more detail in the following sections.

Fig. 5. Test apparatus, under fabrication, which will simulate a unit cell of the blanket

Other types of test apparatus have also been used to measure thermal conductivity or solid/solid interfacial thermal gap conductances. Typically, these apparatus [7] utilize material specimens of size and shape restricted to be compatible with the test apparatus (i.e., small size and specific shape). These apparatus can employ pulsed heating with, for example, a laser to calculate thermal properties from transient data or steady-state heat transfer longitudinally through cylindrical specimens.

For the present studies, we chose to perform tests in a sandwich-type test apparatus because this most closely duplicates many features of the prototype blanket and allows study of many of the complex thermal/structural interactions that can occur in the prototype and hence influence interfacial heat transfer.

In the first phase of this program, there will be no attempt to simulate force loadings of prototypic overall blanket structurally induced feedback on the sandwich. Instead, three different initial gap configurations will be tested in an effort to bound prototypic conditions. The experiments will simulate a near-prototypic heat flux and temperatures through the sandwich in a helium environment with prototypic Be and SS materials and prototypic surface finishes at the material interfaces where thermal conductances will be measured. Because no radiation swelling occurs in these tests, the data will be more representative of start of blanket life.

The water-cooled cold wall of the test section will be fabricated from a stainless coolant panel similar to that of the prototypic blanket design. The panel will be formed from two SS plates embossed with a ribbed pattern and continuously spot welded together to form a multichannel panel conveying cooling water. The hot SS wall will be heated by electrical resistance to achieve prototypic heat fluxes (20-50 w/cm²).

Three different preloading conditions on the test apparatus sandwich before heatup will be used to explore the dependence of interface conductance on interface characteristics. The SS plates will be mechanically loaded and constructed to achieve interface gaps as uniform as possible (i.e., minimize flexural and thermal distortion, as well as edge effects over the array area). The sandwich preloading schemes are

- no interface asperity contact
- asperities "just touching"
- reasonable asperity contact pressure.

The test cases involving asperity contact pressure will be achieved by placing a uniformly distributed dead weight on top of the sandwich to create a constant load during testing. However, the contact pressure may vary with thermal conditions because of material thermal distortions, which change the actual contact area. An effort will be made to measure local temperature distribution in a SS plate in the vicinity of a single Be block to quantify the interplay between interfacial material distortions and temperature variation. Strain gauges embedded in the materials will be used in an effort to study thermally induced interfacial surface distortions.

4 DESCRIPTION OF APPARATUS

The overall features of the test apparatus are shown in Fig. 5. Specific details on sizing of the sandwich elements are described in this section. An electrically heated, thin SS hot plate is located symmetrically in the center of the test apparatus sandwich. The Be blocks are arranged symmetrically in a square array on both sides of the heater. The corresponding elemental layers of the apparatus on each side of the heater are of exactly the same planar size as the heater and must be identical in thermal properties.

Because of symmetry about the heater, the reduction of data to obtain thermal characteristics of the Be array and interfaces is based on the assumption that one-half of the heat generated in the heater passes upward and the other one-half downward into the lower Be array, assuming that radial heat loss from the heater and other layers is negligible. This latter assumption is quite good, because of the use of a guard heater that surrounds the test apparatus opposite the heater and the two Be block arrays, and because the thermal resistance of the test layers is much less than that associated with the insulated path out to the ambient heat sink. Calculations are underway to quantify the importance of the guard heater.

The guard is electrically heated and maintained at the same temperature as the heater or at the average temperature of the Be layer by suitable automatic controls. On both sides of the heater, a water-cooled SS panel is used to achieve the cold-wall temperature on the other side of Be block arrays. By setting the heater power level and adjusting the cold-water temperature and flow rate, the desired heat flux through the Be and temperatures across the blocks can be achieved. The nontest specimen sides of the two cooling panels are insulated with rigid insulation to minimize heat exchange with the rest of the environmental chamber, which houses the sandwich.

The plane of the sandwich is perpendicular to the gravitational field. For the tests that are conducted with an applied load on the interfaces, a uniform static weight load is applied to the top of the sandwich. Because the prototype blanket exists in a helium gas environment, a helium environment is maintained in the enclosing environmental chamber at prototypic pressure.

The entire sandwich is set on a rigid support frame and contained within a shroud that rests on the bottom of the environmental chamber. This system of support frame and shroud allows for ease of assembly and instrumentation of the test apparatus, as well as facilitating supplying it with electricity and water. The support frame is removable by lifting it out of the shroud for reconfiguration of the test specimens. All open regions between the sandwich and the shroud are filled with loose insulation to minimize heat losses and maintain a highly one-dimensional heat flow through the specimens.

For a given set of test conditions, the overall thermal conductance of the Be array is calculated by having accurately measured the power supplied to the heater (using 1/2 power due to symmetry), the temperatures of the hot- and cold-plate surfaces, the planar area (A) of the array, and the distance (L) between the hot- and cold-plates, and by using Fourier's law of conduction for one-dimensional heat transfer. Data analysis is discussed in Sec. 6.

4.1 Layered Sandwich and Heater Sizing

The Be layers experience maximum temperature gradient in the layer composed of 34-mm blocks located next to the SS back wall of the blanket (see

Table 1). Based on this information, and on the desire to obtain gap conductance data for more than one block size, the 34-mm and 59-mm Be block sizes (second layer out from the back wall) were selected for testing. In addition to having all layers of the same planar dimensions (for enhancing one-dimensional heat transfer), two important criteria were used in guiding the sizing of the layers of the sandwich. These criteria are

- 1) The array must contain a large enough number of blocks to approximate the prototype arrays, which are quite large, and to average out individual block differences such as size, material properties, and interface effects.
- 2) To facilitate achieving one-dimensional heat transfer, the planar dimensions of the heater should be at least three to four times the thickness of the test specimen, and the heater plate should be as thin as possible [5,8].

A sizing of the test apparatus planar dimensions for the 59-mm blocks will also satisfy the above criteria for the 34-mm blocks. Additionally, sizing is also presented for a 1/2-scale test apparatus based on a prototype dimension of 1 m (i.e., a 1/2 m x 1/2 m array of Be blocks). This is done to furnish information to aid in deciding whether a larger test apparatus, which will satisfy possible longer range needs of the ITER program, should be built initially. Regardless of which is built, the sizing based on the 59-mm blocks is the smallest test apparatus that should be built.

The power requirement for the electrical heater is based on a maximum prototype heat flux (assuming the surface heat flux is 0.25 of the neutron wall loading) at a Be interface of 50 W/cm² [1, p. 103]. Because the test apparatus is symmetric about the heater, the heater must generate a flux of 100 W/cm². Additionally, a 4 x 4 array of blocks is used to satisfy Criterion 1). Hence, the square array of 59-mm blocks will have planar dimensions of 4 (59 mm) = 23.6 cm and the square heater will have an area of (23.6 cm)² = 556.96 cm² and must deliver total two-sided power of (100 W/cm²)(556.96 cm²) = 55.7 kW. Table 2 summarizes heater size and power requirements for both the minimum-sized test apparatus for a 4 x 4 array of 59-mm Be blocks and a 1/2-scale apparatus.

Table 2. Heater requirements

Be size (cm)	Array configuration	Heater size (cm)	Heater area (cm ²)	Heater total power (kW)
5.9	4 x 4	23.6	556.96	55.7
5.9	8.5 x 8.5 (1/2 scale)	50	2500	250

Additional power supply specifications will be discussed later.

The key features of a square-plate, thin-foil electrical resistance heater are presented for the 4 x 4 array of 5.9-cm Be blocks. Many heaters described in the literature and in ASTM publications employ electrical resistance heating elements embedded in a grooved heater plate. This technique, however, can lead to local heater-plate thermal distortions, which would alter the Be/SS interface geometry and contact characteristics from those that will occur in the prototype. To achieve a more uniform hot-wall boundary condition, a heater concept described in Ref. 5 was adopted for these tests. This design (Fig. 6) employs a very thin metal foil in which I^2R loss electrical resistance heating takes place. The foil is electrically insulated on both sides from two thin metal plates that sandwich and support it. The two metal plates are the hot walls that interface with the two symmetric arrays of Be blocks. Because the foil is continuous over the heater area, variations in the surface temperature of the plate and possible distortions are reduced over those that can occur when a finite number of heater elements are embedded in a grooved plate. Furthermore, because the heater plate is thin, lateral heat flow along the plane of the heater is small and there is no need to use a separate primary heater guard. However, a guard heater as shown in Fig. 5 may be utilized to further minimize radial heat loss from the Be blocks. The low thermal inertia of this heater design relative to that associated with a much thicker grooved, embedded-element heater also reduces thermal drift error and speeds up the test apparatus approach to steady state.

The square heater is of dimension $L = 23.6$ cm. Electrical power input is along two opposing sides of the foil. The two metal cover plates will be made of 1-mm thick prototype ITER 316 SS, with appropriate surface roughness on the side interfaced with the Be blocks. The metal foil will be made of 0.03-mm thick 321 SS. The foil thickness t can be varied to achieve resistance values compatible

Fig. 6. Cross section of square-plate thin-foil electric heater

with power requirements. Uniformity of the foil thickness is very important to achieving uniform heating. Thin foils can be purchased with thickness variations less than $\pm 2\%$. Based on this foil thickness and an electrical resistivity of $\rho = 106 \times 10^{-8} \text{ ohm-m}$ at 500°C (ρ being sensitive to temperature) the electrical requirements for the heater are given by the following equations:

$$R = \rho L/a, \quad \text{where } R \text{ is the foil electrical resistance and } a \text{ is the cross-sectional area (Lt)}$$

$$I = \sqrt{P/R}, \quad \text{where } P \text{ and } I \text{ are, respectively, the power and current supplied to the foil}$$

$$E = P/I, \quad \text{where } E \text{ is the voltage across the foil.}$$

Hence,

$$R = \frac{106 \times 10^{-8} \text{ ohm-m} \quad 23.6 \text{ cm}}{23.6 \text{ cm} \quad 0.003 \text{ cm}} \left(\frac{100 \text{ cm}}{\text{m}} \right)$$

$$= \boxed{3.523 \times 10^{-2} \text{ ohm}},$$

$$I = \sqrt{\frac{55.7 \times 10^3 \text{ W}}{3.523 \times 10^{-2} \text{ ohm}}}$$

$$= \boxed{1257 \text{ amp}},$$

and

$$E = 55.7 \times 10^3 \text{ W} / 1257 \text{ amp}$$

$$= \boxed{44.3 \text{ volts}}.$$

This power, current, and voltage are reasonable values for a power supply. The equivalent values for a 1/2 scale ITER heater design with $L = 0.5 \text{ m}$, $P = 250 \text{ kW}$, and $t = 0.03 \text{ mm}$ are

$$R = \boxed{3.5 \times 10^{-2} \text{ ohm}},$$

$$I = \boxed{2672 \text{ amp}},$$

and

$$E = \boxed{93.56 \text{ volts}}.$$

4.2 Sandwich Loading

It has already been mentioned that three sandwich preloading schemes will be used to explore the dependence of Be/SS interface gap conductance on gas gap size and on contact pressure at the interfaces. The test cases with "reasonable asperity contact pressure" will be achieved by applying a constant, uniformly distributed dead-weight load to the top of the sandwich. Future program test phases can be used to evaluate the influence of nonuniform loadings on gap conductance. These nonuniform loadings can be achieved by varying the dead-weight distribution.

The amount of loading required is guided by the current prototype blanket design criteria [1], which state that, prior to reactor powerup, the LiO₂ breeder and Be layers will be separated from the SS by finite gas gaps. However, once full power is reached and thermal expansion and swelling has taken place, the interfaces are designed to be in nominal contact (i.e., low contact pressure). Discussions with M. Billone have established that an interfacial contact pressure range of 0.01 to 0.05 MPa is adequate to explore the "nominal contact" prototype loading cases. These two levels of contact pressure can be achieved for the 23.6-cm square array of area 556.96 cm² with dead-weight loads of 126.9 lb and 634.5 lb, respectively. If lead, which has a density of 705 lbm/ft³, is used as the dead weight, it would need to be stacked on the order of 1 ft high. Therefore, contact pressure loadings on the order 0.5 atmosphere (0.05 MPa) are achievable.

4.3 Cold-Wall Panel

The heater unit that simulates the hot wall of the sandwich is designed to be symmetric, with uniform heat generation, and thin to minimize thermal

structural distortions (i.e., should remain flat). The water-cooled cold-wall SS panels shown in Figs. 4 and 7 should also remain flat under thermal loading. However, these panels are not symmetrically thermally loaded in the test apparatus. The wall interfacing with the Be blocks will be considerably hotter than the other wall, which interfaces with the rigid insulation of the test apparatus and will nominally be at the temperature of the cooling water. This temperature difference can cause panel distortion. To evaluate the magnitude of this distortion, A. Stojimirovic [9,10] carried out a series of numerical two-dimensional thermo-elastic analyses of the cold panels.

The panel cell that was analyzed is shown in Fig. 7 and its reference case dimensions are $a = 35$ mm, $b = 15$ mm, $t_v = 5$ mm and $t_h = 2$ mm. Analysis of this case, with a 50 W/cm^2 uniform heat flux over one face of the panel and a coolant water flow temperature of 60°C in the panel channels, yielded a 237°C panel hot-face temperature and thermal loading stresses that exceeded the allowable stress of 330 MPa for 316 SS. Furthermore, this stressing caused the individual coolant cell to bend (see Fig. 7) and, when extrapolated to the entire coolant panel, caused a midpanel deflection of $V_{\max} = 1.5$ mm. This deflection far exceeds the Be block surface roughness estimated to be on order of $20\text{--}40 \mu\text{m}$ and, as a consequence, would complicate interpretation of gap conductance test results and exhibit behavior that is unacceptable in the prototype design. The panel dimensions were altered to explore the influence on reducing panel stresses and bending. It was established that

- The thickness t_v of the plate on the hot side of the coolant panel nominally dictates the temperature difference across the panel. Because the panel deformation is roughly proportional to this temperature difference, one should make the hot plate as thin as is compatible with the pressure of the coolant water.
- Panel deformation can also be decreased by increasing its bending stiffness by increasing the separation distance b between the hot and cold plates.

Based on these criteria, the dimensions t_v and b were changed from the reference case to $t_v = 2$ mm and $b = 25$ mm, with the panel cold-side plate thickness remaining at 5 mm. This resulted in stresses falling below the maximum allowable and in panel center deflection being reduced significantly to

The geometry of a characteristic cell.

Deformation of a representative cell.

Deformed shape of one-half of the steel plate panel.

Fig. 7. Water-cooled cold panel

131 μm and the hot-wall temperature reduced to 143°C. Hence, proper dimensioning of the coolant panel can be used to keep cold panel deflections to acceptable values. The test apparatus is now undergoing final design and the cold-panel deflection is being reduced even further with additional design changes. Furthermore, full three-dimensional analysis is being used to quantify panel thermomechanical behavior because two-dimensional analysis is not conservative in predicting deflection.

4.4 Sandwich Heat Flow

An essential requirement of the test apparatus is that one-dimensional heat flow normal through the plane of each element should be achieved by proper design. This implies that isotherms are parallel to the planar surfaces of all elements with negligible heat flow out through the sides of the sandwich. When this requirement is satisfied, one can use the one-dimensional form of Fourier's heat conduction law to interpret the experimental data and calculate the interface conductances.

To check on the ability of the apparatus to achieve reasonable one-dimensional heat flow, a finite-element-code heat conduction analysis was performed by A. Stojimirovic [12]. This scoping analysis assumed no structural thermal distortion (i.e., interfaces remained flat) and that the apparatus behaved symmetrically above and below the heater and also possessed quarter-sector symmetry. Furthermore, for the scoping calculation, it was assumed that there was no heat loss from the environmental chamber to the ambient. Hence, the only heat sink was the water-cooled cold panel maintained at a uniform 60°C sink temperature. The one-sided heat flux for all cases was 50 W/cm², the maximum anticipated for the prototype. The space analyzed not occupied with hard structure was assumed filled with loose-fill quartz wool insulation.

Calculations were made with several different guard temperatures and two different separation distances for the guard from the edges of the sandwich. Figures 8 and 9a and b summarize some typical calculated results for isotherms at various locations in the sandwich. The guard standoff distance from the edge of the sandwich was 5 mm. The guard temperature was set at the average temperature across the Be blocks. Clearly, a high degree of one-dimensional

Fig. 8. Temperature distribution ($^{\circ}\text{C}$) in a vertical sandwich cut (heat flux 50 W/cm^2)

(a) $\Delta T \approx 4^\circ\text{C}$

(b) $\Delta T \approx 3^\circ\text{C}$

Fig. 9. Temperature isotherms on the faces of the Be block array (1/4 sector); (a) hot face, (b) cold face

heat transfer has been achieved. For the final design of the test apparatus a calculation will be made with a simulation of heat loss to the ambient through the environmental chamber walls. In addition, a calculation without a guard heater will also be performed to evaluate what influence a malfunction of the guard would have on temperature distribution in the sandwich and in the insulated space within the chamber.

5 TEST CONDITIONS

The test parameters and their ranges to be explored in the first phase of this program are given in Table 3. Not all combinations of these parameter values will be tested. The same hot and cold SS plates and helium pressure will be used for all tests.

Table 3. Test parameters to be explored in the first phase of the program

Be blocks	Gap configurations	Heat flux	Be temperature differential (extreme)	He pressure	Coolant water temperature	Stainless steel plates
Size (3.4 and 5.9 cm)	No asperities contact (0.1, 0.5 and 1.0 mm)	(20 to 50 W/cm ²)	450°C max.	0.05 – <0.1 MPa	(60 to 100°C)	Annealed 316
Porosity (0.15 and 0.35)	Asperities just touching (0–0.1 mm)					Surface roughness (1–2 µm)
Surface roughness (20 and 40 µm)	Contact pressure exists (0.01 and 0.05 MPa)					

To obtain credible and reproducible data on gap conductances, very tight manufacturing tolerances and specifications must be achieved on Be block overall dimensions, surface roughness, porosity, and microstructure of the sintered material. All these parameters must be quantified. Microstructure control is important because it can influence thermal conductivity and cause possible nonisotropic material properties. Hopefully, all blocks will have nearly identical

microstructure. Checks will be made to verify that the Be blocks meet specifications.

6 DATA ANALYSIS BASIS

The objective of this program is to study experimentally the influence of the ITER blanket design parameters on the effective thermal conductivity or conductance of the entire Be region comprised of the Be block array and the interfacial regions (i.e., Be/SS interfaces) on both sides of the Be. The program will also explore the heat transfer conductances at the individual interfaces. It should be noted that even if both interfaces are comprised of the same materials and matching surface roughness conditions, the heat transfer conductances across the two interfaces need not be identical. For example, when the Be blocks are subject to a large enough temperature gradient normal to the plane of the array, the individual blocks will undergo thermally induced (expansion-contraction) curvature, with the block hot side curved outward and the cold side curved inward. This changes the gap size and local asperity contact conditions, making interface thermal resistances on opposite sides of the blocks unequal.

In Ref. 1, the Be block curvature is shown to be an important feature of predicting the temperature profile through the blanket. This phenomenon has been called thermal rectification in the literature (i.e., the resistance to heat transfer across an interface can be a function of heat flow direction). This behavior is not adequately predictable and occurs even for interfaces that don't undergo gross surface curvature distortions but remain flat, and for contact between similar materials (heat flow being largest when from rough to smooth surface) although it is largest for dissimilar materials [11].

Thermal rectification is dependent upon thermal conditions, material properties, and surface characteristics (i.e., roughness and larger scale distortions). For surfaces that don't undergo gross thermal curvature distortions, the rectification is believed due to thermally induced shape changes of individual asperities, which influences contact area between interfaces and hence thermal resistance [13].

The equations relating heat flow, temperature distribution, material thermal properties, and the dimensions of the test apparatus are presented below. These equations are used to relate the test parameters to the heat transfer resistance or conductance characteristics of interest. For steady-state conditions in the sandwich under the assumptions of one-dimensional heat flow normal through the plane of each element (i.e., the isotherms are parallel to all element planar surfaces, with negligible radial heat flow out through the sides of sandwich), and material properties constant and isotropic for each element, Fourier's law of heat conduction can be written for each element of the sandwich or for the overall sandwich.

The equation presented here for the overall sandwich is based on the assumptions that the apparatus is symmetrical about a plane passing through the foil heater, and that all elements are of the same planar area. The heat flow per unit time Q (where Q is 1/2 the total electrical power supplied to the heater) is then related to the temperature difference across the half sandwich $T_F - T_{H_2O}$ (where T_F is the heater foil temperature and T_{H_2O} is the average temperature of the cooling water), and to the summation of the individual thermal series resistances (R_i) of the sandwich elements by

$$Q = (T_F - T_{H_2O}) / \sum_{i=1}^6 R_i,$$

where

R_1 = resistance of SS cover plate on the foil heater,

R_2 = interface resistance between the SS hot-wall-heater cover plate and the Be block array,

R_3 = resistance of the Be block array,

R_4 = interface resistance between the Be block array and the cold-wall SS plate (in general, $R_2 \neq R_4$),

R_5 = resistance of the cold-wall SS plate,

R_6 = film resistance between the cold-wall SS plate and coolant water flow in channels.

Letting L_i equal the thickness of the individual sandwich elements, $A_i \equiv A$ for equal planar areas of each element, K_i equal to the molecular thermal conductivity of sandwich materials, and h_i equal to the interfacial contact coefficients, the thermal resistances can be written as

$$R_1 = L_1/K_1A ,$$

$$R_2 = 1/h_2A ,$$

$$R_3 = L_3/K_3A ,$$

$$R_4 = 1/h_4A ,$$

$$R_5 = L_5/K_5A ,$$

$$R_6 = 1/h_6A .$$

The terms Q , T_F , T_{H_2O} , L_1 , L_3 , L_5 , K_1 , K_3 , K_5 , and A are reasonably accurately known, measured experimental quantities. Although the lengths may require accounting for thermo-structural expansion, and K_3 requires knowledge of the conductivity of the sintered porous Be blocks, the uncertainties in these quantities is considerably smaller than those associated with the interfacial contact coefficients h_2 and h_4 .

The terms h_2 and h_4 and their dependence on complex thermal, structural, and interfacial characteristics and interaction are the primary source of design uncertainty of the ITER blanket; therefore, the goal of this program is to improve our understanding of these terms and their dependence as they relate to ITER. In the most general case, three modes of heat transfer can occur across the interfaces: molecular conduction through asperity-to-asperity contact, as well as through the gas (He) in the interface voids; radiation, if high enough temperatures exist across the gas voids; and if the thermal buoyancy forces, due to gas spatial temperature variations, are large acting on the void gas, natural convection currents will occur. Furthermore, when the gap between interfaces becomes very small, the gas molecular transport may no longer be in the continuum regime but in transition to free molecular flow. Additionally, proper

characterization of the roughness of interfacing materials and other irregularities becomes very important in the transition from a case where the gas gap is much larger than the surface roughness, to the case where they are of the same order of magnitude or there is asperity-to-asperity contact pressure at the interface. A good discussion of these complexities is given in Ref. 14.

No reliable analytical or empirical expression has yet been developed for the general problem of interfacial heat transfer. However, over the years, several expressions for h_i have evolved, which appear to be qualitatively correct in predicting trends. For narrow ranges of parameters of a given set of experimental conditions, some expressions are reasonably good quantitatively.

One such expression, developed in Ref. 7 for uranium dioxide/Zircaloy-4 interfaces with He-filled voids, used in fission reactor applications and modified for Be/SS interfaces, is as follows:

$$h_i = \frac{K_g}{(r_1 + r_2) + (g_1 + g_2) + G} + \frac{2K_1K_2 P_{12}}{(K_1 + K_2) H_s A \sqrt{r_{12}}} + \left[\sigma / (1/\epsilon_1 + 1/\epsilon_2 - 1) \right] (T_1^2 + T_2^2) (T_1 + T_2), \quad \text{W/m}^2 \cdot \text{K},$$

where

$$K_g = \text{He conductivity} = 3.366 \times 10^{-3} T_g^{0.668}, \quad \text{W/m} \cdot \text{K}$$

$$r_1 = \text{root-mean-square (rms) roughness height of SS, } 10^{-6} \text{ m}$$

$$r_2 = \text{rms roughness height of Be}$$

$$= 1 + 11 \text{ OP, } 10^{-6} \text{ m}$$

$$P = \text{porosity volume fraction of Be}$$

$$g_1 + g_2 = \text{sum of the temperature jump distances}$$

$$= 4.625 \times 10^{-11} T_g^{1.168} (1/a_1 + 1/a_2) / P_g, \text{ m}$$

P_g = He pressure, MPa

a_1 = thermal accommodation coefficient for SS, 0.12

a_2 = thermal accommodation coefficient for Be, 0.145

G = hot gap, m

K_1 = stainless steel thermal conductivity

K_2 = thermal conductivity of 100% dense Be

$A = 0.05 \text{ m}^{1/2}$

ϵ_1 = SS thermal emissivity, 0.9

ϵ_2 = emissivity of Be, 0.6

σ = Stephan-Boltzmann constant, $5.67 \times 10^{-8} \text{ W/m}^2 \cdot \text{K}^4$

T_1 = SS surface temperature, K

T_2 = Be surface temperature, K

$T_g = (T_1 + T_2)/2$ = average gas void temperature, K

P_{12} = interfacial contact pressure, MPa

$r_{12} = \left[(r_1^2 + r_2^2) / 2 \right]^{1/2}$, m

$H_s = 2.25 \times 10^3 (1 - 7.94 \times 10^{-4} T_1)$, MPa

Terms 1, 2, and 3 in the expression for h_i are gas conductance, solid-solid conductance, and radiation conductance, respectively. Term 1 contains a gas gap dimension G , rms roughness heights for the two surfaces r , the temperature jump distances g , and accommodation coefficients a for the two surfaces. The temperature jump distances and accommodation coefficients (ranging from 0 to 1) are concepts introduced in the analysis of interfacial phenomena to take into account temperature discontinuities and nonlinearity of the gas temperature (deviations from Fourier's law) at and near the walls. The expression for h_i does

not account for the possibility of natural-convection-driven currents of the gas in the gap, only molecular conduction.

In the following paragraph, an estimate is presented of whether natural convection currents driven by the temperature difference $T_1 - T_2$ across the He gap are important for the 40- and 80- μm gap sizes of the ITER vertical blanket regions. The natural convection occurs as a result of gravitational forces acting on the variations in He gas density in the gap. The dimensionless parameter Gr, called the Grashof number and defined by $g\beta(T_1 - T_2)G^3/\nu^2$, is used as a measure of the importance of natural convection in fluid filled-spaces. The Grashof number represents the ratio of the strength of thermal buoyancy forces produced by gravity to the viscous forces in the fluid, where

g = gravity,

β = coefficient of fluid volumetric thermal expansion,

G = gap dimension,

ν = kinematic viscosity of fluid.

Experimental data on heat transfer between two parallel vertical plates, maintained at various temperature differences $T_1 - T_2$ for a gas filling, are reported in Ref. 14. It was shown that, when the product of the Grashof number $GR \times$ the Prandtl number Pr of the fluid is less than 10^3 , convection currents are so small and weak that they don't influence the heat transfer between surfaces. The product of $(Gr)(Pr)$ is evaluated for the worst ITER conditions, i.e., for the largest anticipated interfacial temperature difference and largest gap. The He gas properties are based on a temperature of 300°C. The input values are

$g = 32.2 \text{ ft/sec}^2$,

$\beta = 1 \times 10^{-3}/^\circ\text{F}$,

$(T_1 - T_2) = 150^\circ\text{C}$,

$G = 80 \mu\text{m}$,

$\nu = 375.8 \times 10^{-6} \text{ m}^2/\text{s}$,

$$Pr = 0.72.$$

Hence,

$$Gr Pr = \frac{(32.2 \text{ ft/s}^2)(1\text{m} / 3.281 \text{ ft})(10^{-3}/^{\circ}\text{F})(150^{\circ}\text{C})(9/5 ^{\circ}\text{F}/^{\circ}\text{C})(80 \times 10^{-6} \text{ m})^3 0.72}{(375.8 \times 10^{-6} \text{ m}^2/\text{s})^2}$$

$$= 6.92 \times 10^{-6} \ll 10^3.$$

Thus, natural convection does not influence heat transfer at the interface, because the gap is too small.

The preceding expression for h_i is used to aid in the design of the ITER blanket [1]. It is a primary goal of these planned experiments to determine the values of h_2 and h_4 experimentally and compare them with the values obtained from this expression. In determining h_2 and h_4 experimentally, the most direct approach is from local measurements in the sandwich rather than from an overall calculation like that given earlier, where many terms are grouped together. This, however, assumes that the required local measurements can be accurately obtained and lead to more accurate conductance values than those that can be obtained with the global equation. In conducting the experiments and reducing the data, both approaches will be utilized and the results will be compared. A reasonable degree of consistency between approaches will enhance confidence in the final results for h_2 and h_4 .

Based on the assumptions used in formulating the global sandwich equation, Fourier's law can also be written for each elemental interface of the sandwich. Hence,

$$Q = \frac{\Delta T_2}{R_2} = \frac{\Delta T_2}{1/h_2 A} = (T_{12} - T_{32})h_2 A,$$

where T_{12} is the surface temperature of the SS cover plate on the foil heater and T_{32} is the surface temperature of the Be adjacent to the hot SS plate. Thus, $h_2 = Q / (T_{12} - T_{32})A$ and likewise, for the other interface where the Be interfaces with the cold plate, $h_4 = Q / (T_{34} - T_{54})A$. The right hand side of each expression represents quantities that must be measured and the ratio of the two conductances is simply given by $h_2/h_4 = (T_{34} - T_{54})/(T_{12} - T_{32})$, which is the ratio of

the interfacial temperature differences. In practice, the ease with which these elemental equations are used relative to the ease in using the overall equation depends on instrumentation difficulties and the accuracy with which the required measurements can be obtained. In both cases, Q is more readily and accurately measured than the required surface temperatures, the measurement of which involves placement of very small thermocouples in a manner that won't modify local heat fluxes, temperature distributions, and the small interfacial gap size, and will not pick up electrical signal errors from the heaters and other sources. Measurement of surface temperature, in general, requires great care.

The overall equation for sandwich heat transfer can be rearranged to express the interfacial conductances h_2 and h_4 in terms of measurable and known quantities as follows:

$$\frac{1}{h_2} + \frac{1}{h_4} = \frac{A}{Q} (T_F - T_{H_2O}) - \left(\frac{L_1}{K_1} + \frac{L_3}{K_3} + \frac{L_5}{K_5} + \frac{1}{h_6} \right).$$

Upon inspection, it is evident that this equation can only be used to ascertain the combined effect of the two conductances. This is still of value in checking the consistency of results by comparing them with results from the two elemental equations.

7 CONCLUSIONS

An ANL facility for conducting tests on multilayered slab models of fusion blanket designs is being developed and some of its features described. This facility will allow testing under prototypic high heat fluxes, high temperatures, thermal gradients, and variable mechanical loadings in a He gas environment. Steady and transient heat flux tests are possible. Electrical heating by a thin SS two-sided electrical resistance heater plate and SS water-cooled cold panels placed symmetrically on both sides of the heater allow achievement of global one-dimensional heat transfer across blanket specimen layers sandwiched between the hot and cold plates. The heat transfer characteristics at interfaces as well as macroscale and microscale thermomechanical interactions between layers, can be studied in support of the ITER engineering design effort. The engineering design of the test apparatus has highlighted the importance of using

multidimensional thermomechanical analysis of sandwich-type composites to adequately analyze heat transfer. This fact will also be true for the engineering design of ITER.

Some important operating parameters for the high-heat-flux thermomechanical blanket performance facility are

- Electrical heater power supply 60 kW
- Heat flux maximum 50 W/cm²
- Temperature 30–800°C
- Blanket module size 20–30 cm square
(and same thickness)
- He gas pressure 0.05 – <0.10 MPa
- Mechanical loading interface contact pressure 0 – 0.05 MPa

The following types of measurements will be generated by the test facility:

- Multilayer blanket thermomechanical interactions
- Temperature distribution in constituent layers
- Heat flux at interfaces
- Thermal distortion of layers
- Interfacial heat conductances
- Contact pressure
- Thermal conductivity
- Variable environmental gas pressure
- Thermal cycling material response and degradation

REFERENCES

1. Y. Gohar, et al., "U.S. Technical Report for the ITER Blanket/Shield," ITER-TN-BL-5-0-3, Garching, Federal Republic of Germany, July-November 1990.
2. Stojimirovic, A., and Majumdar, S., "Analysis of the Thermo-Mechanical Contact Between Beryllium Blocks and Stainless Steel Plates In ITER Design," Submitted to Fusion Technology, December 1991.
3. ASTM Standard, "Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded-Hot-Plate Apparatus," Annual Book of ASTM Standards, C177-85, Vol. 14.01, 1986.
4. ASTM Standard, "Calculating Thermal Transmission Properties from Steady-State Heat Flux Measurements," Annual Book of ASTM Standards, C1045-85, 1986.
5. ASTM Standard, "Steady-State Thermal Transmission Properties by Means of the Thin-Heater Apparatus," Annual Book of ASTM Standards, C1114-89, 1989.
6. Smith, D. R., et al., "A Guarded-Hot-Plate Apparatus for Measuring Effective Thermal Conductivity of Insulations between 80K and 360K," National Bureau of Standards, NBSIR 81-1657, January 1982.
7. Garnier, J. E., and Begej, S., "Ex-Reactor Determination of Thermal Gap and Contact Conductance between Uranium Dioxide: Zircaloy-4 Interfaces: Stage I: Low Gas Pressure," NUREG/CR-0330, PNL-2696, April 1979.
8. Tye, R. P. (editor), *Thermal Conductivity*, Academic Press, Vol. 1, p. 340, 1969.
9. Stojimirovic, A., memo to K. E. Kasza, "Proposed Dimensions of the Steel Plate Panel," August 28, 1991.
10. Stojimirovic, A., memo to K. E. Kasza, "Proposed Dimensions of the Steel Plate Panel," August 15, 1991.

11. Stevenson, P F., et al., "Thermal Rectification in Similar and Dissimilar Metal Contacts," Trans. of ASME, 113, 30-36, February 1991.
12. Stojimirovic, A., memo to K. E. Kasza, "Thermal Distribution (part IV)," November 1991.
13. Somers, R. R., Fletcher, L. S., "The Thermal Conductance of Dissimilar Metals," Technical Report TEES-4547-83, Texas Engineering Experiment Station, Texas A&M University, College Station, TX, 1983.
14. Holman, J. P., *Heat Transfer*, 4th edition, McGraw-Hill, pp. 255-256, 1976.

DISTRIBUTION LIST FOR ANL/FPP/TM-262

Internal

H. Attaya	C. Johnson	D.-K. Sze
M. Billone	K. Kasza (20)	S.-W. Tam
J. Brooks	S. Majumdar	L. Turner
D. Diercks	C. Malefyt (2)	R. Valentin
D. Ehst	R. Mattas	M. Wambsganss
K. Evans	G. Myers	R. Weeks
P. Finn	B. Picologlou	FPP Files (10)
A. Fischer	C. Reed	ANL Contract File
Y. Gohar (5)	W. Shack	TIS Files (3)
A. Hassanein	D. L. Smith	ANL Patent Dept.
T. Hua	A. Stojimirovic	

External

DOE/OSTI for distribution per UC-420 (40)

Manager, Chicago Operations Office-DOE

ANL-TIS Libraries

Materials and Components Technology Division Review Committee:

H. Berger, Industrial Quality, Inc., Gaithersburg, MD

M. S. Dresselhaus, Massachusetts Institute of Technology, Cambridge, MA

S. J. Green, Electric Power Research Institute, Palo Alto, CA

R. A. Greenkorn, Purdue University, West Lafayette, IN

C.-Y. Li, Cornell University, Ithaca, NY

P. G. Shewmon, Ohio State University, Columbus

R. E. Smith, Electric Power Research Institute, NDE Ctr., Charlotte, NC

M. Abdou, University of California, Los Angeles

C. Baker, Oak Ridge National Laboratory

D. Baldwin, Pacific Northwest Laboratory

S. Berk, U.S. Department of Energy

R. Dowling, U.S. Department of Energy

D. Duquette, Rensselaer Polytechnic Institute, Troy, NY

E. Farnum, Los Alamos National Laboratory

C. Flanagan, Oak Ridge National Laboratory

D. Gelles, Pacific Northwest Laboratory

A. Glass, Lawrence Livermore National Laboratory

G. Hollenberg, Pacific Northwest Laboratory

R. Jones, Pacific Northwest Laboratory

G. Kulcinski, University of Wisconsin, Madison

A. Kumar, University of California, Los Angeles
G. Longhurst, Idaho National Engineering Laboratory
S. Piet, Idaho National Engineering Laboratory
R. Price, U.S. Department of Energy
R. Raffray, University of California, Los Angeles
A. Rowcliffe, Oak Ridge National Laboratory
M. Sawan, University of Wisconsin, Madison
M. Tillack, University of California, Los Angeles
R. Watson, Sandia National Laboratory, Albuquerque
M. Youseff, University of California, Los Angeles
S. Zinkle, Oak Ridge National Laboratory

**DATE
FILMED
8 / 18 / 92**