197
2-1-80
ANL-79-87

DR. 626
ANL-79-87

MASTER

**UNAVAILABILITY MODELING AND ANALYSIS
OF REDUNDANT SAFETY SYSTEMS**

by

Jussi K. Vaurio and Dominic Sciaudone

BASE TECHNOLOGY

ARG-200-10000

ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
Prepared for the U. S. DEPARTMENT OF ENERGY
under Contract W-31-109-Eng-38

CONTINUATION OF THIS DOCUMENT IS UNLIMITED

ANL-79-87

ARGONNE NATIONAL LABORATORY
9700 South Cass Avenue
Argonne, Illinois 60439

UNAVAILABILITY MODELING AND ANALYSIS
OF REDUNDANT SAFETY SYSTEMS

by

Jussi K. Vaurio and Dominic Sciaudone*

Reactor Analysis and Safety Division

DISCLAIMER

October 1979

*Current address: Knolls Atomic Power Laboratory, Schenectady, New York

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	9
I. INTRODUCTION	9
A. Foreword	9
B. Terminology	10
1. m/n Systems	10
2. Time Periods	11
3. Unavailability Rates	12
C. Literature Review	13
D. Scope and Objectives	16
E. Presentation of Material	17
II. UNAVAILABILITY EQUATIONS FOR SINGLE-COMPONENT SYSTEM	18
A. Definition of Terms	18
1. Time Periods	18
2. Failure Probabilities	18
B. Derivation of Unavailability Equations	20
1. Unavailability during Testing	20
2. Unavailability during Repair	20
3. Unavailability during Operational Standby	20
4. Simplification of Equations	22
C. Average Unavailability	23
D. Optimum Test Interval	23
E. Summary	24
III. SYSTEM UNAVAILABILITY EQUATIONS	25
A. Introduction	25
B. Random Testing Scheme	25
C. Uniformly Staggered Testing Scheme	25
1. Two-component Systems	26
2. Three-component Systems	28
3. Four-component Systems	30

TABLE OF CONTENTS

	<u>Page</u>
D. Nearly Simultaneous Testing Scheme	35
1. Two-component Systems.	35
2. Three-component Systems	36
3. Four-component Systems	39
E. Calculation of Optimum Test Interval	45
F. Calculation of Fractional Unavailabilities.	46
G. Summary	47
IV. COMPARISON OF ICARUS AND FRANTIC	48
A. Introduction	48
B. Differences between ICARUS and FRANTIC	48
1. Testing Schemes	48
2. Numerical Calculations	48
3. Component Types	49
4. Failure Modes	49
C. Comparison of ICARUS and FRANTIC for Simple Systems. . .	49
1. Comparison of Uniformly Staggered Testing Scheme	49
2. Comparison of Nearly Simultaneous Testing Scheme	49
D. Treatment of Multicomponent Redundancies	51
1. Test Interval, T_{eff}	51
2. Test-period Duration, τ_{teff}	51
3. Repair-period Duration, τ_{reff}	52
4. Fraction of Downtime during Testing, q_{ocff}	52
5. Remainder of the Parameters	52
E. ICARUS and FRANTIC Comparisons for Two-valves-per- redundancy Systems	53
1. Comparison of Uniformly Staggered Testing Scheme	53
2. Comparison of Nearly Simultaneous Testing Scheme	53
3. Exact Calculations for Average Unavailability of 1/3 System	55
F. Summary	57
V. ANALYSIS OF AN AUXILIARY FEEDWATER SYSTEM	58
A. Description.	58

TABLE OF CONTENTS

	<u>Page</u>
B. Data Base	59
1. Values of ρ_u and ρ_f	59
2. Values of γ_e and γ_r	60
C. Numerical Analysis	60
1. Case I: Plant Steam Available, Offsite Power Available. .	60
2. Case II: Plant Steam Not Available, Offsite Power Available	64
3. Case III: No Steam Available, No Offsite Power Available	66
4. Summary of Results	69
5. Sensitivity of ICARUS Results	71
D. Summary	73
VI. SUMMARY AND CONCLUSIONS	74
A. Summary	74
B. Recommendations for Future Work	75
APPENDICES	
A. Linearization of $\exp(-\lambda s)$	76
B. ICARUS Users' Manual	77
1. Program Summary	77
2. Program Abstract	77
3. Program Use	79
C. Flow Diagrams for ICARUS	82
D. ICARUS Program Listing	86
E. ICARUS Input and Output	102
F. Data Base for ρ_u , ρ_f , γ_e , and γ_r Type Failures	105
ACKNOWLEDGMENTS	108
REFERENCES	108

LIST OF FIGURES

<u>No.</u>	<u>Title</u>	<u>Page</u>
1.	Single-component Redundancies	10
2.	Multicomponent Redundancies	10
3.	Testing, Repair, and Operational Standby Periods of Component Test Interval	11
4.	Uniformly Staggered Testing Scheme	11
5.	Simultaneous Testing Scheme	11
6.	1/1 System Unavailability Curve from Dressler and Spindler . .	14
7.	1/1 System Unavailability Curve from Signoret	15
8.	1/1 System Unavailability Curve from Apostolakis and Bansal . .	15
9.	1/1 System Unavailability Curve from Vesely and Goldberg . . .	16
10.	Simplified Drawing of Auxiliary Feedwater System	58
11.	System Drawing for Cases I and II	61
12.	Average Unavailability vs Test Interval for Case I	64
13.	Average Unavailability vs Test Interval for Case II	66
14.	System Drawing for Case III	67
15.	Average Unavailability vs Test Interval for Case III	69
C.1.	Flow Diagram for MAIN Routine	82
C.2.	Flow Diagram for CALC Subroutine	84
C.3.	Flow Diagram for ITERAT Subroutine	85

LIST OF TABLES

<u>No.</u>	<u>Title</u>	<u>Page</u>
I.	Variable Symbols and Definitions	19
II.	Unavailability Equations during Testing, Repair, and Operational-standby Periods	24
III.	Average Unavailability Equations for m/n Systems with Random Testing Scheme	25
IV.	Errors in $(T/2)^n - \theta^n \approx (T/2)^n$ Approximation	27
V.	Errors in $(T/3)^n - \theta^n \approx (T/3)^n$ Approximation	27
VI.	Errors in $(T/4)^n - \theta^n \approx (T/4)^n$ Approximation	27
VII.	Errors in $T^n - (\theta + \tau_t)^n \approx T^n$ Approximation	36
VIII.	Errors in $T^n - (\theta + 2\tau_t)^n \approx T^n$ Approximation	37
IX.	Errors in $T^n - (\theta + 3\tau_t)^n \approx T^n$ Approximation	41
X.	Equation Numbers for System Unavailability	45
XI.	Input Data for Single-valve Redundancy.	50
XII.	Comparison of ICARUS and FRANTIC Results for Uniformly Staggered Testing	50
XIII.	Comparison of ICARUS and FRANTIC Results for Nearly Simultaneous Testing	51
XIV.	ICARUS and FRANTIC Input Values for Multicomponent Redundancies	53
XV.	Comparison of ICARUS and FRANTIC Results for Two Valves per Redundancy and Uniformly Staggered Testing	54
XVI.	Comparison of ICARUS and FRANTIC Results for Two Valves per Redundancy and Nearly Simultaneous Testing	54
XVII.	Parameter Values for Test System	56
XVIII.	ICARUS Results for Case I.	63
XIX.	ICARUS Results for Case II	65
XX.	ICARUS Results for Case III.	68
XXI.	Summary of Data from All Cases	70
XXII.	Results of Sensitivity Studies	72
A.1.	λs vs $1 - \exp(-\lambda s)$	76

UNAVAILABILITY MODELING AND ANALYSIS OF REDUNDANT SAFETY SYSTEMS

by

Jussi K. Vaurio and Dominic Sciaudone

ABSTRACT

Analytical expressions have been developed to estimate the average unavailability of an m-out-of-n (m/n , $1 \leq m \leq n \leq 4$) standby safety system of a nuclear power plant. The expressions take into account contributions made by testing, repair, equipment failure, human error, and different testing schemes. A computer code, ICARUS, has been written to incorporate these analytical equations. The code is capable of calculating the average unavailability, optimum test interval, and relative contributions of testing, repair, and random failures for any of three testing schemes.

After verification of the methodology and coding in ICARUS, a typical auxiliary feedwater system of a nuclear power plant was analyzed. The results show that the failure modes associated with testing and true demands contribute considerably to the unavailability and that Diesel generators are the most critical components contributing to the overall unavailability of the system.

I. INTRODUCTION

A. Foreword

The development of nuclear power as a viable energy source has put added emphasis on making reactor systems as safe as possible. Reactor designers bear the responsibility of designing systems in which accidents are rare and of developing special systems to mitigate the consequences of an accident if one should occur. As a result, redundant standby safety systems are built into nuclear power plants. These systems do not operate under normal conditions, but should be ready to respond if some emergency situation develops. The emergency core cooling system (ECCS) and the auxiliary feedwater system (AFWS) are two examples of this type of standby safety system. These systems are periodically tested to ensure prompt availability upon demand.

Due to the nature of mechanical components and the human interactions with them, there is a finite probability that the standby system may fail to function once it has been called upon. The factors contributing to this unavailability may range from the random failure of a component in the system, to simply taking the component out of service to test its operability. A method capable of estimating the unavailability of a system as a function of various types of failure modes would greatly aid in determining which factors contribute most to the unavailability and may lead to modifications to the system or maintenance schedules that would reduce the probability of failing to start upon demand.

B. Terminology

Before discussing some of the previous work done on this subject, we will present some basic background and terminology.

1. m/n Systems

A system is designated as being m-out-of-n (m/n) when it is made up of n redundancies, m of which must be available for the system to be available. Clearly, m must be less than or equal to n . For example, an emergency power system may consist of three separate devices, any one of which can supply the demand. This system is designated as being a $1/3$ system.

Each redundancy and system may be composed of single components in parallel (Fig. 1) or a series of components in parallel (Fig. 2). For simplicity, further references will be to single- rather than multicomponent redundancies where each redundancy will be referred to as a component.

Fig. 1. Single-component Redundancies

Fig. 2. Multicomponent Redundancies

Each component in the system is tested periodically, and the following definitions are used: test interval, test period, repair period, and operational standby period.

2. Time Periods

The test period is the time when the component is checked to see if it is operational. If necessary, the component then goes into a repair period. Here, all repairs are done and the component is retested to make sure the repair was successful. Finally, the tested and repaired component goes on operational standby until the next test period. A test interval is the time between the start of successive test periods. These periods are shown schematically in Fig. 3.

Fig. 3. Testing, Repair, and Operational Standby Periods of Component Test Interval

A test interval can be identified for an individual component within a system or for the system itself. In either case, the test interval will be determined by the testing scheme, which may be uniformly staggered, simultaneous, or random. In the uniformly stag-

gered testing scheme, the testing of the components is performed at equally spaced times throughout the test interval as indicated in Fig. 4. In the simultaneous testing scheme, all n components are tested at the beginning of the test interval, as shown in Fig. 5. No two components are voluntarily taken out of service exactly simultaneously, but one after another. Finally, in the random testing scheme, each component is tested at randomly shifted times during the test interval.

Fig. 4

Uniformly Staggered Testing Scheme
(Three-component system, 720-h test interval)

Fig. 5

Simultaneous Testing Scheme
(Three-component system, 720-h test interval)

3. Unavailability Rates

If a component has only random mechanical failures, then its availability or reliability is simply a function of its random failure rate, λ . If $R(s)$ is the availability at some time s , then the availability at any time $s + ds$ can be written as

$$R(s + ds) = R(s)(1 - \lambda ds), \quad (1)$$

where λds is the probability of the component failing during time ds .

The availability at any time s is found by rearranging Eq. 1 and by the calculus to yield

$$R(s) = \exp\left(-\int_0^s \lambda ds\right),$$

where it is assumed that $R(0)$ is unity.

If λ is constant during the time interval of interest,

$$R(s) = \exp(-\lambda s). \quad (2)$$

Another way to use this result is to note that, if the availability falls off exponentially, then the failure rate is a constant and can be interpreted as being equal to the reciprocal of the mean time to component failure.¹

The unavailability of the component is defined as the complement of the availability and is given the symbol $u(s)$. Thus, for a constant failure rate,

$$u(s) = 1 - \exp(-\lambda s). \quad (3)$$

The unavailability of a component at the end of a test interval due to random failures only during the test interval T , is given by

$$u(T) = 1 - \exp(-\lambda T). \quad (4)$$

However, at the end of an arbitrary test interval, we would expect the unavailability to be at some different value than this, since the component may have been taken out of service during testing or underwent some repair during the test interval. An asymptotic state is defined when the value of $u(T)$ no longer changes so that the unavailability at any time is then equal to the unavailability at that same time in any subsequent test interval. This idealization is a sensible approximation, especially after two or three test intervals, when the initial system faults have been worked out.

The average unavailability $\bar{u}$ is defined as

$$\bar{u}(T) = \frac{\int_0^T u(s) ds}{\int_0^T ds}. \quad (5)$$

In the asymptotic state, $\bar{u}$ is a function of only the test interval, T , not of the absolute time from the beginning of the plant operation. There exists an optimum value for the test interval such that the lowest average asymptotic unavailability for the system will be achieved. This value, T_0 , is defined by

$$\frac{d\bar{u}}{dT} = 0. \quad (6)$$

If a system undergoes only random failures, then the average unavailability can be determined by Eqs. 3 and 5 to be

$$\bar{u}(T) = 1 - 1/\lambda T + (1/\lambda T)\exp(-\lambda T).$$

Using Eq. 6, we find the optimum test interval T_0 to be

$$T_0 = 0.$$

This result means that, as long as the component is continually tested, the system is always available. Although this is not realistic since, for example, downtime during testing has been neglected, Eqs. 5 and 6 can be applied to more rigorously derived unavailability equations and more meaningful values of the average unavailability and optimum test intervals can be determined. These topics are covered in Chapter II of this report.

C. Literature Review

Several researchers have addressed the subject of unavailability analysis and optimum testing intervals. Dressler and Spindler² have analytically calculated the time-dependent and average unavailabilities for all periodically tested safety systems with m/n ($1 \leq m \leq n \leq 4$) redundancy for both staggered and simultaneous testing schemes. The methodology assumes constant failure rate, repair time, and test intervals, along with a test-period duration of zero. Testing is assumed not to take the component "off-line," thus allowing no errors during testing.

The results for a 1/1 system give rise to a sawtooth-shaped curve shown in Fig. 6. Since the failure of the component is due only to random causes, the optimum test interval is zero. Although many realistic failure

modes are missing in this model, it contains perhaps the most comprehensive analytical equations currently available for the unavailability of m/n standby systems.

Fig. 6. 1/1 System Unavailability Curve from Dressler and Spindler²

Signoret³ attempts to analyze the contributions made to component failure not only from random failures, but from other sources as well. As in the previous reference, the failure rate and test interval are assumed to be constant and the test duration is zero. The repair period, however, is presented in the form of a constant repair rate or mean time to repair. Also included is the probability of failing to start due to a test-caused failure and the probability of failing to start due to a true demand. These results give rise to the curve in Fig. 7.

The discontinuity of the curve at $s = 0, T, 2T$, etc., is due to the probability that a test fails the component. The curve then drops off exponentially as a result of the constant repair rate before increasing again due to the constant failure rate. Analytical expressions are not derived for the other m/n ($m, n > 1$) systems. Instead, 1/1 curves such as is found in Fig. 7 for various components are multiplied or added together to get numerical results for multicomponent systems.

A further step toward a more realistic assessment of safety-system unavailability has been taken by Apostolakis and Bansal.⁴ An attempt is made to recognize the contributions of human errors and common-cause errors to system unavailability where a finite probability is given for leaving a tested component in a failed state. The probability of failure due to a real demand is also taken into account.

Fig. 7. 1/1 System Unavailability Curve from Signoret³

Other assumptions made by Apostolakis and Bansal are the use of constant failure rates, constant test interval, and constant test duration. Furthermore, it is assumed that the component is down throughout the test period and that this period includes all the repair time needed to bring the component on line. The unavailability as a function of time for this method is found in Fig. 8. Note that the component is completely unavailable [$u(s) = 1.0$] throughout the test ($0 < s \leq \tau_t$). Another feature of this curve is the linearization of the random-failure contribution to the operational standby-phase unavailability. This assumption is discussed further in Appendix A.

Fig. 8. 1/1 System Unavailability Curve from Apostolakis and Bansal⁴

Vesely and Goldberg^{5,6} have developed the FRANTIC computer code, which calculates time-dependent and average unavailabilities due to the effects of test downtime, repair time, test-caused failures, and test staggering. The failure rate, test interval, test time, and repair time are constant, and all detectable failures are assumed to be detected and repaired. A typical unavailability curve for the FRANTIC code methodology is shown in Fig. 9. Note that the unavailability is constant during testing ($0 < s \leq \tau_t$) and repair ($\tau_t < s \leq \tau_t + \tau_r$) and that the linearization for the random-failure contribution is used. The FRANTIC code is discussed further in Chapter IV.

Fig. 9. 1/1 System Unavailability Curve from Vesely and Goldberg⁵

A comprehensive unavailability model has been developed by Vaurio⁷ for a single standby component and for a series system consisting of several components. Reference 7 can be viewed as a theoretical framework and basis for many assumptions made in this work.

D. Scope and Objectives

The scope of the present work is to identify as many types of failure modes as possible and to include them in the development of analytical expressions for estimating the unavailability of redundant safety systems. (The word "type" is used in this context to distinguish between human, random, and mechanical failures.) To achieve this, the basic equations from FRANTIC⁶ are modified and new variables incorporated to represent new types of failures. Average unavailabilities are then calculated for all m/n systems ($1 \leq m \leq n \leq 4$) for uniformly staggered, nearly simultaneous, and random-testing schemes. In addition to this, the optimum test interval and fractional unavailabilities due to testing, repair, and random failure are evaluated.

A computer code, ICARUS, has been written to incorporate the new equations. Since the exact integrals and derivatives indicated in Eqs. 5 and 6 have been analytically programmed, no time-consuming numerical methods are used in arriving at the average unavailabilities and optimum test intervals. Consequently, the running time is short, and coupling with the probabilistic response-surface code PROSA⁸ to do sensitivity analysis of the input data is facilitated. Several sets of simple systems have been analyzed with ICARUS to test the efficacy of the new equations and programming.

A final objective of this work is to apply the ICARUS code to an actual standby safety system. Using data collected from various sources, we analyzed an auxiliary feedwater system of a pressurized water reactor (PWR).

E. Presentation of Material

Chapter II describes the basic equations for treating a single-component (1/1) system. Each parameter is defined, and the unavailability equations for testing, repair, and operational standby periods are developed.

The system average unavailability equations are derived in Chapter III for m/n systems where $1 \leq m \leq n \leq 4$. Included are the system unavailability equations for the random, uniformly staggered, and nearly simultaneous testing schemes that have been programmed into the ICARUS computer code.

Chapter IV compares the ICARUS and the FRANTIC computer codes. A short description of FRANTIC is followed by a comparison of results between the two codes for single- and multicorponent redundancy systems. Details of the ICARUS computer code including flow charts, listing, and a users' manual are given in the appendices.

An auxiliary feedwater system is described and analyzed using the ICARUS code in Chapter V. An analysis is performed to determine the sensitivity of selected output variables to the input data.

Finally, in Chapter VI, the conclusions drawn from this research are presented along with recommendations for future work.

II. UNAVAILABILITY EQUATIONS FOR SINGLE-COMPONENT SYSTEM

In this chapter, the terms used in the development of the unavailability equations are defined and discussed. Also, the unavailability equations for the test, repair, and operational-standby periods are developed leading to the average unavailability and optimum test interval of a 1/1 system.

A. Definition of Terms

Although some of the methods and ideas developed by the authors of previous works were the same, different symbols were used in many cases to represent the same concept. The most commonly used symbols will be used in this work.

1. Time Periods

The test interval, T , is defined as the time between the starts of two consecutive tests for any one component. The variable s is the time since the beginning of the interval. The interval, therefore, starts at $s = 0$ and ends at $s = T$. The test interval is typically one month (720 h) long.

The beginning of a test interval is marked by a component test. The length of this period, τ_t , depends on the component undergoing testing. Immediately after the test, a repair period is begun and lasts for a period τ_r . Again the length of τ_r is dictated by the component. The sum of the test and repair times is given the symbol θ . At time $s = \theta$, the component is ready to go into operational standby for the remainder of the test interval.

2. Failure Probabilities

During the test period, a component may be taken "off-line" for a certain amount of time to perform the test. The variable, q_c , is defined as the fraction of the test period that the component is unavailable to answer a real demand.

There is a finite probability that when the safety system is tested, the very act of operating the component may cause it to fail. This can occur in two ways in the testing period. With a probability of γ_e (per test), a failure is caused that is detected and the component is repaired and ready to go into operational standby at $s = \theta$. With a probability of ρ_u (per test), a failure is caused that is not repaired after the test. This nonrepair could be due to human negligence or some type of hidden failure not detected by testing.

The component breaks down on the initiation of a real or true demand with a probability of γ_r (per true demand). The distinction between γ_e and γ_r is the initiating event. Human errors may play a larger role in γ_e and ρ_u than in γ_r .

This work assumes that true demands are rare events compared to the testing frequency. With this assumption, the unavailability (= the probability that the component does not perform its function if needed at time s) can be written as⁷

$$u(s) = \gamma_r + (1 - \gamma_r)u(s|\gamma_r = 0),$$

where $u(s|\gamma_r = 0)$ contains contributions from all failures other than those caused by true demands.

A component may go into a test in a failed state due to the failure-rate contribution λ , or any of the test-related failures. This probability is designated $\hat{u}$. It may, however, not be detected as being failed, or, if detected, not properly repaired. This may be due to human testing error, repair error, or some kind of detection error. This is defined as occurring with a probability of ρ_f (per test).

The terms and their meanings relative to this work are summarized in Table I.

TABLE I. Variable Symbols and Definitions

T	Test interval
s	Time since beginning of test interval
τ_t	Test-period duration
τ_r	Repair-period duration
θ	Sum of τ_t and τ_r
q_0	Fraction of τ_t that component is down
γ_c	Probability of failure due to a test demand that is repaired
ρ_u	Probability of failure due to a test demand that is not repaired
γ_r	Probability of failure due to a true demand
ρ_f	Probability that a failed component is not detected by a test or not repaired
λ	Failure rate of component
$\hat{u}$	Probability that a component enters the test failed
δ	$\rho_f - \rho_u$
$\bar{\alpha}$	$1 - \alpha$, where α is any of the previously defined probabilities

B. Derivation of Unavailability Equations

1. Unavailability during Testing

A component may be unavailable in its test period because it came into the test failed, it failed during the test, or it may be down a fraction of the test time to perform the test. These events are mutually exclusive, and by using the definitions in Table I, the unavailability during testing, u_T , can be written as

$$0 < s \leq \tau_t, u_T(s) = q_0 + \bar{q}_0 \gamma_e + \bar{q}_0 \bar{\gamma}_e \bar{\gamma}_r + \bar{q}_0 \bar{\gamma}_e \bar{\gamma}_r \rho_u + \bar{q}_0 \bar{\gamma}_e \bar{\gamma}_r \bar{\rho}_u \hat{u} \\ + \bar{q}_0 \bar{\gamma}_e \bar{\gamma}_r \bar{\rho}_u \bar{\hat{u}} \lambda s, \quad (7)$$

where

λs = linearized probability of random component failure. (See Appendix A for further discussions.)

If γ_e , γ_r , and ρ_u are small ($\ll 1$),* Eq. 7 can be written as

$$0 < s \leq \tau_t, u_T(s) = q_0 + (1 - q_0)[\gamma_e + \gamma_r + \rho_u + \hat{u} + (1 - \hat{u})\lambda s]. \quad (8)$$

2. Unavailability during Repair

A component in its repair period may be unavailable due to a failure occurring before or during the repair period. Again these are mutually exclusive, and the unavailability can be written as

$$\tau_t < s \leq \theta, u_R(s) = \gamma_e + \bar{\gamma}_e \gamma_r + \bar{\gamma}_e \bar{\gamma}_r \rho_u + \bar{\gamma}_e \bar{\gamma}_r \bar{\rho}_u \hat{u} + \bar{\gamma}_e \bar{\gamma}_r \bar{\rho}_u \bar{\hat{u}} \lambda s. \quad (9)$$

Again note that, if γ_e , γ_r , and ρ_u are small ($\ll 1$), Eq. 9 becomes

$$\tau_t < s \leq \theta, u_R(s) = \gamma_e + \gamma_r + \rho_u + \hat{u} + (1 - \hat{u})\lambda s. \quad (10)$$

3. Unavailability during Operational Standby

In this period, a component may be failed because of a previous event, or may fail due to a real demand or random failure. The unavailability during this time can be written as

$$\theta < s \leq T, u(s) = \gamma_r + \bar{\gamma}_r(\hat{u}\rho_f + \bar{\hat{u}}\rho_u) + \bar{\gamma}_r[1 - (\hat{u}\rho_f + \bar{\hat{u}}\rho_u)]\lambda s. \quad (11)$$

The term $\hat{u}\rho_f + \bar{\hat{u}}\rho_u$ evolves from the fact that the probability of a failure not being detected prior to testing can only be valid if the component is failed before the test ($\hat{u}$), and if it was not failed ($\bar{\hat{u}}$), the ρ_u probability is valid.

* γ_e , γ_r , and ρ_u are usually on the order of 10^{-3} .

Neglecting second- and higher-order terms gives

$$\theta < s \leq T, u(s) = \gamma_r + \rho_u + (\rho_f - \rho_u)\hat{u} + \lambda s. \quad (12)$$

Using Eq. 12, we can develop an expression for $\hat{u}$. It was previously said that $\hat{u}$ was the probability of entering the test period in a failed state. This would correspond to $u(T)$, given that there were no true demand failures ($\gamma_r = 0$). This line of thought is used since true demands are few (i.e., rare events), and if a failure during a true demand should occur, steps would be taken to repair the component immediately. Thus,

$$\left. \begin{aligned} \hat{u} &= u(T | \gamma_r = 0), \text{ or } \hat{u} = \rho_u + \lambda T + \hat{u}(\rho_f - \rho_u), \\ \text{and} \\ \hat{u} &= \frac{\rho_u + \lambda T}{1 - \delta}, \end{aligned} \right\} \quad (13)$$

where

$$\delta = \rho_f - \rho_u.$$

Equation 13 can be inserted into Eq. 8, giving

$$\begin{aligned} 0 < s \leq \tau_t, u_T(s) &= q_0 + (1 - q_0) \left[\gamma_e + \gamma_r + \rho_u \left(1 + \frac{1}{1 - \delta} \right) \right. \\ &\quad \left. + \lambda s \left(1 + \frac{\rho_u}{1 - \delta} \right) + \frac{\lambda T}{1 - \delta} (1 - \lambda s) \right]. \end{aligned} \quad (14)$$

Since $\lambda \tau_t$ is usually orders of magnitude less than ρ_u , Eq. 14 can be written as

$$0 < s \leq \tau_t, u_T(s) = q_0 + (1 - q_0) \left(\gamma_e + \gamma_r + \rho_u \frac{2 - \delta}{1 - \delta} + \lambda s + \frac{\lambda T}{1 - \delta} \right). \quad (15)$$

Using the same method and approximations, we can rewrite Eq. 10 as

$$\tau_t < s \leq \theta, u_R(s) = \gamma_e + \gamma_r + \rho_u \frac{2 - \delta}{1 - \delta} + \lambda s + \frac{\lambda T}{1 - \delta}. \quad (16)$$

Finally, Eq. 12 can be written as

$$\theta < s \leq T, u(s) = \gamma_r + \frac{\rho_u}{1 - \delta} + \lambda \left(s + \frac{\delta T}{1 - \delta} \right). \quad (17)$$

4. Simplification of Equations

To derive the unavailability formulas for the various systems, the basic unavailability equations must be simplified. Equation 15 can be written as

$$0 < s \leq \tau_t, u_T(s) = A + aT, \quad (18)$$

where

$$A = q_0 + (1 - q_0) \left(\gamma_e + \gamma_r + \rho_u \frac{2 - \delta}{1 - \delta} \right)$$

and

$$a = (1 - q_0)\lambda.$$

The λs term was dropped since the $\lambda \tau_t$ contribution to $u_T(s)$ is small compared to the rest of the terms. This can also be interpreted as if random failures are immediately repaired during the testing and repair periods. Also, since $\delta \ll 1$, the $(1 - q_0)\lambda / (1 - \delta)$ term was simplified to $(1 - q_0)\lambda$ in the expression for a .

Using the same logic, we can write Eq. 16 as

$$\tau_t < s \leq \theta, u_R(s) = B + bT, \quad (19)$$

where

$$B = \gamma_e + \gamma_r + \rho_u \frac{2 - \delta}{1 - \delta}$$

and

$$b = \lambda.$$

For the operational standby phase, the unavailability is

$$\theta < s \leq T, u(s) = C + cT + D'\lambda s, \quad (20)$$

where

$$C = \gamma_r + \frac{\rho_u}{1 - \delta},$$

$$c = \frac{\lambda \delta}{1 - \delta},$$

and

$$D' = 1.0.$$

Equation 20 can be further simplified by setting $c = 0$ and redefining the D' terms to account for the loss. At $s = T/2$,

$$u(T/2) = C + cT + D'\lambda T/2 = C + D\lambda T/2,$$

which leads to

$$D = \frac{1 + \delta}{1 - \delta}.$$

So,

$$\theta < s \leq T, u(s) = C + D\lambda s. \quad (21)$$

This preserves the average unavailability in the interval and makes the term easier to work with.

C. Average Unavailability

A 1/1 system has one component that must always be available for the system to be available. For this system, the average unavailability is given by

$$\bar{U} = \frac{1}{T} \int_0^{\tau_t} u_L(s) ds + \frac{1}{T} \int_{\tau_t}^{\theta} u_R(s) ds + \frac{1}{T} \int_{\theta}^T u(s) ds. \quad (22)$$

Integrating and rearranging terms yield

$$\bar{U} = (1/T)(\tau_t A' + \tau_r B') + \tau_t a + \tau_r b + C + (1/T)(T^2 - \theta^2)D\lambda/2, \quad (23)$$

where

$$A' = A - C \text{ and } B' = B - C.$$

Since $\theta \ll T$, $T^2 - \theta^2 \approx T^2$ and Eq. 23 can be written

$$\bar{U} = (1/T)(\tau_t A' + \tau_r B') + \tau_t a + \tau_r b + C + D\lambda T/2. \quad (24)$$

D. Optimum Test Interval

The optimum test interval is the solution of $d\bar{U}/dT = 0$ for T_0 or

$$-(1/T_0^2)(\tau_t A' + \tau_r B') + D\lambda/2 = 0,$$

so that

$$T_0 = \sqrt{\frac{2}{D\lambda}(\tau_t A' + \tau_r B')}. \quad (25)$$

These results follow directly from the concepts developed in Chapter I, Eqs. 5 and 6.

E. Summary

The terms used in this work were discussed in Sec. II.A. They were then used to develop the basic unavailability equations for a component in each of its three test-interval periods. From these equations, the average unavailability equation for a 1/1 system was calculated. This also allowed the calculation of the optimum test interval.

The 1/1 system equations form the cornerstone on which more complicated system equations can be built. The unavailability equations derived for a component in its three phases of operation are summarized in Table II.

TABLE II. Unavailability Equations during Testing, Repair, and Operational-standby Periods

Period	Time	Unavailability Equation
Testing	$0 < s \leq \tau_t$	$A + aT$
Repair	$\tau_t < s \leq \theta$	$B + bT$
Standby	$\theta < s \leq T$	$C + D\lambda s$

where

$$A = q_0 + (1 - q_0)\{\gamma_e + \gamma_r + \rho_u[(2 - \delta)/(1 - \delta)]\},$$

$$a = (1 - q_0)\lambda,$$

$$B = \gamma_e + \gamma_r + \rho_u[(2 - \delta)/(1 - \delta)],$$

$$b = \lambda,$$

$$C = \gamma_r + \rho_u/(1 - \delta),$$

and

$$D = (1 + \delta)/(1 - \delta).$$

III. SYSTEM UNAVAILABILITY EQUATIONS

A. Introduction

This chapter will introduce and develop the average unavailability equations for all m/n single-component redundancy systems with $1 \leq m \leq n \leq 4$, for the random, uniformly staggered, and nearly simultaneous testing schemes.

B. Random Testing Scheme

In the random testing scheme, the components are tested at randomly shifted times throughout the interval. The average unavailability for any m/n system can be given by the expression

$$\bar{U}_{m/n} = \sum_{k=n-m+1}^n \binom{n}{k} \bar{U}^k (1 - \bar{U})^{n-k}, \quad (26)$$

where $\bar{U}$ is the $\bar{U}$ of Eq. 24 and $\binom{n}{k}$ is the binomial coefficient $n! / [(n-k)!k!]$.

All systems tested in this random scheme have the same optimum test interval. This interval, T_0 , is defined by Eq. 25 and is thought of as being the optimum average test interval.

The equations for the average unavailability of any m/n ($1 \leq m \leq n \leq 4$) system tested using the random testing scheme are listed in Table III.

TABLE III. Average Unavailability Equations for m/n Systems with Random Testing Scheme

m/n	$\bar{U}_{m/n}$	m/n	$\bar{U}_{m/n}$
1/2	$\bar{U}^2$	1/4	$\bar{U}^4$
2/2	$2\bar{U} - \bar{U}^2$	2/4	$4\bar{U}^3 - 3\bar{U}^4$
1/3	$\bar{U}^3$	3/4	$6\bar{U}^2 - 8\bar{U}^3 + 3\bar{U}^4$
2/3	$3\bar{U}^2 - 2\bar{U}^3$	4/4	$4\bar{U} - 6\bar{U}^2 + 4\bar{U}^3 - \bar{U}^4$
3/3	$3\bar{U} - 3\bar{U}^2 + \bar{U}^3$		

where

$$\bar{U} = (1/T)[\tau_t(A - C) + \tau_r(B - C)] + \tau_t a + \tau_r b + C + D\lambda T/2. \quad (\text{Eq. 24})$$

C. Uniformly Staggered Testing Scheme

In the uniformly staggered testing scheme, the components are tested at times $s = 0, T/n, 2T/n, \dots, (n-1)T/n$. The average unavailability equations for a 1/1 system are equivalent, no matter which testing scheme is used. Thus, the equations for systems with two or more redundancies will be presented.

1. Two-component Systems

If two components are in the system, it can be either a 1/2 system (only one need be available) or a 2/2 system (both available).

a. One-out-of-two (1/2) System. For a 1/2 system, the unavailability is the probability that one component is unavailable times the probability that the second component is also unavailable. This product is simply $U(s)U(s + T/2)$ for each of the three periods or

$$0 < s \leq \tau_t, U(s) = (A + aT)(C + D\lambda T/2), \quad (27)$$

$$\tau_t < s \leq \theta, U(s) = (B + bT)(C + D\lambda T/2), \quad (28)$$

and

$$\theta < s \leq T/2, U(s) = (C + D\lambda s)[C + D\lambda(s + T/2)]. \quad (29)$$

Since the durations of both the test (τ_t) and the repair (τ_r) are short compared to T , the unavailability of the component that is on operational standby is held constant while the first component is undergoing test and repair.

The average unavailability for this system is

$$\bar{U}_{1/2} = \frac{2}{T} \int_0^{T/2} U(s)U(s + T/2)ds. \quad (30)$$

Note that the integration is performed over only half the interval since, when the first component reaches time $s = T/2$, the second component begins testing.

Integrating Eq. 30 and gathering terms yields

$$\begin{aligned} \bar{U}_{1/2} = & (2C/T)(\tau_t A' + \tau_r B') + 2C(\tau_t a + \tau_r b + C/2) + D\lambda(\tau_t A' + \tau_r B') \\ & + D\lambda T(\tau_t a + \tau_r b) + (2/T)(2CD\lambda + D^2\lambda^2 T/2)(T^2/4 - \theta^2) \\ & + (2D\lambda/3T)(T^3/6 - \theta^3). \end{aligned} \quad (31)$$

If $T = 720$ h, $\tau_t = 2$ h, and $\tau_r = 15$ h, Tables IV-VI show the errors incurred by making various approximations. For $n > 1$ and $k = 2, 3, 4$, approximating $(T/k)^n - \theta^n$ by $(T/k)^n$ gives rise to an error of less than 1% in each case. These approximations will be used in the applicable system unavailability equations.

TABLE IV. Errors in $(T/2)^n - \theta^n \approx (T/2)^n$ Approximation

n	$(T/2)^n$	θ^n	Percent Error ^a
1	360	17	4.96
2	1.30×10^5	2.89×10^2	0.22
3	4.67×10^7	4.91×10^3	0.01
4	1.68×10^{10}	8.35×10^4	4.97×10^{-4}
5	6.05×10^{12}	1.42×10^6	2.35×10^{-5}

$$^a \frac{\theta^n}{(T/2)^n - \theta^n} \times 100\%.$$

TABLE V. Errors in $(T/3)^n - \theta^n \approx (T/3)^n$ Approximation

n	$(T/3)^n$	θ^n	Percent Error ^a
1	240	17	7.62
2	5.76×10^4	2.89×10^2	0.504
3	1.38×10^7	4.91×10^3	3.56×10^{-2}
4	3.32×10^9	8.35×10^4	2.52×10^{-3}
5	7.96×10^{11}	1.42×10^6	1.78×10^{-4}

$$^a \frac{\theta^n}{(T/3)^n - \theta^n} \times 100\%.$$

TABLE VI. Errors in $(T/4)^n - \theta^n \approx (T/4)^n$ Approximation

n	$(T/4)^n$	θ^n	Percent Error ^a
1	100	17	10.43
2	3.24×10^4	2.89×10^2	0.90
3	5.83×10^6	4.91×10^3	0.084
4	1.05×10^9	8.35×10^4	7.96×10^{-3}
5	1.89×10^{11}	1.42×10^6	7.51×10^{-4}

$$^a \frac{\theta^n}{(T/4)^n - \theta^n} \times 100\%.$$

Equation 31 can be simplified to

$$\begin{aligned}\bar{U}_{1/2} = & (2C/T)(\tau_t A' + \tau_r B') + 2C(\tau_t a + \tau_r b + C/2) + D\lambda(\tau_t A' + \tau_r B') \\ & + D\lambda T(\tau_t a + \tau_r b + C) + (5/24)D^2\lambda^2 T^2.\end{aligned}\quad (32)$$

b. Two-out-of-two (2/2) System. In the 2/2 system, it is easier to think in terms of the availability of the system, $(1 - U_{2/2})$. In this case, the system is available only if both components are available:

$$1 - U_{2/2} = (1 - U_1)(1 - U_2)$$

or

$$U_{2/2} = 1 - (1 - U_1)(1 - U_2).\quad (33)$$

So for this system,

$$0 < s \leq \tau_t, U(s) = 1 - [1 - (A + aT)][1 - (C + D\lambda T/2)],\quad (34)$$

$$\tau_t < s \leq \theta, U(s) = 1 - [1 - (B + bT)][1 - (C + D\lambda T/2)],\quad (35)$$

and

$$\theta < s \leq T/2, U(s) = 1 - [1 - (C + D\lambda s)]\{1 - [C + D\lambda(s + T/2)]\}.\quad (36)$$

The average unavailability is then given by

$$\begin{aligned}\bar{U}_{2/2} = & \frac{2(1 - C)}{T}(\tau_t A' + \tau_r B') + 1 + 2(1 - C)(\tau_t a + \tau_r b) \\ & - D\lambda(\tau_t A' + \tau_r B') - (C - 1)^2 - D\lambda T(\tau_t a + \tau_r b + C - 1) \\ & - (5/24)D^2\lambda^2 T^2.\end{aligned}\quad (37)$$

2. Three-component Systems

If there are three components in the system, it can be a 1/3, 2/3, or 3/3 system. The average unavailability is given by

$$\bar{U} = \frac{3}{T} \int_0^{T/3} U(s) ds.\quad (38)$$

a. One-out-of-three (1/3) System. For a 1/3 system, the unavailability is the product of the unavailability of the three components:

$$0 < s \leq \tau_t, U(s) = (A + aT)(C + D\lambda T/3)(C + 2D\lambda T/3),\quad (39)$$

$$\tau_t < s \leq \theta, U(s) = (B + bT)(C + D\lambda T/3)(C + 2D\lambda T/3), \quad (40)$$

and

$$\theta < s \leq T/3, U(s) = (C + D\lambda s)[C + D\lambda(s + T/3)][C + D\lambda(s + 2T/3)]. \quad (41)$$

Again, since the durations of the test and repair periods are much shorter than $T/3$, the unavailabilities of the components on operational standby can be treated as being constant.

The average unavailability for a 1/3 system is

$$\begin{aligned} \bar{U}_{1/3} = & (3C^2/T)(\tau_t A' + \tau_r B') + 3C^2(\tau_t a + \tau_r b) + 3CD\lambda(\tau_t A' + \tau_r B') \\ & + C^3 + D\lambda T[3C(\tau_t a + \tau_r b) + (2/3)D\lambda(\tau_t A' + \tau_r B') + (3/2)C^2] \\ & + (2/3)D^2\lambda^2 T^2(\tau_t a + \tau_r b + C) + (1/12)D^3\lambda^3 T^3. \end{aligned} \quad (42)$$

b. Two-out-of-three (2/3) System. A 2/3 system is unavailable when any two components are unavailable:

$$\begin{aligned} U_{2/3} = & U_1 U_2 (1 - U_3) + U_1 U_3 (1 - U_2) + U_2 U_3 (1 - U_1) + U_1 U_2 U_3 \\ = & U_1 U_2 + U_1 U_3 + U_2 U_3 - 2U_1 U_2 U_3. \end{aligned} \quad (43)$$

The unavailabilities in each of the periods in the test interval are

$$\begin{aligned} 0 < s \leq \tau_t, U(s) = & (A + aT)(C + D\lambda T/3) + (A + aT)(C + 2D\lambda T/3) \\ & + (C + D\lambda T/3)(C + 2D\lambda T/3) - 2(A + aT)(C + D\lambda T/3)(C + 2D\lambda T/3), \end{aligned} \quad (44)$$

$$\begin{aligned} \tau_t < s \leq \theta, U(s) = & (B + bT)(C + D\lambda T/3) + (B + bT)(C + 2D\lambda T/3) \\ & + (C + D\lambda T/3)(C + 2D\lambda T/3) - 2(B + bT)(C + D\lambda T/3)(C + 2D\lambda T/3), \end{aligned} \quad (45)$$

and

$$\begin{aligned} \theta < s \leq T/3, U(s) = & (C + D\lambda s)[C + D\lambda(s + T/3)] + (C + D\lambda s) \\ & \cdot [C + D\lambda(s + 2T/3)] + [C + D\lambda(s + T/3)][C + D\lambda(s + 2T/3)] \\ & - 2(C + D\lambda s)[C + D\lambda(s + T/3)][C + D\lambda(s + 2T/3)]. \end{aligned} \quad (46)$$

Integrating and rearranging terms give the average unavailability of the system

$$\begin{aligned}
\bar{U}_{2/3} = & (6C/T)(1 - C)(\tau_t A' + \tau_r B') + 6C(1 - C)(\tau_t a + \tau_r b) \\
& + 3D\lambda(1 - 2C)(\tau_t A' + \tau_r B') + 3C^2 - 2C^3 \\
& + D\lambda T\{3(1 - 2C)(\tau_t a + \tau_r b) - (4/3)D\lambda(\tau_t A' + \tau_r B') + 3C(1 - C)\} \\
& - (2/3)D^2\lambda^2 T^2[2(\tau_t a + \tau_r b + C) - 1] - (1/6)D^3\lambda^3 T^3.
\end{aligned} \tag{47}$$

c. Three-out-of-three (3/3) System. For a 3/3 system, it again becomes more practical to think in terms of availability:

$$1 - U_{3/3} = (1 - U_1)(1 - U_2)(1 - U_3)$$

or

$$U_{3/3} = 1 - (1 - U_1)(1 - U_2)(1 - U_3). \tag{48}$$

The unavailability is given by

$$0 < s \leq \tau_t, U(s) = 1 - [1 - (A + aT)][1 - (C + D\lambda T/3)][1 - (C + 2D\lambda T/3)], \tag{49}$$

$$\tau_t < s \leq \theta, U(s) = 1 - [1 - (B + bT)][1 - (C + D\lambda T/3)][1 - (C + 2D\lambda T/3)], \tag{50}$$

and

$$\begin{aligned}
\theta < s \leq T/3, U(s) = & 1 - [1 - (C + D\lambda s)]\{1 - [C + D\lambda(s + T/3)]\} \\
& \cdot \{1 - [C + D\lambda(s + 2T/3)]\}.
\end{aligned} \tag{51}$$

And the average unavailability of the system is

$$\begin{aligned}
\bar{U}_{3/3} = & (3/T)(C - 1)^2(\tau_t A' + \tau_r B') + 3(C - 1)^2(\tau_t a + \tau_r b) \\
& + 1 + (C - 1)^3 + 3(C - 1)D\lambda(\tau_t A' + \tau_r B') \\
& + 3D\lambda T[(2/9)D\lambda(\tau_t A' + \tau_r B') + (C - 1)(\tau_t a + \tau_r b) + (1/2)(C - 1)^2] \\
& + (2/3)D^2\lambda^2 T^2(\tau_t a + \tau_r b + C - 1) + (1/12)D^3\lambda^3 T^3.
\end{aligned} \tag{52}$$

3. Four-component Systems

When four components are in a system, the system can be either 1/4, 2/4, 3/4, or 4/4. The average unavailability is given by

$$\bar{U} = \frac{4}{T} \int_0^{T/4} U(s) ds. \tag{53}$$

a. One-out-of-four (1/4) System. For a 1/4 system, the unavailabilities during testing, repair and standby are given by

$$0 < s \leq \tau_t, U(s) = (A + aT)(C + D\lambda T/4)(C + D\lambda T/2)(C + 3D\lambda T/4), \quad (54)$$

$$\tau_t < s \leq \theta, U(s) = (B + bT)(C + D\lambda T/4)(C + D\lambda T/2)(C + 3D\lambda T/4), \quad (55)$$

and

$$\begin{aligned} \theta < s \leq T/4, U(s) = & (C + D\lambda s)[C + D\lambda(s + T/4)][C + D\lambda(s + T/2)] \\ & \cdot [C + D\lambda(s + 3T/4)]. \end{aligned} \quad (56)$$

The average unavailability for this system is

$$\begin{aligned} \bar{U}_{1/4} = & (4C^3/T)(\tau_t A' + \tau_r B') + C^4 + 4C^3(\tau_t a + \tau_r b) + 6C^2 D\lambda(\tau_t A' + \tau_r B') \\ & + CD\lambda T[6C(\tau_t a + \tau_r b) + (11/4)D\lambda(\tau_t A' + \tau_r B') + 2C^2] \\ & + (1/8)D^2\lambda^2 T^2[22C(\tau_t a + \tau_r b) + 3D\lambda(\tau_t A' + \tau_r B') + 11C^2] \\ & + (3/8)D^3\lambda^3 T^3(\tau_t a + \tau_r b + C) + (251/7680)D^4\lambda^4 T^4. \end{aligned} \quad (57)$$

b. Two-out-of-four (2/4) System. In a 2/4 system, any three of the components being down causes the system to be unavailable:

$$\begin{aligned} U_{2/4} = & U_1 U_2 U_3 (1 - U_4) + U_1 U_2 U_4 (1 - U_3) + U_1 U_3 U_4 (1 - U_2) \\ & + U_2 U_3 U_4 (1 - U_1) + U_1 U_2 U_3 U_4 \\ = & U_1 U_2 U_3 + U_1 U_2 U_4 + U_1 U_3 U_4 + U_2 U_3 U_4 - 3U_1 U_2 U_3 U_4. \end{aligned} \quad (58)$$

Thus, the unavailability equations for the three periods in the test interval are

$$\begin{aligned} 0 < s \leq \tau_t, U(s) = & (A + aT)(C + D\lambda T/4)(C + D\lambda T/2) + (A + aT)(C + D\lambda T/4) \\ & \cdot (C + 3D\lambda T/4) + (A + aT)(C + D\lambda T/2)(C + 3D\lambda T/4) + (C + D\lambda T/4) \\ & \cdot (C + D\lambda T/2)(C + 3D\lambda T/4) - 3(A + aT)(C + D\lambda T/4)(C + D\lambda T/2) \\ & \cdot (C + 3D\lambda T/4), \end{aligned} \quad (59)$$

$$\begin{aligned} \tau_t < s \leq \theta, U(s) = & (B + bT)(C + D\lambda T/4)(C + D\lambda T/2) + (B + bT)(C + D\lambda T/4) \\ & \cdot (C + D\lambda T/2) + (B + bT)(C + D\lambda T/4)(C + 3D\lambda T/4) + (C + D\lambda T/4) \\ & \cdot (C + D\lambda T/2)(C + 3D\lambda T/4) - 3(B + bT)(C + D\lambda T/4)(C + D\lambda T/2) \\ & \cdot (C + 3D\lambda T/4), \end{aligned} \quad (60)$$

and

$$\begin{aligned}
 \theta < s \leq T/4, U(s) = & (C + D\lambda s)[C + D\lambda(s + T/4)][C + D\lambda(s + T/2)] \\
 & + (C + D\lambda s)[C + D\lambda(s + T/4)][C + D\lambda(s + 3T/4)] + (C + D\lambda s) \\
 & \cdot [C + D\lambda(s + T/2)][C + D\lambda(s + 3T/4)] + [C + D\lambda(s + T/4)] \\
 & \cdot [C + D\lambda(s + T/2)][C + D\lambda(s + 3T/4)] - 3(C + D\lambda s)[C + D\lambda(s + T/4)] \\
 & \cdot [C + D\lambda(s + T/2)][C + D\lambda(s + 3T/4)]. \tag{61}
 \end{aligned}$$

Integrating and rearranging terms give the average unavailability of a 2/4 system as

$$\begin{aligned}
 \bar{U}_{2/4} = & (12C^2/T)(1 - C)(\tau_t A' + \tau_r B') + 6CD\lambda(2 - 3C)(\tau_t A' + \tau_r B') \\
 & + 12C^2(1 - C)(\tau_t a + \tau_r b) - 3C^4 + 4C^3 \\
 & + D\lambda T\{(11/4)(1 - 3C)D\lambda(\tau_t A' + \tau_r B') + 6C[(2 - 3C)(\tau_t a + \tau_r b) \\
 & + C(1 - C)]\} + (1/8)D^2\lambda^2 T^2[22(1 - 3C)(\tau_t a + \tau_r b) \\
 & - 9D\lambda(\tau_t A' + \tau_r B') + 11C(2 - 3C)] \\
 & - (3/8)D^3\lambda^3 T^3[3(\tau_t a + \tau_r b + C) - 1] - (251/2560)D^4\lambda^4 T^4. \tag{62}
 \end{aligned}$$

c. Three-out-of-four (3/4) System. In a 3/4 system, if any two components are down, the system is down. In terms of the availability, this becomes

$$\begin{aligned}
 1 - U_{3/4} = & (1 - U_1)(1 - U_2)(1 - U_3)U_4 + (1 - U_1)(1 - U_2)(1 - U_4)U_3 \\
 & + (1 - U_1)(1 - U_3)(1 - U_4)U_2 + (1 - U_2)(1 - U_3)(1 - U_4)U_1 \\
 & + (1 - U_1)(1 - U_2)(1 - U_3)(1 - U_4)
 \end{aligned}$$

or

$$\begin{aligned}
 U_{3/4} = & U_1U_2 + U_1U_3 + U_1U_4 + U_2U_3 + U_2U_4 + U_3U_4 - 2U_1U_2U_3 \\
 & - 2U_1U_2U_4 - 2U_1U_3U_4 - 2U_2U_3U_4 + 3U_1U_2U_3U_4, \tag{63}
 \end{aligned}$$

$$\begin{aligned}
0 < s \leq \tau_t, U(s) = & (A + aT)(C + D\lambda T/4) + (A + aT)(C + D\lambda T/2) + (A + aT) \\
& \cdot (C + 3D\lambda T/4) + (C + D\lambda T/4)(C + D\lambda T/2) + (C + D\lambda T/4)(C + 3D\lambda T/4) \\
& + (C + D\lambda T/2)(C + 3D\lambda T/4) - 2(A + aT)(C + D\lambda T/4)(C + D\lambda T/2) \\
& - 2(A + aT)(C + D\lambda T/4)(C + 3D\lambda T/4) - 2(A + aT)(C + D\lambda T/2)(C + 3D\lambda T/4) \\
& - 2(C + D\lambda T/4)(C + D\lambda T/2)(C + 3D\lambda T/4) + 3(A + aT)(C + D\lambda T/4) \\
& \cdot (C + D\lambda T/2)(C + 3D\lambda T/4), \tag{64}
\end{aligned}$$

$$\begin{aligned}
\tau_t < s \leq \theta, U(s) = & (B + bT)(C + D\lambda T/4) + (B + bT)(C + D\lambda T/2) + (B + bT) \\
& \cdot (C + 3D\lambda T/4) + (C + D\lambda T/4)(C + D\lambda T/2) + (C + D\lambda T/4)(C + 3D\lambda T/4) \\
& + (C + D\lambda T/2)(C + 3D\lambda T/4) - 2(B + bT)(C + D\lambda T/4)(C + D\lambda T/2) \\
& - 2(B + bT)(C + D\lambda T/4)(C + 3D\lambda T/4) - 2(B + bT)(C + D\lambda T/2)(C + 3D\lambda T/4) \\
& - 2(C + D\lambda T/4)(C + D\lambda T/2)(C + 3D\lambda T/4) + 3(B + bT)(C + D\lambda T/4) \\
& \cdot (C + D\lambda T/2)(C + 3D\lambda T/4), \tag{65}
\end{aligned}$$

and

$$\begin{aligned}
\theta < s \leq T/4, U(s) = & (C + D\lambda s)[C + D\lambda(s + T/4)] + (C + D\lambda s)[C + D\lambda(s + T/2)] \\
& + (C + D\lambda s)[C + D\lambda(s + 3T/4)] + [C + D\lambda(s + T/4)][C + D\lambda(s + T/2)] \\
& + [C + D\lambda(s + T/4)][C + D\lambda(s + 3T/4)] + [C + D\lambda(s + T/2)] \\
& \cdot [C + D\lambda(s + 3T/4)] - 2(C + D\lambda s)[C + D\lambda(s + T/4)][C + D\lambda(s + T/2)] \\
& - 2(C + D\lambda s)[C + D\lambda(s + T/4)][C + D\lambda(s + 3T/4)] - 2[C + D\lambda(s + T/2)] \\
& \cdot [C + D\lambda(s + 3T/4)](C + D\lambda s) - 2[C + D\lambda(s + T/4)][C + D\lambda(s + T/2)] \\
& \cdot [C + D\lambda(s + 3T/4)] + 3(C + D\lambda s)[C + D\lambda(s + T/4)][C + D\lambda(s + T/2)] \\
& \cdot [C + D\lambda(s + 3T/4)]. \tag{66}
\end{aligned}$$

The average unavailability for this system then becomes

$$\begin{aligned}
\overline{U}_{3/4} = & (12C/T)(C - 1)^2(\tau_t A' + \tau_r B') + 3C^4 - 8C^3 + 6C^2 + 12C(1 - 2C) \\
& \cdot (\tau_t a + \tau_r b) + 6D\lambda(1 - 4C)(\tau_t A' + \tau_r B') + 18C^2 D\lambda(\tau_t A' + \tau_r B') \\
& + 12C^3(\tau_t a + \tau_r b) + D\lambda T[6(\tau_t a + \tau_r b)(3C - 1)(C - 1) \\
& + (11/4)D\lambda(3C - 2)(\tau_t A' + \tau_r B') + 6C(C - 1)^2] \\
& + D^2\lambda^2 T^2[(9/8)D\lambda(\tau_t A' + \tau_r B') + (11/4)(3C - 2)(\tau_t a + \tau_r b) \\
& + (11/8)(3C - 1)(C - 1)] + D^3\lambda^3 T^3[(9/8)(\tau_t a + \tau_r b) \\
& + (3/8)(3C - 2)] + (251/2560)D^4\lambda^4 T^4.
\end{aligned} \tag{67}$$

d. Four-out-of-four (4/4) System. Finally, for a 4/4 system, all the components must be available for the system to be up. In terms of availability,

$$1 - U_{4/4} = (1 - U_1)(1 - U_2)(1 - U_3)(1 - U_4)$$

or

$$U_{4/4} = 1 - (1 - U_1)(1 - U_2)(1 - U_3)(1 - U_4), \tag{68}$$

$$\begin{aligned}
0 < s \leq \tau_t, U(s) = & 1 - [1 - (A + aT)][1 - (C + D\lambda T/4)][1 - (C + D\lambda T/2)] \\
& \cdot [1 - (C + 3D\lambda T/4)],
\end{aligned} \tag{69}$$

$$\begin{aligned}
\tau_t < s \leq \theta, U(s) = & 1 - [1 - (B + bT)][1 - (C + D\lambda T/4)][1 - (C + D\lambda T/2)] \\
& \cdot [1 - (C + 3D\lambda T/4)],
\end{aligned} \tag{70}$$

and

$$\begin{aligned}
\theta < s \leq T/4, U(s) = & 1 - [1 - (C + D\lambda s)]\{1 - [C + D\lambda(s + T/4)]\} \\
& \cdot \{1 - [C + D\lambda(s + T/2)]\}\{1 - [C + D\lambda(s + 3T/4)]\}.
\end{aligned} \tag{71}$$

The average unavailability for this 4/4 system then becomes

$$\begin{aligned}
\overline{U}_{4/4} = & (4/T)(C - 1)^3(\tau_t A' + \tau_r B') + 1 - (C - 1)^4 - 4(C - 1)^2[(C - 1)(\tau_t a + \tau_r b) \\
& + (3/2)D\lambda(\tau_t A' + \tau_r B')] - 2(C - 1)D\lambda T[(C - 1)^2 + 3(C - 1)(\tau_t a + \tau_r b) \\
& + (11/8)D\lambda(\tau_t A' + \tau_r B')] - (1/8)D^2\lambda^2 T^2[11(C - 1)^2 + 22(C - 1) \\
& \cdot (\tau_t a + \tau_r b) + 3D\lambda(\tau_t A' + \tau_r B')] - (3/8)D^3\lambda^3 T^3(\tau_t a + \tau_r b + C - 1) \\
& - (251/7680)D^4\lambda^4 T^4.
\end{aligned} \tag{72}$$

D. Nearly Simultaneous Testing Scheme

When a system is tested using the nearly simultaneous testing scheme, the components are tested at times $s = 0, \tau_t, 2\tau_t, \dots, (n-1)\tau_t$. Following each test, the repair begins, allowing one test and one repair crew to service all the components. If the testing was done exactly simultaneously, n crews would be needed.

1. Two-component Systems

The average unavailability equations for the 1/2 and 2/2 systems are presented in the following sections. Because of the method in which the tests are staggered, the equations will generally be more involved than for the uniformly staggered scheme.

a. One-out-of-two (1/2) System. For a 1/2 system, the unavailability for the system is calculated from

$$0 < s \leq \tau_t, U(s) = (A + aT)(C + D\lambda T), \quad (73)$$

$$\tau_t < s \leq 2\tau_t, U(s) = (B + bT)(A + aT), \quad (74)$$

$$2\tau_t < s \leq \theta, U(s) = (B + bT)^2, \quad (75)$$

$$\theta < s \leq \theta + \tau_t, U(s) = (C + D\lambda\theta)(B + bT), \quad (76)$$

and

$$\theta + \tau_t < s \leq T, U(s) = (C + D\lambda s)^2. \quad (77)$$

In Eq. 73, unavailability of the second component is assumed to be constant. This is valid, since $\tau_t \ll T$. This assumption is also made in Eqs. 76 and 77. One criterion that is essential to make this set of equations valid is that $\theta \geq 2\tau_t$ or $\tau_r \geq \tau_t$. In general, for the m/n systems ($1 \leq m \leq n \leq 4$) using nearly simultaneous testing, τ_r must be greater than $(n-1)\tau_t$. This is acceptable based on current testing and repair practice at nuclear power plants.

The average unavailability for this system is

$$\begin{aligned} \bar{U}_{1/2} = & (1/T)[\tau_t(AB + AC + BC - 3C^2 + BD\lambda\theta) + \mu(B^2 - C^2)] \\ & + \tau_t[A(b + D\lambda) + a(B + C) + b(C + D\lambda\theta)] + 2Bb\mu + C^2 \\ & + T[\tau_t a(b + D\lambda) + b^2\mu + CD\lambda] + (1/3)D^2\lambda^2\tau_t^2, \end{aligned} \quad (78)$$

where $\mu = \theta - 2\tau_t$.

In terms other than C^2 we integrated Eq. 77 from 0 to T rather than from $\theta + \tau_t$. The errors from this approximation are smaller than the errors found in Table VII. For $n > 1$, the errors are less than 0.1%. The errors are acceptable.

TABLE VII. Errors in $T^n - (\theta + \tau_t)^n \approx T^n$ Approximation

n	T^n	$(\theta + \tau_t)^n$	Percent Error ^a
1	720	19	2.71
2	5.184×10^5	3.61×10^2	6.97×10^{-2}
3	3.73×10^8	6.86×10^3	1.84×10^{-3}
4	2.69×10^{11}	1.30×10^5	4.85×10^{-5}
5	1.93×10^{14}	2.48×10^6	1.28×10^{-6}

a

$$\frac{(\theta + \tau_t)^n}{T^n - (\theta + \tau_t)^n} \times 100\%.$$

b. Two-out-of-two System. The unavailability equations for a 2/2 system are

$$0 < s \leq \tau_t, U(s) = 1 - [1 - (A + aT)][1 - (C + D\lambda T)], \quad (79)$$

$$\tau_t < s \leq 2\tau_t, U(s) = 1 - [1 - (B + bT)][1 - (A + aT)], \quad (80)$$

$$2\tau_t < s \leq \theta, U(s) = 1 - [1 - (B + bT)]^2, \quad (81)$$

$$\theta < s \leq \theta + \tau_t, U(s) = 1 - [1 - (C + D\lambda\theta)][1 - (B + bT)], \quad (82)$$

and

$$\theta + \tau_t < s \leq T, U(s) = 1 - [1 - (C + D\lambda s)]^2. \quad (83)$$

The average unavailability for the system is

$$\begin{aligned} U_{2/2} = & (1/T)[\tau_t(2A + 2B - 4C - AB - AC - BC + 3C^2 - BD\lambda\theta) \\ & + \mu(B - C)(2 - B - C)] + C(2 - C) + \tau_t[a(2 - B - C) + b(2 - A - C) \\ & - D\lambda(A + b\theta)] + 2\mu b(1 - B) + T[D\lambda(1 - C) - \tau_t a(b + D\lambda) - \mu b^2] \\ & - (1/3)D^2\lambda^2T^2. \end{aligned} \quad (84)$$

2. Three-component Systems

The development of the average unavailability equations for three-component systems is again similar to the development for uniformly staggered testing, except for the more complicated test-staggering procedure at the start of the test interval.

a. One-out-of-three (1/3) System. For a 1/3 system, the unavailability of the system at any time in the test interval is given by

$$0 < s \leq \tau_t, U(s) = (A + aT)(C + D\lambda T)^2, \quad (85)$$

$$\tau_t < s \leq 2\tau_t, U(s) = (B + bT)(A + aT)(C + D\lambda T), \quad (86)$$

$$2\tau_t < s \leq 3\tau_t, U(s) = (B + bT)^2(A + aT), \quad (87)$$

$$3\tau_t < s \leq \theta, U(s) = (B + bT)^3, \quad (88)$$

$$\theta < s \leq \theta + \tau_t, U(s) = (C + D\lambda\theta)(B + bT)^2, \quad (89)$$

$$\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = (C + D\lambda\theta)^2(B + bT), \quad (90)$$

and

$$\theta + 2\tau_t < s \leq T, U(s) = (C + D\lambda s)^3. \quad (91)$$

Again the assumption is made that if any component is in test or repair, the system unavailability is constant. The average unavailability for this system is:

$$\begin{aligned} \bar{U}_{1/3} = & (1/T) \{ \tau_t [AB^2 + ABC + AC^2 + B^2C + BC^2 - 5C^3 + BD\lambda\theta(B + 2C + D\lambda\theta)] \\ & + \nu(B^3 - C^3) \} + \tau_t [AD\lambda(B + 2C) + Ab(C + 2B) + a(B^2 + BC + C^2) \\ & + b(C + D\lambda\theta)(2B + C + D\lambda\theta)] + 3\nu B^2b + C^3 + T \{ \tau_t [aD\lambda(B + 2C) \\ & + AD\lambda(b + D\lambda) + ab(2B + C) + b^2(A + C + D\lambda\theta)] + 3\nu Bb^2 + (3/2)C^2D\lambda \} \\ & + T^2 \{ \tau_t [aD\lambda(b + D\lambda) + ab^2] + \nu b^3 + CD^2\lambda^2 \} + (1/4)D^3\lambda^3T^3, \end{aligned} \quad (92)$$

where $\nu = \theta - 3\tau_t$.

Again the integration of the last unavailability equation, Eq. 91, was performed over the interval 0 to T for terms other than C^3 . The errors are smaller than those shown in Table VIII.

TABLE VIII. Errors in $T^n - (\theta + 2\tau_t)^n \approx T^n$ Approximation

n	T^n	$(\theta + 2\tau_t)^n$	Percent Error ^a
1	720	21	3
2	5.184×10^5	4.41×10^2	1.51×10^{-2}
3	3.73×10^8	9.261×10^3	2.48×10^{-3}
4	2.69×10^{11}	1.94×10^5	7.24×10^{-5}
5	1.93×10^{14}	4.08×10^6	2.11×10^{-6}

^a $\frac{(\theta + 2\tau_t)^n}{T^n - (\theta + 2\tau_t)^n} \times 100\%$.

b. Two-out-of-three (2/3) System. For a 2/3 system, the unavailability equations are

$$0 < s \leq \tau_t, U(s) = 2(A + aT)(C + D\lambda T) + (C + D\lambda T)^2 - 2(A + aT)(C + D\lambda T)^2, \quad (93)$$

$$\tau_t < s \leq 2\tau_t, U(s) = (A + aT)(B + bT) + (A + aT)(C + D\lambda T) + (B + bT)(C + D\lambda T) - 2(A + aT)(B + bT)(C + D\lambda T), \quad (94)$$

$$2\tau_t < s \leq 3\tau_t, U(s) = 2(A + aT)(B + bT) + (B + bT)^2 - 2(A + aT)(B + bT)^2, \quad (95)$$

$$3\tau_t < s \leq \theta, U(s) = 3(B + bT)^2 - 2(B + bT)^3, \quad (96)$$

$$\theta < s \leq \theta + \tau_t, U(s) = (B + bT)^2 + 2(B + bT)(C + D\lambda\theta) - (B + bT)^2(C + D\lambda\theta), \quad (97)$$

$$\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = (C + D\lambda\theta)^2 + 2(B + bT)(C + D\lambda\theta) - 2(B + bT)(C + D\lambda\theta)^2, \quad (98)$$

and

$$\theta + 2\tau_t < s \leq T, U(s) = 3(C + D\lambda s)^2 - 2(C + D\lambda s)^3. \quad (99)$$

The average unavailability for this system is

$$\begin{aligned} \bar{U}_{2/3} = & (1/T) \{ \tau_t [(1 - 2A)(C^2 + BC) + 3AC + AB(3 - 2B) + 2B^2 + 2B(C + D\lambda\theta) \\ & \cdot (2 - B) + (C + D\lambda\theta)^2(1 - 2B) - 5C^2(3 - 2C)] + \nu B^2(3 - 2B) - \nu C^2(3 - 2C) \} \\ & + \tau_t \{ (1 - 2C)(2AD\lambda + Ab + aB) + 2C[D\lambda + a(1 - C)] + D\lambda(A + B - 2AB) \\ & + C(a + b) + 2b(1 - 2b)(A + C + D\lambda\theta) + 2aB(1 - B) + 4Bb + 2b(C + D\lambda\theta) \\ & \cdot (1 - C - D\lambda\theta) \} + 6\nu Bb(1 - B) + C^2(3 - 2C) + T \{ \tau_t \{ (1 - 2C)(2aD\lambda + ab) \\ & + (1 - 2A)(b^2 + bD\lambda + D^2\lambda^2) + (1 - 2B)(aD\lambda + 2ab) + b^2[1 - 2(C + D\lambda\theta)] \} \\ & + 3\nu b^2(1 - 2B) + 3CD\lambda(1 - C) \} - T^2 [2a\tau_t(b^2 + bD\lambda + D^2\lambda^2) + 2\nu b^3 \\ & - D^2\lambda^2(1 - 2C)] - (1/2)D^3\lambda^3T^3. \end{aligned} \quad (100)$$

c. Three-out-of-three (3/3) System. For a 3/3 system, the unavailability at any time is given by:

$$0 < s \leq \tau_t, U(s) = 1 - [1 - (A + aT)][1 - (C + D\lambda T)]^2, \quad (101)$$

$$\tau_t < s \leq 2\tau_t, U(s) = 1 - [1 - (A + aT)][1 - (B + bT)] \cdot [1 - (C + D\lambda T)], \quad (102)$$

$$2\tau_t < s \leq 3\tau_t, U(s) = 1 - [1 - (A + aT)][1 - (B + bT)]^2, \quad (103)$$

$$3\tau_t < s \leq \theta, U(s) = 1 - [1 - (B + bT)]^3, \quad (104)$$

$$\theta < s \leq \theta + \tau_t, U(s) = 1 - [1 - (B + bT)]^2[1 - (C + D\lambda\theta)], \quad (105)$$

$$\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = 1 - [1 - (B + bT)][1 - (C + D\lambda\theta)]^2, \quad (106)$$

and

$$\theta + 2\tau_t < s \leq T, U(s) = 1 - [1 - (C + D\lambda s)]^3. \quad (107)$$

These equations give rise to the average unavailability equation

$$\begin{aligned} \bar{U}_{3/3} = & (1/T) \{ 5\tau_t(1 - C)^3 + \tau_t[(A - 1)(C - 1)(B + C - 2) + (A - 1)(B - 1)^2 \\ & + (B - 1)(1 - C - D\lambda\theta)(2 - B - C - D\lambda\theta)] + (1 - C)^3v + (B - 1)^3v \} \\ & + \tau_t \{ (C - 1)[2(A - 1)D\lambda + a(C - 1)] + (A - 1)(B - 1)D\lambda + b(A - 1) \\ & \cdot (2B + C - 3) + a(B - 1)(B + C - 2) + b(1 - C - D\lambda\theta)(3 - 2B - C - D\lambda\theta) \} \\ & + 3(B - 1)^2vb + 1 + (C - 1)^3 + T \{ \tau_t[a(C - 1)(b + 2D\lambda) + (A - 1) \\ & \cdot (b^2 + bD\lambda + D^2\lambda^2) + a(B - 1)(2b + D\lambda) - b^2(1 - C - D\lambda\theta)] + 3(B - 1)vb^2 \\ & + (3/2)D\lambda(C - 1)^2 \} + T^2[a\tau_t(b^2 + bD\lambda + D^2\lambda^2) + vb^3 + (C - 1)D^2\lambda^2] \\ & + (1/4)D^3\lambda^3T^3. \end{aligned} \quad (108)$$

3. Four-component Systems

The average unavailability equations for the 1/4, 2/4, 3/4, and 4/4 systems are presented in the following sections.

a. One-out-of-four (1/4) System. The unavailability of a 1/4 system at any time s is given by

$$0 < s \leq \tau_t, U(s) = (A + aT)(C + D\lambda T)^3, \quad (109)$$

$$\tau_t < s \leq 2\tau_t, U(s) = (A + aT)(B + bT)(C + D\lambda T)^2, \quad (110)$$

$$2\tau_t < s \leq 3\tau_t, U(s) = (A + aT)(B + bT)^2(C + D\lambda T), \quad (111)$$

$$3\tau_t < s \leq 4\tau_t, U(s) = (A + aT)(B + bT)^3, \quad (112)$$

$$4\tau_t < s \leq \theta, U(s) = (B + bT)^4, \quad (113)$$

$$\theta < s \leq \theta + \tau_t, U(s) = (B + bT)^3(C + D\lambda\theta), \quad (114)$$

$$\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = (B + bT)^2(C + D\lambda\theta)^2, \quad (115)$$

$$\theta + 2\tau_t < s \leq \theta + 3\tau_t, U(s) = (B + bT)(C + D\lambda\theta)^3, \quad (116)$$

and

$$\theta + 3\tau_t < s \leq T, U(s) = (C + D\lambda s)^4. \quad (117)$$

Integrating and taking the average yields

$$\begin{aligned} \bar{U}_{1/4} = & (1/T) \left\{ \tau_t \{ A(B^3 + C^3) + ABC(B + C) - 7C^4 + B(C + D\lambda\theta)[B^2 + B(C + D\lambda\theta) \right. \\ & + (C + D\lambda\theta)^2] \} + \sigma(B^4 - C^4) \} + \tau_t \{ (AD\lambda + aC)(B^2 + BC + C^2) \\ & + ACD\lambda(B + 2C) + AbC(2B + C) + B^2[3Ab + aB + 3b(C + D\lambda\theta)] \\ & + b(C + D\lambda\theta)^2(2B + C + D\lambda\theta) \} + 4\sigma B^3b + C^4 + T \{ \tau_t [(AD\lambda + aC) \\ & \cdot (3CD\lambda + BD\lambda + bC + Bb) + (aB + Ab)(CD\lambda + BD\lambda + bC + 3Bb) \\ & + b^2(C + D\lambda\theta)(3B + C + D\lambda\theta)] + 6\sigma B^2b^2 + 2C^3D\lambda \} + T^2 \{ \tau_t \{ (b + D\lambda) \\ & \cdot [D\lambda(AD\lambda + 2aC) + b(2aB + Ab)] + a(B + C)(b^2 + D^2\lambda^2) + b^3(C + D\lambda\theta) \} \\ & + 4\sigma Bb^3 + 2C^2D^2\lambda^2 \} + T^3 [a\tau_t(b + D\lambda)(b^2 + D^2\lambda^2) + \sigma b^4 + CD^3\lambda^3] \\ & + (1/5)D^4\lambda^4T^4, \end{aligned} \quad (118)$$

where $\sigma = 6 - 4\tau_t$.

The integration of Eq. 117 for terms other than C^4 was done over the entire test interval. The subsequent errors are smaller than those listed in Table IX.

TABLE IX. Errors in $T^n - (\theta + 3\tau_t)^n \approx T^n$ Approximation

n	T^n	$(\theta + 3\tau_t)^n$	Percent Error ^a
1	720	23	3.30
2	5.184×10^5	5.29×10^2	1.02×10^{-1}
3	3.73×10^8	1.22×10^4	3.26×10^{-3}
4	2.69×10^{11}	2.80×10^5	1.04×10^{-4}
5	1.93×10^{14}	6.34×10^6	3.33×10^{-6}

$$^a \frac{(\theta + 3\tau_t)^n}{T^n - (\theta + 3\tau_t)^n} \times 100\%.$$

b. Two-out-of-four (2/4) System. The unavailability equations for a 2/4 system are

$$0 < s \leq \tau_t, U(s) = 3(A + aT)(C + D\lambda T)^2 + (C + D\lambda T)^3 - 3(A + aT) \cdot (C + D\lambda T)^3, \quad (119)$$

$$\tau_t < s \leq 2\tau_t, U(s) = 2(A + aT)(B + bT)(C + D\lambda T) + (A + aT)(C + D\lambda T)^2 + (B + bT)(C + D\lambda T)^2 - 3(A + aT)(B + bT)(C + D\lambda T)^2, \quad (120)$$

$$2\tau_t < s \leq 3\tau_t, U(s) = 2(A + aT)(B + bT)(C + D\lambda T) + (A + aT)(B + bT)^2 + (B + bT)^2(C + D\lambda T) - 3(A + aT)(B + bT)^2(C + D\lambda T), \quad (121)$$

$$3\tau_t < s \leq 4\tau_t, U(s) = 3(A + aT)(B + bT)^2 + (B + bT)^3 - 3(A + aT) \cdot (B + bT)^3, \quad (122)$$

$$4\tau_t < s \leq \theta, U(s) = 4(B + bT)^3 - 3(B + bT)^4, \quad (123)$$

$$\theta < s \leq \theta + \tau_t, U(s) = 3(B + bT)^2(C + D\lambda\theta) + (B + bT)^3 - 3(B + bT)^3 \cdot (C + D\lambda\theta), \quad (124)$$

$$\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = 2(B + bT)^2(C + D\lambda\theta) + 2(B + bT)(C + D\lambda\theta)^2 - 3(B + bT)^2(C + D\lambda\theta)^2, \quad (125)$$

$$\theta + 2\tau_t < s \leq \theta + 3\tau_t, U(s) = 3(B + bT)(C + D\lambda\theta)^2 + (C + D\lambda\theta)^3 - 3(B + bT)(C + D\lambda\theta)^3, \quad (126)$$

and

$$\theta + 3\tau_t < s \leq T, U(s) = 4(C + D\lambda s)^3 - 3(C + D\lambda s)^4. \quad (127)$$

The average unavailability for a 2/4 system is

$$\begin{aligned} \bar{U}_{2/4} = & (1/T) \left(\tau_t \{ 3AC^2(1 - C) + C^3 + ABC(2 - 3C) + C^2(A + B) + B^2(A + C) \right. \\ & + B(2 - 3B)[AC + (C + D\lambda\theta)^2] + 3B^2(1 - B)(A + C + D\lambda\theta) + 2B^3 \\ & - 7C^3(4 - 3C) + 2(C + D\lambda\theta)B^2 + 3B(C + D\lambda\theta)^2 + (1 - 3B)(C + D\lambda\theta)^3 \} \\ & + \sigma B^3(4 - 3B) - \sigma C^3(4 - 3C) \Big) + \tau_t \{ C(2 - 3C)(3AD\lambda + Ab + aB) \\ & + 3C^2[a(1 - C) + D\lambda] + 2ABD\lambda(1 - 3C) + C[2D\lambda(A + B) + C(a + b)] \\ & + (2 - 3B)B[AD\lambda + aC + 3b(A + C + D\lambda\theta)] + 2b(1 - 3B)[AC + (C + D\lambda\theta)^2] \\ & + B^2(a + D\lambda) + 2Bb(A + C) + 3aB^2(1 - B) + 6B^2b + 4Bb(C + D\lambda\theta) \\ & + 3b(C + D\lambda\theta)^2[1 - (C + D\lambda\theta)] \} + 12\sigma B^2b(1 - B) + C^3(4 - 3C) \\ & + T \left(\tau_t \{ D\lambda(1 - 3C)[3AD\lambda + 2(Ab + aB)] + aC(2 - 3C)(b + 3D\lambda) \right. \\ & + D^2\lambda^2[A + B + 3(C - AB)] + 2(a + b)CD\lambda + b(1 - 3B)[2(AD\lambda + aC) \\ & + 3b(A + C + D\lambda\theta)] + aB(2 - 3B)(3b + D\lambda) + 2Bb(a + D\lambda) + b^2[A + C \\ & + 3(2B - AC)] + b^2(C + D\lambda\theta)[2 - 3(C + D\lambda\theta)] \} + 6\sigma Bb^2(2 - 3B) \\ & + 6C^2D\lambda(1 - C) \Big) + T^2 \left(\tau_t \{ a(1 - 3C)[b^2 + D\lambda(2b + 3D\lambda)] + (1 - 3A) \right. \\ & \cdot (D^3\lambda^3 + b^2D\lambda + b^3) + D^2\lambda^2[a + b - 3(AB + aB)] + ab(1 - 3B)(3b + 2D\lambda) \\ & + b^3[1 - 3(C + D\lambda\theta)] \} + 4\sigma b^3(1 - 3B) + 2CD^2\lambda^2(2 - 3C) \Big) - T^3 \{ 3a\tau_t(b + D\lambda) \\ & \cdot (b^2 + D^2\lambda^2) + 3\sigma b^4 - D^3\lambda^3(1 - 3C) \} - (3/5)D^4\lambda^4T^4. \end{aligned} \quad (128)$$

c. Three-out-of-four (3/4) System. The unavailability at any time s for a 3/4 system is given by

$$\begin{aligned} 0 < s \leq \tau_t, U(s) = & 3(A + aT)(C + D\lambda T) + 3(C + D\lambda T)^2 - 6(A + aT)(C + D\lambda T)^2 \\ & - 2(C + D\lambda T)^3 + 3(A + aT)(C + D\lambda T)^3, \end{aligned} \quad (129)$$

$$\begin{aligned} \tau_t < s \leq 2\tau_t, U(s) = & (A + aT)(B + bT) + 2(A + aT)(C + D\lambda T) + 2(B + bT) \\ & \cdot (C + D\lambda T) + (C + D\lambda T)^3 - 4(A + aT)(B + bT)(C + D\lambda T) - 2(A + aT) \\ & \cdot (C + D\lambda T)^2 - 2(B + bT)(C + D\lambda T)^2 + 3(A + aT)(B + bT)(C + D\lambda T), \end{aligned} \quad (130)$$

$$\begin{aligned}
2\tau_t < s \leq 3\tau_t, U(s) = & 2(A + aT)(B + bT) + (A + aT)(C + D\lambda T) + 2(B + bT) \\
& \cdot (C + D\lambda T) + (B + bT)^2 - 2(A + aT)(B + bT)^2 - 2(B + bT)^2(C + D\lambda T) \\
& - 4(A + aT)(B + bT)(C + D\lambda T) + 3(A + aT)(B + bT)^2(C + D\lambda T), \quad (131)
\end{aligned}$$

$$\begin{aligned}
3\tau_t < s \leq 4\tau_t, U(s) = & 3(A + aT)(B + bT) + 3(B + bT)^2 - 6(A + aT)(B + bT)^2 \\
& - 2(B + bT)^3 + 3(A + aT)(B + bT)^3, \quad (132)
\end{aligned}$$

$$4\tau_t < s \leq \theta, U(s) = 6(B + bT)^2 - 8(B + bT)^3 + 3(B + bT)^4, \quad (133)$$

$$\begin{aligned}
\theta < s \leq \theta + \tau_t, U(s) = & 3(C + D\lambda\theta)(B + bT) + 3(B + bT)^2 - 6(C + D\lambda\theta) \\
& \cdot (B + bT)^2 - 2(B + bT)^3 + 3(C + D\lambda\theta)(B + bT)^3, \quad (134)
\end{aligned}$$

$$\begin{aligned}
\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = & (B + bT)^2 + (C + D\lambda\theta)^2 + 4(B + bT)(C + D\lambda\theta) \\
& - 4(B + bT)^2(C + D\lambda\theta) - 4(B + bT)(C + D\lambda\theta)^2 \\
& + 3(B + bT)^2(C + D\lambda\theta)^2, \quad (135)
\end{aligned}$$

$$\begin{aligned}
\theta + 2\tau_t < s \leq \theta + 3\tau_t, U(s) = & 3(C + D\lambda\theta)(B + bT) + 3(C + D\lambda\theta)^2 - 6(B + bT) \\
& \cdot (C + D\lambda\theta)^2 - 2(C + D\lambda\theta)^3 + 3(C + D\lambda\theta)^3(B + bT), \quad (136)
\end{aligned}$$

and

$$\theta + 3\tau_t < s \leq T, U(s) = 6(C + D\lambda s)^2 - 8(C + D\lambda s)^3 + 3(C + D\lambda s)^4. \quad (137)$$

Integrating these equations gives rise to the average unavailability equation:

$$\begin{aligned}
\bar{U}_{s,4} = & (1/T) \left\{ \tau_t \{ 3AC(C-1)^2 + 2C^2(2-C) + ABC[3(B+C)-8] - 7C^2(6-8C+3C^2) \right. \\
& + (A+B)(B+3C-2C^2) + B(A+C)(1-2B) + B^3(3A-2) + B^2[7-2B \\
& - 6(C+D\lambda\theta+A)] + 4AB + 3B(C+D\lambda\theta)[1+B^2+(C+D\lambda\theta-1)^2] + 2(C+D\lambda\theta)^2 \\
& \cdot [2-(C+D\lambda\theta)] + B(C+D\lambda\theta)[3B(C+D\lambda\theta)-4(C+D\lambda\theta+B-1)] \} \\
& + \sigma B^2(3B^2-8B+6) - C^2(3C^2-8C+6) \} + \tau_t \{ 3aC(C-1)^2 + (3C-1)(C-1) \\
& \cdot (3AD\lambda + Ab + aB) - 2C(C-1)(a+b+3D\lambda) + 2D\lambda[A(1-2B) + B(1-2C) \\
& + C(1-2A)] + (Ab + aB)[3B^2+3+C(3B-4)] + b(A+C)(1-4B) \\
& + BD\lambda(6AC-4A+1) + (A+B)D\lambda + (a+b)(2B+C-6B^2) - 2B^2(a+D\lambda) \\
& + 3AB(BD\lambda+bC) + b(A+2B+6AB^2) - 6Bb[2(C+D\lambda\theta-1+A)+B] + b(C+D\lambda\theta) \\
& \cdot [9B^2+7-8B+3(C+D\lambda\theta-1)^2] + 2b(C+D\lambda\theta)^2(3B-2) \} + 12Bb\sigma(B-1)^2 \\
& + C^2(3C^2-8C+6) + T \left[\tau_t \{ 3aD\lambda(3C-1)(C-1) + D^2\lambda^2[3AB-2(A+B)-6C+4] \right. \\
& \left. \left. \left. \right\} \right] \quad (138)
\end{aligned}$$

(Contd.)

$$\begin{aligned}
& + (3C - 2)D\lambda[2(Ab + aB) + 3AD\lambda] + abC(3C - 8) + ab(9B^2 + 1) + b(1 - 4B)(4a + D\lambda) \\
& + (Ab + aB)[3(BD\lambda + bC) - 4D\lambda] + (a + b)(b + 3D\lambda - 4CD\lambda) + b^2(3 - 8A - 2C) \\
& + 3Bb[AD\lambda + aC + b(3A - 2)] + b^2\{3[(C + D\lambda\theta)(3B - 2) - 2B + 1] + (C + D\lambda\theta - 1) \\
& \cdot [3(C + D\lambda\theta) - 1]\} + 6\sigma b^2(3B - 1)(B - 1) + 6CD\lambda(C - 1)^2 + T^2\tau_t\{(3A - 2) \\
& \cdot (b^3 + D^3\lambda^3) + aD\lambda(3C - 2)(2b + 3D\lambda) + 3D\lambda(aB + Ab)(b + D\lambda) - 2D^2\lambda^2(a + b) \\
& + ab[3(BD\lambda + bC) - 4D\lambda] + b^2(9aB - 8a - 2D\lambda) + b^3[3(C + D\lambda\theta) - 2]\} + 4\sigma b^3(3B - 2) \\
& + 2D^2\lambda^2(3C - 1)(C - 1) + T^3[3a(b^2 + D^2\lambda^2)(b + D\lambda)\tau_t + 3\sigma b^4 + D^3\lambda^3(3C - 2)] \\
& + (3/5)D^4\lambda^4T^4.
\end{aligned}
\tag{138}$$

d. Four-out-of-four (4/4) System. Finally, for a 4/4 system, the unavailability equations are

$$0 < s \leq \tau_t, U(s) = 1 - [1 - (A + aT)][1 - (C + D\lambda T)]^3, \tag{139}$$

$$\begin{aligned}
\tau_t < s \leq 2\tau_t, U(s) = 1 - [1 - (A + aT)][1 - (B + bT)] \\
\cdot [1 - (C + D\lambda T)]^2,
\end{aligned}
\tag{140}$$

$$\begin{aligned}
2\tau_t < s \leq 3\tau_t, U(s) = 1 - [1 - (A + aT)][1 - (B + bT)]^2 \\
\cdot [1 - (C + D\lambda T)],
\end{aligned}
\tag{141}$$

$$3\tau_t < s \leq 4\tau_t, U(s) = 1 - [1 - (A + aT)][1 - (B + bT)]^3, \tag{142}$$

$$4\tau_t < s \leq \theta, U(s) = 1 - [1 - (B + bT)]^4, \tag{143}$$

$$\theta < s \leq \theta + \tau_t, U(s) = 1 - [1 - (B + bT)]^3[1 - (C + D\lambda\theta)], \tag{144}$$

$$\theta + \tau_t < s \leq \theta + 2\tau_t, U(s) = 1 - [1 - (B + bT)]^2[1 - (C + D\lambda\theta)]^2, \tag{145}$$

$$\begin{aligned}
\theta + 2\tau_t < s \leq \theta + 3\tau_t, U(s) = 1 - [1 - (B + bT)] \\
\cdot [1 - (C + D\lambda\theta)]^3,
\end{aligned}
\tag{146}$$

and

$$\theta + 3\tau_t < s \leq T, U(s) = 1 - [1 - (C + D\lambda s)]^4. \tag{147}$$

The average unavailability for this system is

$$\begin{aligned}
\bar{U}_{4/4} = & (1/T) \left(7\tau_t(1-C)^4 - \tau_t \{ (A-1)(C-1)^3 + (B-1)[(A-1)(C-1)^2 \right. \\
& + (C+D\lambda\theta-1)^3] + (B-1)^2[(A-1)(C-1) + (C+D\lambda\theta-1)^2] + (B-1)^3 \\
& \cdot (A+C+D\lambda\theta-2) \} + (C-1)^4\sigma - (B-1)^4\sigma \Big) + 1 - \tau_t \{ (C-1)^2[(A-1) \\
& \cdot (b+3D\lambda) + a(B+C-2)] + (A-1)(B-1)[b(C-1) + D\lambda(B+1)] \\
& + (B-1)[a(B-1) + b(A-1)](B+C-2) + b(B-1)^2[2(A-1) \\
& + 3(C+D\lambda\theta-1)] + b(C+D\lambda\theta-1)^2(2B+C+D\lambda\theta-3) \} - 4(B-1)^3\sigma b \\
& - (C-1)^4 - T \left(\tau_t \{ [(A-1)D\lambda + a(C-1)][3(C-1)D\lambda + b(B-1)] \right. \\
& + [a(B-1) + b(A-1)][(C-1)(b+2D\lambda) + (B-1)(3b+D\lambda)] + (A-1) \\
& \cdot (B-1)D^2\lambda^2 + ab(C-1)^2 + (C+D\lambda\theta-1)b^2(3B+C+D\lambda\theta-4) \} \\
& + 6(B-1)^2b^2\sigma + 2(C-1)^3D\lambda \Big) - T^2 \left(\tau_t \{ [a(B-1) + b(A-1)] \right. \\
& \cdot (b^2 + bD\lambda + D^2\lambda^2) + (C-1)a(b^2 + 2bD\lambda + 3D^2\lambda^2) + D\lambda[ab(B-1) \\
& + (A-1)D^2\lambda^2] + 2a(B-1)b^2 + b^3(C+D\lambda\theta-1) \} + 4(B-1)b^3\sigma \\
& + 2(C-1)^2D^2\lambda^2 \Big) - T^3 [a\tau_t(b^2 + D^2\lambda^2)(b+D\lambda) + \sigma b^4 + (C-1)D^3\lambda^3] \\
& - (1/5)D^4\lambda^4T^4.
\end{aligned} \tag{148}$$

E. Calculation of Optimum Test Interval

Each of the average unavailability equations for the uniformly staggered and nearly simultaneous testing schemes presented in the previous sections were of the form

$$\bar{U}(T) = \alpha/T + \sum_{i=0}^n \beta_i T^i, \tag{149}$$

where n = number of redundancies in the system, and the coefficients α and β_i are given by the appropriate equations in the preceding sections depending upon the type of system and testing scheme (see Table X).

TABLE X. Equation Numbers for System Unavailability

System	Uniformly Staggered Testing	Nearly Simultaneous Testing	System	Uniformly Staggered Testing	Nearly Simultaneous Testing
1/2	32	78	1/4	57	118
2/2	37	84	2/4	62	128
1/3	42	92	3/4	67	138
2/3	47	100	4/4	72	148
3/3	52	108			

Taking $d\bar{U}(T)/dT$ and setting it equal to zero yields an equation of the form

$$\sum_{i=1}^n i\beta_i T^{i+1} - \alpha = 0. \quad (150)$$

To solve this equation, we use the Newton-Raphson method⁹ for finding the roots of an equation. This method works in the following manner. An initial guess is made at the optimum test interval. (In this case, T_0 from Eq. 25 is sufficient since it is usually within a factor of 1.5 from the true optimum.) A new estimate is obtained from

$$T_{n+1} = T_n - \frac{f(T_n)}{f'(T_n)}, \quad (151)$$

where $f(T_n)$ is the value of Eq. 150 evaluated at T_n , and $f'(T_n)$ is the derivative of Eq. 150 with respect to T and evaluated at T_n .

If the convergence criterion is met ($T_{n+1} - T_n$ less than some specified value), the process is halted. If not, the new guess, T_{n+1} , is substituted for T_n on the right-hand side of Eq. 151.

F. Calculation of Fractional Unavailabilities

Occasionally, it becomes desirable to know how the contributions to the average unavailability break down among testing, repair, and random failures.

Consider a system having an average unavailability of $\bar{U}$ and the input test interval T . If the fraction of time the component is down during testing, q_0 , is set equal to zero, a new value for the average unavailability, $\bar{U}_{NT}$, is obtained. The fraction of the average unavailability due to testing, f_1 , is then

$$f_1 = \frac{\bar{U} - \bar{U}_{NT}}{\bar{U}} = 1 - \frac{\bar{U}_{NT}}{\bar{U}}. \quad (152)$$

To find the contribution made from repair, the parameters B and b from Eq. 19 are set equal to zero while maintaining q_0 at zero. This average unavailability $\bar{U}_{NTNR}$ is used to find the repair contribution, f_2 , using the formula

$$f_2 = \frac{\bar{U} - \bar{U}_{NTNR} - (\bar{U} - \bar{U}_{NT})}{\bar{U}} = \frac{\bar{U}_{NT} - \bar{U}_{NTNR}}{\bar{U}}. \quad (153)$$

The fractional unavailability due to random failure is simply what remains, or

$$f_3 = 1.0 - f_1 - f_2. \quad (154)$$

These results can be used to determine whether testing and repair procedures should be modified to increase the reliability of the system.

G. Summary

The average unavailability equations for all m/n ($1 \leq m \leq n \leq 4$) systems for random, uniformly staggered, and nearly simultaneous testing schemes have been developed. The equations for the uniformly staggered and nearly simultaneous testing schemes are listed in Table X. These equations, along with the methods for calculating the optimum test interval and fractional unavailabilities, have been incorporated into a computer code ICARUS. A user's manual for ICARUS is found in Appendix B.

IV. COMPARISON OF ICARUS AND FRANTIC

This chapter presents various sets of numerical comparisons between ICARUS and FRANTIC to determine the validity of the methodology and accuracy of the coding found in ICARUS. Also, multicomponent redundancies are treated.

A. Introduction

FRANTIC is the acronym for the Formal Reliability Aalysis including Normal Testing, Inspection, and Checking computer code developed at the NRC. It calculates time-dependent and average unavailabilities, and also the breakdown of the unavailability contributions from testing, repair, and random failures.

FRANTIC is able to treat four kinds of components: constant-unavailability components, nonrepairable components, monitored components, and periodically tested components. The main emphasis in this study is to obtain the average unavailability of periodically tested components given such information as the test duration time, repair time, test-override capability, and test efficiency.

B. Differences between ICARUS and FRANTIC

1. Testing Schemes

In comparing ICARUS and FRANTIC, we must recognize that FRANTIC is more general than ICARUS. ICARUS was developed to treat only periodically tested components, while FRANTIC is able to handle a variety of components. Also, FRANTIC calculates time-dependent and average unavailabilities for any test interval (not necessarily in the asymptotic state). Since this option is available, the user can choose the length of the first test interval for each component and thus stagger the test intervals for the components in whatever manner is desired. ICARUS, on the other hand, calculates the average unavailability only in the asymptotic state. As a consequence, with ICARUS, the user must choose one of the three available testing schemes rather than creating a particular testing scheme through the input, as with FRANTIC.

2. Numerical Calculations

In regard to numerical calculations, FRANTIC calculates the average unavailability by multiplying the unavailability of each component at specified times, and performing trapezoidal-rule integration. Consequently, FRANTIC cannot calculate the optimum test interval internally, whereas ICARUS, which is totally analytical in its treatment of the average unavailability equations, calculates the optimum test interval by direct differentiation.

Also, the analytical treatment in ICARUS avoids any inherent numerical error. FRANTIC, for example, can give errors up to a factor of 2.5 for quadruply redundant systems.

3. Component Types

FRANTIC can treat systems made up of different types of component, whereas ICARUS assumes the redundancies in the system to be identical. A formulation has been developed to treat multicomponent redundancies in ICARUS and is presented in Sec. IV.D below

4. Failure Modes

Finally, ICARUS is able to treat three failure modes not found in FRANTIC:

γ_r , failure to start due to true demand,

ϕ_f , failure to detect or repair a failure,

and

ρ_u , failure due to a test demand that is not repaired.

Since the purpose of this research is to incorporate as many failure modes as possible and to evaluate their importance, a more in-depth study of these failure modes is performed in Chapter V.

C. Comparison of ICARUS and FRANTIC Simple Systems

To verify the coding and accuracy of the average unavailability equations found in ICARUS, we used ICARUS and FRANTIC to calculate the average unavailabilities of systems made up of one valve per redundancy. This was done for both staggered and nearly simultaneous testing schemes using only the failure modes common to both codes.

1. Comparison of Uniformly Staggered Testing Scheme

The comparison data for a single valve are given in Table XI. Table XII shows the average unavailability value obtained by the two codes and the percent difference between them. All the differences are less than 2.0% with the majority less than 1.0%. Since this kind of study usually requires order-of-magnitude accuracy, the differences here are well within acceptable bounds.

2. Comparison of Nearly Simultaneous Testing Scheme

The data in Table XI were also applied to the nearly simultaneous testing scheme. Note that $\tau_t = 3.0$ h and $\tau_r = 10.0$ h; therefore, τ_r is always greater than $(n - 1)\tau_t$ for all $n \leq 4$. Table XIII gives the results of the comparisons. Again, all the differences are small ($\leq 1.1\%$).

TABLE XI. Input Data for Single-valve Redundancy

Failure rate (λ)	$3.0 \times 10^{-7}/\text{h}$
Fraction of downtime during test (q_0)	1.0×10^{-1}
Probability of failure due to test demand (γ_e)	$1.0 \times 10^{-3}/\text{d}$
Test period duration (τ_t)	3.0 h
Repair period duration (τ_r)	10.0 h
Test interval (T)	720 h

TABLE XII. Comparison of ICARUS and FRANTIC Results for Uniformly Staggered Testing

System	$\bar{U}$		Percent Difference ^a
	ICARUS	FRANTIC	
1/4	1.73×10^{-15}	1.73×10^{-15}	0
1/3	1.45×10^{-11}	1.46×10^{-11}	0.68
2/4	6.01×10^{-11}	6.00×10^{-11}	0.17
1/2	1.04×10^{-7}	1.06×10^{-7}	1.88
2/3	3.16×10^{-7}	3.16×10^{-11}	0
3/4	6.34×10^{-7}	6.31×10^{-7}	0.48
1/1	5.46×10^{-4}	5.45×10^{-4}	0.18
2/2	1.10×10^{-3}	1.09×10^{-3}	0.92
3/3	1.65×10^{-3}	1.64×10^{-3}	0.61
4/4	2.21×10^{-3}	2.18×10^{-3}	1.38

$$^a \frac{|\bar{U}_F - \bar{U}_I|}{\bar{U}_F}$$

TABLE XIII. Comparison of ICARUS and FRANTIC Results
for Nearly Simultaneous Testing

System	$\bar{U}$		Percent Difference ^a
	ICARUS	FRANTIC	
1/4	9.24×10^{-11}	9.24×10^{-11}	0
1/3	7.66×10^{-10}	7.67×10^{-10}	0.13
2/4	3.05×10^{-9}	3.05×10^{-9}	0
1/2	6.33×10^{-7}	6.40×10^{-7}	1.09
2/3	1.89×10^{-6}	1.91×10^{-6}	1.05
3/4	3.77×10^{-6}	3.81×10^{-6}	1.05
1/1	5.46×10^{-4}	5.45×10^{-4}	0.18
2/2	1.09×10^{-3}	1.09×10^{-3}	0
3/3	1.64×10^{-3}	1.63×10^{-3}	0.61
4/4	2.18×10^{-3}	2.18×10^{-3}	0

$$^a \frac{|\bar{U}_F - \bar{U}_I|}{\bar{U}_F} \times 100\%.$$

Note that the unavailabilities for the uniformly staggered testing scheme were lower than the nearly simultaneous testing scheme in all cases, except for the n/n systems, where the average unavailabilities were calculated to be virtually identical.

D. Treatment of Multicomponent Redundancies

As stated before, the ICARUS code was written to handle systems made up of single-component redundancies. However, we can represent a multicomponent redundancy by an effective "single" component and thus apply ICARUS to the more complicated multicomponent systems if each of the nine ICARUS input parameters are handled correctly. The method for handling each parameter is discussed in the following sections. The theoretical basis for the definitions can be found in Ref. 7.

1. Test Interval, T_{eff}

Since the components in the redundancies are all assumed to have the same test interval T , it remains unchanged. Thus $T_{eff} = T$.

2. Test-period Duration, τ_{teff}

Each component in the redundancy must be tested in the test period. Therefore, τ_{teff} will be the sum of the individual τ_t 's for the components in the redundancy. That is,

$$\tau_{teff} = \sum_{j=1}^k \tau_{tj}, \quad (155)$$

where k equals the number of components in the redundancy.

3. Repair-period Duration, τ_{reff}

The repair-period duration, τ_r , of the redundancy depends upon the probability of the components in the redundancy failing, and the time required to repair a failed component. The probability that a component is repaired after a test (per test) is given by

$$R = \hat{u}(1 - \rho_f) + (1 - \hat{u})\gamma_e = \gamma_e + \frac{\rho_u + \lambda T}{1 - (\rho_f - \rho_u)} [1 - (\rho_f + \gamma_e)].$$

For the redundancy, the effective repair-period duration is

$$\tau_r = \frac{\sum_{j=1}^k R_j \tau_{rj}}{\sum_{j=1}^k R_j}, \quad (156)$$

where the repair times τ_{rj} of components j are weighted by the R_j values defined above for each component.

4. Fraction of Downtime during Testing, q_{0eff}

The total downtime due to testing is assumed to be the sum of the downtimes of the components in series. Thus, the effective fractional downtime value is calculated from

$$q_{0eff} = \frac{\sum_{j=1}^k \tau_{tj} q_{0j}}{\tau_{teff}}. \quad (157)$$

5. Remainder of the Parameters

The remainder of the parameters--the constant failure rate (λ), failure to start on true demand (γ_r), failure due to test demand (repaired, γ_e ; not repaired, ρ_u), and failure to detect or repair a failure (ρ_u)--are treated the same way as the test-period duration. The values for the parameter in question for each component are added together to get an effective value for that parameter.

E. ICARUS and FRANTIC Comparisons for Two-valves-per-redundancy Systems

ICARUS and FRANTIC values for the average unavailabilities were compared for a set of systems that contained two valves in series for each redundancy. For FRANTIC, the values of each parameter for a single valve are given in Table XIV.

TABLE XIV. ICARUS and FRANTIC Input Values
for Multicomponent Redundancies

Parameter	ICARUS Value	FRANTIC Value (per Valve)
γ_e	0.002	0.001
λ	$6.0 \times 10^{-7}/h$	$3.0 \times 10^{-7}/h$
q_0	$1.0 \times 10^{-1}^a$	1.0×10^{-1}
τ_r	10.0 h	10.0 h
τ_t	$6.0 h^a$	3.0 h
T	720 h	720 h

^aICARUS will change these values internally if necessary, to meet the input criteria.

With the methods of Secs. IV.D.1-IV.D.5, the values used in ICARUS for two valves in series (one redundancy) are also given in Table XIV.

1. Comparison of Uniformly Staggered Testing Scheme

The average unavailabilities calculated by ICARUS and FRANTIC for the two-valve-per-redundancy systems are listed in Table XV for the uniformly staggered testing scheme.

In each case, the difference is less than 3%, indicating that the averaging scheme used by ICARUS to represent multicomponent redundancies is adequate.

2. Comparison of Nearly Simultaneous Testing Scheme

The average unavailabilities for the two-valve-per-redundancy systems tested nearly simultaneously are listed in Table XVI. Unlike the previous comparisons, large differences appear in five of the ten cases. It is not clear which of the codes is incorrect since fairly good agreement between the two was established in earlier comparisons.

TABLE XV. Comparison of ICARUS and FRANTIC Results for Two Valves per Redundancy and Uniformly Staggered Testing

System	$\bar{U}$		Percent Difference ^a
	ICARUS	FRANTIC	
1/4	2.790×10^{-14}	2.741×10^{-14}	1.79
1/3	1.169×10^{-10}	1.152×10^{-10}	1.48
2/4	4.852×10^{-10}	4.771×10^{-10}	2.99
1/2	4.213×10^{-7}	4.159×10^{-7}	1.70
2/3	1.274×10^{-6}	1.255×10^{-6}	1.51
3/4	2.562×10^{-6}	2.517×10^{-6}	1.79
1/1	1.101×10^{-3}	1.090×10^{-3}	1.01
2/2	2.212×10^{-3}	2.179×10^{-3}	1.51
3/3	3.332×10^{-3}	3.268×10^{-3}	1.96
4/4	4.360×10^{-3}	4.356×10^{-3}	0.09

$$^a \frac{|\bar{U}_F - \bar{U}_I|}{\bar{U}_F} \times 100\%.$$

TABLE XVI. Comparison of ICARUS and FRANTIC Results for Two Valves per Redundancy and Nearly Simultaneous Testing

System	$\bar{U}$		Percent Difference ^a
	ICARUS	FRANTIC	
1/4	1.473×10^{-11}	1.357×10^{-12}	985.48
1/3	6.087×10^{-9}	3.147×10^{-9}	93.42
2/4	2.429×10^{-8}	7.913×10^{-9}	206.96
1/2	2.534×10^{-6}	2.506×10^{-6}	1.12
2/3	7.556×10^{-6}	6.294×10^{-6}	20.05
3/4	1.504×10^{-5}	1.052×10^{-5}	42.97
1/1	1.101×10^{-3}	1.090×10^{-3}	1.09
2/2	2.204×10^{-3}	2.177×10^{-3}	1.24
3/3	3.296×10^{-3}	3.263×10^{-3}	1.01
4/4	4.360×10^{-3}	4.348×10^{-3}	0.28

$$^a \frac{|\bar{U}_F - \bar{U}_I|}{\bar{U}_F} \times 100\%.$$

One possible source of error is the numerical-integration scheme used by FRANTIC to calculate the average unavailability. FRANTIC chooses points on the time-dependent unavailability curve where changes in slope occur. Then, using trapezoidal-rule integration, we obtain the area under the curve. When applying this to nearly simultaneous testing, note that the changes in slope occur at the start of the interval during test and repair. The rest of the interval is dominated by random failure upon which the method may break down. To show this would require an exact calculation of the average unavailability of one of the systems in question.

3. Exact Calculations for Average Unavailability of 1/3 System

The exact calculations for the average unavailability of a 1/3 system with two valves per redundancy were performed using the following equations, where for notational simplicity, $A_0 = 1 - (A + aT)$ and $B_0 = 1 - (B + bT)$:

$$T - 5\tau_t < s \leq T - 4\tau_t, \quad U(s) = \{1 - A_0[1 - \lambda(s + 4\tau_t)]\}\{1 - [1 - \lambda(s + 3\tau_t)] \\ \cdot [1 - \lambda(s + 2\tau_t)]\}\{1 - [1 - \lambda(s + \tau_t)](1 - \lambda s)\}, \quad (158)$$

$$T - 4\tau_t < s \leq T - 3\tau_t, \quad U(s) = (1 - B_0A_0)\{1 - [1 - \lambda(s + 3\tau_t)][1 - \lambda(s + 2\tau_t)]\} \\ \cdot \{1 - [1 - \lambda(s + \tau_t)](1 - \lambda s)\}, \quad (159)$$

$$T - 3\tau_t < s \leq T - 2\tau_t, \quad U(s) = (1 - B_0^2)\{1 - A_0[1 - \lambda(s + 2\tau_t)]\}\{1 - [1 - \lambda(s + \tau_t)] \\ \cdot (1 - \lambda s)\}, \quad (160)$$

$$T - 2\tau_t < s \leq T - \tau_t, \quad U(s) = (1 - B_0^2)(1 - B_0A_0)\{1 - [1 - \lambda(s + \tau_t)](1 - \lambda s)\}, \quad (161)$$

$$T - \tau_t < s \leq T, \quad U(s) = (1 - B_0^2)^2[1 - A_0(1 - \lambda s)], \quad (162)$$

$$0 < s \leq \tau_t, \quad U(s) = (1 - B_0^2)^2(1 - B_0A_0), \quad (163)$$

$$\tau_t < s \leq \tau_r - 4\tau_t, \quad U(s) = (1 - B_0^2)^3, \quad (164)$$

$$\tau_r - 4\tau_t < s \leq \tau_r - 3\tau_t, \quad U(s) = \{1 - [1 - \lambda(s + 5\tau_t)]B_0\}(1 - B_0^2)^2, \quad (165)$$

$$\tau_r - 3\tau_t < s \leq \tau_r - 2\tau_t, \quad U(s) = \{1 - [1 - \lambda(s + 5\tau_t)][1 - \lambda(s + 4\tau_t)]\}(1 - B_0^2)^2, \quad (166)$$

$$\tau_r - 2\tau_t < s \leq \tau_r - \tau_t, \quad U(s) = \{1 - [1 - \lambda(s + 5\tau_t)][1 - \lambda(s + 4\tau_t)]\} \\ \cdot \{1 - [1 - \lambda(s + 3\tau_t)]B_0\}(1 - B_0^2), \quad (167)$$

$$\tau_r - \tau_t < s \leq \tau_r, \quad U(s) = \{1 - [1 - \lambda(s + 5\tau_t)][1 - \lambda(s + 4\tau_t)]\}\{1 - [1 - \lambda(s + 3\tau_t)] \\ \cdot [1 - \lambda(s + 2\tau_t)]\}(1 - B_0^2), \quad (168)$$

$$\tau_r < s \leq \theta, \quad U(s) = \{1 - [1 - \lambda(s + 5\tau_t)][1 - \lambda(s + 4\tau_t)]\}\{1 - [1 - \lambda(s + 3\tau_t)] \\ \cdot [1 - \lambda(s + 2\tau_t)]\}\{1 - [1 - \lambda(s + \tau_t)]B_0\}, \quad (169)$$

and

$$\theta < s \leq T - 5\tau_t, \quad U(s) = \{1 - [1 - \lambda(s + 5\tau_t)][1 - \lambda(s + 4\tau_t)]\}\{1 - [1 - \lambda(s + 3\tau_t)] \\ \cdot [1 - \lambda(s + 2\tau_t)]\}\{1 - [1 - \lambda(s + \tau_t)](1 - \lambda s)\}. \quad (170)$$

These equations result from knowing that the unavailability of two valves in series is $1 - (1 - U_1)(1 - U_2)$. Thus for three parallel sets of two valves in series, the unavailability is

$$U_{1/3} = [1 - (1 - U_1)(1 - U_2)][1 - (1 - U_3)(1 - U_4)][1 - (1 - U_5)(1 - U_6)]. \quad (171)$$

Also note that for this set of equations, τ_r must be greater than $3\tau_t$.

With the data in the first column of Table XVII for each valve, the average unavailability of the system was calculated to be 3.111×10^{-9} .

TABLE XVII. Parameter Values for Test System

Parameter	Exact Calculation	ICARUS Input	FRANTIC Input
λ	$3.0 \times 10^{-7}/h$	$6.0 \times 10^{-7}/h$	$3.0 \times 10^{-7}/h$
γ_e	1.0×10^{-3}	2.0×10^{-3}	1.0×10^{-3}
q_0	0.10	0.10	0.10
τ_r	10.0 h	10.0 h	10.0 h
τ_t	1.5 h	3.0 h	1.5 h
T	720 h	720 h	720 h

With the data in the second column of Table XVII for each redundancy, the average unavailability for the same system was calculated using ICARUS. The value obtained for this method was $\bar{U}_{1/3} = 3.145 \times 10^{-9}$.

Finally, with the data from the third column of Table XVII, the average unavailability was calculated using the FRANTIC code. The value obtained was 2.310×10^{-8} , which is significantly different from the ICARUS value. To identify why the difference in values occurred, we made two more FRANTIC runs. In the first run, the q_0 value was halved and the τ_t value doubled to maintain the $q_0\tau_t$ value of testing unavailability. The error is small since, in the testing period, the equations are

$$\begin{aligned} \text{Exact } \bar{U} &= (\tau_t/T)[q_0 + (1 - q_0)(\gamma_e + \lambda T)] \\ &= (\tau_t/T)[q_0 + (1 - q_0)\gamma_e] + (1 - q_0)\lambda\tau_t \end{aligned} \quad (172)$$

$$\begin{aligned} \text{Approximate } \bar{U} &= (2\tau_t/T)[q_0/2 + (1 - q_0/2)(\gamma_e + \lambda T)] \\ &= (\tau_t/T)[q_0 + (2 - q_0)\gamma_e] + (2 - q_0)\lambda\tau_t. \end{aligned} \quad (173)$$

This leads to an error of about 1% in this case. The value obtained using these data is $\bar{U}_{1/3} = 1.610 \times 10^{-9}$. This is closer to the ICARUS value.

Next, the original q_0 was multiplied by 2 and τ_t was halved. The value obtained for this case is $\bar{U}_{1/3} = 3.112 \times 10^{-9}$. This is nearly the exact answer calculated by analytical means.

F. Summary

It is not clear what problems arise in modeling nearly simultaneously tested systems using FRANTIC. The three cases presented above should give approximately the same answers, but instead differ by an order of magnitude in at least one of the cases.

As for ICARUS, the averaging methods used to simulate multicomponent redundancy systems appear adequate in light of previous verification runs.

V. ANALYSIS OF AN AUXILIARY FEEDWATER SYSTEM

In this chapter, the ICARUS code is used to calculate the average unavailability of an auxiliary feedwater system for the three testing schemes. Also, the sensitivity of the unavailability values to the ICARUS input is determined.

A. Description

The auxiliary feedwater system (AFWS) provides feedwater to the secondary side of the main steam generator upon the loss of main feedwater. Figure 10 is a simplified flow diagram of the AFWS.

Fig. 10. Simplified Drawing of Auxiliary Feedwater System

The following paragraphs are taken from WASH-1400,¹⁰ and describe an auxiliary feedwater system for a typical PWR 3-loop design.

"Given a need for the AFWS, the three pumps, two electric (350 gpm) and one turbine (700 gpm) can be started either automatically or manually. The electric pumps are started automatically when: (1) a Safety Injection Control System signal is present; (2) loss of offsite power is detected; (3) main feedwater pumps shut off; or (4) low water level is detected by a steam generator. The turbine pump is started when low water level in a steam generator is detected or loss of offsite power is detected.

"All pumps are aligned to the 110,000 gallon condensate tank via separate suction lines at all times, except when maintenance is being performed on a pump. The three pumps deliver water to two headers which penetrate containment. Inside containment, each steam generator can receive condensate from either header.

"All the decay heat produced can be removed by any one of three steam generators. The amount of feedwater decreases with time, and the operators can throttle flow to steam generators by shutting off redundant pumps, and then utilizing the motor operated valves inside containment, decrease the flow as necessary to match the steam produced and released."

The pump test is performed by closing the valve(s) leading to the header, opening the valve(s) on a return loop to the 110,000-gal (416-m³) reservoir, and then operating the pump. In this way, the pump is tested without draining the auxiliary feedwater supply. During the test, the pump is not available since it is valved off from the secondary loop.

B. Data Base

Components such as pumps, valves, and Diesel generators are not exclusive to the nuclear industry. Because of this, a large data base is available for component parameters such as failure rates, test-period durations, and repair-period durations. Extensive data were analyzed and reported in WASH-1400 and will be used in this work whenever appropriate.

1. Values of ρ_u and ρ_f

The data available on human error are small and not as easily found as data on equipment failures. In particular, there is no source of numbers from which to assign values to the failure modes ρ_u (test fails component and is not repaired) and ρ_f (test fails to detect a component as failed). Millan and Edison¹¹ have tabulated a list of auxiliary-feedwater-system failures that occurred in 1974-1976, the plants at which they occurred, their causes, and the docket number for each occurrence. The list was studied, and possible candidates for the failure modes (ρ_u and ρ_f) were selected. The dockets were then read, and each selected failure was assigned a ρ_u or ρ_f designation. Case failures are summarized in Appendix F.

In all, there were six ρ_u failures and two ρ_f failures. In the three-year period, there were 3209 PWR reported occurrences, 95 of which were auxiliary-feedwater-system failures. During this period, also, the 35 power plants studied had accumulated about 83.3 years of operating experience. If we assume that each plant had an auxiliary feedwater system with three redundancies, and each redundancy was tested monthly, the total number of test demands on the components is about 3000. A value for ρ_u can be calculated using

$$\rho_u = 6 \text{ failures} / 3000 \text{ demands} = 2.0 \times 10^{-3} / \text{d.}$$

Calculating a number for ρ_f is not quite as straightforward. A ρ_f failure can only occur if there had been a previous failure of the system and an unsuccessful repair. The value of ρ_f is thus calculated from

$$\rho_f = 2 \text{ failures} / 95 \text{ AFWS failures} = 2.11 \times 10^{-2}.$$

Although the value of ρ_f is greater than that of ρ_u , the contribution it makes to the average unavailability of the system is not as large, since the probability of an auxiliary-feedwater-system failure is in itself small.

2. Values of γ_e and γ_r

Since the auxiliary-feedwater-system failure data were available, it was decided to calculate values for test and true-demand failures, γ_e and γ_r , directly. Since, the only difference between γ_e and γ_r is the time at which the failure (initiating event) occurs, the total number of failures on demand was used to calculate the values of both γ_e and γ_r .

In Ref. 11, three instances of failures on demand were found among the 3000 demands. These are also given in Appendix F. To be on the conservative side, the value obtained for failure on demand was assumed to be valid for both γ_e and γ_r , giving

$$\gamma_e = \gamma_r = 3 \text{ failures} / 3000 \text{ demands} = 1.0 \times 10^{-3} / \text{d}.$$

C. Numerical Analysis

Computer runs of ICARUS were made to calculate the average unavailability of the auxiliary feedwater system in three cases:

Case I: plant steam available, offsite power available.

Case II: no plant steam, offsite power available.

Case III: no plant steam, no offsite power.

1. Case I: Plant Steam Available, Offsite Power Available

Case I models the auxiliary feedwater system when steam is available to power the turbine pump and offsite power is present to operate the two electric pumps. The auxiliary feedwater system would be called upon if, for example, a low water level was detected in the steam generators. To simplify the system for an ICARUS calculation, the system was idealized to look like the one in Fig. 11. This is a 1/3 system since only one pump is needed to supply the steam generators. Also, since these are multicomponent redundancies, the averaging equations presented in Chapter IV are used to model the system.

Fig. 11

System Drawing for Cases I and II

a. Effective Duration of Redundancy Test Period and Fraction of Downtime. The following values of τ_t were obtained from Ref. 10, Table III 5-1:

$$\tau_{t\text{Pump}} = 1.4 \text{ h}, \tau_{t\text{Valve}} = 0.86 \text{ h}.$$

However, since the pump and valves are tested at the same time, the test-period duration of the effective component redundancy is that of a pump plus some additional time to align the valves properly (approximately one valve-test duration time) or

$$\tau_{\text{teff}} = 2.26 \text{ h}.$$

As for q_0 , all the components are taken offline when testing is done. Thus, the value of q_0 for the effective component redundancy is 1.0.

b. Effective Repair-period Duration of Redundancy. The effective repair-period duration of the redundancy is equal to the average of the repair times for each component weighted by the R factor of Eq. 156 for each

component (i.e., by the probability of having to repair the component). The following data were obtained from Ref. 10, Table III 5-3:

$$\tau_{r\text{Valve}} = 7.0 \text{ h and } \tau_{r\text{Pump}} = 19.0 \text{ h.}$$

The R term was derived previously as

$$R = \gamma_e + \hat{u}(1 - \rho_f - \gamma_e) \approx \gamma_e + \rho_u + \lambda T. \quad (14)$$

The values of γ_e , γ_r , and ρ_u obtained in Sec. V.B.2 were for a single redundancy rather than for individual components. Since three components make up each redundancy in Case I, the γ_e , γ_r , ρ_f , and ρ_u values obtained in Sec. V.B.2 are divided by 3 to obtain values for each component in the redundancy to be used to determine the repair-period duration. Thus, for the three components,

$$\gamma_e = \gamma_r = 3.33 \times 10^{-4}, \rho_f = 7.018 \times 10^{-3}, \text{ and } \rho_u = 6.67 \times 10^{-4}.$$

A value for the constant failure rate is also needed for each component, and a problem arises since the failure rates found in WASH-1400 are for components in operation rather than on standby. To obtain a standby λ , the probability of failure on demand, Q_d , for each component (Ref. 10, Table III 4-2) was divided by the length of one test interval to obtain a failure rate, since

$$Q_d = \lambda T. \quad (175)$$

For a valve, $Q_d = 1.0 \times 10^{-4}$. For a test interval of 720 h, $\lambda_v = 1.389 \times 10^{-7}/\text{h}$. The R value for a valve equals

$$R = 3.33 \times 10^{-4} + 6.67 \times 10^{-4} + 1.0 \times 10^{-4} = 1.1 \times 10^{-3}.$$

For the pump, $Q_{dp} = 1.0 \times 10^{-3}$. For a test interval of 720 h, $\lambda_p = 1.389 \times 10^{-6}/\text{h}$. The R value equals

$$R = 3.33 \times 10^{-4} + 6.67 \times 10^{-4} + 1.0 \times 10^{-3} = 2.0 \times 10^{-3}.$$

The value of τ_r for the effective component redundancy is calculated from

$$\tau_{r\text{eff}} = \frac{2R_v\tau_{rv} + R_p\tau_{rp}}{2R_v + R_p} = 12.7 \text{ h.}$$

c. Redundancy Failure Rate. The failure rate for the redundancy can be approximated as the sum of the failure rates of the components in the redundancy:

$$\lambda_{\text{eff}} = 2\lambda_v + \lambda_p = 1.67 \times 10^{-6}/\text{h.}$$

d. ICARUS Results for Random Testing Scheme. The average unavailability, optimum test interval, and unavailability fractions due to testing, repair, and random failures were calculated for the system by ICARUS assuming completely random testing. The results are shown in Table XVIII. The major contributor to the average unavailability is testing, followed by random failures and, finally, repair. The large testing factor is due to the system being completely unavailable during the test-period duration ($q_{0eff} = 1.0$).

TABLE XVIII. ICARUS Results for Case I

Testing Scheme	Completely Random	Uniformly Staggered	Nearly Simultaneous
Average Unavailability	3.23×10^{-7}	1.77×10^{-7}	3.75×10^{-7}
Optimum Test Interval, h	1624.4	1183.2	1381.3
Average Unavailability at $T_{OPTIMUM}$	2.03×10^{-7}	1.62×10^{-7}	3.22×10^{-7}
Unavailability due to Testing (%)	2.71×10^{-7} (83.7)	1.25×10^{-7} (70.6)	3.17×10^{-7} (84.7)
Unavailability due to Repair (%)	2.90×10^{-9} (0.90)	2.81×10^{-9} (1.6)	6.56×10^{-9} (1.7)
Unavailability due to Random Failures (%)	4.97×10^{-8} (15.4)	4.92×10^{-8} (27.8)	5.10×10^{-8} (13.6)

The optimum average test interval is 68 days, which is longer than the 30-day standard. In general, this points to a large test and repair contribution and, as seen in Table XVIII, these two contributions make up about 85% of the average unavailability.

The average unavailability at the optimum test interval is a factor of 1.6 times lower than that at the 30-day interval. Average unavailability versus test interval is plotted in Fig. 12. The curve decreases rapidly with time at short test intervals, but after reaching a minimum, increases rather slowly.

Fig. 12. Average Unavailability vs Test Interval for Case I

e. ICARUS Results for Uniformly Staggered Testing. The results of ICARUS runs made for the uniformly staggered testing scheme are also shown in Table XVIII. Again the testing of the system contributes the most (70.6%) to the average unavailability. Also, the optimum test interval is about 49 days. This is longer than for the once-per-month test, but less than the optimum using random testing. The longer test interval is again due to the high test contribution to the average unavailability.

Average unavailability versus test interval is plotted in Fig. 12. The curve is of the same shape as the curve for the random testing scheme, except that the magnitude at each test interval is smaller.

f. ICARUS Results for Nearly Simultaneous Testing. The results for the nearly simultaneous testing scheme for Case I are also shown in Table XVIII. The average unavailability contribution due to testing is very high and makes the overall average unavailability the highest of all three testing schemes for test intervals greater than 600 h. The optimum test interval is long (57.6 days) due to testing, and the unavailability at the optimum is the highest of all the schemes. Average unavailability versus test interval is plotted in Fig. 12.

2. Case II: Plant Steam Not Available, Offsite Power Available

Case II models a plant at a time when no steam is present to operate the turbine pump, but the electric pumps do have an outside power

source. This system would look like the one in Fig. 11 with the turbine pump having an unavailability equal to 1.0. This is a 1/2 system having the same ICARUS input as Case I.

a. ICARUS Results for Random Testing Scheme. The results for the ICARUS run of the 1/2 system are shown in Table XIX. The average unavailability for the random testing scheme is primarily due to testing (70.2%), with random failure (28.7%) and repair contributions (1.1%) following in order. The average unavailability for this 1/2 system is about 150 times greater than for the same scheme in Case I. The removal of one redundancy can thus greatly affect the performance of a system.

TABLE XIX. ICARUS Results for Case II

Testing Scheme	Completely Random	Uniformly Staggered	Nearly Simultaneous
Average Unavailability	4.71×10^{-5}	3.68×10^{-5}	5.05×10^{-5}
Optimum Test Interval, h	1624.4	1403.1	1572.7
Average Unavailability at T _{OPTIMUM}	3.45×10^{-5}	3.19×10^{-5}	4.13×10^{-5}
Unavailability due to Testing (%)	3.31×10^{-5} (70.2)	2.28×10^{-5} (62.1)	3.59×10^{-5} (71.1)
Unavailability due to Repair (%)	5.20×10^{-7} (1.1)	5.13×10^{-7} (1.4)	9.44×10^{-7} (1.9)
Unavailability due to Random Failures (%)	1.35×10^{-5} (28.7)	1.35×10^{-5} (36.5)	1.37×10^{-5} (27.0)

The optimum test interval is again 68 days (see Sec. III.B), and the average unavailability at this interval is only a factor of 1.37 times less than for the once-per-month test. Average unavailability versus test interval is plotted in Fig. 13. The random scheme has very high unavailability for short test intervals because the probability of having both components of the system tested near or at the same time becomes more probable as the test interval shortens.

Fig. 13. Average Unavailability vs Test Interval for Case II

b. ICARUS Results for Uniformly Staggered Testing. The results for the uniformly staggered testing scheme are listed in Table XIX. The average unavailability is again lower than for random testing, as is the average unavailability at the optimum test interval. The contribution to the unavailability is mostly from testing. The optimum test interval occurs at 58.8 days. Figure 13 is a plot of average unavailability versus test interval.

c. ICARUS Results for Nearly Simultaneous Testing. Table XIX presents the results of the Case II analysis with nearly simultaneous testing. The average unavailability is again the highest of the three testing schemes for test intervals greater than 630 h. Testing is the dominant factor in the unavailability, driving the optimum test interval up to 65.5 days. The average unavailability at the optimum is 1.22 times less than for once-per-month nearly simultaneous testing. Average unavailability versus test interval is plotted in Fig. 13.

3. Case III: No Steam Available, No Offsite Power Available

In Case III, both main power sources for the pumps are gone. There is no steam to drive the turbine pump, and the electric pumps must rely on Diesel generators to operate. The idealized system is shown in Fig. 14. Since all the components in each redundancy must operate, the series system averaging equations of Chapter IV must be used.

Fig. 14
System Drawing
for Case III

a. Duration of Redundancy Test Period and Fraction of Downtime.

The two valves and pump are down during testing, and since the test-period duration of the Diesel generator is the same as that of the pump, 1.4 h (Ref. 10, Table III 5-1), it is assumed that the generator is tested concurrently with the pump; $\tau_t = 2.26$ h, $q_0 = 1.0$.

b. Duration of Redundancy Repair Period. To calculate the repair period duration, τ_r , we must calculate the R term for each component. As for the γ_e , γ_r , ρ_u , and ρ_f terms in Sec. V.C.1.b, each is divided by the number of components in the redundancy. This yields

$$\gamma_e = \gamma_r = 2.5 \times 10^{-4}, \rho_u = 5 \times 10^{-4}, \rho_f = 5.28 \times 10^{-3},$$

and

$$\tau_{r\text{eff}} = \frac{2R_v\tau_{rv} + R_p\tau_{rp} + R_{D/G}\tau_{rD/G}}{2R_v + R_p + R_{D/G}} = 20.0 \text{ h.}$$

The value of $\tau_{rD/G} = 21$ h was obtained from Ref. 10, Table III 5-3.

c. Redundancy Failure Rate. The redundancy failure rate is the sum of the failure rates of the components in the redundancy:

$$\lambda_{\text{eff}} = 2\lambda_v + \lambda_p + \lambda_{D/G} = 4.33 \times 10^{-5}/h,$$

where λ_v and λ_p were evaluated previously and $\lambda_{D/G}$ is derived from the fact that $Q_{D/G} = \lambda T = 3.0 \times 10^{-2}$.

d. ICARUS Results for Random Testing Scheme. The results for the random testing scheme for Case III are shown in Table XX. This is a very unreliable system due to the high failure rate of the Diesel generators. This is evident in the contribution of random failures to the average unavailability. It now dominates and drives the optimum test interval down to 13.4 days. Also, since the repair time for the Diesel generator is long, the repair contribution becomes significant (6.8%).

TABLE XX. ICARUS Results for Case III

Testing Scheme	Completely Random	Uniformly Staggered	Nearly Simultaneous
Average Unavailability	5.43×10^{-4}	4.83×10^{-4}	7.20×10^{-4}
Optimum Test Interval, h	320.5	201.7	214.8
Average Unavailability at T_{OPTIMUM}	3.36×10^{-4}	2.41×10^{-4}	3.85×10^{-4}
Unavailability due to Testing (%)	1.32×10^{-4} (24.3)	1.16×10^{-4} (24.1)	2.20×10^{-4} (30.5)
Unavailability due to Repair (%)	3.70×10^{-5} (6.8)	3.59×10^{-5} (7.4)	3.83×10^{-5} (5.3)
Unavailability due to Random Failures (%)	3.75×10^{-4} (68.9)	3.31×10^{-4} (68.5)	4.62×10^{-4} (64.2)

Figure 15 is a plot of average unavailability versus test interval for the testing scheme. At short test intervals, the slope of the unavailability curve is not as steep as in the previous two cases since testing does not contribute as greatly as before.

Fig. 15. Average Unavailability vs Test Interval for Case III

e. ICARUS Results for Uniformly Staggered Testing. The results for the uniformly staggered testing scheme are also listed in Table XX. The average unavailability is also high for this scheme and system, most of it again due to random failure.

Figure 15 shows the curve for average unavailability versus test interval. The optimum test interval is only 8.4 days and would seem to be unreasonable, even though the reliability of the system could be doubled. Manpower to perform the tests in such short intervals would be scarce, given the other tests and repairs that must be performed.

f. ICARUS Results for Nearly Simultaneous Testing. Table XX shows the results for the nearly simultaneous testing scheme. This is again the least desirable testing scheme for test intervals greater than 216 h.

Figure 15 is a plot of average unavailability versus test interval. The optimum test interval is short, 9.0 days, but reduces the average unavailability by a factor of 2.03. At short test intervals, the simultaneous scheme has a smaller average unavailability than the random scheme.

4. Summary of Results

The pertinent data from all three cases are summarized in Table XXI. For the auxiliary feedwater system, the 1/3 configuration is

TABLE XXI. Summary of Data from All Cases

Testing Scheme	Case I			Case II			Case III		
	Random	Staggered	Simultaneous	Random	Staggered	Simultaneous	Random	Staggered	Simultaneous
Average Unavail- ability at T = 720 h	3.2×10^{-7}	1.8×10^{-7}	3.8×10^{-7}	4.7×10^{-5}	3.7×10^{-5}	5.1×10^{-5}	5.4×10^{-4}	4.8×10^{-4}	7.2×10^{-4}
Optimum Test Interval, h	1624.4	1183.2	1381.3	1624.4	1403.1	1512.7	320.5	201.7	214.8
Average Unavail- ability at Optimum Test Interval	2.0×10^{-7}	1.6×10^{-7}	3.2×10^{-7}	3.5×10^{-5}	3.2×10^{-5}	4.1×10^{-5}	3.4×10^{-4}	2.4×10^{-4}	3.9×10^{-4}
Average Unavail- ability Relative to Case III		0.0007			0.13			1.0	

206 times more available than the 1/2 system (Case I versus Case II) for the 720-h test interval and staggered testing. If the Diesel generator is needed in the 1/2 system, the system suffers an availability drop of a factor of 7.5. The Diesel generators are the most unreliable components in the series.

With data from Table XXI, a yearly average unavailability can be calculated for the three testing schemes. If the probability of having both off-site power and steam available to run the pumps (Case I) can be estimated to be about 0.70 and the probability of losing offsite power is taken to be $0.1/\text{yr}^3$, then the probability of Case II is calculated to be 0.27, which is simply the probability of no steam (0.30) times the probability of offsite power (0.90). The probability of Case III is the remaining 0.03.

For each testing scheme, the yearly average unavailability, assuming a test interval of 720 h is:

Random testing,

$$\bar{U}_{\text{yr}} = 0.70(3.2 \times 10^{-7}) + 0.27(4.7 \times 10^{-5}) + 0.03(5.4 \times 10^{-4}) = 2.91 \times 10^{-5}.$$

Uniformly staggered testing,

$$\bar{U}_{\text{yr}} = 0.70(1.8 \times 10^{-7}) + 0.27(3.7 \times 10^{-5}) + 0.03(4.8 \times 10^{-4}) = 2.45 \times 10^{-5}.$$

Nearly simultaneous testing,

$$\bar{U}_{\text{yr}} = 0.70(3.8 \times 10^{-7}) + 0.27(5.1 \times 10^{-5}) + 0.03(7.2 \times 10^{-4}) = 3.56 \times 10^{-5}.$$

With the most reliable scheme, the average unavailability is 2.45×10^{-5} , of which 59% is due to the Case III unavailability. With the plots in Figs. 12, 13, and 15, an optimum test interval for the yearly average unavailability can be found. The yearly optimum test interval is 473 h for the staggered testing (most reliable) scheme and gives rise to an average unavailability of 2.22×10^{-5} , a factor of 1.10 times less than the average unavailability with a 720-h test interval.

5. Sensitivity of ICARUS Results

The ICARUS code was incorporated as a set of subroutines into the probabilistic response surface code PROSA⁸ in order to study the sensitivity of the ICARUS results to the various input parameters. To perform this analysis, PROSA assigns selected probability distributions to each parameter being evaluated, and then selects combinations of these input parameters to determine the sensitivity of the results or consequences to the input.

Only Case III results were analyzed, since its contribution to the average unavailability was the greatest. The user-defined consequences in

this case were the average unavailability and the optimum test interval. The log normal distribution was assigned to all the input parameters except for q_0 , which was held constant at 1.0. For the parameters γ_r , γ_e , ρ_f , ρ_u , and λ , 90% confidence limits within a factor of 3 from the nominal values used in Sec. V.C.3 were chosen. For τ_r and τ_t , 99.9% confidence limits and for T a nearly 100% confidence limit were used within the same factor of 3 from nominal.

For Case III, uniformly staggered testing, the average unavailability was sensitive to the input parameters in the order listed in Table XXII. The numbers in the third column are the magnitudes of the sensitivity relative to the least sensitive parameter. Note that the ρ_u , γ_r , and ρ_f parameters are third, fifth, and sixth, respectively, in order of sensitivity. This shows the importance of the new failure modes included in the equations derived earlier. For Case I and II, these modes are even more significant, since for these the random failures (λT) are not dominating as in Case III.

TABLE XXII. Results of Sensitivity Studies

Ranking	$\bar{U}$ Sensitivity		T_{OPTIMUM} Sensitivity		$\bar{U}_{1/2}/\bar{U}_{1/3}$ Sensitivity	
	Parameter	Relative Importance	Parameter	Relative Importance	Parameter	Relative Importance
1	λ	793.0	λ	188.5	λ	1011.1
2	T	134.1	τ_t	46.6	T	198.1
3	ρ_u	85.9	ρ_u	37.4	ρ_u	132.0
4	τ_t	47.0	γ_r	17.0	τ_t	67.6
5	γ_r	42.1	ρ_f	6.3	γ_r	48.8
6	ρ_f	35.5	τ_r	4.2	ρ_f	45.8
7	τ_r	17.7	γ_e	1.0	τ_r	17.5
8	γ_e	1.0	T	0	γ_e	1.0

The optimum test interval of 201 h had a standard deviation of about the same magnitude. The order of the sensitivity of the optimum test interval to the input is also listed in Table XXII. As shown, the ρ_u , γ_r , and ρ_f terms were the third, fourth, and fifth most significant terms in determining the optimum test interval.

A final analysis was performed in which the ratio of the average unavailability of the Case III system (1/2) to the same type of system with three redundancies (1/3 system with Diesel generators) was found to be 56 with a standard deviation of 46. In other words, increasing the system from 1/2 to 1/3 would increase the reliability by a factor of 56, but the uncertainty of this value is high (standard deviation = 46).

The order of sensitivity of the ratio to the input is listed in columns 6 and 7 of Table XXII. Note that this is the same order as for the average unavailability of the 1/2 system.

D. Summary

The results of the analysis show that the average unavailability of the auxiliary feedwater system over a one-year period is 2.45×10^{-5} for the most reliable testing scheme (uniformly staggered testing). Most of this unavailability is due to the Diesel generators being part of the system when no outside power source is available.

The sensitivity analysis of the input shows that the new failure modes introduced in this report are important parameters when evaluating the average unavailability of the auxiliary feedwater system.

VI. SUMMARY AND CONCLUSIONS

A. Summary

Standby safety systems at nuclear power plants are called upon to function if an emergency situation develops. The system, however, may fail to respond due to mechanical breakdown or human failure. It is therefore of interest to be able to calculate the average unavailability of the system in order to quantify this probability of failure to respond.

Efforts have been made in the past to develop methods to calculate the average unavailability of a system as a function of various failure modes and testing practices. For the most part, however, these efforts were either severely limited in the number and type of failures that could be treated, or did not allow for the calculation of other parameters of interest related to the average unavailability, such as the optimum test interval.

In order to treat a variety of failure modes and to apply the treatment to the calculation of the average unavailability in such a way that the optimum test interval of the system could also be easily calculated, analytical equations for all m-out-of-n (m/n , $1 \leq m \leq n \leq 4$) safety systems were developed for completely random, uniformly staggered, and nearly simultaneous testing schemes. A computer code, ICARUS, was written to incorporate these equations in such a way that the contributions of testing, repair, and random failures could also be calculated. Since the average unavailability equations were analytically derived and then programmed, the running time of the computer code is short (<1 s for analysis of all m/n systems with $1 \leq m \leq n \leq 4$).

To verify the coding in ICARUS, comparison runs were made between ICARUS and FRANTIC using options common to both codes. For single-component redundancy systems, the results showed adequate agreement for both uniformly staggered and nearly simultaneous testing.

Since most systems have redundancies made up of more than one component, it was clear that some special treatment would be needed in order to apply ICARUS to these systems. In this work, the multicomponent redundancies were represented by a single effective component. Each input parameter was modified to reflect the "effective" component characteristics.

Comparison runs were then made with FRANTIC for systems having two valves in series making up each redundancy. For the uniformly staggered testing scheme, the agreement was again acceptable for all m/n ($1 \leq m \leq n \leq 4$) systems. In the comparison of the nearly simultaneous testing scheme, the highly redundant system comparisons displayed large errors. After checking against a hand calculation of a $1/3$ system, we concluded that FRANTIC cannot suitably treat these highly redundant systems, which are nearly simultaneously tested.

Finally, ICARUS was used to calculate the average unavailability of an auxiliary feedwater system. Data for testing practice and failure modes was obtained from the literature in order to make a realistic assessment of the unavailability. The auxiliary feedwater system can take on various configurations, depending upon the presence of steam and offsite power. A yearly average unavailability for the system was calculated taking into account different configurations. The uniformly staggered testing scheme was found to be the most desirable. Also, the configuration that has Diesel generators driving the electrical pumps accounts for 59% of the yearly average unavailability.

A sensitivity analysis using the PROSA code was performed to determine which of the ICARUS input parameters were the most important. We found that the failure modes in ICARUS that are not in FRANTIC are important enough so that their omission in any unavailability analysis may lead to inaccurate results.

B. Recommendations for Future Work

The equations developed for the ICARUS code represent an extensive development of average unavailability equations for redundant systems. However, additions could be made to the code that would even more realistically model the system in question. The most important of these is the treatment of common-mode or common-cause failure, since common-mode failure has played an important part in system failures in the past.

A second task that might be undertaken would be the modification of the ICARUS code to handle multicomponent redundancies directly. Each redundancy could be treated as a set of miniature systems whose average unavailabilities could be calculated using the existing ICARUS equations. Depending upon the configuration of the components in the redundancy, the average unavailability of the redundancy and then of the system could be calculated. To be able to calculate the optimum test interval directly, the calculation of the average unavailability should be in terms of coefficients of the powers of the test interval T (see Chapter III). The calculation of the optimum test interval is one of the main features found in ICARUS.

Another line of development includes modifications in the FRANTIC code such that the main features of the ICARUS code, as well as the models of Ref. 7, can be merged to a general availability-analysis code.

APPENDIX A

Linearization of $\exp(-\lambda s)$

In order to simplify the average unavailability expressions, an approximation for $\exp(-\lambda s)$ would be in order. Expanding $\exp(-\lambda s)$ in a Taylor series about the origin (Maclaurin series) yields

$$\exp(-s) = 1 - \lambda s + \lambda^2 s^2/2! - \lambda^3 s^3/3! + \lambda^4 s^4/4! - \dots \quad (\text{A.1})$$

Taking the first two terms of the expansion, we can write $\exp(-\lambda s)$ as

$$\exp(-\lambda s) = 1 - \lambda s. \quad (\text{A.2})$$

The unavailability at any time s can be found from

$$\left. \begin{array}{l} \text{or} \\ U(s) = 1 - \exp(-\lambda s) \approx 1 - (1 - \lambda s) \\ U(s) = \lambda s \end{array} \right\} \quad (\text{A.3})$$

Table A.1 shows the errors incurred using this approximation. For values of λs less than 10^{-3} , which is typical for this study, the error is less than 0.1%.

TABLE A.1. λs vs $1 - \exp(-\lambda s)$

λs	$1 - \exp(-\lambda s)$	Percent Error ^a
1.0	0.6321	58.20
0.5	0.3935	27.07
1.0×10^{-1}	9.52×10^{-2}	5.08
5.0×10^{-2}	4.88×10^{-2}	2.52
1.0×10^{-2}	9.95×10^{-3}	0.501
5.0×10^{-3}	5.98×10^{-3}	0.250
1.0×10^{-3}	9.995×10^{-4}	0.050
5.0×10^{-4}	4.999×10^{-4}	0.025
1.0×10^{-4}	9.9995×10^{-5}	0.005

$$\frac{\lambda s - [1 - \exp(-\lambda s)]}{1 - \exp(-\lambda s)} \times 100\%.$$

APPENDIX B

ICARUS Users' Manual

1. Program Summary

The program calculates the unavailability characteristics of a periodically tested standby safety system with m-out-of-n redundancy ($1 \leq m \leq n \leq 4$).

The main functions of the program are to calculate the average unavailability, the optimum test interval, and fractional unavailabilities due to testing, repair, and random failures for three different testing strategies. It will also calculate the average unavailability as a function of the test interval at each point in the range $0.2T_{\text{OPTIMUM}}$ to $1.8T_{\text{OPTIMUM}}$ at intervals of $0.2T_{\text{OPTIMUM}}$.

The code can be used to evaluate sensitivities to different failure modes and data as well as current testing/repair strategies to determine if changes to these strategies will optimize the system availability.

2. Program Abstract

a. Name of Program. ICARUS

b. Computer for Which Program Is Designed. IBM 370/195

c. Description of Problem. The problem is to determine the average unavailability of a standby system with m/n redundancy, given that it can fail due to testing, maintenance, mechanical failure, or human error. The m/n redundancy means that the system has n parallel components, each with 100%/m capacity; i.e., operation of m components is needed to perform the safety function.

ICARUS first calculates the average unavailability, optimum test interval, and average unavailability at the optimum test interval, given the system configuration and testing scheme. If desired, the code then calculates the average unavailabilities at points around the optimum test interval and also calculates the unavailability contributions due to testing, repair, and random failures.

d. Method of Solution. As input data, the program needs the system configuration (m and n), testing scheme, testing and repair parameters, and values for the testing, repair, and standby failure modes. Using these data, the program calculates the average unavailability for the system and solves for the optimum test interval of the system using the unavailability equation. Since the analytical equations for each system and testing strategy are programmed into the code, computational time is very short.

If desired by the user, the code calculates the average unavailability in the interval $0.2T_{\text{OPTIMUM}}$ to $1.8T_{\text{OPTIMUM}}$ at each $0.2T_{\text{OPTIMUM}}$ increment. The program then calculates the contributions (numerically and in percent) that testing, repair, and random failures make to the average unavailability.

e. Restrictions on the Complexity of the Problem. The system configuration can only be m/n with $1 \leq m \leq n \leq 4$, which is sufficient for most safety systems currently in use. The three testing strategies allowed in the code are:

Random
Uniformly staggered
Nearly simultaneous.

In the random testing scheme, the components are tested at randomly shifted times throughout the test interval. The uniformly staggered testing scheme has the component tests being performed at equally spaced times throughout the test interval. Finally, in the nearly simultaneous testing scheme, all the components are tested consecutively at the beginning of the test interval.

The equations assume only one component per redundancy. However, redundancies with several components in series can be analyzed by properly defining the failure data for a series system in terms of the data for individual components.

f. Typical Running Time. Typical running time for all m/n ($1 \leq m \leq n \leq 4$) systems and all three testing schemes is <1 s on an IBM 370/195.

g. Unusual Features of the Program. The analytical unavailability equations for all 28 systems (1/1 system plus nine systems times three testing schemes per system) are separately programmed in the code. For each system, the equations (divided into coefficient equations) are polynomials with both positive and negative powers of the test interval. This allows for the calculation of the optimum test interval by taking the derivative of the average unavailability equation with respect to the test interval, setting that equal to zero, and solving for the optimum test interval. When a numerical solution is required, the Newton-Raphson method, which converges quickly for polynomial equations of this type, is used. Direct analytical equations are available for the random testing scheme.

h. Related and Auxiliary Programs. The ICARUS code can be used with the PROSA response surface analysis code to determine the sensitivities and probability distributions of the unavailabilities and optimum test intervals.

i. Status. The program is operational at ANL.

- j. References. Publications in preparation.
- k. Machine Requirements. IBM 370/195; card reader; line printer.
- l. Programming Language Used. FORTRAN IV.
- m. Operating System. IBM System/370 Model 195; FORTRAN IV (G) or (H) compiler with optimizer.
- n. Other Programming or Operating Information or Restrictions.
All floating-point variables are double precision.
- o. Name and Establishment of Author. Dominic Sciaudone; University of Lowell, Nuclear Engineering Department, 1 University Avenue, Lowell, Massachusetts 01854. J. K. Vaurio, Argonne National Laboratory, Bldg. 208, 9700 S. Cass Avenue, Argonne, Illinois 60439.
- p. Material Available. Source decks, sample problem, control cards.
- q. Category. P. General Mathematical and Computing System Routines.
- r. Keywords. Availability, human errors, periodic testing, redundancy, redundant, reliability, safety system, testing, test interval, unavailability.

3. Program Use

ICARUS can be directed to perform four different tasks. The task to be executed is specified by the input variable ITASK. The tasks are described in Sec. a below. The input for each task is specified in Sec. b below. The flow charts for the program are presented in Appendix C, and the function of each subroutine is briefly described in Sec. c below.

a. Task Descriptions

Each execution of the program performs any one of the following four tasks specified by the variable ITASK. After each case, the program control returns to the beginning and a new case starts (number of cases specified by NCASE).

(1) Task 1 (ITASK = 1): Selected System Unavailabilities.
Calculates and prints the average unavailability, optimum test interval, and average unavailability at the optimum test interval for any system, testing scheme, and failure-mode probabilities specified by the user.

(2) Task 2 (ITASK = 2): Selected System Total and Fractional $\bar{U}$

(a) Performs same task as Task 1.

(b) Calculates and prints the average unavailability of each point in the interval $0.2T_{\text{OPTIMUM}}$ to $1.8T_{\text{OPTIMUM}}$ at an increment of $0.2T_{\text{OPTIMUM}}$.

(c) Calculates the average unavailability contributions due to testing, repair, and random failures in the form of numerical values and percents.

(3) Task 3 (ITASK = 3): All System Unavailabilities. Performs the same task as Task 1 for all m/n systems ($1 \leq m \leq n \leq 4$) and testing schemes using one set of component input values. There are 28 systems in all.

(4) Task 4 (ITASK = 4): All System Total and Fractional Unavailabilities. Performs the same task as Task 2 but for all systems and testing schemes using one set of component input values.

b. Input Instructions

Card 1

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Description</u>
NCASE	1-6	I6	Number of cases to be run

Card 2

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Description</u>
ITASK	1-6	I6	Task indicator (see Sec. a above)

Card 3

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Description</u>
ITITLE	1-80	20A4	Title of case

Card 4 (Optional; only needed for ITASK = 1 or 2)

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Description</u>
NSYSTEM	1-6	I6	Number of systems to be run for case

Card 5

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Descriptions</u>
IMARK	1-12	I12	Marker for system and testing scheme. Three-digit integer. First two digits specify system (12, 1/2 system, etc.) Last digit specifies testing scheme. 1 = random 2 = uniformly staggered 3 = nearly simultaneous. Use IMARK = 100 when ITASK = 3 or 4.

Card 5 (Contd.)

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Descriptions</u>
GAMMAE	13-24	D12.5	Probability that a test causes a failure that gets repaired.
GAMMAR	25-36	D12.5	Probability that a true demand causes a failure.
LAMBDA	37-48	D12.5	Failure rate per hour of component redundancy.
QZERO	49-60	D12.5	Fraction of downtime for a component during a test.
RHOF	60-72	D12.5	Probability that a component that had failed before the test is not detected or not repaired due to human testing error, detection error, or human repair error.

Card 6

<u>Variable</u>	<u>Columns</u>	<u>Format</u>	<u>Descriptions</u>
RHOU	1-12	D12.5	Probability that a test caused a failure that does not get repaired before the next test (negligence or hidden failure).
TAUR	13-24	D12.5	Duration of repair period.
TAUT	25-36	D12.5	Duration of test period.
TUP	37-48	D12.5	Duration of test interval.

c. Subroutine Functions

The function of each subroutine is described below.

CALC	Calculates average unavailabilities and writes all results.
COMB	Calculates the binomial coefficient.
FRACUN	Calculates fractional unavailabilities and writes results
ITERAT	Calculates optimum test interval using Newton-Raphson method.
MAIN	Reads data, calculates unavailability coefficients, and performs overall routine control.

APPENDIX C

Flow Diagrams for ICARUS

Figures C.1-C.3 present the logic used in the calculational subroutines of the ICARUS computer code.

Fig. C.1. Flow Diagram for MAIN Routine

Fig. C.1 (Contd.)

Fig. C.1 (Contd.)

Fig. C.2. Flow Diagram for CALC Subroutine

Fig. C.3. Flow Diagram for ITERAT Subroutine

APPENDIX D

ICARUS Program Listing

The following is a computer listing of the ICARUS computer code.

```

C
C   MAIN PROGRAM
C
C   IMPLICIT REAL*8(A-H,O-Z)
C   REAL*8 LAMBDA
C   COMMON/INTVAR/N,IMRK,IMRK1,ITASK,IWRITE,NN(28),IFLAG,ISIGN,NNSYS
C   1,ITT
C   COMMON/FLTVAR/GAMMAE,GAMMAR,LAMBDA,QZERO,RHOF,RHOU,TAUR,TAUT,TUP,
C   1ERR,A,B,C,D,E,F,TOPT,AP,BP,CP,UBAR1,UBOPT1,TOPT1,USP,UBT,UBT1,UBT2
C   2,UBT3,UBT12,UBT22,UBT32,THETA
C   DIMENSION ISYSTN(450),ITITLE(20)
C   DATA ISYSTN/109*0,1,10*0,2,3,4,7*0,8,9,10,7*0,17,18,19,77*0,5,6,7,
C   17*0,11,12,13,7*0,20,21,22,87*0,14,15,16,7*0,23,24,25,97*0,26,27,28
C   2,7*0/
C   DATA ITITLE/20*4H
C   IREAD=5
C   ICASE=0
C   ERR=1.0D-03
C
C INPUT DATA DEFINITIONS
C
C NCASE   NUMBER OF CASES TO BE RUN - 1 CARD ONLY
C ITITLE  TITLE OF CASE TO BE RUN - 1 FOR EACH CASE
C ITASK   ITASK=1 PRINTS UBAR, T OPTIMUM, AND UBAR(TOPT) FOR SYSTEMS
C         DESIGNATED BY VARIABLE IMARK
C         ITASK=2 PRINTS ITASK=1 INFORMATION PLUS UBAR(TOPT) FOR VALUES
C         OF .2*TOPT TO 1.8*TOPT, AND THE FRACTIONAL UNAVAILABILITIES
C         ITASK=3 PRINTS UBAR, T OPTIMUM, AND UBAR(TOPT) FOR ALL SYSTEMS
C         ITASK=4 PRINTS ALL INFORMATION FOR ALL THE SYSTEMS
C IMARK   MARKER TO DESIGNATE SYSTEM DESIRED - 122 DENOTES 1/2 SYSTEM,
C         STAGGERED TESTING. FIRST 2 INTEGERS ARE SYSTEM CONFIGURATION
C         LAST INTEGER IS TESTING SCHEME: 1-RANDOM 2-STAG. 3-SINULT.
C         IF ITASK IS GREATER THAN 2, SET IMARK TO 100
C NSYSTEM NUMBER OF SYSTEMS TO BE INVESTIGATED (ONLY IF ITASK < 3)
C GAMMAE  PROBABILITY THAT A TEST CAUSES A FAILURE THAT GETS REPAIRED
C GAMMAR  PROBABILITY OF A TRUE DEMAND COMPONENT FAILURE
C LAMBDA  CONSTANT FAILURE RATE FOR A SINGLE COMPONENT
C QZERO   FRACTION OF DOWN TIME DURING A TEST
C RHOF    PROBABILITY THAT A COMPONENT WHICH HAD FAILED BEFORE THE TEST
C         IS RANDOMLY NOT DETECTED AS BEING FAILED BY A TEST OR DOES NOT
C         GET REPAIRED (HUMAN TESTING ERROR, DETECTION ERROR, OR HUMAN
C         REPAIR ERROR)
C RHOU    PROBABILITY THAT A TEST CAUSES A FAILURE THAT DOES NOT GET
C         REPAIRED BEFORE THE NEXT TEST (NEGLIGENCE OR HIDDEN TYPE FAILURE)
C TAUR    REPAIR TIME
C TAUT    TESTING TIME
C TUP     TESTING INTERVAL
C
C READ NUMBER OF CASES TO BE RUN
C
C   READ(IREAD,1000) NCASE
C
C START OF NCASE LOOP
C
C   1 CONTINUE
C
C INITIALIZE FOR CASE
C
C   ICASE=ICASE+1

```

```

        IMARK=0
        N=0
        NNSYS=0
C
C READ TASK NUMBER
C
        READ(IREAD,1000) ITASK
C
C READ AND WRITE CASE TITLE
C
        READ(IREAD,1300) (ITITLE(I),I=1,20)
        WRITE(IWRITE,1200) ICASE,(ITITLE(I),I=1,20)
C
C IF ITASK<3 READ NUMBER OF SYSTEMS TO BE INVESTIGATED
C
        IF(ITASK.GT.2) GO TO 2
        READ(IREAD,1000) NSYSM
        GO TO 3
    2 CONTINUE
        NSYSM=28
    3 CONTINUE
C
C IF ITASK>2, READ VARIABLE INPUT ONLY ONCE. IF NOT, READ NSYSM INPUTS.
C
        IF(IMARK.EQ.100) GO TO 4
        READ(IREAD,1100) IMARK,GAMMAE,GAMMAR,LAMBDA,QZERO,RHOF,RHOU,TAUR,
        1TAUT,TUP
        QZEROP=QZERO
        TAUTP=TAUT
    4 CONTINUE
C
C INITIALIZE FOR SYSTEM
C
C RESET TESTING VARIABLES
C
        QZERO=QZEROP
        TAUT=TAUTP
C
C ITT DEFINES WHICH INPUT CRITERION WAS NOT MET (IF ANY).
C
        ITT=0
C
C IFLAG DEFINES WHICH FRACTIONAL UNAVAILABILITY IS BEING CALCULATED.
C
        IFLAG=0
        N=N+1
        NNSYS=NNSYS+1
        IF(MOD(ITASK,2).NE.0) GO TO 8
C
C SET TESTING PARAMETERS FOR FRACTIONAL UNAVAILABILITY (ITASK=2,4)
C
    44 CONTINUE
        IFLAG=IFLAG+1
        IF(IFLAG.EQ.2) GO TO 6
        GO TO 9
    6 CONTINUE
        QZERO=0.000
        GO TO 9
    8 CONTINUE
        IFLAG=4

```

```

9 CONTINUE
  IF(ITASK.GT.2) GO TO 5
  N=ISYSTH(INARK)
5 CONTINUE

C
C   NN DEFINES SYSTEM AND TESTING SCHEME.
C
C
C   ISIGN DEFINES THE TESTING SCHEME.
C
C
C   IV DEFINES THE NUMBER OF SYSTEM REDUNDANCES.
C
  ISIGN=NN(N)-(NN(N)/10)*10+1
  IV=((NN(N)/10)*10-(NN(N)/100)*100)/10
C
C MAKE SURE INPUT CRITERIA ARE MET FOR EACH SYSTEM. ADJUST VALUES TO MEET
C CRITERIA IF POSSIBLE. IF NOT, PRINT ERROR MESSAGE.
C
  IF(ISIGN.NE.4) GO TO 19
  IF(TAUR.LT.1.00-50) GO TO 112
  THETA=TAUT+TAUR
  GO TO(19,15,16,17),IV
15 CONTINUE
  THU=THETA-2.0*TAUT
  IF(THU.GE.0.000) GO TO 19
  THU=0.000
  TAUT=TAUR
  ITT=1
  GO TO 18
16 CONTINUE
  THU=THETA-3.0*TAUT
  IF(THU.GE.0.000) GO TO 19
  THU=0.000
  TAUT=TAUR/2.000
  ITT=2
  GO TO 18
17 CONTINUE
  TSIG=THETA-4.0*TAUT
  IF(TSIG.GE.0.000) GO TO 19
  TSIG=0.000
  TAUT=TAUR/3.000
  ITT=3
18 CONTINUE
  QZERO=QZEROP*TAUTP/TAUT
19 CONTINUE
  IF(QZERO.GT.1.000) GO TO 112

C
C VARIABLE DEFINITIONS
C
  THETA=TAUT+TAUR
  GDELTA=RHOF-RHOU
  GDEL=1.0-GDELTA
  CUP=GAMMAR+RHOU/GDEL

C
C   WITH SIMULTANEOUS TESTING, AUP USED IN INTEGRATING FROM 0 TO T.
C   WITH RANDOM AND STAGGERED TESTING, AUP-CUP IS USED.
C
  AUP=QZERO+(1.0-QZERO)*(GAMMAR+GAMMAE+RHOU*(2.0-GDELTA)/GDEL)-CUP
  /DN=(1.0-QZERO)*LANBDA

```



```

      BUP=GAMMAR+GAMMAE+RHO*U*(2.0-GDELTA)/GDEL-CUP
      BDN=LAMSDA
      IF(ISIGH.NE.4) GO TO 12
      AUP=AUP+CUP
      BUP=BUP+CUP
12  CONTINUE
      AUP2=AUP*AUP
      ADN2=ADN*ADN
C
C SET REPAIR PARAMETERS FOR FRACTIONAL UNAVAILABILITY.
C
      IF(IFLAG.NE.3) GO TO 11
      BUP=0.000
      BDN=0.000
11  CONTINUE
      BUP2=BUP*BUP
      BDN2=BDN*BDN
      CUP2=CUP*CUP
      DUP=(1.0+GDELTA)/GDEL
      SUP=TAUT*AUP+TAUR*CUP
      SDN=TAUT*ADN+TAUR*BDN
      DLN=DUP*LAMSDA
      DLN2=DLN*DLN
      CDT=CUP+DLN*THETA
      CDT2=CDT*CDT
      EDDLN=BDN+DLN
      AADB=AUP*BDN+BUP*ADN
      AB=ADN+BDN
      BA=AUP+EUP
      CB=BUP+CUP
      CA=AUP+CUP
      AFN1=AUP-1.0
      AFN2=AFN1*AFN1
      BFN1=EUP-1.0
      BFN2=BFN1*BFN1
      CFN1=CUP-1.0
      CFN2=CFN1*CFN1
      A=0.0
      B=0.0
      C=0.0
      D=0.0
      E=0.0
      F=0.0
      AP=SUP
      BP=SDN+CUP
      CP=DLN/2.0
      TOPT1=DSQRT(AP/CP)
      IF(TOPT1.LT.1.0D-20) TOPT1=1.0D-20
      UGAR1=AP/TUP+BP+CP*TUP
      UBOPT1=AP/TOPT1+BP+CP*TOPT1
C
C GO TO SYSTEM DESIGNATED BY ISYSTEM(IMARK).
C
      GO TO (10,20,30,40,50,60,70,80,90,100,110,120,130,140,150,160,170,
1130,190,200,210,220,230,240,250,260,270,280),N
C
      1/1 SYSTEM
C
C
10  CONTINUE

```

```

      CALL CALC
      IF(IFLAG.LT.3) GO TO 44
      GO TO 110
C      1/2 SYSTEM - COMPLETELY RANDOM TESTING
C
20 CONTINUE
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      1/2 SYSTEM - COMPLETELY STAGGERED TESTING
C
30 CONTINUE
  A=2.0*CUP*SUP
  B=2.0*CUP*SDN+DLM*SUP+CUP2
  C=DLM*(SDN+CUP)
  D=5.0/24.0*DLM2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      1/2 SYSTEM - SIMULTANEOUS TESTING
C
40 CONTINUE
  A=TAUT*(AUP*CB+BUP*CDT)+TMU*SUP2
  B=TAUT*(AUP*BDDLH+ADN*CB+BDN*CDT)+2.0*BUP*SDN*TMU+CUP2
  C=TAUT*ADN*(DDLH+BDN2+TMU+CUP*DLM
  D=1.0/3.0*DLM2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      2/2 SYSTEM - COMPLETELY RANDOM TESTING
C
50 CONTINUE
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      2/2 SYSTEM - COMPLETELY STAGGERED TESTING
C
60 CONTINUE
  A=2.0*(CUP*(THETA-SUP)+SUP)
  B=-2.0*SDN*CPH1+DLM*(THETA-SUP)+2.0*CUP-CUP2
  C=-1.0*DLM*(SDN+CPH1)
  D=-5.0/24.0*DLM2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      2/2 SYSTEM - SIMULTANEOUS TESTING
C
70 CONTINUE
  A=TAUT*(-CPH1*AUP+2.*BUP+CUP-BPM1*(AUP+CDT))+TMU*BUP*(2.0-BUP)
  B=TAUT*(-APH1*BDDLH+ADN*(2.-CB)+BDN*(1.-CDT))-2.0*TMU*BDN*BPM1+CUP
  1*(2.0-CUP)
  C=-1.0*(ADN*TAUT*BDDLH+TMU*BDN2+DLM*CPH1)
  D=-1.0/3.0*DLM2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44

```

```

      GO TO 110
C
C      1/3 SYSTEM - COMPLETELY RANDOM TESTING
C
80 CONTINUE
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      1/3 SYSTEM - COMPLETELY STAGGERED TESTING
C
90 CONTINUE
  A=3.0*CUP2*SUP
  B=3.0*CUP2*SDN+3.0*CUP*DLN*SUP+CUP*CUP2
  C=DLN*(3.0*CUP*CDT+2.0/3.0*DLN*SUP+1.5*CUP2)
  D=2.0/3.0*DLN2*(SDN+CUP)
  E=1.0/12.0*DLN*DLN2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      1/3 SYSTEM - SIMULTANEOUS TESTING
C
100 CONTINUE
  A=TAUT*(AUP*(CUP2+CUP+CUP*BUP2)+BUP*CDT*(BUP+CDT))+TNU*BUP2*BUP
  B=TAUT*(AUP*DLN*(CUP+2.0*CUP)+AUP*BDN*(2.0*BUP+CUP)+ADN*(BUP2+BUP*
1CUP+CUP2)+BDN*CDT+(2.0*BUP+CDT))+3.0*TNU*CUP2*BDN+CUP*CUP2
  C=TAUT*(ADN*DLN*(BUP+2.0*CUP)+AUP*DLN*DDLN+ADN*BDN*(2.0*BUP+CUP)+
1EDN2*(AUP+CDT))+3.0*TNU*BUP*BDN2+1.5*CUP2*DLN
  D=TAUT*(ADN*DLN*BDN+ADN*BDN2)+TNU*BDN*BDN2+CUP*DLN2
  E=.25*DLN*DLN2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      2/3 SYSTEM - COMPLETELY RANDOM TESTING
C
111 CONTINUE
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      2/3 SYSTEM - COMPLETELY STAGGERED TESTING
C
120 CONTINUE
  A=3.0*CUP*(2.0*(1.0-CUP)*SUP+CUP*THETA)
  B=3.0*DLN*(1.0-2.0*CUP)*SUP-6.0*CUP*CPH1*SDN+3.0*CUP*DLN*THETA+CUP
12*(3.0-2.0*CUP)
  C=3.0*DLN*(1.-2.*CUP)*SDN+2./3.*DLN2*(THETA-2.*SUP)-3.*CUP*DLN*CPM1
  D=-2.0/3.0*DLN2*(2.0*(SDN+CUP)-1.0)
  E=-1.0/6.0*DLN*DLN2
  CALL CALC
  IF(IFLAG.LT.3) GO TO 44
  GO TO 110
C
C      2/3 SYSTEM - SIMULTANEOUS TESTING
C
130 CONTINUE
  A=TAUT*((1.-2.*AUP)*(CUP2+BUP*CUP)+3.0*AUP*CUP+AUP*BUP*(3.0-2.0*B
1P)+2.*BUP2+2.*BUP*CDT*(2.-BUP)+CDT2*(1.-2.*BUP))+TNU*BUP2*(3.-2.*B

```

```

2UP)
B=TAUT*(1.-2.*CUP)*(2.*AUP*DLH+AABD)+2.*CUP*(DLH-ADN*CPH1)+DLH*(A
1UP+SUP-2.*AUP*SUP)+CUP*AB+2.*BDN*(1.-2.*SUP)*(AUP+CDT)-2.*ADN*CUP*
2BPH1+4.*SUP*BDN+2.*BDN*CDT*(1.-CDT))-6.*TNU*BDN*SUP*BPH1+CUP2*(3.-
32.*CUP)
C=TAUT*(2.*ADN*BDLH*(1.-2.*CUP)+(1.-2.*AUP)*(DLH2+BDN*DLH+BDN2)+(
11.-2.*SUP)*2.*ADN*BDLH+BDN2*(1.-2.*CDT))+3.*TNU*BDN2*(1.-2.*CUP)-
23.*CUP*DLH*CPH1
D=-2.0*(TAUT*ADN*(BDN2+BDN*DLH+DLH2)+TNU*BDN*BDN2-DLH2*(.5-CUP))
E=-.5*DLH*DLH2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110

C
C      3/3 SYSTEM - COMPLETELY RANDOM TESTING
C
140 CONTINUE
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110

C
C      3/3 SYSTEM - COMPLETELY STAGGERED TESTING
C
150 CONTINUE
A=3.0*(THETA+CPH2*(SUP-THETA))
B=3.0*CPH2*SDN+3.0*CPH1*DLH*(SUP-THETA)+1.0+CPH1*CPH2
C=3.0*DLH*(2.0/9.0*DLH*(SUP-THETA)+CPH1*SDN+.5*CPH2)
D=2.0/3.0*DLH2*(SDN+CPH1)
E=1.0/12.0*DLH*DLH2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110

C
C      3/3 SYSTEM - SIMULTANEOUS TESTING
C
160 CONTINUE
A=5.0*TAUT+TAUT*(AFH1*CPH1*(CB-2.)+AFH1*BPH2+BPH1*(1.-CDT)*(2.-SUP
1.-CDT))+TNU*TNU*BPH1*CPH2
D=1.00*TAUT*(CPH1*(2.*AFH1*DLH+ADN*CPH1)+AFH1*BPH1*DLH+BDN*AFH1*(2
1.*SUP+CUP-3.1+ADN*SDH1*(CB-2.)+BDN*(1.-CDT)*(3.-2.*CUP-CDT))+3.*TN
2U*BDN*BPH2+CPH1*CPH2+1.0
C=TAUT*(ADN*CPH1*(BDN+2.0*DLH)+AFH1*(BDN2+DLH*BDN+DLH2)+ADN*BPH1*(
12.0*BDN+DLH)-BDN2*(1.0-CDT))+3.0*BPH1*TNU*CDN2+1.5*CPH2*DLH
D=TAUT*(ADN*DLH*BDLH+ADN*CDN2)+TNU*BDN*BDN2+CPH1*DLH2
E=.25*DLH*DLH2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110

C
C      1/4 SYSTEM - COMPLETELY RANDOM TESTING
C
170 CONTINUE
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110

C
C      1/4 SYSTEM - COMPLETELY STAGGERED TESTING
C
180 CONTINUE
A=4.0*CUP*CUP2*SUP

```

```

B=CUP2*CUP2+4.0*CUP*CUF2*SDN+6.0*CUP2*DLN*SUP
C=CUP*DLN*(6.0*CUP*SDN+2.75*DLN*SUP+2.0*CUP2)
D=.125*DLN2*(22.0*CUP*SDN+3.0*DLN*SUP+11.0*CUP2)
E=3.0/8.0*DLN*DLN2*(SDN+CUP)
F=251.0/7680.0*DLN2*DLN2
CALL CALC
IF(IFLAG,LT.3) GO TO 44
GO TO 110

```

```

C
C      1/4 SYSTEM - SIMULTANEOUS TESTING
C

```

```

190 CONTINUE
A=TAUT*((AUP*(BUP*BUF2+CUP*CUP2)+AUP*BUP*CUP*CB+SUP*CDT*(BUP2+CDT2+
1BUP*CDT))+TSIG*BUP2*CUP2
B=TAUT*((AUP*DLN*ADN*CUP)*(CUP*CB+BUP2)+AUP*CUP*DLN*(BUP2+CUP)+A
1UP*BDN+CUP*(2.0*BUP+CUP)+BUF2*(3.0*AUP*BDN+BUP*ADN+3.0*BDN*CDT)+BD
2N*CDT2*(2.0*BUP+CDT))+4.0*TSIG*BUP*BUF2*BDN*CUF2*CUP2
C=TAUT*((AUP*DLN*ADN*CUP)*(3.0*CUP*DLN*CUP*DLN*BDN*CUP)+AABB*(CUP*
1DLN*BUP*DLN*BDN*CUP+3.0*BUP*BDN)+BUP*BDN*(AUP*DLN*ADN*CUP)+BDN2*CDT
2*(3.0*BUP+CDT))+6.0*TSIG*CUF2*BDN2+2.0*CUP2*CUP*DLN
D=TAUT*(SDN*(DLN*(AUP*DLN+2.0*ADN*CUP)+BDN*(AUP*BDN+2.0*ADN*BUP))+
1ADN*CB*(BDN2*DLN2+BDN2*BDN*CDT)+4.0*TSIG*BUP*BDN*BDN2+2.0*CUP2*DLN2
E=ADN*TAUT*(DLN2*BDN2)*BDN*BDN2*BDN2+TSIG*CUP*DLN*DLN2
F=.2*DLN2*DLN2
CALL CALC
IF(IFLAG,LT.3) GO TO 44
GO TO 110

```

```

C
C      2/4 SYSTEM - COMPLETELY RANDOM TESTING
C

```

```

200 CONTINUE
CALL CALC
IF(IFLAG,LT.3) GO TO 44
GO TO 110

```

```

C
C      2/4 SYSTEM - COMPLETELY STAGGERED TESTING
C

```

```

210 CONTINUE
A=4.0*CUP2*(-3.0*CFH1*SUP+CUP*THETA)
B=6.0*CUP*DLN*(2.-3.0*CUP)*SUP-12.0*CUP2*CFH1*SDN+6.0*CUP2*DLN*THETA-
13.0*CUP2*CUP2+4.0*CUF2*CUP
C=DLN*(2.75*DLN*((1.0-3.0*CUP)*SUP+CUP*THETA)+CUP*(6.0*(2.0-3.0*CU
1P)+SDN-6.0*CUP*CFH1))
D=1.78*DLN2*(22.0*(1.-3.0*CUP)*SDN-3.0*DLN*(3.0*SUP-THETA)+11.0*CUP*(2
1.0-3.0*CUP))
E=-3.0/8.0*(3.0*(SDN+CUP)-1.0)*DLN*DLN2
F=-251.0/2560.0*DLN2*DLN2
CALL CALC
IF(IFLAG,LT.3) GO TO 44
GO TO 110

```

```

C
C      2/4 SYSTEM - SIMULTANEOUS TESTING
C

```

```

220 CONTINUE
A=TAUT*(-3.0*AUP*CUP2*CFH1+CUP2*CUP+AUP*BUP*CUP*(2.0-3.0*CUP)+CUP2
13A*BUP2*CA*BUP*(2.-3.0*BUP)*(CUP*AUP*CDT2)-3.0*BUF2*CFH1*(AUP*CDT)+
22.0*BUP*BUF2+2.0*CDT*CUP2+3.0*CUP*CDT2+CDT*CDT2*(1.-3.0*BUP))+TSIG*BUP
3*BUP2*(4.-3.0*BUP)
B=TAUT*(CUP*(2.-3.0*CUP)*(3.0*AUP*DLN+AABB)+3.0*CUP2*(DLN*CFH1*ADN)+2
1.0*AUP*BUP*DLN*(1.-3.0*CUP)+2.0*BA*CLP*DLN+CUP2*AB*(2.-3.0*BUP)*BUP*(A

```

```

2UP*DLH+ADN*CUP+3.*BDN*(AUP+CDT))+2.*BDN*(1.-3.*BUP)*(CUP*AUP+CDT2)
3*BUP2*(ADH+DLH)+2.*BUP*BDN*CA-3.*ADN*BUP2*BFH1+6.*BUP2*BDN+4.*BUP*
CDN*CDT+3.*BDN*CDT2*(1.-CDT))-12.*TSIG*BUP2*BDN*BFH1+CUP2*CUP*(4.-
5.*BUP)
C=TAUT*(DLH*(1.-3.*CUP)*(3.*AUP*DLH+2.*AAB)+ADN*CUP*(2.-3.*CUP)*(
1BDN+3.*DLH)+DLH2*(BA+3.*(CUP-AUP*BUP))+2.*AB*CUP*DLH+BDN*(1.-3.*CU
2P)*(2.*(AUP*DLH+ADN+CUP)+3.*BDN*(AUP+CDT))+ADH*BUP*(2.-3.*BUP)*(3.
3*BDN+DLH)+2.*BUP*BDN*(ADH+DLH)+BDH2*(CA+3.*(2.*BUP-AUP*CUP))+BDH2*
4CDT*(2.-3.*CDT))+6.*TSIG*BUP*BDN2*(2.-3.*CUP)-6.*CUP2*DLH*CFH1
D=TAUT*(ADH*(1.-3.*CUP)*(BDH2+DLH*(3.*DLH+2.*BDN)))+(1.-3.*AUP)*(DL
1H+DLH2+BDH2*DLH+BDN*BDH2)+DLH2*(AB-3.*AAB)+ADN*CDN*(1.-3.*CUP)*(3
2.*BDN+2.*DLH)+BDN*BDH2*(1.-3.*CDT))+4.*TSIG*BDN*BDN2*(1.-3.*CUP)+2
3.*CUP*DLH2*(2.-3.*CUP)
E=-3.*ADN*TAUT*BDLH*(BDH2+DLH2)-3.*TSIG*BDH2*BDN2*DLH*DLH2*(1.-3.
1*CUP)
F=-3.0/5.0*DLH2*DLH2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C      3/4 SYSTEM - COMPLETELY RANDOM TESTING
C
230 CONTINUE
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C      3/4 SYSTEM - COMPLETELY STAGGERED TESTING
C
240 CONTINUE
A=4.0*CUP*(CUP*THETA*(3.-2.*CUP)+3.*CFH2*SUP)
B=3.0*CUP2-CUP2-8.0*CUP+CUP2+6.0*CUP2+6.0*DLH*(1.0-4.0*CUP)*SUP+6.
10-CUP*DLH*(-2.0*THETA*CFH1+3.0*CUP*SUP)+12.0*CUP*BDN*CFH2
C=6.*DLH*BDN*CFH1*(3.*CFH1+2.)+2.75*DLH2*(3.*CFH1+1.)*SUP-THETA*(
12.*CFH1+1.))+6.*CUP*CFH2*DLH
D=9./8.*DLH2*DLH*SUP-.75*DLH2*DLH*THETA+2.75*DLH2*(3.*CFH1+1.)*BDN
1+11./8.*(3.*CFH1+2.)*CFH1*DLH2
E=9./8.*DLH*DLH*BDN+3./8.*DLH*DLH2*(3.*CFH1+1.)
F=251./2560.*DLH2*DLH2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C      3/4 SYSTEM - SIMULTANEOUS TESTING
C
250 CONTINUE
A=TAUT*(3.*AUP*CUP*CFH2+2.*CUP2*(2.-CUP)+AUP*BUP*CUP*(3.*CB-8.)+(B
1UP+3.*CUP-2.*CUP2)*BA+BUP*CA*(1.-2.*BUP)+BUP*BUP2*(3.*AUP-2.)*BUP2
2*(7.-2.*BUP-6.*(CDT+AUP))+4.*AUP*BUP+3.*BUP*CDT*(1.+BUP2*(CDT-1.)*
3*2)+2.*CDT2*(2.-CDT)+BUP*CDT*(3.*BUP*CDT-4.*(CDT+BFH1)))+TSIG*BUP2
4*(3.*CUP2-8.*CUP+6.)
B=TAUT*(3.*ADH*CUP*CFH2+(3.*CUP-1.)*CFH1*(3.*AUP*DLH+AAB)-2.*CUP*
1CFH1*(AB+3.*DLH)+2.*DLH*(AUP*(1.-2.*CUP)+BUP*(1.-2.*CUP)+CUP*(1.-2
2.*AUP))+AAB*(3.*BUP2+3.*CUP*(3.*BUP-4.))+BDN*CA*(1.-4.*BUP)+BUP*D
3LN*(6.*AUP+CUP-4.*AUP+1.)*BA+DLH*AB*(2.*BUP+CUP-6.*BUP2)-2.*BUP2*(
4ADH+DLH)+3.*AUP*BUP*(CUP*DLH+BDN+CUP)+BDN*(AUP+2.*BUP+6.*AUP*BUP2)
5+6.*BUP*BDN*(2.-2.*AUP-BUP-2.*CDT)+BDN*CDT*(9.*BUP2+7.-8.*BUP+3.*(
6CDT-1.))*2)+2.*BDH*CDT2*(3.*BUP-2.))+12.*BUP*BDN*TSIG*BFH2+CUP2*(3
7.*CUP2-8.*CUP+6.)
C=TAUT*(3.*ADH*DLH*(3.*CUP-1.)*CFH1+DLH2*(3.*AUP*BUP-2.*BA-6.*CUP+

```

```

14.)*(3.*CUP-2.)*DLN*(2.*AABD+3.*AUP*DLN)+ADN*BDN*CUP*(3.*CUP-8.)*A
2DN*BDN*(9.*BUP2+1.)*BDN*(1.-4.*BUP)*(4.*ADN*DLN)+AABD*(3.)*(BUP*DLN
3+BDN*CUP)-4.*DLN)+AP*(BDN+3.*DLN-4.*CUP*DLN)+BDN2*(3.-8.*AUP-2.*CU
4P)+3.*BUP*BDN*(AUP*DLN+ADN*CUP+BDN*(3.*AUP-2.))+BDN2*(3.)*(CDT*(3.*
5BUP-2.))-2.*BUP+1.)*(CDT-1.)*(3.*CDT-1.))+6.*TSIG*BDN2*(3.*BUP-1.0
6)*BPM1+6.*CUP*DLN*CPM2
D=TAUT*((3.*AUP-2.)*(BDN2*BDN*DLN*DLN2)+ADN*DLN*(3.*CUP-2.)*(2.*BD
1N+3.*DLN)+3.*DLN*ADN*BDN*DLN2-2.*DLN2*ADN*BDN*(3.)*(BUP*DLN+BDN*CU
2P)-4.*DLN)+BDN2*(9.*ADN*BUP-8.*ADN-2.*DLN)+BDN*BDN2*(3.*CDT-2.))+4
3.*TSIG*BDN*BDN2*(3.*CUP-2.)+2.*DLN2*(3.*CUP-1.)*CPM1
E=3.*ADN*(BDN2+DLN2)-BDN*TAUT+3.*TSIG*BDN2*BDN2+DLN2*DLN*(3.*CUP
1-2.)
F=3./5.*DLN2*DLN2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C      4/4 SYSTEM - COMPLETELY RANDOM TESTING
C
260 CONTINUE
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C      4/4 SYSTEM - COMPLETELY STAGGERED TESTING
C
270 CONTINUE
A=.0*(THETA-CPM1+CPM2*(SUP-THETA))
B=1.0-CPM2*CPM2-4.*CDN2*(CPM1*SDN+1.5*DLN*(SUP-THETA))
C=-2.*CPM1*DLN*(CPM1+3.*CPM1*SDN+11./8.*DLN*(SUP-THETA))
D=-1./8.*DLN2*(11.*CPM2+22.*CPM1*SDN+3.*DLN*(SUP-THETA))
E=-3./8.*DLN2*DLN*(11.*CPM1)
F=-251./7680.*DLN2*DLN2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C      4/4 SYSTEM - SIMULTANEOUS TESTING
C
280 CONTINUE
A=7.*TAUT-TAUT*(APM1+CPM1*CPM2+BPM1*(APM1*CPM2+(CDT-1.))*3)+BPM2*(
1APM1+CPM1*(CDT-1.))*2)+BPM1*CPM2*(AUP-2.+CDT))+TSIG*BPM2*BPM2*TSIG
B=1.-TAUT*(CPM2*(APM1+(BDN+3.*DLN)+ADN*(CB-2.))+APM1+CPM1*(BDN*CPM
11+DLN*(CUP+1.))+BPM1*(ADN*BPM1+APM1*BDN))+CB-2.)*BDN*BPM2*(2.*APM1
2+3.)*(CDT-1.))+BDN*(CDT-1.))*2*(2.*CUP+CDT-3.))-4.*BPM2*CPM1*TSIG*B
3DN-CPM2*CPM2
C=-1.*TAUT*(APM1*DLN+ADN*CPM1)*(3.*CPM1*DLN+BDN*BPM1)+(ADN*BPM1+B
1DN+APM1)*(CPM1*(BDN+2.*DLN)+BPM1*(3.*BDN*DLN))+APM1-CPM1*DLN2+ADN*
2BDN*CPM2*(CDT+1.))+CPM2*(3.*BUP+CDT-4.))-6.*BPM2*BDN2*TSIG-2.*CPM1*
3CPM2*DLN
D=-1.0*TAUT*(ADN*CPM1+BDN*APM1)*(BDN2+BDN*DLN+DLN2)+CPM1*ADN*(BDN
12+2.*BDN*DLN+3.*DLN2)+DLN*(ADN*BDN*CPM1+APM1*DLN2)+2.*ADN*BPM1*BDN
22+BDN2*BDN*(CDT-1.))-4.*BPM1*TSIG*BDN2*BDN-2.*CPM2*DLN2
E=-1.*ADN*(BDN2+DLN2)*BDN*TAUT-TSIG*BDN2*BDN2-CPM1*DLN2*DLN
F=-1.0/5.0*DLN2*DLN2
CALL CALC
IF(IFLAG.LT.3) GO TO 44
GO TO 110
C
C WRITE ERROR MESSAGE AND STOP IF INPUT CRITERIA NOT MET.

```

```

C
112 CONTINUE
  WRITE(IWRITE,1410)
  C/2/
110 CONTINUE
C
C CHECK FOR LAST SYSTEM AND CASE.
C
  IF(NNSYS.IE.NNSYSTH) GO TO 3
  IF(ICASE.EQ.NCASE) GO TO 300
  GO TO 1
300 CONTINUE
  STOP
1000 FORMAT(2I6)
1100 FORMAT(I12,50I2,5/40I2,5)
1200 FORMAT(1H1,130(1H*)//62X,NCASE,I3//25X,20A4//130(1H*)//)
1300 FORMAT(20A4)
1400 FORMAT(//130(1H*)//20X,70H***** INPUT ERROR ***** CHECK TO SEE
  THAT THE VALUES OF TAUT, TAUR, //20X,34HAND QZERO MEET THE INPUT C
  RITERIA.//130(1H*))
  END
  BLOCK DATA
  COMMON/INTVAR/N,INRK,INRK1,ITASK,IWRITE,NN(28),IFLAG,ISIGN,NNSYS
  1,ITT
  DATA NN/110,121,122,123,221,222,223,131,132,133,231,232,233,331,
  1332,333,141,142,143,241,242,243,341,342,343,441,442,443/
  DATA IWRITE/0/
  END
  SUBROUTINE CALC
C
C THIS SUBROUTINE PERFORMS CALCULATIONS AND WRITES THE RESULTS.
C
  IMPLICIT REAL*8(A-H,O-Z)
  REAL*8 LAMBDA
  COMMON/INTVAR/N,INRK,INRK1,ITASK,IWRITE,NN(28),IFLAG,ISIGN,NNSYS
  1,ITT
  COMMON/ELTV/2/GEN ME,CM HAD,LAMBDA,QZERO,RHOF,RHOU,TAUR,TAUT,TUP,
  1EFR,A,B,C,D,E,F,TCHT,AP,BP,CP,UBAR1,CEOPT1,TOPT1,UBP,UBT,UBT1,UBT2
  2,UBT3,UBT12,UBT22,UBT32,THETA
C
C   UBP IS TOTAL SYSTEM UNAVAILABILITY.
C
C
C   UBT IS THE UNAVAILABILITY CALCULATED THIS STEP (DEFINED BY IFLAG).
C
C
C   UBT1 IS THE FRACTION OF UNAVAILABILITY DUE TO TESTING.
C
C
C   UBT12 IS THE UNAVAILABILITY DUE TO TESTING.
C
C
C   UBT2 IS THE FRACTION OF UNAVAILABILITY DUE TO REPAIR.
C
C
C   UBT22 IS THE UNAVAILABILITY DUE TO REPAIR.
C
C
C   UBT3 IS THE FRACTION OF UNAVAILABILITY DUE TO RANDOM FAILURES.
C

```



```

C
C   UBT32 IS THE UNAVAILABILITY DUE TO RANDOM FAILURE.
C
C
C   INRK DEFINES M OF M/N SYSTEM.
C
C   INRK=NN(N)/100
C   INRK1=(NN(N)-100*INRK)/10
C   GO TO (20,20,30,40),ISIGN
C
C CALCULATIONS FOR M/N SYSTEM, RANDOM TESTING.
C
C 20 CONTINUE
C   UBARR=0.0
C   UBOPTR=0.0
C   KP=INRK1-INRK+1
C   DO 1 KK=KP,INRK1
C
C CALL COMB TO CALCULATE BINOMIAL COEFFICIENT
C
C   CALL COMB(COMB1,KK,INRK1)
C   UBARR=UBARR+COMB1-UBARR**KK*(1.0-UBARR)**(INRK1-KK)
C   UBOPTR=UBOPTR+COMB1*UBOPT1**KK*(1.0-UBOPT1)**(INRK1-KK)
C 1 CONTINUE
C   IF(MOD(ITASK,2).EQ.0.AND.IFLAG.NE.1) GO TO 22
C   IF(INNSYS.NE.1) WRITE(INRITE,1249)
C   IF(INRK1.EQ.1) GO TO 2
C   WRITE(INRITE,2000) INRK,INRK1
C   GO TO 3
C 2 CONTINUE
C   WRITE(INRITE,2500) INRK,INRK1
C 3 CONTINUE
C
C WRITE INPUT AND RESULTS.
C
C   WRITE(INRITE,2600) GAMMAE,GAMMAR,LAMBDA,QZERO,PHOF,RHO,TAUR,TAUT,
C 1TUP
C   WRITE(INRITE,2300) UBARR,TOPT1,UBOPTR
C   IF(IFLAG.EQ.1) GO TO 21
C   RETURN
C 21 CONTINUE
C   IF(DABS(TOPT-THETA).LE.1.0D-05) GO TO 6
C   WRITE(INRITE,1250)
C   GO TO 7
C 6 CONTINUE
C   WRITE(INRITE,1251)
C   TOPT=TUP
C 7 CONTINUE
C
C CALCULATE AND WRITE UBAP VALUES FOR INTERVAL FROM .2 TO 1.8*TOPT.
C
C   DO 5 J=2,18,2
C   TJ=J
C   TJ=.1*TJ*TOPT1
C   UB1=AP*TJ+BP+CP*TJ
C   UB=0.0
C   KP=INRK1-INRK+1
C   DO 4 KK=KP,INRK1
C   CALL COMB(COMB1,KK,INRK1)

```

```

      UD=UB+COMBI*UB1**KK*(1.0-UB1)**(IMRK1-KK)
4  CONTINUE
      WRITE(IWRITE,1300) TJ,UB
5  CONTINUE
      USP=UBAPR
      RETURN
22 CONTINUE
      CALL FRACUN(IFLAG,UBARR)
      RETURN
C
C CALCULATIONS FOR M/N SYSTEM, STAGGERED TESTING.
C
      30 CONTINUE
      UBART=A/TUP+B*C*TUP+D*TUP**2+E*TUP**3+F*TUP**4
      IF(MOD(ITASK,2).EQ.0.AND.IFLAG.NE.1) GO TO 33
C
C CALL ITERAT TO CALCULATE OPTIMUM TEST INTERVAL.
C
      CALL ITERAT
      TOPTI=TOPT
      UOPTI=A/TOPTI+B*C*TOPTI+D*TOPTI**2+E*TOPTI**3+F*TOPTI**4
      IF(MNSYS.NE.1) WRITE(IWRITE,1249)
      WRITE(IWRITE,2100) IMRK,IMFK1
      WRITE(IWRITE,2600) GAMMAE,GAMMAR,LAMBDA,QZERO,RHOF,RHOU,TAUR,TAUT,
      1TUP
      WRITE(IWRITE,2300) UBART,TOPTI,UOPTI
      USP=UBART
      IF(IFLAG.EQ.1) GO TO 31
      RETURN
C
C CALCULATIONS FOR M/N SYSTEM, SIMULTANEOUS TESTING.
C
      40 CONTINUE
      UBARI=A/TUP+B*C*TUP+D*TUP**2+E*TUP**3+F*TUP**4
      IF(MOD(ITASK,2).EQ.0.AND.IFLAG.NE.1) GO TO 44
C
C CALL ITERAT TO CALCULATE OPTIMUM TEST INTERVAL.
C
      CALL ITERAT
      TOPTI=TOPT
      UOPTI=A/TOPTI+B*C*TOPTI+D*TOPTI**2+E*TOPTI**3+F*TOPTI**4
      IF(MNSYS.NE.1) WRITE(IWRITE,1249)
      WRITE(IWRITE,2200) IMRK,IMFK1
      WRITE(IWRITE,2600) GAMMAE,GAMMAR,LAMBDA,QZERO,RHOF,RHOU,TAUR,TAUT,
      1TUP
C
C INFORM USER OF INPUT VALUE ADJUSTMENT IF APPLICABLE.
C
      IF(ITT.EQ.1) WRITE(IWRITE,2700)
      IF(ITT.EQ.2) WRITE(IWRITE,2800)
      IF(ITT.EQ.3) WRITE(IWRITE,2900)
      WRITE(IWRITE,2300) UBARI,TOPTI,UOPTI
      USP=UBARI
      IF(IFLAG.EQ.1) GO TO 31
      RETURN
31 CONTINUE
      IF(DABS(TOPT-THETA).LE.1.0D-05) GO TO 8
      WRITE(IWRITE,1250)
      GO TO 9
8 CONTINUE

```

```

      WRITE(IWRITE,1251)
      TOPT=TUP
      9 CONTINUE
C
C CALCULATE AND WRITE UBAR VALUES FOR INTERVAL FROM .2 TO 1.8*TOPT.
C
      DO 42 J=2,18,2
      TJ=J
      TJ=.1*TJ*TOPT
      UB=A/TJ+B+C*TJ+D*TJ**2+E*TJ**3+F*TJ**4
      WRITE(IWRITE,1300) TJ,UB
      42 CONTINUE
      RETURN
      33 CONTINUE
      CALL FRACUN(IFLAG,UBAR)
      RETURN
      44 CONTINUE
      CALL FRACUN(IFLAG,UBAR)
      RETURN
1249 FORMAT(1H1)
1250 FORMAT(61//),25X,80HAVERAGE UNAVAILABILITIES FROM TIMES .2*TOPT TO
      11.8*TOPT AT INTERVALS OF .2*TOPT://49X,4H T ,29X,4HUBAR/)
1251 FORMAT(61//),25X,80HAVERAGE UNAVAILABILITIES FROM TIMES .20*T TO
      1 1.8*T AT INTERVALS OF .20*T ://49X,4H T ,29X,4HUBAR/)
1300 FORMAT(45X,1PD12.5,25X,1PD12.5)
2000 FORMAT(28X,10(1H*),12,7H OUT OF,12,43H SYSTEM - COMPLETELY RANDOM
      1TEST INTERVALS ,10(1H*)/)
2100 FORMAT(27X,10(1H*),12,7H OUT OF,12,45H SYSTEM - UNIFORMLY STAGGERE
      1D TEST INTERVALS ,10(1H*)/)
2200 FORMAT(27X,10(1H*),12,7H OUT OF,12,45H SYSTEM - NEARLY SIMULTANEOU
      1S TEST INTERVALS ,10(1H*)/)
2300 FORMAT(//25X,22HAVERAGE UNAVAILABILITY,5X,1PD12.5//25X,21HOPTIMUM T
      1TEST INTERVAL,6X,1PD12.5//25X,47HAVERAGE UNAVAILABILITY AT OPTIMUM
      2 TEST INTERVAL,5X,1PD12.5)
2500 FORMAT(46X,10(1H*),12,7H OUT OF,12,8H SYSTEM ,10(1H*)/)
2600 FORMAT(//25X,6HGAUSSIAN,2X,1PD12.5,10X,6HGMNAR,2X,1PD12.5,10X,6HLM
      1EDA,2X,1PD12.5/25X,6HQUZERO ,2X,1PD12.5,10X,4HRTIOF,4X,1PD12.5,10X,6
      2HRTIOU ,2X,1PD12.5/25X,6HTAUR ,2X,1PD12.5,10X,6HTAUT ,2X,1PD12.5
      3,10X,6HT ,2X,1PD12.5)
2700 FORMAT(//25X,80(1H*)/25X,8(1H*),4X,54HTHE TAUR.GT.TAUT CRITERION W
      1AS NOT MET. THE VALUES OF ,6X,8(1H*)/25X,8(1H*),4X,58HQZERO AND TA
      2UT HAVE BEEN CHANGED TO SATISFY THE CONDITION.,2X,8(1H*)/25X,80(1H
      3*)/)
2300 FORMAT(//25X,80(1H*)/25X,8(1H*),4X,56HTHE TAUR.GT.2*TAUT CRITERION
      1 WAS NOT MET. THE VALUES OF ,4X,8(1H*)/25X,8(1H*),4X,58HQZERO AND
      2TAUT HAVE BEEN CHANGED TO SATISFY THE CONDITION.,2X,8(1H*)/25X,80(
      31H*)/)
2900 FORMAT(//25X,80(1H*)/25X,8(1H*),4X,56HTHE TAUR.GT.3*TAUT CRITERION
      1 WAS NOT MET. THE VALUES OF ,4X,8(1H*)/25X,8(1H*),4X,58HQZERO AND
      2TAUT HAVE BEEN CHANGED TO SATISFY THE CONDITION.,2X,8(1H*)/25X,80(
      31H*)/)
      END
      SUBROUTINE COMB(COMB1,IK,IIMRK1)
C
C THIS SUBROUTINE CALCULATES THE BINOMIAL COEFFICIENT.
C
      IP=1
      DO 1 IJ=1,IIMRK1
      IP=IP*IJ
      1 CONTINUE

```

```

      UD=IP
      ID=1
      DO 2 IJ=1,IK
      ID=ID+IJ
2     CONTINUE
      UD=ID
      ID2=1
      UD2=1.0
      IIF=IIMRK1-IFK
      IF(IIF.EQ.0) GO TO 4
      DO 3 IJ=1,IIF
      ID2=ID2+IJ
3     CONTINUE
      UD2=ID2
4     CONTINUE
      CCDD1=UP/(UD*UD2)
      RETURN
      END
      SUBROUTINE FRACUN(IF,U)
C
C THIS SUBROUTINE CALCULATES THE FRACTIONAL UNAVAILABILITIES.
C
      IMPLICIT REAL*8(A-H,O-Z)
      REAL*8 LAMBDA
      COMMON/INTVAR/N,INRK,INRK1,ITASK,IWRITE,NN(28),IFLAG,ISIGN,NNSYS
      1,ITT
      COMMON/FLTVAR/GAMMAE,GAMMAR,LAMBDA,QZERO,RHOF,RHOU,TAUR,TAUT,TUP,
      1ERR,A,B,C,D,E,F,TCPT,AP,BP,CP,USAR1,UDOPT1,TCPT1,UBP,UST,UBT1,UST2
      2,UBT3,UBT12,UBT22,UBT32,THETA
      UBT=U/USP
      GO TO (4,2,3,4),IF
2     CONTINUE
      UBT1=UBT
      RETURN
3     CONTINUE
      UBT2=UBT1-UBT
      UBT1=1.000-UBT1
      UBT12=USP*UBT1
      UBT22=USP*UBT2
      UBT3=1.000-UBT1-UBT2
      UBT32=USP*UBT3
      WRITE(IWRITE,2400) UBT12,UBT1,UBT22,UBT2,UBT32,UBT3
      RETURN
4     CONTINUE
      RETURN
2400 FORMAT(6(/),25X,29HUNAVAILABILITY DUE TO TESTING,13X,1PD12.5,5X,2P
      1F6.2,2X,8HPER CENT//25X,28HUNAVAILABILITY DUE TO REPAIR,14X,1PD12.
      25,5X,2PF6.2,2X,8HPER CENT//25X,37HUNAVAILABILITY DUE TO RANDOM FAI
      3LURES,5X,1PD12.5,5X,2PF6.2,2X,8HPER CENT//)
      END
      SUBROUTINE ITERAT
      IMPLICIT REAL*8(A-H,O-Z)
C
C THIS SUBROUTINE USES THE NEWTON-RAPHSON METHOD TO FIND THE OPTIMUM
C TEST INTERVAL FOR THE SYSTEM.
C
      REAL*8 LAMBDA
      COMMON/INTVAR/N,INRK,INRK1,ITASK,IWRITE,NN(28),IFLAG,ISIGN,NNSYS
      1,ITT
      COMMON/FLTVAR/GAMMAE,GAMMAR,LAMBDA,QZERO,RHOF,RHOU,TAUR,TAUT,TUP,

```

```

1ERR,A,B,C,D,E,F,TOPT,AP,BP,CP,UBAR1,USOPT1,TOPT1,USP,UBT,UBT1,UBT2
2,UST3,UBT12,UBT22,UBT32,THETA
TOLD=TOPT1
1 CONTINUE
FX=4.0 *F*TOLD**5+3.0*C*TOLD**4+2.0*D*TOLD**3+C*TOLD**2-A
FXP=20.0 *F*TOLD**4+12.0 *C*TOLD**3+6.0*D*TOLD**2+2.0*C*TOLD
TT=TOLD-FX/FXP
IF(TT.LE.THETA) GO TO 3
IF(ABS(TT-TOLD).LE.(ERR-THETA)) GO TO 2
TOLD=TT
GO TO 1
2 CONTINUE
TOPT=TT
GO TO 4
3 CONTINUE
TOPT=THETA
4 CONTINUE
RETURN
END

```

APPENDIX E

ICARUS Input and Output

Presented is a sample computer run of ICARUS for two systems: a 1/3 system tested using the uniformly staggered testing scheme and a 2/4 system using the uniformly staggered testing scheme. The task flag is set to calculate the average unavailability as a function of test interval and also to calculate the fractions of the average unavailability due to testing, repair, and random failures.

There were eight input cards, and they appeared in the following order:

Card 1, NCASE = 1, column 6

Card 2, ITASK = 2, column 6

Card 3, ITITLE = ICARUS Documentation Run, columns 29-52

Card 4, NSYSTEM = 2, column 6

Card 5, IMARK = 132, columns 10-12

GAMMAE = 1.0D-03, columns 18-24

GAMMAR = 1.0D-03, columns 30-36

LAMBDA = 3.0D-07, columns 42-48

QZERO = 1.0D-01, columns 54-60

RHOE = 1.0D-03, columns 66-72

Card 6, RHOU = 1.0D-03, columns 6-12

TAUR = 7.0, columns 22-24

TAUT = 3.0, columns 34-36

TUP = 720.0, columns 44-48

Card 7, IMARK = 242, columns 10-12

Rest of Card 7 is the same as Card 5.

Card 8 is the same as Card 6.

The output is arranged in the following manner. The case title is printed first with each of the systems to be studied following. The system title is printed, as are the values that ICARUS uses to do the calculations. (These may be different from the input if ICARUS makes internal modifications to the input.) Next, ICARUS prints the average unavailability, the optimum test interval, and the average unavailability at the optimum test interval.

If the task flag is set, the code will print the average unavailability for values of the test interval that range from 0.2 to 1.8 times the optimum. The same flag will calculate and print the fractional unavailabilities.

CASE 1

ICARUS DOCUMENTATION RUN

***** 1 OUT OF 3 SYSTEM - UNIFOMMLY STAGGERED TEST INTERVALS *****

GAMMAE	1.000000-03	GAMMAR	1.000000-03	LAMBDA	3.000000-07
WZERO	1.000000-01	RHOF	1.000000-03	RHOU	1.000000-03
TAUR	7.000000 00	TAUT	3.000000 00	T	7.200000 02

AVERAGE UNAVAILABILITY	1.529800-08
OPTIMUM TEST INTERVAL	1.331920 03
AVERAGE UNAVAILABILITY AT OPTIMUM TEST INTERVAL	1.412940-08

AVERAGE UNAVAILABILITIES FROM TIMES .2*TAUT TO 1.5*TAUT AT INTERVALS OF .2*TAUT:

T	UBAR
2.663840 02	2.346450-08
5.327680 02	1.679580-08
7.991520 02	1.493170-08
1.065540 03	1.428220-08
1.331920 03	1.412940-08
1.598300 03	1.423440-08
1.864690 03	1.449470-08
2.131070 03	1.485930-08
2.397460 03	1.530000-08

UNAVAILABILITY DUE TO TESTING	5.529550-09	36.14	PER CENT
UNAVAILABILITY DUE TO REPAIR	2.871250-10	1.98	PER CENT
UNAVAILABILITY DUE TO RANDOM FAILURES	9.482100-09	61.98	PER CENT

***** 2 OUT OF 4 SYSTEM - UNIFORMLY STAGGERED TEST INTERVALS *****

GAMMAE	1.000000-03	GAMMAK	1.000000-03	LAMBDA	3.000000-07
QZERO	1.000000-01	RHOF	1.000000-03	RHOU	1.000000-03
TAUP	7.000000 00	TAUT	3.000000 00	T	7.200000 02

AVERAGE UNAVAILABILITY 6.161590-08

OPTIMUM TEST INTERVAL 1.311030 03

AVERAGE UNAVAILABILITY AT OPTIMUM TEST INTERVAL 5.676780-08

AVERAGE UNAVAILABILITIES FROM TIMES .2*TOPT TO 1.8*TOPT AT INTERVALS OF .2*TOPT:

T	UBAR
2.682000 02	9.457640-08
5.364130 02	6.757280-08
8.046190 02	6.002060-08
1.072830 03	5.736740-08
1.341630 03	5.676780-08
1.609240 03	5.719400-08
1.877450 03	5.825200-08
2.145650 03	5.973530-08
2.413860 03	6.152970-08

UNAVAILABILITY DUE TO TESTING 2.207320-08 35.82 PER CENT

UNAVAILABILITY DUE TO REPAIR 1.146160-09 1.86 PER CENT

UNAVAILABILITY DUE TO RANDOM FAILURES 3.839650-08 62.32 PER CENT

APPENDIX F

Data Base for ρ_u , ρ_f , γ_e , and γ_r Type Failures

The following reported occurrences were used as the bases for the values of the parameters ρ_u , ρ_f , γ_e , and γ_r in the auxiliary-feed-water-system analysis of Chapter V.

Failure Type: ρ_u

Plant: Zion Unit 2 Docket No.: 50-304-183

Event: Three Related Abnormal Occurrences with Diesel Generation

Date: February 17, 1974

Cause: The unit was operating at 25% power with two auxiliary feed-water pumps inoperable. During the daily testing of the third pump, the standby ac power-supply Diesel generator started, but tripped out on over-speed. Due to an operator error, the synchro-speed setter had been set on 13.5 instead of 12. After it was reset, the Diesel operated properly. Then the output breaker would not close on the bus so that the D/G control panel was latched closed. A loose screw was lodged in the pivot. The screw was removed. The lapsed time to correct these defects exceeded the 4-h limit of operating without an AFWS pump by 2.7 h.

Failure Type: ρ_f

Plant: Turkey Point Unit No. 3 Docket No.: 50-250-230

Event: Malfunction of Auxiliary Feedwater Pumps

Date: May 8, 1974

Cause: All three auxiliary feedwater pumps had been tested satisfactorily on May 7, 1974, according to the operation procedure OP7304.1, which is the monthly test. After the test, the pump packing was adjusted on the A and B pumps. Apparently, the packing was tightened with the pumps secured, and the packing was tight enough to prevent the pumps from starting. The pumps were not tested for operability after the packing was tightened.

Failure Type: ρ_u

Plant: Prairie Island
Nuclear Generating Plant I Docket No.: 50-282-274

Event: Failure of No. 12 Auxiliary Feedwater Pump to Start

Date: August 13, 1974

Cause: During testing with the reactor at 100% power, an electric auxiliary-feedwater-system pump failed to start. During maintenance

on August 6, 1974, someone inadvertently opened the breaker for the auxiliary lube oil pump. This action prevented the No. 12 auxiliary feedwater pump from starting due to the lube-oil pressure interlock.

Failure Type: β_u

Plant: H. B. Robinson Unit No. 2 Docket No.: 50-261-454

Event: Overspeed Trip of Steam-driven Auxiliary Feedwater Pump

Date: November 19, 1974

Cause: Investigation revealed the woodward governor manual setting was out of adjustment. It could not be determined if the setting was inadvertently moved after a previous test or changed by noncognizant personnel working in the area.

Failure Type: β_f

Plant: Oconee 3 Docket No.: 50-287-268

Event: Inoperable Emergency Feedwater Pump

Date: April 30, 1975

Cause: Maintenance was performed on the emergency feedwater pump to repair a leaking packing gland on April 19, 1975. The packing was apparently set too tight, and the pump was returned to service without verifying operability as is required by procedure.

Failure Type: β_u

Plant: Trojan Nuclear Plant Docket No.: 50-344-249

Event: Diesel-driven Auxiliary-feedwater-pump Failure to Start

Date: January 9, 1976

Cause: This occurrence was caused by a change in engine conditions (oil and water temperatures, etc.) from those under which the governor had last been aligned.

Failure Type: β_u

Plant: Trojan Nuclear Plant Docket No.: 50-344-387

Event: The Turbine-driven Auxiliary Feedwater Pump Failed to Automatic Start

Date: October 19, 1976

Cause: The trip throttle valve (MO 3071) was not properly reset by an auxiliary operator for an automatic start.

Failure Type: $\rho_u, \gamma_e, \gamma_r$

Plant: Millstone Unit 2 Docket No.: 50-336-539

Event: Pump Inlet Steam Valve Fails to Open

Date: July 24, 1976

Cause: The cause of the valve-shaft shearing prohibiting the valve from opening was discovered to be improper torque switch setting (reported October 22, 1976).

Failure Type: γ_e, γ_r

Plant: Zion Unit 1 Docket No.: 50-295-324

Event: An Auxiliary Feedwater Pump Found Inoperable

Date: June 6, 1974

Cause: On June 6, 1974, at 2115 h with the unit 1 reactor operating at 75% power level and the steam-generator load at 750 MW, the shift supervisor, during a tour of the plant, found the overspeed trip valve on the 1A steam-turbine-driven auxiliary feedwater pump in the tripped position. The trip valve was reset, and an attempt was made to run the pump. The pump started normally, but water accumulation in the turbine exhaust pipe caused an excessive water hammer that broke one of the exhaust pipe hangers. Because of this, the 1A auxiliary feedwater pump was shut down and declared inoperable pending repairs.

Failure Type: γ_e, γ_r

Plant: Zion Unit 1 Docket No.: 50-295-606

Event: Auxiliary Feedwater Pump Fails to Start

Date: March 5, 1976

Cause: The pump had been started and stopped several times to maintain steam-generator pressure. Because of this, moisture accumulation was higher than normal in the turbine and moisture could not drain off properly. The pump thus became waterbound and failed to start.

ACKNOWLEDGMENTS

This report summarizes results obtained under a contract between Argonne National Laboratory and the University of Lowell. We would like to thank Dr. Gilbert J. Brown as well as all the other members of the Department of Nuclear Engineering, University of Lowell, for helpful comments and discussion during the work. We also thank all our friends at Argonne National Laboratory, especially Jim Cahalan and the rest of the members of the Reactor Analysis and Safety Division, who were always ready to provide help and encouragement.

REFERENCES

1. A. E. Greene and A. J. Bourne, *Reliability Technology*, Wiley-Interscience, London, p. 272 (1972).
2. E. Dressler and H. Spindler, *The Unavailability of Standby Systems as a Function of Test Strategy and Repair Time* (in German), MRR 144, Technical University at Munich (1975).
3. J. P. Signoret, *Availability of a Periodically Tested Standby System*, NUREG/TR-0027 (1976).
4. G. E. Apostolakis and P. P. Bansal, *Effect of Human Error on the Availability of Periodically Inspected Redundant Systems*, IEEE Trans. Reliab. R-26(3), 220 (1977).
5. W. E. Vesely and F. F. Goldberg, *Time Dependent Unavailability Analysis of Nuclear Safety Systems*, IEEE Trans. Reliab. R-26(4), 257 (1977).
6. W. E. Vesely and F. F. Goldberg, *FRANTIC--A Computer Code for Time Dependent Unavailability Analysis*, NUREG-0193 (1977).
7. J. K. Vaurio, *Unavailability of Components with Inspection and Repair*, Nucl. Eng. Des. (in press).
8. J. K. Vaurio, "Response Surface Techniques Developed for Probabilistic Analysis of Accident Consequences," *Proc. ANS Topical Meeting*, Los Angeles, p. II.2 (May 1978).
9. M. R. Rosenthal, *Numerical Methods in Computer Programming*, Richard D. Irwin, Inc., Homewood, Ill., pp. 236-237 (1966).
10. *Reactor Safety Study: An Assessment of Accident Risks in U. S. Commercial Nuclear Power Plants*, WASH-1400, USNRC (Oct 1975).
11. J. D. Millan and G. E. Edison, *Common Cause Failure Experience in PWR Auxiliary Feedwater Systems for Large Breeder Reliability Analysis*, WARD-SR-3045-5 (Aug 1978).
12. V. Joksimovic et al., "HTGR Risk Assessment Study," *Proc. Int. Conf. Nuclear System Reliability Engineering and Risk Assessment*, Gatlinburg, Tenn. p. 180 (1977).