RECEIVED

JUL 01 1996

OSTI

**HFC SUPERMARKET
REFRIGERATION DEMONSTRATION**

Phases I and II

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

D/E

The New York State Energy Research and Development Authority (NYSERDA) is a public benefit corporation created in 1975 by the New York State Legislature. F. William Valentino is President and Chief Operating Officer.

NYSERDA's primary mission is to carry out a broad program of energy research, development and demonstration projects designed to develop and apply efficient technologies to help ensure that New York has secure and economical future supplies of energy, while protecting environmental values and promoting economic growth.

NYSERDA derives its basic research revenues from an assessment levied on the intrastate sales of New York State's investor-owned electric and gas utilities. Additional research dollars come from limited corporate funds and a voluntary annual contribution by the New York Power Authority.

In its research program, NYSERDA stresses consultation and collaboration with other organizations, including utilities, universities, industries, private engineering and scientific research firms, local governments, and State and federal agencies. These efforts stretch NYSERDA's limited research funds and ensure the involvement of those who can use the results of the research.

In its federally funded Energy Services program, NYSERDA provides technical assistance to improve the energy and environmental performance of businesses and institutions, helps secure energy-project funding from private and public sources, and converts fleet vehicles to alternative fuels. The Energy Analysis program focuses on using energy, regulatory, and environmental policies to help New York State businesses grow and to meet the needs of New York State's energy consumers.

NYSERDA also has responsibility for:

- Managing the 3,300-acre Western New York Nuclear Service Center at West Valley 35 miles south of Buffalo, the site of a former commercial nuclear fuel reprocessing plant and a low-level radioactive waste disposal area. These responsibilities include:
 - Participating in the West Valley Demonstration Project, a joint federal/State effort to solidify the high-level radioactive wastes left over from the reprocessing operation and to clean up the facilities used.
 - Maintaining the portion of the site not being used in the Demonstration Project, including the shut-down low-level radioactive waste disposal area.
- Issuing tax-exempt bonds to finance facilities for electric and gas utilities and energy projects for private companies.
- Constructing and operating facilities for disposal of low-level radioactive wastes produced in New York State, once the State makes disposal method and site decisions and approvals have been issued by State regulatory agencies.
- Managing a 365-acre portion of a Superfund clean-up site in Malta, 20 miles north of Albany. Part of the site was once owned by the federal government. Portions of it have been used by the federal government and its contractors since the 1940s for activities that have included rocket engine and fuel testing, weapons testing, and space research.

For more information, contact the Technical Communications unit, NYSERDA, 2 Empire State Plaza, Suite 1901, Albany, New York 12223-1253, (518) 465-6251, ext. 250.

State of New York
George E. Pataki,
Governor

Energy Research and Development Authority
F. William Valentino,
President

NYSERDA--96-6

**HFC-134A AND HCFC-22 SUPERMARKET REFRIGERATION
DEMONSTRATION AND LABORATORY TESTING**

Phase I — Final Report

Prepared for

**THE NEW YORK STATE
ENERGY RESEARCH AND DEVELOPMENT AUTHORITY**

Raymond J. Albrecht, P.E.
Senior Project Manager

EMPIRE STATE ELECTRIC ENERGY RESEARCH CORPORATION

1515 Broadway
New York, New York 10036

Frank Porretto
Program Manager

and

ELECTRIC POWER RESEARCH INSTITUTE

3412 Hillview Avenue
P.O. Box 10412
Palo Alto, California 94303

Mukesh Khattar
Project Manager

Prepared by

ASPEN SYSTEMS, INC.

184 Cedar Hill Street
Marlborough, MA 01752

Hamed Borhanian, Project Manager
Lenley Rafuse, Project Engineer

1586-EEED-BES-91

NYSERDA
Report 96-6

April 1996

NOTICE

This report was prepared by Aspen Systems, Inc., in the course of performing work contracted for and sponsored by the New York State Energy Research and Development Authority, Empire State Electric Energy Research Corporation, and Electric Power Research Institute (hereafter the "Sponsors"). The opinions expressed in this report do not necessarily reflect those of the Sponsors or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it. Further, the Sponsors, the State of New York, and the contractor make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, or other information contained, described, disclosed, or referred to in this report. The Sponsors, the State of New York, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately owned rights and will assume no liability for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

ABSTRACT

Aspen Systems and a team of nineteen agencies and industry participants conducted a series of tests to determine the performance of HFC-134a, HCFC-22, and CFC-502 for supermarket application. This effort constitutes the first phase of a larger project aimed at carrying out both laboratory and demonstration tests of the most viable HFC refrigerants and the refrigerants they replace. The results of the Phase I effort are presented in the present report. The second phase of the project has also been completed. It centered on testing all viable HFC replacement refrigerants for CFC-502. These were HFC-507, HFC-404A, and HFC-407A. The latter results are published in the Phase II report for this project.

As part of Phase I, a refrigeration rack utilizing a horizontal open drive screw compressor was constructed in our laboratory. This refrigeration rack is a duplicate of one we have installed in a supermarket in Clifton Park, NY. During Phase I, we obtained comparative data for HFC-134a, HCFC-22, CFC-12, and CFC-502. Test results have shown similar efficiencies for HFC-134a, HCFC-22, and CFC-502 at low evaporator temperatures. At medium temperatures, HFC-134a exhibited the best performance followed by CFC-12, HCFC-22, and CFC-502.

A second component of Phase I was the demonstration of a CFC-502 to HCFC-22 retrofit in a supermarket. The low-temperature rack in the Clifton Park supermarket was used to conduct this test. The test portion of the rack was composed of a screw compressor and two semi-hermetic reciprocating compressors. We collected data from this test starting in July 1991. The retrofit was accomplished successfully by simply adding suction line desuperheaters to the reciprocating compressor system. The results for the screw compressor confirmed our laboratory findings. The screw performed less efficiently with HCFC-22 (compared to CFC-502) due to the low viscosity of the oil. Compared to the screw, the performance of the reciprocating compressors varied depending on the control system used.

The third aspect of Phase I was a field test HFC-134a in a supermarket's medium-temperature and air-conditioning refrigeration racks. A new supermarket in Glens Falls, NY, was equipped with state-of-the-art refrigeration systems based on

three different compressor technologies. All three refrigeration racks in the store were instrumented. The medium and A/C racks were charged with HFC-134a, and the low-temperature rack was charged with HCFC-22. We collected performance data from this store starting in May 1992. The preliminary data from these tests are presented in this report. The overall conclusion is that HFC-134a is a viable, energy-efficient long-term replacement refrigerant for medium-temperature refrigeration

ACKNOWLEDGMENTS

The successful continuation of this project would not have been possible without the invaluable assistance of the following individuals and organizations:

- New York State Energy Research and Development Authority:
 - Mr. Raymond Albrecht
 - Mr. Robert Callender
 - Ms. Joan Edwards
- Empire State Electric Energy Research Corporation:
 - Mr. Frank Porretto
- Niagara Mohawk Power Corporation:
 - Mr. Adam Hinge
 - Mr. Alex Hall
- Electric Power Research Institute:
 - Mr. Mukesh Khattar
- Hannaford Bros. Co.:
 - Mr. Tom Mathews
 - Mr. Steven Hitchcock
 - Mr. Jim Bokco
 - Mr. Winn Williams
 - Mr. Bion Pike
- Allied Signal:
 - Mr. Mark Spatz
 - Mr. Michael Hughes
 - Mr. Theodore Atwood
- Howden Compressors:
 - Mr. Charles Bizilj
 - Mr. Douglas Szandrocha
 - Mr. Lee Evans
 - Mr. David Johnson
- Bitzer Compressors:
 - Mr. Stephen Brown
 - Mr. Harry Brown
 - Mr. David Laird
- Carrier Corporation/Carlyle Compressors:
 - Mr. Paul Tollar
 - Mr. Rich D'Aversa
 - Mr. Peter Narreau
 - Mr. Anton Heinrichs
 - Mr. Charles Cove

- Phoenix Refrigeration Systems:

Mr. Mark Goldberg
Mr. John Kerr
Mr. Grant Brown
Mr. Carl Goldberg

- CPI Engineering:

Mr. Tom Rajewski
Mr. Glenn Short

- Castrol, Inc.:

Mr. Anthony Huffman

- EIL Instruments:

Mr. Dennis Rice
Mr. Robert Lewis

- Eastern Heating:

Mr. Fred Giardinelli
Mr. Bill Metz
Mr. Ray Vogel
Mr. Bob Kanser

- Hill Refrigeration:

Mr. John Vana
Mr. Tom Moffatt

- Spectronics Corp.:

Mr. John Duerr

- Sporlan Valve:

Mr. Leroy Manor
Mr. Andy Schoen

- Demand Defrost:

Ms. Jani Bryson

- ALCO Controls:

Mr. Patrick Varley

TABLE OF CONTENTS

SUMMARY	S - 1
Background	S - 1
Results - Laboratory Tests	S - 2
Summary of Results and Conclusions of the	
Laboratory Tests	S - 5
Results - Clifton Park CFC-502 To HCFC-22 Field Retrofit	S - 5
Summary of Results and Conclusions of the Clifton Park	
CFC-502 to HCFC-22 Conversion	S - 9
Results - Glens Falls HFC-134A And HCFC-22 Field Tests	S - 10
Low-Temp Rack Test Results	S - 12
Med-Temp Rack Test Results	S - 14
A/C Rack Test Results	S - 16
Summary of Results and Conclusions of the Glens Falls	
HFC-134A and HCFC-22 Field Tests	S - 17
 1. INTRODUCTION	 1 - 1
Description of the R&D Project	1 - 1
Phase I Scope of Work	1 - 3
 2. LABORATORY TESTING	 2 - 1
Description Of The Laboratory Test Setup	2 - 1
Description of the HFC-134a Rack	2 - 1
Instrumentation	2 - 8
Scope Of Work	2 - 8
Rack Modifications	2 - 10
Verification of Instrumentation	2 - 10
Compressor Optimization	2 - 11
System Optimization	2 - 12
Test Results	2 - 20
CFC-502 Performance	2 - 20
HCFC-22 Performance	2 - 20
HFC-134a Performance	2 - 29
CFC-12 Performance	2 - 29
Performance Comparison of the Refrigerants	2 - 31
Oil Management	2 - 35
Refrigerant Conversion Issues	2 - 39
Summary and Conclusions	2 - 41
 3. CLIFTON PARK CFC-502 TO HCFC-22 RETROFIT	 3 - 1
The Demonstration Site Supermarket	3 - 1
Supermarket's Refrigeration Schedule	3 - 2
Reciprocating Compressor Rack	3 - 2
Screw Compressor Rack	3 - 4
Layout of Major Components	3 - 6
Oil Management	3 - 6
Instrumentation	3 - 8

	CFC-502 to HCFC-22 Conversion	3 - 8
	Demonstration Testing Results	3 - 12
	Test History	3 - 12
	Test Procedure and Operating Conditions	3 - 13
	Data Reduction Procedure	3 - 13
	Performance Results	3 - 15
	Comparison of Refrigeration Systems	3 - 21
	Additional Testing	3 - 33
	New Screw Compressor Performance	3 - 33
	Liquid pump / Condenser Control	3 - 36
	Economizer Control	3 - 37
	Reliability History	3 - 37
	Summary and Conclusions	3 - 38
4.	GLENS FALLS HFC-134a AND HCFC-22 FIELD TESTING	4 - 1
	The Demonstration Site Supermarket	4 - 1
	Description of the Glens Falls Refrigeration Systems	4 - 2
	Low-Temp Rack	4 - 2
	Med-Temp Rack	4 - 6
	Med-Temp Rack (20°F system)	4 - 6
	Med-Temp Rack (15°F system)	4 - 9
	A/C Rack	4 - 10
	Oil Management	4 - 11
	Instrumentation	4 - 13
	Control and Data Acquisition Systems	4 - 13
	Demonstration Testing Procedure	4 - 14
	Test Procedure	4 - 14
	Data Reduction	4 - 15
	Low-Temp Demonstration Testing History And Results	4 - 16
	History Of The Low-Temp Rack	4 - 16
	Low-Temp Performance Results	4 - 17
	Med-Temp Demonstration Testing History And Results	4 - 25
	History Of The Med-Temp Rack	4 - 25
	Med-Temp Performance Results	4 - 26
	A/C Rack Demonstration Testing History And Results	4 - 34
	History Of The A/C Rack	4 - 34
	A/C rack Performance Results	4 - 36
	System Issues	4 - 39
	TD Control	4 - 39
	Liquid Pumps	4 - 42
	Variable Frequency Drives	4 - 42
	Oil Analysis	4 - 43
	Reliability	4 - 48
	Projected Annual Performance And Energy Costs	4 - 49
	Economic Analysis	4 - 50
	Summary and Conclusions	4 - 53
	Low-Temp	4 - 53
	Med-Temp	4 - 53
	Air Conditioning	4 - 54

5.	TECHNOLOGY TRANSFER	5 - 1
	Publicity	5 - 1
	Presentations	5 - 2
6.	REFERENCES	6 - 1
	APPENDIX A	A - 1
	APPENDIX B	B - 1

LIST OF FIGURES

FIGURE	PAGE
S - 1 Normalized Refrigeration Capacities for Different Refrigerants	S - 3
S - 2 Comparison of Refrigerant Performance at +20°F with 2.6-Vi Capacitor	S - 4
S - 3 Comparison of Refrigerant Performance at -20°F with the 3.6-Vi Compressor	S - 4
S - 4 History of the Weekly Refrigeration Load for the HCFC-22 Low-Temp Rack of the Clifton Park Store	S - 7
S - 5 Comparison of the HCFC-22 EER Performance for the Three Refrigeration	S - 7
S - 6 Comparison of the CFC-502 EER Performance for the Three Refrigeration	S - 8
S - 7 Arrangement of the Refrigeration Systems in the Glens Falls Test Store	S - 11
2 - 1 HFC-134a Laboratory Test Rack Piping and Instrumentation Diagram	2 - 2
2 - 2 Aspen Systems' HFC-134a Laboratory Test Rack	2 - 2
2 - 3 Aspen Systems' Refrigeration Facility Piping and Instrumentation Diagram	2 - 3
2 - 4 CFC-502 Refrigeration Capacities of the Three Howden Compressors Compared to Manufacturer Data	2 - 13
2 - 5 CFC-502 Refrigeration Efficiencies of the Last Two Howden Compressors Compared to Manufacturer Data	2 - 13
2 - 6 History of the CFC-502 Weekly Refrigeration Load for the Low-Temp Rack of the Clifton Park Store	2 - 14
2 - 7 Effect of Refrigeration Load and Compressor Speed on EER	2 - 16
2 - 8 Effect of Economizer Superheat on CFC-502 Performance	2 - 17
2 - 9 Effect of Economizer Superheat on HFC-134a Performance	2 - 18
2 - 10 CFC 502 Performance - Raw Data	2 - 21
2 - 11 CFC-502 Performance	2 - 21
2 - 12 Comparison of Laboratory and Field Results	2 - 22
2 - 13 CFC-502 Economizer Performance	2 - 22
2 - 14 Comparison of HCFC-22 and CFC-502 Performance with 68 cSt Mineral Oil	2 - 24
2 - 15 Comparison of Performance with 68 cSt Mineral Oil and 260 cSt POE OIL	2 - 27
2 - 16 Comparison of Performance with Full Oil Flow and Reduced Oil Flow	2 - 27
2 - 17 Economizer Performance at +20°F	2 - 28
2 - 18 Economizer Performance at -20°F	2 - 28
2 - 19 HFC-134a System Performance	2 - 30
2 - 20 HFC-134a Economizer Performance	2 - 30
2 - 21 CFC-12 System Performance	2 - 31
2 - 22 Normalized Refrigeration Capacities for Different Refrigerants	2 - 33
2 - 23 Comparison of Refrigerant Performance at +20°F with 2.6-Vi Compressor	2 - 33

FIGURE	PAGE
2 - 24 Comparison of Refrigerant Performance at +20°F with 3.6-Vi Compressor	2 - 34
2 - 25 Comparison of Refrigerant Performance at -20°F with the 3.6-Vi Compressor	2 - 35
2 - 26 Oil Carry-Over for CFC-12	2 - 39
2 - 27 Oil Carry-Over Summary	2 - 40
3 - 1 The Rack Housing All Six Compressors	3-3
3 - 2 The Two Carlyle Compressors Serving the -20°F Refrigeration Load	3-3
3 - 3 The EIL RC-1000 Controller, the Toshiba Inverter, and the Switch Gear for the Low-Temp Rack	3-5
3 - 4 The Clifton Park Screw Compressor Rack	3-5
3 - 5 The Clifton Park Low-Temp Screw Compressor Rack P&I Diagram	3-6
3 - 6 The Clifton Park Low-Temp Rack Oil Equalization Diagram	3-7
3 - 7 The Two Com-Trol Energy Management Systems	3-11
3 - 8 History of the Weekly Refrigeration Load for the HCFC-22 Low-Temp Rack of the Clifton Park Store	3-16
3-9a History of the Hourly Refrigeration Load, SDT, and Ambient Temperature for Recips on Inverter	3-17
3 - 9b History of the Hourly Power, EER, and SST for Recips on Inverter	3-17
3 - 10a History of the Hourly Refrigeration Load, SDT, and Ambient Temperature for Screw on Inverter	3-18
3 - 10b History of the Hourly Power, EER, and SST for Screw on Inverter	3-18
3 - 11a History of the Hourly Refrigeration Load, SDT, and Ambient Temperature for Recips on Unloaders	3-19
3 - 11b History of the Hourly Power, EER, and SST for Recips on Unloaders	3-19
3 - 12 History of the Hourly Refrigeration Load for Recips on Inverter (Non-Smoothed Data)	3-20
3 - 13 EER vs. SDT for Recips on Inverter (Smoothed Raw Data)	3-21
3 - 14 EER vs. SDT for Recips on Inverter (Fitting a Spline)	3-22
3 - 15 EER vs. SDT for Recips on Inverter (Spline Curve Fit)	3-22
3 - 16 Comparison of the HCFC-22 EER Performance for the Three Refrigeration Systems	3-23
3 - 17 Comparison of the CFC-502 EER Performance for the Three Refrigeration Systems	3-23
3 - 18 Comparison of CFC-502 and HCFC-22 EER Performance for Recips on Inverter	3-25
3 - 19 Comparison of CFC-502 and HCFC-22 EER Performance for Screw on Inverter	3-25
3 - 20 Comparison of CFC-502 and HCFC-22 EER Performance for Recips on Unloaders	3-26
3 - 21 Comparison of the HCFC-22 Power Consumption for the Three Refrigeration Systems	3-27
3 - 22 Comparison of the CFC-502 Power Consumption for the Three Refrigeration Systems	3-27
3 - 23 Comparison of the HCFC-22 Refrigeration Load for the Three Refrigeration Systems	3-28
3 - 24 Comparison of the CFC-502 Refrigeration Load for the Three Refrigeration Systems	3-28
3 - 25 Comparison of the HCFC-22 SST Data for the Three Refrigeration Systems	3-30

FIGURE	PAGE
3 - 26 Comparison of the CFC-502 SST Data for the Three Refrigeration Systems	3-31
3 - 27 Comparison of the HCFC-22 and CFC-502 SST Data for the SCR System	3-31
3 - 28 Comparison of MK4 and MK3 Screw Compressors EER Performance	3-34
3 - 29 MK4 Screw Compressor SST Data	3-35
3 - 30 Comparison of MK4 Screw Compressor and Recips on Inverter EER Performance	3-35
3 - 31 MK4 Screw Compressor and Recips on Inverter Power Comparison	3-36
3 - 32 Comparison of the MK4 Screw Compressor EER With and Without the Liquid Pump	3-37
3 - 33 Comparison of the MK4 Screw Compressor EER With and Without the Economizer	3-38
4 - 1 Arrangement of the Refrigeration Systems in the Glens Falls Test Store	4 - 3
4 - 2 The Open-Drive Screw Compressors in the Low-Temp Refrigeration System	4 - 4
4 - 3 The Carlyle Semihermetic Recip Compressors in the Low-Temp Refrigeration System	4 - 4
4 - 4 The Bitzer 6H2 Open-Drive Recip Compressors in the +20°F Refrigeration System	4 - 7
4 - 5 The Carlyle 06EM175 Semihermetic Recip Compressors in the +20°F Refrigeration System	4 - 7
4 - 6 The Howden 91-mm Screw Compressors in the +20°F Refrigeration System	4 - 8
4 - 7 The Carlyle 5H40 Open-Drive Recip Compressors in the +15°F Refrigeration System	4 - 9
4 - 8 The Bitzer Open-Drive Recip Compressors in the A/C System Compressors Arrangement and Oil Equalization	4 - 10
4 - 9 Diagram of the Glens Falls +20°F Med-Temp Refrigeration Rack	4 - 12
4 - 10 Weekly Refrigeration Load Profile for the -25°F Rack	4 - 18
4 - 11 Average Daily Refrigeration Load Profile for the -25°F Rack	4 - 19
4 - 12 EER Performance of the Howden Open-drive Screw on the -25°F System	4 - 19
4 - 13 EER Performance of the Carlyle Semihermetic Recips on the -25°F System	4 - 20
4 - 14 Comparison of the EER Performance of the Screw and Recip Compressors on the -25°F System	4 - 21
4 - 15 Weekly Refrigeration Load Profile for the -15°F System	4 - 23
4 - 16 Average Daily Refrigeration Load Profile for the -15°F System	4 - 23
4 - 17 EER Performance of the Carlyle Semihermetic Recips on the -15°F System	4 - 24
4 - 18 EER Performance of the Howden Open-drive Screw Compressor on the -15°F System	4 - 24
4 - 19 Comparison of the EER Performance of the Screw and Recip Compressors on the -15°F System	4 - 25
4 - 20 Weekly Refrigeration Load Profile for the +15°F System	4 - 27
4 - 21 Average Daily Refrigeration Load Profile for the +15°F System	4 - 28

FIGURE	PAGE
4 - 22 EER Performance of the Carlyle Open-drive Recips on the +15°F System	4 - 28
4 - 23 Weekly Refrigeration Load Profile for the +20°F System	4 - 30
4 - 24 Daily Refrigeration Load Profile for the +20°F System	4 - 31
4 - 25 EER Performance of the Semihermetic Recip Section of the +20°F System	4 - 31
4 - 26 EER Performance of the Open-drive Recip Section of the +20°F System	4 - 32
4 - 27 EER Performance of the Open-drive Screw Section of the +20°F System	4 - 33
4 - 28 Comparison of Laboratory and Field Performance of the Screw Compressor	4 - 33
4 - 29 Comparison of the EER Performance of the Three +20°F Compressor Systems	4 - 34
4 - 30 Daily Refrigeration Load Profile for the A/C Rack	4 - 37
4 - 31 Daily Power Consumption Profile of the A/C Rack	4 - 37
4 - 32 Effect of Ambient Temperature on the A/C Load	4 - 38
4 - 32 Effect of Ambient Temperature on the Power Consumption of the A/C Rack	4 - 38
4 - 34 EER Performance of A/C Rack	4 - 39
4 - 35 System EER for the Medium-Temperature Rack Using Two Condenser Fan Control Algorithms	4 - 41
4 - 36 System Power for the Medium-Temperature Rack Using Two Condenser Fan Control Algorithms	4 - 41
4 - 37 Moisture Level History for the Low-Temperature Rack	4 - 44
4 - 38 Acid Number History for the Low-Temperature Rack	4 - 44
4 - 39 Moisture Level History for the Low-Temperature Rack	4 - 46
4 - 40 Acid Number History for the Medium-Temperature Rack	4 - 46
4 - 41 Moisture Level History for the A/C Rack	4 - 47
4 - 42 Acid Number History for the A/C Rack	4 - 47

LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
S - 1 Description of the Refrigeration Systems in the Glens Falls Store	S - 11
S - 2 Parameters Used in the Economic Analysis	S - 13
S - 3 Annual Energy Usage and Cost of Glens Falls Low-Temp Refrigeration Systems	S - 13
S - 4 Economic Comparison of Low-Temp Refrigeration Systems Using HCFC-22	S - 15
S - 5 Annual Energy Usage and Cost of Glens Falls Med-Temp Refrigeration Systems	S - 15
S - 6 Economic Comparison of Med-Temp +20°F Refrigeration Systems Using HFC-134	S - 16
1 - 1 Description of the Refrigeration Racks in the Glens Falls Store	1 - 4
2 - 1 Refrigeration System instrumentation	2 - 9
2 - 2 Test Information Obtained From the Laboratory Test Setup	2 - 9
2 - 3 Theoretical Viscosity of Refrigeration Oils When Diluted With HCFC-22	2 - 26
2 - 4 Economized Refrigeration Capacity of the Howden Compressor for Different Refrigerants (4000 rpm)	2 - 31
2 - 5 SDT Conditions Where the Economizer Improves the Efficiency of the Screw Compressor	2 - 34
2 - 6 Summary of 68-cSt Mineral Oil Carryover Tests For CFC-502	2 - 36
2 - 7 Summary of 68-cSt Mineral Oil Carryover Tests For HCFC-22	2 - 36
2 - 8 Summary of 260-cSt POE Oil Carryover Tests For HCFC-22	2 - 37
2 - 9 Summary of 68-cSt POE Oil Carryover Tests For HFC-134a	2 - 37
2 - 10 Summary of 68-cSt POE Oil Carryover Tests For CFC-12	2 - 38
3 - 1 Low-Temperature (-20°F) Refrigeration Schedule of the Clifton Park Store	3 - 2
3 - 2 Test Information Obtained From the Clifton Park Low-Temp Rack	3 - 8
3 - 3 List of Instrumentation for the Clifton Park Low-Temp Rack	3 - 9
3 - 4 Clifton Park HCFC-22 Test Weekly History	3 - 14
3 - 5 Clifton Park HCFC-22 Test History of Modifications	3 - 15
3 - 6 Peak Hourly Power Consumption for the Three Refrigeration Systems with HCFC-22	3 - 39
4 - 1 Description of the Refrigeration Systems in the Glens Falls Test Store	4 - 2
4 - 2 -25°F System Refrigeration Schedule	4 - 17
4 - 3 -15°F System Refrigeration Schedule	4 - 21
4 - 4 +15°F System Refrigeration Schedule	4 - 27
4 - 5 +20°F System Refrigeration Schedule	4 - 29
4 - 6 Glens Falls Store Oil Test Summary	4 - 43
4 - 7 Annual Energy Usage and Cost of Glens Falls Low-Temp Refrigeration Systems	4 - 50

<u>TABLE</u>	<u>PAGE</u>
4 - 8 Annual Energy Usage and Cost of Glens Falls Med-Temp Refrigeration Systems	4 - 51
4 - 9 Parameters Used in the Economic Analysis	4 - 51
4 - 10 Economic Comparison of Low-Temp Refrigeration Systems Using HCFC-22	4 - 52
4 - 11 Economic Comparison of Med-Temp +20°F Refrigeration Systems Using HFC-134	4 - 52

SUMMARY

IN THIS SECTION

BACKGROUND

RESULTS - LABORATORY TESTS

RESULTS - CLIFTON PARK CFC-502 TO HCFC-22 FIELD RETROFIT

RESULTS - GLENS FALLS HFC-134a AND HCFC-22 FIELD TESTS

BACKGROUND

As the deadline approaches for the complete phase-out of CFC refrigerant production, the supermarket industry is faced with uncertainties regarding alternative refrigerants and their effect on system design and efficiency. The New York State Energy Research and Development Authority (NYSERDA), the Empire State Electric Energy Research Corporation (ESEERCO), and the Electric Power Research Institute (EPRI) cosponsored a project to design and test supermarket refrigeration systems that use alternative, non-CFC, refrigerants. The demonstration sites for the project were in Clifton Park and Glens Falls, NY. The Glens Falls store was the first supermarket to use HFC-134a for its entire air-conditioning (A/C) and medium-temperature (med-temp) refrigeration loads. Aspen Systems, and a team of sixteen industry participants, conducted this project to determine the performance of HFC-134a, HCFC-22, and CFC-502 for supermarket application. This effort constitutes the first phase of a larger project aimed at carrying out both laboratory and demonstration tests of the most viable HFC refrigerants and the refrigerants they replace. The results of the Phase I effort are presented in this report. The second phase of the project has also been completed and it centered on testing all viable HFC replacement refrigerants for CFC-502. These were HFC-507, HFC-404A, and HFC-407A. The Phase II results are published in the Phase II final report.

The Phase I work concentrated on the then-available long-term candidates for the replacement of CFC-12 and CFC-502 in supermarkets. These candidates were determined to be HFC-134a for medium- and high-temperature refrigeration and HCFC-22 for low-temperature (low-temp) refrigeration. The laboratory testing portion of the effort aimed at evaluating CFC-12, CFC-502, HCFC-22, and HFC-134a

refrigerants for both low- and med-temp refrigeration. These tests were conducted using a 40-hp open-drive screw compressor.

The field-testing portion of the program was aimed at designing and installing refrigeration and A/C racks based on HCFC-22 and HFC-134a in two supermarkets, both Shop 'n Save stores, owned by Hannaford Bros. Co., of Maine. In the Clifton Park store, we retrofitted a CFC-502 low-temp refrigeration rack to HCFC-22. In the Glens Falls store, we demonstrated HCFC-22 in a low-temp rack and HFC-134a in med-temp and A/C racks. Each of these racks housed several different refrigeration systems based on different compressor technologies. The information collected detailed the refrigeration load and energy consumption of these refrigeration systems.

RESULTS - LABORATORY TESTS

The four refrigerants tested in the laboratory were CFC-502, HCFC-22, HFC-134a and CFC-12. CFC-502 and CFC-12 provided the baseline for comparison to the two alternative refrigerants.

Each refrigerant was tested at -20°F saturated suction temperature (SST) and +20°F SST conditions. All tests were performed using a screw compressor. We strove to conduct each test with the appropriate internal volume ratio (V_i) for the compressor.

Lack of time, however, did not permit the testing of all combinations. HCFC-22 was tested with a V_i optimized for low-temp (3.6), and CFC-12 was tested with a V_i optimized for med-temp (2.6). Hence, tests for HCFC-22 at +20°F and CFC-12 at -20°F SST were not performed with the optimum V_i . The tests with CFC-502 and HFC-134a were performed with both sets of V_i 's.

The measured capacities with each refrigerant are normalized to the compressor's displacement in the bar chart of Figure S-1. CFC-502 and HCFC-22 require similar compressor displacements at +20°F SST. The volume flow requirements for the two low pressure refrigerants, CFC-12 and HFC-134a are also similar at +20°F SST. At -20°F SST, HCFC-22 requires 20% more displacement for a specific load than CFC-502 and 31% less than CFC-12.

Figure S-1. - Normalized Refrigeration Capacities for Different Refrigerants

Figure S-2 shows the energy efficiency ratio (EER) of the compressor with the four refrigerants, plotted against the saturated discharge temperature (SDT). The curves represent the results obtained at +20°F (med-temp) condition with the 2.6-Vi compressor. Since we had not obtained actual data with HCFC-22 for a 2.6-Vi, the HCFC-22 data obtained with the 3.6-Vi compressor were corrected using an adjustment factor calculated from the CFC-502 data. The curves show similar performance for HFC-134a, HCFC-22, and CFC-12. These refrigerants all enjoy a distinct efficiency advantage over CFC-502 at +20°F SST.

Figure S-3 shows the -20°F SST performance of the 3.6-Vi compressor with CFC-502, HCFC-22 and HFC-134a. The energy efficiency performance of the compressor is similar for all three refrigerants. Only at high SDTs (above 100°F) does the EER of HFC-134a fall perceptively below that of CFC-502 and HCFC-22. This is a result of the exceptionally high pressure ratio (11.4@-20°F SST/110°F SDT) and the compressor's Vi which is much too low for this pressure ratio.

Figure S-2. - Comparison of Refrigerant Performance at +20°F with 2.6-Vi Compressor

Figure S-3. - Comparison of Refrigerant Performance at -20°F with the 3.6-Vi Compressor

Summary of Results and Conclusions of the Laboratory Tests

The following list summarizes some of the most important observations made during the laboratory testing:

- As expected, for a fixed compressor displacement, the HFC-134a refrigeration capacity at +20°F SST is 32% lower than that of HCFC-22 or CFC-502. The HFC-134a capacity is 3% greater than that of CFC-12.
- At +20°F SST, the system EER with HFC-134a compared to CFC-502 was significantly better. The EER was comparable for HFC-134a, CFC-12, and HCFC-22.
- At -20°F SST, when compared to CFC-502, HCFC-22 exhibited 7% lower capacity. The EERs were comparable. HFC-134a capacity was 46% lower than CFC-502 capacity. Its EER was similar to that of the other two refrigerants below 100°F SDT.
- Even though at -20°F SST, HFC-134a is as efficient as CFC-502 and HCFC-22 (below 100°F SDT), it is not an ideal replacement refrigerant for low-temp supermarket applications. This is due to its subatmospheric evaporator pressure and its prohibitively high pressure ratio.
- Improper volume ratio selection can have a severe negative impact on the EER of a screw compressor.
- With screw compressors, oil dilution by HCFC-22 must be examined closely to ensure that the oil viscosity is adequate to seal between the lobes of the screws. POE oils are diluted more than mineral oils for a given viscosity. A significant penalty in capacity and EER will result if the viscosity of the oil injected between the rotors is too low.
- When changing oil in anticipation of a switch to an alternative refrigerant such as HFC-134a, a run time between purges of 200 hours appeared to mix the oils more thoroughly and minimized required oil changes. Mixing times on the order of 4 to 8 hours seemed insufficient for a good purge.

RESULTS - CLIFTON PARK CFC-502 TO HCFC-22 FIELD RETROFIT

The Clifton Park store was selected for a CFC-502 to HCFC-22 retrofit because, during a previous project (1), we had already obtained extensive CFC-502 data on its low-temp rack. The low-temp (-20°F SST) rack in this store is composed of two independent systems. The first, a semi-hermetic reciprocating compressor rack, is the store's original refrigeration system (the reference rack). The second, an open-drive screw compressor rack, was added for comparison testing of the two types of compressors on CFC-502. At the time, the store had been in operation for less than a

year and its existing refrigeration systems were state-of-the-art. The Clifton Park store is located about 20 miles north of Albany, NY, and has a floor area of 62,000 sq. ft.

It was decided to use a variable-frequency inverter to control the capacity of the screw compressor. This also afforded us the opportunity to test the reciprocating compressors using a variable-frequency drive. As a result, we conducted a three-way test between:

1. The screw compressor with variable speed capacity control (designated in this report as SCR).
2. The reciprocating compressors with unloader capacity control (UNL), and
3. The reciprocating compressors with variable speed (inverter) capacity control (INV).

The changeover of the Clifton Park low-temp refrigeration system from CFC-502 to HCFC-22 was initiated on July 7, 1991, and was accomplished over two consecutive nights. A crew of seven service people was required. The UNL system was run for the first eight weeks of HCFC-22 operation while we converted the components of the screw compressor rack to HCFC-22. Oil analysis performed after the changeover showed no abnormalities. Refrigerant analysis indicated that the refrigerant in the system after the changeover was 99.9% pure HCFC-22.

Figure S-4 depicts the history of the HCFC-22 refrigeration load for the Clifton Park store. It also provides a pictorial depiction of the switchovers between the different systems. The average weekly refrigeration loads of the three systems are essentially equal. Up to the first quarter of 1992, the refrigeration load averaged about 100 MBH. Afterwards, the average load noticeably decreased to about 90 MBH. The primary cause of the load reduction was that the store stopped using ice for many sections of their produce, reducing the demand on the ice machine.

Figure S-5 shows the comparison of the curve fits of the HCFC-22 EER data for the three refrigeration systems. These curves indicate abnormal EER performance at low SDTs. To illustrate this, consider Figure S-6, which shows the CFC-502 results for the three systems. The performance of the low-temp rack on the two refrigerants is substantially different. With HCFC-22, all three systems exhibit a marked reduction in EER at SDTs below 50°F. This difference in performance between CFC-502 and

Figure S-4. - History of the Weekly Refrigeration Load for the HCFC-22 Low-Temp Rack of the Clifton Park Store

Figure S-5. - Comparison of the HCFC-22 EER Performance for the Three Refrigeration

ASPEN SYSTEMS CFC-502 DEMONSTRATION RESULTS

Figure S-6. - Comparison of the CFC-502 EER Performance for the Three Refrigeration

HCFC-22 is due to the excessive cycling of the compressors with HCFC-22. The reason for this cycling is the lower flow rate of HCFC-22 at low ambient temperatures. The HCFC-22 reduction in EER at low SDTs is most pronounced for the INV, and least pronounced for the SCR.

With HCFC-22, the UNL shows the best overall performance, followed by the INV. The SCR is last. However, the situation was not ideal for the SCR, since we were using a 150 Saybolt Universal Seconds (SUS) oil. This oil was selected based on the requirements of the reciprocating compressors (recips) as opposed to the screw compressor (screw) since the wear rates of the recips are supposed to be excessive at higher viscosities. Our laboratory results have shown that with a higher viscosity oil, the SCR performance can improve by an average of 5%. With CFC-502, the INV shows the best performance. Compared to the SCR, the UNL has a higher EER above 60°F SDT, while the SCR has a distinctly higher EER below 60°F SDT.

The CFC-502 performance for the INV follows the general pattern of EER/SDT dependence for positive displacement compressors. The HCFC-22 performance is similar to that of CFC-502 above 80°F SDT. The EER of the SCR is generally lower for HCFC-22, which is in agreement with our laboratory results. The laboratory tests have shown that, with 68 centistokes (300 SUS) mineral oil, the screw compressor's low-temp EER performance deteriorates when switching to HCFC-22. Only after we switched to substantially higher-viscosity (1500 SUS) polyolester (POE) oil, did we obtain equivalent CFC-502 and HCFC-22 EER performance. In Clifton Park, this problem is compounded by the use of 150 SUS mineral oil. As a result, the screw in Clifton Park performs even worse than the screw in the laboratory running on 300 SUS mineral oil. For the UNL system, above 50°F SDT, the HCFC-22 performance is better than or equal to that of CFC-502.

Summary of Results and Conclusions of the Clifton Park CFC-502 to HCFC-22 Conversion

- The conversion of the low-temp rack in Clifton Park from CFC-502 to HCFC-22 was accomplished over two nights.
- The average HCFC-22 refrigeration load was 100 MBH and was not different from the CFC-502 refrigeration load.
- Compared to CFC-502, the HCFC-22 EER performance improved for the UNL and deteriorated for the SCR.
- With HCFC-22, the most efficient system was the UNL followed by the INV and the SCR. In contrast, with CFC-502, the most efficient system was the INV. In terms of efficiency, the SCR and UNL have similar seasonal performance. However, the UNL consumes less power. This is due to the additional refrigeration load carried by the screw as a result of the mechanically subcooled liquid lines.
- All three systems operated less stably with HCFC-22 compared to CFC-502. This is due to the lower mass flow rates associated with HCFC-22.
- The HCFC-22 performance of the SCR was lower than the results obtained in Aspen Systems laboratory. The cause of the lower performance is the low viscosity of the oil used in Clifton Park.
- The conversion was successful. The systems performed reliably and, in some cases, we observed improved performance compared to CFC-502.

RESULTS - GLENS FALLS HFC-134a AND HCFC-22 FIELD TESTS

The Glens Falls Shop 'n Save superstore was designated as a demonstration site for advanced, non-CFC refrigeration systems in its design stage. Completed in March of 1992, the store employed HFC-134a for its A/C and med-temp systems and HCFC-22 for its low-temp system. The 63,000-ft² store operates 24 hours a day. In addition to the testing of alternative refrigerants, different compressor technologies were tested. The med-temp system was tested with open-drive recip, semihermetic recip, and open-drive screw compressors. The low-temp system was tested with open-drive screws from two different manufacturers as well as semihermetic recip. The A/C rack used open-drive recip. All compressors, except those on the A/C rack, used variable-frequency drives for capacity control.

Each system was fully instrumented to allow measurement of operational parameters and energy efficiency. Data collected from these systems were used to establish seasonal performance and electric power demand. Materials performance issues such as component reliability and oil/refrigerant compatibility were also addressed. Oil samples from each system were analyzed on a regular basis to identify excessive contamination, decomposition, chemical shifts, wear, or other long-term compatibility problems.

A summary description of the A/C and refrigeration systems at the Glens Falls Shop 'n Save store is shown in Table S-1. The arrangement of the refrigeration systems in Table S-1 is schematically illustrated in Figure S-7. The low-temp rack has two suction groups, -25°F and -15°F, which share a common oil separator, condenser, reclaim coils, receiver, and liquid pump. For the tests described in this section, the low-temp refrigeration system had one Howden open-drive screw compressor, two Carlyle open-drive screw compressors, and two Carlyle 06ER175 semihermetic recip compressors.

The med-temp rack also has two suction groups, +20°F and +15°F. The +20°F group includes three Bitzer 6H2 open-drive reciprocating compressors, four Carlyle 06EM175 semihermetic reciprocating compressors, and three Howden-91mm open-drive screw compressors. The +15°F med-temp system has two Carlyle 5H40 open-drive reciprocating compressors.

**Table S-1. Description of the Refrigeration Systems
in the Glens Falls Test Store**

Rack Name	Refrigerant	Load (MBH)	Compressor				Oil		
			No.	Type	Manufacturer	Qty	Grade (SUS)	Type	Manufacturer
-25°F/-15°F Low-temp	HCFC-22	126/177	1	Semi, Screw	Carlyle	1	300	AB	Zerol
"			2	Open, Screw	Howden	1			
"			3	Semi, Recip	Carlyle	2			
+15°F Med-temp	HFC-134a	239	4	Open, Recip	Carlyle	2	300	POE	CPI
+20°F Med-temp	HFC-134a	540	5	Open, Screw	Howden	3	300	POE	CPI
"			6	Open, Recip	Bitzer	3			
"			7	Semi, Recip	Carlyle	4			
Air Conditioning	HFC-134a	1200	8	Open, Recip	Bitzer	4	150	POE	Castrol

Legend: Open - Open-Drive; Semi - Semihermetic; AB - Alkylbenzene; POE - Polyol Ester

**Figure S-7. Arrangement of the Refrigeration Systems
in the Glens Falls Test Store**

The A/C rack serves one +40°F suction group. The A/C for the store is supplied by 5 roof-mounted air handlers. The heating load is met with heat reclaim from the refrigeration racks and by gas heaters. The cooling load is met using outside air when the outdoors ambient temperature is below 70°F. Above this temperature, the HFC-134a-filled A/C rack provides the required mechanical cooling.

The following tests were conducted on a continuous basis:

- The +20°F system was alternated between each bank of compressors every week. The collected data allowed optimization and comparison of the three different compressor configurations.
- The compressors on the low-temp rack were alternated between the -15°F and -25°F suction groups on a weekly basis. As on the +20°F systems, the compressors' performance was optimized and compared.
- The +15°F system was continuously monitored. The A/C rack was monitored when it was in operation during the cooling season.
- Oil samples were taken on a regular basis from each system. Samples were analyzed to determine if there was excessive contamination, decomposition, chemical shifts, wear or other long-term compatibility problems between the refrigerant, oil, and system components.

A massive amount of data was collected during these tests. We used the second-order curve fits of the EER data to calculate the annual EER (AEER) of the refrigeration systems. The analysis utilized bin temperature data from Albany, NY (8).

We also examined the life cycle cost (LCC) of the different options that were tested. The economic analysis performed is described in Appendix B. The economic descriptors calculated were: the LCC, the net present value savings (NPVS), the return on investment (ROI), and the simple payback period. Table S-2 lists the values used for this analysis.

Low-Temp Rack Test Results

Several operational issues concerning the results for the Carlyle open-drive screw compressors have cast doubt over the validity of the data obtained with these compressors. The low-temp results presented are, therefore, limited to the Howden open-drive screw and Carlyle semihermetic reciprocating compressors.

Table S-2. - Parameters Used in the Economic Analysis

DISCOUNT RATE	7	%
COST OF ELECTRICITY	0.1	\$/KW-HR
ELECTRICITY ESCALATION RATE	5	%/YR
MAINTENANCE COST (RECIPS)	1000	\$/YR
MAINTENANCE COST (SCREWS)	900	\$/YR
MAINTENANCE COST ESCALATION	5	%/YR
SALVAGE VALUE	500	\$
SYSTEM LIFE	15	YR

For the low-temp analysis, the semihermetic recip was chosen as the base system. The semihermetic recip is the industry standard for supermarket refrigeration. The low-temp analysis shown in Table S-3 clearly indicates that the screw compressor has a higher AEER and a lower annual operating cost.

Table S-3. Annual Energy Usage and Cost of Glens Falls Low-Temp Refrigeration Systems

-25°F System					
Compressor	System	Annual	Annual Energy	Operating	Cost
	No.	EER	Consumption	Cost	Difference
		BTU/W-HR	KW-HR	\$/YR	\$/YR
Open-Drive Screw	2	7.37	142624	14262	-925
Semihermetic Recip	3	6.92	151874	15187	BASE
Refrigeration Load = 120 MBH.					
Minimum SDT = 40°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kw-hr (Including demand charges).					
-15°F System					
Compressor	System	Annual	Annual Energy	Operating	Cost
	No.	EER	Consumption	Cost	Difference
		BTU/W-HR	KW-HR	\$/YR	\$/YR
Open-Drive Screw	2	8.89	118244	11824	-802
Semihermetic Recip	3	8.33	126263	12626	BASE
Refrigeration Load = 120 MBH.					
Minimum SDT = 40°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kw-hr (Including demand charges).					

Table S-4 summarizes the economic comparison of the semihermetic reciprocating and the open-drive screw compressor on the -25°F and -15°F loads. The open-drive screw has a significant advantage over the semihermetic reciprocating. The payback period of approximately three years may be attractive to a supermarket, given the reduced risk of compressor failure due to liquid slugging and consequent food spoilage.

Med-Temp Rack Test Results

The results of the bin temperature analysis for the +20°F systems are presented in Table S-5. The AEER for the open-drive reciprocating compressors is 14.82. For the semihermetic reciprocating compressors the AEER is 13.39. On the basis of these figures, the annual operating cost savings of the open-drive system versus the semihermetic system is about \$1600 based on \$0.10/kWh, including energy and demand costs.

The reason for the poor performance of the screw compressors was the improper selection of their V_i 's. The optimum (desired) V_i for all three screws would have been 2.6. Of the three compressors installed in the +20°F system, however, two had a V_i of 3.6 and one had a V_i of 5.0. There is a significant energy and cost penalty associated with the improper V_i selection of the +20°F screw compressors. In terms of AEER, selecting the wrong V_i results in 16% higher energy consumption. As shown in Table S-5, the annual EER based on the field data is 13.01, whereas the laboratory data obtained with the proper V_i yield an AEER of 15.11. This emphasizes the importance of selecting the correct V_i when installing a screw compressor. Unless a refrigeration system is selected and installed correctly, it will not yield the expected energy efficiency that an engineering analysis predicts.

Table S-6 summarizes the economic comparison of the three compressor types on the +20°F system. The open-drive reciprocating, despite their clear EER advantage, may not be economically justifiable due to the 6 years required to pay back the additional capital cost.

**Table S-4. Economic Comparison of Low-Temp
Refrigeration Systems Using HCFC-22**

-25°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$ (1000)	\$	%	YR
Semihermetic Recip	23000	15187	1000	500	232.3	BASE SYSTEM		
Open-Drive Screw	26000	14262	900	500	222.0	10265	40.4	2.9
-15°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$ (1000)	\$	%	YR
Semihermetic Recip	23000	12626	1000	500	199.2	BASE SYSTEM		
Open-Drive Screw	26000	11824	900	500	190.5	8672	35.9	3.3

**Table S-5. Annual Energy Usage and Cost of Glens Falls
Med-Temp Refrigeration Systems**

+15°F System					
Compressor	System	Annual	Annual Energy	Operating	
	No.	EER	Consumption	Cost	
		BTU/W-HR	KW-HR	\$/YR	
Open-Drive Recip	5	12.97	107758	10776	
Refrigeration Load = 160 MBH.					
Minimum SDT = 65°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kw-hr (Including demand charges).					
+20°F System					
Compressor	System	Annual	Annual Energy	Operating	Cost
	No.	EER	Consumption	Cost	Difference
		BTU/W-HR	KW-HR	\$/YR	\$/YR
Open-Drive Recip	6	14.82	148914	14891	-1596
Semihermetic Recip	7	13.39	164,869	16487	BASE
Open-Drive Screw	5	13.01	169653	16965	478
Open-Drive Screw	(a)	15.11	146124	14612	-1875
Refrigeration Load = 252 MBH.					
Minimum SDT = 65°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kW-hr (Including demand charges).					
(a) Energy usage based on laboratory performance.					

**Table S-6. - Economic Comparison of Med-Temp +20°F
Refrigeration Systems Using HFC-134**

SYSTEM DESCRIPTION	INITIAL COST	ENERGY	MAINT COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	MWH	\$	\$	\$1000	\$	%	YR
SEMI - RECIP	28934	164.9	1000	500	255.1	BASE SYSTEM		
OPEN - RECIP	38327	148.9	1000	500	243.8	11255	20.6	5.9
OPEN - SCREW	45821	169.7	900	500	276.8	-21784	****	****
OPEN - SCREW*	45821	146.1	900	500	246.4	8666	13.5	8.6
* based on lab results with properly selected compressor Vi								

In this analysis, the open-drive screws show poor field performance when the results from the improperly selected compressors are used. An evaluation based on the laboratory results is also shown, to illustrate the potential economic benefit when the screws are properly selected. However, even with the proper Vi, the payback period of 8.6 years hardly justifies the additional capital cost.

A/C Rack Test Results

From its start-up, the air conditioning refrigeration rack had several operational problems. These problems included: improper selection of theraml expansion valves (TXVs) and distributor orifices for HFC-134a operation, flooding of compressors, the high pressure difference across the liquid pump, and a substantial pressure loss in the racks suction line.

The performance results of the A/C rack are not completely reliable since few data were collected after its operational problems were corrected. The measured instantaneous EER data available were significantly lower than expected. The most likely cause for this was the cycling of the compressors and large swings in SST.

As there were several operational issues concerning the A/C rack, we are unable to calculate a reasonable seasonal EER value for this rack.

Summary of Results and Conclusions of the Glens Falls HFC-134a and HCFC-22 Field Tests

All refrigeration systems in the Glens Falls store operated well and within expected performance range. On a rack-by-rack basis, the following summarizes the results we obtained.

Low-Temp

- We did not expect and did not experience any problems with the low-temp HCFC-22 system. The data collected for the Howden screw compressor show similar performance to Aspen Systems' laboratory data.
- The screw compressor provided 7% better AEER than the recip for both -25°F and -15°F suction groups. Economic analysis indicates a payback period of about three years.

Med-Temp

- Our experience with HFC-134a in the med-temp rack has been extremely favorable. We have observed no incompatibility problems between HFC-134a, its POE lubricant, and the rest of the system. HFC-134a appears to be a trouble-free long-term refrigerant replacement for med-temp refrigeration.
- All compressor systems on the med-temp rack performed as expected except for the screw compressors. The open-drive reciprocating compressors showed the best AEER at 14.82 Btu/W-hr.
- The Vi of the open-drive screws was not optimized. According to our laboratory results, with the correct Vi, the open-drive screws would have performed at least as efficiently as the open-drive reciprocating compressors.
- Economic analysis indicates lengthy payback periods for the open-drive recip and open-drive screws compared to semihermetic recip.

Air-Conditioning

- From its start-up, the A/C refrigeration rack had several operational problems. These problems included: improper selection of TXVs and distributor orifices for HFC-134a operation, flooding of compressors, the high pressure difference across the liquid pump, and a substantial pressure loss in the rack's suction line.
- The measured EER for the A/C rack was significantly lower than expected. The most likely cause for this is the cycling of the compressors and large swings in SST.
- The performance results of the A/C rack are not completely reliable since few data were collected after its operational problems were corrected.

INTRODUCTION

Section 1

IN THIS SECTION

DESCRIPTION OF THE R&D PROJECT PHASE I SCOPE OF WORK

DESCRIPTION OF THE R&D PROJECT

As the deadline approaches for the complete phase-out of production of CFC refrigerants, the supermarket industry is faced with the uncertainties regarding alternative refrigerants and their effect on system design and efficiency. The New York State Energy Research and Development Authority Energy Authority (NYSERDA), the Empire State Electric Energy Research Corporation (ESEERCO), and the Electric Power Research Institute (EPRI) have cosponsored a project to design and test supermarket refrigeration systems that use alternative, non-CFC, refrigerants. The demonstration sites for the project were in Clifton Park and Glens Falls, NY. The Glens Falls store is the first supermarket to use HFC-134a for its entire air-conditioning and medium temperature refrigeration loads. Aspen Systems and a team of sixteen industry participants conducted this project to determine the performance of HFC-134a, HCFC-22, and CFC-502 for supermarket application. This effort constitutes the first phase of a larger project aimed at carrying out both laboratory and demonstration tests of the most viable HFC refrigerants and the refrigerants they replace. The results of the Phase I effort are presented in this report. The second phase of the project has also been completed and it centered on testing all viable HFC replacement refrigerants for CFC-502. These were HFC-507, HFC-404A, and HFC-407A. The Phase II results are published in a separate report.

The proposed work concentrated on the then available long-term candidates for the replacement of CFC-12 and CFC-502 in supermarkets. These candidates were determined to be HFC-134a for medium- and high-temperature refrigeration and HCFC-22 for low-temperature refrigeration. The work plan aimed at designing and installing refrigeration and air-conditioning racks based on these refrigerants in two supermarkets. The information collected detailed the refrigeration load and energy consumption of several different refrigeration systems using these ozone-friendly refrigerants. This effort also supplied performance data on one supermarket air-conditioning rack using HFC-134a.

refrigerants. This effort also supplied performance data on one supermarket air-conditioning rack using HFC-134a.

The supermarket chain sponsoring the project was Hannaford Bros. Co., of Maine. Since its inception, this program was supported by several refrigeration equipment manufacturers. Because of its increasing importance and visibility, additional manufacturers of related equipment became active participants in this project during the first year. The major participants, other than the sponsors, the supermarket chain, and Aspen Systems, were as follows:

- ALCO Controls- Valve Manufacturer
- Allied Signal, Inc. - refrigerant manufacturer
- Brown Engineering/Bitzer Compressors - compressor manufacturer
- Carlyle Compressor Company - compressor manufacturer
- Castrol, Inc. - lubricant manufacturer
- CPI Engineering Services, Inc. -lubricant manufacturer
- Demand Defrost Systems - defrost control manufacturer
- Eastern Heating and Cooling, Inc. - installation contractor
- E.I.L. Instruments, Inc. - control system manufacturer
- Hannaford Brothers - owner of the Shop 'n Save supermarket
- Hill Refrigeration - display case manufacturer
- Howden Compressors, Inc. - compressor manufacturer
- Niagara Mohawk Power Corporation - local electric utility
- Phoenix Refrigeration Systems, Inc. - refrigeration system manufacturer
- Spectronics Corporation - leak detection system manufacturer
- Sporlan Valve Company - valve manufacturer

The above companies have contributed substantial amounts of equipment and services to this project. As a result of their contribution, we have been able to triple the scope of the project with only a relatively small increase in outside funding.

PHASE I SCOPE OF WORK

The objectives of this project were to develop, evaluate, and demonstrate the most suitable environmentally safe refrigeration systems for the low-temperature (low-temp), medium temperature (med-temp), and air-conditioning (A/C) loads of a supermarket. The program was designed to test refrigeration racks based on screw, semi-hermetic reciprocating, and open-shaft reciprocating compressors.

The work plan for the Phase I of this effort included the following tasks:

1. Design and build a satellite rack in Aspen Systems' laboratory based on an open-shaft screw compressor to complement our existing refrigeration test facility. Use this laboratory setup to establish the comparative performance of screw compressors utilizing CFC-12, CFC-502, HCFC-22, and HFC-134a refrigerants.
2. Replace the CFC-502 in the -20°F rack at the Clifton Park supermarket site with HCFC-22, and carry out field tests comparing the two refrigerants.
3. Design a mechanical center to house the entire refrigeration and air conditioning systems of a second supermarket. Design the two low-temp racks (-15°F and -25°F) to operate on HCFC-22 and the two med-temp racks (+15°F and +20°F) and the air conditioning rack (+40°F) to operate on HFC-134a. Design the +20°F med-temp rack to be composed of three systems, each capable of serving the entire +20°F refrigeration load. Base the three systems on screw, open-shaft reciprocating, and semi-hermetic reciprocating compressors. Instrument and monitor all three racks.
4. Obtain test results from the HCFC-22 rack of the first supermarket site and all the racks (HCFC-22 and HFC-134a) of the second site for at least one year.
5. Prepare a Phase I Final Report detailing the results of the laboratory and demonstration testing.

The work plan was based on two demonstration projects in two separate supermarkets. The first supermarket, a superstore located in Clifton Park, NY, had been the test site for a previous contract with NYSERDA to demonstrate a screw compressor refrigeration rack in a supermarket running on CFC-502 (1). As a result of this previous effort, we already had an instrumented, functioning, low-temp rack in Clifton Park. This installation included the following:

- A low-temp (-20°F) reciprocating compressor system composed of two Carlyle semi-hermetic compressors with unloaders.
- A low-temp (-20°F) screw compressor rack composed of one Howden open-shaft compressor without unloaders.
- Two Com-Trol and one EIL energy management systems capable of processing 192 data points.

- One 50-hp variable-speed inverter capable of running either compressor set independently.
- All instrumentation necessary to evaluate the performance of the system.

Either the screw or the reciprocating compressor system was capable of satisfying the -20°F refrigeration load of the supermarket. The variable speed inverter was used to control the capacity of the screw compressor system. The reciprocating compressor system was operated in two distinct modes: a) with unloader capacity control, and b) with inverter capacity control. The load was switched on a weekly basis from the screw compressor to the reciprocating compressors running on unloaders to the reciprocating compressors running on the inverter. This allowed a performance comparison between the three different modes of operation. The -20°F load was only a portion of the total low-temp refrigeration load. The other low-temp suction groups were -25°F and -35°F. These were not part of the test and were not instrumented.

The second site was a superstore located in Glens Falls, NY, all of whose refrigeration systems were dedicated to this project. Table 1-1 lists the compressors used for each of the systems in Glens Falls.

**Table 1-1. - Description of the Refrigeration Racks
in the Glens Falls Store**

Low-Temp Rack
<u>-25°F or -15°F LOW-TEMP SYSTEM (HCFC-22)</u>
Two Carlyle 33 cfm Open-Drive Screws
One Howden 91 mm Open-Drive Screw
Two Carlyle 06ER175 Semihermetic Recips
Med-Temp Rack
<u>+15°F MED-TEMP SYSTEM (HFC-134a)</u>
Two Carlyle 5H40 Open-Drive Recips
<u>+20°F MED-TEMP SYSTEM (HFC-134a)</u>
Three Howden 91 mm Open-Drive Screws
Three Bitzer 6H2 Open-Drive Recips
Four Carlyle 06EM175 Semihermetic Recips
A/C Rack
<u>+40°F A/C SYSTEM (HFC-134a)</u>
Three Bitzer 6F2 and One Bitzer 4H2 Open-Drive Recips

The three low-temp systems were rotated on a weekly basis between the -15°F and -25°F refrigeration loads. The med-temp +20°F load was served by a different compressor group each week. The two other compressor groups were idle. All compressor systems except the +40°F A/C system were controlled by variable-speed drives. The entire store was instrumented and the data was collected by an EIL energy management system and a high-precision data logger. The Clifton Park test was completed by June 1993, while the Glens Falls test continued until April 1994.

LABORATORY TESTING

Section 2

IN THIS SECTION

DESCRIPTION OF THE LABORATORY TEST SETUP

SCOPE OF WORK

TEST RESULTS

OIL MANAGEMENT

REFRIGERANT CONVERSION ISSUES

SUMMARY

DESCRIPTION OF THE LABORATORY TEST SETUP

Aspen Systems' laboratory refrigeration test setup consists of two screw compressor racks. The larger one is based on a 50-hp vertical hermetic Dunham-Bush screw compressor (2). The smaller rack uses a 40-hp horizontal open-shaft Howden screw compressor. The smaller, open-drive rack was used for the HFC-134a tests performed for this project. This rack shares the same condenser, receiver, evaporators, and heat source as the larger rack. The setup was designed to obtain accurate and reliable test data for the refrigerants being tested. In this section, a comprehensive description of the laboratory setup is presented.

Description of the HFC-134-a Rack

The piping and instrumentation diagram for the HFC-134a portion of the rack is presented in Figure 2-1. Figure 2-2 shows a photograph of the HFC-134a rack with the larger vertical hermetic rack in the background. The major components of the laboratory system consist of the open-drive screw compressor, its drive motor, variable-frequency drive (VFD) and controller, two chillers, an economizer heat exchanger (subcooler), a receiver, an oil cooler, an oil separator, a gas-fired boiler, an air-cooled condenser, and a display case. All but the last three items are mounted on the screw compressor rack. Figure 2-3 shows how the screw compressor rack is connected to the condenser, display case, brine chillers, and the economizer subcooler. The condenser is installed on the roof, while the display case and gas-fired boiler are located adjacent to the refrigeration rack.

Figure 2-1. - HFC-134a Laboratory Test Rack Piping and Instrumentation Diagram

Figure 2-2. - Aspen Systems' HFC-134a Laboratory Test Rack

Figure 2-3. - Aspen Systems' Refrigeration Facility Piping and Instrumentation Diagram

The heat input for the refrigeration cycle is from an ethylene glycol brine loop. The major components of the brine loop are the gas-fired hydronic boiler and its circulating pump. The boiler is sized to provide the heat removed by the chillers. The pump circulates a 45% solution of ethylene glycol and water that withstands freezing to -25°F.

Two chillers were included to account for the large variation in refrigeration load experienced by the system. During these tests, the system's capacity varied from 59 MBH to 264 MBH, depending on the refrigerant used and the test conditions. Thus, the design incorporates two chillers, each capable of handling half the maximum load.

A solenoid valve can automatically isolate one of the chillers from the circuit. The display case is used to measure the effect of different refrigerants and lubricants on the heat transfer rate in the evaporator coil. It can also be used to determine the effect of hot gas defrost on system performance. The major components of the laboratory test stand are described below.

Screw Compressor. The screw compressor was a 91-mm "Hummingbird" compressor manufactured by Howden Compressors. The compressor is an open-drive, oil-injected unit with a built-in two-element oil separator. Two different versions of this compressor were used during testing. Their specifications are as follows:

Model No.	MK3WCVF91
Maximum rpm	5000
Displacement (4000 rpm)	73 cfm
Internal Volume Ratio	3.6
Model No.	MK4WCVF91
Maximum rpm	5000
Displacement (4000 rpm)	73 cfm
Internal Volume Ratio	2.6

The two compressors had different internal volume ratios (V_i 's) to match the pressure ratios of the different refrigerants at the med- and low-temp operating conditions.

For an ideal gas undergoing isentropic, reversible, adiabatic compression, the V_i can be calculated as follows:

$$V_i = \left(\frac{P_{dis}}{P_{suc}} \right)^{\frac{1}{k}}$$

where P_{suc} = suction pressure,
 P_{dis} = discharge pressure, and
 k = ratio of specific heats.

The V_i should be selected in order to optimize the annual energy efficiency ratio (AEER) of the system. This mandates that the V_i be selected for a saturated discharge temperature (SDT) that is substantially lower than the design SDT. When the V_i is selected at the design condition (typically 110°F SDT in the Northeast) the compressor will run less efficiently at all conditions below the design condition. Since over 90% of the compressor operating hours are spent at SDTs well below the design condition, the V_i should be optimized for a time-averaged SDT.

In New England, a typical med-temp system (20°F saturated suction temperature [SST]) with floating-head condenser control would operate at a time averaged SDT of 75°F. For these conditions, the compressor Vi that most closely matches the desired Vi is 2.6.

For a low-temp application with floating head condenser control, the Vi should be selected for an average SDT of 65°F. At -20°F SST, the desired compressor Vi would be 3.6.

Besides featuring different Vi's, the compressors are also constructed differently. The MK3 compressor is the one described under "Compressor Optimization" below. The MK4 compressor includes all the revisions described therein and several other improvements that increased its capacity and EER, including larger ports. Our tests with HFC-134a on the MK4 indicated a 3.7% increase in EER and a 5.8% increase in capacity over the MK3 at +20°F SST, 110°F SDT.

Motor. A high-efficiency, induction motor manufactured by Baldor is used to drive the screw compressor. The motor is balanced for operation up to 4500 rpm. The remaining specifications for the motor are as follows:

Motor Model No.	EM2538T
Nominal Rating	40 hp
Type	Open Drip-Proof
Max. Efficiency	92%

Controller. The rack uses an EIL RC-1000 to control the variable-speed drive and maintain a constant system suction pressure. The RC-1000 uses a conventional proportional-integral-derivative (PID) algorithm to perform this task. However, the RC-1000 could not operate the rack on HFC-134a at operating conditions below -15°F evaporator temperature. Below -15°F, the saturated pressure of HFC-134a is sub-atmospheric. The suction setpoint of the RC-1000 cannot be set to a vacuum. Hence, we obtained and installed a stand-alone PID controller that accepts an absolute pressure setting. This controller allowed us to map the performance of the rack with HFC-134a at SSTs below -15°F.

Variable-Frequency Drive. A constant-torque, variable-speed inverter manufactured by Allen Bradley was used to control the speed of the compressor drive motor. The inverter was oversized by 25% to accommodate the expected power

consumption of the rack using the different refrigerants. The specifications of the inverter are as follows:

Model No.	1336-B050-EAG-FA2-L3
Nominal Rating	50 hp
Type	Sinusoidal PWM
Max. Rated Efficiency	98%

Condenser. The condenser is an air-cooled, direct-drive unit manufactured by Dunham-Bush. The condenser specifications are as follows:

Model No.	LSBC-242D-ARFNN8N
Heat transfer rating	21,200 Btu/°F/hr
Fan power	3.92 kW
Number of fans	4
Weight	1290 lbs
Dimensions	88x88x49 in.

In addition, the condenser is equipped with fan cycling contactors that can be cycled by the control system.

Brine Chillers. The brine chillers are shell-and-tube units manufactured by Dunham-Bush. They consist of a stainless steel housing and inner-finned copper tubing. The stainless steel housing was specified by Dunham-Bush for low-temp application. The specifications of the chillers are:

Model No.	CHSK-7601A-JJ-T
Rating at 9°F approach and 10°F range, for water	42 ton
Rating with ethylene glycol	20 ton
Brine side pressure drop	3.5 psi
Insulation thickness	2 in
Weight	397 lbs
Dimensions	12-3/8 Dia x 74L in

Display Case. The display case is a coffin-type unit manufactured by Hill Refrigeration. Its specifications are:

Model Number	NZ8FK
Refrigeration Load at -20°F	11,200 Btu/hr
Usable Internal Volume	27.7 cu ft
Length	8 ft

The display case came equipped with a hot gas defrost check valve.

Receiver. The receiver is a horizontal unit manufactured by Standard Refrigeration:

Model No.	96105
Refrigerant Capacity (CFC-502)	269 lbs
Dimensions	96L x 11Dia in

Hydronic Boiler. The boiler is a gas-fired unit manufactured by Edwards Engineering. The specifications for the boiler are:

Model Number	V500MC
Input Heat Rating	500 MBH
Output Heat Rating	400 MBH
Dry Weight	1100 lbs
Dimensions	53H x 30Dia in

The boiler package includes a circulating pump, a natural gas pressure regulator, and controls.

Economizer Subcooler. In order to improve the energy efficiency of the screw compressor, its economizer port was used for mechanical subcooling. The selected subcooler was a shell and tube heat exchanger manufactured by Dunham-Bush. This unit was connected in a counter-flow configuration. The subcooler was initially installed horizontally, but was later mounted vertically with the thermal expansion valve (TXV) feeding from the bottom, resulting in an upward flow of refrigerant evaporating in the tube side. The specifications for the subcooler are:

Model No.	SC004243A00U
Max. Load	36 MBH
Dimensions	4.2Dia x 36L in

Oil Cooler. The air-cooled oil cooler is manufactured by Dunham-Bush. The copper tubes in this particular oil cooler are inner-finned, making it one of the most effective units on the market. The oil cooler fan is controlled by a thermostat that was initially set at 140°F. The oil cooler's specifications are:

Model No.	DB-22-4
Oil flow rate	6 gpm
Heat rejection at 50°F DT	14 MBH
Dimensions	16H x 20W x 18D in
Fan motor rating	1/4 hp

Oil Separator. The rack uses an AC&R helical oil separator that was specially designed for screw compressor application. We have found that this unit is considerably more efficient than traditional coalescing oil separators. The specifications for the oil separator are:

Model No.	S-5292
Capacity (HCFC-22 @ 20°F SST)	265 MBH
Dimensions	6Dia x 18H in

Instrumentation

The laboratory test rack was fully instrumented to ensure accurate and reliable performance evaluation of each refrigerant we tested. Table 2-1 lists the instrumentation used in the rack. Table 2-2 lists the type of performance data we obtained.

The most critical instruments were those used to measure the power and refrigeration load of the rack. For measuring the electric power, we used two-stator polyphase G.E. Watt-hour meters with a pulse output. Since these meters are the kind used by utilities, they most accurately reflect electric utility charges. The refrigeration load measurement was accomplished with three high-accuracy instruments: the two brine loop thermistors and the brine loop flow meter. The thermistors are precision interchangeable devices with 0.18°F accuracy. The brine loop flow meter was calibrated at three different brine temperatures. The load was also checked against an energy balance made possible by orifice plate flow meters in the refrigerant loop. These independent load measurements allowed us to have a high degree of confidence in our data.

SCOPE OF WORK

The laboratory testing phase of this project consisted of the following major tasks:

- Modification of our existing refrigeration test rack.
- Verification of the instrumentation.
- Optimization of the Howden screw compressor.
- Optimization of system performance.
- Baseline testing with CFC-502 and CFC-12.
- Testing of alternative refrigerants HCFC-22 and HFC-134a.

Each of these major tasks is described separately below.

Table 2-1. Refrigeration System Instrumentation

NO.	COMPONENT	MANUFACTURER	MODEL NO.
1-	Thermocouples (9)	Omega	TMQSS-12SU-6
2-	Brine Loop Thermistors (2)	Omega	ON-910-44034
3-	Pressure Transducers (7)	Rosemount	1151GP7E12M1B1
4-	Differential Pressure Transducers (3)	Rosemount	1151DP7E12M1B1
5-	Suction Orifice Plate Flow Meter	Foxboro	OP-FTT-304-300-3
6-	Discharge Orifice Plate Flow Meter	Foxboro	OP-FTT-304-300-2
7-	Vapor Injection Orifice Flow Meter	Foxboro	OP-FTT-304-300-2
8-	Display Case Flow Meter	Fluidyne	214-200
9-	Brine Loop Flow Meter	Signet Sci.	MK-515-P0 2NPT
10-	Liquid Line Flow Meter	K Flow	K-250
11-	Compressor Wattmeter	G.E.	700X1G79
12-	Condenser Wattmeter	OSI	PC5-15B
13-	Torque Sensor	Sensor Developments	01100
	Data Acquisition		
14-	Computer	Compuadd	286/20MHZ
15-	Data-Logger	Campbell Sci.	21X
16-	Multiplexer	Campbell Sci.	AM32

Table 2-2. Test Information Obtained from the Laboratory Test Setup

1-	Refrigeration Cycle State Points
2-	Power Consumption
3-	Refrigeration Capacity
4-	EER
5-	Evaporator Heat Transfer Rates
6-	Ambient Subcooling
7-	Mechanical Subcooling
8-	Compressor Efficiencies
9-	Electric Drive Efficiency
10-	Drive Frequency
11-	Suction and Discharge Superheat
12-	Vapor Injection Benefit
13-	Condenser Power
14-	Oil Analysis

Rack Modifications

As part of this effort, we designed and built the HFC-134a rack to be coupled with our existing vertical screw compressor system. A detailed description of this rack is included above. This section describes the additions and modifications performed on the rack during our experimentation.

An oil chamber was included to allow for measurement of oil carryover from the compressor. As shown in Figure 2-1, this chamber was connected to the oil outlet of the separator, the discharge line, the suction line, and the oil reservoir. During oil carryover tests, the oil from the separator is diverted to this chamber. While the oil is being collected, the chamber is vented to the suction line to remove the trapped refrigerant. The amount of oil collected during a specific time period is recorded using a calibrated sight glass. When measurements are completed, discharge pressure is used to return the oil to the oil reservoir.

Initially, the Howden compressor, oil reservoir, and oil cooler were filled with a 68-cSt (300-SUS) mineral oil and the rack was charged with CFC-502.

During the CFC-502 testing a VFD was added to the condenser fans. This provided better control of compressor discharge pressure during testing.

The original, standard design oil separator was replaced with the helical oil separator (described above) after the CFC-502 testing was completed.

Verification of Instrumentation

The existing instrumentation was augmented by several additional sensors and the data collection system was upgraded. The existing Hewlett Packard 75D laptop computer/calculator-based system was time-consuming for processing and storing the data. The data acquisition and storage program was rewritten to utilize a 286-based personal computer. This allowed the creation of MS-DOS ASCII files that could be easily processed by the data reduction program.

The instrumentation was then verified to ensure its accuracy. We checked the Watt-hour meter with a voltmeter and a true root-mean-square ammeter using the power factor curve supplied by the motor manufacturer. The pressure transducers were calibrated at the beginning of testing and as required during testing.

For final verification, the Dunham-Bush vertical screw compressor was started and system performance tests were run. The results were compared to data from previous CFC-502 tests obtained under a previous contract (2). Several sensors were found to be defective and were replaced. The measured subcooling load was low. However, after the instrumentation was checked, this was attributed to a problem with the vapor injection port of the compressor. The instruments that were used to determine the load were calibrated. The brine thermistors were calibrated to room temperature and to each other. The brine flow meter was re-calibrated at three different brine temperatures to establish the effect of brine temperature variation. The suction line orifice plate (refrigerant) flow meter was continuously checked against the brine flow meter through an energy balance of the evaporator heat transfer.

During the CFC-502 testing, a coriolis-effect mass flow meter was added to the liquid line of the system. This type of flow meter was a candidate for the Glens Falls demonstration site and was installed in the laboratory rack to verify its operation. Prior to installation, the flow meter was calibrated using water. After installation, the meter was checked against the suction and discharge orifice plates of the rack. The advantage of these flow meters is that they measure mass and not volume flow. Hence, they are insensitive to the density and viscosity of the fluid and can be calibrated using water. Volumetric-type flow meters have to be calibrated using a fluid with the same density and viscosity as the refrigerant. This is impractical, especially because the refrigerant properties vary with operating conditions.

Compressor Optimization

Initial tests of the compressor with CFC-502 indicated a 16% lower than published capacity at -20°F SST and 110°F SDT. We were unable to determine the EER, since the Watt-hour meter was not yet functioning. After consulting with Howden concerning the compressor performance, they decided to provide a second compressor.

The second compressor performed considerably better, but was still 7% low on capacity. The EER was also 13% low. As a result, Howden replaced it with a third, modified compressor. This compressor was slightly low on capacity but was on the mark for the EER.

The improvements incorporated into the third Howden compressor are listed below:

- Reduced rotor-to-bore clearance due to electroplating of the bore with nickel.
- Reduced rotor to end plate clearance.
- Opening of the suction and discharge ports, which reduced the pressure drop across these ports.
- Closing of the liquid injection slot and the discharge bleed groove, which reduced leakage.

The laboratory compressor performance is plotted against the compressor published curves in Figures 2-4 and 2-5. A combined motor and drive efficiency of 90% was used for these curves. The arrows indicate the discrepancy between the measured performance and the published data. The laboratory compressor has an understandably lower economized capacity than the published values since a shell and tube economizer is used in the test rack while the Howden published curves are based on the use of a flash receiver. A shell and tube heat exchanger is only 70 to 80% effective whereas a flash receiver operates at close to 100% effectiveness.

System Optimization

Once we were satisfied that the compressor was performing properly, a series of tests to map the compressor's performance were initiated. The tests were patterned after the conditions observed for the low-temp rack at the Clifton Park demonstration site.

Constant Load. A constant load was selected for laboratory testing. The CFC-502 demonstration results at the Clifton Park site had indicated a relatively constant load throughout the year on the low-temp system (1). Figure 2-6 shows that the average weekly load varied between 90 and 110 MBH throughout the test period. Thus, when we began these tests, we felt that a constant laboratory refrigeration load would accurately simulate the average daily load of a supermarket.

Variable-Speed Control. While there is some energy penalty associated with the use of VFDs, field tests have shown that compressors equipped with VFDs achieve higher annual EERs (1). Therefore, a VFD was selected for capacity control. The maximum speed of the drive was set at 68 Hz, and the minimum 30 Hz.

Figure 2-5. - CFC-502 Refrigeration Efficiencies of the Last Two Howden Compressors Compared to Manufacturer Data

Figure 2-4. - CFC-502 Refrigeration Capacities of the Three Howden Compressors Compared to Manufacturer Data

ASPEN SYSTEMS CFC-502 DEMONSTRATION RESULTS

Figure 2-6. - History of the CFC-502 Weekly Refrigeration Load for the Low-Temp Rack of the Clifton Park Store

To determine the inverter efficiency, we ran the system at 60 Hz on the inverter and then bypassed the inverter and ran the system directly off the line voltage. For this test, the load was constant at 92 MBH and the SST was -19.0°F. The SDT varied from 98.5°F to 100°F. After accounting for the slight difference in pressure ratio, the loss associated with the inverter was measured at 3%. The inverter manufacturer's rated efficiency at 60 Hz is 98%. The additional 1% loss is within the accuracy of the measurement. It could also be attributed to the reduction in motor efficiency caused by the distorted waveform produced by the inverter.

At fixed suction and head pressures, as the refrigeration load decreases, the drive responds by reducing the compressor speed. The slower speed is accompanied by a reduction in compressor and drive efficiencies that combine to reduce the measured EER. The effect of compressor speed on system capacity and EER was tested with CFC-502 at -20°F SST and 110°F SDT. At approximately 2600 RPM, the economized capacity of the compressor is reduced by half from 109 MBH to 55 MBH, and the EER is reduced from 3.65 to 2.79 Btu/W-hr (Figure 2-7). A significant penalty in EER is incurred at lower speeds. This suggests that a screw compressor should be run at high rpms whenever possible to maximize its efficiency for a given load. When several screw compressors are run in parallel, only one compressor should be slowed

down by a VFD. The other compressors should be run at full speed and cycled on and off as required. This will allow all but the variable-speed screw to run at maximum efficiency.

Economizer Superheat Optimization. Screw compressors have an auxiliary suction connection (economizer port) which allows the introduction of refrigerant vapor into the compressor at a higher pressure than suction pressure. When used with a subcooler, this port can be used to subcool the liquid that is fed to the evaporators and thus improve compressor efficiency. This method of system performance improvement is most effective at high pressure ratios. At lower pressure ratios, using the economizer port can actually decrease system performance. This effect was examined for CFC-502 and HFC-134a.

The initial test results obtained with CFC-502 were disappointing. The laboratory EER was lower than the EER measured at the Clifton Park demonstration site. However, by examining the effect of the economizer superheat on system EER, we were able to reverse the situation. In the first test, conducted at 56°F SDT (Figure 2-8a), the economizer superheat was changed from a low value of 2.5°F to a maximum value of 12°F. The EER was highest at the maximum economizer superheat, suggesting that the thermal expansion valve should be set at the highest superheat setting. In the second test, conducted at the higher SDT of 110°F (Figure 2-8b), the economizer superheat ranged from 1 to 18°F. The EER improves with an increase in economizer superheat up to a superheat of 10°F. From 10°F to 18°F superheat, the EER was relatively insensitive to economizer superheat. Thus, using the higher economizer superheats, the laboratory performance was improved substantially.

Similar tests were run for HFC-134a at 20°F SST. As shown in Figure 2-9, the economizer superheat had little effect on performance from 3°F to 11°F. Over 11°F there was a slight drop in EER; and below 3°F, the EER dropped rapidly. Capacity also suffered below 3°F.

At very low economizer superheats, the flow could contain liquid droplets. This would decrease the amount of subcooling available and increase the power consumption of the compressor.

ASPEN SYSTEMS LABORATORY RESULTS

(a)

ASPEN SYSTEMS LABORATORY RESULTS

(b)

Figure 2-7. - Effect of Refrigeration Load and Compressor Speed on EER

ASPEN SYSTEMS LABORATORY RESULTS

(a)

ASPEN SYSTEMS LABORATORY RESULTS

(b)

Figure 2-8. - Effect of Economizer Superheat on CFC-502 Performance

ASPEN SYSTEMS LABORATORY RESULTS

Figure 2-9. - Effect of Economizer Superheat on HFC-134a Performance

Subcooler Orientation. The subcooler used for the economizer circuit is a shell and tube heat exchanger piped in a counter-flow configuration. The typical orientations for the installation of this heat exchanger are: a) horizontal; and b) vertical, with the vaporized refrigerant flowing upward. Our laboratory rack used the former installation, while the racks at the demonstration sites used the latter.

Theoretically, a vertical orientation will increase the effectiveness of the subcooler, since the liquid droplets will have a longer time to evaporate. Oil return is the only potential problem with this configuration. We decided to change the orientation of the laboratory subcooler from horizontal to vertical and determine the actual improvement of one configuration over the other.

First, the compressor performance with the horizontal subcooler was determined. At 110°F SDT and -20°F SST, the economized capacity was 103 MBH, with an EER of 3.67. The subcooler was then repiped in a vertical position. The new configuration had a significant impact on system capacity. At 110°F SDT, the capacity increased to 109 MBH with a slight increase in EER. For a fixed superheat setting, the economizer flow increased 40% and the mechanical subcooling increased from 41.0 to 64.3°F. No abnormal oil return problems were noted.

Condenser Control. In order to obtain high SDTs even during cold ambient conditions, a VFD was installed on the condenser fans. The alternative approach of raising the head pressure using a "holdback" pressure regulator induces artificial ambient subcooling that would not be present in a system that fully floats the head. We connected the condenser variable-speed drive to the RC-1000 controller as if it were another refrigeration rack using a high-pressure sensor as a suction input. In this configuration, the RC-1000 controlled the condenser fan speed as if it were a compressor. This method proved unsatisfactory. The use of a high-pressure transducer on a suction input limited our resolution and the control gain did not provide enough adjustment. The addition of a derivative gain did not alleviate the problem. After discussing the problem with EIL, we concluded that this was not a good application for this controller. A separate PID controller was added which allowed precise control of the condenser drive to achieve the desired discharge pressures.

Leak Detection System. The Spectronics fluorescent leak detection fluid was added to the system before the CFC-502 testing was completed. No discernible effect on the system performance was noted. The only noticeable change was the oil color. After several days, two leaks were found with the UV light. After a few months of operation, when the system was down for service, the laboratory lights were turned off and several smaller leaks were found and corrected.

The leak detection fluid was purged from the system when the oil was changed during HCFC-22 operation. During the HFC-134a tests, a leak detection fluid designed to work with the refrigerant and the POE oil was installed. Again, we found no discernible effect on system performance.

Display Case. The display case, which was part of the original test rack, was instrumented to determine the effect of different refrigerants on the heat transfer in a display case coil. Two electric heaters were installed to simulate the refrigeration load. The test results were inconclusive. The discrepancy in the energy balance between the air flow, the refrigerant flow, and the electric heater power was too great to ensure reliable data.

TEST RESULTS

The four refrigerants that we tested were CFC-502, HCFC-22, HFC-134a, and CFC-12. CFC-502 and CFC-12 provided the baseline for comparison to the two alternative refrigerants.

Each refrigerant was tested at a low-temp condition (-20°F SST) and a med-temp condition (+20°F SST). We strove to test each condition with the appropriate compressor volume ratios, but time did not permit the testing of all combinations. HCFC-22 was tested with a Vi optimized for low-temp (3.6), and CFC-12 was tested with a Vi optimized for med-temp (2.6). Tests for HCFC-22 at +20°F and CFC-12 at -20°F SST were not performed with the optimum Vi. The tests with CFC-502 and HFC-134a were performed with both sets of Vi's.

CFC-502 Performance

The energy efficiency data for CFC-502 (with the economizer on) for the 3.6-Vi compressor are shown plotted against SDT in Figure 2-10. Figure 2-11 shows the second-order curve fits of the above data. The curve fits are used for comparison to the other refrigerants. Figure 2-11 also shows the curve fit for the data with the 2.6-Vi compressor.

In Figure 2-12, the -20°F SST data is compared to our Clifton Park field demonstration data (1). The laboratory data show improved EER performance. This is attributed to the steady-state nature of our laboratory testing and the improved tolerances of our MK3 laboratory compressor.

Test results with the economizer off at -20°F SST show that the subcooling circuit increases the performance over the entire operating range (Figure 2-13).

HCFC-22 Performance

With the completion of the CFC-502 testing, we recovered the refrigerant and drained the oil from the compressor. The power heads and other internal parts of the thermal expansion valves were changed. The system was evacuated, a 68-cSt (300 SUS) mineral oil was added to the compressor, and HCFC-22 was installed in the system.

ASPEN SYSTEMS LABORATORY RESULTS

Figure 2-10. - CFC 502 Performance - Raw Data

ASPEN SYSTEMS LABORATORY RESULTS

Figure 2-11. - CFC-502 Performance

Figure 2-12. - Comparison of Laboratory and Field Results

Figure 2-13. - CFC-502 Economizer Performance

As expected, the compressor discharge temperature was much higher with HCFC-22 than with CFC-502. After conferring with Howden and the lubricant manufacturer, the setpoint of the oil temperature safety switch was increased from 140°F (used for CFC-502) to 180°F. Compared to CFC-502, the system was considerably less stable. This confirms results obtained from the HCFC-22 conversion in the Clifton Park demonstration test (see Section 3). The TXV selection was verified to ensure that the correct valve sizes were used. In an attempt to improve system stability, the bulbs of the TXVs were clamped in several different positions around the circumference of the evaporator discharge tubing. A minor increase in stability was noted.

The system was further stabilized by optimizing the control and derivative gains on the RC-1000 controller. Higher gain settings provided more stable suction pressures at the expense of wider swings in compressor speed. Values between 40 and 100 have proven to be a good compromise between compressor cycling and suction pressure variations.

The underlying cause for cycling is the reduced refrigerant mass flow. For a given compressor capacity, at -20°F SST, HCFC-22 mass flow will be only 73% of that with CFC-502. In our tests, the evaporator flow rate was further reduced by a 15% reduction in the capacity of the screw compressor with HCFC-22. Thus, the resulting mass flow for HCFC-22 in our lab tests was only 62% of that for CFC-502. The lower flow rates reduce the ability of the flow to entrain both the oil and liquid refrigerant in the evaporator. The liquid and gas tend to separate and cause unstable flows in the tubes of the evaporator (3, 4). This leads to intermittent cycling in suction superheat and results in TXV hunting (5).

Contrary to our expectations, the low-temp system performance with HCFC-22 was inferior to that with CFC-502. Figure 2-14 shows that the EER of HCFC-22 is consistently lower than that of CFC-502 at -20°F SST. The economized capacity of the compressor decreased from 109 MBH to 91 MBH. At 20°F SST, the EER of the two refrigerants is essentially identical. The economized capacity of the compressor decreased from 253 MBH to 242 MBH at 20°F SST.

ASPEN SYSTEMS LABORATORY RESULTS

Figure 2-14. - Comparison of HCFC-22 and CFC-502 Performance with 68 cSt Mineral Oil

The apparent cause of the capacity reduction was a decrease in the refrigerant flow pumped by the compressor. Compared to Howden's published data, the CFC-502 volumetric efficiency (VE) was within 2%, but the HCFC-22 VE was about 20% lower. We ran several tests to determine the cause of this discrepancy.

The first test consisted of running the system at a high SST to increase the evaporator flow rate and flush out any oil and liquid that may have accumulated in the barrels at lower flows. We ran the system at +20°F SST for an entire 24-hour period. The system capacity increased slightly and the flow rate increased accordingly. The HCFC-22 volumetric efficiency under these conditions was about 12% lower than the published data. Hence, we obtained some improvement but not enough to explain the discrepancy.

We ran a test where we increased the evaporator superheat from 10 to 60°F. This test indicated that the low HCFC-22 capacity was not due to the presence of liquid droplets in the suction. As we increased the superheat, the mass flow dropped in proportion to the reduced suction gas density.

At the suggestion of Howden, we ran a test to determine the effect of the oil injection rate on capacity and power. The oil flow was reduced using a ball valve at the inlet of the oil filter. The approximate flow rate reduction was determined by the change in the oil temperature difference across the oil cooler. Reducing the oil flow from full flow to 60% of full flow did not affect the capacity. The power, however, dropped 3%. This clearly indicates that the capacity problem was not due to excessive oil flow. But it also shows that, with HCFC-22, the EER can be improved by reducing the amount of oil injected into the compressor.

The appropriateness of the selected internal Vi was also reviewed. Howden performance charts indicated that a Vi of 5.0 was desirable for -20°F SST/110°F SDT operation with HCFC-22. Though the Vi has a significant effect on power and EER, it does not drastically affect capacity. It was decided that the effect of the Vi could not cause the discrepancies observed in compressor capacity.

At the recommendation of the compressor manufacturer, we changed the lubricant from a 68-cSt mineral oil to a higher viscosity (100 cSt, 460 SUS) polyol ester (POE) oil manufactured by CPI. This test was to indicate if the low VE was due to the dilution of the mineral oil by HCFC-22. The compressor and oil reservoir were drained and refilled with the new lubricant four times. The system was run from 4 to 18 hours between oil changes. Oil test samples taken after the fourth change indicated that 10% of the old 68-cSt oil was still present. The reported viscosity was approximately 400 SUS (which CPI still considers as 100-cSt oil). Contrary to our expectations, testing with this oil indicated a decrease in the compressor capacity of 4%. The decrease in capacity is attributed to the increased solubility of HCFC-22 in POE oils compared to mineral oils.

After reviewing recent literature on screw compressor performance (6), a 260-cSt POE oil was selected for testing. Since the POE oil is diluted more than the mineral oil, a much higher viscosity is required for sealing between the lobes of the screws. The 260-cSt oil selected was formulated to provide the same viscosity as the oil designated as a 320 ISO fluid in Reference 6.

The viscosity of the oil in the compressor under operating conditions is one of the parameters that determines the sealing performance of the oil. When the oil is diluted with HCFC-22, its viscosity drops. The theoretical dilution levels and diluted

oil viscosities for each oil at 180°F are shown in Table 2-3. The theoretical viscosities of the 68-cSt and the 100-cSt oils are both lower than the desired 10-cSt that is considered ideal for sealing the rotors. The 260-cSt oil has sufficient viscosity to seal well.

The oil in the system was changed to 260-cSt POE oil. After four purges, the oil sample tests indicated an actual viscosity of 245-cSt.

The performance of the rack with the 260-cSt oil exhibited a marked improvement over that with either the 100-cSt POE oil and the 68-cSt mineral oil. At -20°F SST and 110°F SDT, the compressor economized capacity increased from 91 MBH to 101 MBH. This represents a 10.5% increase compared to the 68-cSt oil. As shown in Figure 2-15, the EER did not increase as much, since the increase in capacity was accompanied by an increase in power consumption. At 20°F SST, the economized capacity increased from 242 MBH to 252 MBH. The discharge temperature of the compressor was also higher, requiring the setpoint of the oil temperature switch to be raised from 180°F to 190°F.

Oil flow reduction experiments were repeated with the 260-cSt oil at -20°F and 20°F SST. The oil flow rate was reduced to approximately 60% of the original oil flow. As shown in Figure 2-16, at 20°F SST, the EER was improved for the range of SDTs tested with no change in compressor capacity. At -20°F SST, the EER was improved at the lower SDTs but was unchanged at the higher SDTs.

Tests with the 68-cSt oil at 20°F SST indicated similar performance with and without the economizer (Figure 2-17). Tests with the 260-cSt oil showed similar results. At -20°F SST with the 68-cSt oil, the economizer improved the system EER above 40°F SDT (Figure 2-18). The chronology of the test schedules did not permit us to run the 260-cSt oil at -20°F SST.

**Table 2-3. - Theoretical Viscosity of Refrigeration Oils
When Diluted With HCFC-22**

	Dilution	Viscosity
	%	cSt
MINERAL 68	15	4
POE 100	28	5.5
POE 260	25	13

Figure 2-15. - Comparison of Performance with 68 cSt Mineral Oil and 260-cSt POE OIL

Figure 2-16. - Comparison of Performance with Full Oil Flow and Reduced Oil Flow

Figure 2-17. - Economizer Performance at +20°F

Figure 2-18. - Economizer Performance at -20°F

HFC-134A Performance

At the completion of the HCFC-22 tests, the 260-cSt POE oil was purged from the system and replaced with CPI Engineering's Solest 68, a 68-cSt POE oil designed for use with HFC-134a. The HCFC-22 was recovered. The expansion valves were converted to CFC-12 heads and internal parts. Sporlan Value Co. and Alco Controls Co. both recommended this conversion for HFC-134a operation. The system was evacuated and HFC-134a was installed.

We did not observe any instability problems with HFC-134a under any operating conditions. Our initial tests were done with the MK3 3.6-Vi compressor. At +20°F SST (110°F SDT) the economized capacity was 172 MBH, and at -20°F SST it was 59 MBH. Figure 2-19 shows the energy-efficiency performance of the compressor with HFC-134a. The -20°F SST tests were performed only for academic reasons. It is impractical to run HFC-134a at -20°F SST in a supermarket due to its sub-atmospheric suction pressure, its high-pressure ratio, and its loss of capacity compared to CFC-12.

The MK3 compressor was replaced with the MK4 compressor with a Vi of 2.6. The new compressor provided better capacity and performance due its tight tolerances and lower loss in its suction and discharge ports. Our tests with HFC-134a on the MK4 indicated a 3.7% decrease in EER and a 5.8% increase in capacity over the MK3 at +20°F SST, 110°F SDT. Figure 2-19 also shows the performance of the MK4 compressor. At +20°F SST (Figure 2-20), the economizer improved the system performance for SDTs above 87°F.

CFC-12 Performance

To determine the performance of the screw compressor with CFC-12, the HFC-134a refrigerant and the Solest 68 POE oil were replaced with CFC-12 and a 68-cSt mineral oil provided by CPI Engineering. All testing with CFC-12 was on the 2.6-Vi compressor.

We did not observe any instability problems with CFC-12 under any operating conditions. At +20°F SST (110°F SDT) the economized capacity was 176 MBH and at -20°F SST it was 70 MBH. Figure 2-21 shows the energy efficiency-performance of the compressor with CFC-12.

Figure 2-19. - HFC-134a System Performance

Figure 2-20. - HFC-134a Economizer Performance

ASPEN SYSTEMS LABORATORY RESULTS

Figure 2-21. - CFC-12 System Performance

Performance Comparison of the Refrigerants

The refrigeration capacities of the screw compressor for the different refrigerants are compared in Table 2-4. The 2.6-Vi MK4 results are listed for the +20 °F SST and the 3.6 Vi MK3 results for the -20°F SST. For comparison, HCFC-22 capacity at +20°F was adjusted by the ratio of the MK4 to MK3 capacities measured with CFC-502. In addition, the CFC-12 capacity at -20°F was reduced by the ratio of MK4 to MK3 results for HFC-134a.

Table 2-4. - Economized Refrigeration Capacity of the Howden Compressor for Different Refrigerants (4000 rpm)

REFRIGERANT	-20°F SST			+20°F SST		
	CAPACITY (MBH)	RELATIVE TO CFC-502 (%)		CAPACITY (MBH)	RELATIVE TO CFC-12 (%)	
		ACTUAL	THEORETICAL		ACTUAL	THEORETICAL
CFC-502	109	100	100	268	100	100
CFC-12	70	64	56	176	66	0.59
HCFC-22	101	93	91	267	100	0.95
HFC-134a	59	54	52	182	68	0.60

For the theoretical calculations in Table 2-4, a constant compressor displacement and a 110°F SDT were assumed. The -20°F SST calculations were based on 25°F of superheat and 70°F of subcooling. The +20°F SST calculations were based on 25°F of superheat and 40°F of subcooling.

The HCFC-22 capacity compared to that of CFC-502 is 7% lower at -20°F SST. At +20°F SST, the two capacities are essentially identical. Thermodynamic cycle calculations predict lower capacities for HCFC-22 at both suction temperatures. At both SSTs, HCFC-22 had lower liquid temperatures than expected.

The HFC-134a capacity compared to that of CFC-502 is 54% at -20°F SST, and 68% at 20°F SST. Thermodynamic cycle calculations indicate reductions to 52% and 60% for the two cases, respectively. Higher compressor volumetric efficiency appears to be the reason for the higher than expected capacities. HFC-134a had a 3% higher capacity than CFC-12 at +20°F SST. Hence, at +20°F SST, the actual HFC-134a capacity exceeded our expectations.

The measured capacities shown in Table 2-4 are normalized to the displacement of the test compressor in the bar chart of Figure 2-22. CFC-502 and HCFC-22 require similar compressor displacements at +20°F SST. The cfm requirements for the two low pressure refrigerants, CFC-12 and HFC-134a are also similar at +20°F SST. At -20°F SST, HCFC-22 requires 20% more displacement for a specific load than CFC-502, and 31% less than CFC-12.

Figure 2-23 shows the comparison of the compressor's EER with the four refrigerants. The curves represent the results obtained at +20°F SST condition with the 2.6-Vi compressor. Since we had not obtained actual data with HCFC-22 for a 2.6-Vi, the HCFC-22 data obtained with the 3.6-Vi compressor were corrected using an adjustment factor calculated from the CFC-502 data. The curves show similar performance for HFC-134a, HCFC-22, and CFC-12. These refrigerant all enjoy a distinct efficiency advantage over CFC-502 at +20°F SST.

It is important to note the effect the Vi selection has on the relative performance of the refrigerants. Figure 2-24 shows the performance of the 3.6-Vi compressor with CFC-502, HCFC-22, and HFC-134a. Both HCFC-22 and CFC-502 are more severely penalized by the high volume ratio.

Figure 2-22. - Normalized Refrigeration Capacities for Different Refrigerants

Figure 2-23. - Comparison of Refrigerant Performance at +20°F with 2.6-VI Compressor

Figure 2-24. - Comparison of Refrigerant Performance at +20°F with 3.6-Vi Compressor

The economized performance for all three refrigerants is summarized in Table 2-5. This table lists the operating conditions under which the economizer should be in operation. Outside these operating conditions, the system performance can be improved by disabling the economizer.

At -20°F SST, the energy efficiency performance of the system is similar for CFC-502, HFC-134a, and HCFC-22 (Figure 2-25). Only at high SDTs (above 100°F) does the EER of HFC-134a fall perceptively below that of CFC-502 and HCFC-22. This is a result of the exceptionally high-pressure ratio (11.4@-20°F SST/110°F SDT) and the low Vi of this compressor.

Table 2-5. - SDT Conditions Where the Economizer Improves the Efficiency of the Screw Compressor

REFRIGERANT	-20°F SST	20°F SST
CFC-502	All SDTs	Not Tested
HCFC-22	SDT > 40°F	SDT > 85°F
CFC-12	Not Tested	All SDTs
HFC-134a	Not Tested	SDT > 87°F

**Figure 2-25. - Comparison of Refrigerant Performance at -20°F
with the 3.6 Vi Compressor**

OIL MANAGEMENT

Screw compressors inherently require a large flow of oil to operate properly. The oil is injected at several points inside the compressor for bearing lubrication and sealing between the lobes of the screw. Nearly all the oil injected into the compressor is carried over with the discharge refrigerant flow.

To minimize the amount of oil carryover, the Howden compressor is fitted with an internal oil separator. This two-element separator was designed to keep most of the oil inside the compressor. The resulting oil carryover should be sufficiently low that a standard external oil separator regularly used for reciprocating compressors racks could be used.

We measured the amount of oil removed by the external separator to determine how well the internal separator was performing. The measurements are listed in Tables 2-6 through 2-10 and plotted in Figures 2-26 and 2-27. For HCFC-22, the oil carryover was measured for both the 68-cSt mineral oil and the 260-cSt polyol ester oil (Tables 2-7 and 2-8).

**Table 2-6. - Summary of 68 cSt Mineral Oil Carryover Tests
for CFC-502**

SDT	SST	Load	Total Flow	Speed	Oil Carryover Rate			
°F	°F	MBH	lb/hr	rpm	ml/min	gal/hr	lb/hr	ppm
85	-20	115	2,500	n/a	156.7	2.48	18.9	7,544
66	-20	116	2,200	n/a	250.4	3.97	30.1	13,696
66	-20	116	2,300	n/a	313	4.96	37.7	16,377
40-54	-20	128	2,300	n/a	134.3	2.13	16.2	7,024
50.5	-20	109	2,001	2,567	97.9	1.55	11.8	5,890
72	-20	109	2,275	3,004	212.2	3.36	25.5	11,224
110	-20	109	2,900	4,000	255.8	4.05	30.8	10,614
100	-20	109	2,800	3,761	195.7	3.1	23.5	8,410
75	-20	109	2,300	2,985	195.6	3.1	23.5	10,235
57	-20	112	2,200	2,985	171.2	2.71	20.6	9,362
100	-20	109	2,800	3,940	172.7	2.74	20.8	7,421
61	-20	109	2,300	3,224	91.8	1.46	11	4,804
110	20	254	6,100	4,000	195.4	3.1	23.5	3,855
92	20	254	5,300	3,582	189.1	3	22.8	4,293
48	-20	106	2,000	2,805	229.4	3.64	27.6	13,804
53	-20	108	2,100	2,746	280.9	4.45	33.8	16,094

**Table 2-7. - Summary of 68 cSt Mineral Oil Carryover Tests
for HCFC-22**

SDT	SST	Load	Total Flow	Speed	Oil Carryover Rate			
°F	°F	MBH	lb/hr	rpm	ml/min	gal/hr	lb/hr	ppm
60	-20	94	1230	3000	31	0.49	3.69	2999
83	-20	96	1430	3500	132	2.09	15.9	11,122
55	-20	92	1220	2900	64	1.01	7.65	6267
65	-20	90	1150	3300	51	0.81	6.17	5365
75	-20	91	1160	3500	56	0.88	6.67	5753
90	-20	91	1300	3900	51	0.81	6.12	4711
87	20	239	3375	3500	477	7.56	57.43	17,016
87	20	239	3375	3500	478	7.57	57.49	17034
110	20	244	3830	3900	875	13.87	105.28	27488
110	20	244	3830	3900	1058	16.76	127.21	33215
85	20	245	3400	3500	473	7.50	56.93	16744
80	20	239	3411	3600	404	6.40	48.57	14239
80	20	239	3411	3600	380	6.03	45.75	13414
92	20	240	3260	3900	473	7.49	56.90	17454
92	20	240	3260	3900	435	6.89	52.35	16057

**Table 2-8. - Summary of 260 cSt POE Oil Carryover Tests
for HCFC-22**

SDT	SST	Load	Total Flow	Speed	Oil Carryover Rate			
°F	°F	MBH	lb/hr	rpm	ml/min	gal/hr	lb/hr	ppm
103	20	248	3700	3000	895.55	14.19	107.77	29127
102	20	248	3600	3500	943.61	14.96	113.55	31542
109	20	248	3700	2900	638.19	10.12	76.80	20756
97	20	248	3600	3300	756.49	11.99	91.03	25287
96	20	248	3700	3500	729.19	11.56	87.75	23716
96	20	248	3600	3,900	840.61	13.32	101.16	28099

The oil carryover rate showed a strong dependency on the total mass flow rate through the compressor. For flow rates below 3000 lb/hr we found oil carryover into the external separator in the 1- to 5-gal/hr range for all refrigerants. At higher flow rates, a standard oil separator was inadequate for oil separation. Visual inspection of the flow from the separator indicated excessive oil flow into the system. With CFC-502, the measured carryover rates were erratic and seemed low. We therefore replaced the oil separator with a new, centrifugal separator which was designed for use with screw compressors. The tests with the other refrigerants

**Table 2-9. - Summary of 68 cSt POE Oil Carryover Tests
for HFC-134a**

SDT	SST	Load	Total Flow	Speed	Oil Carryover Rate			
°F	°F	MBH	lb/hr	rpm	ml/min	gal/hr	lb/hr	ppm
110	20	156	2,500	3,500	95.33	3.61	11.47	4,589
110	20	156	2,500	3,600	125.49	3.41	15.1	6,040
97	20	144	2,250	2,250	93.22	1.48	11.22	4,986
103	20	144	2,300	2,300	102.61	1.63	12.35	5,369
109	20	144	2,360	2,360	87.48	1.39	10.53	4,461
110	20	173	2,800	2,800	161.83	2.56	19.47	6,955
97	20	173	2,600	2,600	242.78	3.85	29.22	11,237
110	40	264	3,800	3,970	491.72	7.79	59.17	15,572
110	40	264	3,800	3,970	472.82	7.49	56.9	14,973
107	40	264	3,900	3,970	525.43	8.33	63.23	16,213
107	40	264	4,000	3,970	361.2	5.73	43.47	10,867

**Table 2-10. - Summary of 68 cSt POE Oil Carryover Tests
for CFC-12**

SDT	SST	Load	Total Flow	Speed	Oil Carryover Rate			
°F	°F	MBH	lb/hr	rpm	ml/min	gal/hr	lb/hr	ppm
110	-18.5	5.6	1,515	3,970	15.57	0.25	1.87	1,237
110	20	14.7	3,500	3,970	110.43	1.75	13.29	3,797
110	20	14.7	3,500	3,970	132.62	2.1	15.96	4,560
110	33	19	4,400	3,975	632.1	10.01	76.07	17,288
110	33	19	4,400	3,975	585.59	9.27	70.47	16,016
110	33	19	4,400	3,975	568.04	9	68.36	15,536
95	32	19	4,000	3,800	490.57	7.77	59.03	14,758
95	32	19	4,000	3,800	531.16	8.41	63.92	15,980
95	32	19	4,000	3,800	490.57	7.77	59.03	14,758
95	32	19	4,000	3,800	558.22	8.84	67.18	16,794
91	20	14.7	3,200	3,800	216.67	3.43	26.07	8,148
91	20	14.7	3,200	3,800	218.41	3.46	26.28	8,214
91	20	14.7	3,200	3,800	210.83	3.34	25.37	7,929
91	20	14.7	3,200	3,800	208.52	3.3	25.09	7,842
80	20	14.4	3,000	3,400	136.65	2.16	16.44	5,481
80	20	14.4	3,000	3,400	137.86	2.18	16.59	5,530
80	20	14.4	3,000	3,400	143.46	2.27	17.26	5,754
80	20	14.4	3,000	3,400	104.42	1.65	12.57	4,188
80	33	17.5	3,300	3,200	260	4.12	31.29	9,481
80	33	17.5	3,300	3,200	231.6	3.67	27.87	8,446
80	33	17.5	3,300	3,200	358.13	5.67	43.1	13,060
80	33	17.5	3,300	3,200	390.75	6.19	47.02	14,249
68	20	14.4	2,700	2,900	118.72	1.88	14.29	5,291
68	20	14.4	2,700	2,900	144.55	2.29	17.39	6,443
68	20	14.4	2,700	2,900	251.45	3.98	30.26	11,207
68	20	14.4	2,700	2,900	223.13	3.53	26.85	9,945
63	20	11.5	2,100	2,750	118.94	1.88	14.31	6,816

indicated better removal of discharge oil with this separator. At high flow rates, the oil carryover was as high as 3% of the total refrigerant flow.

Our test results indicated that the old separator was marginal at low flow rate conditions. The centrifugal oil separator proved to be adequate for low-temp, low-flow applications, but was marginal for high refrigerant flow applications, even with the integral oil separator. A dual-chamber coalescing oil separator may still be required for these applications.

Figure 2-26. - Oil Carryover for CFC-12

REFRIGERANT CONVERSION ISSUES

Our laboratory experience has shown that several factors influence the effectiveness of a refrigerant changeover. Some of the most important ones are: the types of oil being removed and installed and their relationship to each other, the duration of compressor run time between each oil purge, and the system's oil carryover and oil return characteristics.

Purging oil from the system can be time-consuming and costly. In our first oil change from a 68-cSt mineral oil to a 100-cSt POE, four oil purges were carried out over the course of two days of continuous running. At the end, 10% of the original mineral oil was still present in the system. Since the test results with this level of contamination were adequate, no further flushing with 100-cSt oil was done. Later, we found that increasing the compressors run time (to 200 hours) between each purge can significantly reduce the number of purges required.

The second oil change cycle replaced the 100-cSt POE/68-cSt mineral oil with a 260-cSt oil. Again, the oil was changed four times. Test results indicated approximately 9% contamination of the 260-cSt oil with the previous oil.

Figure 2-27. - Oil Carryover Summary

The final oil change cycle removed the 260-cSt POE oil and replaced it with a 68-cSt POE oil designed for HFC-134a. After the sixth oil change, the compressor was

allowed to run for several hours and an oil sample was taken and analyzed. The results indicated 10% contamination with the old oil. Next, we ran the system for an additional 200 hours and another oil sample was taken. This time, oil analysis indicated a final viscosity of 66-cSt with only 1% of old oil contamination. The additional run time must have allowed better mixing of the oils within the system. A seventh oil change that we had carried out while waiting for the results of the analysis was not required.

We have concluded that two issues are of critical importance during the oil purge process. First, all system refrigerant lines need to be opened to ensure that the old oil can be circulated back to the compressor. Second, extended compressor run time between each oil purge is required to improve the mixing and purging process.

We estimate that to install a new oil with less than 1% final contamination requires four oil purges. With a price of \$40/gallon, the lubricant cost for a large refrigeration system may approach \$2,000 for a changeover.

SUMMARY

- At +20°F SST, the system EER with HFC-134a compared to CFC-502 was significantly better. The EER was comparable for HFC-134a, CFC-12, and HCFC-22.
- As expected, for a fixed compressor displacement, the HFC-134a refrigeration capacity at +20°F SST is 32% lower than that of HCFC-22 or CFC-502. The HFC-134a capacity is 3% greater than that of CFC-12.
- At -20°F SST, when compared to CFC-502, HCFC-22 exhibited 7% lower capacity. The EERs were comparable. HFC-134a capacity was 46% lower than CFC-502 capacity. Its EER was similar to the other two refrigerants below 100°F SDT. Even though at -20°F SST, HFC-134a is as efficient as CFC-502 and HCFC-22 (below 100°F SDT), it is not an ideal replacement refrigerant for low-temp supermarket applications. This is due to its subatmospheric evaporator pressure and its prohibitively high-pressure ratio.
- Under certain operating conditions, the performance of a screw compressor refrigeration system improves by disabling the economizer. These conditions are reflected in Table 2-9.
- Improper volume ratio selection can have a severe negative impact on the EER of a screw compressor.

- Conversions from CFC-502 to HCFC-22 suffer from instability due to the reduction in the mass flow of the fluid. Phase separation in the evaporator causes large fluctuations in evaporator superheat and results in TXV hunting.
- With screw compressors, oil dilution by HCFC-22 must be examined closely to ensure that the oil viscosity is adequate to seal between the lobes of the screws. POE oils are diluted more than mineral oils for a given viscosity. A significant penalty in capacity and EER will result if the viscosity of the oil injected between the rotors is too low.
- Oil carryover from the internal oil separator of the screw compressor was excessive at high refrigerant flow rates. A high-capacity, dual-chamber, coalescing, external oil separator may be required if the system is to operate properly for the full flow range of the compressor.
- When changing oil in anticipation of a switch to an alternative refrigerant such as HFC-134a, a run time between purges of 200 hours appeared to mix the oils more thoroughly and minimized required oil changes. Mixing times on the order of 4 to 8 hours seemed insufficient for a good purge.

CLIFTON PARK CFC-502 TO HCFC-22 RETROFIT

Section 3

IN THIS SECTION

THE DEMONSTRATION SITE SUPERMARKET

CFC-502 TO HCFC-22 CONVERSION

DEMONSTRATION TESTING RESULTS

ADDITIONAL TESTING

RELIABILITY HISTORY

SUMMARY

THE DEMONSTRATION SITE SUPERMARKET

The Clifton Park store was selected for a CFC-502 to HCFC-22 retrofit because we had already obtained extensive CFC-502 data on its low-temp rack. The low-temp (-20°F SST) rack in this store is composed of two independent systems. The first, a semi-hermetic reciprocating compressor rack, is the store's original refrigeration system (the reference rack). The second, an open-drive screw compressor rack, was added for comparison testing of the two types of compressors on CFC-502. At the time, the store had been in operation for less than a year and its existing refrigeration systems were state-of-the-art. The principal attraction of this particular store was its very large compressor room, which offered plenty of empty space for the screw compressor rack. By moving two of the circuits to a different suction group, it was possible to match the store's low-temp (-20°F) refrigeration load to the CFC-502 capacity of the compressor. Both systems were in place at the time of the HCFC-22 retrofit. The Clifton Park store is located about 20 miles north of Albany, NY, and has a floor area of 62,000 sq. ft.

It was decided to use a variable-frequency inverter to control the capacity of the screw compressor. This also afforded us the opportunity to test the reciprocating compressors using a variable-frequency drive. As a result, we conducted a three-way test between:

1. The screw compressor with variable-speed capacity control (designated in this report as SCR).
2. The reciprocating compressors with unloader capacity control (UNL).

3. The reciprocating compressors with variable-speed (inverter) capacity control (INV).

The following section describes the Clifton Park store and its existing low-temp refrigeration systems prior to the conversion of its -20°F rack to HCFC-22. A complete description of the results of testing with CFC-502 can be found in Reference 1.

Supermarket's Refrigeration Schedule

The -20°F low-temp refrigeration load of the test supermarket was 149.2 MBH. This load consists of the six circuits listed in Table 3-1.

Reciprocating Compressor Rack

The -20°F reference system in the Clifton Park store consisted of two Carlyle semi-hermetic compressors. These were mounted on a skid that also housed two -25°F and two +15°F compressors. The six compressors shared an oil separator, condenser, receiver, oil reservoir, and heat reclaim coil. The system was originally designed to run at -15°F, but the store conditions required that it be run at -20°F. Figure 3-1 shows the entire skid with all six compressors. The -20°F compressors are the two on the far left. Figure 3-2 shows a close-up view of the -20°F portion of the reference rack. This section is dedicated to the description of the various components of this rack.

Reciprocating Compressors. The Carlyle compressors shown in Figure 3-2, are two identical Model 06ER165 high-efficiency units equipped with suction cutoff unloaders. Each compressor could be unloaded in two steps, reducing the capacity 33 and 66%, respectively. The compressors were equipped with six cylinders and each step

**Table 3-1. - Low-Temp (-20°F) Refrigeration Schedule
of the Clifton Park Store**

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP (°F)	LOAD (MBH)
A8	Service Meat	24 ft	-20	7.6
A9	Frozen Food Glass Door	13 DRS	-20	23.7
A10	Frozen Food Glass Door	17 DRS	-20	30.9
A11	Ice Maker	1 UNIT	-20	30.5
A12	Frozen Food Glass Door	13 DRS	-20	23.7
A13	Frozen Food Glass Door	18 DRS	-20	32.8
	Total			149.2

Figure 3-1. - The Rack Housing All Six Compressors

Figure 3-2. - The Two Carlyle Compressors Serving the -20°F Refrigeration Load

unloaded two cylinders. The corresponding reduction in power consumption for each step was 28 and 56%, respectively. The nominal rating of each compressor was 20 hp. Their rated CFC-502 refrigeration capacity at -20°F SST and 110°F SDT was 80 MBH each. This resulted in a total capacity of 160 MBH, which is a safe match for a 149 MBH refrigeration load. With the unloaders, the rack provided six steps of capacity control.

Controller. The rack used an EIL RC-48 compressor control system. This unit was specifically designed for parallel compressor supermarket refrigeration application. The RC-48 was not, however, equipped to control a variable-frequency inverter. Hence, we added an EIL RC-1000 controller to control the rack when the variable-speed capacity control was in use. Originally, the RC-1000 used a PI (proportional-integral) algorithm to control the VFD. Later, this was changed to a PID (proportional-integral-derivative) algorithm. This controller was used when the SCR and INV systems were in operation. Figure 3-3 shows the RC-1000 in the center, the inverter on the right, and the switch gear in the bottom left. The manual switches were used to select one of the three operation modes of the rack (INV, UNL, or SCR). An EIL TDC-64 were used for temperature and defrost control. On this rack, no evaporator pressure regulators were used. Instead, the TDC-64 controlled suction line solenoid valves in order to maintain the desired case, cooler, or freezer temperatures.

Screw Compressor Rack

The screw compressor rack was installed in the Clifton Park store during a previous CFC-502 demonstration project sponsored by NYSERDA (1). The rack, shown in Figure 3-4, was designed by Aspen Systems and manufactured on-site by Eastern Heating and Cooling. It was 58 in. long and 24 in. wide. It housed one screw compressor, a motor, a subcooler, an oil cooler, and an electrical control panel.

Screw Compressor. As portrayed in Figure 3-4, the screw compressor sits on the left side of the rack. It is a 91-mm "Hummingbird" compressor manufactured by Howden Compressors identical to the one used in our laboratory (described in Section 2).

Variable Frequency Drive. A variable-torque inverter manufactured by Toshiba is used to control the speed of the compressors. The inverter was originally oversized by 25% to accommodate the constant-torque nature of the positive displacement compressor. The specifications of the inverter are as follows:

Figure 3-3. - The EIL RC-1000 Controller, the Toshiba Inverter, and the Switch Gear for the Low-Temp Rack

Figure 3-4. - The Clifton Park Screw Compressor Rack

Model No. TOSVERT-130H

Nominal Rating 50 hp

Type Sinusoidal PWM

Max. Efficiency 95%

Other Screw Compressor Rack Components. The other components of the rack, such as the motor, oil cooler, and economizer, were similar to those used in our laboratory rack. The laboratory apparatus is described in Section 2.

Layout of Major Components

Figure 3-5 shows the piping and instrumentation (P&I) diagram of the low-temp system before the HCFC-22 conversion. The screw compressor rack was built on a separate base and piped to the existing reciprocating compressor rack. The two systems shared the same condenser, receiver, and suction and discharge headers.

Oil Management

The marriage of a screw and a recip compressor on a single rack was not a trivial matter. The oil sump of a screw is at discharge pressure while that of a recip is at

Figure 3-5. - The Clifton Park Low-Temp Screw Compressor Rack P&I

suction pressure. Since the oil level must be maintained in either of the two sumps, it was necessary to devise a system that equalized the oil, despite the pressure difference in the two housings. Figure 3-6 illustrates the method employed for oil equalization. The oil accumulated in the oil reservoir can be fed either to the recip or screw compressors. In the recip, the oil level is maintained by an oil level regulator mounted on the compressor. With the screw, oil is injected into its suction line when an external oil level switch calls for more oil. After this oil is carried through the compression process, it reaches the oil sump and raises the oil level. An inverted oil level regulator mounted directly on the screw ensures that any excess oil accumulated in its sump is pushed into the oil reservoir. This flow is induced by the pressure difference between the sump of the screw and the oil reservoir. The pressure of the oil reservoir is set by a differential check valve at 20 psi above the suction pressure.

Figure 3-6. - The Clifton Park Low-Temp Rack Oil Equalization Diagram

Instrumentation

The Clifton Park test rack was fully instrumented to ensure accurate and reliable performance evaluation of the parameters listed in Table 3-2. Table 3-3 provides a comprehensive list of the instrumentation used in Clifton Park. In all, 75 instrumentation points were monitored at 10-minute intervals.

The most critical instruments were those used to measure the power and refrigeration load of the rack. For measuring the electric power, we used two-stator polyphase G.E. Watt-hour meters with a pulse output. Since these meters were the same kind used by utilities, they provided a power that most accurately reflected electric utility charges. The refrigeration load measurements were made using turbine flow meters in conjunction with thermocouples located in the liquid and suction lines (to and from the display cases).

Two Com-Trol 2002 energy management systems (Figure 3-7) were used to gather the data and download it to Aspen Systems offices once a week.

CFC-502 TO HCFC-22 CONVERSION

Performing a refrigerant changeover in an operating supermarket poses severe time challenges to the service personnel involved. The work must have a minimum impact on the products and the customers.

The changeover of the Clifton Park low-temp refrigeration system from CFC-502 to HCFC-22 was accomplished over two consecutive nights. A crew of seven service people was required.

**Table 3-2. - Test Information Obtained From the
Clifton Park Low-Temp Rack**

1-	Refrigeration Cycle State Points
2-	Power Consumption
3-	Refrigeration Capacity
4-	EER
5-	Ambient Subcooling
6-	Mechanical Subcooling
7-	Suction and Discharge Superheat
8-	Vapor Injection Benefit
9-	Condenser Power

Table 3-3. - List of Instrumentation for the Clifton Park Low-Temp Rack

Com-Trol System # 1:							
Point	AI#	Type	Description	Symbol	Min.	Max.	Units
1	1	Pres	Screw compressor suction	P1	-2.5	50	psig
2	2	Pres	Screw compressor discharge	P2	-15	300	psig
3	3	Pres	Vapor injection port	P3	-15	300	psig
4	4	Temp	Screw compressor suction	T1	-50	150	F
5	5	Temp	Screw compressor discharge	T2	50	300	F
6	49	Temp	Vapor Injection Port	T3	-50	150	F
7	7	Pres	Recip. compressor suction	P4	-5	100	psig
8	8	Pres	Recip. compressor discharge	P5	-15	300	psig
9	9	Temp	#1 Recip. compressor discharge	T8	-50	150	F
10	12	Temp	#2 Recip. compressor discharge	T9	-50	150	F
11	10	Temp	#1 Recip. compressor suction	T6	50	300	F
12	11	Temp	#2 Recip. compressor suction	T7	50	300	F
13	16	Temp	Condenser air stream	T13	-50	150	F
14	53	Temp	Outdoor ambient	T39	-50	150	F
15	56	kW	Compressors	W1	0	80	kW
16	57	kW	Condenser	W2	0	80	kW
17	6	Temp	Subcooler refrigerant inlet	T34	-50	150	F
18	13	Pres	Subcooler inlet	P6	-15	300	psig
19	50	Temp	Subcooler refrigerant outlet	T35	-50	150	F
20	48	Pres	Subcooler outlet	P7	-15	300	psig
21	78	Temp	Vapor injection TX valve inlet	T36	-50	150	F
22	51	Temp	#1 Indoor ambient	T37	-50	150	F
23	52	Temp	#2 Indoor ambient	T38	-50	150	F
24	70	Temp	Not used	T32	-50	150	F
25	47	Temp	Receiver outlet	T33	-50	150	F
26	59	Flow	#1 Circuit inlet, A8, 24' MEAT	F1	0	100	%F.S.
27	60	Flow	#2 Circuit inlet, A9, 13DRS FF	F2	0	100	%F.S.
28	61	Flow	#3 Circuit inlet, A10, 17DRS FF	F3	0	100	%F.S.
29	62	Flow	#4 Circuit inlet, A11, ICE	F4	0	100	%F.S.
30	63	Flow	#5 Circuit inlet, A12, 13DRS Z	F5	0	100	%F.S.
31	64	Flow	#6 Circuit inlet, A13, 18DRS Z	F6	0	100	%F.S.
32	71	Flow	Not used	F7	0	100	%F.S.
33	17	Temp	#1 Circuit inlet	T14	-50	150	F
34	18	Temp	#1 Circuit outlet	T15	-50	150	F
35	19	Pres	#1 Circuit inlet	P9	-15	300	psig
36	20	Pres	#1 Circuit outlet	P10	-5	100	psig
37	21	Temp	#2 Circuit inlet	T16	-50	150	F
38	22	Temp	#2 Circuit outlet	T17	-50	150	F
39	23	Pres	#2 Circuit inlet	P11	-15	300	psig

Table 3-3 (Cont.) - List of Instrumentation for the Clifton Park Low-Temp Rack

Com-Trol System # 1:							
Point	Alt#	Type	Description	Symbol	Min	Max	Units
40	24	Pres	#2 Circuit outlet	P12	-5	100	psig
41	25	Temp	#3 Circuit inlet	T18	-50	150	F
42	26	Temp	#3 Circuit outlet	T19	-50	150	F
43	27	Pres	#3 Circuit inlet	P13	-15	300	psig
44	28	Pres	#3 Circuit outlet	P14	-5	100	psig
45	29	Temp	#4 Circuit inlet	T20	-50	150	F
46	30	Temp	#4 Circuit outlet	T21	-50	150	F
47	31	Pres	#4 Circuit inlet	P15	-15	300	psig
48	32	Pres	#4 Circuit outlet	P16	-5	100	psig
49	33	Temp	#5 Circuit inlet	T22	-50	150	F
50	34	Temp	#5 Circuit outlet	T23	-50	150	F
51	35	Pres	#5 Circuit inlet	P17	-15	300	psig
52	36	Pres	#5 Circuit outlet	P18	-5	100	psig
53	37	Temp	#6 Circuit inlet	T24	-50	150	F
54	38	Temp	#6 Circuit outlet	T25	-50	150	F
55	39	Pres	#6 Circuit inlet	P19	-15	300	psig
56	40	Pres	#6 Circuit outlet	P20	-5	100	psig
57	41	Temp	#1 Display case air curtain	T26	-50	150	F
58	42	Temp	#2 Display case air curtain	T27	-50	150	F
59	43	Temp	#3 Display case air curtain	T28	-50	150	F
60	44	Temp	Not used	T29	-50	150	F
61	45	Temp	#5 Display case air curtain	T30	-50	150	F
62	46	Temp	#6 Display case air curtain	T31	-50	150	F
63	72	Pres	Oil cooler port	P21	-15	300	psig
64	73	Pres	Screw comp. suction (extra)	P8	-2.5	50	psig
65	67	kWh	Ohio Semitronics Wattmeter	W3	0	80	kW
66	69	kWh	Condenser	W4	0	80	kW
67	79	kWh	GE Wattmeter	W5	0	80	kW
Com-Trol System # 2:							
1/68	74	Temp	Heat reclaim in	T10	50	300	F
2/69	14	Temp	Condenser refrigerant inlet	T11	50	300	F
3/70	15	Temp	Condenser refrigerant outlet	T12	50	150	F
4/71	75	Temp	Oil cooler in	T4	50	300	F
5/72	76	Temp	Oil cooler out	T5	50	300	F
6/73	54	DewP	Indoor dewpoint	H1	0	100	F
7/74	55	DewP	Outdoor dewpoint	H2	0	100	F
8/75	77	Pres	Screw comp. suction (extra)	P8	-2.5	50	psig

Figure 3-7. - The Two Com-Trol Energy Management

The process was started by shutting the liquid line valves to all the cases. The rack compressors were used to remove the refrigerant from the cases. The compressors pushed the refrigerant into the high side of the system. A refrigerant recovery device was used to remove the liquid from the receiver and condenser.

When the cases had reached atmospheric pressure, the suction lines from the cases were isolated. Four service personnel then began replacing the TXV and distributor in each case. A liquid line filter drier was also installed upstream of the TXV to minimize the chance of the TXV port being blocked. The HCFC-22 valve ports were smaller than the CFC-502 valve ports, and were therefore more susceptible to clogging.

Three service personnel continued removing refrigerant from the rack and condenser. They expedited the refrigerant removal by opening a bypass line, which connected the low-temp rack to the medium-temperature rack (the medium-temperature rack is a CFC-502 system). Once the system had been brought to near atmospheric pressure, several high-capacity vacuum pumps were attached to the rack to prepare it for charging with HCFC-22.

As the changeover of each display case was completed, the finished case was placed on a vacuum pump. Once the rack and condenser were put on vacuum pumps, the suction valves to the finished cases were opened. After 1.5 hours on the vacuum pumps, the evacuated sections of the system were charged with HCFC-22 and the compressors were started. The compressors were off-line for approximately four hours. The changeover of all the low-temp cases was completed in about seven hours.

The +15°F cases, which share the same high side with the low-temp rack, were switched to the medium-temperature rack for the first night. These cases were converted to HCFC-22 operation on the second night.

Oil analysis before the refrigerant changeover showed no abnormalities. Since CFC-502 is in part HCFC-22, and the oil was not showing any sign of degradation, the decision was made to leave the existing oil in place. This allowed for a much faster changeover. Oil analysis after the changeover did not show any abnormalities. Refrigerant analysis performed after the changeover indicated that the refrigerant in the system was 99.9% pure HCFC-22.

This changeover was performed before new EPA rules concerning venting were enacted. Under the present EPA rules, the refrigerant must be recovered until the system has reached a vacuum of 15 in. Hg. This would, of course, prolong the time required to complete a changeover.

DEMONSTRATION TESTING RESULTS

Test History

The Clifton Park HCFC-22 conversion took place on July 7, 1991. The UNL system was run for the first eight weeks of HCFC-22 operation while we converted the components of the screw compressor rack to HCFC-22.

Table 3-4 lists weekly results obtained during the first phase of this project. The power readings from the utility-type Wattmeter were recorded both manually and automatically. The two measurements were checked against each other to verify the accuracy of the downloaded data. The manually recorded Watt-hour measurements are reflected in the third column of Table 3-4. When divided by the time elapsed from the previous measurement, these yield the average kW values provided in column 6. The downloaded kW measurements are listed in column 8. As shown, these are in

agreement with the manually recorded power readings. Table 3-4 also shows the weekly average values for the SDT, SST, refrigeration load, and EER.

Table 3-5 lists the history of modifications and repairs of the low-temp rack. Most repairs and modifications were related to the control system or involved changing the operating setpoints. We experienced no mechanical failures on these systems except for a leaking relief valve. On June 3, 1992, we sent the screw compressor to Howden for a thorough examination. The Howden technicians observed no measurable wear. A new screw compressor with larger suction and discharge ports was installed during October 1992. Results from that test are described below, under Additional Testing, New Screw Compressor Performance.

Test Procedure and Operating Conditions

The test plan was simple. Each week the load was switched between the three refrigeration systems (see above). Initially, the switchovers were scheduled for Mondays. However, the service technicians would occasionally miss a switchover when a holiday would fall on a Monday. Hence, when the Glens Falls project was started, we decided to move the switchovers to Tuesdays. The suction setpoint was initially set at -14°F. This was eventually lowered to -18°F to satisfy frozen food requirements. The condensing temperature was allowed to float down to approximately 50°F. Lower head pressures were not examined due to the extremely low EERs encountered at these conditions (see below, Performance Results).

Data Reduction Procedure

Measurements were recorded every 10 minutes and stored in the two Com-Trol units. The data was downloaded on a weekly basis, generally on the day of the switchover. Each week, we collected close to 0.5 Mbytes of data. A CrossTalk™ script was written to automate the data downloading procedure. A set of computer programs was developed to reduce the downloaded data into two tabular formats: the first for viewing and the second for input to the computer software used for generating graphs. Various curve-fitting techniques such as polynomial regressions, spline fits, and data smoothing were used to generate meaningful averages of the data.

Table 3-4. - Clifton Park HCFC-22 Test Weekly History.

MANUALLY RECORDED RESULTS						AVERAGE RESULTS FROM DOWNLOADED DATA					
Date	Time	Watt-hour Reading	kWh Used	Elapsed Hours	Average kW	System in Operation	Power (kW)	SDT (°F)	SST (°F)	Load (MBH)	EER (Btu/Watt-hr)
07/10/91						UNL	17.2	89.8	14.8	125.1	7.3
07/16/91						UNL	16.0	74.7	14.0	100.7	6.3
07/23/91						UNL	19.2	93.9	14.2	97.5	5.1
07/29/91						UNL	17.4	88.1	14.1	100.4	5.8
08/05/91						UNL	16.8	86.5	14.3	98.0	5.8
08/12/91						UNL	16.2	84.1	14.2	97.8	6.0
08/19/91	09:20:00	48816	---	---	---	UNL	18.0	88.9	14.4	100.1	5.6
08/26/91	08:20:00	52103	3287	167.0	19.68	UNL	19.7	84.2	12.8	107.1	5.4
09/02/91						INV	16.3	85.9	11.9	102.5	6.3
09/09/91	08:15:00	57427	5324	335.9	15.85	INV	15.2	81.4	11.9	101.4	6.7
09/16/91	08:10:00	60458	3031	167.9	18.05	SCR	17.8	79.4	13.0	105.7	5.9
09/23/91	08:10:00	63040	2582	168.0	15.37	UNL	15.0	77.7	16.6	98.0	6.5
09/30/91	14:45:00	65333	2293	174.6	13.13	INV	13.2	68.2	15.0	97.2	7.4
10/07/91	08:15:00	68286	2953	161.5	18.28	SCR	18.3	79.6	15.5	101.4	5.5
10/14/91	08:15:00	70655	2369	168.0	14.10	UNL	14.1	71.4	16.6	107.2	7.6
10/21/91	08:30:00	72855	2200	168.3	13.08	INV	13.4	67.6	13.9	97.2	7.3
10/28/91	08:15:00	75766	2911	167.8	17.35	SCR	17.5	76.0	-17.3	98.6	5.6
11/04/91	08:15:00	78018	2252	168.0	13.40	UNL	13.3	63.0	-20.6	93.4	7.0
11/11/91	08:30:00	80072	2054	168.3	12.21	INV	12.2	58.2	-18.2	103.9	8.5
11/18/91	08:15:00	82288	2216	167.8	13.21	SCR	13.2	60.1	-19.6	104.6	7.9
11/25/91	08:15:00	84577	2289	168.0	13.63	UNL	13.7	65.4	-19.0	106.7	7.8
12/02/91	08:45:00	86628	2051	168.5	12.17	INV	12.1	59.7	-16.7	107.8	8.9
12/09/91	08:15:00	88568	1940	167.5	11.58	SCR	11.4	56.6	-18.3	95.9	8.4
12/16/91	08:20:00	90468	1900	168.1	11.30	UNL	11.3	57.4	-19.1	84.1	7.4
12/23/91	08:05:00	92260	1792	167.8	10.68	INV	10.6	53.7	-16.4	97.7	9.3
12/30/91	08:50:00	94144	1884	168.8	11.16	SCR	11.1	55.6	-18.7	99.7	9.0
01/06/92	08:15:00	95989	1845	167.4	11.02	UNL	10.8	56.2	-20.4	101.9	9.4
01/13/92	08:15:00	97857	1868	168.0	11.12	INV	11.0	56.0	-16.2	99.1	9.0
01/20/92	10:15:00	99703	1846	170.0	10.86	SCR	DATA LOST				
01/27/92	11:15:00	1430	1727	169.0	10.22	UNL	10.1	51.3	-19.3	111.2	11.0
02/03/92	08:15:00	3173	1743	165.0	10.56	INV	10.5	52.2	-17.6	108.2	10.3
02/10/92	08:55:00	4993	1820	168.7	10.79	SCR	10.8	52.2	-18.7	109.7	10.2
02/17/92	08:15:00	6747	1754	167.3	10.48	UNL	10.4	53.1	-19.5	110.0	10.6
02/24/92	08:15:00	8645	1898	168.0	11.30	INV	11.2	53.9	-17.6	106.8	9.6
03/02/92	08:15:00	10550	1905	168.0	11.34	SCR	11.3	53.6	-19.3	101.3	9.0
03/09/92	08:15:00	12381	1831	168.0	10.90	UNL	10.8	54.2	-18.8	97.6	9.0
03/16/92	07:10:00	14183	1802	166.9	10.80	INV	10.7	54.7	-16.5	99.4	9.3
03/23/92	07:10:00	16017	1834	168.0	10.92	SCR	10.9	52.7	-17.4	97.3	8.9
03/30/92	08:15:00	17920	1903	169.1	11.25	UNL	11.1	55.5	-18.7	93.2	8.4
04/06/92	08:15:00	19776	1856	168.0	11.05	INV	11.0	55.3	-17.3	103.4	9.4
04/13/92	08:15:00	21971	2195	168.0	13.07	SCR	13.1	59.8	-17.9	100.5	7.7
04/20/92	08:15:00	23950	1979	168.0	11.78	UNL	11.6	62.5	-18.5	110.7	9.5
04/27/92	08:15:00	26425	2475	168.0	14.73	INV	14.7	72.7	-18.2	92.4	6.3
05/04/92	08:15:00	29118	2693	168.0	16.03	SCR	16.0	73.0	-17.7	93.6	5.8
05/12/92	16:00:00	31924	2806	199.8	14.05	UNL	14.3	75.0	-18.3	93.1	6.5
05/19/92	08:40:00	34498	2574	160.7	16.02	INV	16.0	80.5	-17.6	88.2	5.5
05/22/92	17:30:00	35367	869	80.8	10.75	SCR	SYSTEM SWITCHED PREMATURELY				
06/02/92	08:20:00	39362	3995	254.8	15.68	UNL	12.5	75.3	13.8	90.9	6.9
06/09/92	08:20:00	42462	3100	168.0	18.45	INV	18.4	89.2	-18.6	88.4	4.8
06/16/92	16:15:00	45033	2571	175.9	14.61	UNL	14.7	85.8	13.2	92.4	6.3
06/23/92	08:15:00	47753	2720	160.0	17.00	INV	17.1	82.0	-18.1	87.2	5.1
06/30/92	11:30:00	50835	3082	171.3	18.00	UNL	17.9	93.1	-17.4	92.4	5.2
07/07/92	09:30:00	54886	4051	166.0	24.40	INV	DATA-LOGGER BEING REPAIRED				
07/14/92	14:50:00	57197	2311	173.3	13.33	UNL	DATA-LOGGER BEING REPAIRED				
						INV	DATA-LOGGER BEING REPAIRED				

NOTES: The date shown in the left column is the last day of the week represented by the data.
 Highlighted areas indicate test periods where the SST was too high.

LEGEND

UNL: Reciprocating Compressor Rack on Unloaders
 INV: Reciprocating Compressor Rack on the Inverter
 SCR: Screw Compressor Rack on the Inverter

Performance Results

This section summarizes the extensive results obtained from the Clifton Park store after the HCFC-22 switchover. The weekly average performance results were listed in Table 3-4. Using the data in this table, we generated the following weekly history of the refrigeration loads for the three systems.

Refrigeration Load. Figure 3-8 depicts the history of the HCFC-22 refrigeration load for the Clifton Park store. It also illustrates a comparison of results among the different systems. The average weekly refrigeration loads of the three systems are essentially equal. Up to the first quarter of 1992, the refrigeration load averaged about 100 MBH. Since then, the average load noticeably decreased to about 90 MBH. The primary cause of the load reduction was a change in store operation. The store no longer used ice for some of its produce, and the demand on the ice machine was thus significantly lower. Concurrent with the load decrease, the rack control algorithm was changed from a PI to a PID version. Also, there was a slight rise in the suction pressure setpoint.

Table 3-5. - Clifton Park HCFC-22 Test History of Modifications

DATE	MODIFICATION
08/19/91	Replaced TXV in VI subcooler.
09/11/91	Adjusted superheat on TXV's on SYS A13 (had noticed that suction side was frequently saturated).
09/11/91	Replaced A12 suction side pressure transducer.
09/16/91	Lowered suction set point by 2 psi.
10/21/91	Lowered suction set point by 2 psi (actually, added 2 psi offset to the RC-1000 reading).
10/21/91	Opened subcooler TXV's two turns.
11/18/91	Changed UNL suction setpoint from 11in, 9out to 10in, 10out making setpoints on all three racks the same.
04/09/92	Replaced firmware in RC-1000 to include PID control.
04/13/92	Replaced CPU in malfunctioning RC-1000.
05/12/92	Started switching and downloading on Tuesdays.
05/19/92	Changed to EIL firmware 5.0.
05/22/92	Leaking relief valve in screw rack. Switched to UNL.
06/03/92	Sent screw compressor to Howden for a complete checkover and replacement by an optimized unit.
07/07/92	Com-Trol not communicating. After changing modem and power supply, sent unit back to Com-Trol.
08/14/92	Installed repaired Com-Trol unit.

Results History. Figures 3-9, 3-10, and 3-11 are snapshots of the entire test history of the three refrigeration systems. The average hourly load, SDT, ambient temperature, power, EER, and SST are plotted against hours of operation for the entire duration of the test. The horizontal axes of the top and bottom curves are identical. Every line in these figures is composed of as many data points as the number of hours shown on the horizontal axis. To reduce the scatter of the results, the data are smoothed using a 21-point window. This means that every data point is averaged with its 20 neighboring points (10 points on each side). The resulting smoothed data points are connected to their neighboring points by a small segment of straight line. Smoothing allows the general trend of these curves to be clearly discerned. To illustrate this fact, the refrigeration load data of Figure 3-9a are shown in their original non-smoothed form in Figure 3-12. The scatter in non-smoothed data is so large that it masks the trend of the data.

Figures 3-9a and 3-9b show the results for the recips on inverter. These curves indicate that even smoothed data are subject to substantial fluctuations. The refrigeration load follows the general trend of Figure 3-8. A comparison of ambient

Figure 3-8. - History of the Weekly Refrigeration Load for the HCFC-22 Low-Temp Rack of the Clifton Park Store

Figure 3-9a. - History of the Hourly Refrigeration Load, SDT, and Ambient Temperature for Recips on Inverter

Figure 3-9b. - History of the Hourly Power, EER, and SST for Recips on Inverter

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-10a. - History of the Hourly Refrigeration Load, SDT, and Ambient Temperature for Screw on Inverter

Figure 3-10b. - History of the Hourly Power, EER, and SST for Screw on Inverter

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-11a. - History of the Hourly Refrigeration Load, SDT, and Ambient Temperature for Recips on Unloaders

Figure 3-11b. - History of the Hourly Power, EER, and SST for Recips on Unloaders

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-12. - History of the Hourly Refrigeration Load for Recips on Inverter (Non-Smoothed Data)

temperature and SDT shows that fan cycling held the minimum condensing temperature above 50°F. After the first 300 hours of operation, the SST was held at an average of -17°F.

Even though smoothed data are useful in reducing the scatter of the data, smoothing eliminates the extreme peaks in the data. Based on the raw (non-smoothed) data, the power for the INV peaked at 27 kW at an SDT of 106°F and ambient temperature of 90°F. Hence, at high ambient temperatures, the condenser TD was about 16°F. The range of ambient temperature for the INV was from 4 to 90°F.

The results for the SCR are shown in Figures 3-10a and 3-10b. Similar to the INV, after the first 300 hours of operation, the SST averaged -17°F. Based on the raw data, the power peaks at 22.5 kW at an SDT of 97°F and ambient temperature of 82°F. The ambient temperature range while the SCR was in operation was 0 to 82°F.

The results for the UNL are shown in Figures 3-11a and 3-11b. After the first 300 hours of operation, the SST averaged -19°F. Based on the raw data, the power peaks at 25 kW at an SDT of 111°F. The ambient temperature range while the SCR was in operation was 0 to 89°F.

Comparison of Refrigeration Systems

Spline Fits. The smoothed data of Figures 3-9, 3-10, and 3-11 would be confusing if they were simply plotted on top of each other for comparison. In order to compare the performance of the three refrigeration systems, it is necessary to transform the data into a form that allows a simple comparison. Consider the EER data obtained for the INV in Figure 3-13. There is considerable variation in EER for given SDT values. Thus, it is desirable to assign a single value to the EER of the system at any given SDT. To accomplish this, spline points were visually imbedded in the smoothed data and a spline was drawn between these points (Figure 3-14). The resulting spline, Figure 3-15, is an accurate representation of the performance of the system for the range of available data. This method was used on all the data to simplify the performance comparison between the three refrigeration systems. The first 300 hours of data collected on the three systems were excluded since, during this period, the suction setpoint was not lowered to its final value. The shaded SST region in Table 3-4 shows the data that were excluded on the basis of their high SSTs.

EER Comparison. Figure 3-16 shows the comparison of the splines fitted through the HCFC-22 EER data of the three refrigeration systems. These curves indicate abnormal EER performance at low SDTs. To illustrate this, consider Figure 3-17, which shows

Figure 3-13. - EER vs. SDT for Recips on
Inverter (Smoothed Raw Data)

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-14. - EER vs. SDT for Recips on Inverter (Fitting a Spline)

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-15. - EER vs. SDT for Recips on Inverter (Spline Curve Fit)

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-16. - Comparison of the HCFC-22 EER Performance for the Three Refrigeration Systems

ASPEN SYSTEMS CFC-502 DEMONSTRATION RESULTS

Figure 3-17. - Comparison of the CFC-502 EER Performance for the Three Refrigeration

the CFC-502 results for the three systems. The performance of the low-temp rack on the two refrigerants is substantially different. With HCFC-22, all three systems exhibit a marked reduction in EER at SDTs below 50°F. This abnormal behavior is due to the excessive cycling of the compressors at low ambient temperatures. The reason for this cycling is discussed in the subsections below, entitled "SST Comparison" and "Analysis of the Effect of Lower HCFC-22 Flow Rates".

With HCFC-22, the UNL shows the best overall performance followed by the INV. The SCR is last. However, the situation was not ideal for the SCR, since we were using a 150-SUS oil. This oil was selected based on the requirements of the reciprocating compressors, since the wear rates of the reciprocating compressors were supposed to be excessive with higher viscosity oils. Our laboratory results have shown that with a higher viscosity oil the SCR performance can improve by an average of 5%. With CFC-502, the INV shows the best performance. Compared to the SCR, the UNL has a higher EER above 60°F SDT, while the SCR has a distinctly higher EER below 60°F SDT. As shown in Figures 3-10a and 3-11a, the two systems spend a considerable amount of the time below 60°F. Thus, only a bin temperature analysis can show which has the best seasonal EER.

The HCFC-22 reduction in EER at low SDTs is most pronounced for the INV, and least pronounced for the SCR. Figure 3-18 shows the direct comparison of HCFC-22 and CFC-502 performance for the INV. The CFC-502 performance follows the general pattern of EER/SDT dependence for positive-displacement compressors. The HCFC-22 performance is similar to that of CFC-502 at SDTs higher than 80°F. Below 80°F SDT, it crosses above the CFC-502 curve at 72°F and crosses back at 53°F.

As shown in Figure 3-19, the EER of the SCR is generally lower for HCFC-22, which is in agreement with our laboratory results (see Figure 2-14). The laboratory tests have shown that, with 68-cSt (300-SUS) mineral oil, the screw compressor's low-temp EER performance deteriorates when switching to HCFC-22. Only after we switched to substantially higher viscosity (1500-SUS) POE oil did we obtain equivalent CFC-502 and HCFC-22 EER performance. In Clifton Park, this problem was compounded by the use of 150-SUS mineral. As a result, the screw in Clifton Park performed even worse than the screw in the laboratory running on 300-SUS mineral oil. Figure 3-20 compares the HCFC-22 performance of the UNL with its CFC-502 performance. Above 50°F SDT, the HCFC-22 performance was better than or equal to that of CFC-502.

ASPEN SYSTEMS DEMONSTRATION RESULTS

Figure 3-18. - Comparison of CFC-502 and HCFC-22 EER Performance for Recips on Inverter

ASPEN SYSTEMS DEMONSTRATION RESULTS

Figure 3-19. - Comparison of CFC-502 and HCFC-22 EER Performance for Screw on Inverter

ASPEN SYSTEMS DEMONSTRATION RESULTS

Figure 3-20. - Comparison of CFC-502 and HCFC-22 EER Performance for Recips on Unloaders

Power Comparison. The HCFC-22 power consumption of the three systems is presented in Figure 3-21. The SCR has the highest power consumption, followed by the INV. The UNL is the most efficient system on HCFC-22. The CFC-502 results are similar (Figure 3-22), except that the INV consumes less power than the UNL for SDTs less than 83°F. With CFC-502, the use of the inverter improves the seasonal performance of the recips, since the SDT is less than 83°F for most of the year.

The UNL consumes less power with HCFC-22 than with CFC-502. The situation is reversed for the SCR and the INV. At low SDTs, the UNL and SCR consume similar amounts of power regardless of the refrigerant used. The INV, however, consumes less power (at low SDTs) with CFC-502. For HCFC-22, a comparison of the power curves in Figure 3-21 with the EER curves of Figure 3-16 suggests that the fluctuations in EER are caused solely by the refrigeration load.

Refrigeration Load Comparison. A comparison of the curves in Figures 3-23 and 3-24 indicates that all three systems operate less stably with HCFC-22 than with CFC-502. The instability in load is most pronounced with the INV and least pronounced with the SCR. The average refrigeration load for the two refrigerants is similar and is about 100 MBH, except for the SCR with CFC-502. With CFC-502, The refrigeration load for the SCR is consistently higher than that of the other two systems

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-21. - Comparison of the HCFC-22 Power Consumption for the Three Refrigeration Systems

ASPEN SYSTEMS CFC-502 DEMONSTRATION RESULTS

Figure 3-22. - Comparison of the CFC-502 Power Consumption for the Three Refrigeration Systems

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-23. - Comparison of the HCFC-22 Refrigeration Load for the Three Refrigeration Systems

ASPEN SYSTEMS CFC-502 DEMONSTRATION RESULTS

Figure 3-24. - Comparison of the CFC-502 Refrigeration Load for the Three Refrigeration Systems

(see Figures 3-24 and 2-6). The increase in load for the SCR is attributable to a parasitic heat gain in the subcooled liquid lines. When the SCR is in operation, the liquid is mechanically subcooled by the economizer and is considerably colder than when the UNL or INV is running. As an example, at 80°F SDT, the liquid temperature for the SCR is 23°F while for the UNL and INV it is 67°F. The lower liquid temperature (44°F) results in the pickup of a parasitic load in the trenches that poses an additional burden on the SCR. Thus, it is not surprising that the EER performance of the SCR compared to that of the other two systems (Figure 3-17) is not as unfavorable as its power consumption comparison (Figure 3-22).

For HCFC-22, however, the average refrigeration load of the SCR is not higher than that of the other two systems (Figures 3-23 and 3-8). The absence of parasitic load can be partially explained by the fact that the subcooling load is less for HCFC-22. At 80°F SDT, the mechanical subcooling load for CFC-502 is 17.5 MBH, while for HCFC-22 it is only 11 MBH. This, combined with the lower refrigerant flow rates of HCFC-22, may reduce the parasitic load picked up in the trenches.

SST Comparison. The SST curves in Figure 3-25 show unusual fluctuations for a supermarket refrigeration system. The expected behavior is that shown in Figure 3-26 for CFC-502. This figure shows that the INV controls the average suction set point to within 0.2°F. The SST bandwidth for the UNL is wider at about 1°F. The slight fluctuation in average SST with the UNL is due to the finite steps in capacity with unloaders. Below 75°F SDT, the SCR holds a tight control over the SST. However, above 75°F SDT, the full capacity of the screw compressor is reached and the SST climbs above its setpoint. This also explains the change in the slope of the SCR power curve in Figure 3-22 at 75°F SDT. Since the power consumption of a compressor increases at higher SSTs, the power consumption of the SCR increases more rapidly above 75°F SDT.

With HCFC-22 (Figure 3-25), however, the SST seems to be strongly affected by the variations in load. This effect is most pronounced for the INV, which suffers the largest variations in load (Figure 3-25). The rapid fluctuations in load at low SDTs impeded the controller's ability to maintain suction temperature. The swings in load are so violent (Figure 3-12) that the compressors are frequently shut off on low-pressure safety. This happens in two steps: first the low-speed limit of the inverter is reached; and then the suction pressure falls below its low-pressure setpoint. The controller then waits 30 seconds to restart the compressors. During

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-25. - Comparison of the HCFC-22 SST Data for the Three Refrigeration Systems

this period the SST climbs well above the suction setpoint. This cycling was observed by the service technician on many occasions. As a result, the apparent average SST increased at lower SDTs. With the SCR, this was not as much of a problem because of its smaller refrigeration capacity. The smaller capacity prevented frequent low pressure trips. The UNL did not suffer from this problem, suggesting that the problem was related to the limited capacity reduction allowed by the inverter. If the unloaders were to be used in conjunction with the inverter, this problem may be resolved.

The reason the screw compressor was undersized was that we originally sized it for -15°F operation. The original refrigeration schedule of the supermarket specified a -15°F SST for Clifton Park's low-temp rack. During the CFC-502 testing, we discovered that the supermarket operators were running the rack at -20°F SST. As shown in Figure 3-26, the screw compressor could maintain the suction below -15°F with CFC-502. With HCFC-22, according to our laboratory results, the capacity of the screw compressor with 300-SUS mineral oil decreased by about 18 MBH (see above). The 18-MBH decrease in capacity was verified against the Clifton Park demonstration results in the following manner. As shown in Figure 3-27, the screw could not maintain a -18°F suction setpoint above 75°F SDT with HCFC-22. With CFC-502, the

ASPEN SYSTEMS CFC-502 DEMONSTRATION RESULTS

Figure 3-26. - Comparison of the CFC-502 SST Data for the Three Refrigeration Systems

ASPEN SYSTEMS DEMONSTRATION RESULTS

Figure 3-27. - Comparison of the HCFC-22 and CFC-502 SST Data for the SCR System

screw could not maintain a -18°F SST above an SDT of 92°F . We used these data to calculate the actual HCFC-22 capacity reduction in Clifton Park. Using manufacturer's data sheets, the economized capacity at 75°F SDT (-18°F SST, CFC-502, 4500 rpm) was 176 MBH. The economized capacity at 92°F SDT (other conditions the same) is 196 MBH. Thus, the Clifton Park screw compressor suffered a loss in capacity of 20 MBH (196 vs. 176 MBH) when we switched to HCFC-22. This was in complete agreement with our laboratory results. The additional 2-MBH loss in the field was due to the lower viscosity of the oil used in Clifton Park (150- vs. 300-SUS).

Analysis of the Effect of Lower HCFC-22 Flow Rates. A cursory look at Figures 3-16, 3-23, and 3-25 reveals that none of the three systems operates stably with HCFC-22, especially at lower SDTs. The cause of this instability was the lower flow rates associated with HCFC-22. The higher refrigeration effect of HCFC-22 compared to CFC-502 resulted in about 30% less mass flow rate for a given load. The lower refrigerant velocity, caused phase separation in the evaporator coils of the display cases and resulted in increased TXV hunting (5). At lower SDTs, the refrigeration effect was larger, resulting in even lower mass flow rates. Thus, with HCFC-22, the evaporator coils were oversized, especially at lower SDTs.

With the TXVs' excessive hunting, the infinite adjustability and fast response of the inverter caused it to chase the load and intensified the hunting. The situation was further aggravated when the minimum condensing setpoint was reached. The condenser fans started cycling in response to the violent fluctuations in load. Examining Figure 3-9a one can see that all these scenarios all clearly enacted at low SDTs. The large variations in condenser temperature difference ($\text{TD} = \text{SDT} - \text{ambient temperature}$) at SDTs below 60°F indicated that the fans were cycling. The large fluctuations in refrigeration load indicated that the TXVs were hunting. The destabilizing role of the inverter is discerned by comparing Figures 3-9a and 3-11a. The fluctuations in load at low SDTs are larger for the INV than for the UNL. These are smoothed data; as shown in Figure 3-12, the actual fluctuations in load have a much higher amplitude.

We can now explain the unfamiliar HCFC-22 behavior of the INV in Figure 3-18. As the load fluctuated between its high and low values, the heat rejection rate of the condenser followed suit. As a result, the SDT followed the variations in the load and fluctuated accordingly. Thus in Figure 3-18, at low SDTs, the combination of fan

cycling and condenser heat rejection rate fluctuation caused the SDT to jump back and forth between, say, 50 and 60°F. The EER, therefore, moved up and down along the slope of the lower SDT portion of the curve. Meanwhile, the power (Figure 3-19) remained unperturbed, primarily because of the long integration time of the pulse output of the Wattmeter, which spanned several minutes. Thus, the power measurement saddles several fluctuations in load (and SDT) and remained essentially constant.

ADDITIONAL TESTING

After reviewing the results we decided to perform several modifications to the system and run additional tests.

1. A newer model screw compressor with larger inlet and outlet ports and tighter tolerances was installed.
2. To improve the low SDT performance, a liquid pump was installed. The condenser control was altered to allow the system to operate at lower SCTs.
3. The effect of disabling the economizer port on the screw compressor rack at SDTs below 50°F was examined. By examining the data, we found that with HCFC-22, the subcooler could actually increase the liquid temperature at low condensing temperatures. Our laboratory tests had indicated that the economizer had little or no effect on EER between 40 and 50°F SDT.
4. Performance testing was completed for each new configuration. The low SDT data were collected during cold ambient conditions. The high temperature data were simulated by disabling condenser fans.

New Screw Compressor Performance

The new, improved screw compressor was installed in October 1992. This 91-mm MK4 Howden compressor had tighter rotor-to-rotor, rotor-to-bore, and end clearances. The discharge and suction passageways were enlarged to minimize losses. Laboratory tests indicated a 3.7% increase in EER and a 5.8% increase in capacity compared to the older MK3 screw compressor.

The field tests performed with the MK4 compressor indicated an average load of 94 MBH. The EER performance was distinctly better than with the MK3 compressor. Figure 3-28 shows generally better performance from 50 to 85°F SDT. Below 50°F SDT, the performance was significantly better. The condenser control was changed to allow lower SCTs and the liquid pump was on. This minimized the fan cycling that had occurred during previous tests and provided more stable operation, reducing the power usage of the compressor.

**Figure 3-28. - Comparison of MK4 and MK3
Screw Compressors EER Performance**

bove 85°F SDT, the MK3 compressor appeared to outperform the MK4. However, this was misleading. When the MK3 was tested, the average SST was well above the setpoint at higher SDTs (Figure 3-25, SCR). During the MK4 testing, the SST was very close to the setpoint over most of the range of SDTs (Figure 3-29). This could be attributed to both the higher compressor capacity and the lower average system load. Only above 88°F SDT did the SST exceed -18°F. Thus, the MK3 did not have a better EER. It was merely running at a higher SST.

Comparison of the MK4 EER with recent INV results indicates that the INV is still better than the SCR (Figure 3-30). Since we obtained limited data on both compressors, the curve-fits are not as smooth as the ones from previous tests.

The power comparison (Figure 3-31) indicates that the inverte-driven recipis and the inverter-driven screw used the same power from 40 to 55°F SDT. Above that, the trend was the same as with the MK3 compressor. The measured power did not include power used for the liquid pump.

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-29. - MK4 Screw Compressor SST Data

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-30. - Comparison of MK4 Screw Compressor and Recips on Inverter EER

**Figure 3-31. - MK4 Screw Compressor and
Recips on Inverter Power Comparison**

Note that the power is lower than that shown in Figure 3-21. There are two reasons for this. First, as mentioned above, the change in condenser control reduced system instability and compressor power. Second, one of the ice machines was not in use and therefore the overall load was lower. The lower load led to a lower power consumption.

Liquid Pump / Condenser Control

The liquid pump, manufactured by Hysave, was installed in the second week of December 1992. The system was run for one week with the liquid pump off to determine its effect on compressor power. Figure 3-32 indicates a drop in compressor power consumption when the pump was in use. However, the power consumed by the pump, measured at 380 W, more than offset the decrease in compressor power.

This result indicates that the major savings in power and increase in EER for the SCR were accomplished by reducing the minimum SCT setting. Our laboratory tests with the screw compressor indicated that SDTs down to 40°F were attainable without a liquid pump. We did not repeat this test with the INV. Since the INV operated with only a small amount of subcooling, its power usage may have been more sensitive to the liquid pump operation.

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-32. - Comparison of the MK4 Screw Compressor Power With and Without the Liquid

Economizer Control

The economizer was disabled for a one-week period. As shown in Figure 3-33, the EER was clearly better above 50°F SDT with the economizer on. Below 50°F SDT, the screw compressor operated more efficiently without the economizer. This result agrees with our laboratory findings.

RELIABILITY HISTORY

During the three years that the systems were in operation, we did not encounter any problem related to the screw compressor. The reciprocating compressors also performed reliably. We had to replace one malfunctioning solenoid valve on the screw compressor rack and had a few problems with the control and energy management systems. The instrumentation was reliable, and we replaced only one pressure transducer. Oil analysis on the racks revealed no abnormalities.

The MK3 screw compressor was removed on June 3, 1992, for inspection and replacement with the newer MK4. The inspection of the MK3 revealed no measurable wear on the moving parts.

ASPEN SYSTEMS HCFC-22 DEMONSTRATION RESULTS

Figure 3-33. - Comparison of the MK4 Screw Compressor EER With and Without the Economizer

SUMMARY

- The conversion of the low-temp rack in Clifton Park from CFC-502 to HCFC-22 was accomplished over two nights.
- The average HCFC-22 refrigeration load was 100 MBH and was not different from the CFC-502 refrigeration load.
- Compared to CFC-502, the HCFC-22 EER performance improved for the UNL and deteriorated for the SCR.
- With HCFC-22, the most efficient system was the UNL followed by the INV and the SCR. In contrast, with CFC-502, the most efficient system was the INV. In terms of efficiency, the SCR and UNL had similar seasonal performance. However, the UNL consumed less power. This was due to the additional refrigeration load carried by the screw as a result of the mechanically subcooled liquid lines.
- The peak hourly power consumption recorded for each system on HCFC-22 is given in Table 3-6.
- All three systems operated less stably with HCFC-22 compared to CFC-502. This was due to the lower mass flow rates associated with HCFC-22.

Table 3-6. Peak Hourly Power Consumption for the Three Refrigeration Systems With HCFC-22.

	Peak Power (kW)	Ambient Temperature (°F)	SDT (°F)
SCR	22.5	82	97
UNL	25	89	111
INV	27	90	106

- The HCFC-22 performance of the SCR was lower than that obtained in Aspen Systems' laboratory. The cause of the lower performance was the low viscosity of the oil used in Clifton Park.
- The conversion was successful. The systems performed reliably and, in some cases, we observed improved performance compared to CFC-502.
- The replacement of the older MK3 screw with a newer MK4 version improved energy efficiency performance.
- The INV still appeared to have better performance than the new MK4 SCR over most of the SDT range.
- Disabling the economizer at low SDTs showed some EER improvement.
- The lower condenser settings and use of a liquid pump lead to better performance on the INV.
- The lower condenser setpoints produced better performance for the SCR with or without the liquid pump in operation. The mechanical subcooling of the economizer appears to provide sufficient subcooling to maintain case temperatures.

GLENS FALLS HFC-134a AND HCFC-22 FIELD TESTING

Section 4

IN THIS SECTION

THE DEMONSTRATION SITE SUPERMARKET
DEMONSTRATION TESTING PROCEDURE
LOW-TEMP DEMONSTRATION TESTING HISTORY AND RESULTS
MED-TEMP DEMONSTRATION TESTING HISTORY AND RESULTS
A/C RACK DEMONSTRATION TESTING HISTORY AND RESULTS
SYSTEM ISSUES
OIL ANALYSIS
RELIABILITY
PROJECTED ANNUAL PERFORMANCE AND ENERGY COSTS
ECONOMIC ANALYSIS
SUMMARY

This section describes the Glens Falls demonstration test site and summarizes the results we obtained in the first year of its operation.

THE DEMONSTRATION SITE SUPERMARKET

The Glens Falls Shop 'n Save is a new supermarket that was designated as a demonstration site for advanced, non-CFC refrigeration systems in its design stage. Completed in March of 1992, the store employs HFC-134a for its air-conditioning (A/C) and medium-temperature (med-temp) systems and HCFC-22 for its low-temperature (low-temp) systems. The 63,000 ft² store operates 24 hours a day.

In addition to the testing of alternative refrigerants, different compressor technologies were tested. The med-temp system employs open-drive reciprocating compressors (recips), semihermetic recips, and open-drive screw compressors. The low-temp system uses open-drive screws from two different manufacturers as well as semihermetic recips. The A/C rack uses open-drive recips. All compressors, except those on the A/C rack, are controlled by VFDs for capacity control.

Each system was fully instrumented to allow measurement of operational parameters and energy efficiency. Data collected from these systems were used to establish seasonal performance and electric power demand.

Materials performance issues such as component reliability and oil/refrigerant compatibility were also addressed. Oil samples from each system were analyzed on a regular basis to identify excessive contamination, decomposition, chemical shifts, wear, or other long-term compatibility problems.

Description of the Glens Falls Refrigeration Systems

A summary description of the A/C and refrigeration systems at the Glens Falls Shop 'n Save store is shown in Table 4-1. The arrangement of the refrigeration systems in Table 4-1 is schematically illustrated in Figure 4-1.

Low-Temp Rack

The low-temp rack in the Glens Falls store has two suction groups, -25°F and -15°F, which share a common oil separator, condenser, reclaim coils, receiver, and liquid pump. The rack configuration is illustrated in Figure 4-1. A description of each of the components of the low-temp rack follows:

Compressors. For the tests described in this section, the low-temp refrigeration system had one Howden open-drive screw compressor, two Carlyle open-drive screw compressors, and two Carlyle 06ER175 semihermetic recip compressors. The low-temp rack houses the screw compressors (Figure 4-2), while the semihermetic recip (that were added as backup) are mounted on a skid of their own (Figure 4-3). A

Table 4-1. Description of the Refrigeration Systems in the Glens Falls Test Store

Rack Name	Refrigerant	Load (MBH)	Compressor				Oil		
			No	Type	Manufacturer	Qty	Grade (SUS)	Type	Manufacturer
-25°F/-15°F Low-temp	HCFC-22	126/177	1	Semi, Screw	Carlyle	1	300	AB	Zerol
"			2	Open, Screw	Howden	1			
"			3	Semi, Recip	Carlyle	2			
+15°F Med-temp	HFC-134a	239	4	Open, Recip	Carlyle	2	300	POE	CPI
+20°F Med-temp	HFC-134a	540	5	Open, Screw	Howden	3	300	POE	CPI
"			6	Open, Recip	Bitzer	3			
"			7	Semi, Recip	Carlyle	4			
Air Conditioning	HFC-134a	1,200	8	Open, Recip	Bitzer	4	150	POE	Castrol

Legend: Open - Open-Drive; Semi - Semihermetic; AB - Alkylbenzene; POE - Polyol Ester

**Figure 4-1. Arrangement of the Refrigeration Systems
in the Glens Falls Test Store**

complete description of the Howden compressor can be found in Section 2. The Carlyle screw compressors are rated at 33 cfm. They were installed with their dedicated external oil separator/reservoir. The three sets of compressors were switched between the -15°F and -25°F refrigeration loads on a weekly basis.

Oil Coolers. The two low-temp Carlyle screws share one oil cooler and the low-temp Howden screw has its own cooler. These oil coolers, mounted in the ceiling of the mechanical center, draw air from the mechanical room and exhaust it outside. The specifications for the Carlyle oil coolers are as follows:

Model No.	DB-32-4
Oil flow rate	6.0 gpm
Heat transfer rating	60 MBH
Dimensions	28H x 28W x 18D in.
Fan horsepower	3/4

The specifications for the Howden oil cooler are as follows:

Model No.	DB-31-4
Oil flow rate	6.0 gpm
Heat transfer rating	48 MBH
Dimensions	28H x 28W x 18D in.
Fan horsepower	3/4

Condenser. The roof-mounted condenser is an air-cooled, belt-driven unit manufactured by Bohn.

Model No.	BVF-100
Heat transfer rating	48,830 Btu/°F/hr
Number of fans	3
Fan horsepower	3

**Figure 4-2. The Open-Drive Screw Compressors
in the Low-Temp Refrigeration System**

**Figure 4-3. The Carlyle Semihermetic Recip Compressors
in the Low-Temp Refrigeration System**

Oil Separator. The oil separator is a high-efficiency, dual-chamber, coalescing type made by Frick.

Model No. DOC-12
Oil carryover rate 10 ppm

Liquid Pump. This rack employs a liquid refrigerant pump to assist in floating head operation. The pump also provides additional pressure required for the mass flow meters. The pump is a 2-hp Hansen sealed centrifugal unit with a magnetic drive.

Economizer Subcoolers. There is one subcooler for each suction group. The two subcoolers are Dunham-Bush shell and tube heat exchangers with the following specifications:

Model No. SC003482AJ
Max. load 43.4 MBH
LMTD @ design load 31.1°F

Controller. Two RC-1000 rack controllers identical to the one described below under Med-Temp Rack were used for the two suction groups.

Inverter. A single Emerson Eclipse inverter with the following specifications was coupled to the Howden compressor.

Model No. 6230 - 8421
Nominal rating 50 hp
Type Sinusoidal PWM
Maximum efficiency 96%
Number of drives 1

Individual Emerson Eclipse inverters with the following specifications were used for each Carlyle screw compressor.

Model No. 6230 - 8521
Nominal rating 30 hp
Type Sinusoidal PWM
Maximum efficiency 96%
Number of drives 2

Each compressor was controlled by its own inverter. For the Howden compressor, the maximum speed was 4400 rpm. The Carlyle screws run at a maximum speed of 2200 rpm.

Med-Temp Rack

The med-temp rack had two suction groups, +20°F and +15°F. These shared a common oil separator, condenser, reclaim coils, receiver, and liquid pump (Figure 4-1).

Condenser. The roof-mounted condenser is an air-cooled, belt-driven unit manufactured by Bohn. Specifications of the condenser are listed below:

Model No.	BVF-200
Heat transfer rating	96,630 Btu/°F/hr
Number of fans	6
Fan horsepower	3

Oil Separator. The oil separator is a high-efficiency, dual-chamber, coalescing type made by Frick.

Model No.	DOC-16
Oil carryover rate	10 ppm

Liquid Pump. This rack employs a liquid refrigerant pump to assist in floating-head operation. The pump also compensates for the pressure drop across the mass flow meters. It is a 3-hp sealed centrifugal unit with a magnetic drive manufactured by Hansen.

Med-Temp Rack (20°F System)

Compressors. The three different compressor groups serving the +20°F med-temp cases (Table 4-1) were alternated on a weekly basis. This system includes three Bitzer 6H2 open-drive reciprocating compressors (Figure 4-4), four Carlyle 06EM175 semihermetic reciprocating compressors (Figure 4-5) and three Howden 91-mm open-drive screw compressors (Figure 4-6). The Bitzer and Howden compressors are direct-coupled to their respective motors.

Oil cooler. The three +20°F Howden screws share a single oil cooler. The oil cooler, mounted in the mechanical center's ceiling, draws air from the mechanical room and exhausts it outside.

Model No.	DB-32-4
Oil flow rate	12 gpm
Heat transfer rating	77 MBH
Dimensions	28H x 28W x 18D in.
Fan horsepower	3/4 hp

**Figure 4-4. The Bitzer 6H2 Open-Drive Recip Compressors
in the +20°F Refrigeration System**

**Figure 4-5. The Carlyle 06EM175 Semihermetic Recip
Compressors**

**Figure 4-6. The Howden 91-mm Screw Compressors
in the +20°F Refrigeration System**

Subcooler. The subcooler is used in conjunction with the economizer ports of the three screw compressors to increase their capacity and performance. Refrigerant used to subcool the liquid is returned to the compressors' economizer ports. The specifications for the Dunham-Bush subcooler are as follows:

Model No.	SC004481AJ
Max. load	93.5 MBH
LMTD @ design load	21.0°F

Variable-Frequency Drives. Three VFDs were installed for control of the +20°F compressors. The inverters are Emerson Eclipse, constant-torque VFDs.

Model No.	6230 - 8421
Nominal rating	50 hp
Type	Sinusoidal PWM
Maximum efficiency	96%
Number of drives	3

Controller. The refrigeration system is controlled by an EIL RC-1000 rack controller. This controller is identical to the one installed at the Clifton Park site and in our laboratory. We utilized the RC-1000 suction pressure control algorithm for all test racks. The suction pressure was maintained at a specific value and the circuit suction solenoid valves were cycled to maintain case temperature.

Three inverters are available to drive each bank of compressors. When the inverters are driving either the open-drive or the semihermetic recips, the maximum inverter output is set to 60 Hz. The compressors are all driven at the same speed. The minimum speed on the recips is set to maintain the required minimum oil pump pressure.

When the screw compressors were in operation, the drives were configured for a maximum frequency of 67 Hz. The maximum compressor speed was 4000 rpm. The compressors were driven sequentially. Thus, the first compressor would be at full speed before the second one was started.

Med-Temp Rack (15°F System)

Compressors. The +15°F med-temp system has two Carlyle 5H40 open-drive reciprocating compressors. Each compressor has a direct-coupled motor. Both compressors are driven by one inverter (Figure 4-7).

**Figure 4-7. The Carlyle 5H40 Open-Drive Recip Compressors
in the +15°F Refrigeration System**

Variable-Frequency Drive. The inverter is an Emerson Eclipse, constant-torque VFD.

Model No.	6230 - 8002
Nominal rating	75 hp
Type	Sinusoidal PWM
Maximum efficiency	96%
Number of drives	1

Controller. An RC-1000 rack controller identical to the one described for the med-temp rack, above, was used for this suction group.

A/C Rack

The A/C for the store is supplied by five roof-mounted air handlers. The heating load is met with heat reclaim from the refrigeration racks and by gas heaters. The cooling load is met using outside air when the outdoors ambient temperature is below 70°F. Above this temperature, the HFC-134a-filled A/C rack provides the required mechanical cooling.

Compressors. The A/C system uses three Bitzer 6F.2 and one Bitzer 4H.2 open-drive reciprocating compressors (Figure 4-8). These compressors are direct driven and are cycled on and off to match the required capacity.

**Figure 4-8. The Bitzer Open-Drive Recip Compressors
in the A/C System**

Condensers. The roof-mounted condenser is an air-cooled, belt-driven unit manufactured by Bohn. The specifications of the condenser are listed below:

Model No.	BVF-200
Heat transfer rating	96,630 Btu/°F/hr
Number of fans	6
Fan horsepower	3

Liquid Pump. This rack employs a liquid refrigerant pump to provide additional pressure required for the mass flow meters. The pump is a 3-hp Hansen sealed centrifugal unit with a magnetic drive.

Controller. An RC-1000 is used to control the compressors. The compressors are staged to maintain the desired suction pressure setpoint. The space temperature is maintained by cycling the suction solenoid valves on the air handler evaporator coils.

Oil Management

Both the low- and med-temp racks required special attention for their oil management systems. Screw compressors require a significant amount of oil to seal their rotors during the compression process and, as a result, discharge a substantial amount of oil. The low-temp rack contains three of these compressors. Though the Howden compressor contains its own internal separator, we have found that its oil carryover rate can be as high as 4 gal/hr (see Section 2). The discharge lines of the two Carlyle screw compressors were piped into a special oil separator/reservoir supplied with the compressors. The amount of oil not captured by this separator is substantially less than the oil carryover of the Howden compressor. The excess oil from all the screw compressors is carried through the high and low sides and can significantly reduce the effectiveness of the condenser and evaporators. Furthermore, this oil can accumulate preferentially in either the sump of the Howden screw or the oil reservoir of the Carlyle compressors. To reduce the amount of oil carried into the condenser and evaporators, a separate oil separator for the combined discharge flow was installed. The oil separated by this oil separator is directed to an external oil reservoir. When a compressor is low on oil, oil is fed from the external reservoir into the compressor's oil injection ports.

The med-temp rack has a total of 12 compressors, three of which are screws and two of which are at lower suction pressure than the others. The arrangement of the compressors and the oil management system of the +20°F portion of this rack is shown in Figure 4-9. There is a single oil separator for the combined discharge flow. The oil collected by this separator is gravity-fed to an oil reservoir that is maintained at

Figure 4-9. Compressors Arrangement and Oil Equalization Diagram of the Glens Falls
+20°F Med-Temp Refrigeration Rack

discharge pressure. For the recips, a pressure regulator reduces the oil supply pressure to about 45 psi above suction. For the screws, the oil is fed directly into their oil injection port, just downstream of the oil cooler.

In addition, oil storage and feeding must be designed to feed oil to the low-pressure sumps of the recips and the high-pressure oil injection port of the screws.

Instrumentation

Each of the refrigeration systems is instrumented for temperature, pressure, flow, and power measurements. A description of each type of sensor is listed below.

1. Temperatures and Dewpoints - Critical points in the liquid and suction lines used to determine the refrigeration load are monitored with precision RTDs inserted into the flow. All other points are monitored with immersion thermistors or clamp-on, solid-state temperature sensors. Indoor and outdoor temperatures and dewpoints also are measured.
2. Pressures - System pressures that are critical to calculating refrigeration loads are measured by precision pressure transmitters calibrated prior to installation. Standard EIL pressure transducers are used for all other pressure readings.
3. Flow Rates - Coriolis-effect mass flow meters are used to measure the refrigerant flow rate in the liquid line of each suction group. These flow meters provide pulse outputs for each pound of refrigerant mass that passes through them. Pulses accumulated over a specified data collection interval are divided by the duration of that interval to determine the mass flow rate. Since the meters measure mass flow directly, no adjustments are needed for changes in temperature, viscosity, or density.
4. Electric Power - Power for each bank of compressors is measured with a two-stator, polyphase Watt-hour meter equipped with an electronic demand register. These meters provide pulse output for each unit of energy used. Pulses accumulated over a specified data collection interval are divided by the duration of that interval to determine power level. This type of meter will read accurately despite the frequency variations and harmonics produced by the VFDs. The power used by each refrigerant condenser is monitored with hall-effect-type Watt transducers. The condenser fan motors are not powered by VFDs.

Control and Data Acquisition Systems

Control of the refrigeration racks is handled by four EIL RC-1000 refrigeration rack controllers similar to the one installed in our laboratory and the Clifton Park test site. These controllers regulate all facets of system operation including compressor speed, case temperature, defrost cycles, and condenser fan cycling.

The RC-1000 controllers are also capable of recording data and were therefore used as part of the data collection system. However, the RC-1000 uses eight-bit resolution for sampling data, which is insufficient for critical readings. An independent, sixteen-bit Campbell Scientific CR-7 data logger was installed to monitor the critical data points.

The CR-7 data points are recorded every 12 seconds and are averaged over 5-minute periods. The 5-minute values are stored in the unit's internal memory prior to being downloaded. The RC-1000 records instantaneous data every five minutes and stores it in its internal memory.

The instrumentation and data collection system were not completed when the store opened in March of 1992. In the rush to meet the accelerated construction schedule, many sensors were not installed at startup. Weeks after the store was opened, many probes and transducers were still being installed.

Sensor installation was completed by May 12, 1992, when data collection of the most critical values was initiated. During the first few weeks, we replaced several failed sensors and corrected system wiring problems.

DEMONSTRATION TESTING PROCEDURE

Test Procedure

The five refrigeration systems in the Glens Falls store provided a wealth of data about compressor and system performance. The performance parameters relating to the compressors were measured on a continuous basis. Other limited-duration tests were conducted to determine the performance of specific components.

Continuous Tests. The following tests were conducted on a continuous basis:

- The +20°F system was alternated between each bank of compressors every week. The collected data allowed optimization and comparison of the three different compressor configurations.
- The compressors on the low-temp rack were alternated between the -15°F and -25°F suction groups on a weekly basis. As on the +20°F rack, performance of the compressors was optimized and compared.
- The +15°F rack was continuously monitored. The A/C rack was monitored when it was in operation, during the cooling season.

- Oil samples were taken on a regular basis from each system. Samples were analyzed to determine if there was excessive contamination, decomposition, chemical shifts, wear, or other long-term compatibility problems between the refrigerant, oil, and system components.

Limited-Duration Tests. The limited-duration or one-time tests included the following:

- Condenser TD - Once the system performance was established, the condenser TD setpoint was varied to determine its effect on the compressor rack and condenser power. The performance of the system was also determined without the use of the TD control to determine the net effect on power of this control method.
- Liquid pump characteristics - The power usage of the liquid pumps was measured to determine their net effect on each system's performance.
- Compressor internal inspection - The compressor manufacturers were given the opportunity to replace the currently installed compressors and inspect them for long-term wear or internal damage.

Data Reduction

All data were downloaded and saved in weekly blocks that isolated the performance of each group of compressors. Average weekly data were summarized in a table showing date and time of compressor switchover, manually recorded Watt-hour readings, power consumption, and average results. The manually recorded Watt-hour readings were used to verify power readings derived from the data collection system. The data sets were combined and reduced by FORTRAN programs developed by Aspen Systems.

The data reduction programs were similar to the routines we used for reducing the data from the Clifton Park demonstration site and from our laboratory test rack. The task of rewriting the data reduction programs was more complex than anticipated. There were 157 data points scattered over five different data loggers. All five data sets were required to calculate all parameters. If one data set was missing, the data could not be fully utilized, and some calculated values would be invalid. Though the clocks of the units were periodically synchronized, there were always discrepancies in the time stamps of the data sets and the data reduction program had to accommodate this. Also, new refrigerant subroutines had to be incorporated into the program to analyze the HFC-134a systems.

LOW-TEMP DEMONSTRATION TESTING HISTORY AND RESULTS

This section describes the test history and results obtained from the low-temp rack of the Glens Falls store between June 1992 and August 1993. Following a history of the operation of the racks, the test results for each suction group are reviewed. System- and lubricant-related issues are addressed last. Detailed history sheets are provided in Appendix A.

History of the Low-Temp Rack

The low-temp refrigeration system is composed of three sets of compressors: two open-drive screws, one semihermetic screw, and one semihermetic recip. Initially, the system used HCFC-22 and a 300-SUS alkylbenzene oil. This rack was converted to CFC-502 on May 11, 1993, and to HFC-507 (AZ-50) about six weeks later. Results for testing done after that date are covered in Volume II of this report.

Several control and piping issues required attention after startup. Some of the problems were due to the experimental nature of the installation.

The receiver level varied dramatically during the first several months. The charge was migrating to the non-operating, supposedly isolated compressors through an unchecked oil line. An isolation valve was added to the line to stop the migration.

It was noted that many of the -25°F display cases were unable to maintain their setpoint temperatures. Field measurements showed that the suction stops were undersized and were restricting the refrigerant flow. The existing stops were replaced with the next larger size to reduce pressure drop and improve control.

One problem occurred with the reciprocating compressors. The compressors were installed with liquid injection desuperheating. The liquid injection valve was controlled by the rack controller to open at a specific discharge temperature, injecting liquid into the suction line. During the spring, the temperature sensor failed and the controller locked the liquid injection valve open. The liquid continually dumping into the compressor eventually caused a compressor failure.

Three issues arose concerning the results for the Carlyle open-drive screw compressors. A wiring mistake with the wattmeter produced unreliable data for the Carlyle open-drive screw compressors. In addition, the control sequences for the

unloader and the variable-volume ratio were not correctly installed and affected overall performance. The results presented are, therefore, limited to the Howden open-drive screw and Carlyle semihermetic reciprocating compressors.

The single 91-mm Howden experienced only one minor problem. The shaft seal leaked perceptibly more than the other open-drive compressors. Our laboratory tests have shown an increased leakage at speeds above 4000 rpm (the speed limit for the Glens Falls compressor is set at 4400 rpm). Howden engineers have suggested that, due to its design, the seal on the MK3 compressor (the version installed in Glens Falls) can be expected to leak at high speeds. It is anticipated that replacing the MK3 compressor with an MK5 will solve this problem, since the MK5 has a redesigned seal which minimizes leakage.

Low-Temp Performance Results

-25°F Suction Group Performance. The -25°F suction group consists of eight circuits with a total calculated load of 126 MBH. Forty percent of the load is contributed by the open coffin cases, 34% by the reach-in door cases, and the remainder by the grocery freezer. A complete refrigeration schedule for this suction group is shown in Table 4- 2.

The measured average weekly load for this rack is shown in Figure 4-10. The peak summer weekly load of 126 MBH was reached in July of 1992 (Week No. 6). One abnormally high peak in December is attributed to a faulty defrost sensor (Week No. 25).

Table 4-2. -25°F System Refrigeration Schedule

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP. (°F)	LOAD (MBH)
A9	WEZ - FK Frozen Food	6 ft	-25	2.70
	WIZ - FK Frozen Food	24 ft	-25	15.12
A10	WIZ Frozen Food	24 ft	-25	15.12
A11	WEZ - FK Frozen Food	6 ft	-25	2.70
	WIZ - FK Frozen Food	24 ft	-25	15.12
A12	ZER Ice Cream	14 DRS	-25	22.40
A13	ZER Ice Cream	13 DRS	-25	20.80
A14	Grocery Freezer	21x28x8 ft	-25	32.16
	Total			126.12

ASPEN SYSTEMS DEMONSTRATION RESULTS
-25°F SYSTEM

**Figure 4-10. - Weekly Refrigeration Load Profile
for the -25°F Rack**

The daily load profile, averaged for July and August of 1992, is shown in Figure 4-11 and indicates that the average load varies from 113 to 134 MBH during the course of the day. The maximum load occurs between 6 and 7 p.m. The actual hourly load has reached as high as 144 MBH, exceeding the design load by 14%. The speed of each screw compressor was increased to accommodate these peak loads and maintain suction pressure. The recips were not run during this period.

Figure 4-12 shows the performance with the open-drive screw compressor connected to the load. Figure 4-13 shows the performance when the semihermetic recip compressors are connected to the load. The performance is plotted against the SDT. The SDT is the saturated temperature corresponding to the compressor discharge pressure (measured at the discharge manifold). It is generally a few degrees higher than the condensing temperature, depending on the pressure drop between the compressor discharge and the condenser. The minimum SDT setpoint for the low-temp rack was 26°F. The suction temperature range for these graphs is -5 to 20°F.

ASPEN SYSTEMS DEMONSTRATION RESULTS
-25°F SYSTEM

Figure 4-11. - Average Daily Refrigeration Load Profile for the -25°F Rack

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
-25°F SYSTEM / HOWDEN 91mm / HCFC-22

Figure 4-12. - EER Performance of the Howden Open-drive Screw on the -25°F System

**Figure 4-13. - EER Performance of the Carlyle
Semihermetic Recips on the -25°F System**

It should be noted that with the RC-1000, selecting a suction setpoint for the low-temp rack is not as precise as desired, since the controller setpoint can only be set in increments of 1 psi. At -25°F, a 1-psi change in pressure for HCFC-22 produces a 2°F change in SST.

The data was smoothed and corresponding spline points were determined (see Section 3 for a complete description of this process). A second order curve was fitted through the spline points. As shown in Figure 4-12, there is a close agreement between field and laboratory results for the Howden compressor. The EER performance of the semihermetic recip shows close correspondence to the manufacturer's data (corrected for operating conditions). The published data were corrected for actual operating conditions and drive losses of the inverter.

The second-order curve fits for each compressor are compared in Figure 4-14. The results indicate that the screw is more efficient than the recips at SDTs below 73°F.

ASPEN SYSTEMS DEMONSTRATION RESULTS

-25°F SYSTEM / HCFC-22

Figure 4-14. - Comparison of the EER Performance of the Screw and Recip Compressors on the -25°F System

-15°F Suction Group Performance. The -15°F suction group consists of eight circuits with a total load of 177 MBH. Thirty-five percent of the load is contributed by the two ice machines, 17% by the service meat and dual-temp meat cases, 35% by the reach-in door cases, and the remaining 15% by the bakery freezer. A complete refrigeration schedule for this suction group is shown in Table 4-3.

Table 4-3. -15°F System Refrigeration Schedule

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP. (°F)	LOAD (MBH)
A1	Produce Ice - Howe		-5	32.40
A2	Fish Ice - Scotsman		-5	29.70
A3	ZER Frozen Foods	15 DRS	-15	21.00
A4	ZER Frozen Foods	14 DRS	-15	19.60
A5	ZER Frozen Foods	15 DRS	-15	21.00
A6	EGM - T Service Meat	24 ft	-15	9.60
A7	TZ - FK Dual Temp Meat Coffin	36 ft	-15	16.56
A15	Bakery Freezer	11x20x8	-15	26.66
	Total			176.52

The measured weekly load on this rack is shown in Figure 4-15. The peak weekly load of 170 MBH was reached in July of 1992. The daily load profile, averaged for June, July, and August of 1992, is shown in Figure 4-16 and indicates that the average hourly load varies from 132 to 163 MBH during the course of the day. The daily load profile on this system and on the -25°F system are closely tied to defrost schedules. Peaks in load typically occur after the defrost of a major circuit. The maximum load occurs between 8 and 9 a.m.

The maximum hourly measured load was 200 MBH, 23 MBH above the design load. Initially, the suction climbed above its setpoint during these high-load conditions. Increasing the maximum speed on the Howden compressor to 4000 rpm and on the Carlyle screw compressors to 2200 rpm provided better control during these high-load conditions.

During the fall of 1992, the load on this suction group was reduced when one of the two ice machines was disconnected. The store chose not to ice certain products. A significant decrease in average load is seen in the beginning of the year. Data collected since the summer of 1993 (not included in this report) clearly indicate this decrease in load.

Figure 4-17 shows the EER performance with the semihermetic recip compressor, while Figure 4-18 shows the performance with the open-drive screw compressor. The suction temperature range for these graphs is 0 to 25°F. Comparing the screw and reciprocating compressors' curve fits shows that the screw compressor exhibits higher efficiencies at SDTs below 90°F (Figure 4-19).

The EER performance of the screw compressor is similar to our lab results (Figure 4-18). The solubility of the refrigerant in oil is similar for the mineral and alkylbenzene oils. Therefore, the difference of the oils used in the laboratory and field tests has little effect on the compressor's performance. The EER performance of the semihermetic recip shows close correspondence to adjusted manufacturer data. The published data were corrected for actual operating conditions and drive losses of the inverter.

ASPEN SYSTEMS DEMONSTRATION RESULTS
-15°F SYSTEM / HCFC-22

Figure 4-15. - Weekly Refrigeration Load Profile
for the -15°F System

Figure 4-16. - Average Daily Refrigeration Load
Profile for the -15°F System

ASPEN SYSTEMS DEMONSTRATION RESULTS

-15°F SYSTEM / TWO CARLYLE 06ER175 / HCFC-22

Figure 4-17. - EER Performance of the Carlyle Semihermetic Recips on the -15°F System

ASPEN SYSTEMS DEMONSTRATION RESULTS

-15°F SYSTEM / ONE HOWDEN 91mm / HCFC-22

Figure 4-18. - EER Performance of the Howden Open-drive Screw Compressor on the -15°F System

ASPEN SYSTEMS DEMONSTRATION RESULTS
-15°F SYSTEM / HCFC-22

Figure 4-19. - Comparison of the EER Performance of the Screw and Recip compressors on the -15°F System

MED-TEMP DEMONSTRATION TESTING HISTORY AND RESULTS

History of the Med-Temp Rack

The med-temp refrigeration rack serves two suction groups: +15°F and +20°F. The +15°F system is composed of two, equal, open-drive reciprocating compressors. This system runs all the time. The +20°F system is composed of three sets of compressors: four semihermetic recips, three open-drive recips, and three open-drive screws. Only one of these compressor groups runs at any given time. As indicated in Table 4-1, the rack uses HFC-134a with a 300-SUS POE lubricant manufactured by CPI.

After initial startup of this rack, we had the normal debugging associated with any new installation. Several problems arose in the control and piping of the system. None of these were specific to the use of the HFC-134a refrigerant or the POE oil.

The receiver level varied dramatically. We determined that the charge was migrating to a non-operating, supposedly isolated section of the system. The charge passed by a defective check valve into the air reclaim coil. Once this was discovered, the defective valve was replaced.

Several items are worthy of note. We discovered that centralized filtration of oil can be inadequate for a multiple-screw compressor installation. Filtration should be installed at the oil inlet of each compressor. Inadequate filtration at the inlet to each screw allowed small metal chips to enter the compressor and cause severe bearing damage during these tests.

As discussed above, under Oil Management, mating of recip and screw compressors on the same rack can cause oil migration problems. Special attention must be given to the selection and installation of an adequate oil separator. Oil migration from the screw compressors to the reciprocating compressors must be eliminated. A mispiping of the med-temp rack's oil separator caused excessive oil carryover into the system. The oil would eventually migrate to the lowest pressure point in the system, the +15°F compressors. It apparently entered the compressors through their suction ports.

The reason for the excessive oil carryover was the improper piping of the med-temp oil separator. The oil separator is composed of two separate compartments and, due to the absence of oil floats in the piping, oil would externally flow from the first to the second compartment. This oil flow was then entrained by the discharge refrigerant flow leaving the oil separator. When the floats were added to the oil separator the problem was resolved.

Med-Temp Performance Results

+15°F Suction Group Results. The +15°F suction group consists of eight circuits with a total load of 239 MBH. Multideck cases make up the majority of the load with only 7% of the load being contributed by the enclosed service deli cases. A complete refrigeration schedule for this suction group is shown in Table 4-4. The measured average weekly load on this rack is shown in Figure 4-20. The peak weekly load of 205 MBH was reached during the second week of July 1993 (week 57). Outside temperatures reached 102°F during this week. The daily load profile, averaged for June, July, and August of 1993, is shown in Figure 4-21 and indicates that the average load varies from 158 to 212 MBH during the course of the day. The maximum load occurs at 5 p.m. and again at 8 p.m. The maximum hourly measured load was 242 MBH, essentially the design load.

Table 4-4. - +15°F System Refrigeration Schedule

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP (°F)	LOAD (MBH)
B21	HLM - T S.S. Meat	36 ft	15	43.20
B22	HLM - T S.S. Meat	24 ft	15	28.80
B23	LM - T Meat Coffin	12 ft	15	3.78
B24	5LMK S.S. Meat	24 ft	15	37.20
B25	HLM - T S.S. Fish	8 ft	15	9.60
B26	5LMK S.S. Cheese/Sandwich	40 ft	15	62.00
B27	EGM - T Service Deli	44 ft	15	17.60
B28	5LMK S.S. Meat	24 ft	15	37.20
	Total			239.38

Figure 4-20. - Weekly Refrigeration Load Profile for the +15°F System

Figure 4-22 shows the energy efficiency performance of the +15°F system. For this system, the suction had to be maintained slightly below the nominal 15°F and the average SST was 13.6°F. The field results are compared to the manufacturer's data for HFC-134a. As shown, there is a close correspondence between the two.

ASPEN SYSTEMS DEMONSTRATION RESULTS

+15°F SYSTEM

Figure 4-21. - Average Daily Refrigeration Load Profile for the +15°F System

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS

TWO CARLYLE 5H40 / +15°F RACK / HFC-134a

Figure 4-22. - EER Performance of the Carlyle Open-drive Recips on the +15°F System

+20°F Suction Group Results. The +20°F suction group consists of 20 circuits with a total load of 540 MBH. The coolers and prep rooms make up 48% of the suction group load. Dairy door cases account for 13%, and produce cases account for 24% of the load. The remaining 15% of the load is from the floral bakery and deli cases and also a small office A/C load. A complete refrigeration schedule for this suction group is shown in Table 4-5. Note that the case loads were taken at full value and not derated as recommended by Hill Refrigeration, the case manufacturer.

The measured weekly load on this rack is shown in Figure 4-23. The peak weekly load of 330 MBH was reached during the second week of July 1993 (week 55). Outside temperatures reached 102°F during this week. The peak hourly load was 432 MBH for this week, which is only 80% of the design load. The fact that the compressors are rarely required to operate simultaneously confirms that the actual refrigeration load is lower than design load.

Table 4-5. - +20°F System Refrigeration Schedule

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP. (°F)	LOAD (MBH)
B1	BER Dairy	8 DRS	20	11.20
B2	BER Dairy	15 DRS	20	21.00
B3	BER Dairy	10	20	14.00
B4	Dairy Cooler	14x47x8	20	64.19
B5	BER Beer	16 DRS	20	22.40
B6	Meat Cutting Room	26x30x10	20	60.41
B7	Meat Cooler	17x40x10	20	42.66
B8	Fish Cooler	8x14x8	20	7.52
B9	HLP - T Produce	84 ft	20	65.10
B10	EVIP Produce	12 ft	20	3.00
	VIP Produce	36 ft	20	23.40
B11	Produce Prep Room	20x24x10	20	31.20
B12	Produce Cooler	20x26x10	20	32.11
B13	HLP - T Produce	48 ft	20	37.20
B14	Deli Cooler	11x15x8	20	10.08
B15	VIP Deli	6 ft	20	3.90
B16	Floral, Revcon Swin - FR - 154	13 ft	20	13.00
B17	Bakery Prep Room	11x12x8	20	10.73
B18	SS Bakery, Revcon Screbr - 072	12 ft	20	4.80
	Service Bakery, Tcreb - R076	6.50 ft	20	2.60
B19	Service Meat Coil		20	14.40
B20	Office A/C		20	44.80
	Total			539.71

Figure 4-23. - Weekly Refrigeration Load Profile for the +20°F System

The daily load profile for late August and early September 1992 is shown in Figure 4-24. The customer count for the same period is also shown in this figure. Though the load generally increases with the number of customers, there is no direct correspondence between customers and load on this system. Peak loads generally occur at the end of certain circuit defrost cycles.

Figure 4-25 shows the performance results for the Carlyle semihermetic recip. The results are compared to the manufacturer's preliminary data for HFC-134a. A constant 7% penalty was assumed for using VFDs (Carlyle semihermetic data accounts for motor efficiency). The measured performance is slightly lower than the manufacturer's data. This can be attributed to system and cycling losses.

In Figure 4-26, the Bitzer open-drive recip EER data are compared to the manufacturer's published data. A 15% drive loss is used for the inverter, motor, and coupling losses. The data are slightly lower than the performance predicted by Bitzer at lower SDTs. Again, this can be attributed to system and cycling losses.

Figure 4-24 - Daily Refrigeration Load Profile for the +20°F System

Figure 4-25. - EER Performance of the Semihermetic Recip Section of the +20°F System

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS

+20°F RACK / THREE BITZER 6H2 / HFC-134a

Figure 4-26. - EER Performance of the Open-drive Recip Section of the +20°F System

The Howden screw compressor data are also lower than the expected performance (Figure 4-27). The data are close to the lab results for a 2.6-Vi compressor at high SDTs, but show a much lower EER performance as the head drops.

The screw compressors installed in the +20°F system were not supplied correctly for this application. The desired screw compressors would have had a Vi of 2.6. The internal volume ratio of a screw compressor determines the compression ratio that the gas undergoes before it is discharged. Of the three compressors installed in the +20°F system, two had a Vi of 3.6 and one had a Vi of 5.0. This means that they were over-compressing the refrigerant. Since the Vi of the compressors was not clearly marked on their nameplates, we only discovered this discrepancy when, after one year, the compressors were disassembled for inspection.

Figure 4-28 shows the curve fit through the field data of Figure 4-27 and reflects the Vi of the compressors used in the lab and in the field. Here the importance of selecting the correct Vi ratio for a screw compressor is clearly illustrated. At lower SDTs (lower compression ratios), the EER of the laboratory compressor is significantly higher since its Vi is better matched to med-temp refrigeration.

Figure 4-27. - EER Performance of the Open-drive Screw Section of the +20°F System

Figure 4-28. - Comparison of Laboratory and Field Performance of the Screw Compressor

Figure 4-29 compares the energy efficiency performance of the three compressors types that serve the +20°F refrigeration load. This figure clearly shows the advantage of using open-drive reciprocating compressors for this application. However, as explained above, the poor performance of the screw compressors could be deceiving. The results obtained in the laboratory are a better indicator of how correctly selected screw compressors would operate in the field.

A/C RACK DEMONSTRATION TESTING HISTORY AND RESULTS

History of the A/C Rack

The A/C refrigeration rack was sized for a cooling load of 100 tons. Three 6F.2 and one 4H.2 Bitzer compressors are driven directly off the electric bus with no inverters. The rack serves five roof-mounted air handlers.

From its startup, the A/C refrigeration rack experienced several operational problems. Improper selection (for HFC-134a operation) of the TXVs and the distributor orifice allowed the cooling coils in the evaporators to flood through. The orifice in the coil distributors was much too large; and the A/C TXVs should have been installed with an HFC-134a A/C charge. This improper installation damaged one of the four

Figure 4-29. - Comparison of the EER Performance of the Three +20°F Compressor Systems

compressors. By the end of July 1992, all of the five distributors had been replaced and a marked improvement in superheat was found. Before the change, the superheat was usually below 10°F, often close to zero. After the change, the superheat varied from 5 to 20°F.

In addition to the above-mentioned changes, the liquid pump was also turned off. The pump, which was installed in 1992, provided over a 50-psi differential increase in the liquid pressure. The added pressure at the inlet of the TXVs would aggravate the flooding condition. After the pump was shut off, the suction superheat increased to values ranging from 10°F to 30°F. Without this pump, we were unable to read the refrigerant flow properly and were thus unable to obtain any meaningful data during the summer of 1992. Later in 1992, a different liquid pump, which produced only 20 psid, was installed in order to allow us to measure the liquid flow.

Service technicians at the site noticed a fairly large pressure drop from the evaporator coil outlet to the mechanical room suction. During calibration of the pressure transducers, we measured a 3.8-psi difference from where the suction line entered the mechanical center to the compressor. Total suction line pressure drop was estimated at 14 psid under normal operating conditions. Approximately 0.4 psid can be attributed to the suction filters. When the 9,000 lb/hr flow is forced through two 2-1/8 in. valves upstream of the header, 3.4 psid is incurred. These valves are extremely undersized. Undersized valves in the air handler are suspected to contribute the remaining pressure drop. In order to compensate for this high pressure drop, the SST setting of the rack was lowered to +25°F instead of the nominal 40°F. A third valve was installed at the header to reduce the pressure drop.

After the above changes were completed, the rack was run at 38°F SST through June 1993. However, a hot period in the first week of July 1993 required that the SST be dropped to 32°F. This is due to the fact that at full capacity, the higher flow rate caused too much pressure drop to allow us to operate at 38°F SST. Flooding of the coils persisted into 1993. Readjustment of the TXVs helped produce positive superheats in the daytime, but nighttime flooding persisted. The flooding occurred when the VFD that controls the air handler fan motors dropped to 40% of full speed. The coils and TXVs could no longer control the refrigerant flow to produce superheat. The minimum speed was increased and a coil bypass damper was closed to alleviate the problem. In order to prevent this problem at low loads, a new split coil with separate TXVs would have been required.

A/C Rack Performance Results

The calculated A/C load for the store based on an 85°F outside temperature is 100 tons (1200 MBH). The average daily load profile during the summer week ending August 31, 1993 is shown in Figure 4-30. The outside temperature for the week and a typical customer count is also shown. The load jumps at 7 a.m., when the setting for the store temperature automatically changes from 75 to 72°F. As the outdoor temperature increases and the number of customers increases, the load rises. The maximum hourly average refrigeration load recorded was 72 tons.

The daily power profile (Figure 4-31) follows a pattern similar to the load. The maximum hourly average power recorded was 85.4 kW.

The correlation between outside ambient temperature and load is apparent in Figure 4-32. Figure 4-33 shows the variation of power with ambient temperature.

The energy efficiency of the system is shown in Figure 4-34. The data start from July 1993. Since there was significant scatter in the raw data, the data points were smoothed (see Section 3). The results presented in the figure are the smoothed data points. Data sets that included periods of flooding were not used. In Figure 4-34, a drive efficiency of 91%, representing the motor and coupling losses, was assumed for the Bitzer data. The A/C rack does not utilize VFDs. In addition, there is still nearly a 3-psid from the point where the suction line enters the compressor room and the compressor suction. The Bitzer data is corrected for this as well.

The measured EER is significantly lower than expected. The most likely cause is the cycling of the compressors and large swings in SST. During periods where a fixed number of compressors are on for extended periods, the EER will approach the expected values. This rarely happens, however. Most often, one of the three 6F2 compressors would be cycling on and off. (The smaller 4H2 has had repeated oil trips during the testing period and was often off-line.)

Considering all the issues that have arisen with this system, it is understandable that the measured EER has been lower than the Bitzer data. The relatively large capacity steps can also be responsible for the low performance of the compressors. The use of unloaders or unequal capacity compressors would reduce the capacity steps and improve the system's efficiency.

Figure 4-30. - Daily Refrigeration Load Profile for the A/C Rack

Figure 4-31. - Daily Power Consumption Profile of the A/C Rack

ASPEN SYSTEMS DEMONSTRATION RESULTS
A/C SYSTEM / THREE BITZER 6HF.2 AND ONE 4H.2 / HFC-134a

Figure 4-32. - Effect of Ambient Temperature on the A/C Load

ASPEN SYSTEM DEMONSTRATION RESULTS
A/C SYSTEM / THREE BITZER 6F.2 AND ONE 4H.2 / HFC-134a

Figure 4-33. - Effect of Ambient Temperature on the Power Consumption of the A/C Rack

ASPEN SYSTEMS DEMONSTRATION RESULTS
A/C SYSTEMS / THREE BITZER 6F.2 AND ONE 4H.2 / HFC-134a

Figure 4-34. - EER Performance of A/C Rack

In addition, the valve size at the air handlers and at the rack should be increased to reduce pressure loss. New evaporators would also alleviate the nighttime flooding. Split coils would allow better load matching and ensure superheat control.

SYSTEM ISSUES

TD Control

As part of these tests, we evaluated a temperature difference (TD) control algorithm for control of the condenser fans that was provided with the store's energy management systems. The condenser TD is the difference between the saturated condenser temperature (SCT) and ambient temperature. The algorithm was designed to optimize condenser fan cycling and maximize system EER. During July and August of 1992, the med-temp condenser was run with two different control schemes: TD control and all fans on. Two periods were examined: TD control was used during the week ending July 21, 1992, while all fans were used during the two week period ending August 18, 1992 utilized all condenser fans on. The Carlyle 06E semihermetic recip compressors were operating on the +20°F load during both periods.

The graphs indicate the recorded system power and system EER for each condition. The system power includes the power used by the condenser and the power for the liquid pump. As shown in Figure 4-35, the EER with the TD control is significantly lower through most of the SDT range.

When the TD control cycles the fans on, the liquid line pressure would drop and flashing would occur in the flow meter. This would cause erroneously low flow readings until the flash gas had cleared. To check whether our flow data were erroneous, we examined the system power readings (Figure 4-36). Clearly the TD control uses more power at SDTs above 65°F, but not as much as indicated by the EER results. The trend at low SDTs indicates that power consumption would be lower with TD control.

Another issue with the TD control algorithm was that it was not measuring the right control parameter. For the control algorithm to use the actual SCT, it would have needed a lookup table to convert the condenser pressure to its corresponding saturated temperature. In order to avoid the inclusion of this lookup table, the condenser temperature was estimated by measuring the liquid temperature in the dropleg from the condenser. The data indicate that the dropleg sensor measured a temperature up to 6°F lower than the saturated temperature at the receiver (because of ambient subcooling). This led to a higher condenser TD than desired (the TD control maintained an actual condenser temperature difference of 18.1°F). The TD control setpoint was 11°F.

In summary, the TD control algorithm as configured for this test did not reduce the power consumption. The rapid fan cycling caused instability in the system operation. The rapid cycling of the condenser fans would also be expected to wear the belts of the condenser fans much more rapidly.

Future testing should use a variable-speed control algorithm based on the actual SCT. Preliminary analysis indicates a substantial savings of condenser fan power with little change in compressor power. This should also help alleviate the instability and wear issues encountered with the fan cycling algorithm.

Figure 4-35. - System EER for the Med-Temp Rack Using Two Condenser Fan Control Algorithms

Figure 4-36. - System Power for the Med-Temp Rack Using Two Condenser Fan Control Algorithms

Liquid Pumps

Liquid pumps (also called liquid pressure amplifiers) are used by Hannaford Brothers in all their stores. The store operators have found that the additional pressure provided by the liquid pump eliminates most instances of liquid flashing at the cases.

Sealed, magnetic-drive, liquid pumps manufactured by Hansen were used in the liquid line of each system. These pumps delivered 50 to 60 psi of head. Later, in May 1993, these pumps were replaced with HySave equivalents that delivered only 20 psi of head.

The use of these pumps entails a significant energy penalty. We measured a 2 to 3°F increase in the liquid temperature across the pump. The power consumption of the pumps on the A/C and med-temp racks was 2.9 kW each. The low-temp pump power was 1.4 kW.

This energy cost should be balanced against the ability to aggressively float the head pressure. The compressor power results for the low-temp rack indicate a substantial decrease in power when the minimum SDT is reduced from 80°F to 40°F. Assuming a 120 MBH load on the -15°F and -25°F systems with recips on both suction groups, the total rack power would decrease from 32.30 kW at 80°F to 18.45 kW at 40°F. The net power savings is 13.85 kW.

The primary application concern with liquid pumps is to ensure that the pump has adequate liquid subcooling at its suction. The amount of liquid head equivalent to the minimum required subcooling is referred to as the net positive suction head (NPSH) requirement of the pump. The receiver for each system was therefore mounted at ceiling level in the mechanical center to provide adequate NPSH at the pump inlet. However, this precaution does not always prevent the pump from cavitating. Changes in system operation such as sudden drops in the head pressure can cause flashing at the pump inlet resulting in cavitation and premature pump failure.

Variable-Frequency Drives

We had originally planned to test the actual efficiency loss of the motor/inverter combination at the Glens Falls test site. The inability to maintain very stable operating conditions made this test impractical. We were, however, capable of carrying out this test in the lab, and found a drive efficiency of 97%, 1% lower than the published data on the drive.

Two application concerns with regard to the VFDs were noted. First is the selection of a single VFD to drive two compressors at once. A single, constant-torque VFD rated at the total of the two motor sizes was unable to provide the required starting torque. The next higher size was required to ensure adequate starting torque.

The second concern relates to the application of a VFD to a screw compressor. At the completion of the HCFC-22 testing, one of the low-temp screws was switched from inverter operation to across-the-line operation by one of the service personnel. The screw compressor failed shortly thereafter. The reason for the failure was reverse rotation of the screw rotors. A VFD drives a motor in a particular direction independent of the input phase sequence. If a VFD installation can be bypassed to run across the line, the motor's rotation must be verified before it is started. A low pressure switch was added to the discharge of the screw compressor to prevent the possibility of repeating this oversight.

OIL ANALYSIS

The oil from each rack was sampled and analyzed on a regular basis. The analysis examined the metal content, moisture level, and acid number. The results of the oil analysis for each system are shown in Table 4-6.

The oil from the low-temp rack had a consistently low metal content, moisture level, and acid number. Its moisture level and acid number history are shown in Figures 4-37 and 4-38, respectively. The low-temp compressors appear to be running with no abnormalities or wear.

Table 4-6. Glens Falls Store Oil Test Summary

	Low-Temp			Med-Temp			Air Conditioning		
	Max.	Min.	Last	Max.	Min.	Last	Max.	Min.	Last
Aluminum (ppm)	0.5	0.5	0.5	0.9	0.5	0.5	0.5	0.5	0.5
Copper (ppm)	4.7	0.1	0.1	14	0.1	1	6.1	0.3	3.1
Iron (ppm)	0.9	0.1	0.1	17	0.1	5.2	1.9	0.2	1.9
Tin (ppm)	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Zinc (ppm)	1.5	0.1	0.5	4.9	0.1	1	2.8	0.2	2.8
Moisture (ppm)	40	13	20	129	36	36	169	22	169
Acid Number	0.01	0.01	0.01	0.15	0.01	0.04	0.27	0.01	0.01

ASPEN SYSTEMS DEMONSTRATION RESULTS
LOW-TEMP RACK WITH ALKYL BENZENE OIL

Figure 4-37. - Moisture Level History for the Low-Temperature Rack

ASPEN SYSTEMS DEMONSTRATION RESULTS
LOW-TEMP RACK WITH ALKYL BENZENE OIL

Figure 4-38. - Acid Number History for the Low-Temperature Rack

The POE oil used in the med-temp and A/C racks is extremely hygroscopic and will generally have a higher moisture content than common mineral oils. The med-temp oil analysis has generally been very good. The Solest 68 POE oil had moisture contents much higher than those of traditional mineral oils (Table 4-6 and Figure 4-39). Every time the system was opened, a subsequent increase occurred in the measured moisture level. When the work was completed and the system was allowed to run undisturbed, the moisture level dropped significantly.

We were able to maintain moisture levels below 50 ppm. To achieve this we used Sporlan type HH filter driers in the liquid and oil feed lines. We had no moisture-related problems. The lubricant manufacturer, CPI, had been monitoring many systems including Glens Falls and found that moisture levels below 200 ppm have not caused any long term problems. The moisture is tightly bonded to the POE structure and will not easily break free. Thus, the water absorbed by these oils is not available to interact with the wetted parts of the system.

The acid number was first measured at over 0.1 (Figure 4-40). Later readings indicated a downward trend reaching a minimum of about 0.025. It finally stabilized at just under 0.040. Even though we operated near the maximum limit set for mineral oil acid numbers, CPI considers it normal for POE oils. CPI has monitored many systems using POE oil with acid numbers as high as 0.1 that have operated trouble-free.

Two compressors have been removed and dismantled for wear analysis. Wear patterns were similar to those found on compressors running with traditional refrigerants and lubricants.

Analysis of the Castrol SW32 POE oil in the A/C rack has also indicated high moisture levels. Readings varied between 22 and 169 ppm (Figure 4-41). Castrol indicated that readings below 200 ppm are normal and that readings as high as 400 ppm may be acceptable. As shown in Table 4-6, the oil in the A/C rack had a high copper content. This may be an indication that the compressors sustained some damage from liquid slugging. The acid number and the content of other metals were low (Figure 4-42).

Castrol also indicated that high measured moisture readings may not be indicative of actual moisture levels in the refrigeration system. Typically samples are "aired out" before shipping to allow dissolved refrigerant to escape from the oil and prevent

ASPEN SYSTEMS DEMONSTRATION RESULTS
MED-TEMP RACK WITH POE OIL

Figure 4-39. - Moisture Level History for the Med-Temp Rack

ASPEN SYSTEMS DEMONSTRATION RESULTS
MED-TEMP RACK WITH POE OIL

Figure 4-40. - Acid Number History for the Med-Temp Rack

Figure 4-41. - Moisture Level History for the A/C Rack

Figure 4-42. - Acid Number History for the A/C Rack

absorbs moisture during this process. Castrol also believes that the moisture may be migrating into the oil through the walls of the plastic shipping bottle.

It is important to note that specific maximum limits have not yet been determined for either moisture level or acid number. Both POE oil manufacturers recommend increased monitoring of systems that have moisture levels above 200 ppm. Acid numbers may also be high with POE oils. Both Castrol and CPI have indicated that acid numbers in the range of 0.1 to 0.2 could be acceptable.

Our testing to date has indicated that moisture levels up to 180 ppm for short periods are acceptable. We also found that moisture levels below 50 ppm are attainable in a tight system with POE oil. In the first few months of operation, the acid number for the med-temp oil was above 0.05. In subsequent months, it dropped below 0.05. We had no oil-related problems during the test period. During these tests, no discernible oil problems were discovered that could be attributed to the use of POE oil and HFC-134a.

RELIABILITY

Once the initial problems associated with an experimental demonstration were resolved, the systems reported no significant problems associated with the use of the alternative refrigerants or oils. Oil analysis repeatedly indicated no breakdown or wear problems.

The application of HCFC-22 to a low-temp system created a system operational liability. With HCFC-22, at high SDTs, the compressor discharge temperature can exceed the manufacturer's specification. To eliminate this problem, liquid is injected into the suction of the compressor. In our installation, a control sensor on the discharge line sensed discharge temperature. When this reached 210°F, a solenoid valve was opened and liquid was injected into the suction. A TXV was installed to regulate the flow, but the valves-sensing bulb was not attached. When the control sensor for this injection failed, the controller read it as a constant high temperature and allowed liquid to dump uncontrolled into the compressor suction. This eventually led to failure of one of the recip compressors.

For HCFC-22 applications that require liquid injection, a secondary sensor should be installed to de-energize the liquid injection if the suction is too cold. In addition, the TXV bulb should be attached and insulated.

Other reliability issues that have arisen are either related to operational issues or the nature of the experimental setup. The A/C operation with variable-speed air-handler fan allowed many periods of liquid flooding in the suction line. Since there was only one full-size coil with a single expansion valve, at partial air handler fan speeds (lower loads), the expansion valve was too large to control the liquid refrigerant flow. The initial use of suction solenoids to isolate the air handlers and a liquid pump with nearly 60 psi of head in the liquid line contributed to this problem. This led to gasket failures and indications of excessive wear.

Oil filtration for multiple-screw compressor installations must provide protection of each compressor. The +20°F system required three compressors to meet the design load. A single filter was installed in the oil line out to the oil cooler. This single filter was too remote from the individual compressors to prevent small metal chips from entering the compressor oil injection port and causing significant damage to the compressor bearings. Future installation should incorporate oil filtration at the oil injection port of each screw compressor.

PROJECTED ANNUAL PERFORMANCE AND ENERGY COSTS

We used the second-order curve fits of the data to calculate the AEER of the refrigeration systems. The analysis utilized bin temperature data from Albany, NY (8). Since there were several operational issues concerning the A/C rack, we are unable to present a reasonable seasonal EER value for this rack.

For the low-temp analysis, the semihermetic recip was chosen as the base system. The semihermetic recip is the industry standard for supermarket refrigeration. The low-temp analysis shown in Table 4-7 clearly indicates that the screw compressor has a higher AEER and a lower annual operating cost.

Apart from the discrepancy caused by the incorrect volume ratios (see above), the data on the +20°F system were consistent with our expectations. The AEER for the open-drive reciprocating compressors was 14.82 (Table 4-8). For the semihermetic reciprocating compressors, the AEER was 13.39. On the basis of these figures, the annual operating cost savings of the open-drive system versus the semihermetic system is about \$1600, based on \$0.10/kWh, including energy and demand costs.

**Table 4-7. Annual Energy Usage and Cost of Glens Falls
Low-Temp Refrigeration Systems**

-25°F System					
Compressor	System	Annual	Annual Energy	Operating	Cost
	No.	EER	Consumption	Cost	Difference
		BTU/W-HR	KW-HR	\$/YR	\$/YR
Open-Drive Screw	2	7.37	142,624	14,262	-925
Semihermetic Recip	3	6.92	151,874	15,187	BASE
Refrigeration Load = 120 MBH.					
Minimum SDT = 40°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kw-hr (Including demand charges).					
-15°F System					
Compressor	System	Annual	Annual Energy	Operating	Cost
	No.	EER	Consumption	Cost	Difference
		BTU/W-HR	KW-HR	\$/YR	\$/YR
Open-Drive Screw	2	8.89	118,244	11,824	-802
Semihermetic Recip	3	8.33	126,263	12,626	BASE
Refrigeration Load = 120 MBH.					
Minimum SDT = 40°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kw-hr (Including demand charges).					

A significant energy and cost penalty is associated with the improper Vi selection of the +20°F screw compressors. In terms of AEER, selecting the wrong Vi results in 16% higher energy consumption. As shown in Table 4-8, the annual EER based on the field data is 13.01, whereas the laboratory data yield an AEER of 15.11. On the basis of these figures, an increased cost of \$2,353 was incurred. This emphasizes the importance of selecting the correct Vi when installing a screw compressor. Unless a refrigeration system is selected and installed correctly, it will not yield the energy efficiency that an engineering analysis predicts.

ECONOMIC ANALYSIS

Though a particular system may be more energy efficient than others, the system's economic benefit must be favorable to justify its use. For this analysis, we examined the LCC of the different options tested. The economic analysis performed is described in Appendix B. The economic descriptors calculated were: the LCC, the NPVS, the ROI, and the simple payback period. Table 4-9 lists the parameter values used for this analysis.

**Table 4-8. Annual Energy Usage and Cost of Glens Falls
Med-Temp Refrigeration Systems**

+15°F System					
Compressor	System	Annual	Annual Energy	Operating	
	No.	EER	Consumption	Cost	
		BTU/W-HR	KW-HR	\$/YR	
Open-Drive Recip	5	12.97	107,758	10,776	
Refrigeration Load = 160 MBH.					
Minimum SDT = 65°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/kw-hr (Including demand charges).					
+20°F System					
Compressor	System	Annual	Annual Energy	Operating	Cost
	No.	EER	Consumption	Cost	Difference
		BTU/W-HR	KW-HR	\$/YR	\$/YR
Open-Drive Recip	6	14.82	148,914	14,891	-1,596
Semihermetic Recip	7	13.39	164,869	16,487	BASE
Open-Drive Screw	5	13.01	169,653	16,965	478
Open-Drive Screw	(a)	15.11	146,124	14,612	-1,875
Refrigeration Load = 252 MBH.					
Minimum SDT = 65°F.					
Albany bin temperature data used for analysis.					
Cost based on 0.10 \$/KW-hr (Including demand charges).					
(a) Energy usage based on laboratory performance.					

**Table 4-9. - Parameters Used in the Economic
Analysis**

DISCOUNT RATE	7	%
COST OF ELECTRICITY	0.1	\$/KW-HR
ELECTRICITY ESCALATION RATE	5	%/YR
MAINTENANCE COST (RECIPS)	1,000	\$/YR
MAINTENANCE COST (SCREWS)	900	\$/YR
MAINTENANCE COST ESCALATION	5	%/YR
SALVAGE VALUE	500	\$
SYSTEM LIFE	15	YR

The initial costs for the refrigeration racks were obtained from Phoenix Refrigeration based on systems whose capacities matched the refrigeration loads. These loads are close to the actual measured loads in Glens Falls. There were slight variations between these capacities and the capacities of the systems actually installed. Table

4-10 summarizes the economic comparison of the semihermetic recip and the open-drive screw compressor on the -25°F and -15°F loads. The open-drive screw has a significant advantage over the semihermetic recip. The payback period of approximately three years may be attractive to a supermarket given the reduced risk of slugging and consequent food spoilage.

Table 4-11 summarizes the economic comparison of the three compressor types on the +20°F system. The open-drive recip, despite their clear EER advantage, may not be economically justifiable due to the six years required to pay back the additional capital cost.

Table 4-10. Economic Comparison of Low-Temp Refrigeration Systems Using HCFC-22

-25°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	YR
Semihermetic Recip	23,000	15,187	1,000	500	232.3	BASE SYSTEM		
Open-Drive Screw	26,000	14,262	900	500	222.0	10,265	40.4	2.9
-15°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	YR
Semihermetic Recip	23,000	12,626	1,000	500	199.2	BASE SYSTEM		
Open-Drive Screw	26,000	11,824	900	500	190.5	8,672	35.9	3.3

Table 4-11. - Economic Comparison of Med-Temp +20°F Refrigeration Systems Using HFC-134

SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINT. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	MWH	\$	\$	\$1000	\$	%	YR
SEMI - RECIP	28,934	164.9	1,000	500	255.1	BASE SYSTEM		
OPEN - RECIP	38,327	148.9	1,000	500	243.8	11,255	20.6	5.9
OPEN - SCREW	45,821	169.7	900	500	276.8	-21,784	****	****
OPEN - SCREW*	45,821	146.1	900	500	246.4	8,666	13.5	8.6

* Based on lab results with properly selected compressor Vi

In this analysis, the open-drive screws fare poorly when the field results from the improperly selected compressors are used. An evaluation based on the laboratory results is also shown to illustrate the potential economic benefit when the screws are properly selected. However, even with the proper Vi, the payback period of 8.6 years hardly justifies the additional capital cost.

This analysis assumes a rate for electricity that includes both fuel and demand charges. Starting in December 1992, we began measuring store power and demand. In the second phase of this project, we will examine the effect of the individual racks on total store power and the monthly demand.

SUMMARY

All refrigeration systems in the Glens Falls store operated well and within the expected performance range. On a rack-by-rack basis, the following summarizes the results we obtained.

Low-Temp

- We did not expect and did not experience any problems with the low-temp HCFC-22 system. The data collected for the Howden screw compressor show similar performance to Aspen Systems' laboratory data.
- The screw compressor provided 7% better AEER than the recips for both -25°F and -15°F suction groups. Economic analysis indicates a payback period of about three years.

Med-Temp

- Our experience with HFC-134a in the med-temp rack was extremely favorable. We have observed no incompatibility problems between HFC-134a, its POE lubricant, and the rest of the system. HFC-134a appears to be a trouble-free long-term refrigerant replacement for med-temp refrigeration.
- All compressor systems on the med-temp rack performed as expected, except for the screw compressors. The open-drive reciprocating compressors showed the best AEER at 14.82 Btu/W-hr.
- The Vi ratio of the open-drive screws was not optimized. According to our laboratory results, with the correct Vi, the open-drive screws would have performed at least as efficiently as the open-drive reciprocating compressors.
- Economic analysis indicates lengthy payback periods for the open-drive recips and open-drive screws compared to semihermetic recips.

Air Conditioning

- From its start-up, the A/C refrigeration rack experienced several operational problems. These problems included: improper selection of TXVs and distributor orifices for HFC-134a operation, flooding of compressors, a high pressure difference across the liquid pump, and a substantial pressure loss in the rack's suction line.
- The measured EER for the A/C rack was significantly lower than expected. The most likely cause for this is the cycling of the compressors and large swings in SST.
- The performance results of the A/C rack are not completely reliable since few data were collected after its operational problems were corrected.

TECHNOLOGY TRANSFER

Section 5

IN THIS SECTION

PUBLICITY

PRESENTATIONS

PUBLICITY

The following is a brief description of some of the publicity about this project as of November 1, 1992.

1. Associated Press Article on the Glens Falls store released the week of June 1, 1992. This article appeared in many papers nationwide during the week it was issued.
2. Consulting-Specifying Engineer, May 18, 1992, News in Review, "First supermarket non-CFC refrigeration and air conditioning systems installed." This contained a brief description of the Glens Falls refrigeration systems and mentioned the funding authorities. There was also an excellent picture of all three of the low temperature screw compressors.
3. Engineered System, May 1992, "Screw Compressors Make The Grade In Supermarkets." This general article on screw compressors in supermarkets had several large sections devoted to the testing being done by Aspen Systems. It included two pictures of the rack at Clifton Park and one of the rack at Aspen Systems.
4. Store Equipment and Design, March/April 1992, "Shop 'N Save in first U.S. test of non-H/CFC". This article presents some of the results of Clifton Park tests and details the Glens falls refrigeration systems. There is also a listing of the project funding agencies and project participants.
5. Air Conditioning, Heating and Refrigeration News, April 27, 1992, "New supermarket uses HFC-134a for medium temperature refrigeration". This is a broad overview of the refrigerants and compressors installed at the Glens Falls store. The project participants and the funding agencies are listed.
6. Glens Falls Store Opening Ceremony, March 23, 1992. This event was covered by several newspaper reporters including one from the New York Times. Several local television stations also covered the ceremony. Hannaford received an award from the American Lung Association at this ceremony for using non-CFCs in this store. Advertisements announcing the opening of the non-CFC store were placed in the New York Times and the Wall Street Journal by Hill Refrigeration, Carlyle Compressor, and Phoenix Refrigeration.
7. Televised CNN spots on the Glens Falls store were aired on the 4th and 5th of January 1992.

8. ASHRAE Journal, November 1991, Industry News, "R-134a test installation planned." This short piece had an overview of the Glens Falls demonstration site and a picture of a technician working on a refrigeration rack. A partial list of project participants and funding agencies was included.

PRESENTATIONS

1. 1992 International CFC Halon Alternatives Conference, September 1992, "HFC-134a and HCFC-22 Supermarket Refrigeration Demonstration." Paper by Messrs. Ray Albrecht, Hamed Borhanian, and Lenley Rafuse. This paper was presented at the conference by Mr. Borhanian. The paper had a description of the Glens Falls demonstration site and preliminary test results, and listed all project participants.
2. FMI Conference, September 1992, Two presentations by project participants Mr. Charlie Bizilj of Howden Compressors and Mr. Tom Mathews of Hannaford Bros., included preliminary results from the Glens Falls demonstration site.
3. NSP's Grocery Manager/Operator Seminar, October 1992, Cosponsored by EPRI. Mr. Hamed Borhanian presented preliminary results from Glens Falls.
4. Ontario Hydro's Symposium on Meeting Supermarket Needs, November 1992. Mr. Tom Mathews presented preliminary results from Glens Falls.

REFERENCES

Section 6

1. Borhanian, H., "Commercial Refrigeration Screw Compressor System Development and Demonstration - Final Report," NYSERDA, 938-EEED-AEP-87, Aspen Systems, Inc., 1993.
2. Borhanian, H., and Toscano, W. M., Lee, K. P., "Development and Testing of a Screw Compressor Supermarket Refrigeration System - Phase II final Report," DOE/Bonneville Power Administration, DOE/BP-15105-2, Aspen Systems, Inc., December 1986.
3. Bergles, A.E., et al., Two Phase Flow and Heat Transfer in the Power Industry, Hemisphere Publishing Co., 1981, 1:18-20.
4. Ganic, E.N., et al., Handbook of Heat Transfer Fundamentals, McGraw Hill, 1985, 13:32-38.
5. Schoen, A., "Resolving TEV Hunting Problems," Heating/Piping/Air Conditioning, July 1990.
6. Short, G. D., Sjolholm L. I., "Twin Screw Compressor Performance and Complex Ester Lubricants with HCFC-22," Proceedings of the 1990 International Compressor Engineering Conference, Purdue University, July 17-20, 1990.
7. Toscano, W.M., et al., "Research and Development of Highly Energy-Efficient Supermarket Refrigeration Systems, Vol. 1 - Executive Summary and Task Reports", ORNL/Sub/80-61601/1, October 1981.
8. "Engineering Weather Data," U.S. Air Force, AFM 88-29, PM5-785. Obtained from Niagara Mohawk Power Corporation.
9. "Protection of Stratospheric Ozone; Refrigerant Recycling," 40 CFR Part 82, Federal Register Vol. 58, No. 92, May 14, 1993.

WEEKLY HISTORY OF GLENS FALLS REFRIGERATION RACKS

Appendix A

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE -25°F RACK, HCFC-22

			MANUALLY RECORDED DATA			DOWNLOADED DATA AVERAGE RESULTS					
Date	Time	Compressor	kWh	Duration	Ave Power	SST F	SDT F	LOAD MBH	POWER KW	EER	POWER BALANCE %
7/21/92	13:55	Carlyle	4240	169	23.8	-21.7	89	125	24.5	5.1	-2.7
7/28/92	10:25	Carlyle	3880	165	22.4	-22.2	82	126	22.5	5.6	-0.5
8/4/92	9:00	Carlyle	4000	167	22.8	-22.4	84	126	22.6	5.6	0.9
8/11/92	8:20	Carlyle	3880	167	22.0	-22.0	84	126	22.1	5.7	-0.5
8/18/92	16:00	Carlyle	3880	176	21.0	-21.8	81	122	21.1	5.8	-0.5
9/1/92	14:00	Carlyle	7960	334	22.6	-21.6	85	115	22.7	5.1	-0.1
9/8/92	12:05	Carlyle	3760	166	21.5	-22.8	80	114	21.9	5.2	-1.6
9/15/92	11:15	Carlyle	3720	167	21.1	-23.3	78	116	21.0	5.5	0.7
9/22/92	14:15	Carlyle	3840	171	21.3	-21.7	80	120	21.1	5.7	1.2
9/29/92	11:45	Carlyle	3200	166	18.4	-24.0	71	123	18.5	6.6	-0.8
10/6/92	10:15	Carlyle	2800	166	16.1	-24.1	65	110	15.9	6.9	1.3
10/13/92	10:30	Carlyle	3040	168	17.2	-23.9	68	117	17.2	6.8	-0.2
10/20/92	10:35	Carlyle	2880	168	16.3	-24.3	63	114	16.2	7.0	0.8
10/27/92	14:30	Howden	2640	168	15.0	-22.7	61	111	14.8	7.5	1.0
11/3/92	11:15	Carlyle	2640	168	14.9	-24.3	58	110	14.9	7.4	0.1
11/10/92	11:00	Howden	2520	168	14.3	-23.9	58	105	14.3	7.3	-0.7
11/17/92	11:30	Carlyle	2640	169	14.9	-24.0	59	110	14.8	7.4	0.3
11/24/92	11:20	Howden	2120	167	12.0	-16.4	59	117	12.4	9.5	-2.5
12/1/92	11:20	Carlyle	2760	168	15.6	-24.4	61	133	15.6	8.5	0.2
12/8/92	11:20	Howden	2440	168	13.8	-23.8	58	121	13.6	8.9	1.6
12/15/92	11:05	Carlyle	2320	168	13.1	-24.4	56	110	13.0	8.4	0.8
12/22/92	11:05	Howden	2520	173	13.8	-22.0	61	107	13.8	7.8	0.4
12/30/92	11:10	Carlyle	2240	163	13.1	-24.4	54	107	13.0	8.2	0.4
1/5/93	11:05	Howden	2520	168	14.3	-23.8	60	107	14.3	7.5	-0.7
1/12/93	13:30	Carlyle	2360	168	13.3	-24.6	52	103	13.1	7.9	1.8
1/19/93	n/a	Backup	2400	173	13.2	-24.7	55	96	13.3	7.2	-0.6
1/26/93	11:25	Backup	2200	164	12.8	-24.7	46	107	12.7	8.4	0.4
2/2/93	n/a	Carlyle	1840	168	10.4	-23.2	35	109	10.4	10.5	0.5
2/9/93	11:40	Carlyle	1800	169	10.1	-23.7	37	109	10.3	10.6	-1.1
2/16/93	11:10	Carlyle	2040	168	11.6	-24.4	41	118	11.5	10.2	0.7
2/23/93	11:15	Howden	1680	168	9.5	-21.8	35	114	8.9	12.8	6.4
3/2/93	12:20	Carlyle	2160	169	12.2	-22.4	42	108	12.2	8.9	0.1
3/9/93	10:10	Backup	2160	166	12.4	-21.2	49	97	12.4	7.9	0.2
3/16/93	12:10	Howden	1760	170	9.9	-21.5	41	106	10.4	10.2	-4.7
3/23/93	1:00	Carlyle	3040	168	17.2	-21.9	64	104	16.9	6.2	1.7
3/30/93	11:30	Backup	3480	151	21.9	-21.3	80	92	22.2	4.2	-1.3
4/6/93	11:00	Howden	4360	167	24.8	-20.1	94	103	24.9	4.1	-0.5
4/13/93	10:40	Backup	4320	169	24.3	-22.8	63	107	24.4	4.4	-0.5
4/20/93	9:10	Carlyle	3160	167	18.0	-23.8	67	124	18.1	6.8	-0.1
4/27/93	9:00	Backup	4560	168	25.7	-23.3	66	109	25.7	4.3	0.3
5/4/93	19:10	Howden	4400	168	25.0	-20.5	73	114	25.0	4.6	-0.1
5/11/93	n/ap	Carlyle	-	-	-	-18.9	81	118	21.2	5.6	-

Note:

1. Alternate running of three banks of compressors: two 33 CFM Carlyle screws and one 91mm Howden screw, two Carlyle 06ER175 Backup compressors.
2. The date shown is the last day of the period (usually one week) during which data was taken.
3. The Power Balance is a comparison of manually recorded power from the watt meters and the power determined from the downloaded data.

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE -25°F RACK, HCFC-22

HISTORY OF MODIFICATIONS:

7/14/92 Begin reliable data collection.
8/19/92 Carlyle oil Filter pressure added.
8/26/92 Economizer SH high; adjusted down.
9/1/92 RC-2 firmware failure; 5.0E firmware installed. Data from this RC for this week lost.
9/24/92 Oil float lock-out disabled.
10/1/92 Economizer TXV changed from GA to C head. SH adjusted.
10/13/92 Economizer TXV SH adjusted down.
10/20/92 Suction settings for Carlyle operation were 7/7 5/5.
Settings for Howden 7/7.
11/11/92 Economizer TXV changed. Excessive contaminants found in valve.
11/24/92 Setpoint not changed at previous switchover.
1/7/93 -15 and -25 kWh meter swapped. No change in power readings noted.
1/19/93 Backup compressors added into alternation.
Test points removed from RC-1000 by electrician. RC-1000 data lost.
1/21/93 Removed and reinstalled refrigerant charge. Disabled air heat reclaim.
2/1/93 Condenser minimum pressure increased from -35 to 50 psig.
2/2/93 Flow meter re-zeroed. Large offset found.
2/10/93 Subcooler TXV began flooding thru.
Feb-93 Carlyle oil filter changed; exact day not known.
Feb-93 Downloaded data time period is shorter than full week causing power discrepancy.
3/9/93 P5, P5a, P10 pressure checked; offsets adjusted. Measured 6 psid across filter.
Pressure differential set at 6 psid across oil pressure regulating valve
3/29/93 Backup compressor C1 failed. Switched to Carlyle screw.
3/30/93 Subcooler TXV repaired.
4/27/93 Carlyle opens removed.
5/4/93 Hansen liquid pumps removed; Hysave liquid pump #835 installed.
Carlyle backup C1 failed connecting rod; 05/06 switched to Carlyle
High liquid injection flow is suspected cause.
Discharge temperature sensor used to control liquid injection failed.
5/6/93 New Carlyle Semihermetic screw installed.
5/9/93 Carlyle compressor failed; XL reverse rotation is suspected cause.
5/11/93 Low temperature rack switched over to CFC-502 from HCFC-22.

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE -15°F RACK, HCFC-22

			MANUALLY RECORDED DATA			DOWNLOADED DATA AVERAGE RESULTS						
Date	Time	Compressor	kWh	Duration	Ave Power	SST F	SDT F	LOAD MBH	POWER kW	EER	POWER BALANCE %	
7/14/92	13:00	Howden	3840	169	21.6	*****	*****	*****	*****	*****	*****	
7/21/92	13:55	Howden	3960	169	22.3	-18.5	89	143	23.2	5.8	-3.9	
7/28/92	10:25	Howden	3600	165	20.8	-11.2	82	134	20.9	6.1	-0.5	
8/4/92	9:00	Howden	3800	167	21.7	-11.7	84	140	21.7	6.1	0.0	
8/11/92	8:20	Howden	3880	167	22.0	-13.3	84	152	21.9	6.6	0.4	
8/18/92	16:00	Howden	4000	176	21.6	-14.1	81	161	21.6	7.1	0.3	
9/1/92	14:00	Howden	8240	334	23.4	-14.6	85	156	23.6	6.3	-0.5	
9/8/92	12:05	Howden	3920	166	22.4	-16.3	80	149	22.3	6.3	0.4	
9/15/92	11:15	Howden	3800	167	21.6	-16.7	78	149	21.6	6.5	0.1	
9/22/92	14:15	Howden	4000	171	22.2	-16.4	80	154	22.2	6.6	0.0	
9/29/92	11:45	Howden	3440	166	19.7	-19.4	71	169	19.6	8.2	0.9	
10/6/92	10:15	Howden	3040	166	17.5	-21.1	65	145	17.4	8	0.4	
10/13/92	10:30	Howden	3240	168	18.3	-20.5	68	138	18.1	7.2	0.8	
10/20/92	10:35	Howden	2760	168	15.6	-17.7	63	140	15.6	8.5	0.1	
10/27/92	14:30	Carlyle	2760	168	15.6	-18.2	61	132	15.6	8.1	0.4	
11/3/92	11:15	Howden	2320	168	13.1	-16.2	58	128	13.2	9.3	-0.7	
11/10/92	11:00	Carlyle	2680	168	15.2	-18.5	58	133	15.1	8.4	0.3	
11/17/92	11:30	Howden	2280	169	12.8	-16.0	59	130	12.6	9.5	1.6	
11/24/92	11:20	Carlyle	2600	167	14.8	-18.2	59	127	14.9	9.7	-1.0	
12/1/92	11:20	Howden	2480	168	14.0	-16.4	61	131	14.2	8.1	-0.9	
12/8/92	11:20	Carlyle	2440	168	13.8	-18.4	58	126	13.8	8.8	0.2	
12/15/92	11:05	Howden	2000	168	11.3	-16.3	56	116	11.4	9.7	-0.8	
12/22/92	11:05	Carlyle	2720	173	14.9	-19.2	61	122	14.7	7.9	1.4	
12/30/92	11:10	Howden	1840	163	10.7	-16.3	54	108	10.8	9.5	-0.9	
1/5/93	11:05	Carlyle	2520	168	14.3	-19.0	60	115	14.3	7.6	-0.7	
1/12/93	n/a	Howden	2040	168	11.5	-16.3	52	109	11.3	9.9	2.0	
1/19/93	n/a	Howden	2040	173	11.2	-16.3	55	109	11.2	9.3	0.2	
1/26/93	11:25	Howden	1840	164	10.7	-16.1	46	110	10.7	9.7	-0.4	
2/2/93	n/a	Backup	1560	168	8.8	-16.3	35	104	8.9	11.1	-1.2	
2/9/93	11:40	Backup	1560	169	8.8	-16.2	37	115	8.8	12.3	-0.4	
2/16/93	11:10	Howden	1680	168	9.5	-16.2	41	115	9.5	11.5	0.3	
2/23/93	11:15	Carlyle	1720	168	9.7	-15.0	35	114	9.0	12	7.8	
3/2/93	12:20	Backup	1760	169	9.9	-14.0	42	112	9.9	10.8	0.4	
3/9/93	10:10	Howden	1960	166	11.2	-16.3	49	119	11.3	10	-0.6	
3/16/93	12:10	Carlyle	1760	170	9.8	-15.5	41	109	9.8	10.7	0.7	
3/23/93	1:00	Backup	2360	168	13.3	-17.1	64	104	13.2	7.5	1.1	
3/30/93	11:30	Howden	3240	167	18.4	-15.7	80	115	18.5	5.9	-0.5	
4/6/93	11:00	Carlyle	4360	167	24.8	-15.6	94	112	25.3	4.3	-2.0	
4/13/93	10:40	Howden	2360	169	13.3	-15.7	63	110	13.3	7.9	-0.3	
4/20/93	9:10	Backup	2600	167	14.8	-16.2	67	114	14.9	7.3	-0.6	
4/27/93	9:00	Howden	2600	168	14.7	-15.7	66	124	14.7	8	-0.3	
5/4/93	19:10	Backup	3200	168	18.1	-17.8	73	109	18.1	5.8	0.5	
5/11/93	n/ap	Howden	-	-	-	-15.0	81	118	20.0	5.6	-	

- Note:
1. Alternate running of two banks of compressors: Two 33 CFM Carlisle screws and One 91mm Howden screw.
 2. The date shown is the last day of the period (usually one week) during which data was taken.
 3. The Power Balance is a comparison of manually recorded power from the watt meters and the power determined from the downloaded data.

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE -15°F RACK, HCFC-22

HISTORY OF MODIFICATIONS:

7/14/92 Begin reliable data collection.
7/28/92 Oil separator repiped.
8/25/92 Suction pressure offset accidentally altered in field.
9/24/92 Suction pressure offset changed, wrong sign entered lowering suction control setpoint instead of raising it.
10/1/92 Economizer TXV head changed from GA to C.
10/13/92 Howden tripped for unknown reason
10/15/92 Suction offset corrected. Economizer SH adjusted down 5 deg F.
10/20/92 Suction settings changed for -15 operation: Carlyle 11/11 10/10
for Howden 11/11
11/17/92 Liquid RTD defective. RC-1000 thermistor used for calculations
12/1/92 Liquid RTD replaced.
1/7/93 -15 and -25 kWh meter swapped. No change in power readings noted.
1/19/93 Test points removed from RC-1000 by electrician. RC-1000 data lost.
1/21/93 Removed and reinstalled refrigerant charge. Disabled air heat reclaim.
2/1/93 Condenser minimum pressure increased from 35 to 50 psig.
2/2/93 Flow meter re-zeroed. Insignificant offset found.
2/16/93 Carlyle settings changed from 11/11 10/10 to 12/12 11/11
2/22/93 Leak in butcher case repaired. Carlyle off on low oil.
2/23/93 Down loaded data time period is shorter than full week causing power discrepancy.
5/4/93 Hansen liquid pumps removed; Hysave liquid pump #835 installed.
Carlyle backup C1 failed connecting rod; 05/06 switched to carlyle
High liquid injection flow is suspected cause.
Discharge temperature sensor used to control liquid injection failed.
Control chanded to one XL and on inverter driven. XL setpoint 6 psig, inv 7psig.
5/11/93 Low temperature rack switched over to CFC-502 from HCFC-22.

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE +15°F RACK - HFC-134a

						DOWNLOADED DATA: AVERAGE RESULTS					
Date	Time	Compressor	kWh	Duration	Ave. Power	SST	SDT	LOAD	POWER	EER	POWER BALANCE %
6/30/92	13:00	Carlyle 5H40	3920	170	23.1	10.1	101	187.2	23	7.30	0.6
7/7/92	11:55	Carlyle 5H40	3520	166	21.2	10.2	90	181.2	21.5	8.70	-1.3
7/14/92	13:00	Carlyle 5H40	3920	169	23.2	10.1	94	182.4	24.5	8.00	-5.4
7/21/92	13:55	Carlyle 5H40	3680	169	21.8	9.9	95	180	22.5	8.00	-3.2
7/28/92	10:25	Carlyle 5H40	3120	165	19.0	9.6	88	171.6	18.9	9.00	0.4
8/4/92	9:00	Carlyle 5H40	3160	167	19.0	9.9	87	182.4	18.8	9.70	0.9
8/11/92	8:20	Carlyle 5H40	3040	167	18.2	9.9	87	183.6	18.5	9.90	-1.8
8/18/92	16:00	Carlyle 5H40	3080	176	17.5	10.1	85	180	17.6	10.20	-0.4
9/1/92	14:00	Carlyle 5H40	6320	334	18.9	9.4	88	163.2	19.4	8.40	-2.5
9/8/92	12:05	Carlyle 5H40	3120	166	18.8	8.1	87	111.6	18.7	6.00	0.4
9/15/92	11:15	Carlyle 5H40	3160	167	18.9	7.3	86	177.6	19.1	9.30	-1.0
9/22/92	14:15	Carlyle 5H40	3280	171	19.2	7.5	86	171.6	18.9	9.00	1.5
9/29/92	11:45	Carlyle 5H40	2800	166	16.9	7.3	82	157.2	17	9.20	-0.5
10/6/92	10:15	Carlyle 5H40	2040	166	12.3	14.3	75	98.4	12.3	8.00	0.2
10/13/92	10:30	Carlyle 5H40	2120	168	12.6	16.6	79	142.8	12.6	11.30	0.0
10/20/92	10:35	Carlyle 5H40	1920	168	11.4	16.9	76	142.8	11.5	12.50	-0.7
10/27/92	10:15	Carlyle 5H40	1720	168	10.3	18.3	72	136.8	10.2	13.40	0.6
11/3/92	10:15	Carlyle 5H40	1440	168	8.6	19.5	63	132	8.3	15.8	3.3
11/10/92	10:15	Carlyle 5H40	1320	168	7.9	19.5	63	130.8	7.9	16.4	-0.5
11/17/92	11:00	Carlyle 5H40	1320	169	7.8	19.4	61	130.8	7.8	16.8	0.3
11/24/92	10:20	Carlyle 5H40	1720	167	10.3	14.3	65	142.8	10.4	13.7	-1.2
12/1/92	10:15	Carlyle 5H40	1800	168	10.7	13.5	65	141.6	10.7	13.2	0.2
12/8/92	10:15	Carlyle 5H40	1520	168	9.0	13.4	60	124.8	9	13.8	0.5
12/15/92	10:15	Carlyle 5H40	1520	168	9.0	13.3	60	117.6	8.8	13.3	2.8
12/22/92	10:15	Carlyle 5H40	1600	168	9.5	13.2	65	122.4	9.9	12.4	-3.8
12/30/92	10:15	Carlyle 5H40	1440	168	8.6	13.2	58	122.4	8.5	14.4	0.8
1/5/93	10:15	Carlyle 5H40	1720	168	10.2	13.2	65	135.6	10.2	13.4	0.4
1/12/93	10:15	Carlyle 5H40	1480	168	8.8	13	57	117.6	8.1	14.5	8.8
1/19/93	14:45	Carlyle 5H40	1480	173	8.6	13.1	58	115.2	8.5	13.5	0.9
1/26/93	10:15	Carlyle 5H40	1600	164	9.8	13.1	66	67.2	10.1	6.7	-3.1
2/2/93	10:15	Carlyle 5H40	1480	168	8.8	12.9	58	122.4	8.7	13.9	1.3
2/9/93	10:45	Carlyle 5H40	1480	169	8.8	12.9	58	122.4	8.7	14	1.0
2/16/93	10:15	Carlyle 5H40	1560	168	9.3	13	61	97.2	9.4	10.4	-0.9
2/23/93	10:15	Carlyle 5H40	1440	168	8.6	13	55	127.2	8.3	15.4	3.3
3/2/93	10:45	Carlyle 5H40	1440	169	8.5	13.1	56	133.2	8.6	15.5	-0.6
3/9/93	8:30	Carlyle 5H40	1720	166	10.4	13.2	66	151.2	10.4	14.6	-0.2
3/16/93	10:15	Carlyle 5H40	1560	170	9.2	13	60	140.4	9	15.7	2.1
3/23/93	10:15	Carlyle 5H40	1600	168	9.5	13.5	63	144	9.5	15.2	0.3
3/30/93	9:15	Carlyle 5H40	1920	167	11.5	13	68	160.8	11.5	14	0.0
4/6/93	8:30	Carlyle 5H40	1760	167	10.5	12.9	68	150	10.7	14	-1.7
4/13/93	9:30	Carlyle 5H40	2120	169	12.5	13.4	74	129.6	12.5	10.3	0.4
4/20/93	8:10	Carlyle 5H40	2160	167	13.0	13.3	72	162	12.9	12.6	0.5
4/27/93	8:30	Carlyle 5H40	2120	168	12.6	13.4	71	168	12.6	13.2	0.0
5/4/93	8:00	Carlyle 5H40	2280	168	13.6	13.5	75	171.6	13.6	12.6	0.1
5/18/93	8:20	Carlyle 5H40	4920	336	14.6	13.8	76	170.4	13.8	12.4	6.0
5/25/93	8:55	Carlyle 5H40	2280	169	13.5	13.7	75	168	13.5	12.4	0.2
6/1/93	10:00	Carlyle 5H40	2320	169	13.7	13.8	75	164.4	13.4	12.2	2.4
6/8/93	9:00	Carlyle 5H40	2200	167	13.2	13.7	74	171.6	13.1	13.1	0.6
6/15/93	9:00	Carlyle 5H40	2880	168	17.1	13.9	84.3	196.8	17.1	11.5	0.3
6/22/93	9:10	Carlyle 5H40	2840	168	16.9	13.8	82.1	199.2	16.8	11.9	0.6
6/29/93	8:20	Carlyle 5H40	2920	167	17.5	14	84.1	194.4	17.6	11.1	-0.7
7/6/93	8:30	Carlyle 5H40	3040	168	18.1	14.1	86.7	190.8	18.2	10.4	-0.6
7/13/93	9:30	Carlyle 5H40	3440	169	20.4	14.3	93.3	205.2	20.3	10.1	0.3
7/20/93	9:00	Carlyle 5H40	2880	168	17.1	14.1	86.2	190.8	17.1	11.2	0.3
7/27/93	9:30	Carlyle 5H40	2760	168	16.4	14.1	83.9	188.4	16.5	11.4	-0.4

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE + 15°F RACK - HFC-134a

						DOWNLOADED DATA AVERAGE RESULTS					
Date	Time	Compressor	kWh	Duration	Ave Power	SST	SDT	LOAD	POWER	EER	POWER BALANCE %
8/3/93	9:30	Carlisle 5H40	3040	168	18.1	14.2	88.5	186	18.1	10.3	0.0
8/10/93	8:40	Carlisle 5H40	2760	167	16.5	14.2	84.5	174	16.5	10.6	0.1
8/17/93	8:20	Carlisle 5H40	3120	168	18.6	14.3	87.2	140.4	17.3	8.1	7.6
8/24/93	11:25	Carlisle 5H40	2600	171	15.2	14.2	85.9	134.4	16.5	8.1	-7.9
8/31/93	11:05	Carlisle 5H40	3080	168	18.4	14.3	91	135.6	18.4	7.3	-0.1
9/7/93	8:55	Carlisle 5H40	2880	166	17.3	14.2	87.9	138	17.3	8	0.3
9/14/93	10:40	Carlisle 5H40	2560	170	15.1	14.1	80.8	127.2	15	8.5	0.5
9/21/93	8:35	Carlisle 5H40	2400	166	14.5	14.2	79	129.6	14.4	8.9	0.5
9/28/93	7:50	Carlisle 5H40	2680	167	16.0	8.8	77.9	158.4	16	9.9	0.2
10/5/93	8:55	Carlisle 5H40	2440	169	14.5	7.5	72	157.2	14.4	10.9	0.4
10/12/93	8:40	Carlisle 5H40	2320	168	13.8	7.5	70.8	147.6	14	10.5	-1.3
10/19/93	8:30	Carlisle 5H40	2360	168	14.0	7.4	70.7	162	14	11.6	0.2
10/26/93	9:10	Carlisle 5H40	2320	169	13.8	7.4	70	160.8	13.7	11.8	0.4
11/2/93	8:40	Carlisle 5H40	2120	167	12.7	7.3	67.3	109.2	12.5	8.7	1.6
11/9/93	9:05	Carlisle 5H40	2040	169	12.1	7.2	66.9	146.4	12.1	12	-0.2
11/23/93	9:00	Carlisle 5H40	4160	336	12.4	7.1	65.2	139.2	11.6	11.9	0.2
11/30/93	10:45	Carlisle 5H40	1840	170	10.8	8	62.5	130.8	10.7	12.1	1.2
12/7/93	12:00	Carlisle 5H40	1920	169	11.4	8.2	64	147.6	11.3	13.1	0.5
12/14/93	7:15	Carlisle 5H40	1720	164	10.5	7.9	61.4	144	10.7	13.4	-1.9
12/21/93	14:45	Carlisle 5H40	1960	176	11.2	8	62.3	147.6	11.1	13.3	0.5
12/28/93	10:00	Carlisle 5H40	1560	163	9.6	7.3	54.4	130.8	9.3	14	2.8

- Note:
1. Two Carlisle 5H-40 open drive.
 2. The date shown is the last day of the period (usually one week) during which data was taken.
 3. The Power Balance is a comparison of manually recorded power from the watt meters and the power determined from the downloaded data.

HISTORY OF MODIFICATIONS:

- 7/1/92 Beginning of consistent valid data collection.
- 7/21/92 Oil separator repiped.
- 7/22/92 Switched from TD control to head pressure control.
- 9/4/92 375 lbs refrigerant added. Suction control set to 10 psig (7 °F SST) during service. Pump cavitation caused low load reading for part of week . With the low load reading removed load would be 181 MBH and the EER 8.67.
- 9/18/92 125 lbs of refrigerant added.
- 9/29/92 Changed from head control to TD control: 4 cut in ; 0 offset.
- 10/1/92 Set suction control to 15 psig (15 deg F).
- 10/2/92 TD control settings changed: 8 cut in ; 4 offset.
- 10/5/92 125 lbs of refrigerant added.
- 10/6/92 Pump cavitation caused low load reading for much of the week.
- 10/7/92 Large leak in suction line repaired. 125 lbs of refrigerant added.
- 10/9/92 125 lbs of refrigerant added.
- 10/23/92 63 lbs of refrigerant added.
- 11/3/92 One of the 5H40s electrically disconnected. Run only one 5H40 for winter.
- 1/20/93 RC-1000 CPU changed.
- 1/22/93 Frequency setting of RC-1000 found set at 50 Hz. reset to 60 Hz.
- 1/25/93 Added 125lbs of refrigerant.
- 1/26/93 Pump cavitation caused low load reading for part of the week . With the low load reading removed the load would be 116 MBH and the EER would be 13.1.
- 2/16/93 RC3 locked-up and had to be master cleared. RC-1000 data lost for this week.Pump cavitation caused low load reading for part of the week . With the low load reading removed the load would be 134 MBH and the EER 14.1.
- 2/17/93 Drained oil from 5H40 compressors.
- 3/25/93 2nd 5H40 turned back on.
- 3/30/93 Inverter freq. bypass accidently removed/ reinstalled. Bypass 27 Hz because of vibration problem.
- 4/13/93 Pump cavitation caused low load reading for part of the week . With the low load reading removed the load would be 153 MBH and the EER would be 12.0.
- 5/4/93 Hansen liquid pumps removed; HySave installed.
- 4/13/93 Oil changed. Installed new Solest 68. Remove 25 gallon. Installed 23 gallon.
- 8/17/93 Data from this week indicates pump cavitation.
- 9/23/93 Liquid pump not pumping.
- 11/30/93 Shut off one 5H40. Running just one 5H40.

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE +20°F RACK - HFC-134a

						DOWNLOADED DATA AVERAGE RESULTS					
Date	Time	Compressor	kWh	Duration	Ave. Power	SST	SDT	LOAD	POWER	EER	POWER BALANCE %
8/18/92	18:00	Carlyle	4760	176	27.1	17.7	85	294	27.1	10.8	0.0
9/1/92	14:00	Carlyle	8600	334	25.7	19.0	87	288	25.8	134.0	-0.2
9/8/92	12:05	Howden	4320	166	26.0	18.5	88	276	26.1	10.6	-0.4
9/15/92	11:15	Bitzer	3760	167	22.5	20.4	87	277	22.5	12.3	-0.1
9/22/92	14:15	Carlyle	4360	171	25.5	17.8	86	263	25.4	10.4	0.4
9/29/92	11:45	Howden	4000	166	24.2	18.1	82	262	24.4	10.8	-0.9
10/6/92	10:15	Bitzer	3080	166	18.6	19.3	75	179	18.3	9.7	1.7
10/13/92	10:30	Carlyle	3560	168	21.2	18.1	79	254	21.3	12.0	-0.7
10/20/92	10:35	Howden	3640	168	21.7	17.3	76	251	21.5	11.6	0.7
10/27/92	10:15	Bitzer	2560	168	15.3	19.0	73	235	15.3	15.4	-0.2
11/3/92	10:15	Carlyle	2480	168	14.8	19.8	63	244	14.8	16.5	-0.3
11/10/92	10:15	Howden	2800	168	16.7	17.2	63	246	16.6	14.8	0.4
11/17/92	11:00	Bitzer	2080	169	12.3	18.7	62	233	12.3	18.9	0.2
11/24/92	10:20	Carlyle	2520	167	15.1	19.1	65	224	15.1	14.8	-0.3
12/1/92	10:15	Howden	3320	168	19.8	17.0	65	241	19.6	12.3	0.9
12/8/92	10:15	Bitzer	1920	168	11.4	18.4	60	223	11.4	19.5	0.3
12/15/92	10:15	Carlyle	2200	168	13.1	19.4	60	206	13.2	15.6	-0.8
12/22/92	10:15	Howden	2800	168	16.7	17.3	65	205	16.6	12.4	0.4
12/30/92	10:15	Bitzer	1760	168	10.5	18.3	59	194	10.5	18.6	-0.2
1/5/93	10:15	Carlyle	2360	168	14.0	18.0	65	214	14.0	15.2	0.3
1/12/93	10:15	Howden	2320	168	13.8	18.4	57	202	13.5	17.1	2.3
1/19/93	14:45	Bitzer	1720	173	10.0	19.3	59	211	10.1	20.9	-1.3
1/26/93	10:15	Carlyle	2160	164	13.2	17.5	66	101	13.2	7.4	0.1
2/2/93	10:15	Howden	2120	168	12.6	18.5	58	205	12.7	16.2	-0.6
2/9/93	10:45	Bitzer	1760	169	10.4	18.8	58	199	10.5	19.5	-0.5
2/16/93	10:15	Carlyle	2240	168	13.4	19.0	61	216	13.3	16.1	0.5
2/23/93	10:15	Howden	2240	168	13.3	21.7	55	205	14.0	14.6	-4.8
3/2/93	10:45	Bitzer	1640	169	9.7	18.0	56	218	9.8	22.2	-0.7
3/9/93	8:30	Carlyle	2400	166	14.5	17.1	66	230	14.3	16.1	1.3
3/16/93	10:15	Bitzer	1760	170	10.4	18.8	60	211	10.4	20.3	-0.3
3/23/93	10:15	Carlyle	2120	168	12.6	17.7	63	208	12.5	16.6	1.0
3/30/93	9:15	Bitzer	2560	167	15.3	17.5	68	248	15.4	16.1	-0.5
4/6/93	8:30	Carlyle	2760	167	16.5	16.0	68	250	16.5	15.1	0.0
4/13/93	9:30	Bitzer	3040	169	18.0	16.3	74	211	18.0	11.8	-0.1
4/20/93	8:10	Carlyle	3240	167	19.4	16.2	72	256	19.4	13.2	0.2
4/27/93	8:30	Bitzer	3040	168	18.1	16.1	71	257	18.0	14.2	0.3
5/4/93	8:00	Carlyle	3480	168	20.8	16.9	75	274	20.9	13.1	-0.6
5/18/93	8:20	Bitzer	7080	336	21.1	16.6	76	270	20.6	13.1	2.2
5/25/93	8:55	Carlyle	3600	169	21.4	16.6	75	274	20.4	13.4	4.7
6/1/93	10:00	Bitzer	3320	169	19.6	16.6	75	280	19.5	14.3	0.7
6/8/93	9:00	Carlyle	3360	167	20.1	16.6	74	268	20.1	13.3	0.1
6/15/93	9:00	Bitzer	4240	168	25.2	17.3	84	288	25.1	11.5	0.6
6/22/93	9:10	Carlyle	4160	168	24.8	17.8	82	312	24.9	12.5	-0.6
6/29/93	8:20	Bitzer	4320	167	25.9	17.8	84	311	25.7	12.1	0.7
7/6/93	8:30	Carlyle	4600	168	27.4	17.9	87	302	27.5	11.0	-0.4
7/13/93	9:30	Bitzer	5120	169	30.3	18.2	93	330	30.1	10.9	0.7
7/20/93	9:00	Carlyle	4360	168	26.0	16.4	86	302	26.1	11.6	-0.6
7/27/93	9:30	Bitzer	4000	168	23.8	16.4	84	288	23.8	12.1	0.0
8/3/93	9:30	Carlyle	4680	168	27.9	16.3	89	307	27.9	11.0	-0.2
8/10/93	9:40	Bitzer	3960	167	23.7	16.5	85	298	23.6	12.7	0.4
8/17/93	8:20	Carlyle	4360	168	26.0	16.6	87	248	26.7	9.3	-2.6
8/24/93	11:00	Bitzer	4240	171	24.8	16.4	86	223	23.9	9.3	3.7
8/31/93	11:05	Carlyle	4840	168	28.9	16.6	91	250	28.8	8.6	0.3
9/7/93	8:55	Bitzer	4200	166	25.3	16.5	88	247	25.3	9.8	0.0
9/14/93	10:40	Carlyle	3720	170	21.9	16.4	81	217	22.0	9.9	-0.4
9/21/93	8:35	Bitzer	3320	166	20.0	16.6	79	222	20.0	11.1	0.1
9/28/93	7:50	Carlyle	3440	167	20.6	16.4	78	256	20.5	12.5	0.4
10/5/93	8:55	Bitzer	3040	169	18.0	16.5	72	263	17.9	14.7	0.6
10/12/93	8:40	Carlyle	3080	168	18.3	17.6	71	234	18.4	12.7	-0.3
10/19/93	8:30	Bitzer	2920	168	17.4	16.2	71	241	17.3	13.9	0.3

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE +20°F RACK - HFC-134a

						DOWNLOADED DATA AVERAGE RESULTS					
Date	Time	Compressor	kWh	Duration	Ave Power	SST	SDT	LOAD	POWER	EER	POWER BALANCE %
10/26/93	9:10	Carlyle	2920	169	17.3	16.1	70	235	17.5	13.5	-1.1
11/2/93	8:40	Bitzer	2560	167	15.3	15.8	67	241	15.2	15.9	0.9
11/9/93	9:05	Carlyle	2600	169	15.4	16.1	67	268	15.4	17.4	0.0
11/23/93	9:00	Bitzer	5000	336	14.9	16.5	65	221	13.8	16.0	0.5
11/30/93	10:45	Carlyle	2280	170	13.4	16.7	63	227	13.5	16.9	-0.7
12/7/93	12:00	Bitzer	2240	169	13.2	17.6	64	230	14.0	10.5	-5.4
12/14/93	7:15	Carlyle	2240	164	13.7	17.1	61	19	13.6	16.6	0.5
12/21/93	14:45	Bitzer	2200	176	12.5	16.5	62	18	12.6	17.5	-0.6
12/28/93	10:00	Carlyle	1920	163	11.8	18.0	54	16	11.1	17.5	6.0

Note: 1. Alternate between three banks of compressors: three Howden 91mm, Four Carlyle 06EM175, and Three Bitzer 6H.2.
2. The date shown is the last day of the period (usually one week) during which data was taken.
3. The Power Balance is a comparison of manually recorded power from the watt meters and the power determined from the downloaded data.

GLENS FALLS SHOP 'N SAVE - WEEKLY HISTORY OF THE +20°F RACK - HFC-134a

HISTORY OF MODIFICATIONS:

8/18/92 Liquid pump power removed from compressor Watthour meter.
9/4/92 375 lbs of refrigerant added.
9/18/92 125 lbs of refrigerant added.
9/28/92 #1 and #2 screws were controlled by a single analog signal. Rewired to have #1 and #2 to be controlled individually.
9/29/92 Changed from head control to TD control: 4 cut in ; 0 offset.
Suction pressure offset and suction pressure settings altered to correct RC-1000 readings.
10/2/92 TD control settings changed: 8 cut in ; 4 offset.
10/5/92 125 lbs of refrigerant added.
10/6/93 Low charge caused pump cavitation and flow reading error. No data from this week is valid.
10/7/92 Large leak in suction line repaired. 125 lbs of refrigerant added.
10/9/92 125 lbs of refrigerant added.
10/13/92 Howden Economizer pressure transducer defective.
10/21/92 Lowered minimum speed to 600 rpm. Output of RC-1000 has not been low enough.
10/22/92 Lowered minimum speed to 525 rpm. EIL reading now at 30Hz.
10/23/92 Leak at transducer P32. 63 lbs of refrigerant added.
10/27/92 Head control at 55/51 psig.
10/29/92 Analog output board changed. Minimum speed on recipis set to 750 rpm.
Howden economizer pressure transducer replaced.
11/5/92 Head control at 30 deg F
11/23/92 One Inverter driven Carlyle (C4) off on oil safety. Reset at 11:45am.
12/15/92 One Inverter driven Carlyle (C3) off on oil safety.
12/29/92 Changed Howden suction setpoints from 18/17/16 to 19/18/17 psig.
12/31/92 One Inverter driven Carlyle (C3) off on oil safety.
Timer on the oil pressurization reservoir pressurization installed.
1/5/93 Individual oil feed to each Howden Screw installed.
1/21/93 Howden economizer disabled.
1/25/93 Added 125 lbs charge. Receiver at 20%.
1/26/93 Pump cavitation caused low load reading for part of the week. With the low load reading removed the load would be 207 MBH and the EER would be 18.3.
1/28/93 Head control changed to 51/45 (50 deg F).
2/16/93 RC3 locked-up and had to be master cleared. RC-1000 data lost for this week.
06E #3 oil trip discovered.
2/18/93 #1 and 3 Howden shut down and would not turn. #2 ran at full speed.
2/20/93 Bitzer compressor on with Howden.
2/22/93 Switched from Howden and Bitzer to all Bitzers. Data for week ending 2/23 not valid.
3/10/93 Produce prep and finger cases disconnected.
3/26/93 Setpoint changed.
4/13/93 Oil changed. Installed new Solest 68. Removed 25 gal., installed 23 gal. Pump cavitation caused low load reading for part of the week. With the low load reading removed the load would be 233 MBH and the EER 17.9.

HISTORY OF MODIFICATIONS:

5/4/93 Hansen liquid pumps removed; Hysave installed.
5/10/93 Critical temperature, pressure and power readings calibrated.
5/24/93 Flow meter zero checked.
7/9/93 Third Bitzer on-line to meet load.
7/13/93 Fourth Carlyle on-line. Control through EIL compressor staging.
8/17/93 Data from this week indicates pump cavitation.
9/23/93 Liquid pump not pumping. Per Hysave instructions technician partially closed outlet ball valve and pump began operating properly. Outlet ball valve opened.
9/28/93 Return to only two Bitzers on-line.
10/5/93 Return to 3 Carlyle compressors.
Unused A-rack heat reclaim coils piped into Brack
10/8/93 Solenoid installed in heat reclaim drop leg. Opens when heat reclaim is on.
10/12/93 Added 125 lb. of R-134a
11/2/93 Filter drier changed.

LIFE CYCLE COST ANALYSIS

Appendix B

The life cycle cost (LCC) of a system can be calculated as follows:

$$LCC = C - S + M \sum_{J=1}^N \left[\frac{1+EM}{1+I} \right]^J + P \sum_{J=1}^N \left[\frac{1+EP}{1+I} \right]^J$$

where:

C = initial system cost

S = salvage value of the system at year N

M = annual maintenance cost

P = annual cost of electric energy

N = Useful life of the system in years

EM = annual escalation rate of maintenance cost

EP = annual escalation rate of the cost of electric energy

I = interest rate

The life cycle cost is the present value of the total cost of the entire system over its entire lifetime. This cost includes initial cost, operating cost, and maintenance cost, less the system salvage value.

There are three economic comparisons that we have examined: net present value savings (NPVS), return on investment (ROI), and simple payback period.

The net present value savings is defined as:

$$NPVS = LCC_{\text{base system}} - LCC_{\text{alternative system}}$$

The return on investment of an alternative system compared to the base system is defined as the interest rate at which the NPVS is equal to zero:

$$ROI = I, \text{ for } NPVS(I) = 0$$

ROI can be used to compare the relative merit of two different prospective investments, For two systems with equal risk factors the one with the higher ROI is the more financially beneficial.

The simple payback period is the time required for an investor to recoup his initial investment. It is defined as

$$\text{Payback Period} = \text{Initial investment} / \text{annual cost savings}$$

or

$$\text{Payback Period} = \text{increased system cost} / (\text{annual energy savings} * \text{cost of energy})$$

**LABORATORY AND FIELD TESTING OF ADVANCED LOW-TEMPERATURE
REFRIGERANTS FOR SUPERMARKET APPLICATIONS**

Phase II — Final Report

Prepared for

**THE NEW YORK STATE
ENERGY RESEARCH AND DEVELOPMENT AUTHORITY**

Raymond J. Albrecht, P.E.
Senior Project Manager

and

EMPIRE STATE ELECTRIC ENERGY RESEARCH CORPORATION

1515 Broadway
New York, New York 10036

Frank Porretto
Program Manager

Prepared by

ASPEN SYSTEMS, INC.
184 Cedar Hill Street
Marlborough, MA 01752

Hamed Borhanian, Project Manager
Lenley Rafuse, Project Engineer

1586-EEED-BES-91

NYSERDA
Report 96-6

April 1996

NOTICE

This report was prepared by Aspen Systems, Inc., in the course of performing work contracted for and sponsored by the New York State Energy Research and Development Authority, Empire State Electric Energy Research Corporation, and Electric Power Research Institute (hereafter the "Sponsors"). The opinions expressed in this report do not necessarily reflect those of the Sponsors or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it. Further, the Sponsors, the State of New York, and the contractor make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, or other information contained, described, disclosed, or referred to in this report. The Sponsors, the State of New York, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately owned rights and will assume no liability for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

ABSTRACT

Aspen Systems, and a team of nineteen agencies and industry participants conducted a series of tests to evaluate the performance of viable long-term replacement refrigerants for supermarket applications. For the first phase of this effort, we determined the performance of HFC-134a, HCFC-22, and CFC-502 for several supermarket applications. The results of the Phase I effort are presented in a separate report (1). The results of the second phase of the project are the subject of this report. Phase II centered on laboratory testing of all viable HFC replacement refrigerants for CFC-502. It also included the field demonstration of one of these long-term replacement refrigerants, HFC-507.

LABORATORY RESULTS

Laboratory tests were conducted to determine the performance of HFC-507, HFC-404A, and HFC-407A, relative to CFC-502, for low-temperature applications. A laboratory refrigeration rack with four types of refrigeration compressors was used. An open-drive screw compressor, an open-drive reciprocating (recip) compressor, a semihermetic recip compressor, and an internally compounded two-stage recip compressor were tested. Tests were conducted to simulate a low (-20°F) saturated suction temperature (SST) refrigeration system.

The test results show that the relative refrigeration capacity and energy efficiency ratio (EER) for each of the refrigerants is dependent on the compressor type. Under most conditions, the EER performance of HFC-507 was nearly identical to that of HFC-404A and similar to that of CFC-502. At high saturated discharge temperatures (SDTs), HFC-407A EER performance nearly matched that of CFC-502, but dropped at lower SDTs.

Among the HFC alternatives, regardless of the compressor type, HFC-507 exhibited the highest refrigeration capacity, followed by HFC-404A and HFC-407A. With the semihermetic and open-drive recip, all HFC refrigerants registered a lower capacity compared to CFC-502. With the internally compounded recip and open-drive screw, HFC-507 and HFC-404A registered higher capacities, while HFC-407A showed a slightly lower capacity than CFC-502.

DEMONSTRATION RESULTS

For the demonstration test, the low-temperature rack of a fully instrumented supermarket in Glens Falls, NY, was converted from HCFC-22 to HFC-507. The rack contains three sets of compressors: one consisting of an open drive screw compressor, one consisting of a semihermetic screw compressor, and the third consisting of two semihermetic reciprocating compressors. We monitored the performance of the rack on two suction groups (-15°F and -25°F SST) for 10 months. The conversion from HCFC-22 to HFC-507 at the demonstration site went smoothly and no startup problems were encountered with the refrigerant or the polyol ester (POE) lubricant.

The efficiency performance of the low-temp rack on HFC-507 and HCFC-22 was similar. With the open-drive screw, the EER of the two refrigerants was virtually identical below 80°F SDT. Above 80°F SDT, HCFC-22 showed higher EERs. With the semihermetic reciprocating compressors, below 68°F SDT, HFC-507 showed higher EERs than HCFC-22. Above 68°F SDT, HCFC-22 showed slightly higher EERs. No refrigerant comparison data were obtained for the semihermetic screw, since it was added during the refrigerant conversion.

The screw compressors provided significantly better AEER than the reciprocating compressors for the low-temp rack. The screw's advantage over the reciprocating compressors was more pronounced for the -15°F suction group. The reciprocating compressors were more efficient than the screws at high SDTs, suggesting that in warmer climates they may show a better annual performance.

Our experience with HFC-507 in the low-temp rack of the Glens Falls store has been extremely favorable. We have observed no incompatibility problems between HFC-507, its POE lubricant, and the rest of the system. HFC-507 appears to be a trouble-free long-term refrigerant replacement for low-temperature refrigeration.

ACKNOWLEDGMENTS

The successful continuation of this project would not have been possible without the invaluable assistance of the following individuals and organizations.

Funding Agencies

- New York State Energy Research and Development Authority:
Mr. Raymond Albrecht
Mr. Joseph Rizzuto
Mr. Robert Callender
Ms. Joan Edwards
- Empire State Electric Energy Research Corporation:
Mr. Frank Porretto

Demonstration Supermarket

- Hannaford Bros. Co.:
Mr. Tom Mathews
Mr. Steven Hitchcock
Mr. Jim Boyko
Mr. Winn Williams
Mr. Bion Pike

Corporate Sponsors

- ALCO Controls:
Mr. Patrick Varley
- AlliedSignal:
Mr. Mark Spatz
Mr. Frank Wilson
Mr. Michael Hughes
Mr. Theodore Atwood
- Bitzer Compressors:
Mr. Stephen Brown
Mr. Harry Brown
Mr. David Laird

- Carrier Corporation/Carlyle Compressors:

Mr. Paul Tollar
Mr. Rich D'Aversa
Mr. Peter Narreau
Mr. Anton Heinrichs
Mr. Charles Cove

- Castrol, Inc.:

Mr. Anthony Huffman
Mr. David Jones

- Conyers Tank and Welding:

Mr. John Kerr

- CPI Engineering:

Mr. Tom Rajewski
Mr. Glenn Short

- Demand Defrost

Ms. Jani Bryson

- Du Pont Chemicals:

Mr. Paul Reed
Mr. Mark Shiflett

- Eastern Heating and Cooling:

Mr. Fred Giardinelli
Mr. Bill Metz
Mr. Ray Vogel
Mr. Bob Kanser
Mr. Greg Thomsen

- EIL Instruments:

Mr. Dennis Rice
Mr. Robert Lewis

- Hill Refrigeration:

Mr. John Vana
Mr. Tom Moffatt

- Howden Compressors:

Mr. Charles Bizilj
Mr. Douglas Szandrocha
Mr. Lee Evans
Mr. David Johnson

- ICI Klea:
 - Mr. George Haines
 - Mr. Thomas Dekleva
 - Mr. Bruce Gilbert
- Niagara Mohawk Power Corporation:
 - Mr. Adam Hinge
 - Mr. Alex Hall
- Phoenix Refrigeration Systems:
 - Mr. Mark Goldberg
 - Mr. Grant Brown
 - Mr. Carl Goldberg
- Spectronics Corp.:
 - Mr. John Duerr
- Sporlan Valve:
 - Mr. Leroy Manor
 - Mr. Andy Schoen

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
SUMMARY	S-1
Background	S-1
Results - Laboratory Tests	S-2
Summary of Results and Conclusions of the Laboratory Tests	S-4
Results - Demonstration Test	S-4
-25°F suction Group Test Results	S-5
-15°F Suction Group Test Results	S-5
Load Factor of the Low-Temp Rack	S-7
Projected Annual Performance	S-8
Economic Analysis Results	S-9
Summary of Results and Conclusions of the Demonstration Test	S-10
 1. INTRODUCTION	 1-1
Description of the R&D Project	1-1
Scope Of Work	1-2
 2. LABORATORY RESULTS	 2-1
Scope of Laboratory Work	2-1
Description of the Laboratory Test Setup	2-2
Refrigeration System	2-2
Instrumentation	2-7
Test Plan	2-9
Test Results - Comparison of Refrigerant	2-11
Semihermetic Recip	2-12
Open Drive Recip	2-14
Semihermetic Internally Compounded Recip	2-16
Open Drive Screw	2-18
Performance Comparison of the Three Replacement Refrigerants Relative to CFC-502	2-19
Selection of the Proper Suction Pressure Setpoint for HFC-407A	2-22
Test Results - Comparison of Compressors	2-23
Comparison of the Four Compressors With CFC-502	2-23
Comparison of the Four Compressors With HFC-507	2-24

<u>SECTION</u>	<u>PAGE</u>
Comparison of the Four Compressors With HFC-404A	2-24
Comparison of the Four Compressors With HFC-407A	2-26
Comparison of the Four Compressors - Summary	2-26
Projected Annual Energy Efficiency	2-27
Summary of Results and Conclusions	2-29
 3. GLENS FALLS HFC-507 FIELD TESTING	 3-1
The Demonstration Site Supermarket	3-1
Low-Temp Rack	3-2
-25°F Suction Group Refrigeration Schedule	3-5
-15°F Suction Group Refrigeration Schedule	3-6
Oil Management	3-7
Control and Data Acquisition Systems	3-8
Instrumentation	3-9
History of the Low-Temp Refrigeration System	3-9
Demonstration Testing Results	3-11
Test Procedure	3-11
Data Reduction	3-11
-25°F Suction Group Test Results	3-11
-15°F Suction Group Test Results	3-17
System Issues	3-21
Oil Analysis	3-23
Reliability	3-24
Load Factor of the Low-Temp Rack	3-24
Projected Annual Performance	3-24
Economic Analysis	3-29
Summary of Results and Conclusions	3-30
 4. TECHNOLOGY TRANSFER	 4-1
Publicity	4-1
Presentations/Papers	4-2
Awards	4-3
 5. REFERENCES	 5-1
 APPENDIX A - HISTORY OF THE GLENS FALLS	
LOW-TEMPERATURE RACK	A-1
 APPENDIX B - LIFE CYCLE COST ANALYSIS	 B-1

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
S-1	Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -25°F Suction Group	S-5
S-2	Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -15°F Suction Group	S-6
S-3	Load Factors of the Refrigeration Racks in Glens Falls Store Compared to the Load Factor of the Entire Store	S-7
2-1	Laboratory Test Rack Piping Diagram Showing Some of the Critical Instrumentation	2-3
2-2	Aspen Systems' Laboratory Test Rack	2-3
2-3	CFC-502 Energy Efficiency Performance of the Semihermetic Recip Compared to Manufacturer's Data	2-11
2-4	Comparison of the Energy Efficiency Performance of the Semihermetic Recip Compressor for all Refrigerants	2-13
2-5	CFC-502 Energy Efficiency Performance of the Open-drive Recip Compared to Manufacturer's Data	2-14
2-6	Comparison of the Energy Efficiency Performance of the Open-Drive Recip Compressor for All Refrigerants	2-15
2-7	Comparison of the Energy Efficiency Performance of the Internally Compounded Recip Compressor for All Refrigerants	2-17
2-8	Comparison of the Energy Efficiency Performance of the Open-Drive Screw Compressor for all Refrigerants	2-19
2-9	Comparison of the Energy Efficiency Performance of the Four Compressors with CFC-502	2-24
2-10	Comparison of the Energy Efficiency Performance of the Four Compressors with HFC-507	2-25
2-11	Comparison of the Energy Efficiency Performance of the Four Compressors with HFC-404A	2-25
2-12	Comparison of the Energy Efficiency Performance of the Four Compressors with HFC-407A	2-26
2-13	Annual Bin Temperature Distribution for Albany, NY.	2-28

FIGURE	PAGE
3-1 Piping and Instrumentation Diagram of the Low-Temp Rack	3-3
3-2 History of the Refrigeration Load for the -25°F Suction Group	3-6
3-3 History of the Refrigeration Load for the -15°F Suction Group	3-7
3-4 Energy Efficiency Performance of the Semihermetic Recips on the -25°F Suction Group	3-12
3-5 Energy Efficiency Performance of the Semihermetic Screw on the -25°F Suction Group	3-13
3-6 Energy Efficiency Performance of the Open-drive Screw on the -25°F Suction Group	3-14
3-7 Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -25°F Suction Group	3-16
3-8 Comparison of the Energy Efficiency Performance of the Semihermetic Recips with HCFC-22 and HFC-507 on the -25°F Suction Group	3-16
3-9 Comparison of the Energy Efficiency Performance of the Open-Drive Screw with HCFC-22 and HFC-507 on the -25°F Suction Group	3-17
3-10 Energy Efficiency Performance of the Semihermetic Recips on the -15°F Suction Group	3-18
3-11 Energy Efficiency Performance of the Semihermetic Screw on the -15°F Suction Group	3-19
3-12 Energy Efficiency Performance of the Open-drive Screw on the -15°F Suction Group	3-20
3-13 Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -15°F Suction Group	3-22
3-14 Comparison of the Energy Efficiency Performance of the Semihermetic Recips with HCFC-22 and HFC-507 on the -15°F Suction Group	3-22
3-15 Comparison of the Energy Efficiency Performance of the Open-drive Screw with HCFC-22 and HFC-507 on the -15°F Suction Group	3-23
3-16 History of the Acid Number of the Low-Temp Rack with HFC-507 and POE Oil	3-24
3-17 History of the Moisture Content of the Low-Temp Rack with HFC-507 and POE Oil	3-25
3-18 Load Factors of the Refrigeration Racks in Glens Falls Store Compared to the Entire Store	3-27

LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
S-1 List of Long-Term CFC-502 Substitutes Tested	S-2
1-1 Description of the Refrigeration Racks in the Glens Falls Store	1-3
2-1 List of Long-Term CFC-502 Substitutes Tested	2-2
2-2 Description of Laboratory Test Rack Compressors	2-4
2-3 Refrigeration System Instrumentation	2-8
2-4 Test Information Obtained From the Laboratory Test Setup.	2-8
2-5 Operating Conditions for Testing	2-9
2-6 Summary of Lab Results with the Semihermetic Recip at 110°F SDT	2-13
2-7 Summary of Lab Results with the Open-Drive Recip at 110°F SDT	2-15
2-8 Summary of Lab Results with the Internally Compounded Recip at 110°F SDT (3-ton Subcooler)	2-17
2-9 Summary of Lab Results with the Open-drive Screw at 110°F SDT (3-ton Subcooler)	2-20
2-10 Theoretical Refrigeration Capacity of the Three Replacement Refrigerants on Four Types of Compressors Relative to CFC-502	2-20
2-11 Measured Refrigeration Capacity of the Three Replacement Refrigerants on Four Types of Compressors Relative to CFC-502	2-21
2-12 Operating Conditions Used for AEER Calculations	2-27
2-13 Projected Annual Energy Efficiency Performance of All Compressor Types	2-28
3-1 Description of the Low-Temp Refrigeration Systems in the Glens Falls Test Store	3-4
3-2 -25°F Suction Group Refrigeration Schedule	3-5
3-3 -15° Suction Group Refrigeration Schedule	3-6
3-4 List of the Critical Instrumentation of the Glens Falls Low-Temp Rack	3-10
3-5 Oil Test Summary of the Low-Temp Rack in the Glens Falls Store	3-24
3-6 Extrapolated Compressor EER at 110°F SDT Based on Curve Fits of Field Data	3-28

<u>TABLE</u>	<u>PAGE</u>
3-7 Annual EER and Energy Usage of the Low-Temp Refrigeration Systems in the Glens Falls Store	3-28
3-8 Parameters Used for the Economic Analysis	3-29
3-9 Economic Comparison of Low-Temp Refrigeration Systems Using HFC-507	3-30
3-10 Economic Comparison of Low-Temp Refrigeration Systems Using HCFC-22	3-30

SUMMARY

IN THIS SECTION

BACKGROUND

RESULTS - LABORATORY TESTS

RESULTS - DEMONSTRATION TEST

BACKGROUND

As the deadline approaches for the complete phase out of CFC refrigerant production, the supermarket industry is faced with many uncertainties regarding alternative refrigerants and their effect on system design and efficiency. The New York State Energy Research and Development Authority (NYSERDA) and the Empire State Electric Energy Research Corporation (ESEERCO) cosponsored a project directed toward resolving these uncertainties. The project was aimed at testing long-term replacement refrigerants for low-temperature (low-temp) supermarket refrigeration systems. The scope of the program included testing non-CFC refrigerants both in a laboratory and in an operating store. The demonstration site for the project was a Shop 'n Save supermarket in Glens Falls, NY. The Glens Falls store was the first supermarket to use HFC-134a for its entire air conditioning (A/C) and medium-temperature (med-temp) refrigeration loads (2).

The proposed work concentrated on newly available candidates for the replacement of CFC-502 in low-temp supermarket applications. The candidates that were selected for testing were HFC-507, HFC-404A, and HFC-407A (see Table S-1). The work plan aimed at testing these refrigerants in a laboratory refrigeration rack that simulated a supermarket operation. The laboratory tests were conducted at Aspen Systems' Marlborough, MA, facility. One of the more promising candidates (HFC-507), was also retrofitted in the low-temp (HCFC-22) rack of the Glens Falls demonstration site (2).

The laboratory testing portion of the effort aimed at evaluating the CFC-502, HFC-507, HFC-404A, and HFC-407A on three reciprocating compressors (recip) and one screw compressor (screw). The compressor types tested were: a semihermetic recip, an open-drive recip, an internally compounded two-stage recip, and an open-drive screw.

Table S-1. List of Long-Term CFC-502 Substitutes Tested

ASHRAE DESIGNATION	MANUFACTURER	MANUFACTURER DESIGNATION	REFRIGERANT MIXTURE	COMPOSITION (%)
HFC-507	Allied Signal	AZ-50	HFC-125/143a	50/50
HFC-404A	Dupont	HP62	HFC-125/143a/134a	44/52/4
HFC-407A	ICI	Klea 60	HFC-32/125/134a	20/40/40

For the field-testing portion of the project, we evaluated three refrigeration systems serving the low-temperature (low-temp) load of a supermarket. These systems utilized semihermetic recip, an open-drive compressor and, a semihermetic screw. The three systems were tested with two refrigerants, HCFC-22 and HFC-507.

RESULTS - LABORATORY TESTS

In the laboratory tests, the refrigerants listed in Table S-1, as well as the baseline refrigerant (CFC-502), were tested on the four compressors listed in Table S-2. Tests were conducted to determine the performance of each compressor with each refrigerant. The capacity of each compressor at -20°F saturated suction temperature (SST) and 110°F saturated discharge temperature (SDT) was determined at the outset of each test. The actual (measured) refrigeration capacity of each refrigerant for each compressor relative to CFC-502 is shown in Table S-3. The energy efficiency of each compressor was measured for the range of SDTs encountered in a typical supermarket.

The resulting energy efficiency ratio (EER) data were used to calculate a projected annual EER (AEER) for each of the four compressors. For ambient conditions, bin temperature data for Albany, NY, were used. The results of the annual bin temperature analysis are summarized in Table S-4. As expected, the compressors that utilized subcooling (internally compounded recip and open-drive screw) showed higher overall AEERs than the non-subcooled recip. With all but the screw compressor, the alternative refrigerants appear to impose a measurable AEER penalty compared to CFC-502. With the screw compressor, HFC-507 showed essentially the same AEER as CFC-502, while HFC-404A indicated a 1.1% increase and HFC-407A exhibited a 4.7% decrease. The internally compounded recip showed the least AEER reduction among the recip. The open-drive recip shows the highest AEER penalty for converting from CFC-502 to an alternative refrigerant. Still, even with this penalty, the open-drive recip exhibits higher AEERs than the semihermetic unit.

Table S-2. Description of Laboratory Test Rack Compressors

COMPRESSOR TYPE	MANUF'R	MODEL NO.	DISP.	MOTOR		OIL COOLER MANUF'R
			cfm	hp	MAX. EFFI.	
Semihermetic Recip	Carlyle	06ER175	75.4	20	-	N/A
Open-Drive Recip	Carlyle	5H40	92.4	25	0.94	D&B
Internally Compounded Recip	Carlyle	06CC675	75.4	20	-	N/A
Open-Drive Screw	Bitzer	OSN5361	83.3	40	0.93	ITT

Legend: Disp. - Displacement at 60 Hz, N/A - Not Applicable, Manuf'r - Manufacturer, Effi. - Efficiency

Table S-3. Measured Refrigeration Capacity of the Three Replacement Refrigerants on Four Types of Compressors Relative to CFC-502

COMPRESSOR	REFRIGERATION CAPACITY RELATIVE TO CFC-502 (%)		
	HFC-507	HFC-404A	HFC-407A
SEMIHERMETIC RECIP	97	93	90
OPEN-DRIVE RECIP	95	93	84
INTERNALLY COMPOUNDED RECIP	108	102	95
OPEN-DRIVE SCREW	112	108	99

Table S-4. Projected Annual Energy Efficiency Performance of All Compressor Types

REFRIGERANT	CFC-502	HFC-507	HFC-404A	HFC-407A
SEMIHERMETIC RECIP	8.47	8.29	8.27	8.16
OPEN-DRIVE RECIP	8.99	8.43	8.43	8.37
INTERNALLY COMPOUNDED RECIP	9.40	9.13	9.26	8.78
OPEN-DRIVE SCREW	8.86	8.87	8.96	8.44

Summary of Results and Conclusions of the Laboratory Tests

Following are some of the most important observations made during the laboratory testing:

- HFC-507, HFC-404A, and HFC-407A appear to be viable alternatives to CFC-502.
- The performance of HFC-507, HFC-404A, and HFC-407A, relative to CFC-502, varied substantially depending on the compressor tested.
- CFC-502 valve bodies and heads were used for all testing. The valves required only minor superheat adjustment for proper operation on HFC-404A and HFC-407A. The valves also worked well for HFC-507, but required significant superheat adjustment from their CFC-502 settings. As expected, the capacity and EER performance of HFC-507 and HFC-404A were very similar.
- The design of the oil pumps on the older recips did not consistently provide sufficient pressure using alternative refrigerants and oils. The manufacturer now has a higher-capacity oil pump for these compressors.
- Comparison of compressor technologies indicated that the internally compounded compressor can offer distinct advantages in annual energy usage.
- The screw compressor EER was nearly identical using CFC-502, HFC-507, or HFC-404A. AEER calculations showed a slight improvement with HFC-404A.
- The EER performance of recips can substantially benefit from operating at lower than design speeds.

RESULTS - DEMONSTRATION TEST

The Glens Falls Shop 'n Save superstore was designated as a demonstration site for advanced, non-CFC refrigeration systems in its design stage. Completed in March of 1992, the store employed HFC-134a for its A/C and med-temp systems, and HCFC-22 for its low-temp system. We identified several HFC-based CFC-502 substitutes and installed the one that, at the time, promised to be the most trouble-free. The refrigerant selected was HFC-507 (AZ-50), manufactured by Allied Signal. It is an azeotropic 50/50 mixture of HFC-143a and HFC-125 and has been commercially available since late 1993. The focus of the HFC-507 conversion was the low-temp system, which is composed of an open-drive screw, a semihermetic screw, and two semihermetic recips (Table S-5). All compressors use variable-frequency drives (VFDs) for capacity control. The low-temp rack has two suction groups, -25°F and -15°F, that share a common oil separator, condenser, heat (water) reclaim, receiver, and liquid pump.

Table S-5. Description of the Low-Temp Refrigeration Systems in the Glens Falls Test Store

COMPRESSOR						OIL		
NO.	TYPE	MANUF'R	MODEL	DISP.	QTY.	GRADE	TYPE	MANUF'R
				(cfm)		(cSt)		
1	Semi, Recip	Carlyle	06ER175	75.4	2	100	POE	Castrol
2	Semi, Screw	Carlyle	06TRF065	65.0	1	100	POE	Castrol
3	Open, Screw	Howden	91mm Hummingbird	65.5	1	100	POE	Castrol
Legend: Open - Open-Drive; Semi - Semihermetic; POE - Polyol Ester; Disp. - Displacement at 60 Hz. Manufr - Manufacturer, Qty - Quantity								

Prior to the HFC-507 conversion, the low-temp rack operated on HCFC-22 and a 300-SUS alkylbenzene oil. For the HFC-507 conversion, the oil in the rack was purged and replaced with a Castrol SW100 (450-SUS) polyol ester (POE) oil. The three compressor banks were alternated between the -25°F and -15°F suction groups on a weekly basis. Data were collected between June 1993 and March 1994, and the compressors' performance was measured and compared. The EER results for HFC-507 are shown separately for the -25°F and -15°F suction groups.

-25°F Suction Group Test Results

Curve fits of the EER performance for each compressor type on the -25°F suction group are compared in Figure S-1. The results indicate that the open-drive screw is more efficient than the other two types of compressor at SDTs below 73°F. This compressor's 3.6 internal volume ratio (V_i) favors the lower SDTs. The semihermetic screw features variable V_i and shows better performance at high SDTs. The performance of this compressor is much closer to that of the semihermetic recip, though it shows a slightly higher EER at low SDTs. At high SDTs, the semihermetic recips show the highest system efficiency.

-15°F Suction Group Test Results

The energy efficiency performance of the three compressor types on the -15°F suction group is compared in Figure S-2. The results indicate that the open-drive screw is significantly more efficient than the other two types of compressors at SDTs below 68°F. This is similar to our findings on the -25°F suction group. The semihermetic screw exhibits higher EERs than the recips over most of the operating range. Only

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
-25°F SUCTION GROUP / HFC-507

Figure S-1. Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -25°F Suction Group

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
-15°F SUCTION GROUP / HFC-507

Figure S-2. Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -15°F Suction Group

above 98°F SDT does the recip's performance exceed that of the semihermetic screw. The semihermetic recip's show the best performance near design conditions.

Load Factor of the Low-Temp Rack

A measurement that is of interest to utilities for identifying the demand associated with any electric system is load factor. The load factor is defined as the average power used by the system for a given period (in this case one month), divided by its 15-minute demand. A fixed, 15-minute demand interval is the method used by the utility supplying the store's electric power, Niagara Mohawk.

Figure S-3 shows the load factor of the low-temp rack, juxtaposed against the load factors of the other refrigeration racks and that of the entire store, for 15-months starting in January 1994. The load factor for the low-temp rack varies from 0.45 to 0.69. The medium temperature rack shows load factors that vary between 0.45 and 0.64. As expected, the air conditioning rack's load factor is very low in the beginning of the cooling season and climbs to 0.5 by the end of summer. The store's load factor peaks in the winter and ranges between 0.73 and 0.89. The store load factor is consistently higher than that of any rack.

Figure S-3. Load Factors of the Refrigeration Racks in Glens Falls Store Compared to the Load Factor of the Entire Store

Projected Annual Performance

The curve fits in Figures S-1 and S-2 as well as performance curves for HCFC-22, were used to calculate a projected annual EER (AEER) for each of the three compressor types. For ambient conditions, bin temperature data for Albany, NY, were used. The performance results of the bin temperature analysis for the two suction groups are listed in Table S-6. The two screw compressors show higher AEERs than the semihermetic recip. This corroborates our laboratory findings. The screw compressor's EER exceeds the efficiency of the recip at lower SDTs, where the system spends most of its operating time. As shown, the screw's advantage over the recip is more pronounced for the -15°F system. This is because the relative efficiency of screws compared to recip increases at lower pressure ratios. At -25°F SST, HCFC-22 and HFC-507 AEER performance is similar. However, at -15°F SST, HCFC-22 shows better efficiency than HFC-507, is to be expected based on theoretical cycle calculations.

Table S-6. Annual EER and Energy Usage of the Low-Temp Refrigeration Systems in the Glens Falls Store

-25°F SYSTEM				
	HFC-507		HCFC-22	
COMPRESSOR	ANNUAL EER	ANNUAL ENERGY CONSUMPTION	ANNUAL EER	ANNUAL ENERGY CONSUMPTION
	Btu/W-hr	kW-hr	Btu/W-hr	kW-hr
Semihermetic Recip	7.00	150,091	6.90	151874
Open-Drive Screw	7.40	142,614	7.40	142624
Semihermetic Screw	7.15	147,056	Not Meas.	Not Measured
-15°F SYSTEM				
	HFC-507		HCFC-22	
COMPRESSOR	ANNUAL EER	ANNUAL ENERGY CONSUMPTION	ANNUAL EER	ANNUAL ENERGY CONSUMPTION
	Btu/W-hr	kW-hr	Btu/W-hr	kW-hr
Semihermetic Recip	7.85	133,972	8.33	126263
Open-Drive Screw	8.74	120,223	8.89	118244
Semihermetic Screw	8.54	123,141	Not Meas.	Not Measured

Economic Analysis Results

An economic analysis was performed to determine the relative life cycle costs (LCCs) of the different refrigeration systems tested. The economic descriptors calculated were: the LCC, the net present value savings (NPVS), the return on investment (ROI), and the simple payback period. The semihermetic recipes were chosen as the base system since they constitute the industry standards for supermarket refrigeration. Table S-7 lists the results of the economic analysis for both the -25°F and -15°F suction groups with HFC-507.

Both the open-drive and semihermetic screws show an economic advantage over the semihermetic recipes. For the -25°F system, the open-drive screw has the highest ROI (33.9%), translating into a payback period of 3.5 years. The semihermetic screw exhibits an ROI of 24.5%, for a payback period of five years. As expected, the screws are even more economical for the -15°F suction group. The ROI of the semihermetic screw is the highest, at 67.1%, for a payback period of only 1.7 years. The ROI of the open-drive screw is 56.5%, for a payback period of two years. The economic analysis for HCFC-22 showed a slightly better economic performance (compared to HFC-507) at -25°F SST, but a somewhat worse performance at -15°F SST.

Table S-7. Economic Comparison of the Low-Temp Refrigeration Systems in the Glens Falls Store Using HFC-507

-25°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	yr
Semihermetic Recip	23,000	15,009	1,000	500	230.0	Base System		
Semihermetic Screw	25,000	14,706	900	500	226.8	3,222	24.5	5.0
Open-Drive Screw	26,000	14,261	900	500	222.0	7,970	33.9	3.5
-15°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	yr
Semihermetic Recip	23,000	13,397	1,000	500	209.1	Base System		
Semihermetic Screw	25,000	12,314	900	500	195.8	13,311	67.1	1.7
Open-Drive Screw	26,000	12,022	900	500	193.1	16,087	56.5	2.0
Economic parameters used in the analysis								
Discount Rate	7%		Maintenance Cost (Screws)		\$900/yr			
Electricity Cost (including demand)	10 ¢/kW-hr		Maintenance Cost Escalation Rate		5%/yr			
Electricity Escalation Rate	5%/yr		Salvage Value		\$500			
Maintenance Cost (Recips)	\$1000/yr		System Life		15 yr			

Summary of Results and Conclusions of the Demonstration Test

The following observations were made during the demonstration testing:

- The conversion from HCFC-22 to HFC-507 at the demonstration site went smoothly and no startup problems were encountered with the refrigerant or the POE lubricant.
- Our experience with HFC-507 in the low-temp rack of the Glens Falls store has been extremely favorable. We have observed no incompatibility problems between HFC-507, its POE lubricant, and the rest of the system. HFC-507 appears to be a trouble-free, long-term refrigerant replacement for low-temp refrigeration.
- The efficiency performance of the low-temp rack on HFC-507 and HCFC-22 was similar. With the open-drive screw, the EER of the two refrigerants was virtually identical below 80°F SDT. Above 80°F SDT, HCFC-22 showed higher EERs. With the semihermetic recip, HFC-507 showed higher EERs than HCFC-22 below 68°F SDT. Above 68°F SDT, HCFC-22 showed slightly higher EERs.
- The screw compressors provided significantly better AEER than the recip for the low-temp rack. The screw's advantage over the recip was more pronounced in the -15°F suction group.
- The recip were more efficient than the screws at high SDTs, suggesting that in warmer climates they may show a better annual performance.
- HCFC-22 and HFC-507 annual efficiency results were similar for a -25°F suction group. At -15°F SST, HCFC-22 performed noticeably better than HFC-507.
- An economic analysis indicated a payback period of 3.5 to 5 years for a screw compressor rack over a semihermetic recip compressor rack for a -25°F refrigeration load. The payback period for a screw compressor rack is even more attractive for a -15°F refrigeration load (1.7 to 2 years). HCFC-22 shows a slightly better economic performance (compared to HFC-507) at -25°F SST, but a somewhat worse performance at -15°F SST.

INTRODUCTION

Section 1

IN THIS SECTION

DESCRIPTION OF THE R&D PROJECT

SCOPE OF WORK

DESCRIPTION OF THE R&D PROJECT

As the deadline approaches for the complete phase out of CFC refrigerant production, the supermarket industry is faced with many uncertainties regarding alternative refrigerants and their effect on system design and efficiency. The New York State Energy Research and Development Authority (NYSERDA), Niagra Mohawk Power Corporation, and the Empire State Electric Energy Research Corporation (ESEERCO) cosponsored a project directed toward resolving these uncertainties. The project was aimed at testing long-term replacement refrigerants for low-temperature (low-temp) and medium temperature (med-temp) supermarket refrigeration systems. For the first phase of this effort, we determined the performance of HFC-134a, HCFC-22, and CFC-502 for several supermarket applications. The results of the Phase I effort are presented in separate report (1). The results of the second phase of the project are the subject of this report. Phase II concentrated on newly available candidates for the replacement of CFC-502 in low-temp supermarket applications. Several candidates were identified for testing. These were HFC-507, HFC-404A, and HFC-407A. The work plan aimed at testing these refrigerants in a laboratory refrigeration rack that simulated a supermarket operation. One of the more promising candidates (HFC-507), was also retrofitted in the low-temp (HCFC-22) rack of a supermarket in Glens Falls, NY.

The supermarket chain sponsoring the project is Hannaford Bros. Co., of Maine. Since its inception, this program has received the support of several manufacturers. The major participants, other than the sponsors, the supermarket chain, and Aspen Systems, have been the following organizations:

- ALCO Controls- Valve Manufacturer
- Allied Signal, Inc. - refrigerant manufacturer
- Brown Engineering/Bitzer Compressors - compressor manufacturer

- Carlyle Compressor Company - compressor manufacturer
- Castrol, Inc. - lubricant manufacturer
- CPI Engineering Services, Inc. - lubricant manufacturer
- Dupont Chemicals - refrigerant manufacturer
- Eastern Heating and Cooling, Inc. - installation contractor
- E.I.L. Instruments, Inc. - control systems manufacturer
- Hannaford Brothers - owner of the Shop 'n Save supermarket
- Hill Refrigeration - display case manufacturer
- Howden Compressors, Inc. - compressor manufacturer
- ICI Klea - refrigerant manufacturer
- Niagara Mohawk Power Corporation - local electric utility
- Phoenix Refrigeration Systems, Inc. - refrigeration systems manufacturer
- Spectronics Corporation - leak detection systems manufacturer
- Sporlan Valve Company - valve manufacturer

SCOPE OF WORK

The work plan was divided into two parts: field testing and laboratory testing. For the field testing portion of the project, we evaluated three refrigeration systems serving the low-temperature (low-temp) load of a supermarket. These systems utilized semihermetic recip, and open-drive and semihermetic screw compressors. The three systems were tested with two refrigerants, HCFC-22 and HFC-507.

The laboratory testing portion of the effort aimed at evaluating the most viable replacement refrigerants for CFC-502 using four different types of compressors. The compressor types tested were: semihermetic recip, open-drive recip, internally compounded two-stage recip, and open-drive screw.

The work plan for this effort included the following tasks:

1. Redesign and retrofit the existing refrigeration rack in Aspen Systems' laboratory to include three new reciprocating compressors and one new screw compressor. Use this laboratory setup to establish the comparative performance of the different compressors on CFC-502, HFC-507, HFC-404A, and HFC-407A.

2. Replace the HCFC-22 in the low-temp rack of the test supermarket with HFC-507 and carry out field comparisons of the two refrigerants. Alternate between the existing screw and reciprocating compressors to determine relative performance of each compressor system.
3. Obtain demonstration test results from the HFC-507 system for as long as possible.
4. Prepare a final report detailing the results of the laboratory and demonstration testing.

The refrigeration systems in the Glens Falls store are described in Table 1-1.

The low-temp rack was switched on a weekly basis to alternate the compressors between the -15°F and -25°F refrigeration loads. The entire store was instrumented and the data was collected by EIL energy management systems and a high-precision data logger. Due to a lack of sufficient funds, the demonstration phase of the project was limited to less than a year of testing.

**Table 1-1. - Description of the Refrigeration Racks
in the Glens Falls Store**

Low-Temp Rack
<u>-25°F or -15°F LOW-TEMP SYSTEM (HCFC-22)</u>
One Carlyle 65 cfm Semihermetic Screw
One Howden 91 mm Open-Drive Screw
Two Carlyle 06ER175 Semihermetic Recips
Med-Temp Rack
<u>+15°F MED-TEMP SYSTEM (HFC-134a)</u>
Two Carlyle 5H40 Open-Drive Recips
<u>+20°F MED-TEMP SYSTEM (HFC-134a)</u>
Three Howden 91 mm Open-Drive Screws
Three Bitzer 6H2 Open-Drive Recips
Four Carlyle 06EM175 Semihermetic Recips
A/C Rack
<u>+40°F A/C SYSTEM (HFC-134a)</u>
Three Bitzer 6F2 and One Bitzer 4H2 Open-Drive Recips

LABORATORY TESTING

Section 2

IN THIS SECTION

SCOPE OF LABORATORY WORK

DESCRIPTION OF THE LABORATORY TEST SETUP

TEST PLAN

TEST RESULTS - COMPARISON OF REFRIGERANTS

TEST RESULTS - COMPARISON OF COMPRESSORS

PROJECTED ANNUAL ENERGY EFFICIENCY

SUMMARY OF RESULTS AND CONCLUSIONS

The objective of this effort was to identify and evaluate the most promising long-term low-temperature replacement refrigerants for CFC-502. This section describes Aspen Systems' laboratory test facility and summarizes the laboratory test program. The test results of alternative refrigerants are compared to results obtained with CFC-502.

SCOPE OF LABORATORY WORK

The laboratory testing phase of this project consisted of the following major tasks:

- Modification of existing refrigeration test rack.
- Instrument verification.
- Baseline testing with CFC-502.
- Testing of alternatives for CFC-502.

The refrigerants listed in Table 2-1 were identified as the most viable long-term replacements for CFC-502 in low-temp applications. HFC-404A is also manufactured by Elf Atochem as FX-70. All the refrigerants in Table 2-1 have zero ozone depletion potential (ODP) and their only special requirement is the use of a synthetic oil. Several polyol ester (POE) oils were identified that work well with these refrigerants. We utilized our existing laboratory refrigeration rack for these laboratory tests. The description of our refrigeration facility and the instrumentation is given below. Comparison of the low-temp performance of CFC-502, HCFC-22, and HFC-134a can be found in Section 2 of the Phase I Final Report (1).

Table 2-1. List of CFC-502 Substitutes Tested

ASHRAE DESIGNATION	MANUFACTURER	MANUFACTURER DESIGNATION	REFRIGERANT MIXTURE	COMPOSITION (%)
HFC-507	Allied Signal	AZ-50	HFC-125/143a	50/50
HFC-404A	Dupont	HP62	HFC-125/143a/134a	44/52/4
HFC-407A	ICI	Klea 60	HFC-32/125/134a	20/40/40

DESCRIPTION OF THE LABORATORY TEST SETUP

At the start of this project, Aspen Systems' laboratory refrigeration test setup consisted of two screw compressor racks. The larger one was based on a 50-hp, vertical, hermetic Dunham-Bush screw compressor (2). The smaller rack used a 40-hp, horizontal, open shaft, Howden screw compressor (1). Complete descriptions of each system can be found in the references noted.

For this project, we added four new compressors: a Bitzer OSN5361 open-drive screw, a Carlyle 5H40 open-drive recip, a Carlyle 06ER175 semihermetic recip, and a Carlyle 06CC675 semihermetic internally compounded two-stage recip.

In order to accommodate the new compressors, we removed the vertical screw compressor as well as a test display case and a horizontal receiver from the rack. We replaced the receiver with a new vertical receiver mounted on the wall above the rack.

All compressors shared the same condenser, receiver, evaporators, and heat source. The setup was designed to obtain accurate and reliable test data for the refrigerants tested. A comprehensive description of the laboratory setup is presented below.

Refrigeration System

The piping and instrumentation diagram for the rack is presented in Figure 2-1. Figure 2-2 shows a photograph of the complete test rack. The major components of the laboratory system consisted of five compressors with their respective drive motors, a VFD and controller, two chillers, economizer heat exchangers (subcoolers), a receiver, oil coolers, oil separators, a gas-fired boiler, and an air-cooled condenser. All items except for the last two were mounted on the rack. The condenser was installed on the roof while the gas-fired boiler was located adjacent to the refrigeration rack.

**Figure 2-1. Laboratory Test Rack Piping Diagram
Showing Some of the Critical Instrumentation**

Figure 2-2. Aspen Systems' Laboratory Test Rack

The heat input for the refrigeration cycle was supplied by an ethylene glycol brine loop. The major components of the brine loop were the gas-fired hydronic boiler and its circulating pump. The boiler was sized to provide the heat removed by the chillers. The pump circulated a 45% solution of ethylene glycol and water that withstands freezing to -25°F.

Compressors. Five different compressors were installed on the rack. These are summarized in Table 2-2. The semihermetic recip with its small footprint and reliable operation has become the industry's workhorse. The open-drive recip can offer higher efficiencies than the semihermetic compressors because the motor's parasitic heat is not dumped into the refrigeration loop. The semihermetic internally compounded compressor was originally designed for HCFC-22 operation. We decided to test the effect of its built-in subcooling capability with HFC refrigerants. Screw compressors have shown some promise to perform more efficiently than reciprocating compressors at low pressure ratios. Both of the screw compressors also had built-in subcooling options.

We chose the Bitzer screw compressor for these tests, since its Vi of 5.0 was better suited to low-temp operation. The 2.6-Vi Howden screw compressor had been used for the previously completed medium-temperature (med-temp) testing.

Controller. Two controllers were used to govern the operation of the rack and its compressors. The first was a standard PID controller, and the second an energy management system manufactured by EIL (the RC-1000). Either unit could be used to control the compressors. The RC-1000 had the capability of controlling a supermarket rack. It used a modified PID algorithm to control the VFD and maintain a constant

Table 2-2. Description of Laboratory Test Rack Compressors

COMPRESSOR TYPE	MANUF'R	MODEL NO.	DISP.	MOTOR		OIL COOLER MANUF'R
			cfm	hp	MAX. EFFI.	
Semihermetic Recip	Carlyle	06ER175	75.4	20	-	N/A
Open-Drive Recip	Carlyle	5H40	92.4	25	0.94	D&B
Internally Compounded Recip	Carlyle	06CC675	75.4	20	-	N/A
Open-Drive Screw	Bitzer	OSN5361	83.3	40	0.93	ITT
Open-Drive Screw	Howden	91mm Hummingbird	65.5	40	0.92	D&B
Legend: Disp. - Displacement at 60 Hz, N/A - Not Applicable, Manuf'r - Manufacturer, Effi. - Efficiency						

system suction pressure. The standard PID controller allows modification of all PID parameters and is able to maintain a better control of suction pressure for testing purposes.

Variable-Frequency Drive. A constant-torque, variable speed inverter manufactured by Allen Bradley was used to control the speed of the compressor/motor drive. The specifications of the inverter are as follows:

Model No.	1336-B050-EAG-FA2-L3
Nominal Rating	50 hp
Type	Sinusoidal PWM
Max. Efficiency	98%

Condenser. The condenser was an air-cooled, direct-drive unit manufactured by Dunham-Bush. The condenser specifications are as follows:

Model No.	LSBC-242D-ARFNN8N
Heat transfer rating	21,200 Btu/°F/hr
Fan power	3.92 kW
Number of fans	4
Weight	1290 lbs
Dimensions	88 x 88 x 49 in.

The original fan cycling contactors were bypassed and a VFD with separate PID controller was installed. The PID controller allowed precise control of head pressure during testing.

Brine Chillers. The brine chillers were shell-and-tube units manufactured by Dunham-Bush. They consisted of a stainless steel housing and inner-finned copper tubing. The stainless steel housing was specified by Dunham-Bush for low-temp application. The specifications of the chillers are as follows:

Model No.	CHSK-7601A-JJ-T
Rating at 9°F approach and 10°F range, for water	42 ton
Rating with ethylene glycol	20 ton
Brine side pressure drop	3.5 psi
Weight	397 lbs
Dimensions	12-3/8 Dia. x 74 L in.

Receiver. The receiver was a vertical unit manufactured by Conyers Tank and Welding:

Model No.	AS1454
Refrigerant Capacity (CFC-502)	240 lbs
Dimensions	14 Dia. x 54 L in.

Hydronic Boiler. The boiler was a gas-fired unit manufactured by Edwards Engineering.

Model Number	V500MC
Input Heat Rating	500 MBH
Output Heat Rating	400 MBH
Dry Weight	1100 lbs
Dimensions	53 H x 30 Dia. in.

The boiler package included a circulating pump, a natural gas pressure regulator, and controls.

Economizer Subcooler. Three of the test compressors had the capability to accept vaporized refrigerant at an interstage pressure. This capability could be utilized to mechanically subcool the liquid and increase the compressor efficiency. We had two different subcooler heat exchangers on the rack. The original subcooler was a 3-ton shell-and-tube heat exchanger connected in a counter flow configuration. This unit, which is manufactured by Dunham-Bush, was mounted vertically, with the evaporating refrigerant flowing upwards in the tube side. The specifications for the subcooler are listed below:

Model No.	SC004243A00U
Max. Load	36 MBH
Dimensions	4.2 Dia. x 36 L in.

The second subcooler was a 2-ton brazed-plate heat exchanger provided by Carlyle. The 2-ton unit is sized for the internally compounded compressor for operation on HCFC-22.

Model No.	B15X20X7/85
Max. Load	24 MBH
Dimensions	20 H x 4 W x 3 D in.

Oil Cooler. Three of the compressors in Table 2-2 required oil cooling. The open-drive recip and the Howden open-drive screw share the original rack oil cooler. This air-cooled oil cooler, manufactured by Dunham-Bush, had copper tubes that are inner-finned. The oil cooler fan is controlled by a thermostat that was set at 120°F. The safety thermostat was set to 190°F. The oil cooler's specifications are:

Model No.	DB-22-4
Oil flow rate	6 gpm
Heat rejection at 50°F DT	14 MBH
Dimension	16H x 20W x 18D in.
Fan motor rating	1/4 hp

A separate oil cooler was provided with the Bitzer compressor. This unit is manufactured by ITT and its specifications are:

Model No. 5-705-16-610-007
Dimension 19.7 H x 17.6 W x 15.5 D in.
Fan motor rating 0.9 hp

Oil Separator. There were three oil separators in the system. An AC&R coalescing unit served all three of the recip compressors. Its specifications are:

Model No. S-5890
Capacity (HCFC-22 @ -40°F SST) 138 MBH
Dimensions 6 Dia. x 15-5/8 H in.

An AC&R helical unit was installed on the Howden screw compressor. This separator was specially designed for high-efficiency oil separation. Its specifications are:

Model No. S-5292
Capacity (HCFC-22 @ 20°F SST) 265 MBH
Dimensions 6 Dia. x 18 H in.

A separate oil separator/reservoir was provided with the Bitzer screw compressor. Its specifications are:

Model No. OA1854
Capacity (HCFC-22 @ Low Temperature) 12,786 cfh
Dimensions 11 Dia. x 29 H in.

Instrumentation

The laboratory test rack is fully instrumented to ensure accurate and reliable performance evaluation of the refrigerants. Table 2-3 lists the instrumentation used in the rack. Table 2-4 lists the type of performance data we obtain.

The most critical instruments are those used to measure the power and refrigeration load of the rack. For the electric power, we use a two-stator polyphase Watt-hour meter with a pulse output. The harmonics produced by VFDs can distort the readings of many power transducers. These utility-type meters have been proven to provide accurate power metering when used with a VFD. Refrigerant flow is measured using orifice plates in the suction, discharge, and economizer lines. The refrigeration load is measured using three highly accurate instruments: two brine loop thermistors and a brine loop flow meter. The thermistors are precision interchangeable devices with 0.2°F accuracy. The load is continuously checked by comparing the heat gained by the brine to the heat lost from the refrigerant in the chillers. To obtain the refrigerant heat loss, we determine the refrigerant flow using an orifice plate flow meter located in

Table 2-3. Refrigeration System instrumentation

NO.	COMPONENT	MANUFACTURER	MODEL NO.
1-	Thermocouples (9)	Omega	TMQSS-12SU-6
2-	Brine Loop Thermistors (2)	Omega	ON-910-44034
3-	Pressure Transducers (7)	Rosemount	1151GP7E12M1B1
4-	Differential Pressure Transducers (3)	Rosemount	1151DP7E12M1B1
5-	Suction Orifice Plate Flow Meter	Foxboro	OP-FTT-304-300-3
6-	Discharge Orifice Plate Flow Meter	Foxboro	OP-FTT-304-300-2
7-	Vapor Injection Orifice Flow Meter	Foxboro	OP-FTT-304-300-2
8-	Display Case Flow Meter	Fluidyne	214-200
9-	Brine Loop Flow Meter	Signet Sci.	MK-515-P0 2NPT
10-	Liquid Line Flow Meter	K Flow	K-250
11-	Compressor Wattmeter	G.E.	700X1G79
12-	Condenser Wattmeter	OSI	PC5-15B
13-	Torque Sensor	Sensor Developments	01100
	<u>Data Acquisition</u>		
14-	Computer	Compuadd	286/20MHZ
15-	Data-Logger	Campbell Sci.	21X
16-	Multiplexer	Campbell Sci.	AM32

Table 2-4. Test Information Obtained from the Laboratory Test Setup.

1-	Refrigeration Cycle State Points
2-	Power Consumption
3-	Refrigeration Capacity
4-	EER
5-	Evaporator Heat Transfer Rates
6-	Ambient Subcooling
7-	Mechanical Subcooling
8-	Compressor Efficiencies
9-	Electric Drive Efficiency
10-	Drive Frequency
11-	Suction and Discharge Superheat
12-	Vapor Injection Benefit
13-	Condenser Power
14-	Oil Analysis

the suction line. This flow is multiplied by the enthalpy difference of the refrigerant across the chiller to calculate the refrigeration load. An energy imbalance of less than 5% is considered acceptable. Most of our results show less than 3% imbalance. This independent verification allows us to have a high degree of confidence in the accuracy of our results.

Verification of Instrumentation. All instruments were calibrated to ensure the accuracy of their measurements. The Watt-hour meter was calibrated by the manufacturer. We verified the Watt-hour meter's operation with an independent solid-state meter operating on a non-VFD-driven load. The pressure transducers were calibrated at the beginning of testing and as required during testing. Temperature probes were checked in an ice bath before installation and against each other at ambient temperature. The brine flow meter was calibrated at three different brine temperatures.

In addition, a coriolis-effect mass flow meter is mounted in the liquid line of the system. This is the type of flow meter used in the Glens Falls demonstration site. Prior to installation, the flow meter was calibrated using water. After installation, the meter was used to periodically check the suction, discharge, and economizer flow rates measured by the orifice plates.

TEST PLAN

The test procedure for measuring the performance of each compressor and refrigerant combination consisted of two steps. First, we determined the compressor's capacity at the conditions listed in Table 2-5. Next, holding the refrigeration load constant, we measured the compressor's performance over a range of operating discharge pressures. The head was varied so as to obtain an SDT range from 110°F down to 40°F.

Table 2-5. Operating Conditions for Testing

SATURATED SUCTION TEMPERATURE	-20 ± 0.4°F
SATURATED DISCHARGE TEMPERATURE	110 ± 0.4°F
RETURN GAS TEMPERATURE	0 ± 5°F
ECONOMIZER SUPERHEAT	13 ± 4°F
ECONOMIZER CONDITION FOR THE SCREW AND INTERNALLY COMPOUNDED RECIP COMPRESSORS	ALWAYS ON

A VFD was used to match the compressor's capacity to the refrigeration load as the SDT was reduced. Thus, all of the EER results presented include motor and inverter efficiency losses. The open-drive screw was tested with the 3-ton subcooler. The internally compounded recip was tested with both the 2- and 3-ton subcoolers. All tests for the above two compressors were conducted with the subcooler (economizer) operating.

In order to obtain high SDTs even during cold ambient conditions, a separate VFD was installed to control the speed of the condenser fans. This VFD was modulated by a PID controller to maintain the desired discharge pressure.

The test conditions of Table 2-5 and the procedures described above are only applicable to refrigerants that exhibit little or no temperature glide. These include CFC-502, HFC-507, and HFC-404A. For all practical purposes, HFC-404A performs as an azeotrope. Since its evaporator glide is less than 1°F, we decided to treat this near-azeotropic refrigerant as an azeotrope.

However, since HFC-407A has a significant temperature glide, we had to redefine the test parameters for measuring its performance.

HFC-407A can have a glide of over 10°F in the condenser and 6 to 10°F in the evaporator. Since the saturated evaporator temperature (SET) glides upward as the refrigerant passes through the evaporator, the measured SST will be higher than that of the azeotropic refrigerants. For our tests, we matched the average SET of HFC-407A to the SET obtained with the other refrigerants. For the azeotropic refrigerants, the SDT and the saturated condensing temperature (SCT) were essentially the same since there was only a 2 psi drop from the compressor discharge to the condenser outlet. For HFC-407A, the discharge pressure was adjusted upward to maintain an average SCT equivalent to the SDTs found for the other refrigerants. In all the graphs comparing the EER performance of HFC-407A to the other refrigerants, the X axis represents the SDT for the azeotropic refrigerants and the SCT for HFC-407A.

For the lubricant, we chose a Castrol SW68 (300-SUS) POE oil, which was a compromise for both the recips and the screw. This oil is too viscous for the recips and not viscous enough for the screw. Our own previous laboratory tests (1) and tests performed by others (3) have established that a measurable degradation in screw compressor performance can be expected when the oil viscosity is lower than 600-1500 SUS. For the recips, a 300-SUS oil was expected to produce a slightly higher power consumption than a 150-SUS oil. Since we could not run two different

oils in the laboratory refrigeration rack, we settled for a 300-SUS oil with the agreement of all manufacturers whose equipment were being tested. The impact of the use of this oil on the screw compressor capacity and performance is discussed in Section 2.4.4.

The conversion from one refrigerant to another was straightforward. We first removed the refrigerant from the system using a recovery unit. Any required system maintenance or repair was performed, and the system was evacuated overnight. The system was then refilled with the next refrigerant. CFC-502 thermal expansion valves (TXVs) were used for all tests. Since the POE oil was compatible with all of the refrigerants, no oil changes were required.

TEST RESULTS - COMPARISON OF REFRIGERANTS

Figure 2-3 shows the CFC-502 laboratory data obtained for the semihermetic recip. A second-degree polynomial curve is fitted through the data. For visual clarity, in the subsequent graphs that compare the performance of the four refrigerants, only the curve fits are shown and the actual data are not presented. In addition to the EER data, the graphs also show the SST, the refrigeration load, and the return gas temperature (RGT) for each refrigerant, averaged over the SDT range tested. The test results for the different refrigerants are presented for each compressor separately.

Figure 2-3. CFC-502 Energy Efficiency Performance of the Semihermetic Recip Compared to Manufacturer's Data

Semihermetic Recip

The semihermetic recip is one of the more commonly used compressors in the supermarket industry. Figure 2-3 compares the CFC-502 laboratory data for the semihermetic recip with that provided by the compressor manufacturer. The performance data from the manufacturer are adjusted for the actual RGT and drive loss that is present in our system. There is close agreement between the laboratory and manufacturer data at 110°F SDT. The compressor performance is higher than the manufacturer's data at lower SDTs. The higher efficiency is the result of the lower compressor speed. The manufacturer's data rate the compressor at 1750 rpm while our low SDT results were obtained at lower speeds. At low speeds, a reciprocating compressor operates more efficiently due to reduced windage losses and improved volumetric efficiency. Thus, the higher energy efficiency was as expected.

The performance of the compressor with all four refrigerants is compared in Figure 2-4. The actual operational values for the system at 110°F SDT are listed in Table 2-6.

HFC-507. At -20°F SST and 110°F SDT, we found a capacity of 81.7 MBH, 3% lower than that of CFC-502, and an EER of 4.05 Btu/W-hr, 6.9% lower than that of CFC-502. The EER performance of HFC-507 relative to CFC-502 increases as the SDT decreases. Below 52°F SDT, the HFC-507 EER performance is better than that of CFC-502. Our measured performance corresponds closely to HFC-507 data provided by Carlyle.

HFC-404A. A decrease in both capacity and EER was found when testing this compressor with HFC-404A. Compared to CFC-502, the capacity of 78.4 MBH represents a loss of 6.9%. The EER of 4.00 Btu/W-hr at 110°F SDT reflects a decrease of 8.0%. There was very little EER difference between HFC-507 and HFC-404A over most of the SDT range.

HFC-407A. With HFC-407A, at 110°F SDT, the capacity is lower than that of CFC-502 by 10.2% at 75.6 MBH, while the EER is virtually the same at 4.33 Btu/W-hr. At lower SDTs we found the HFC-407A EER performance to be lower than that of CFC-502.

ASPEN SYSTEMS LABORATORY RESULTS
SEMIHERMETIC RECIP / 68 CST POE OIL

Figure 2-4. Comparison of the Energy Efficiency Performance of the Semihermetic Recip Compressor for all Refrigerants

Table 2-6. Summary of Lab Results with the Semihermetic Recip at 110°F SDT

	UNITS	REFRIGERANT			
		CFC-502	HFC-507	HFC-404A	HFC-407A
OIL TYPE		POE	POE	POE	POE
OIL VISCOSITY	cSt	68	68	68	68
SST	°F	-20.0	-20.0	-20.2	-16.5
SDT / SCT (KLEA 60)	°F	110.0	110.4	109.9	109.9
SUCTION TEMPERATURE	°F	3.3	4.3	2.2	2.9
DISCHARGE TEMPERATURE	°F	205	196	197	235
DROP LEG TEMPERATURE	°F	108	111	110	107
RECEIVER OUTLET TEMP.	°F	107	110	109	106
SUBCOOLED LIQUID TEMP.	°F	106	109	108	104
SUCTION PRESSURE	PSIG	15.3	17.9	16.2	11.0
DISCHARGE PRESSURE	PSIG	248	282	268	260
EVAPORATOR FLOW	lb/hr	2,129	2,039	1,862	1,357
FREQUENCY	Hz	60	60	60	60
SATURATED RECEIVER TEMP.	°F	110.6	110.4	110.3	106.5
RECEIVER SUBCOOLING	°F	3.3	0.1	0.8	0.9
SYSTEM SUBCOOLING	°F	4.2	1.4	1.7	5.8
REFRIGERATION LOAD	MBH	84.2	81.7	78.4	75.6
POWER	kW	19.3	20.2	19.6	17.5
EER	BTUW-hr	4.35	4.05	4.00	4.33

Open-Drive Recip

The open-drive recip EER performance with CFC-502 is compared to the manufacturer's performance data in Figure 2-5. The inverter efficiency used was the measured value of 95.9%. A coupling efficiency of 99% was used. These efficiencies, together with factors for density and enthalpy change are used to correct the manufacturer's test data for our operating conditions. The manufacturer's performance program automatically includes a motor efficiency of 93%. For CFC-502, the measured load of 90.5 MBH is identical to that predicted by the manufacturer's performance program. The measured power, however, is nearly 8% higher. As shown in Figure 2-5, the higher power produces a consistently lower EER. The EER performance of the open-drive recip compressor with all four refrigerants is compared in Figure 2-6. The actual operational values for the system at 110°F SDT are listed in Table 2-7.

HFC-507. With HFC-507, we found that the capacity at -20°F SST and 110°F SDT was 85.8 MBH, 5.2% below that of CFC-502. The EER was 4.06 Btu/W-hr, 7.5 % lower than that of CFC-502.

HFC-404A. The measured capacity of the open-drive recip with HFC-404A was 83.9 MBH with an EER of 4.10 Btu/W-hr. The capacity decreased by 7.3% compared to CFC-502. The EER at 110°F SDT decreased by 6.6% compared to CFC-502.

Figure 2-5. CFC-502 Energy Efficiency Performance of the Open-drive Recip Compared to Manufacturer's Data

ASPEN SYSTEMS LABORATORY RESULTS
OPEN-DRIVE RECIP / 68 CST POE OIL

Figure 2-6. Comparison of the Energy Efficiency Performance of the Open-Drive Recip Compressor for All Refrigerants

Table 2-7. Summary of Lab Results with the Open-drive Recip at 110°F SDT

		REFRIGERANT			
		CFC-502	HFC-507	HFC-404A	HFC-407A
OIL TYPE		POE	POE	POE	POE
OIL VISCOSITY	cSt	68	68	68	68
SST	°F	-19.8	-20.0	-19.9	-16.3
SDT / SCT (KLEA 60)	°F	110.1	110.1	110.0	110
SUCTION TEMPERATURE	°F	3.0	1.4	2.3	2.7
DISCHARGE TEMPERATURE	°F	184	177	180	213
DROP LEG TEMPERATURE	°F	108	110	109	106
RECEIVER OUTLET TEMP.	°F	106	109	109	107
SUBCOOLED LIQUID TEMP.	°F	106	108	108	105
SUCTION PRESSURE	PSIG	15.4	17.9	16.4	11.1
DISCHARGE PRESSURE	PSIG	248	281	271	261
EVAPORATOR FLOW	lb/hr	2,311	2,146	1,957	1,366
FREQUENCY	Hz	60	60	60	60
SATURATED RECEIVER TEMP.	°F	110.1	110	110.1	106.5
RECEIVER SUBCOOLING	°F	2.6	0.8	1.1	0.2
SYSTEM SUBCOOLING	°F	4.1	1.7	2.1	4.5
REFRIGERATION LOAD	MBH	90.5	85.8	83.9	75.5
POWER	kW	20.5	21.1	20.5	17.5
EER	BTU/W-hr	4.39	4.06	4.10	4.32

HFC-407A. For HFC-407A, the open-drive recip capacity dropped by 16.6% to 75.5 MBH. The EER performance at 110°F SDT decreased by only 1.6%, from 4.39 to 4.32 Btu/W-hr.

Semihermetic Internally Compounded Recip

This compressor was originally designed for operation with HCFC-22. Unfortunately, due to budgetary constraints, we were unable to test this compressor on HCFC-22. Hence, no comparison with manufacturer's data (available only for HCFC-22) was possible.

The brazed plate subcooler supplied with the compressor was sized to match the expected 2-ton load for HCFC-22. With CFC-502 at 110°F SDT, the 2-ton subcooler had a 25°F approach, resulting in a much higher liquid outlet temperature than desired. For the same subcooler outlet temperature, the subcooling load with CFC-502 is about 50% higher than the load with HCFC-22. Hence, we used the 3-ton shell-and-tube subcooler (intended for the screw compressor) instead. This heat exchanger provided an approach of only 7°F at high SDTs. Compared to its performance with the 2-ton subcooler, the capacity at 110°F SDT increased from 97 MBH to 104 MBH, an increase of 7.2%, while the EER increased nearly 6%. Additional performance comparisons between the 2- and 3-ton subcoolers are presented below, under Test Results. All results presented in this section were obtained with the 3-ton subcooler.

The performance of the compressor with each refrigerant is compared in Figure 2-7 and discussed below. The actual operational values for the 3-ton subcooler at 110°F SDT are listed in Table 2-8.

HFC-507. With HFC-507, the capacity at -20°F SST and 110°F SDT was 113 MBH, 8.1% higher than that of CFC-502, while the EER dropped by 0.9% to 5.49 Btu/W-hr. HFC-507 EER performance was lower than that of CFC-502 over the entire SDT range.

We found that with HFC-507, TXVs need to be opened several turns to obtain the same superheat as with CFC-502.

HFC-404A. The measured capacity with HFC-404A was 106 MBH, 6.0% lower than that of HFC-507 but 1.6% higher than that of CFC-502. The EER at 110°F SDT was 5.33 Btu/W-hr, 3.8% lower than that of CFC-502. HFC-404A EER performance was lower than that of CFC-502 over the entire SDT range.

ASPEN SYSTEMS LABORATORY RESULTS
INTERNALLY COMPOUNDED RECIP/ 68 CST POE OIL / 3 TON SUBCOOLER

Figure 2-7. Comparison of the Energy Efficiency Performance of the Internally Compounded Recip Compressor for All Refrigerants

Table 2-8. Summary of Lab Results with the Internally Compounded Recip at 110°F SDT (3-ton Subcooler)

	UNITS	REFRIGERANT			
		CFC-502	HFC-507	HFC-404A	HFC-407A
OIL TYPE		POE	POE	POE	POE
OIL VISCOSITY	cSt	68	68	68	68
SST	°F	-19.9	-19.8	-20.0	-16.3
SDT / SCT (KLEA 60)	°F	110.3	109.8	110.0	109.9
SUCTION TEMPERATURE	°F	1.8	0.9	2.3	3
DISCHARGE TEMP.	°F	178	176	175	208
DROP LEG TEMPERATURE	°F	109	108	110	107
RECEIVER OUTLET TEMP.	°F	108	110	110	106
SUBCOOLED LIQUID TEMP.	°F	48.4	50.6	49.0	42.7
SUCTION PRESSURE	PSIG	15.4	18.0	16.3	11.1
ECONOMIZER PRESSURE	PSIG	83.3	93.7	89.2	71.9
DISCHARGE PRESSURE	PSIG	249	280	271	260
EVAPORATOR FLOW	lb/hr	1,972	1,810	1,658	1,267
FREQUENCY	Hz	60	60	60	60
SATURATED RECEIVER TEMP.	°F	-	-	110.1	-
RECEIVER SUBCOOLING	°F	1.9	-	0.5	-0.1
SYSTEM SUBCOOLING	°F	61.9	59.2	61.1	67.3
SATURATED ECONOMIZER TEMP.	°F	41.7	42.2	42.0	41.7
ECONOMIZER SUPERHEAT	°F	12.1	18.1	11.7	10.5
REFRIGERATION LOAD	MBH	104.4	112.9	106.1	98.6
POWER	kW	18.8	20.6	19.9	18.2
EER	BTU/W-hr	5.54	5.49	5.33	5.42

HFC-407A. With HFC-407A, the internally compounded recip showed a capacity decrease of 5.6% to 98.6 MBH compared to CFC-502. The EER at 110°F SDT decreased by 2.2% to 5.42 Btu/W-hr.

Open-Drive Screw

The EER performance of the screw compressor with the four refrigerants is compared in Figure 2-8. The operating parameters for this compressor with the 3-ton subcooler at 110°F SDT are listed in Table 2-9.

It is important to note that the CFC-502 performance is not optimized due to the low viscosity of the POE lubricating oil and the high solubility of CFC-502 in the oil. This increases the internal leakage inside the compressor, reducing the volumetric efficiency and EER (1, 2). With the HFC refrigerants, the leakage is much less severe. At the time, the manufacturer recommended a 150-cSt oil for both CFC-502 and its HFC alternatives.

In addition, we ran this compressor at well below the minimum head pressures recommended by Bitzer. At low SDTs, the oil flow was not always adequate to satisfy the sealing requirements of the screws. Despite this limitation, we tested down to 40°F SDT to assess the possible energy savings with low head pressure operation.

We could not directly compare the compressor capacities found with each refrigerant. The 40-hp motor supplied with the Bitzer screw compressor was not large enough for operation with the alternative refrigerants. With CFC-502, we were running well into the service factor of the motor at 67 Hz. Sixty-seven Hz (4000 RPM) was the speed recommended for maximum screw compressor efficiency. With the alternative refrigerants, increases in capacity or decreases in EER resulted in motor overload trips at speeds over 60 Hz. Therefore, all HFC refrigerant tests were run at a maximum speed of 60 Hz and the CFC-502 results were normalized to this speed.

HFC-507. The EER results with HFC-507 were nearly identical to those obtained with CFC-502. The EER at 110°F SDT is 4.00 Btu/W-hr, approximately 3% lower than that of CFC-502. We saw an increase in capacity from 144 MBH to 160 MBH.

HFC-404A. For HFC-404A, the capacity was 156 MBH, an 8.4% increase compared to CFC-502. The EER of 4.07 Btu/W-hr is 1.2% lower than that of CFC-502.

Figure 2-8. Comparison of the Energy Efficiency Performance of the Open-drive Screw Compressor for All Refrigerants

HFC-407A. With HFC-407A, we measured a capacity of 142 MBH, a 1.2% decrease compared to CFC-502. The EER of 3.97 Btu/W-hr was 3.6% lower than that of CFC-502.

As mentioned earlier, the oil used for these tests was not ideal for screw compressor performance. The low-viscosity oil allowed excessive leakage between the lobes of the screws, reducing the capacity and efficiency.

To assess the effect of the low-viscosity oil on the compressor performance, we replaced the 68 cSt Castrol SW68 with an ICI Emkarate RL 150S rated at 140 cSt. A complete set of tests was repeated for HFC-407A. The capacity of the compressor at 110°F SCT increased by 4.0% over the capacity found with Castrol SW68. The EER increased by 2.8%. The improvement in efficiency decreased as the SDT was lowered.

Performance Comparison of the Three Replacement Refrigerants Relative to CFC-502

The theoretical refrigeration capacity for each refrigerant relative to CFC-502 is shown in Table 2-10. The conditions listed in Table 2-5 were used for theoretical calculations. The amount of subcooling used in the calculations is also indicated in the table. The measured refrigeration capacity of each refrigerant in each compressor relative to CFC-502 is shown in Table 2-11.

**Table 2-9. Summary of Lab Results with the Open-Drive Screw
at 110°F SDT (3-ton Subcooler)**

	UNITS	REFRIGERANT			
		CFC-502	HFC-507	HFC-404A	HFC-407A
OIL TYPE		POE	POE	POE	POE
OIL VISCOSITY	cSt	68	68	68	68
SST	°F	-19.9	-20.2	-20.1	-16.2
SDT / SCT (KLEA 60)	°F	110.3	110.2	110.0	110.0
SUCTION TEMPERATURE	°F	2	-2.6	-0.4	2.2
DISCHARGE TEMPERATURE	°F	152	150.1	150.7	168.2
DROP LEG TEMPERATURE	°F	104	106	108	106
RECEIVER OUTLET TEMPERATURE	°F	104	108	108	106
SUBCOOLED LIQUID TEMPERATURE	°F	47.0	48.4	46.9	32.4
SUCTION PRESSURE	PSIG	15.4	17.7	16.3	11.1
ECONOMIZER PRESSURE	PSIG	73.6	83.7	79.6	55.5
DISCHARGE PRESSURE	PSIG	249	281	270	261
EVAPORATOR FLOW	lb/hr	2,893	2,492	2,376	1,710
FREQUENCY	Hz	67	60	60	60
SATURATED RECEIVER TEMPERATURE	°F	107.0	108.1	108.1	105.1
RECEIVER SUBCOOLING	°F	2.7	0.1	0.1	-1.2
SYSTEM SUBCOOLING	°F	63.4	61.8	63.2	77.6
SATURATED ECONOMIZER TEMP.	°F	35.5	36.4	36.3	30.2
ECONOMIZER SUPERHEAT	°F	16.5	15.2	12.4	11.1
REFRIGERATION LOAD	MBH	160.6	160.4	155.9	142.0
POWER	kW	39.0	40.1	38.3	35.8
EER	BTU/W-h	4.12	4.0	4.07	3.97

**Table 2-10. Theoretical Refrigeration Capacity of the
Three Replacement Refrigerants on Four Types of
Compressors Relative to CFC-502**

COMPRESSOR	REFRIGERATION CAPACITY RELATIVE TO CFC-502 (%)		
	HFC-507	HFC-404A	HFC-407A
SEMIHERMETIC RECIP 4°F SUBCOOLING	103	93	94
OPEN-DRIVE RECIP 4°F SUBCOOLING	103	93	94
INTERNALLY COMPOUNDED RECIP 60°F SUBCOOLING	107	102	95
OPEN-DRIVE SCREW 60°F SUBCOOLING	107	102	95

Table 2-11. Measured Refrigeration Capacity of the Three Replacement Refrigerants on Four Types of Compressors Relative to CFC-502

COMPRESSOR	REFRIGERATION CAPACITY RELATIVE TO CFC-502 (%)		
	HFC-507	HFC-404A	HFC-407A
SEMIHERMETIC RECIP	97	93	90
OPEN-DRIVE RECIP	95	93	84
INTERNALLY COMPOUNDED RECIP	108	102	95
OPEN-DRIVE SCREW	112	108	99

Throughout this discussion, the term "relative capacity" is used to denote the ratio of the refrigeration capacity of each refrigerant to that of CFC-502.

For the semihermetic and open-drive recip, the actual capacity of HFC-507 is lower than that of CFC-502 despite the fact that theoretical calculations indicated an improvement. The internally compounded recip showed an increase in HFC-507 relative capacity that is slightly higher than that predicted by cycle calculations. The screw compressor showed a much larger increase in HFC-507 relative capacity than predicted.

The EER performance of HFC-507 relative to CFC-502 varied depending on which compressor was being tested. The semihermetic recip performance was very close over most of the operating range. At very high SDTs, the performance of HFC-507 was slightly lower. The open-drive recip had a lower performance over the entire operating range. The internally compounded recip performance was generally lower than that of CFC-502. The open-drive screw compressor exhibited nearly identical performance to CFC-502.

The measured relative capacities with HFC-404A were very close to the predicted values for all recip compressors. The screw compressor indicated a larger increase in relative capacity than that predicted by cycle calculations. As with HFC-507, this was in part due to the poor sealing ability of the 68 cSt POE oil that was used with the CFC-502.

The EER performance of HFC-404A relative to CFC-502 also varied depending on which compressor was tested. Though there were some measurable EER differences between HFC-404A and HFC-507, they generally produced similar performance curves with each of the compressors. The exception was the internally compounded unit.

With this compressor, HFC-507 showed a closer EER performance to CFC-502 at high SDTs. At lower SDTs, EER performance of HFC-404A was better than that of HFC-507. Compared to HFC-404A, HFC-507 produced a higher refrigeration capacity with all of the compressors.

Performance of HFC-407A relative to CFC-502 also depended on the compressor. For the semihermetic recip, the actual capacity of HFC-407A was 4% lower than that of CFC-502. The relative capacity of the open-drive recip was 11% lower. The internally compounded recip showed a relative capacity identical to the predicted value. The screw compressor showed a higher relative capacity than predicted by about 4%.

The EER performance of the semihermetic recip with HFC-407A was similar to that of CFC-502 at 110°F SDT. At lower SDTs, we measured a relative decrease in the EER performance of HFC-407A.

With HFC-407A, the EER performance of the open-drive recip at 110°F SDT was closer to that of CFC-502 than to those of the other two alternatives with only a 1.6% reduction in EER. The performance at lower SDTs appears to be similar to HFC-507 and HFC-404A.

With HFC-407A, the internally compounded unit showed a reduction in EER compared to that of CFC-502, which got progressively worse as lower SDTs were examined. Above 95°F SDT, HFC-404A performed slightly better than HFC-407A and slightly worse than HFC-507. Below 95°F SDT, its EER performance was lower than those of the other refrigerants.

The open-drive screw with HFC-407A showed a noticeable reduction in EER at all SDTs compared to the other refrigerants.

One significant operational issue that we encountered was the foaming of the oil, especially during start-up. The foaming would cause oil trips with the recip compressors. This problem was also observed by Carlyle during their tests, and they now provide HFC compressors with a higher-capacity oil pump. This pump can maintain oil pressure even during periods of foaming.

Selection of the Proper Suction Pressure Setpoint for HFC-407A

The method used for these tests employed a fixed suction pressure for all of the floating head data. This control method is typical of many existing systems. With high-glide refrigerant such as HFC-407A, there can be additional opportunities to increase performance if a floating suction control is used.

As the discharge pressure is lowered, the liquid temperature entering the thermal expansion valve decreases. Since the saturation temperature of HFC-407A entering the evaporator drops as the liquid temperature is lowered, the actual SET is lowered while the suction pressure is unchanged. Thus at lower head pressures, the suction pressure can be raised without penalizing evaporator performance. This will increase the system's operating EER performance.

For the semihermetic recip at 63°F SCT, a 3.2% increase in EER from 8.43 Btu/W-hr to 8.70 Btu/W-hr would be found for HFC-407A if the suction pressure were increased to maintain the same average SET that was found when the SCT was 110°F. CFC-502 at these same conditions has an EER of 8.68 Btu/W-hr.

Current supermarket rack controllers include a floating suction algorithm. The suction pressure setpoint is increased based on the air temperature in one or two key cases. The controller will raise the suction pressure setpoint so long as the case temperature is maintained. This type of control would allow the system to take advantage of HFC-407A's SET shift at lower SCTs.

TEST RESULTS - COMPARISON OF COMPRESSORS

We had the unique opportunity to examine several types of compressors with all viable CFC-502 long-term refrigerants. In this section, the test results are presented in a format that allows easy comparison of the four types of compressors for each refrigerant tested. The results show the performance of the internally compounded compressor with both the 2- and 3-ton subcoolers.

Comparison of the Four Compressors With CFC-502

Figure 2-9 shows the comparison of the EER performance of the four compressors on CFC-502. As shown in the figure, the internally compounded recip had the best EER performance of all compressors. Above 68°F SDT, its performance is better with the 3-ton subcooler. Below 68°F SDT, the 2-ton subcooler performs distinctly better than the 3-ton unit. This is because at lower SDTs, the subcooling load decreases and the 2-ton subcooler becomes more ideally matched to this load. The open-drive screw and recip performed similarly with the screw, with poorer EER performance at higher SDTs. The semihermetic recip showed the lowest EERs below 100°F SDT.

Figure 2-9. Comparison of the Energy Efficiency Performance of the Four Compressors with CFC-502

Comparison of the Four Compressors With HFC-507

As with CFC-502, the internally compounded recip shows the best EER performance with HFC-507 (Figure 2-10). The performance crossover point for the 2- and 3-ton subcoolers is 78°F. The open-drive screw ranks third in overall performance. At low SDTs (below 55°F), it performed more efficiently than the internally compounded recip with the 3-ton subcooler. The open-drive and semihermetic recip compressors showed similar performance, with the open-drive exhibiting slightly higher EERs over most of the SDT range.

Comparison of the Four Compressors With HFC-404A

With HFC-404A, the internally compounded recip with the 3-ton subcooler shows the highest EER for SDTs above 57°F (Figure 2-11). Below this threshold, the screw compressor is the most efficient. Again, the open-drive and semihermetic recips show similar performance, with the open-drive displaying a slight edge.

Figure 2-10. Comparison of the Energy Efficiency Performance of the Four Compressors with HFC-507

Figure 2-11. Comparison of the Energy Efficiency Performance of the Four Compressors with HFC-404A

Comparison of the Four Compressors With HFC-407A

With HFC-407A, several of the compressors experienced low oil pressure shutdowns at lower SDTs. The most affected was the open-drive recip, which could not be run below 78°F SDT. The newer, high-capacity oil pumps from Carlyle should take care of this problem for the semihermetic and compound cooling compressors, but there is no high-capacity oil pump for the open-drive recip.

As shown in Figure 2-12, the internally compounded compressor performed significantly better than the other compressors. For the range of SDTs for which data were collected, the open-drive and semihermetic recips performed almost identically. Compared to these two compressors, the screw compressor showed higher EERs for SDTs below 90°F.

Comparison of the Four Compressors - Summary

With all of the alternative refrigerants, the internally compounded recip showed the best EER performance. This is the result of the compressor's built-in two-stage compression and mechanical subcooling.

Overall, the open-drive screw compressor showed the second best EER performance. As indicated previously, the performance of the screw can be improved with a higher-viscosity oil.

Figure 2-12. Comparison of the Energy Efficiency Performance of the Four Compressors with HFC-407A

The EER of the open-drive recip is similar to that of the open-drive screw on CFC-502, but it is noticeably lower with the alternative refrigerants. Re-expansion in the cylinder is the suspected cause of this high loss in capacity and EER. The high clearance volume in the open-drive recip can produce lower volumetric efficiencies with the HFC refrigerants and cause the reduced capacity and performance.

The semihermetic recip provided the lowest EERs of the tested compressors. Its single-stage operation, lack of subcooling, and the added motor load to the refrigeration system all adversely affect its performance.

PROJECTED ANNUAL ENERGY EFFICIENCY

We used the second-order curve fits of the measured results to calculate a projected annual EER (AEER) for each of the four compressors. The program used for this calculation is described in Reference 4.

The input parameter values are listed in Table 2-12. The refrigeration load of 120 MBH is typical for the low-temperature suction group of a supermarket. The condenser heat transfer rating was chosen for a design temperature difference (TD) of 9°F. No additional subcooling was specified, since subcooling is included in the curve-fit equations. A minimum condensing temperature of 40°F was chosen for floating-head conditions. The suction pressure drop was set at 0 psid, since all measurements were made at the compressor. The fraction of compressor power transferred to the refrigerant is dependent on the type of compressor. For ambient conditions, bin temperature data for Albany, NY (5), shown in Figure 2-13, were used.

Table 2-12. Operating Conditions Used for AEER Calculations

DESCRIPTION	VALUE	UNIT
Refrigeration Load	120	MBH
Overall Condenser Heat Rating	24,000	Btu/hr/°F
Specified Subcooling	0	°F
Minimum Condensing Temperature	40	°F
Suction Line Pressure Drop	0	psid
Discharge Line Pressure Drop	5	psid
<u>Fraction Of Compressor Power Into Refrigeration System</u>		
Semihermetic Compressors	0.93	
Open-Drive Compressors	0.85

Figure 2-13. Annual Bin Temperature Distribution for Albany, NY.

The results of the annual bin temperature analysis are summarized in Table 2-13. As expected, the compressors that utilized subcooling (internally compounded recip and open-drive screw) show higher overall AEERs than the non-subcooled recip. With all but the screw compressor, the alternative refrigerants appear to impose a measurable AEER penalty compared to CFC-502. With the screw compressor, HFC-507 showed essentially the same AEER as CFC-502, while HFC-404A indicated a 1.1% increase and HFC-407A showed a 4.7% decrease. The internally compounded recip showed the least AEER reduction among the recip. The open-drive recip showed the highest AEER penalty for converting from CFC-502 to an alternative refrigerant. Still, even with this penalty, the open-drive recip exhibits higher AEERs than the semihermetic unit.

Table 2-13. Projected Annual Energy Efficiency Performance of All Compressor Types

REFRIGERANT	CFC-502	HFC-507	HFC-404A	HFC-407A
SEMIHERMETIC RECIP	8.47	8.29	8.27	8.16
OPEN-DRIVE RECIP	8.99	8.43	8.43	8.37
INTERNALLY COMPOUNDED RECIP	9.40	9.13	9.26	8.78
OPEN-DRIVE SCREW	8.86	8.87	8.96	8.44

SUMMARY OF RESULTS AND CONCLUSIONS

- The performance of HFC-507, HFC-404A, and HFC-407A, relative to CFC-502, varied substantially depending on the compressor tested.
- Compared to CFC-502, the semihermetic recip had a drop in capacity of 3% with HFC-507, despite a predicted increase. HFC-404A had a 6.9% drop, while HFC-407A showed a 10.2% decrease.
- The open-drive recip had a 5% decrease in capacity with HFC-507, a 7.3% decrease with HFC-404A, and a 16.6% decrease with HFC-407A. Its EER with all three alternatives was significantly lower than with CFC-502. This is possibly due to the higher clearance volume and older valve design of this compressor.
- The internally compounded compressor with the 3-ton subcooler had an 8.1% increase in capacity with HFC-507, a 1.6% increase with HFC-404A, and a 5.6% decrease with HFC-407A. The EER performance for both refrigerants was lower than with CFC-502.
- The screw compressor capacity registered a larger than expected increase with both HFC-507 and HFC-404A. This was in part due to the low-viscosity highly soluble oil used during the CFC-502 testing. HFC-407A had essentially the same capacity as CFC-502.
- The screw compressor capacity and performance improved when the 68 cSt oil was replaced with a 140-cSt oil.
- The screw compressor's EER was nearly identical using CFC-502, HFC-507, and HFC-404A. AEER calculations showed a slight improvement with HFC-404A.
- The HFC-407A performance was comparable to that of CFC-502 at high SCTs. In systems that have fixed suction control, the performance decreased at lower SCTs relative to CFC-502. If a controller that employs a floating suction control is used, the performance at lower SDTs should be similar to CFC-502.
- The design of the oil pumps on the older recip does not consistently provide sufficient pressure with the alternative refrigerants and oils. The manufacturer now has a higher-capacity oil pump for these compressors.
- No other oil- or refrigerant-related problems were noted.
- CFC-502 valve bodies and heads were used for all testing. The valves required only minor superheat adjustment for proper operation on HFC-404A and HFC-407A. The valves also worked well for HFC-507, but required significant superheat adjustment from their CFC-502 settings. As expected, the capacity and EER performance of HFC-507 and HFC-404A were very similar.
- Comparison of compressor technologies indicated that the internally compounded compressor can offer distinct advantages in annual energy usage.
- The screw compressor exhibited favorable annual energy performance, better than that of the single stage recip that were tested.
- The EER performance of recip can substantially benefit from operating at lower than that of design speeds.

- Recips that do not minimize the cylinder clearance may pay a higher penalty when converting from CFC-502 to one of the HFC alternative refrigerants tested.
- HFC-507, HFC-404A, and HFC-407A appear to be viable alternatives to CFC-502.

GLENS FALLS HFC-507 FIELD TESTING

Section 3

IN THIS SECTION

THE DEMONSTRATION SITE SUPERMARKET

HISTORY OF THE LOW-TEMP REFRIGERATION SYSTEM

DEMONSTRATION TESTING RESULTS

RELIABILITY

LOAD FACTOR OF THE LOW-TEMP RACK

PROJECTED ANNUAL PERFORMANCE

ECONOMIC ANALYSIS

SUMMARY OF RESULTS AND CONCLUSIONS

One of the primary goals of this project was to field-test a viable long-term replacement refrigerant for CFC-502 in the low-temp refrigeration system of a supermarket. The supermarket selected was a Shop 'n Save superstore located in Glens Falls, NY. We identified several HFC-based CFC-502 substitutes (see Table 2-1) and installed the one that, at the time, promised to be the most trouble-free. The refrigerant selected was HFC-507 (AZ-50) manufactured by Allied Signal. AZ-50 was (and still is) the only azeotropic HFC-based refrigerant that offered the potential of performing similarly to CFC-502. It was recently designated as Refrigerant 507 by American Society of Heating, Refrigerating and Air-Conditioning Engineers' Refrigerants Technical Subcommittee (TC 3.1). It is an azeotropic 50/50 mixture of HFC-143a and HFC-125 and has been commercially available since late 1993.

This section describes the Glens Falls demonstration test site and summarizes the results obtained from operating the low-temp rack on HFC-507.

THE DEMONSTRATION SITE SUPERMARKET

The Glens Falls Shop 'n Save superstore was designated as a demonstration site for advanced, non-CFC refrigeration systems in its design stage. Completed in March of 1992, the store employed HFC-134a for its A/C and med-temp systems, and HCFC-22 for its low-temp system. The 63,000-sq. ft. superstore operates 24 hours a day.

The focus of the HFC-507 conversion was the low-temp system which is composed of an open-drive screw compressor, a semihermetic screw, and two semihermetic reciprocating compressors (Figure 3-1). All compressors use VFDs for capacity control.

The system was fully instrumented during construction to allow measurement of operational parameters and energy efficiency. Data collected were used to establish seasonal performance and electric power demand.

Materials performance issues such as component reliability and oil/refrigerant compatibility were also addressed. Oil samples were analyzed on a regular basis to identify excessive contamination, decomposition, chemical shifts, wear, or other long-term compatibility problems.

A complete description of the store, its refrigeration systems, and the instrumentation can be found in Reference 1.

Low-Temp Rack

A summary description of the low-temp refrigeration rack at the Glens Falls Shop 'n Save store is given in Table 3-1. The low-temp rack has two suction groups, -25°F and -15°F, that share a common oil separator, condenser, heat (water) reclaim, receiver, and liquid pump. The rack's piping and instrumentation diagram is illustrated in Figure 3-1. Descriptions of the major components are given below:

Compressors. As shown in Table 3-1, the low-temp refrigeration system had one Howden open-drive screw compressor, one Carlyle semihermetic screw compressor, and two Carlyle semihermetic recip compressors. The Howden compressor has an integral oil separator. The Carlyle screw compressor was provided with an external oil separator/reservoir. The three compressor sets were rotated between the -15°F and -25°F refrigeration loads on a weekly basis.

Oil Coolers. Each screw had its own oil cooler. These oil coolers, mounted in the mechanical center's ceiling, drew air from the mechanical room and exhaust it outside. The specifications for the Carlyle oil cooler are:

Manufacturer	Dunham-Bush
Model No.	DB-32-4
Oil flow rate	6.0 gpm
Heat transfer rating	60 MBH
Dimensions	28H x 28W x 18D in.
Fan power	3/4 hp

Figure 3-1. Piping and Instrumentation Diagram of the Low-Temp Rack

Table 3-1. Description of the Low-Temp Refrigeration Systems in the Glens Falls Test Store

COMPRESSOR						OIL		
NO.	TYPE	MANUF'R	MODEL	DISP. (cfm)	QTY	GRADE (cSt)	TYPE	MANUF'R
1	Semi, Recip	Carlyle	06ER175	75.4	1	100	POE	Castrol
2	Semi, Screw	Carlyle	06TRF065	65.0	1	100	POE	Castrol
3	Open, Screw	Howden	91mm Hummingbird	65.5	1	100	POE	Castrol

Legend: Open - Open-Drive; Semi - Semihermetic; POE - Polyol Ester; Disp. (Displacement) is at 60 Hz.

The specifications for the Howden oil cooler are:

Manufacturer Dunham-Bush
 Model No. DB-31-4
 Oil flow rate 6.0 gpm
 Heat transfer rating 48 MBH
 Dimensions 28H x 28W x 18D in.
 Fan power 3/4 hp

Condenser. The roof-mounted condenser was an air-cooled, belt-driven unit manufactured by Bohn. Its specifications are:

Model No. BVF-100
 Heat transfer rating 48,830 Btu/°F/hr
 Number of fans 3
 Fan power 3 hp

Oil Separator. The oil separator was a high efficiency, dual-chamber, coalescing-type made by Frick. Its specifications are:

Model No. DOC-12
 Carry over rate 10 ppm

Liquid Pump. This rack employed a liquid refrigerant pump to assist in floating the head. The pump also compensated for the pressure drop across the mass flow meters. The pump was a 3/4 hp Hysave centrifugal unit.

Economizer Subcooler. The subcoolers were Dunham-Bush shell and tube heat exchangers. Their specifications are:

Model No. SC003482AJ
 Max. load 43.4 MBH
 LMTD @ design load 31.1°F

Inverter. Two VFDs were used to control the compressor sets that refrigerated the -15°F and -25°F suction groups. The inverters are Emerson Eclipse constant-torque VFDs. Their specifications are:

Model No.	6230 - 8421
Nominal rating	50 hp
Type	Sinusoidal PWM
Maximum efficiency	96%

The maximum frequency output was set to 80 Hz for the open-drive screw and 72 Hz for the semihermetic screw. The maximum frequency of the recip was limited to 60 Hz.

Controller. The refrigeration system was controlled by an EIL RC-1000 rack controller. We utilized the RC-1000 suction pressure control algorithm to control the capacity of all test racks. The controller transmitted an analog signal to the inverter to vary the compressor speed and maintain a specific suction pressure setpoint. The suction solenoid valves in the refrigerant circuits were cycled to maintain case temperature.

-25°F Suction Group Refrigeration Schedule

The -25°F suction group consisted of eight circuits with a total calculated load of 126 MBH. Forty percent of the load was from open coffin cases, 34% from reach-in door cases, and the remainder from a grocery freezer. A complete refrigeration schedule for this suction group is shown in Table 3-2.

The measured average weekly load for this system is shown in Figure 3-2. The peak summer weekly load of 133 MBH was reached during the second week of July 1993.

Table 3-2. -25°F Suction Group Refrigeration Schedule.

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP (°F)	LOAD (MBH)
A9	WEZ - FK Frozen Food	6 ft	-25	2.70
	WIZ - FK Frozen Food	24 ft	-25	15.12
A10	WIZ Frozen Food	24 ft	-25	15.12
A11	WEZ - FK Frozen Food	6 ft	-25	2.70
	WIZ - FK Frozen Food	24 ft	-25	15.12
A12	ZER Ice Cream	14 drs	-25	22.40
A13	ZER Ice Cream	13 drs	-25	20.80
A14	Grocery Freezer	21x28x8	-25	32.16
	Total			126.12

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
-25°F SUCTION GROUP / HFC-507 / 68 CST POE OIL

**Figure 3-2. History of the Refrigeration Load for the
-25°F Suction Group**

-15°F Suction Group Refrigeration Schedule

The -15°F suction group consisted of eight circuits with a total load of 177 MBH. Thrity-five percent of the load was generated by the two ice machines, 17% was from the service meat and dual temp meat cases, 35% was from reach-in door cases, and the remaining 15% was produced by the bakery freezer. A complete refrigeration schedule for this suction group is found in Table 3-3.

Table 3-3. -15°F Suction Group Refrigeration Schedule

CIRCUIT	DESCRIPTION	LINEUP	SUCTION TEMP. (°F)	LOAD (MBH)
A1	Produce Ice - Howe		-5	32.4
A2	Fish Ice - Scotsman		-5	29.7
A3	ZER Frozen Foods	15 drs	-15	21
A4	ZER Frozen Foods	14 drs	-15	19.6
A5	ZER Frozen Foods	15 drs	-15	21
A6	EGM - T Service Meat	24 ft	-15	9.6
A7	TZ - FK Dual Temp Meat Coffin	36 ft	-15	16.56
A15	Bakery Freezer	11x20x8	-15	26.66
	Total			176.52

The measured weekly load on this rack is shown in Figure 3-3. The peak weekly load of 131 MBH was reached during the last week in August 1993.

During the fall of 1992, the load on this suction group was reduced when one of the two ice machines was disconnected. The store managers chose not to use ice for certain products. A significant decrease in average load was seen in the beginning of 1993 (2). The peak load fell from 170 MBH in the summer of 1992 to 131 MBH in the summer of 1993. The 39 MBH drop in load is somewhat higher than the 32.4 MBH listed in the schedule for the ice machine.

Oil Management

The low-temp rack required a special design for its oil management systems. Screw compressors require a significant amount of high-pressure oil to seal their rotors during the compression process. As a result, they discharge a substantial amount of oil. The low-temp rack contained two of these compressors. Though the open-drive Howden screw compressor contained its own internal separator, we found that its oil carryover rate could be as high as 4 gal/hr(2). As illustrated in Figure 3-1, the discharge line of the semihermetic screw compressor was piped into a special oil separator/reservoir supplied with the compressors. The amount of oil not captured by

**Figure 3-3. History of the Refrigeration Load for the
-15°F Suction Group**

this separator was substantially less than the oil carryover of the Howden compressor. The excess oil from all the screw compressors was carried through the high and low sides and could significantly reduce the effectiveness of the condenser and evaporators. Furthermore, this oil could accumulate preferentially in either the sump of the open-drive screw, in the oil reservoir of the semihermetic compressor, or in the semihermetic recip.

To reduce the amount of oil carried into the condenser and evaporators and ensure adequate oil supply to each compressor, an additional oil separator for the combined discharge flow was installed (Figure 3-1). The oil separated by this oil separator was directed to an external oil reservoir that was maintained at discharge pressure. When a compressor is low on oil, oil is fed from the external reservoir into the compressors' oil injection ports. For the recips, a pressure regulator reduced the oil supply pressure to about 45 psi above suction before it was fed to the compressors' oil floats.

Control And Data Acquisition Systems

The control of the low-temp refrigeration suction groups was handled by two EIL RC-1000 refrigeration rack controllers. These controllers regulate all facets of the system operation, including compressor speed, case temperature, defrost cycles, and condenser fan cycling.

The RC-1000 controllers are also capable of recording data and were therefore used as part of the data collection system. However, the RC-1000 used eight-bit resolution for storing the data, that was insufficient for critical readings. An independent, sixteen-bit Campbell Scientific CR7 data logger was installed to monitor the critical data points.

The CR7 data points were recorded every 12 seconds and were averaged over five-minute periods. The five-minute values were stored in the unit's internal memory until they were downloaded. The RC-1000 systems stored instantaneous data every five minutes in the internal memory.

Instrumentation

Each of the refrigeration systems was instrumented for temperature, humidity, pressure, flow, and power measurements. A description of each type of sensor is provided below.

1. Temperatures and Dewpoints - Critical points in the liquid and suction lines used to determine the refrigeration load were monitored with precision RTDs inserted into the flow. All other points were monitored with immersion thermistors or clamp-on, solid-state temperature sensors. Indoor and outdoor temperatures and dewpoints were also measured.
2. Pressures - System pressures critical to calculating refrigeration loads were measured by precision pressure transmitters calibrated prior to installation. Standard EIL pressure transducers were used for all other pressure readings.
3. Flow Rates - Coriolis-effect mass flow meters were used to measure the refrigerant flow rate in the liquid line of each suction group. These flow meters provide pulse outputs for each pound of refrigerant mass that passes through them. Pulses accumulated over a specified data collection interval were divided by the duration of that interval to determine the mass flow rate. Since the meters measure mass flow directly, no adjustments were needed for changes in temperature, viscosity, or density.
4. Electric Power - Power for each bank of compressors was measured with a two-stator, polyphase Watt-hour meter equipped with an electronic demand register. These meters provided pulse output for each unit of energy actually used. Pulses accumulated over a specified data collection interval were divided by the duration of that interval to determine power level. This type of meter reads accurately despite the frequency variations and harmonics produced by the variable-frequency drives. The power used by each refrigerant condenser was monitored with Hall-effect-type Watt transducers. The condenser fan motors were not powered by variable-frequency drives.

Table 3-4 lists the critical instruments used to measure the performance of the Glens Falls low-temp rack.

HISTORY OF THE LOW-TEMP REFRIGERATION SYSTEM

The low-temp refrigeration system is composed of three sets of compressors: an open-drive screw, a semihermetic screw, and two semihermetic reciprocating (Table 3-1). When the store was opened, it used HCFC-22 and a 300 SUS alkylbenzene oil. Prior to the HFC-507 conversion, the rack was converted (on May 11, 1993) to CFC-502 for a period of five weeks. On June 15, 1993, the system was converted to HFC-507. The five-week period was used to obtain some reference CFC-502 data. Also during this period, the rack was purged six times with a Castrol SW100 (450-SUS) POE oil. Field

Table 3-4. List of the Critical Instrumentation of the Glens Falls Low-Temp Rack

Point	Type	Description	Symbol	Units
<u>High Accuracy Campbell Scientific Data Logger</u>				
1	Temperature	-15 EVAPORATOR LIQUID	TE	°F
2	Temperature	-15 EVAPORATOR SUCTION	TF	°F
3	Temperature	-25 EVAPORATOR LIQUID	TG	°F
4	Temperature	-25 COMPRESSOR SUCTION	TH	°F
5	Pressure	-15 EVAPORATOR LIQUID	PE	psig
6	Pressure	-15 COMPRESSOR SUCTION	PF	psig
7	Pressure	-25 EVAPORATOR LIQUID	PG	psig
8	Pressure	-25 COMPRESSOR SUCTION	PH	psig
9	Pressure	LOW-TEMP RACK DISCHARGE	PL	psig
10	Flow	-15 LOW-TEMP	FC	lb/pulse
11	Flow	-25 LOW-TEMP	FD	lb/pulse
12	Power	-15 LOW-TEMP	PWC	kWh/pulse
13	Power	-25 LOW-TEMP	PWD	kWh/pulse
14	Temperature	OUTDOOR TEMPERATURE	TK	°F
15	Power	STORE POWER	PWF	kWh/pulse

test kits indicated that after six changes the mineral oil level was below 5%. Lab tests still indicated a mineral oil concentration of up to 20%. For this reason, the rack was purged a seventh time, to ensure that the mineral oil concentration was below 5%.

Originally, the rack contained two Carlyle open-drive screw compressors. These prototype compressors suffered from several control problems that caused invalid data. Later, during the refrigerant conversion, these compressors were replaced with a single high-speed Carlyle semihermetic screw. Consequently, all valid HFC-507 data for Carlyle screws were obtained on the semihermetic screw, while no HCFC-22 data were obtained with this compressor.

Data collected on CFC-502 during the period of May 11, 1993 through June 15, 1993 are not presented in this report. The relatively short run time for each compressor on each suction group, the multiple oil purges, and several operational problems, have shed some doubt as to the validity of these data.

This section describes the test procedure and results obtained from the Glens Falls store between June 1993 and March 1994. The test plan and data reduction procedure are presented, followed by performance and reliability results.

DEMONSTRATION TESTING RESULTS

Test Procedure

The following tests were conducted on a continuous basis:

- The three compressor banks were alternated between the -15°F and -25°F suction groups on a weekly basis. Compressor performances were measured and compared.
- Oil samples were taken on a regular basis from each system. Samples were analyzed to determine if excessive contamination, decomposition, chemical shifts, wear or other long term compatibility problems occurred between the refrigerant, oil, and system components.

Data Reduction

Data were downloaded and saved in weekly blocks that corresponded to the performance of each group of compressors. Average weekly data were summarized in a table showing date and time of compressor switchover, manually recorded Watt-hour readings, power consumption, and average results. This table is included in Appendix A. The manually recorded Watt-hour readings were used to verify power readings derived from the data collection system. The data sets were combined and reduced by FORTRAN programs developed by Aspen Systems.

-25°F Suction Group Test Results

Figures 3-4, 3-5 and 3-6 show the EER performance with the semihermetic recip, the semihermetic screw, and the open-drive screw compressors, respectively, as each is connected to the -25°F refrigeration load. The performance is plotted against the SDT. The SDT is the saturated temperature corresponding to the compressor discharge pressure (measured at the discharge manifold). It is generally a few degrees higher than the condensing temperature. The difference depends on the pressure drop between the compressor discharge and the condenser. The minimum SDT setpoint for the low-temp rack was 34°F (80 psig). The suction temperature range for these graphs is -5 to 20°F.

Semihermetic Recips. Figure 3-4(a) shows the raw data collected for the semihermetic recipis. These data were smoothed according to the procedure outlined in Section 3 of Reference 2, and a second-order polynomial was fitted through the smoothed data. The same procedure was repeated for the other compressor types. Figure 3-4(b) shows the curve fit of the data in Figure 3-4(a) juxtaposed against the expected performance curve based on the manufacturer's data. The manufacturer's

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
SEMIHERMETIC RECIPS / -25°F SUCTION GROUP / HFC-507

Figure 3-4. Energy Efficiency Performance of the Semihermetic Recips on the -25°F Suction Group, (a) Raw Measured Data, (b) Curve Fit of Measured Data Compared to Manufacturer's Data

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
SEMIHERMETIC SCREW / -25°F SUCTION GROUP / HFC-507

Figure 3-5. Energy Efficiency Performance of the Semihermetic Screw on the -25°F Suction Group, (a) Raw Measured Data, (b) Curve Fit of Measured Data Compared to Manufacturer's Data

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
OPEN-DRIVE SCREW / -25°F SUCTION GROUP / HFC-507

Figure 3-6. Energy Efficiency Performance of the Open-Drive Screw on the -25°F Suction Group, (a) Raw Measured Data, (b) Curve Fit of Measured Data Compared to Laboratory Data

data was corrected for superheat, subcooling, and inverter efficiency. The lower measured efficiencies (at high SDTs) in Figure 3-4(b) are most likely due to parasitic system losses. The system performance improves at lower SDTs because the shaft speed of the recips was reduced to match the compressors' capacity to the refrigeration load. Recips operate more efficiently at lower shaft speeds due to reduced valve losses. The manufacturer's data are for a constant speed and do not reflect the benefit for operating at lower speeds.

Semihermetic Screw. Figure 3-5 shows the performance with the semihermetic screw. Again, the EER is lower than the corrected manufacturer's data. The measured performance relative to manufacturer's data does not improve at lower SDTs, since a screw compressor does not operate more efficiently at lower speeds.

Open-Drive Screw. Figure 3-6 shows the EER performance of the open-drive screw. The comparison curve is based on laboratory results under similar conditions. However, the compressor used in the laboratory tests was a more recent, improved version (Mark IV) with a low V_i of 2.6. The demonstration compressor was an older (Mark III) version, and had a higher V_i (3.6). The laboratory results include the inverter drive efficiency but do not include cycling losses.

Compressors Performance Comparison. The curve fits for each compressor type are compared in Figure 3-7. The comparison indicates that the open-drive screw is more efficient than the other two types of compressor at SDTs below 73°F. This compressor's 3.6 internal volume ratio favors the lower SDTs. The semihermetic screw features variable V_i and shows better performance at high SDTs. The performance of this compressor is much closer to that of the semihermetic recips, though it shows a slightly higher EER at low SDTs. At high SDTs, the semihermetic recips show the highest system efficiency.

Refrigerant Performance Comparison. The performance of the semihermetic recips on HFC-507 and HCFC-22 is similar (Figure 3-8). The EER is somewhat better for HCFC-22 at SDTs above 80°F. At lower SDTs, HFC-507 exhibits a slight advantage. The open-drive screw performance for the two refrigerants is indistinguishable up to 80°F SDT (Figure 3-9). Above this point, HFC-507 shows significantly lower performance. Actual suction temperature range for Figures 3-7 and 3-8 ranged from

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
-25°F SUCTION GROUP / HFC-507

Figure 3-7. Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -25°F Suction Group

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
SEMIHERMETIC RECIPS / -25°F SUCTION GROUP

Figure 3-8. Comparison of the Energy Efficiency Performance of the Semihermetic Recips with HCFC-22 and HFC-507 on the -25°F Suction Group

Figure 3-9. Comparison of the Energy Efficiency Performance of the Open-Drive Screw with HCFC-22 and HFC-507 on the -25°F Suction Group

-5 to 20°F. As mentioned above, no HCFC-22 performance was obtained for the semihermetic screw.

-15°F Suction Group Test Results

The energy efficiency performance of the three compressor types on the -15°F suction group is presented in Figures 3-10, 3-11 and 3-12. The minimum SDT setpoint for the low-temp rack was 34°F (80 psig). The suction temperature range for these graphs is 0 to 25°F. All of the graphs exhibit significant spread in the data at the lowest SDTs. This is attributed to increased cycling of the compressors with the lower load.

Semihermetic Recips. Figure 3-10 shows the EER performance with the semihermetic recips. Preliminary HFC-507 data from the manufacturer are also shown. The manufacturer's data are corrected for superheat, subcooling, and the use of the inverter. As in the -25°F suction group, the EER performance compared to manufacturer's data improves at lower SDTs because of lower shaft speeds.

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
SEMIHERMETIC RECIPS / -15°F SUCTION GROUP / HFC-507

Figure 3-10. Energy Efficiency Performance of the Semihermetic Recips on the -15°F Suction Group, (a) Raw Measured Data, (b) Curve Fit of Measured Data Compared to Manufacturer's Data

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
SEMIHERMETIC SCREW / -15°F SUCTION GROUP / HFC-507

Figure 3-11. Energy Efficiency Performance of the Semihermetic Screw on the -15°F Suction Group, (a) Raw Measured Data, (b) Curve Fit of Measured Data Compared to Manufacturer's Data

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
OPEN-DRIVE SCREW / -15°F SUCTION GROUP / HFC-507

Figure 3-12. Energy Efficiency Performance of the Open-Drive Screw on the -15°F Suction Group, (a) Raw Measured Data, (b) Curve Fit of Measured Data Compared to Laboratory Data

Semihermetic Screw. The EER performance with the semihermetic screw is shown in Figure 3-11. Again the performance is lower than that predicted by the manufacturer's data. The measured performance relative to manufacturer's data does not improve at lower SDTs, since a screw compressor does not operate more efficiently at lower speeds.

Open-Drive Screw. Figure 3-12 shows the open-drive screw on the -15°F load. As in the case of the -25° suction group, the comparison curve is based on laboratory results using a Mark IV screw compressor with a Vi of 2.6. The demonstration unit is an older model with a Vi of 3.6.

Compressors Performance Comparison. The EER curve fits for each compressor are compared in Figure 3-13. The comparison indicates that the open-drive screw is significantly more efficient than the other two types of compressors at SDTs below 68°F. This is similar to our findings on the -25°F suction group. The semihermetic screw exhibits higher EERs than the reciprocating compressors over most of the operating range. Only above 98°F SDT does the performance of the reciprocating compressors exceed that of the semihermetic screw. The semihermetic reciprocating compressors show the best performance near design conditions.

Refrigerant Performance Comparison. For the -15°F SST suction group with the semihermetic reciprocating compressors, the EER performance was significantly lower with HFC-507 than with HCFC-22 (Figure 3-14). This is in contrast to our findings with these compressors on the -25°F load. The large disparity between installed and actual refrigeration load must contribute to this loss in performance. When HCFC-22 was tested, this suction group was connected to nearly 40 MBH higher refrigeration load, which matched the compressors' capacity more closely.

Comparison of the EER performance for the two refrigerants (Figure 3-15) with the open-drive screw indicates a distinct difference in performance. Below 60°F SDT, HFC-507 shows higher EER. Above 60°F SDT, HCFC-22 shows better efficiency.

System Issues

Throughout the 10 months of testing, we did not experience any refrigerant- or oil-related problems. However, the startup of the screw compressors with the wrong shaft rotation became an issue. Unlike reciprocating compressors, the internal design of the rotor bearings allows the screw compressor to spin only in one direction. When the compressor spins

Figure 3-13. Comparison of the Energy Efficiency Performance of the Three Compressor Types on the -15°F Suction Group

Figure 3-14. Comparison of the Energy Efficiency Performance of the Semihermetic Recips with HCFC-22 and HFC-507 on the -15°F Suction Group

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
OPEN-DRIVE SCREW / -15°F SUCTION GROUP

Figure 3-15. Comparison of the Energy Efficiency Performance of the Open-Drive Screw with HCFC-22 and HFC-507 on the -15°F Suction Group

in the opposite direction, the bearings cannot absorb the reversed axial force and will seize, damaging the compressor. This problem arose because of the lack of familiarity of the service technicians with screw compressors. A differential pressure switch was added to ensure that the compressor was spinning in the proper direction. In order to satisfy the semihermetic screw's oil pressure requirement, the minimum SDT setpoint was increased from 10°F (45 psig) to 34°F (80 psig) . After these initial issues were resolved, the operation was uneventful.

Oil Analysis

The oil from the rack was sampled and analyzed on a regular basis. The analysis examined metal content, moisture level, and acid number. Minimum, maximum, and last recorded values for each system are shown in Table 3-5.

The oil from the low-temp rack has had a consistently low metal content and acid number. The acid number history is shown in Figure 3-16. The low-temp compressors appeared to be running with no abnormalities or wear.

**Table 3-5. Oil Test Summary of the
Low-Temp Rack in the Glens Falls Store**

	LOW-TEMP		
	MAX	MIN	LAST
Aluminum (ppm)	<.05	<.05	<.05
Copper (ppm)	0.7	<0.1	0.3
Iron (ppm)	1.1	<0.1	<0.1
Tin (ppm)	<0.5	<0.5	<0.5
Zinc (ppm)	0.6	<0.1	0.4
Moisture (ppm)	143	26	32
Acid Number	0.01	0.01	0.01

**Figure 3-16. History of the Acid Number of the Low-Temp Rack
with HFC-507 and POE Oil**

Measuring the actual system moisture in oil samples can be difficult. POE oils are extremely hygroscopic and will generally have a higher moisture content than mineral oils. Figure 3-17 indicates the high moisture readings recorded on the low-temp rack. These readings are not necessarily indicative of the actual levels in the system. The manufacturer (Castrol) believes that some moisture may have migrated into the oil when it was shipped to the lab in a plastic sample bottle.

GLENS FALLS SHOP 'N SAVE DEMONSTRATION RESULTS
LOW-TEMP RACK / HFC-507/ 68 CST POE OIL

Figure 3-17. History of the Moisture Content of the Low-Temp Rack with HFC-507 and POE Oil

To determine if this was the case, we took two simultaneous samples, one in a plastic container and one in a metal container (last samples shown in Figure 3-17). A significantly lower moisture was found in the sample in metal containers. It appeared that in order to obtain accurate moisture readings, certain plastic containers could not be used. Also, the difference between the samples sent to the Thompson and Castrol laboratories may have been due to migration through the plastic bottles. The Castrol lab is located in Los Angeles, CA, whereas the Thompson lab is in Minneapolis, MN. The difference in the humidity and ambient temperatures of the two sites may also have been the cause of the difference in their moisture measurements.

As previously noted, specific maximum limits have not yet been determined for either moisture level or acid number. When measurements are made with plastic containers, Castrol recommends monitoring the system closely to ensure that moisture levels are kept below 200 ppm. A better indication of moisture in the oil is obtained if metal containers or more-moisture-resistant plastic containers are used.

No discernible oil problems were discovered that could be attributed to the use of POE oil or HFC-507.

RELIABILITY

No significant problems were reported associated with the use of the alternative refrigerants or oils. Oil analysis repeatedly indicated no breakdown or wear problems.

The fact that screw compressors can only rotate in one direction must be made clear to service technicians. One failure of one of the screws was due to reverse rotation of the screw. This occurred when the inverter was bypassed in an attempt to run the compressor directly from the electric bus. Otherwise, the inverter would have protected the compressor as it has built-in phase reversal protection. As described above under System Issues, in order to protect the compressor without relying on the phase sequence, a differential pressure switch was added between the suction and discharge ports of the compressors.

LOAD FACTOR OF THE LOW-TEMP RACK

A measurement that is of interest to utilities for identifying the demand associated with an electric system is load factor. The load factor is defined as the average power used by the system for a given period (in this case one month), divided by the system's 15-minute demand. A fixed 15-minute demand interval is the method used by the utility supplying the store's electric power, Niagara Mohawk.

Figure 3-18 shows the load factor of the low-temp rack, juxtaposed against the load factors of the other refrigeration racks and that of the entire store, for fifteen months, starting in January 1994. The load factor for the low-temp rack varies from 0.45 to 0.69. The med-temp rack shows load factors that vary from 0.45 to 0.64. As expected, the air conditioning rack's load factor is very low in the beginning of the cooling season and climbs to 0.5 by the end of summer. The store's load factor peaks in the winter and ranges from 0.73 to 0.89, which is consistently higher than that of any of the racks.

PROJECTED ANNUAL PERFORMANCE

We used the second-order curve fits in Figures 3-7 and 3-13 to calculate a projected annual EER (AEER) for each of the three compressor types with HFC-507. For HCFC-22, we used the curve fits in Figures 3-8, 3-9, 3-14, and 3-15. Since the semihermetic screw was installed after the HCFC-22 was removed from the system, no HCFC-22 data were available for this compressor. The performance curves in the

Figure 3-18. Load Factors of the Refrigeration Racks in Glens Falls Store Compared to the Entire Store

aforementioned figures had to be extrapolated to cover SDTs up to 110°F. The results of these extrapolations are shown in Table 3-6, where the EERs of all compressors at the design condition of 110°F SDT are illustrated. The resulting curve fits were fed into a bin temperature analysis program described in Reference 4. Table 2-12 summarizes the input parameters for the program. The refrigeration load of 120 MBH is typical for the low-temp suction group of a supermarket. The condenser heat transfer rating was chosen for a design TD of 9°F. No additional subcooling was specified, since subcooling was included in the curve-fit equations. A minimum condensing temperature of 40°F was chosen for floating-head conditions. The suction pressure drop was set at 0 psid, since all measurements were made at the compressor. The fraction of compressor power transferred to the refrigerant is dependent on the type of compressor. For ambient conditions, bin temperature data for Albany, NY (5) were used. The ambient temperature profile is shown in Figure 2-13.

The performance results of the bin temperature analysis for the two suction groups are listed in Table 3-7. The two screw compressors show higher AEERs than the semihermetic recip. This corroborates our laboratory findings. The screw compressor's EER exceeds the efficiency of the recip at lower SDTs, where the system spends most of its operating time. As shown, the screw's advantage over the recip is more pronounced for the -15°F system. This is because the relative efficiency of

**Table 3-6. Extrapolated Compressor EER at 110°F SDT
Based on Curve Fits of Field Data**

SUCTION GROUP	SYSTEM DESCRIPTION	EER	
		Btu/W-hr	
		HFC-507	HCFC-22
-25°F	Semihermetic Recip	3.84	4.00
	Semihermetic Screw	3.61	Not Measured
	Open-Drive Screw	2.59	3.39
-15°F	Semihermetic Recip	4.64	4.64
	Semihermetic Screw	3.9	Not Measured
	Open-Drive Screw	3.31	4.28

Table 3-7 Annual EER and Energy Usage of the Low-Temp Refrigeration Systems in the Glens Falls Store

-25°F SYSTEM				
	HFC-507		HCFC-22	
COMPRESSOR	ANNUAL	ANNUAL ENERGY	ANNUAL	ANNUAL ENERGY
	EER	CONSUMPTION	EER	CONSUMPTION
	Btu/W-hr	kW-hr	Btu/W-hr	kW-hr
Semihermetic Recip	7.00	150,091	6.90	151,874
Open-Drive Screw	7.40	142,614	7.40	142,624
Semihermetic Screw	7.15	147,056	Not Meas.	Not Measured
-15°F SYSTEM				
	HFC-507		HCFC-22	
COMPRESSOR	ANNUAL	ANNUAL ENERGY	ANNUAL	ANNUAL ENERGY
	EER	CONSUMPTION	EER	CONSUMPTION
	Btu/W-hr	kW-hr	Btu/W-hr	kW-hr
Semihermetic Recip	7.85	133,972	8.33	126,263
Open-Drive Screw	8.74	120,223	8.89	118,244
Semihermetic Screw	8.54	123,141	Not Meas.	Not Measured

screws compared to recips increases at lower pressure ratios. At -25°F SST, HCFC-22 and HFC-507 AEER performance is similar. However, at -15°F SST, HCFC-22 shows better efficiency than HFC-507, which can be expected from theoretical cycle calculations.

ECONOMIC ANALYSIS

Though a particular system may be more energy efficient, the system's economic benefit must be favorable to justify its use. For an economic analysis, we examined the LCC of the different options tested. The economic analysis performed is described in Appendix B. The economic descriptors calculated are: the LCC, the NPVS, the ROI, and the simple payback period. Table 3-8 summarizes the parameter values used for this analysis.

For the economic analysis of the low-temp rack, the semihermetic recipcs were chosen as the base system. These compressors are industry standards for supermarket refrigeration. Table 3-9 lists the results of the economic analysis for both the -25°F and -15°F suction groups with HFC-507. The first cost data for the different racks are based on estimates obtained from Phoenix Refrigeration Systems.

Both the open-drive and semihermetic screws show an economic advantage over the semihermetic recipcs. For the -25°F system, the open-drive screw has the highest ROI (33.9%), translating into a payback period of 3.5 years. The semihermetic screw exhibits an ROI of 24.5%, with a payback period of 5 years.

As expected, the screws are even more economical for the -15°F suction group. The ROI of the semihermetic screw is the highest, at 67.1%, with a payback period of only 1.7 years. The ROI of the open-drive screw is 56.5%, with a payback period of 2 years.

With HCFC-22 (Table 3-10), the payback period for the open-drive screw for -25°F SST is 2.9 years, showing even more economic advantage than with HFC-507. However, for -15°F SST, the payback period of 3.3 years is substantially longer than the 2 years determined for HFC-507.

Table 3-8 Parameters Used for the Economic Analysis

Discount Rate	7	%
Electricity Cost (including demand)	10	¢/kW-hr
Electricity Escalation Rate	5	%/yr
Maintenance Cost (Recips)	1,000	\$/yr
Maintenance Cost (Screws)	900	\$/yr
Maintenance Cost Escalation Rate	5	%/yr
Salvage Value	500	\$
System Life	15	yr

**Table 3-9. Economic Comparison of Low-Temp
Refrigeration Systems Using HFC-507**

-25°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	YR
Semihermetic Recip	23,000	15,009	1,000	500	230.0	Base System		
Semihermetic Screw	25,000	14,706	900	500	226.8	3,222	24.5	5.0
Open-Drive Screw	26,000	14,261	900	500	222.0	7,970	33.9	3.5
-15°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	YR
Semihermetic Recip	23,000	13,397	1,000	500	209.1	Base System		
Semihermetic Screw	25,000	12,314	900	500	195.8	13,311	67.1	1.7
Open-Drive Screw	26,000	12,022	900	500	193.1	16,087	56.5	2.0

**Table 3-10. Economic Comparison of Low-Temp
Refrigeration Systems Using HCFC-22**

-25°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	YR
Semihermetic Recip	23,000	15,187	1,000	500	232.3	BASE SYSTEM		
Open-Drive Screw	26,000	14,262	900	500	222.0	10,265	40.4	2.9
-15°F SYSTEM								
SYSTEM DESCRIPTION	INITIAL COST	ENERGY COST	MAINTEN. COST	SALVAGE VALUE	LCC	NPVS	ROI	PAYBACK PERIOD
	\$	\$	\$	\$	\$(1000)	\$	%	YR
Semihermetic Recip	23,000	12,626	1,000	500	199.2	BASE SYSTEM		
Open-Drive Screw	26,000	11,824	900	500	190.5	8,672	35.9	3.3

SUMMARY OF RESULTS AND CONCLUSIONS

- The conversion from HCFC-22 to HFC-507 at the demonstration site went smoothly and no startup problems with the refrigerant or the POE lubricant were encountered.
- Seven oil changes were performed prior to the retrofit with HFC-507. Field test kits indicated that after six changes the mineral oil level was below 5%. Lab tests still indicated a mineral oil concentration of 20%.
- Our experience with HFC-507 in the low-temp rack of the Glens Falls store has been extremely favorable. We have observed no incompatibility problems between HFC-507, its POE lubricant, and the rest of the system. HFC-507 appears to be a trouble-free long-term refrigerant replacement for low-temp refrigeration.
- The efficiency performance of the low-temp rack on HFC-507 and HCFC-22 was similar. With the open-drive screw, the EER of the two refrigerants was virtually identical below 80°F SDT. Above 80°F SDT, HCFC-22 showed higher EERs. With the semihermetic recip, HFC-507 showed higher EERs than HCFC-22 below 68°F SDT. Above 68°F SDT, HCFC-22 showed slightly higher EERs.
- The screw compressors provided significantly better AEER than the recip for the low-temp rack. The screw's advantage over the recip was more pronounced for the -15°F suction group.
- The recip were more efficient than the screws at high SDTs suggesting that in warmer climates they may show a better annual performance.
- HCFC-22 and HFC-507 annual efficiency results were similar for a -25°F suction group. At -15°F SST, HCFC-22 performed noticeably better than HFC-507.
- An economic analysis indicated a payback period of 3.5 to 5 years for a screw compressor rack over a semihermetic recip compressor rack for a -25°F refrigeration load using HFC-507. The payback period for a screw compressor rack is even more attractive for a -15°F refrigeration load (1.7 to 2 years). HCFC-22 shows a slightly better economic performance (than HFC-507) at -25°F SST, but a somewhat worse performance at -15°F SST.

TECHNOLOGY TRANSFER

Section 4

IN THIS SECTION

PUBLICITY

PRESENTATIONS/PAPERS

AWARDS

PUBLICITY

The following is a brief description of some of the publicity about this project and its predecessor as of November 1, 1992.

1. Associated Press article, released the week of June 1, 1992. This article on the Glens Falls store appeared in many papers nationwide during the week it was issued.
2. Consulting-Specifying Engineer, May 18, 1992, News in Review, "First supermarket non-CFC refrigeration and air conditioning systems installed." This article contained a brief description of the Glens Falls refrigeration systems and mentioned the funding authorities. There was also an excellent picture of all three low-temp screw compressors.
3. Engineered System, May 1992, "Screw Compressors Make The Grade In Supermarkets." This general article on screw compressors in supermarkets had several large portions devoted to the testing being done by Aspen Systems. It included two pictures of the rack at Clifton Park and one of the rack at Aspen Systems.
4. Store Equipment and Design, March/April 1992, "Shop 'N Save in first U.S. test of non-H/CFC." This article presents some of the results of Clifton Park tests and details the Glens Falls refrigeration systems. There is also a listing of the project funding agencies and project participants.
5. Air Conditioning, Heating and Refrigeration News, April 27, 1992, "New supermarket uses HFC-134a for medium temperature refrigeration." This is a broad overview of the refrigerants and compressors installed at the Glens Falls store. The project participants and the funding agencies were listed.
6. Glens Falls Store Opening Ceremony, March 23, 1992. This event was covered by several news paper reporters including one from the New York Times. Several local television stations also covered the ceremony. Hannaford received an award from the American Lung Association at this ceremony for using non-CFCs in this store. Advertisements announcing the opening of the non-CFC store were placed in the New York Times and the Wall Street Journal by Hill Refrigeration, Carlyle Compressor, and Phoenix Refrigeration.

7. Televised CNN spots on the Glens Falls store were aired on the 4th and 5th of January 1992.
8. ASHRAE Journal, November 1991, Industry News, "R-134a test installation planned." This short piece presented an overview of the Glens Falls demonstration site and a picture of a technician working on a refrigeration rack. A partial list of project participants and funding agencies was also included.
9. Energy Users News, January 1993, "Store Gets HFC-based Refrigeration System." This article reviewed the installation and operation of the Glens Falls store, including costs associated with the HFC-134a conversions. All of the funding agencies were mentioned and many of the project participants were noted in the article.
10. Store Equipment and Design, January/February, 1993, "Substitute beats Standby." This article elaborated on the HFC-134a field and laboratory test results.
11. Store Equipment and Design, March 1993, "Hannaford goes chlorine-free in 6-months refrigerant try-out." The article describes the pending change from HCFC-22 to AZ-50 at the Glens Falls Shop 'n Save store.
12. HVAC, April 1993, "Testing the waters on R-134a." This article reviewed the Glens Falls Store installation.
13. A publicity event was held at the store on November 10, 1993, to note the reception of EPA Award mentioned below.
14. Air Conditioning, Heating and Refrigeration News, November 29, 1993, "N.Y. Supermarket Gets Award for 'Ozone-Friendly' System." This article describes the EPA Award and the history of the Glens Falls store.
15. ASHRAE Journal, February 1994, Vol 36. No. 2., p. 30, "Using R-134a and R-22 in Supermarket Refrigeration Application." This article was authored by Messrs. Ray Albrecht, Hamed Borhanian, Tom Mathews and Lenley Rafuse and described the Glens Falls store demonstration project.

PRESENTATIONS/PAPERS

1. 1992 International CFC Halon Alternatives Conference, September 1992, "HFC-134a and HCFC-22 Supermarket Refrigeration Demonstration". Paper by Messrs. Ray Albrecht, Hamed Borhanian, and Lenley Rafuse. This paper was presented at the conference by Mr. Borhanian. The paper had a description of the Glens Falls demonstration site and preliminary test results and listed all project participants.
2. FMI Conference, September 1992, Two presentations by project participants Mr. Charlie Bizilj of Howden Compressors and Mr. Tom Mathews of Hannaford Bros. included preliminary results from the Glens Falls demonstration site.
3. NSP's Grocery Manager/Operator Seminar, October 1992, Cosponsored by EPRI. Mr. Hamed Borhanian presented preliminary results from Glens Falls.

4. Ontario Hydro's Symposium on Meeting Supermarket Needs, November 1992. Mr. Tom Mathews presented preliminary results from Glens Falls.
5. Northeast Chapter of ASHRAE Seminar 'Alternative Refrigerants for Supermarkets.' presentations by the following project participants: Mr. Mark Spatz, Allied Signal; Mr. Len Rafuse, Aspen Systems, Inc.; Mr. Stephen Brown, Brown Engineering Co.; Mr. Tom Rajewski, CPI Engineering Services, Inc.; Mr. Tom Mathews, Hannaford Bros.; Mr. Ray Albrecht, NYSERDA; Mr. Carl Goldberg, Phoenix Refrigeration Systems, Inc.; and Mr. John Duerr, Spectronics.
6. 1993 International CFC Halon Alternatives Conference, October 1993. Two papers presented. "Laboratory Testing of Long Term CFC Replacement Refrigerants for Medium Temperature Screw Compressor Refrigeration Systems" by Messrs. Hamed Borhanian, and Lenley Rafuse, presented by Mr. Borhanian.. "HFC-134a and HCFC-22 Supermarket Refrigeration Demonstration" by Messrs. Raymond Albrecht, Hamed Borhanian, and Lenley Rafuse, presented by Mr. Raymond Albrecht.
7. 1994 International CFC Halon Alternatives Conference, September 1994, "Laboratory Testing of Long Term CFC Replacement Refrigerants for Low Temperature Refrigeration Systems." Paper by Messrs. Hamed Borhanian and Lenley Rafuse. This paper was presented at the conference by Mr. Borhanian. The paper describes the laboratory testing outlined in Section 2 of this report.

AWARDS

The project received the EPA Stratospheric Ozone Protection Award in October 1993, in recognition of its contributions to global environmental protection.

HISTORY OF THE GLENS FALLS LOW-TEMPERATURE RACK

Appendix A

GLENS FALLS SHOP 'N SAVE DEMONSTRATION SITE

WEEKLY HISTORY OF THE -25°F SUCTION GROUP, HFC-507

Date	Time	Compressor	MANUALLY RECORDED DATA			DOWNLOADED DATA AVERAGE RESULTS					
			kWh	Duration	Ave. Power	SST °F	SDT °F	LOAD MBH	POWER kW	EER	POWER BALANCE %
6/22/93	9:10	Semi Recip	-	168	-	-28.7	78	-	25.2	-	-
6/29/93	8:20	Semi Recip	4360	167	26.1	-25.8	85	-	26.1	-	-0.1
7/6/93	8:30	Semi Screw	4320	168	25.7	-22.7	87	-	25.9	-	-0.8
7/13/93	9:30	Semi Recip	4440	169	26.3	-22.5	94	127	26.4	4.8	-0.5
7/20/93	9:00	Semi Screw	4360	168	26.0	-24.8	85	133	26.1	5.1	-0.3
7/27/93	9:30	Open Screw	4600	169	27.3	-23.7	84	125	27.4	4.6	-0.4
8/3/93	9:30	Open Screw	5080	168	30.2	-22.6	88	126	30.1	4.2	0.5
8/10/93	8:20	Semi Screw	4040	167	24.2	-25.0	83	122	24.5	5.0	-1.3
8/17/93	8:40	Semi Recip	4240	168	25.3	-27.1	88	119	25.2	4.7	0.3
8/24/93	11:25	Open Screw	4320	171	25.3	-23.3	82	125	25.4	4.9	-0.6
8/31/93	11:00	Semi Recip	4200	168	25.1	-25.3	89	124	25.1	4.9	-0.1
9/7/93	8:50	Semi Screw	4280	166	25.8	-24.7	85	133	25.9	5.1	-0.4
9/14/93	10:35	Semi Screw	3560	170	21.0	-24.7	75	122	20.8	5.9	0.8
9/21/93	8:30	Semi Screw	3320	166	20.0	-25.1	71	124	20.2	6.1	-0.9
9/28/93	7:35	Open Screw	3480	168	20.8	-23.7	70	112	20.8	5.4	-0.2
10/5/93	8:50	Semi Screw	2960	169	17.5	-25.3	62	114	17.4	6.6	0.5
10/12/93	8:15	Semi Recip	2680	167	16.0	-24.3	62	112	16.1	6.9	-0.6
10/19/93	8:25	Open Screw	3160	168	18.8	-23.1	61	113	18.7	6.1	0.5
10/26/93	9:06	Semi Recip	2600	169	15.4	-24.0	62	112	15.6	7.2	-1.1
11/2/93	8:00	Semi Screw	2560	167	15.3	-25.3	58	116	15.3	7.6	0.2
11/9/93	9:00	Open Screw	2400	169	14.2	-23.9	54	110	14.2	7.8	0.0
11/23/93	9:00	Semi Recip	4760	336	14.2	-23.9	55	104	14.2	7.4	-0.2
11/30/93	11:00	Semi Screw	2200	169	13.0	-24.7	49	108	13.0	8.3	0.1
12/7/93	12:30	Open Screw	1880	169	11.1	-24.0	50	109	11.2	9.8	-0.7
12/14/93	8:30	Semi Screw	2040	164	12.4	-25.2	46	118	12.4	9.5	0.4
12/21/93	15:30	Semi Recip	2200	176	12.5	-23.2	48	102	12.5	8.2	0.2
12/28/93	11:50	Semi Screw	1880	163	11.5	-24.9	42	113	11.2	10.0	2.9
1/4/94	12:30	Open Screw	1600	168	9.5	-23.9	42	108	9.6	11.2	-1.0
1/11/94	9:15	Semi Recip	1880	166	11.3	-25.1	41	80	11.1	7.3	2.2
1/18/94	9:05	Open Screw	1560	168	9.3	-22.8	41	106	9.5	11.5	-2.5
1/25/94	11:15	Semi Recip	1920	170	11.3	-25.1	41	89	11.2	7.9	0.9
2/1/94	9:40	Open Screw	1640	166	9.9	-23.8	43	102	9.9	10.4	-0.4
2/15/94	12:35	Semi Recip	4400	340	13.0	-23.9	54	101	12.9	7.9	0.4
3/1/94	9:00	Semi Screw	4880	332	14.7	-25.2	56	116	14.7	7.9	-0.1
3/15/94	11:45	Semi Recip	4320	338	12.8	-26.0	44	102	12.8	8.0	-0.2

- Notes:
1. The date shown is the last day of the test period (usually one week) during which data was taken.
 2. Compressor column notes which bank of compressors was used during the test period:
Semi Screw - one 65 CFM Carlyle semihermetic screw, Open Screw - one 91mm Howden screw
Semi Recip - two Carlyle 06ER175 compressors.
 3. The power balance is a comparison between manually recorded power from the watt meters and the power determined from the downloaded data.

GLENS FALLS SHOP 'N SAVE DEMONSTRATION SITE
WEEKLY HISTORY OF THE -15°F SUCTION GROUP, HFC-507

			MANUALLY RECORDED DATA			DOWNLOADED DATA-AVERAGE RESULTS					
Date	Time	Compressor	kWh	Duration	Ave Power	SST °F	SDT °F	LOAD MBH	POWER kW	EER	POWER BALANCE %
6/22/93	9:10	Open Screw	-	168	-	-19.8	78	126	21.1	5.0	-
6/29/93	8:20	Open Screw	4000	167	23.9	-16.8	85	128	23.8	5.4	0.5
7/6/93	8:30	Open Screw	4040	168	24.0	-14.7	87	127	23.9	5.3	0.5
7/13/93	9:30	Semi Screw	4200	169	24.9	-16.3	94	128	24.7	5.2	0.6
7/20/93	9:00	Open Screw	3720	168	22.2	-15.0	85	118	22.2	5.3	0.0
7/27/93	9:30	Semi Recip	3440	169	20.4	-15.3	84	110	20.3	5.3	0.6
8/3/93	9:30	Semi Screw	3680	168	21.9	-14.4	88	125	21.9	5.7	0.0
8/10/93	8:40	Semi Recip	3360	167	20.1	-16.6	83	118	20.0	5.9	0.6
8/17/93	8:20	Open Screw	4080	168	24.3	-15.0	88	126	24.3	5.2	0.1
8/24/93	11:25	Semi Screw	3480	171	20.3	-15.5	82	131	20.2	6.4	0.7
8/31/93	11:00	Open Screw	4120	168	24.6	-15.0	89	126	24.4	5.2	0.8
9/7/93	8:50	Semi Recip	3280	166	19.8	-13.7	85	118	20.0	5.7	-1.1
9/14/93	10:35	Semi Recip	2880	170	17.0	-13.9	75	109	16.9	6.3	0.4
9/21/93	8:30	Open Screw	2760	166	16.6	-15.0	71	119	16.6	7.2	0.2
9/28/93	7:35	Semi Recip	2720	168	16.2	-16.0	70	116	16.3	7.1	-0.4
10/5/93	8:50	Open Screw	2480	169	14.7	-15.0	62	120	14.6	8.2	0.4
10/12/93	8:15	Semi Screw	2440	167	14.6	-15.3	62	125	14.5	8.6	0.5
10/19/93	8:25	Semi Recip	2400	168	14.3	-16.0	61	109	14.2	7.6	0.5
10/26/93	9:06	Semi Screw	2280	169	13.5	-14.2	62	114	13.5	8.4	0.2
11/2/93	8:00	Open Screw	2120	167	12.7	-15.1	58	107	12.6	8.5	0.8
11/9/93	9:00	Semi Recip	2040	169	12.1	-15.9	54	101	12.1	8.4	-0.2
11/23/93	9:00	Semi Screw	4040	336	12.0	-15.8	55	119	12.0	9.9	0.2
11/30/93	11:00	Open Screw	1680	169	9.9	-15.2	49	107	9.9	10.8	0.4
12/7/93	12:30	Semi Recip	1840	169	10.9	-16.0	50	92	11.2	8.4	-2.8
12/14/93	8:30	Open Screw	1480	164	9.0	-15.2	46	106	9.1	11.6	-0.8
12/21/93	15:30	Semi Screw	1840	176	10.5	-15.7	48	108	10.3	10.6	1.7
12/28/93	11:50	Semi Recip	1520	163	9.3	-15.4	42	103	9.2	11.3	1.3
1/4/94	12:30	Semi Screw	1480	163	9.1	-15.9	42	101	9.0	11.1	0.8
1/11/94	9:15	Open Screw	1280	166	7.7	-15.1	41	95	7.6	12.5	1.6
1/18/94	9:05	Semi Recip	1560	168	9.3	-17.3	41	60	9.2	6.2	0.7
1/25/94	11:15	Open Screw	1320	170	7.8	-15.1	41	100	7.8	12.8	-0.4
2/1/94	9:40	Semi Screw	1560	166	9.4	-14.8	43	107	9.4	11.4	-0.2
2/15/94	12:35	Semi Screw	3840	340	11.3	-15.9	54	112	11.2	10.0	0.9
3/1/94	9:00	Semi Recip	3920	332	11.8	-15.1	56	103	11.9	8.6	-0.9
3/15/94	11:45	Open Screw	3120	338	9.2	-15.8	44	104	9.1	11.4	1.4

- Notes:
1. The date shown is the last day of the test period (usually one week) during which data was taken.
 2. Compressor column notes which bank of compressors was used during the test period:
Semi Screw - one 65 CFM Carlyle semihermetic screw, Open Screw - one 91mm Howden screw
Semi Recip - two Carlyle 06ER175 compressors.
 3. The power balance is a comparison between manually recorded power from the watt meters and the power determined from the downloaded data.

HISTORY OF MODIFICATIONS: LOW TEMPERATURE RACK

6/16/93 Removed R-502, drained oil from compressors, reservoir. Installed AZ-50 and SW-100. Power meter wiring corrected. Offset correction determined.

6/18/93 Carlyle screw motor overload trip. Switched to Backup at 8:40 am. Removed HH. Installed RCW filter driers.

6/19/93 Flow meter failed. Unable to calculate load and EER.

6/23/93 New Carlyle Screw installed. Timer for loading delay added. Oil filter for Carlyle and main filter changed. Subcooler flooding slightly to cool motor.

6/24/93 Carlyle low oil pressure trip after 5 pm.

6/25/93 Carlyle screw off on oil float switched to Backup.

6/29/93 Carlyle screw on-line. Motor overload sensor and shell temp sensors installed. Max. speed set to 60 Hz. Reverse rotation discharge low pressure switch at 0 psig. Inverter V-Hz curve 2. RC-1000 setpoint at 13 psig.

7/2/93 New -25 flow meter installed.

7/6/93 Howden at 4400 RPM unable to hold suction. Switched to Backup with setpoint at 13 psig.

7/7/93 Setpoint dropped to 13 psig. Volume ratio switching corrected.

7/9/93 Leak in -15 cross over manifold fixed.

7/13/93 Carlyle screw suction running high. Max speed increased from 60 Hz to 65 Hz at 12:30 pm. Howden Max. shaft speed increased to 5000 RPM.

7/29/93 Howden off on high current. Carlyle screw off on motor temp.

8/18/93 Technician noted noisy bearing on Howden motor. Rack A Three leaks: receiver blank-off plate, liquid pressure transducer, liquid temperature probe.

8/19/93 Carlyle screw tripped out. Technician originally thought it was oil float trip. Review of temperature data indicated it may have been high shell temp trip.

8/31/93 RC-2 logic for oil reservoir functioning.

9/6/93 Backup off on low oil pressure. Minimum RPM increased to 800 RPM from 600 RPM.

9/7/93 Trip on 9/6 cause low readings for -15. Load is 118 MBH, SST is -15.0°F for operating period.

9/9/93 Removed 6.5 gallons of oil from A rack.

9/10/93 Closed top port on Carlyle float tank. Backup C1 off on oil. No oil in compressors. Float may be sticking. Flocon setting increased to 55 psi from 45 psi.

9/11/93 7 pm Carlyle screw off on oil float.

9/17/93 Variable Vi set to operate opposite polarity (i.e. low Vi at high SDT) Make-up oil flow shut-off. Flocon at 0 psi (manual open). Float tank valved off with oil in it. Timer (15 sec) added to Carlyle separator float switch.

9/21/93 Carlyle Vi back to normal. Howden injection into suction.

9/23/93 -15 subcooler solenoid leaking by. Ball valve closed.

9/28/93 Liquid injection into economizer inlet of Carlyle screw is implemented. Max speed is 70 Hz.

10/5/93 Minimum head reset to 75psig from 61 psig. I/C freezer flooding through. Demand sensor needed in front of coil.

10/11/93 Carlyle screw oil pressure trip.

10/12/93 Oil differential tripped. Decreased setting from 35 to 30psid.

10/19/93 Howden subcooler not on this week.

10/23-24/93 Reverse rotation low pressure trip on Carlyle screw.

11/2/93 Reverse rotation low pressure switch with capillaries is replaced with one that accepts 1/4" lines.

11/10/93 Minimum head increased form 75 to 80 psig. Carlyle screw oil differential set at 25 psid. Carlyle oil make-up tank disabled. Make-up controlled by reservoir float. If make-up oil has not satisfied float in 15 seconds, compressor trips off.

11/30/93 Howden oil injection into oil line. Reverses Rotation trip. Reduced reverse rotation low pressure switch again.

12/7/93 Flashing in flow meter caused low readings. Actual load at 108 MBH.

12/17/93 Carlyle screw off on oil differential.

12/21/93 Head control changed to all fans on. CI=88,CO=84. Pump cavitation decreased measured load. Actual load is 114.1MBH.

1/5/94 Technician noted that the Howden seal is leaking.

1/11/94 Pump cavitation caused low readings.

2/23/94 CI=84,CO=88.

LIFE CYCLE COST ANALYSIS

Appendix B

The life cycle cost (LCC) of a system can be calculated as follows:

$$LCC = C - S + M \sum_{J=1}^N \left[\frac{1+EM}{1+I} \right]^J + P \sum_{J=1}^N \left[\frac{1+EP}{1+I} \right]^J$$

where:

C = initial system cost

S = salvage value of the system at year N

M = annual maintenance cost

P = annual cost of electric energy

N = useful life of the system in years

EM = annual escalation rate of maintenance cost

EP = annual escalation rate of the cost of electric energy

I = interest rate

The life cycle cost is the present value of the total cost of the entire system over its entire lifetime. This cost includes initial cost, operating cost, and maintenance cost less system salvage value.

There are three economic comparisons that we have examined: net present value savings (NPVS), return on investment (ROI), and simple payback period.

The net present value savings is defined as:

$$NPVS = LCC_{\text{base system}} - LCC_{\text{alternative system}}$$

The return on investment of an alternative system compared to the base system is defined as the interest rate at which the NPVS is equal to zero:

$$ROI = I, \text{ for } NPVS(I) = 0$$

ROI can be used to compare the relative merit of two different prospective investments, For two systems with equal risk factors, the one with the higher ROI is the more financially beneficial.

The simple payback period is the time required for an investor to recoup his initial investment. It is defined as

$$\text{Payback Period} = \text{Initial investment} / \text{annual cost savings}$$

or

$$\text{Payback Period} = \text{increased system cost} / (\text{annual energy savings} * \text{cost of energy})$$