Gasification Product Improvement Facility (GPIF)

Final Report

September 1995

Work Performed Under Contract No.: DE-AC21-92MC28202

For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
Morgantown, West Virginia

By
CRS Serrine, Inc.
Greenville, South Carolina

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, 175 Oak Ridge Turnpike, Oak Ridge, TN 37831; prices available at (615) 576-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161; phone orders accepted at (703) 487-4650.

Gasification Product Improvement Facility (GPIF)

Final Report

Work Performed Under Contract No.: DE-AC21-92MC28202

For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880

By
CRS Sirrine, Inc.
1041 E. Butler Road
Greenville, South Carolina 29606

September 1995

Gasification Product Improvement Facility
Fort Martin Station, West Virginia
Jacobs-Sirrinc Job No. 16N25706

Gasification Product Improvement Project

Index

Section I.	Final Report
Section II.	Mass Balance
Section III.	Equipment List
Section IV.	Process Design Basis
Section V.	Process Flow Diagrams

TABLE OF CONTENTS
GPIF FINAL REPORT Contract No. DE-AC21-92MC28202

- 1.0 EXECUTIVE SUMMARY**
- 2.0 CONTRACT OBJECTIVE**
- 3.0 SIGNIFICANT FACILITY DESIGN EVOLUTION SUMMARY**
 - 3.1 TASK 1 NATIONAL ENVIRONMENTAL POLICY ACT DOCUMENTATION**
 - 3.2 TASK 2 WORK PLAN**
 - 3.3 TASK 3 PERMIT INFORMATION**
 - 3.4 TASK 4 CONCEPTUAL DESIGN**
 - 3.5 TASK 5 BENCH-SCALE TECHNICAL CONCEPT STUDIES**
 - 3.6 TASK 6 DETAILED CONSTRUCTION DESIGN**
 - 3.6.1 OPERATING PRESSURE CHANGE FROM 600 to 400 psig**
 - 3.6.2 OPERATING PRESSURE CHANGE FROM 400 to 325 psig**
 - 3.6.3 REROUTING OF PIPE BRIDGE TO FT MARTIN**
 - 3.6.4 DESIGN PRODUCT GAS TEMP. CHANGE FROM 1100° F to 1500° F**
 - 3.6.5 GPIF STATE AIR PERMIT REQUIREMENTS**
 - 3.7 TASKS 7 THRU 9**
- 4.0 PyGas™ TECHNOLOGY ADVANTAGES - BASIC GASIFIER TRAITS**
 - 4.1 VIABILITY OF THE PyGas™ GASIFICATION CONCEPT**
 - 4.2 IMPORTANT PROCESS CHEMISTRY**
 - 4.2.1 IN-SITU SULFUR REMOVAL**
 - 4.2.2 CONTROL OF FUEL NITROGEN RELEASE**
 - 4.3 INHERENT ADVANTAGES OF THIS PROCESS COMPARED WITH AVAILABLE COMMERCIAL TECHNOLOGIES**
 - 4.4 RELATED PyGas™ PROCESS CHEMISTRY MODELING**
 - 4.4.1 THE PYROLYZER**
 - 4.4.2 UPPER ZONE OF THE GASIFIER**
 - 4.4.3 UPPER BED GASIFICATION**
 - 4.4.4 LOWER BED GASIFICATION**
 - 4.4.5 MATH MODEL PREDICTIONS**
 - 4.4.6 TECHNICAL CONCLUSIONS**
 - 4.5 TECHNICAL/ECONOMIC ADVANCES**
 - 4.6 THE REPOWERING OPTION CONCEPT**
 - 4.7 CONCEPTUAL RILEY PyGas™ DESIGN**
 - 4.8 COMMERCIALIZATION APPROACH**
 - 4.8.1 MARKET DESCRIPTION**
 - 4.8.2 RILEY COMMERCIALIZATION SUMMARY**
 - 4.8.3 COMMERCIALIZATION PLAN**
- 5.0 CONCLUSION**
 - 5.1 PROJECT CANCELLATION BY DOE**
 - 5.2 OBJECTIVE NOT MET**
 - 5.3 DESIRED FUTURE CONTRACT FOR PyGas™ PILOT TEST UNIT**

GPIF FINAL REPORT
Contract No. DE-AC21-92MC28202

1.0 EXECUTIVE SUMMARY

At present time, America's reliance on foreign oil imports is greater than ever, and the volatile Eastern Europe and Middle East show no signs of easing tensions. Hence, the potential for loss of a major portion of the nation's heretofore abundant fossil oil based energy supply is as tenuous as it has ever been.

This coupled with increasing world pressure to reduce air emissions from energy related industries provides a "double-barreled" reason for the United States to seek to reduce the high cost associated with Integrated Gasification Combined Cycle (IGCC) in general, and coal gasification in particular.

The gasifier selected for development under this contract is an innovative and patented hybrid technology which combines the best features of both fixed-bed and fluidized-bed types. DB Riley, Inc., and Jacobs-Sirrine Engineers have formed a team to develop and commercialize this technology, called PyGas™ meaning Pyrolysis Gasification. PSI Power Serv's (formerly PSI Technology) role has been in an environmental assessment and technology developmental research capacity. PyGas™ is well suited for integration into advanced power cycles such as IGCC. It is also well matched to hot gas clean-up technologies currently in development. Unlike other gasification technologies, PyGas™ can be designed into both large and small scale systems.

It is expected that partial repowering with PyGas™ could be done at a cost of electricity of only 2.78 cents/kWh, more economical than natural gas repowering.

It is extremely unfortunate that Government funding for such a noble cause is becoming reduced to the point where current contracts must be canceled. However, this is the reality of the current situation regarding this particular contract.

We are grateful to those at METC who made a valiant, though futile attempt to reincarnate a smaller version of the PyGas™ gasifier at the Wilsonville, Alabama site.

We continue to hold onto the hope that eventually, funding to do a PyGas™ pilot plant will be forthcoming with a new approach and new contract at some time in the future and at a place as yet undefined.

2.0 CONTRACT OBJECTIVE

The DOE Fossil Energy Program has a mission to develop energy systems that utilize national coal resources in power systems with increased efficiency and environmental compatibility. The Gasification Product Improvement Facility (GPIF) project was initiated to provide a test facility to support early commercialization of advanced fixed-bed coal gasification technology at a cost approaching \$1,000 per kilowatt for electric power generation applications. The project was to include an innovative, advanced, air-blown, pressurized, fixed-bed, dry-bottom gasifier and a follow-on hot metal oxide gas desulfurization sub-system. To help defray the cost of testing materials, the facility was to be located at a nearby utility coal fired generating site. The patented PyGas™ technology was selected via a competitive bidding process as the candidate which best fit overall DOE objectives.

3.0 SIGNIFICANT FACILITY DESIGN EVOLUTION SUMMARY

The GPIF project contractor is Jacobs-Sirrinc Engineers (formerly CRS Sirrine Engineers, Inc.). Project Team members as sub-contractors included DB Riley (formerly Riley Stoker Corp.) and PSI Power Serv (formerly PSIT Co.). The project relationship is shown in the following figure :

Figure 1 GPIF - A Government, Utility, and Industry Partnership

Of the nine tasks associated with Phase I of this project, the first four were completed, Task 5 was deleted, and Task 6 was partially completed.

3.1 TASK 1 NATIONAL ENVIRONMENTAL POLICY ACT DOCUMENTATION

A Topical Report entitled "Environmental Report" was prepared by the Project Team and issued to the DOE/METC in March, 1993. Subsequently, an "Environmental Assessment" was completed, leading to an Environmental Impact Statement and finding of No Significant Impact (NEPA Permit) for this facility.

3.2 TASK 2 WORK PLAN

A detailed "Work Plan" was developed for the performance of Phase I in accordance with the contract requirements. This plan was critiqued, reissued, and accepted by the DOE/METC.

3.3 TASK 3 PERMIT INFORMATION

The Project Team developed a comprehensive listing of potential permits, certificates, and inspection requirements for this project. Meetings were held to determine which potential requirements were applicable to this facility, those that could be included in the utility host's existing permit base, and those that could be handled by letter exemption or waiver.

3.4 TASK 4 CONCEPTUAL DESIGN

A complete conceptual design of the gasifier sub-system and the infrastructure required for the gasifier and the hot gas cleanup system was completed, reviewed, revised, and resubmitted several times during the third and fourth quarters of 1993 and first quarter of 1994. Final acceptance by DOE/METC of a topical report titled "Conceptual Design Report" was received in February, 1994. A completed Revision-0 design package was included in the "Conceptual Design" report. Completion of this significant project segment was a pre-requisite to initiation of the detailed design effort.

Concurrent with conceptual design was re-estimating facility capital costs and the development of the commercialization plan.

3.5 TASK 5 BENCH-SCALE TECHNICAL CONCEPT STUDIES

This task was deleted by the DOE/METC technical project manager in order to redirect greater technical emphasis on the facility design. Parallel work under a different contract (CRADA No. 94-021) effectively eliminated the need for the original concept studies effort identified in this task.

3.6 TASK 6 DETAILED CONSTRUCTION DESIGN

Significant effort on this task was expended by the Project Team from March, 1994 up to cancellation of the contract. Following are the most significant facility design evolutionary issues :

3.6.1 OPERATING PRESSURE CHANGE FROM 600 to 400 psig

The gasifier was originally 6 ft.-6 in. diameter with a normal operating pressure of 600 psig. The design pressure was 770 psig. The gasifier was also specified to operate at a minimum pressure of 200 psig. Coal throughput was to be 6 tons per hour at 600 psig operating pressure, and 2 tons per hour at 200 psig.

This 600 psig operating pressure was higher than gasifiers had previously designed for or built by DOE/METC. Design conditions for many components, such as lock hoppers, lock hopper valves and the fuel feed system exceeded design conditions for those components used on previous and contemporary gasifiers. The high pressure design, therefore, required development work for some support equipment, with associated higher cost, in addition to the development work required for the gasifier vessel itself.

A process air compressor for this high pressure was available, but pushed the limit of available equipment. The required motor horsepower was very high, nearly 7000 horsepower. This exceeded the electrical capacity for motor start up without the addition of a low voltage starter.

In December 1994, the gasifier normal operating pressure was reduced to 400 psig, with the 200 psig minimum pressure still required. This was done to limit equipment development work to the

gasifier itself and to control cost of auxiliary systems. This pressure reduction allowed use of support equipment with design conditions at levels used on previous DOE/METC gasifiers. Design pressure was also reduced to 660 psig. The lower normal operating pressure reduced the normal coal throughput to 4 tons per hour. Reduced pressure and lower coal feed rates reduced the process air compressor size, with motor horsepower being reduced to 3000 horsepower. The reduced voltage starter was still required, however. Capacities of other support equipment, such as coal and limestone handling, product gas cyclone, and the HRSG, were decreased due to the new lower coal throughput. An equipment cost reduction resulted for this specification change.

3.6.2 OPERATING PRESSURE CHANGE FROM 400 to 325 psig

After the scope and design conditions for the gasifier and the support equipment was firmed up, the project cost estimate was updated. When the estimate update was completed, the cost had increased much above the contract cost. A list of potential cost saving scope reductions was developed, which would still allow testing the PyGas™ technology. Scope changes which would not allow scaleup to a commercial unit were not considered. Operating pressure reduction to 325 psig was one of several scope reductions selected. Several other scope reductions were also required to reduce the cost below the original contract estimate level.

Other scope reductions selected were:

- Reduce the gasifier diameter from 6 ft. 6 in. to 5 ft. 0 in.

- Delete use of a separate limestone system to remove sulfur from the product gas during the gasification process itself.

- Replacing the HRSG with a product gas incinerator, without heat recovery, and a package boiler to supply gasifier process steam.

Reducing the gasifier diameter reduced the building size. The combination of reducing the gasifier diameter and reducing operating pressure to 325 psig, decreased the anticipated total coal throughput to 2 tons per hour. The combination of reduced pressure and coal through put reduced the process air compressor motor to less than 2000 horsepower. That eliminated the need for a costly reduced voltage starter. In addition, all other motor horsepower requirements were reduced, as were piping and valve sizes.

The separate limestone storage and feed system was deleted. In addition, wet oxidation of ash was replaced with a lower cost dry ash handling and storage system.

The original HRSG concept was to recover heat from the incineration of the product gas and send the resulting steam to Fort Martin. This required an expensive high pressure boiler, a long high pressure steam pipe connecting to Fort Martin, and the use of high quality boiler feedwater obtained from Fort Martin. By using a simple incinerator to burn the product gas, the expensive HRSG and steam piping were eliminated. A less expensive small package boiler was added to provide the steam required for the gasification process.

3.6.3 REROUTING OF PIPE BRIDGE TO FT MARTIN

The original concept was to route the utility bridge from the East end of the gasifier structure, passing north of the existing settling ponds, and cooling tower No. 2, then turning South to run between cooling tower No. 2 and Unit No. 2 powerhouse.

Detailed design development revealed numerous underground services in the area between Unit No. 2 and cooling tower No. 2. Most of the underground services were large circulating water pipes or electrical duct banks. The nature of the project did not allow for these to be relocated. Utility bridge foundation location and span length became a major engineering and cost hurdle.

In addition to the design considerations, Allegheny Power Systems (APS) indicated that the utility bridge in the original location would preclude access to the cooling tower No. 2 circulating water pumps, as well as other major equipment that require periodic attention. APS requested that an alternate route be used.

In response to the objections of APS and to control cost, an alternate route was proposed. The alternate route maintains the portion of the original route along the North side of the settling ponds. The new segments turned the utility bridge South between the East end of the settling ponds and the West side of cooling tower No. 2. The bridge then continued to the river bank and then turned East along the river bank to Unit No. 2.

As project cost became a problem, a lower cost alternate route was searched for. As part of this effort the bridge routing was again scrutinized. An investigation into the feasibility of locating the bridge on the South side of the lagoons, along the river bank was begun. This investigation was not completed before work on the project was stopped, however, since its distance was some 350 ft. less, it is reasonable to expect that it would have provided significant savings.

3.6.4 DESIGN PRODUCT GAS TEMP. CHANGE FROM 1100° F to 1500° F

The original product gas design temperature at the gasifier outlet was 1100° F. A combination of water and steam spray was to be utilized to achieve desired exit gas temperature. As reliance on spray water cooling of the product gas became more of a design issue, the desire not to spray water into the product gas stream had to be evaluated against the cost of high temperature piping. Projections were that the maximum product gas outlet temperature could even exceed 1800° F under some conditions. Calculations for the required length of the spray pipe revealed that about 60 ft would be required. This length presented building size problems. In addition there were concerns about possible water droplets entering the product gas cyclone causing erosion of the cyclone wall and possible solids deposition concerns. The decision was then made to increase the product gas outlet design temperature to 1500° F. This temperature was chosen because valves required around the lock hoppers were known to be available at such design temperatures. The plan was to cool the product gas as much as possible in a length of 10 ft. under the extreme conditions. Normally little or no cooling would be required. Gasifier operating variables would be limited to not exceed 1500° F at the end of the cooling spray pipe, if the cooling capability in 10 ft. would otherwise result in temperature exceeding 1500° F.

During the development of the estimate discussed in 3.6.2 above, the product gas pipe designed for 1500° F design temperature was found to be very expensive. Both high alloy pipe and refractory lined pipe were considered. One of the cost saving items then selected was to reduce the product gas design temperature to 1100° F. The gasifier diameter and coal through put reductions had the effect of reducing product gas temperature to less than 1100° F for normal operation. Only in extreme operating conditions would the product gas temperature exceed 1100° F. A cooling spray pipe designed for 50° F gas temperature reduction was included in the scope. This allowed a maximum gasifier product gas outlet temperature of 1150° F. Gasifier process variables would be limited to prevent higher temperature if 50° F reduction still resulted in temperatures higher than 1100° F. Only very minor limitations were expected to control the temperature in this scenario.

3.6.5 GPIF STATE AIR PERMIT REQUIREMENTS

The original scope of the GPIF included a flue gas duct from the GPIF to Fort Martin. GPIF flue gas was to tie into the Fort Martin Unit No. 2 precipitator inlet duct. The GPIF was considered part of the Fort Martin system, and therefore was to be covered by the existing Fort Martin permit.

The GPIF would gasify the same coal being burned by Fort Martin. Flue gas from incineration of GPIF product gas would pass through the Fort Martin precipitator and stack. Steam generated from the GPIF product gas would be supplied to the Fort Martin system. The PyGas™ process using the original concept of limestone mixed with coal feed, was expected to use low sulfur coal as well as remove most of the coal's sulfur. The result would be less SO₂ emission with GPIF operating than with GPIF not operating.

Discussions by DOE/METC with the State of West Virginia resulted in the requirement for a state air permit. The most serious impact was the requirement for a SO₂ scrubber and the schedule delay for construction.

The SO₂ scrubber added capital cost scope to the project without being covered by additional dollars added to the contract. In addition, no construction work was allowed by DOE/METC until the permit was issued.

It is logical to the Project Team that small research facilities such as the GPIF should not require commercial scrubbers. It is unclear why other facilities such as Wilsonville, Alabama have been able to be constructed without the requirement of SO₂ scrubbers, while in Maidsville, West Virginia, the opposite was the case.

3.7 TASK 7 TASK 8 TASK 9

The Site Preparation/Construction, Pre-Operational Test planning and testing tasks had not yet started at the time of project cancellation.

However, the following illustrates what was anticipated for the test plan and sequence :

Table 1

GPIF TEST PLAN

- Start with Coke Breeze
- Eastern Bituminous Coals
- Test Other Coals
 - Mid-Western Bituminous
 - Western Sub-Bituminous
 - Lignite Coals
- Full Complement of Input/Output Data
- Sulfur, Alkali, Ammonia Measurements

Table 2
GPIF TEST SEQUENCE

- Independent Pyrolyzer
- Integrated Pyrolyzer/Fixed-Bed
- Parametric Testing

The time-line of the project, re-direction of technical and installation emphasis by DOE/METC, and a variety of developments which impeded progress can readily be seen in the following major deliverables and a summary of events tables :

Table 3
Major Team Deliverables

• Mar 93	TASK 1	ENVIRONMENTAL REPORT ISSUED
• Mar 93	TASK 2	WORK PLAN ISSUED
• Jun 93	TASK 3	PERMIT INFORMATION ISSUED
• Feb 94	TASK 4	CONCEPTUAL DESIGN REPORT ISSUED
• Jun 94	TASK 4	SANITATION SYSTEM REPORT ISSUED
• Oct 95	TASK 6	REV-1 PROCESS DESIGN BASIS ISSUED

Table 4
Summary of Major Events

• Jun 91	-	Mon Power Site Access Agreement
• Sep 92	-	EPC Contract Award
• Mar 93	-	Task 1 - Environmental Report Issued
• Jun 93	-	JSE/DB Riley Teaming Agreement Reached
• Feb 94	-	Task 4 - Conceptual Design Complete
	-	Gasifier Diameter from 5' to 6.5'
	-	Phase 1 Cost Estimate from \$24.8 to \$27.8-mil
• Mar 94	-	Environmental Assessment/Finding of No Significant Impact Issued (NEPA)
• Jun 94	-	METC Core Team Interactive in Concept Design
• Jul 94	-	CRS Sitrine Acquired by Jacobs Engineering Group
• Sep 94	-	Revised Concept Design Completed
• Oct 94	-	METC Project Team Formed/Operations Responsibility
• Dec 94	-	State WV Decision Requiring GPIF Air Permit
	-	Construction Start Delayed from Jun 95 to Oct 95
	-	Design Pressure Changed from 600 psig to 400 psig
• Jan 95	-	Independent Cost Review
• Feb 95	-	Flue Gas Desulfurization Added to Scope
	-	Rev - 0 Process Design Basis Completed
	-	Pipe Bridge to Ft. Martin Rerouted
• Mar 95	-	Air Permit Application Submitted
• Apr 95	-	JSE/Riley Executed Commercialization Agreement
	-	25% Design Review Completed
• May 95	-	Design Basis Pressure Reduced to 325 psig
	-	Gasifier Diameter Reduced from 6.5' to 5'
	-	Design Temperature Changed from 1100°F to 1500°F
	-	Project Costs Revised
• Aug 95	-	Termination Notice Received
	-	Rev-1 Process Design Basis Completed
• Sep 95	-	Termination Cost Proposal Submitted
• Oct 95	-	Final Technical Report (25 Page) Submitted

4.0 PyGas™ TECHNOLOGY ADVANTAGES

A DOE/METC internally generated report confirmed that fixed-bed systems have the highest potential thermal efficiency of all gasification concepts. This is because more of the Btus go to the Brayton thermodynamic cycle and less to the Rankine thermodynamic cycle than any other gasification process.

BASIC PyGas™ GASIFIER TRAITS

In this hybrid dual-stage gasifier, virtually all of the hydrogen and carbon in the coal is converted into fuel gas, which can then be combusted in highly efficient gas turbines and/or conventional boilers arranged in combined cycle configuration.

The stages of the hybrid PyGas™ gasifier process are depicted in the following process schematic :

Figure 2 PyGas™ Process Schematic

The purpose of the first stage of the PyGas™ gasifier is to de-cake eastern bituminous coals within a fluidized-bed pyrolyzer. This process overcomes the capacity reductions and operational difficulties commonly associated with agglomerating tendencies of caking coals in conventional fixed-bed gasifiers.

It is now apparent that even caking coals can be rendered non-caking in a fluidized-bed pyrolyzer tube (pre-treatment). This stage also offers the additional benefit of tar destruction due to a combination of residence time, elevated temperatures, and steam injection.

Once rendered non-caking, the coal char overflows the pyrolyzer tube and falls into a fixed-bed below. As is commonly done in fixed-bed gasifier applications using low swelling coals, coke, and char, gasification is achieved by introducing air and steam via a rotating grate. Bottom ash carbon content can thus be controlled to the low levels acceptable to industry and the environment.

4.1 VIABILITY OF THE PyGas™ GASIFICATION CONCEPT

There exists significant data to confirm the viability of the two major components which comprise the PyGas™ gasifier, and the use of limestone as a sulfur capture agent. These attributes are considered essential to achieving the DOE/METC GPIP project low cost objective of \$1000/kW.

4.2 IMPORTANT PROCESS CHEMISTRY

Initially, C. Lowell (Wormser Engineering) et al and subsequently, Foster Wheeler Development Corp. demonstrated as high as 95% sulfur retention by the use of limestone injection with the coal into a "slug flow" pyrolyzer operated at 1600°F and of the same geometry as the one used within the PyGas™ gasifier vessel. Since the PyGas™ coal gasifier operates at from 1300°F to 1600°F in its rapid devolatilization pyrolyzer section, it is expected that the limestone will directly react, and subsequently form calcium sulfide while in the pyrolyzer section of the PyGas™ gasifier. Once CaS is formed along with char in the pyrolyzer, it is further expected that control of the gasifier operating temperature at the top of the gasifier by combusting pyrolysis gases will not adversely affect the CaS solids since both the METC MGas and the KRW kinetic rate models predict very rapid endothermic gasification and temperature drop to the vicinity of 1500°F within a very short distance within the upper solids bed. Similarly, it is believed that the lower PyGas™ operating temperatures in the gasifier solids bed region (lower than typical fixed-beds) will allow the CaS to remain or oxidize to CaSO₄ since the grate area operates in an oxidizing atmosphere.

J.M. Eakman (Exxon Research) et al identified that alkali metal gasification catalysts increase the rate of steam gasification, promote gas phase methanation, and minimize agglomeration of caking coals in a slugging pilot scale unit whose geometry was very similar to that of the PyGas™ proprietary gasifier pyrolysis section.

C.Y. Wen (West Virginia University) et al concluded from their entrained-bed coal gasification modeling that the effect of total pressure was increased carbon conversion at any steam to fuel ratio. They also concluded that increasing oxygen to fuel ratios increased carbon conversion at any operating pressure and at an optimum steam to coal ratio. The existence of an optimum steam to fuel ratio is important, because one can obtain the same carbon conversion at a lower oxygen feed by maintaining optimal steam to fuel ratios in the 0.4 to 0.5 range. Moreover, their carbon conversion efficiencies considerably exceeded that required by the pyrolyzer section of the PyGas™ gasifier indicating that acceptably high carbon utilization may be expected thereby minimizing conventional fixed bed gasification air and steam requirements.

H.S. Muralidhara (West Virginia University) et al concluded from their study that after initial pyrolysis, kinetic reaction rate increases in direct proportion to calcium content of the coal. This may prove valuable to the PyGas™ proprietary gasification process and may serve to explain in part why C. Lowell et al achieved greater than 50% carbon utilization during carbonization. As catalysts like calcium and potassium increase the reaction rate, endothermic reactions continue to lower the exit gas temperature. The 1600°F threshold, previously thought to be the practical kinetic limit of coal gasification reactions may be lowered toward 1200°F by such catalytic effects.

D.E. Woodmansee et al (General Electric) found that the efficiency of converting coal enthalpy to cold gas fuel value increased by 4% when the steam/air mass ratio was reduced. This is consistent with the PyGas™ concept of pyrolysis and cracking control by air flow with minimization of steam injection.

E. J. Nemeth et al (U.S. Steel Corporation) pilot scale results showed that the desulfurization of coal-derived gas at 1500 to 1770°F is feasible. They found that desulfurization of the hot reducing gas initially exceeded 97% removal of H₂S with dolomite.

C.Y. Wen et al (West Virginia University) stated that the understanding of coal pyrolysis is very important in view of the potential of the process to take advantage of (1) the phenomena of rapid pyrolysis and (2) obtaining higher yields of gaseous hydrocarbons by the application of pressure and hydrogen atmosphere. It was also stated that pilot plant studies of Union Carbide showed that release of gaseous hydrocarbons is improved significantly under high partial pressure of hydrogen. The char-gas reactions that take place during the second stage following the pyrolysis reaction may be classified into two distinct categories, namely volumetric reactions and surface reactions. Thus, diffusion is an important step in heterogeneous char-gas reactions. Higher hydrogen partial pressure improves the carbon conversion in the first stage of fast pyrolysis. For this reason, the PyGas™ process provides for the introduction of steam into the pyrolysis section of the gasifier along with the coal, limestone, and air.

If in the char-oxygen reaction (burning of char), the temperature and/or the particle size decrease substantially, the reaction may proceed toward the chemical reaction control regime, and it may take place uniformly throughout the internal pore surfaces of the particles. This observation may allow the PyGas™ gasifier to operate at lower steam to coal ratios in the gasifier combustion zone without experiencing the ash melting problems of conventional fixed bed gasifiers.

Wen observed that very little study has been done on the relative reactivities of different coal-chars in char-steam reactions. These works concluded that carbon-steam or char-steam reaction is chemical reaction controlled for smaller carbon/char particles (roughly <500 micron) and at temperatures up to 1800°F. At these conditions, the reaction occurs uniformly throughout the interior of the pore surfaces of the solid particles.

Wen also concluded that the phenomena of pyrolysis, particularly that of rapid and flash pyrolysis are yet to be understood well. The GPIF would have corrected this deficiency.

4.2.1 IN-SITU SULFUR REMOVAL

The fluidized-bed processing of coals having 3 to 5 percent sulfur content in the presence of limestone and dolomite has demonstrated capture of 88 to 95 percent of all sulfur released. Much of the captured sulfur is in the form of calcium sulfide (CaS). Retention of sulfur in this form has proven much more difficult within fixed-bed processes, probably due to the release of sulfur dioxide at elevated temperatures. Studies on the oxidation of CaS by Lynch and Elliot and Tones-Ordannes demonstrate that at high temperatures (greater than 2,500°F), complete oxidation occurs releasing SO₂ and producing CaO. At temperatures below 2,000°F, sulfate was produced in small amounts. In the intermediate range (2,100 to 2,300°F), the conversion of CaS oscillated rapidly between the formation of oxide and the sulfate. Rehmat conducted a study of these reactions for dolomite and limestone over the range of 1,500 to 1,900°F and up to 400 psig. Greater levels of sulfation were reported for dolomites (83 to 100 percent) than for limestone's (18 to 34 percent). The fixed-bed combustion zone in the PyGas™ process must be carefully controlled with a test objective to minimize sulfur release. Substantial sulfur retention is anticipated within the PyGas™ process.

4.2.2 CONTROL OF FUEL NITROGEN RELEASE

The volatile fraction of coal bound nitrogen is known to be released as hydrogen cyanide and ammonia in coal gasification processes. Control of the amounts of these compounds which are formed will be attempted by the utilization of controlled combustion, adding air within the gasifier vessel. This must also be a test objective. It is known that elevated temperatures reduces the formation of these species. The extent of molecular nitrogen formation from fuel bound nitrogen must be weighed against the inherent inefficiencies brought about by adding air to the pyrolysis gas before such operation can be considered sufficiently effective for commercial viability.

4.3 INHERENT ADVANTAGES OF THIS PROCESS COMPARED WITH AVAILABLE COMMERCIAL TECHNOLOGIES

The single most important inherent advantage of this system configuration is that the two most costly equipment areas in the existing power plant, the boiler and steam turbine, are both utilized at near full capacity. Precedence for operating a fully fired combined cycle (both the combustion turbine and the existing boiler are fired, and the existing boiler utilizes turbine exhaust gas) has been set nearly thirty years ago at such utility installations as West Texas Utilities San Angelo Station, and Oklahoma Public Service Company's Horseshoe Lake Station, both of which are combined cycle installations which utilize a fired boiler. Since the boiler island represents the largest cost of a coal fired power plant (typically 25% of the equipment cost), it makes more sense to utilize it rather than to pay to demolish it, or even more costly, to replace it with another type of boiler.

4.4 RELATED PyGas™ PROCESS CHEMISTRY MODELING

The PyGas™ coal gasifier employs several related and critically important process chemistries:

The pyrolyzer section rapidly drives off approximately 50% of the coal weight in the form of gaseous volatiles by pneumatically injecting the raw coal into the preheated pyrolyzer cone at from 1300° F to 1800° F. This "rapid pyrolysis" process has been proven successful in overcoming previous concerns of sticky tar formation which results in agglomeration in conventional fixed-bed gasifiers. The reason is that instant subjection of the coal to temperatures which exceed the point at which tar can exist in liquid form result in their devolatilization to gaseous form and even cracking with sufficient residence time.

Pneumatic introduction of crushed limestone along with the crushed coal into the rapid devolatilization pyrolyzer section of PyGas™ allows the CaCO_3 to react with H_2S to form CaS .

The introduction of additional top air into the PyGas™ gasifier elevates the temperature to approximately 2300° F (depending upon the specific ash fusion characteristics of each coal). This causes the tar vapors to crack and liberate additional sulfur to form additional H_2S , then endothermically react to form additional H_2 & CO .

This results in two distinct advantages:

1. The tars liberate sulfur which would otherwise not be captured by hot gas cleanup systems, and
2. The troublesome tar and carbon-black thermophoresis related pluggages downstream of the gasifier can be avoided.

As the hot coal gas then passes cocurrently down through a char laden partially fixed/partially fluidized-bed (manometer effect), endothermic gasification reactions serve to both rapidly consume available carbon, and to cool down the bed allowing previously volatilized alkali to condense onto and potentially be tied up by added or naturally occurring aluminosilicates in the ash. Any available carbon remaining in the ash is subsequently gasified above the rotating grate in the usual fixed-bed coal gasifier method using typical steam to coal ratios (but at considerably reduced mass flows) initially for oxidation, and then both temperature control and gasification.

The lower solids bed is also expected to capture the remaining sulfur fraction as it becomes released during gasification as CaS and subsequently (with adequate temperature control) allow the CaS to oxidize to CaSO₄ since it operates in the typical fixed-bed gasifier oxidizing manner.

The expected gasifier exit temperature from PyGas™ is approximately 1200°F to 1500°F, which is nearly ideal for hot gas cleanup systems which require raw gas temperatures above 1200°F. The control of PyGas™ raw gas exit temperature to match precisely the required zinc based sulfur sorbent operating temperature range may be accomplished in two ways:

1. Water spray mist injection is contemplated to both cool the PyGas™ exiting raw gases and maintain sufficient gas moisture levels as needed in the sulfur absorber vessel. Unlike the limits of singularly fired combined cycle plants which have unfired HRSG's, compressor surge margin limitations can be maintained irrespective of coal gas moisture in the dual fired combined cycle arrangement. This is because not all of the turbine air bled to the gasifier need be returned to the turbine combustor. This is the result of the plant arrangement having both a booster air compressor, and an auxiliary air compressor for dual combined cycle firing of coal gas.
2. Since it is well known that most coal ash contains calcium and potassium based compounds which produce catalytic endothermic gasification reactions, exit raw gas temperatures from the PyGas™ gasifier may be driven below its anticipated 1500°F level toward 1200°F. The test facility is expected to reveal just how far such gasification reactions can be driven. Its results may then dictate whether zinc ferrite, zinc titanate, Z-sorb, or other hot metal sorbent is optimum.

The bottom ash from PyGas™ is expected to contain less than 5% residual carbon and 50% to 100% sulfur removal in the form of CaS and fully oxidized CaSO₄, along with unreacted residual CaCO₃. Obviously, sufficient sulfur capture would obviate the need for separate hot gas cleanup.

Significant effort has been given to this continuing process, including the development of a mathematical model to determine the appropriate operating conditions within the PyGas™ gasifier vessel using both the METC-MGAS and KRW kinetic rate limitations.

The preliminary results of this modeling effort are included herein. They have also been presented at and published by the American Society of Mechanical Engineers (ASME) under the title "THE PyGas™ PROCESS, AS MODELED BY DOE-MGAS & KRW KINETIC RATE EQUATIONS".

These most significant developments showed conclusively that adding a pyrolyzer such as contemplated by the PyGas™ gasifier increases the gasifier yield by avoiding liquid phase tars, as well as by quickly consuming 50% of the coal in a relatively small fluidized bed vessel operated in the "slug flow" regime.

If all that the PyGas™ gasifier ever did was to condition caking coal to avoid agglomeration, it would no doubt be considered very successful. However, the PyGas™ gasifier can potentially perform several additional process benefits in the gasification of coal. These include cracking tar, condensing volatilized alkali, preventing coal fines carryover from the gasifier, producing raw gas

at temperatures ideal for hot gas cleanup systems, and handling coal of any expected moisture content with no adverse affect on gasifier exit temperature.

Additional air is specifically introduced at the top of the gasifier to further reduce cyanide and ammonia levels as well as to raise its operating temperature sufficiently to crack the tars driven to gaseous form during pyrolysis. To do this requires only to add air until the gasses at the top of the PyGas™ gasifier reach approximately 2300 F. The specific coal inorganic fraction fusion characteristics will dictate more precisely the top gas operating temperature just as it does for conventional fixed-bed gasifiers.

Since the last stage of the PyGas™ coal gasification process is that of carbon gasification, the raw gas exit temperature will always be very close to the optimum for metal oxide types of hot gas cleanup systems, in the 1200°F to 1500°F range. This is a decided advantage as opposed to either the molten slag bottom entrained bed gasifier types which produce raw gas too hot for hot gas cleanup systems, and conventional fixed-bed gasifiers whose raw gas product is often too cold depending on how much coal moisture had to be evaporated hence cooling down its exiting temperatures.

Irrespective of coal moisture content, the PyGas™ gasifier's raw gas exit temperatures remain nearly constant at near optimum hot gas cleanup temperatures. Conventional fixed-bed gasifiers which have no control over raw gas exit temperatures affected by incoming coal moisture and associated tar condensation will create significant difficulty for hot gas cleanup system control.

Based upon the repeated past successes of pyrolyzers (sometimes called "carbonizers") built and operated by several U.S. Government agencies as well as independent private organizations, and owing to the simplicity of merely placing such a device within the confines of a fixed-bed air-blown coal gasifier vessel in such a manner that gravity alone is necessary to move the products of pyrolysis into the conventional gasifier, a decision by the DOE to accept the PyGas™ gasifier as "ready for pilot scale testing" would be quite reasonable.

4.4.1 THE PYROLYZER

Pyrolysis is the chemical change created by the addition of heat in a reducing atmosphere. Gasification is the phase change from solid to gas also produced by the addition of heat also in a reducing atmosphere. As coal enters any gasifier, it must be heated to gasification reaction temperatures. During heating, volatiles (i.e. CO, CO₂, H₂, H₂S, & NH₃) and condensable hydrocarbons (referred to as tars) are released. The release of the volatile products is directly affected by the heating conditions. As coal is heated, its volatiles form bubble-cell structures throughout the coal. Under rapid heating conditions (10⁴ °F/sec), the expansion of the volatiles within the bubbles quickly reach high enough pressures to "break" the bubbles and escape before the coal particle expands. However, as the heating conditions decrease to under 10³ °F/sec, the coal particles swell before the pressure within the "volatile bubbles" is high enough to rupture the "bubbles". The phenomenon of tars forming a sticky surface coating on coal results in adjacent particles "sticking" together and forming an incipient clinker. This phenomenon is known as agglomeration. Air and steam pass around such agglomerated lumps following a path of least resistance. This bypassing results in a diminished gasification reaction since the air and steam cannot reach the unreacted coal contained within the agglomerated lump. When this happens, channeling occurs within a gasifier and its productivity and efficiency quickly diminish.

Rapid devolatilization occurs in the PyGas™ pyrolyzer section. The rapid heating liberates the tars in gaseous form rather than tacky liquid form. Thus, the agglomeration characteristics of highly caking coals from most eastern American bituminous seams becomes irrelevant.

The PyGas™ pyrolyzer resembles the pyrolyzers used by the United States Bureau of Mines to devolatilize various coals by a process sometimes called "carbonization". In addition to identifying their empirical relationships, reports produced by Wormser Engineering, Inc. and West Virginia University were reviewed to model the pyrolyzer performance. A major objective of PyGas™ is the rapid devolatilization and maximization of carbon conversion in the pyrolyzer. This, in turn, minimizes air and steam requirements needed to gasify the remaining carbon (char) in the fixed bed gasifier section. Volatiles released, and thus carbon conversion, can be higher than ASTM test indications of weight loss of caking coals as a result of rapid devolatilization. The US Bureau of Mines notes that bituminous coal volatile yield peaks at approximately 1300° F if rapid heating is applied. On the other hand, if the heat rate is slowed down, the volatile yield becomes proportional to pyrolysis temperature. Peak weight loss of the coals was then compared with the test data with the determination of the volatile content of coal by ASTM standards.

Cases for several different air-to-coal ratios at the top of the gasifier were developed. Limiting the amount of air added resulted in the ability to reach upper zone temperatures of 2300° F without the addition of steam to the top of the gasifier. As more air is added to the top of the gasifier, additional steam must be added to keep temperatures from exceeding 2300° F. As the air-to-coal ratio at the top of the gasifier increases, total steam-to-coal ratio to the gasifier also increases. As the air-to-coal ratio to the top of the gasifier increases, the amount of air needed for lower bed gasification decreases. The total mass flow of air for pyrolysis and gasification remains relatively constant over the range of upper area air-to-coal ratios. Investigation of carbon conversion indicates that as the amount of top air increases, the carbon conversion in the upper bed increases and the requirement for lower bed carbon conversion decreases. The amount of moisture in the product gas changes and the higher heating value of the product gas also varies markedly as a function of top air-to-coal ratio. As the amount of air to the top of the gasifier increases, steam needed to maintain gasifier peak temperatures also increases. The result is a gas with a large amount of moisture and a low heating value. It is, therefore, apparent that peak performance should be gained by operating the PyGas™ gasifier with minimal amount of steam to gasify the coal. The model was also applied to determine the gas constituents exiting the pyrolyzer, exiting the upper gasifier bed, exiting the lower gasifier bed, and finally the combined raw product gas.

Table 5
Predicted Gas Compositions at Various Stages in the PyGas™ Gasifier
Using DOE - CCT4 Reference Coal Analysis
(volumetric percentages)

COAL GAS CONSTITUENT	PYROLYZER EXIT	UPPER GASIFIER EXIT	LOWER GASIFIER EXIT	COMBINED RAW PRODUCT GAS
CO	23.8	27.39	23.51	26.34
H ₂	19.77	17.59	15.33	16.98
CO ₂	3.94	1.8	6.08	2.95
H ₂ O	2.14	2.35	17.49	6.43
CH ₄	4.70	0.00	0.00	0.00
H ₂ S	0.91	0.57	0.00	0.42
N ₂	43.31	49.13	37.14	45.90
Tars	<1.0	<0.1	<0.1	<0.1
Alkali (ppmv)	<.1	<.1	<0.01	<0.01
Temp (°F)	1300	1500	1500	1500
HHV (Btu/scf)	198	151	134	144

4.4.6 TECHNICAL CONCLUSIONS

The PyGas™ coal gasification process promises to alleviate previous limitations in the type of coals that can be effectively gasified in an air-blown, fixed-bed gasification system.

1. Caking coals can be gasified without the adverse effects of sticky tars which have historically resulted in agglomeration in fixed-bed gasifiers.
2. It incorporates features to eliminate (by cracking) tar formations from exiting the gasifier and plugging downstream piping and equipment.
3. It provides a bed of ash on which volatilized alkali can condense and become retained by aluminosilicates either contained within or added to the coal ash.
4. By cracking sulfur containing tar formations, a previous concern of hot gas cleanup system sulfur bypass is eliminated.
5. High moisture containing coals can be gasified without lowering the gasifier exit temperature which could otherwise adversely affect the hot gas cleanup system, and without excessive exit gas moisture which can otherwise exceed turbine compressor surge margin limitations.
6. In contrast to slagging gasifiers, coals with high or low ash fusion characteristics can be gasified in this air-blown gasifier.
7. The exit temperature allows for optimum performance of the hot gas cleanup unit to remove sulfur compounds.
8. Utilized in concert with hot gas cleanup and a combination of rich/lean gas turbine combustion followed by NO_x reburning in fired retrofitted boilers, emissions of SO₂, NO_x, and CO₂ are expected to be the lowest ever achieved by an IGCC system.

The result is expected to be a clean, low-Btu gaseous fuel of approximately 150 Btu/scf at 1200° F, suitable for firing gas turbines, power boilers, and other combustion processes.

4.5 TECHNICAL/ECONOMIC ADVANCES

Historically, fixed-bed gasifiers have been less than successful when gasifying eastern U.S. highly caking coals. This is due to high free swelling coal's propensity to swell and form sticky tars and asphaltines resulting in agglomeration, overheating, and clinkering. Several gasifier manufacturers and researchers have attempted to mechanically break up such agglomerates in an "ex post facto" manner with water cooled stirrers. To date, none have adequately dealt with the phenomenon. Work done in 1963 by Lurgi for the Bureau of Mines on highly caking eastern bituminous coal clearly shows that conventional fixed-bed gasifiers experience coal throughput limitations of from 49% to 65% due to the caking characteristics of Pittsburgh #8 coal. This resulted despite the use of a water cooled stirring device intended to break up incipient agglomerates. The remarks column for the 28 hour test duration identified overheating, porous coke in the discharge, blocked ash discharge, and large semi-fused clinker occurrences. Other fixed-bed coal gasifier manufacturers have experienced very much the same results when attempting to gasify highly caking coals. The PyGas™ gasifier is a novel approach aimed at preventing the thermal conditions which promote the agglomeration phenomenon such as that just described.

Since the PyGas™ gasification process is also intended to crack gaseous tars, it is expected to result in significantly less tar sulfur related sulfur bypass of the hot gas cleanup system, and far less concern for operational constraints relating to tar and carbon-black thermophoresis pluggage potential downstream of the gasifier than currently exists for current fixed-bed gasifiers.

The anticipated condensation of volatilized alkali onto the coal ash within the gasifier where it can be stabilized by the aluminosilicates in the ash represents yet another very substantial potential technological advantage of the PyGas™ coal gasification process.

Another potential technical advance of PyGas™ type of coal gasification process was demonstrated by Acurex under DOE contract. Less ammonia conversion to NOx was reported for low Btu gas combustion than for medium Btu gas. When combusted in a rich/lean mode, as much as 95% NOx reduction resulted. Additionally, when low Btu PyGas™ gasifier coal gas is also combusted in the burners of an existing retrofit/repowered boiler with turbine exhaust gas, a significant amount of NOx reduction by "reburning" can also take place. West Texas Utilities San Angelo plant demonstrated a 50% reduction in the NOx that had been produced by the gas turbine when operated in the fired gas turbine and fired boiler combined cycle mode.

Yet another potential technical advance which the PyGas™ gasifier would likely enjoy over other fixed-bed gasifiers is its consistently relatively moderate raw gas exit temperature (approximately 1200° F). Typical coal gasifiers cannot control their raw gas exiting temperatures due to the evaporative process of the entering coal's moisture which can vary daily with coal moisture content.

Carbon carryover from the PyGas™ coal gasifier is expected to be very low since none of the coal feed fines can bypass the gasification process as is the case with most fixed-bed coal gasifiers. Controlled agglomeration of fines within the gasification vessel is also possible since the whole decaking process is done within the gasifier vessel.

Existing boilers fired with high gas mass flows as would be the case for a fired combined cycle retrofit/repowered boilers with low Btu PyGas™ gasifier coal gas have the potential to produce more burner turbulence, better mixing and lower CO emissions.

The final technical advance is the potential ability of the PyGas™ gasifier to produce exit gas temperatures very near the optimum for hot gas cleanup systems. This is in contrast to the very hot slagging gasifiers which must either quench their gas (very inefficient), or indirectly cool their gas which shifts more heat to the less efficient Rankine thermodynamic cycle and away from the more efficient Brayton thermodynamic cycle.

Therefore, the PyGas™ gasifier coal gasification process claims the following potential advances :

POTENTIAL TECHNICAL ADVANCES

1. Operates even on eastern high caking bituminous coals.
2. Cracks tars for condensation and thermophoresis avoidance.
3. Liberates tar related sulfur promoting higher hot gas cleanup system sulfur capture.
4. Condenses and captures volatilized alkali with in-bed ash-aluminosilicate reactions.
5. When the low Btu PyGas™ gasifier coal gas is rich/lean fired in a gas turbine, then fired in a retrofit/repowered existing boiler on turbine exhaust gas, the an emission of rate less than 0.1 lb/mil-Btu of NOx is anticipated without an SCR.
6. High raw gas exit temperatures consistent with the needs of hot gas cleanup systems.
7. Low carbon carryover since coal feed fines cannot bypass the gasification process.
8. Not requiring significant raw gas cooling (with associated Btus going to the Rankine cycle) keeps more Btus in the more efficient Brayton cycle, achieving the highest cycle efficiency.

Relative to economics issues, following are the relevant issues:

1. The PyGas™ gasifier is air-blown thereby eliminating a very costly and energy intensive individual subsystem in the plant, the oxygen separation plant. A recent Destec ad indicated a \$30-million oxygen separation plant is used by their process on an \$80-million balance of system.
2. The PyGas™ gasifier is intended to be manufactured in the largest truck shippable shop fabricated vessel module; a size sufficient to produce 100 MWe in a combined cycle application.
3. The PyGas™ gasifier has only one moving part inside the vessel, the rotating grate.
4. The crushed coal feed system is pressurized far upstream of the gasifier which alleviates the requirement for a hot high pressure lock hopper valve since it operates in a 150° F environment.
5. Since the PyGas™ gasifier incorporates continuous pneumatic crushed coal feed, no valuable coal gas is wasted through a coal feed lock hopper vent system.
6. Fixed-bed gasifiers traditionally operate on sized lump coal. The PyGas™ gasifier uses crushed coal to 1/4 inch by zero. Therefore, it can operate on far cheaper "run of mine" coal feed.
7. What may be the single most important economics issue of all is that the PyGas™ coal gasification process is suitable for and intended to retrofit/repower existing utility boilers without the need for pressure part modifications to the boiler. Since the boiler is the single most expensive piece of equipment in a utility generating station, making use of it rather than planning to demolish it in favor of a new boiler would save substantial costs.
8. The PyGas™ gasifier is expected to be sold to utility generating companies much like boilers and turbines have been marketed in the past. The repowering approach is always a lower cost one than for the utility to have to purchase energy "over the fence" at value added costs from a private owner/operator, because the existing facility's efficiency is substantially increased and most of the facility cost already exists making it largely already "sunk" and amortized.

4.6 THE REPOWERING OPTION CONCEPT

In a normal repowering setting (not the GPIF), a conventional heat recovery steam generator would be contemplated downstream of the combustion turbine to produce approximately 250°F turbine exhaust gas in the normal fashion except that it would be designed to produce saturated steam only. This would be necessary to make up for the lowered pulverized coal flame temperature when firing on turbine exhaust gas under fully matched combustion turbine and pulverized coal fired boiler conditions, and the attendant reduction in furnace performance (steam generation). Conversely, the additional gas mass flow over the superheater would then allow full steam temperature to be reached and full Rankine cycle efficiency to be maintained.

With proper attention to heat transfer duty within an existing power boiler, it is possible to utilize combustion turbine exhaust gas as a source of windbox oxygen while utilizing its existing steam generators on pulverized coal at loads consistent with the increased gas mass flow associated with turbine exhaust gas firing. Overall net efficiencies of power generation can exceed 42%.

The PyGas™ coal gasifier with its coal feed preparation system represents a major step toward small affordable modular coal gasification systems for the power generation industry. The single most notable feature of the full sized gasifier is its extremely compact module size relative to other competing coal gasification technologies. It will be designed as truck shippable modular vessels of approximately 100 MWe equivalent capacity (when utilized in the combined cycle mode).

The repowering process concept is to match an available combustion turbine size to the existing boiler size to maximize total IGCC efficiency without exceeding existing boiler/turbine operational limitations. While not within the scope of this project, this concept is postulated as one of several potential solutions to the new Clean Air Act. The host utility therefore, will have an interest in the consideration of extending the use of coal gasification (assuming test gasifier success) to simultaneously increase power generation efficiency by approximately 20% while reducing emissions. Two factors weigh heavily in this system matching effort:

1. Selection of combustion turbines whose exhaust gas oxygen content nearly matches the existing boiler's fired oxygen requirement at normal excess air levels minimizes dry stack gas losses.
2. As larger combustion turbines are considered, a point is reached where the gas mass flow through the existing boiler becomes excessive.

Assuming an eventual fuel firing switch (not included in this project) in the existing boiler from pulverized coal to low Btu/scf coal gas, a change in furnace performance must be recognized.

The lower emissivity of the coal gas flame results in slightly lower furnace absorptivity, and a higher furnace exit gas temperature. This in combination with higher than normal gas mass flow due to the use of turbine exhaust gas encroaches on superheater metal temperature limitations. One simple method of controlling this limit is to operate the existing boiler at slightly reduced output. How much lower than full steam flow operation of the existing boiler depends on its specific design and the capacity of other related equipment such as potential coal handling and storage limits. There is always a substantial gain in net power due to the gas turbine contribution.

4.7 CONCEPTUAL RILEY PyGas™ DESIGN

Figure 3 shows the general arrangement of the PyGas™ gasifier which evolved during the course of the conceptual design phase of the contract. While certain equipment design details have become better understood and developed, the basic apparatus remains as depicted in its original patent disclosures.

Coal, sorbent, air and steam are co-injected vertically upward into a carbonizer tube cone forming a jetting fluidized-bed. Recirculation of previously devolatilized char particles back down into the jet provides the heat source for rapid devolatilization of incoming raw coal particles. It also sufficiently insulates coal particles from one another, inhibiting tar based agglomeration. Maintenance of bed temperatures below the melting point of the coal's inorganic fraction also inhibits high temperature melted ash agglomeration.

While the whole issue of fines generation in the jetting fluidized-bed has been rigorously reviewed, the potential to control agglomeration within the slugging carbonizer tube has yet to be evaluated. Others have successfully controlled high temperature agglomeration (KRW) to produce gravitational separation of the inorganic coal fraction. The design incorporates the ability to test and determine the potential for PyGas™ to control fines elutriation by controlling char solids agglomeration.

The ability to raise top gas temperatures to assure complete gaseous tar cracking is also provided.

A separation annulus directs all flow in a downward direction to separate solids from the gaseous flow, and to assure well distributed flow characteristics as well as some gasification, depending on the gas temperature, solids residence time, and kinetic limitations of gasification reactions.

A conventional fixed-bed with reversible rotating grate provides sufficient residence time for char to become gasified by introducing air and steam under-grate in the same manner utilized for the past century to gasify coke and anthracite.

The potential for in-situ sulfur capture with concurrent sorbent feed is provided for in the design.

Figure 3 General PyGas™ Gasifier Arrangement

4.8 COMMERCIALIZATION APPROACH

4.8.1 MARKET DESCRIPTION

Virtually the entire existing coal fired utility market from 100 MWn on upward represents the potential market for the PyGas™ gasifier. Once demonstrated, it will compete very successfully with all of the various pulverized coal plants with scrubbers, circulating fluidized bed boilers (CFBC), and other integrated gasification combined cycles because it has at least twice the coal throughput of a fixed-bed Lurgi gasifier on caking coals, cracks tar vapors, condenses volatilized alkali, uses "run of mine" coal, does not bypass coal fines, and maintains ideal hot raw gas outlet temperatures consistent with hot gas cleanup system temperature limitations. The market share gained by this technology will be considerable because this technology is proprietary and patent protected (applied for worldwide).

Shop fabricated 50 to 100 MWe equivalent modules are intended to replace existing pulverizers which are usually of similar incremental sizing and numbers in utility applications. It was recognized by the utility industry long ago that redundancy was necessary for pulverizer application to coal fired utility boilers (note the "typical" 300 MW DOE reference plant example has some six (6) pulverizers). In like fashion, the utility industry has utilized a multiplicity of coal burners for individual boilers (although not shown, the 300 MW reference plant likely has from eighteen (18) to twenty-four (24) coal burners).

The application of the PyGas™ gasifier modular vessels follows the very same time tested logic (the function of the PyGas™ gasifier and its coal preparation equipment are the same as the pulverizers and the coal burners of contemporary coal fired systems, so the concept of using several partially redundant modules is not new, rather, it is a logical adaptation to existing coal fired facilities). The statistical improvement to availability is quantifiable and has been previously developed.

It should be noted that since the addition of the PyGas™ gasifier results in lowering the maximum fireside gas temperature via the introduction of turbine exhaust gas to the windbox of the existing utility coal boiler, forced outages most commonly caused by local excessive temperatures to superheater and waterwall tubing are far less likely. Therefore, the use of this technology in retrofit of existing coal boilers will actually reduce existing superheater and waterwall tube failures. This is achieved by lowering the furnace gas temperature both by dilution with turbine exhaust gas and by reducing the firing rate of the existing boiler. The net effect remains significantly greater electric output at much increased efficiency due to the addition of a small gas turbine to the cycle.

The project team identified existing coal fired utility power plants as near term candidates for standardized PyGas™ gasifier application. While many consider conventional flue gas scrubbers as the economical solution to the emissions concerns of large coal fired utilities, such systems are expensive and adversely affect power plant efficiency by consuming significant quantities of power which would have otherwise been available to the grid. In effect, while reducing stack emissions, scrubbers return reduced plant electricity output for their significant expense.

Retrofitting and repowering existing coal fired power plants with the PyGas™ gasifier results in much lower emissions than currently available commercial scrubber systems plus very substantial increased power output for the same coal input for which the facility has already been designed.

The "Commercialization Plan" contemplated for this emerging product to serve a burgeoning power production market was developed with the recognition that first unit implementation looms as the greatest threat to timely introduction of this concept for widespread use in the cogeneration, independent power production, and utility industries.

Since additional development of the PyGas™ hybrid gasifier is currently needed before the economic goals of the project team can be realized, it is believed that the cogeneration, independent power production, and utility industries will not endorse it until such time that the improved gasifier is demonstrated.

There is solid justification for the consideration of the addition of PyGas™ gasifier systems to existing coal fired utility plants. The majority of the most costly of the capital cost items of the power plant already exist. These include coal receiving/handling/storage/reclaim, water sourcing/purification/treatment/disposal, electricity generation/conditioning/distribution, and the most costly of all, the boiler island itself.

Unlike other repowering strategies which require replacement of the boiler island, this approach presents a way to simply add on the PyGas™ gasifier system to the existing coal designed plant

with minimum modification to the existing infrastructure. The result is also an approximate 15% to 20% increase in power output while simultaneously reducing the plant's stack gas emissions by well in excess of 90% for SO₂, NO_x, and particulates, and 15% to 20% for CO₂.

4.8.2 RILEY COMMERCIALIZATION SUMMARY

The PyGas™ Pilot Development Facility planned for the GPIF would provide the necessary data to prove the benefits of the PyGas™ process and scaling parameters to offer commercial sized plants. This is an absolute necessity in DB Riley's commercialization plans for the technology.

In market studies conducted by DB Riley and others, a majority of the old coal plants are under 300 MWe in size, with an average around 150 MWe. This is the target niche for DB Riley's commercialization efforts to repower using PyGas™ technology.

A key ingredient of the commercialization of the PyGas™ technology is data from a pilot plant facility to conclusively prove the process and allow scale-up to take place.

The following summarizes the overall commercialization plan for PyGas™ :

- A PyGas™ pilot development facility is essential for commercialization.
- The commercialization strategy is based on repowering existing coal-fired boilers less than 300 MWe, which account for the majority of units that will become repowering candidates by the turn of the century.
- Existing coal fired plants are more likely to repower with coal.
- Repowering will provide the experience base for entering the U.S. and foreign new capacity or "greenfield" power generation market.
- Full PyGas™ repowering costs are less than \$1000/kW; 25-50% lower than other coal based technologies. Partial repowering with PyGas™ can be performed at less than \$500/kW, which is less than most natural gas combined cycle facility capital costs.
- Cost of electricity of less than 3¢/kWh for partial repowering is more economical with PyGas™ than partial repowering with natural gas.
- This partial repowering strategy, which is well suited to PyGas™, is especially attractive during soft demand for added capacity. Partial repowering results in approximately 20% capacity growth, while full repowering adds 200% capacity growth.

PyGas™ modular gasification can provide a system that beats natural gas on a levelized cost of electricity analysis when partially or fully repowering small to moderate sized coal plants.

In several studies made by DB Riley, adding PyGas™ would provide very attractive systems at electricity costs less than 3 ¢/kWh when partially repowering existing coal fired utilities providing 10% to 50% MW growth and at 10% to 20% greater efficiency than the existing generating station.

In a fully repowered scenario, PyGas™ would provide a plant with 200% MW growth at a cost less than 3.5¢/kWh.

Figure 3 Partial IGCC Repowering With PyGas™

4.8.3 COMMERCIALIZATION PLAN

The PyGas™ technology is a patented process and apparatus. These patents have been transferred from Jacobs-Sirrine Engineers Inc. of Greenville, SC to DB Riley, Inc. located in Worcester, MA. DB Riley, and its parent, Deutsche Babcock have experience in gasification, combustion, and boiler design and manufacture. The PyGas™ technology is complemented by a number of other key IGCC related components currently offered or being developed by Deutsche Babcock and DB Riley such as hot gas filters, gas coolers, and heat recovery steam generators (HRSG).

DB Riley will be responsible for the marketing, sales, and manufacture of the PyGas™ gasification system. Commercialization efforts will be lead by DB Riley. Under a teaming arrangement, Jacobs-Sirrine Engineers will assist DB Riley in its commercialization efforts, and will concentrate its efforts in the pulp and paper and refinery industries. Under the same teaming arrangement, Jacobs-Sirrine plans to provide design, engineering and construction services.

The main focus of the entire effort surrounds the gasifier itself which will be designed and supplied by DB Riley. The team's timing plans in conjunction with the case studies developed for several repowering strategies as well as new installation scenarios are as follows :

1996-1997

- Discuss with utility companies their plans for repowering/new additions.
- Introduce PyGas™ and pilot plant results for repowering their specific site.
- Identify potential sites for new PyGas™ modules in repowering or new utilities.

1998-2000

- Utilize pilot plant data to prepare initial offerings.
- Book initial repowering project.

There are a significant number of 30-, 40-, and 50-year old generating units in the U.S.

The Office of Technology Assessment has estimated that approximately 170,000 MWe of the U.S.'s steam generating units will be at least 30 years old by 1995. In a separate analysis, EPRI has stated that by the year 2000 - there will be 87,000 MWe over 45 years old. The average size plant is 150 MWe. Another source states that the majority of fossil fired units in the U.S. with a plant output under 300 MWe were built during the 1950's and are now approaching the end of their design life. In addition, many utilities report the need for additional generating facilities in the coming decade. According to the Association of Edison Illuminating Companies April, 1995 projections, there could be 30,000 to 85,000 MWe growth during the next 10 year period.

How will the utilities cope with the small inefficient units that may have already suffered some capacity and efficiency degradation over time?

New "greenfield" coal fired plants cost in excess of \$1000/kW and new advanced clean coal technologies may be in the \$1200 to \$1500/kW range. Coupling low natural gas fired new combined cycle and repowered plant costs with current low natural gas prices, new coal based generating facilities cannot compete in the near future.

Repowering can extend the life of older coal based plants and lead to a resurgence of the U.S. power generating equipment market. Most of the existing facility equipment including coal receiving, handling, storage, preparation, and conveying systems, water treatment, condensing and cooling systems, boiler island steam generation systems, steam turbine and generator systems, power transforming and distribution systems as well as most of the related auxiliary systems can continue to be utilized.

Installed capital costs in the range of \$500/kW have been reported for natural gas fired CTCC repowering projects. This compares to \$600 to \$800/kW for an equivalent but entirely new CTCC installation. These costs were typical from several of the references included even as recently as May, 1995 Power Engineering.

Coal costs less than natural gas although the differential of \$1.00 to \$1.50/milBtu is low and may continue to remain low for the near term. Consequently, for a coal fired repowering scenario to make sense, the plant would most likely have to be built at a capital cost consistent with the all inclusive cost of electricity equal to that of a natural gas fired repowered combined cycle. According to EPRI, this allows only a \$600 to \$800/kW capital expenditure. Therefore, only existing coal fired installations where the plant's equipment infrastructure is in place and in good condition can be considered coal repowering candidates in the near term.

Eventually, coal to gas price differential is expected to increase as the world-wide demand for natural gas continues to grow and the resource becomes depleted. In the interim, IGCC plant capital costs will decrease, and new PyGas™ "greenfield" installations will be built. This may not occur before the year 2010.

5.0 CONCLUSION

Repowering existing coal based electric power generating stations with PyGas™ is, by far, the least capital cost approach to the currently untapped IGCC market. In addition, potential operating efficiency gains from such repowering are greater than the efficiency differences of the entire range of existing coal fired facilities. This means that even the least efficient existing coal fired utility which currently gets virtually no dispatch operation would, if repowered, become the most efficient coal fired unit of the utility, with the highest percentage of dispatch. Therefore, there is currently a vast untapped market for PyGas™.

The majority of coal based repowering candidates in the near term will be under 300 MWe in size. This makes most of them too small for conventional IGCC consideration utilizing oxygen separation plants, high temperature gasification with associated fuel gas cooling requirements, and costly hot gas desulfurization. Such systems, while technically viable, are not cost effective.

Cost of electricity of less than 3 cents/kWh for partial repowering is more economical with PyGas™ than even partial repowering with natural gas.

However, unless and until a successfully operating PyGas™ pilot development facility is built, this promising technology cannot be commercialized.

5.1 PROJECT CANCELLATION BY DOE

The unfortunate reality of this project is that the DOE/METC has chosen to cancel this project for their convenience. We understand this decision stems from a general congressional mandate to reduce the overall fossil fuel program budget. We also understand this decision to be totally budget based and should not be construed as a negative reflection on the technology, and that the DOE/METC has not found anything that would prove the PyGas™ technology to not be viable.

5.2 OBJECTIVE NOT MET

Since the GPIF contract has been canceled, the original objective of the development of an advanced highly efficient fixed-bed gasification process at a cost of less than \$1,000 per kilowatt has not been met.

5.3 HOPEFUL OF FUTURE CONTRACT FOR PyGas™ PILOT TEST UNIT

The entire project team is very disappointed at the unfortunate decision to discontinue this project at a time when the most essential prerequisite to commercialization, hardware design, fabrication, installation, and demonstration was so close to being achieved.

Figure 4 shows what the GPIF would have looked like at the Fort Martin station site. While we appreciate the efforts to date of the DOE/METC in support of PyGas™, we can only hope for the resurrection of the PyGas™ technology at a new facility location at a future date.

Figure 4 The GPIF Facility as it Would Look at the Fort Martin Generating Station

REFERENCES

1. Lowell, C., et al, A Multi-Stage Desulfurizing Fluid-Bed Combustor for Coal-Fired Hot Gas Generator Systems, DOE Contract No. DE-AC21-78MC-10484
2. Robertson, Archie, Second-Generation Pressurized Fluidized-Bed Combustion Plant, FWEC Carbonizer Test Runs 1 Through 10, DOE Contract DE-AC21-86MC21023, September, 1992
3. Radulovic, Predrag T., Fixed-bed Combustion and Gasification Processes, DOE Contract DE-AC21-93MC30040, Nov. 3, 1994
4. Schmidt, D.K. et al, Advanced Development of a Pressurized Ash Agglomerating Coal Gasification System, DOE Contract DE-AC21-82MC19122, July 31, 1987
5. Gomez, M., et al, Entrained-Bed Carbonization of Bituminous Coals, U.S. Bureau of Mines, RI 7141, 1968
6. Eakman, J.M., et al, Gasifier Operation and Modeling in the Exxon Catalytic Coal Gasification Process, Exxon Research & Engineering, Baytown, Texas: AIChE
7. Wen, C.Y., et al, Entrained-Bed Coal Gasification Modeling, West Virginia University, Morgantown, West Virginia: AIChE
8. Wen, C.Y., et al, Production of Low BTU Gas Involving Coal Pyrolysis and Gasification, Coal Gasification, L.G. Masey, Advances in Chemistry, No. 131, pp 9-28, American Chemical Society
9. Schmidt, D.K. et al, Advanced Development of a Pressurized Ash Agglomerating Coal Gasification System, Phase II, DOE Contract DE-AC21-82MC19122, July 31, 1984
10. Lang, E.W., et al Carbonization of Agglomerating Coals in a Fluidized Bed, Southern Research Institute, Industrial and Engineering Chemistry, Vol. 49, No. 3, March, 1957
11. Barton, R.K., et al The Use of a Spouted Bed for the Low Temperature Carbonization of Coal, The Institution of Engineers, Australia, Mechanical & Chemical Engineering Transactions, May, 1968
12. Barton, R.K., et al, The Rates of Devolatilization of Coal Under Spouted Bed Conditions, The Institution of Engineers, Australia, Mechanical & Chemical Engineering Transactions, May, 1969
13. Ratcliffe, J.S., et al, Low Temperature Carbonization of Coal, The Institution of Engineers, Australia, Mechanical & Chemical Engineering Transactions, May, 1969
14. Quinlan, M.J., et al, A Design Equation for the Low Temperature Carbonization of Coal Under Spouted Bed Conditions, The Institution of Engineers, Australia, Mechanical & Chemical Engineering Transactions, May, 1971
15. Pitt, G.J., et al, The Kinetics of the Evolution of Volatile Products from Coal, Fourth International Conference on Coal Science, May 30, 1961
16. Rhinehart, R. Russell, et al, Dynamic Modeling of a Pilot-Scale Fluidized-bed Coal Gasification Reactor, N.C. State University, American Chemical Society, 1987

17. Neogi, D., et al, Study of Coal Gasification in an Experimental Fluidized Bed Reactor, AIChE Journal, Vol 32, No. 1, January, 1986
18. Wen, C.Y., et al, User's Manual for Computer Simulation and Design of the Moving Bed Coal Gasifier, DOE Report DE-AT21-79MC16474, January, 1982
19. PSI Technology, Inc., NOx and Alkali Vapor Control Strategies, DOE Contract DE-AC21-92MC28202, Appendix B, July, 1990
20. Bachovchin, Dennis M., A Study of High Temperature Removal of Alkali in a Pressurized Gasification System, Westinghouse R&D, DOE Contract DE-AC21-83MC20050, Proceedings of the 7th Gasification Conference
21. Early, W.P., et al, Practical Operating Experience on a Riley Gasifier, Early, 88th National Mtg. AIChE, June, 1980
22. Dr. Fred L. Jones, et al, Source Test and Evaluation of a Riley Gas Producer Firing North Dakota Lignite, Symposium on Environmental Impacts of Fuel Conversion Technology, Denver, CO, October 26, 1981
23. Woodmansee, D.E., et al, Gasification of Illinois #6 Coal in an Advanced Fixed-Bed Gasifier, General Electric Company, Schenectady, New York: AIChE
24. Monazam, Esmail R., et al, Modeling and Simulation of a Crossflow Coal Gasifier, Fuel Science and Technology Int'l, 10(1), 52-73, (1992)
25. Pater, K.Jr., et al, Final Report on the METC 42-Inch Fixed-Bed Coal Gasifier, DE-AC21-83MC20201, March, 1986
26. Gumz, Wilhelm, Gas Producers & Blast Furnaces, John Wiley & Sons, Inc., 1950
27. Smith, D.P., Design Studies for Gasification/Hot Gas Desulfurization System Operation in a Load Following Mode, DOE Contract DE-AC21-86MC22247, June 1988
28. Klett, M.G., et al, Conceptual Designs of Advanced High-Temperature Desulfurization Processes Volume II Integrated Gasification Combined Cycle. Final Report, DOE/MC/21098--2248-Vol.2, DOE Contract DE-AC21-84MC21098, Dec, 1986
29. Muralidhara, H.S., et al, Effect of Calcium on Gasification, West Virginia University, Morgantown, West Virginia: AIChE
30. Nemeth, E.J., et al, Desulfurization of Hot Coal-Derived Gas by Calcined Dolomite, U.S. Steel Corporation, Monroeville, Pennsylvania: AIChE
31. Wen, C.Y., et al, Solid-Gas Reactions in Coal Conversion Processes, West Virginia University, Morgantown, West Virginia: AIChE
32. Acurex Corporation, NOx Control by Ammonia Reduction in IGCC Processes, DOE Contract DE-AC21-86MC23275
33. Miller, Earle C., Leonard, R. Redfern, Combined Cycle-Gas Turbine and Steam Generator, Riley Stoker Corp., Worcester, MA, 1963

34. Leonard, R.R., et al, Steam Generation from Turbine Exhaust Gas, Riley Stoker Corp., National Power Conference, Cincinnati, Ohio, September 24, 1963
35. Johnson, S.A., et al, NOx Tests Performed on the Riley Front Fired Unit During the Period 12-15-72 through 2-16-72 at West Texas Utilities Lake Nasworthy Plant, San Angelo, Texas, Riley Stoker Internal Report, 1972
36. Menster, M., et al, Devolatilization of Coal by Rapid Heating, Pittsburgh Energy Research Center, U.S. Bureau of Mines, May, 1983
37. Nelson, S.G., Coal Gasification/Cogeneration Combined Cycle Power Plant Designs, Davy McKee, & Bloomfield, H., NASA Lewis Research Center, Coal Technology '80, Nov., 1980
38. Baily, F.G., Rendine, A.P., Robbins, K.E., Steam Turbines for STAG Combined-Cycle Power Systems, GE Company, Schenectady, New York, 1989, p.2-3.
39. CRS Sirrine Engineers, Inc., Internal Economic Study for a Mid-western Utility, May, 1991
40. Steam Generating Units - Power Test Codes", ASME New York, New York , ASME PTC4.1- 1985
41. Bauer, F.W., et al, Diagnosis of Thermal and Fluid Dynamic Performance of a Boiler, Stone & Webster Engineering Corporation, Technical Paper Series, 1989
42. CRS Sirrine Engineers Inc., Design and Performance of Standardized Fixed Bed Air Blown Gasifier IGCC Systems for Future Electric Power Generation, Department of Energy Contract No. DE-AC21-89MC26291, March 1991.
43. Solomon, Peter R. and Hamblen, David G., Pyrolysis.
33. Menster, M., O'Donnell, H.J., Ergun, S., Friedel, R.A., Devolatilization of Coal by Rapid Heating, Pittsburgh Energy Research Center, US Bureau of Mines, May 1973.
45. Wormser Engineering, Inc., A Multi-Stage Desulfurizing Fluid-Bed Combustor for Coal-Fired Hot Gas Generator Systems, Department of Energy Contract No. DE-AC21-78MC-10484.
46. Rudolph, Paul, The Lurgi Process: The Route to SNG from Coal.
47. Wen, C.Y., Bailie, R.C., Lin, C.Y., and O'Brien W.S., Production of Low Btu Gas Involving Coal Pyrolysis and Gasification, Chemical Engineering Department, West Virginia University, May 1973.
48. Wen, C.Y., Chen, H., Onozaki, M., User's Manual for Computer Simulation and Design of the Moving-Bed Coal Gasifier. Morgantown Energy Technology Center [Rep.]; DOE/METC (U.S. Department of Energy), 1982; DOE/MC/16474 1390 (DE83009533).
49. Schmidt, D.K., et al. Advanced Development of a Pressurized Ash Agglomerating Fluidized-Bed Coal Gasification System. Morgantown Energy Technology Center [Rep.]; DOE/METC (U.S. Department of Energy), 1987; DOE/MC/19122-2521 (DE88002932).
50. Kuehn, S., Advancing Gas Turbine Technology: Evolution and Revolution, Power Engineering, May, 1995

51. MacGregor, P., Maslak, C., Stoll, H., The Economic Viability of Integrated Gasification Combined Cycle, GE Industrial and Power Systems, American Power Conference, Chicago, 1991
52. Shadle, L., PyGas™ Design Support, METC Proceedings of the Coal Fired Power Systems '93 - Advances in IGCC and PFBC Review Meeting, June, 1993
53. Sadowski, R.S., Henderson, S., Pulp and Paper Industry Repowering with Integrated Gasification Combined Cycle (IGCC), Jacobs-Sirrine Engineers, TAPPI Engineering Conference, Sept, 1995
54. Sadowski, R., Mahajan, K., Shadle, L., Innovative Gasification Technology for Future Power Generation, Air & Waste Management, June, 1995
55. Sullivan, J.L., The Economics of Combustion Turbine Combined Cycle Repowering, Burns & McDonnell Engineering, Co., Power Gen, 1994 - 7th International Conference, December, 1994
56. Smith, R., Henderson, C.R., S.E. Pace, VanLaar, J.A., Warren, S.G., Methodology of Performing a Repowering Evaluation, Union Electric, EPRI, Sargent & Lundy, Power Gen, 1994 - 7th International Conference, December, 1994
57. Tawney, R.K., Hekmat, M., Baker, K.I., Bechtel, Economic Evaluation of Combined Cycle Repowering Options, Power Gen, 1994 - 7th International Conference, December, 1994
58. Dixit, V., Gasification Product Improvement Facility Status, DB Riley, DOE/METC, Proceedings of the Coal Fired Power Systems - 95 Advances in IGCC and PFBC Review Meeting, June, 1995
59. Sullivan, T., Briesch, M., Repowering - A Ready Source of New Capacity, Westinghouse Electric, 8th Cogeneration and Independent Power Congress, Boston, 1993
60. Office of Technology Assessment, Congressional and Public Affairs, Washington, DC
61. Hewson, T., Stamberg, J., Repowering Technology Market Assessment, Energy Ventures, Presented at EPRI Repowering Technology Workshop, May, 1993
62. TAG™ - Technical Assessment Guide, EPRI TR-102276-V1R7, Volume 1: Rev.7, June, 1993
63. Annual Energy Outlook 1995, Department of Energy/Energy Information Administration, January, 1995

NO.	DESCRIPTION	DATE	BY
1	DESIGNED FOR USE		
2	DESIGNED FOR USE		
3	DESIGNED FOR USE		
4	DESIGNED FOR USE		
5	DESIGNED FOR USE		
6	DESIGNED FOR USE		
7	DESIGNED FOR USE		
8	DESIGNED FOR USE		
9	DESIGNED FOR USE		
10	DESIGNED FOR USE		
11	DESIGNED FOR USE		
12	DESIGNED FOR USE		
13	DESIGNED FOR USE		
14	DESIGNED FOR USE		
15	DESIGNED FOR USE		
16	DESIGNED FOR USE		
17	DESIGNED FOR USE		
18	DESIGNED FOR USE		
19	DESIGNED FOR USE		
20	DESIGNED FOR USE		
21	DESIGNED FOR USE		
22	DESIGNED FOR USE		
23	DESIGNED FOR USE		
24	DESIGNED FOR USE		
25	DESIGNED FOR USE		

DATE: 6/7/95

BY: [Signature]

PROJECT: [Blank]

SCALE: [Blank]

CLASSIFICATION PROJECT: [Blank]

REVISIONS: [Blank]

DEPARTMENT OF ENERGY

PROJECT TITLE: [Blank]

OPF FLOW SHEET

PROJECT NO.: 1615716-OPF

18

HEAT AND MATERIAL BALANCE CALCULATIONS FOR THE PYROLYZER

JSE THERMOMODEL - MASS BALANCE INPUTS

DESIGNATED INPUTS		Spec Coal	W/WATER-GAS	10/19/95 15:48
		THERMOMODEL	REACTION	"Normal Operation"
		INPUTS	W.E. SKINNER	325 psig Operating Press; Spec Coal
*AIR/COAL	1.720	4.54fps @ 1773°F	Balanced Temperature, Carbon Remaining & Mass	
*STEAM/COAL	0.17	1.701 fps (Pyro SV)	863 °C	
*SORBENT/COAL	0.2404	37% ofSV@1.72 A/C	1136 °K	
T FINAL DEG. F	1657	1585	1585 °F	Calc.
*% CARBON REMAINING	50%	50%	lb/hr	Wt %
% CO	19.86%	19.24%	2342	23.66%
% CO2	6.09%	6.71%	1284	12.98%
% H2	19.87%	20.49%	180	1.81%
% H2O	8.87%	8.24%	646	6.52%
% CH4	1.37%	1.37%	95	0.96%
% N2	43.53%	43.53%	5300	53.54%
%H2S	0.42%	0.42%	51	0.52%
*COAL FEED RATE (LB/HR)	4000	50%	9899	Pyrolysis Gas
T DEG. F FOR CP (EST.)	1657		C 2852	
Kp (T)	0.77		H 279	
Kp (apparent)	0.69		O 3080	
*METHANE CONVERSION %	5%		N 5300	
*SULFUR CONVERSION %	48%		S 112	
DELTA MASS	0			
*CO/CO2 =	3.26	3.26006069	*= Iterative Formula-Ht Form Based on LHV	
%O2	0.23	HT. FORM OF COAL BTU/LB	-0.05 X 1000	
%O	0.77		HHV Analysis :	Btu/lb As Rec'd (LHV)
% CONV BY O	9%		DuLong Formula =	12580 12114
% CONV BY H2O	41%		Foster Wheeler Tests =	12724 12258
BTU/DSCF 59 DEG F	155.9	154.9	METC Specs. =	12500 12034
BTU/WACF 59 DEG F	142.9	141.9	Used to Tie (LHV)=	12034
HT. FORM OF COAL BTU/LB	-54		% OF COAL AS CH	73%
PYRO HEAT LOSS - ASSUMED	14.55%	1.25E+06 BTU/HR	MW OF CH	6.70
CALCULATED °F PYRO HT LOSS	282	CHANGE CO/CO2 RATIO		
PYRO HEAT LOSS (% OF TOTAL)	2.60%	UNTIL DELTA MASS EQUALS 0		
CLOSURE (OUT/IN) - FW TEST TR-2.5	11%			

HEAT AND MATERIAL BALANCE CALCULATIONS FOR THE PYROLYZER

Gibbs Free Energy (kcal/mole) (25 deg C)	Enthalpy (kcal/mole) (25 deg C)	Entropy (cal/(mole deg.)) (25 deg C)
-6.816	-9.834	-10.13 0.0%

Equilibrium Constant Reaction

$$K_p(T) = \frac{Y(\text{CO}_2) \cdot Y(\text{H}_2)}{Y(\text{CO}) \cdot Y(\text{H}_2\text{O})}$$

$$\log(K_p) = a + b \cdot T + c \cdot T^2 + d \cdot T^3 + e \cdot T^4 + f \cdot T^5$$

coefficients	a	b	c	d	e	f
	18.74	-6.28E-02	8.79E-05	-6.35E-08	2.32E-11	-3.38E-15

T (DEG. F)	T (DEG.K)	Kp(T)	Kp(app.)	T deg. F (at Kp(app.))
1657	1176	0.77	0.69	1766.3624
Kp = 8.67E-01				
19.86% CO	<div> <div>Start With</div> <div>0.031</div> <div>Conversion =</div> <div>0.031</div> <div>of CO</div> </div>	19.24% CO		
19.87% H2		20.49% H2		
6.09% CO2		6.71% CO2		
8.87% H2O		8.24% H2O		
1.37% CH4		1.37% CH4		
0.42% H2S		0.42% H2S		
43.53% N2		43.53% N2		
CP(AVE)= 7.19	*Iterative Formula		T (Ht. Bal) = 1585.46	CP (AVE) = 7.96
T = 1657			T (Equil.) = 1585.51	CP(EST)= 7.96
			1585.51	

DOE - GPF - PyGas™ (Base Case 2 TPH)		325 psig Operation - Specified Design				Reference Coal - RFP Specification - MOAS Kinetics				10/18/95 14:40	
Design Support Document, Mass Balance		Using Thermomodel (Assume 50% Devolatilization)				5 ft Dia Test Size				JSE Predicted Output (24% Bed Volatil)	
Stream No.	Identified	1 Flow Coal FL Martin Pile GPF Recycling Hopper wt %	2 Sorbent Limestone Sorbent Pile Limestone/Coke Bin 8.08 "Coke/Mole Ratio"	3 Coal Storage Bin Crusher/Dryer	4 Coal Dryer Combustion Air Anhydrous Coal Dryer Inlet	4a Coal Dryer Combustion Gas Coal Dryer Vent System	5a Natural Gas Pipeline Coal Dryer Inlet	5b Natural Gas Pipeline Burner Support Inlet	5c Natural Gas Pipeline PyGas™ Preheat Inlet	5d Natural Gas Pipeline Start-up HPSG Inlet	5 Natural Gas Pipeline Total Usage @Start Inlet
11	CO	28.010									
12	H2	2.016									
13	CO2	44.010									
14	H2O	18.015									
15	CH4	18.042									
16	C2H6	30.068									
17	H2S	34.078									
18	COS	60.070									
19	N2	28.013									
20	Ar	39.948									
21	HCl	36.461									
22	HCN	27.026									
23	NH3	17.030									
24	CS2	76.131									
25	SO2	64.059									
26	NO	30.006									
27	O2	31.999									
28	NaCl	58.497									
29	KCl	74.596									
30	CaSO4	136.142									
31	Ca(OH)2	74.093									
32	Cl2	35.500									
33	Total Gas (lb/hr)										
34	Volumetric Flow Rates (STP 14.7 psia, 30F)										
35	(acfm)										
36	(scfm)										
37	Heat (BTU/hr)										
38	Qp (BTU/hr)										
39	Qh (BTU/hr)										
40	Qw (BTU/hr)										
41	Qs (BTU/hr)										
42	Sensible Heat above										
43	50 F Inlet steam										
44	Latent Heat of										
45	Water Inlet steam										
46	Chemical Heat										
47	(BTU/hr)										
48	Sensible Heat										
49	above 50 F Inlet										
50	Latent Heat										
51	of Water Inlet										
52	Total Heat (MBtu/hr)										
53	Unburnt Analysis										
54	C	12.011	68.80%	3453	9%	0	3444	91	230	31	142
55	H	1.008	4.60%	232	Purity	0	231	30	75	10	47
56	O	18.000	4.70%	237	0	0	236	0	0	0	0
57	N	14.007	1.20%	60	0	0	60	11	27	4	17
58	S	32.060	2.80%	141	0	0	141	0	0	0	0
59	CaO	56.078	0.10%	5	0	0	5	0	0	0	0
60	H2O	18.016	3.00%	151	0	0	151	0	0	0	0
61	NaCl	58.497									
62	KCl	74.596									
63	CaSO4	136.142									
64	Ca	40.080									
65	CaS	72.140									
66	ASH, Inerts (pph)	18.00%	755	0	753						
67	Total Solids (pph)		5034	0	5021						
68	Total Flow (pph)		5034	0	5021						
69	Total Flow (ppe)	1.40	0.00	1.40	0.73	0.76	0.04	0.09	0.01	0.06	0.20
70	Pressure (psig)	0.0	0.0	0.0	1	0	20	20	20	20	20
71	Temperature (F)	80	80	80	80	450	80	80	80	80	80
72	Changes in this Issue:	Deleted Ca from pyrolyzer reactions (streams 10 & 14); Set Ar to Thermomodel calculations; Recovered lost Sulfur in CoFlow region (was fed to Ca as CaS); Reduced error in Stream 9d to less than 1%.									

DOE - GPF - PyGas™ (Base Case 2 TPI)		325 psig Operation - Specified Design				Gasifier Efficiency (Gas Out/Coal In + Air In + Steam In) = 77.26%		Cold Gas Efficiency (Gas Out/Coal In) = 84.04%		10/19/95 14:40
Design Support Document - Mass Balance		Using Thermodynamic (Assume 54% Devolatilization)				CONTRACT NO. DE-AC21-82MC202		Page 2		05/
Stream No.		8a	8b	8c	8d	8e	8f	8g	8h	06/
From		Combustion Air	Total Exhausts	Combustion Air Balance	Rotary Valve Leakage	Coal Dryer Air	Coal Prep Exhaust	Removed Linerstone System	Bucket Elevator Exhaust	07/
To		Total	Baghouse Vents	Less Baghouse Vents	Convey System	Coal Dryer Vent System	Coal Prep System		Coal Bin Vent System	08/
Gas	Mass Wt	In/hr	Air or Incomplete Comb.	In/hr, (If Vents Used)	@ 1.25 In/hr Coal		In/hr			09/
CO	28.010	0	0	0	0	0	0	0	0	10/
H ₂	2.018	0	0	0	0	0	0	0	0	11/
CO ₂	44.010	21	343	21	1	1	6	2	2	12/
H ₂ O	18.015	278	428	278	9	9	77	29	31	13/
CH ₄	18.042	0	0	0	0	0	0	0	0	14/
C ₂ H ₆	30.068	0	0	0	0	0	0	0	0	15/
H ₂ S	34.078	0	0	0	0	0	0	0	0	16/
COS	60.070	0	0	0	0	0	0	0	0	17/
H ₂	28.013	32809	19188	13621	1013	1013	9118	3386	3714	18/
Ar	39.948	863	353	510	18	18	160	59	85	19/
HCl	36.461	0	0	0	0	0	0	0	0	20/
HCN	27.028	0	0	0	0	0	0	0	0	21/
NH ₃	17.030	0	0	0	0	0	0	0	0	22/
CS ₂	78.131	0	0	0	0	0	0	0	0	23/
SO ₂	64.059	0	0	0	0	0	0	0	0	24/
NO	30.006	0	0	0	0	0	0	0	0	25/
O ₂	31.999	11278	5400	5875	310	310	2792	1037	1137	26/
NaCl	58.497	0	0	0	0	0	0	0	0	27/
KCl	74.596	0	0	0	0	0	0	0	0	28/
CaSO ₄	136.142	0	0	0	0	0	0	0	0	29/
Ca(OH) ₂	74.085	0	0	0	0	0	0	0	0	30/
Cl ₂	35.500	0	0	0	0	0	0	0	0	31/
Total Gas (lb/hr)		43758	22964	20795	1350	1350	12150	4514	4950	32/
Volumetric Flow Rates (STP 14.7 psia, 59°F)										33/
(acfm)		10148	5325	4822	307	461	3123	1028	1127	34/
(acfm)		9575	5025	4550	295	295	2658	988	1083	35/
Heat (BTU/hr)										36/
Q _p (BTU/hr F)										37/
Q _h (BTU/hr)							12500	12500	12500	38/
Q _h (BTU/hr)							12038	12038	12038	39/
Sensible Heat above										40/
30 F BTU/hr steam							0	0	0	41/
Latent Heat of										42/
Water BTU/hr steam										43/
Chemical Heat										44/
(Q _h) MBtu/hr										45/
Sensible Heat										46/
above 30 F MBtu/hr										47/
Latent Heat										48/
of Water MBtu/hr										49/
Total Heat (MBtu/hr)										50/
										51/
C	12.011						1.19		8.92	52/
H	1.008						0.08		0.60	53/
O	18.000						0.00		0.61	54/
N	14.007						0.02		0.16	55/
S	32.060						0.05		0.36	56/
CaO	58.079								0.01	57/
H ₂ O	18.016						0.05	0.16	0.30	58/
NaCl	58.497									59/
KCl	74.596									60/
CaCO ₃	100.089							0.16		61/
Ca	40.080						0.00			62/
CaS	72.140									63/
ASH ₂ Inerts (pph)							0.26	1.40	1.95	64/
Total Solids (pph)						104	1.74	1.71	3.27	65/
Total Flow (pph)		43758	22964	20795	1350	1454	12152	4515	4953	66/
Total Flow (psig)		12	6	6	4.20	0	3	1	1	67/
Pressure (psig)		0	0	0	0.0	0.0	0.0	0.0	0.0	68/
Temperature (F)		90	90	90	80	350	150	80	80	69/
										70/

DOE - GPIF - PyGas™ (Base Case 2 TPH)		325 psi Operation - Specified Design				10/19/95 14:40			
Design Support Document, Mass Balance		Using Thermomax (Assume 50% Devolatilization)				Page 3			
Stream No.	7	7a	7b	7c	7d	7e	7f	7g	7h
Location	Coal	Crushed Coal	Coal	Coal	Coal Crusher Dust			Coal Feed	Limestone/Coal Feed
From	Staging Screens	Crusher Flats	Cyclone Separator	Rejects Total Bin	Classifier Dust Collector			Weight Feeder	Weight Feeder
To	Coal Surge Bin	Cyclone Separator	Screens	Flt. Martin Coal Pile @ 18.00%	Total Bin @ .01 lb/Min			Coal/Limestone Pressure Locks	
On								lb/hr	lb/hr
CO									
H ₂									
CO ₂									
H ₂ O									
CH ₄									
C ₂ H ₆									
H ₂ S									
CO _S									
N ₂		1013							
Ar									
HCl									
H ₂ N									
NH ₃									
CS ₂									
SO ₂									
NO									
O ₂		310							
NaCl									
KCl									
CaSO ₄									
Ca(OH) ₂									
Cl ₂									
Total Gas (lb/hr)		1350							
Volumetric Flow Rates (STP 14.7 psia, 60°F)									
(acfm)		347							
(scfm)		295							
Heat (BTU/hr)									
Op (BTU/hr)	8,341	8,341	0,341	8,341	8,341	8,341	8,341	8,341	8,341
HHV (BTU/hr)	12500	12500	12500	12500	12500	12500	12500	12500	12500
LHV (BTU/hr)	12038	12038	12038	12038	11944	11944	11944	12038	12038
Sensible Heat above 50 F	50	50	50	50	50	50	50	50	50
Latent Heat of Water	482	586	586	586	556	556	556	482	482
Chemical Heat (LHV) MBtu/hr	48.15	78.79	75	18.88	1.55	1.43	1.41	48.15	48.15
Sensible Heat above 50 F MBtu/hr	8.24	8.30	0	8.00	8.01	8.01	8.01	8.24	8.24
Latent Heat of Water MBtu/hr	1.85	2.84	3	8.42	8.07	8.07	8.07	1.85	1.85
Total Heat (MBtu/hr)	50.23	79.93	78	11.30	1.63	1.51	1.49	50.23	50.23
C	2805	3444	3355	820	89.2			2805	2805
H	188	231	225	42	6.0			188	188
O	192	236	230	42	6.1			192	192
N	40	80	59	11	1.8			40	40
S	114	141	137	25	3.6			114	114
CaO		5	5	1	0.1				
H ₂ O	40	151	147	27	3.9	10.9	10.75	40	40
NaCl									
KCl									
CaCO ₃						10.9	10.75		
Ca									
CaS									
ASH, Inerts (pph)	811	753	734	136	19.5	98.2	98.78	811	811
Total Solids (pph)	4000	5021	4891	904	130	120	118	4000	4000
Total Flow (pph)	4000	6371	6241	904	130	120	118	4000	4000
Total Flow (gpm)	1.1	2	1.7	0.3	0.04	0.03	0.033	1.1	1.1
Pressure (psig)	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0
Temperature (F)	150	150	150	150	80	80	80	125	125
								600 lb/hr Min	200 lb/hr Min

DOE - GPF - PyGas™ (Base Case 2 TTP)		Reference Case - RFP Spectrochem - MGA8 Process		Using Thermomax (MGA8 50% Development)		325 psi Operation - Specified Design		10/19/95 14:40	
Stream No.	Stream Name	Stream No.	Stream Name	Stream No.	Stream Name	Stream No.	Stream Name	Stream No.	Stream Name
601	Feed Gas (Btu/hr)	601	Feed Gas (Btu/hr)	601	Feed Gas (Btu/hr)	601	Feed Gas (Btu/hr)	601	Feed Gas (Btu/hr)
602	CO	602	CO	602	CO	602	CO	602	CO
603	H ₂	603	H ₂	603	H ₂	603	H ₂	603	H ₂
604	CO ₂	604	CO ₂	604	CO ₂	604	CO ₂	604	CO ₂
605	H ₂ O	605	H ₂ O	605	H ₂ O	605	H ₂ O	605	H ₂ O
606	CH ₄	606	CH ₄	606	CH ₄	606	CH ₄	606	CH ₄
607	C ₂ H ₆	607	C ₂ H ₆	607	C ₂ H ₆	607	C ₂ H ₆	607	C ₂ H ₆
608	H ₂ S	608	H ₂ S	608	H ₂ S	608	H ₂ S	608	H ₂ S
609	CO ₂ S	609	CO ₂ S	609	CO ₂ S	609	CO ₂ S	609	CO ₂ S
610	N ₂	610	N ₂	610	N ₂	610	N ₂	610	N ₂
611	Ar	611	Ar	611	Ar	611	Ar	611	Ar
612	HCl	612	HCl	612	HCl	612	HCl	612	HCl
613	H ₂ N	613	H ₂ N	613	H ₂ N	613	H ₂ N	613	H ₂ N
614	HCN	614	HCN	614	HCN	614	HCN	614	HCN
615	CH ₃ N	615	CH ₃ N	615	CH ₃ N	615	CH ₃ N	615	CH ₃ N
616	C ₂ H ₅ N	616	C ₂ H ₅ N	616	C ₂ H ₅ N	616	C ₂ H ₅ N	616	C ₂ H ₅ N
617	NO	617	NO	617	NO	617	NO	617	NO
618	SO ₂	618	SO ₂	618	SO ₂	618	SO ₂	618	SO ₂
619	SO ₃	619	SO ₃	619	SO ₃	619	SO ₃	619	SO ₃
620	NaCl	620	NaCl	620	NaCl	620	NaCl	620	NaCl
621	CaSO ₄	621	CaSO ₄	621	CaSO ₄	621	CaSO ₄	621	CaSO ₄
622	CaO	622	CaO	622	CaO	622	CaO	622	CaO
623	Total Gas (Btu/hr)	623	Total Gas (Btu/hr)	623	Total Gas (Btu/hr)	623	Total Gas (Btu/hr)	623	Total Gas (Btu/hr)
624	CO ₂	624	CO ₂	624	CO ₂	624	CO ₂	624	CO ₂
625	CH ₄	625	CH ₄	625	CH ₄	625	CH ₄	625	CH ₄
626	CaSO ₄	626	CaSO ₄	626	CaSO ₄	626	CaSO ₄	626	CaSO ₄
627	NaCl	627	NaCl	627	NaCl	627	NaCl	627	NaCl
628	CaO	628	CaO	628	CaO	628	CaO	628	CaO
629	Total Gas (Btu/hr)	629	Total Gas (Btu/hr)	629	Total Gas (Btu/hr)	629	Total Gas (Btu/hr)	629	Total Gas (Btu/hr)
630	CO ₂	630	CO ₂	630	CO ₂	630	CO ₂	630	CO ₂
631	CH ₄	631	CH ₄	631	CH ₄	631	CH ₄	631	CH ₄
632	CaSO ₄	632	CaSO ₄	632	CaSO ₄	632	CaSO ₄	632	CaSO ₄
633	NaCl	633	NaCl	633	NaCl	633	NaCl	633	NaCl
634	CaO	634	CaO	634	CaO	634	CaO	634	CaO
635	Total Gas (Btu/hr)	635	Total Gas (Btu/hr)	635	Total Gas (Btu/hr)	635	Total Gas (Btu/hr)	635	Total Gas (Btu/hr)
636	CO ₂	636	CO ₂	636	CO ₂	636	CO ₂	636	CO ₂
637	CH ₄	637	CH ₄	637	CH ₄	637	CH ₄	637	CH ₄
638	CaSO ₄	638	CaSO ₄	638	CaSO ₄	638	CaSO ₄	638	CaSO ₄
639	NaCl	639	NaCl	639	NaCl	639	NaCl	639	NaCl
640	CaO	640	CaO	640	CaO	640	CaO	640	CaO
641	Total Gas (Btu/hr)	641	Total Gas (Btu/hr)	641	Total Gas (Btu/hr)	641	Total Gas (Btu/hr)	641	Total Gas (Btu/hr)
642	CO ₂	642	CO ₂	642	CO ₂	642	CO ₂	642	CO ₂
643	CH ₄	643	CH ₄	643	CH ₄	643	CH ₄	643	CH ₄
644	CaSO ₄	644	CaSO ₄	644	CaSO ₄	644	CaSO ₄	644	CaSO ₄
645	NaCl	645	NaCl	645	NaCl	645	NaCl	645	NaCl
646	CaO	646	CaO	646	CaO	646	CaO	646	CaO
647	Total Gas (Btu/hr)	647	Total Gas (Btu/hr)	647	Total Gas (Btu/hr)	647	Total Gas (Btu/hr)	647	Total Gas (Btu/hr)
648	CO ₂	648	CO ₂	648	CO ₂	648	CO ₂	648	CO ₂
649	CH ₄	649	CH ₄	649	CH ₄	649	CH ₄	649	CH ₄
650	CaSO ₄	650	CaSO ₄	650	CaSO ₄	650	CaSO ₄	650	CaSO ₄
651	NaCl	651	NaCl	651	NaCl	651	NaCl	651	NaCl
652	CaO	652	CaO	652	CaO	652	CaO	652	CaO
653	Total Gas (Btu/hr)	653	Total Gas (Btu/hr)	653	Total Gas (Btu/hr)	653	Total Gas (Btu/hr)	653	Total Gas (Btu/hr)
654	CO ₂	654	CO ₂	654	CO ₂	654	CO ₂	654	CO ₂
655	CH ₄	655	CH ₄	655	CH ₄	655	CH ₄	655	CH ₄
656	CaSO ₄	656	CaSO ₄	656	CaSO ₄	656	CaSO ₄	656	CaSO ₄
657	NaCl	657	NaCl	657	NaCl	657	NaCl	657	NaCl
658	CaO	658	CaO	658	CaO	658	CaO	658	CaO
659	Total Gas (Btu/hr)	659	Total Gas (Btu/hr)	659	Total Gas (Btu/hr)	659	Total Gas (Btu/hr)	659	Total Gas (Btu/hr)
660	CO ₂	660	CO ₂	660	CO ₂	660	CO ₂	660	CO ₂
661	CH ₄	661	CH ₄	661	CH ₄	661	CH ₄	661	CH ₄
662	CaSO ₄	662	CaSO ₄	662	CaSO ₄	662	CaSO ₄	662	CaSO ₄
663	NaCl	663	NaCl	663	NaCl	663	NaCl	663	NaCl
664	CaO	664	CaO	664	CaO	664	CaO	664	CaO
665	Total Gas (Btu/hr)	665	Total Gas (Btu/hr)	665	Total Gas (Btu/hr)	665	Total Gas (Btu/hr)	665	Total Gas (Btu/hr)
666	CO ₂	666	CO ₂	666	CO ₂	666	CO ₂	666	CO ₂
667	CH ₄	667	CH ₄	667	CH ₄	667	CH ₄	667	CH ₄
668	CaSO ₄	668	CaSO ₄	668	CaSO ₄	668	CaSO ₄	668	CaSO ₄
669	NaCl	669	NaCl	669	NaCl	669	NaCl	669	NaCl
670	CaO	670	CaO	670	CaO	670	CaO	670	CaO
671	Total Gas (Btu/hr)	671	Total Gas (Btu/hr)	671	Total Gas (Btu/hr)	671	Total Gas (Btu/hr)	671	Total Gas (Btu/hr)
672	CO ₂	672	CO ₂	672	CO ₂	672	CO ₂	672	CO ₂
673	CH ₄	673	CH ₄	673	CH ₄	673	CH ₄	673	CH ₄
674	CaSO ₄	674	CaSO ₄	674	CaSO ₄	674	CaSO ₄	674	CaSO ₄
675	NaCl	675	NaCl	675	NaCl	675	NaCl	675	NaCl
676	CaO	676	CaO	676	CaO	676	CaO	676	CaO
677	Total Gas (Btu/hr)	677	Total Gas (Btu/hr)	677	Total Gas (Btu/hr)	677	Total Gas (Btu/hr)	677	Total Gas (Btu/hr)
678	CO ₂	678	CO ₂	678	CO ₂	678	CO ₂	678	CO ₂
679	CH ₄	679	CH ₄	679	CH ₄	679	CH ₄	679	CH ₄
680	CaSO ₄	680	CaSO ₄	680	CaSO ₄	680	CaSO ₄	680	CaSO ₄
681	NaCl	681	NaCl	681	NaCl	681	NaCl	681	NaCl
682	CaO	682	CaO	682	CaO	682	CaO	682	CaO
683	Total Gas (Btu/hr)	683	Total Gas (Btu/hr)	683	Total Gas (Btu/hr)	683	Total Gas (Btu/hr)	683	Total Gas (Btu/hr)
684	CO ₂	684	CO ₂	684	CO ₂	684	CO ₂	684	CO ₂
685	CH ₄	685	CH ₄	685	CH ₄	685	CH ₄	685	CH ₄
686	CaSO ₄	686	CaSO ₄	686	CaSO ₄	686	CaSO ₄	686	CaSO ₄
687	NaCl	687	NaCl	687	NaCl	687	NaCl	687	NaCl
688	CaO	688	CaO	688	CaO	688	CaO	688	CaO
689	Total Gas (Btu/hr)	689	Total Gas (Btu/hr)	689	Total Gas (Btu/hr)	689	Total Gas (Btu/hr)	689	Total Gas (Btu/hr)
690	CO ₂	690	CO ₂	690	CO ₂	690	CO ₂	690	CO ₂
691	CH ₄	691	CH ₄	691	CH ₄	691	CH ₄	691	CH ₄
692	CaSO ₄	692	CaSO ₄	692	CaSO ₄	692	CaSO ₄	692	CaSO ₄
693	NaCl	693	NaCl	693	NaCl	693	NaCl	693	NaCl
694	CaO	694	CaO	694	CaO	694	CaO	694	CaO
695	Total Gas (Btu/hr)	695	Total Gas (Btu/hr)	695	Total Gas (Btu/hr)	695	Total Gas (Btu/hr)	695	Total Gas (Btu/hr)
696	CO ₂	696	CO ₂	696	CO ₂	696	CO ₂	696	CO ₂
697	CH ₄	697	CH ₄	697	CH ₄	697	CH ₄	697	CH ₄
698	CaSO ₄	698	CaSO ₄	698	CaSO ₄	698	CaSO ₄	698	CaSO ₄
699	NaCl	699	NaCl	699	NaCl	699	NaCl	699	NaCl
700	CaO	700	CaO	700	CaO	700	CaO	700	CaO
701	Total Gas (Btu/hr)	701	Total Gas (Btu/hr)	701	Total Gas (Btu/hr)	701	Total Gas (Btu/hr)	701	Total Gas (Btu/hr)
702	CO ₂	702	CO ₂	702	CO ₂	702	CO ₂	702	CO ₂
703	CH ₄	703	CH ₄	703	CH ₄	703	CH ₄	703	CH ₄
704	CaSO ₄	704	CaSO ₄	704	CaSO ₄	704	CaSO ₄	704	CaSO ₄
705	NaCl	705	NaCl	705	NaCl	705	NaCl	705	NaCl
706	CaO	706	CaO	706	CaO	706	CaO	706	CaO
707	Total Gas (Btu/hr)	707	Total Gas (Btu/hr)	707	Total Gas (Btu/hr)	707	Total Gas (Btu/hr)	707	Total Gas (Btu/hr)
708	CO ₂	708	CO ₂	708	CO ₂	708	CO ₂	708	CO ₂
709	CH ₄	709	CH ₄	709	CH ₄	709	CH ₄	709	CH ₄
710	CaSO ₄	710	CaSO ₄	710	CaSO ₄	710	CaSO ₄	710	CaSO ₄
711	NaCl	711	NaCl	711	NaCl	711	NaCl	711	NaCl
712	CaO	712	CaO	712	CaO	712	CaO	712	CaO
713	Total Gas (Btu/hr)	713	Total Gas (Btu/hr)	713	Total Gas (Btu/hr)	713	Total Gas (Btu/hr)	713	Total Gas (Btu/hr)
714	CO ₂	714	CO ₂	714	CO ₂	714	CO ₂	714	CO ₂
715	CH ₄	715	CH ₄	715	CH ₄	715	CH ₄	715	CH ₄
716	CaSO ₄	716	CaSO ₄	716	CaSO ₄	716	CaSO ₄	716	CaSO ₄
717	NaCl	717	NaCl	717	NaCl	717	NaCl	717	NaCl
718	CaO	718	CaO	718	CaO	718	CaO	718	CaO
719	Total Gas (Btu/hr)	719	Total Gas (Btu/hr)	719	Total Gas (Btu/hr)	719	Total Gas (Btu/hr)	719	Total Gas (Btu/hr)
720	CO ₂	720	CO ₂	720	CO ₂	720	CO ₂	720	CO ₂
721	CH ₄	721	CH ₄	721	CH ₄	721	CH ₄	721	CH ₄
722	CaSO ₄	722	CaSO ₄	722	CaSO ₄	722	CaSO ₄	722	CaSO ₄
723	NaCl	723	NaCl	723	NaCl	723	NaCl	723	NaCl
724	CaO	724	CaO	724	CaO	724	CaO	724	CaO
725	Total Gas (Btu/hr)	725	Total Gas (Btu/hr)	725	Total Gas (Btu/hr)	725	Total Gas (Btu/hr)	725	Total Gas (Btu/hr)
726	CO ₂	726	CO ₂	726	CO ₂	726	CO ₂	726	CO ₂

21 DOE - GPF - PyGas (Base Case 2 TPH)				325 psi Operation - Specified Design				Page 5				10/19/95 14:40			
22 Design Support Documents, Mass Balance				Using Thermoflex (Assume 50% Dehydration)											
Stream No.	Stream Name	Stream No.	Stream Name	Compressed Air @ High Pressure Compressor Under Quarter Top	Gas/Steam/Feed Air/Gas Carbon Steam/Gas Carbon	wt %	wt %	Compressed Air @ High Pressure Compressor At Quarter Top	wt %	wt %	Compressed Air @ High Pressure Compressor At Quarter Top	wt %	wt %	Compressed Air @ High Pressure Compressor At Quarter Top	wt %
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
11	CO	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
12	H ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
13	CO ₂	3	0.01	0.05	0.03	0.03	0.03	0	0.01	0.05	0	0.01	0.05	0	0.03
14	H ₂ O	36	0.18	0.64	1.02	1.02	0.64	0	0.16	0.64	0	0.16	0.64	0	1.02
15	CH ₄	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
16	C ₂ H ₆	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
17	H ₂ S	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
18	CO ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
19	H ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
20	Ar	4281	21.65	73.03	77.28	77.28	21.65	0	21.65	73.03	0	21.65	73.03	0	77.28
21	H ₂	75	0.36	1.31	0.95	0.95	0.36	0	0.36	1.31	0	0.36	1.31	0	0.95
22	H ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
23	H ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
24	CS ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
25	SO ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
26	NO	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
27	CO	1305	8.63	22.98	20.72	20.72	8.63	0	8.63	22.98	0	8.63	22.98	0	20.72
28	H ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
29	H ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
30	CaSO ₄	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
31	Ca(OH) ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
32	C ₂	0	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0	0.00	0.00	0	0.00
33	Total Gas (lb/hr)	5814	28.86	100.00	100.00	100.00	28.86	0	28.86	100.00	0	28.86	100.00	0	100.00
34															
35	Volumetric Flow Rate (BTP 14.7 psia, 60°F)														
36	(cc/min)	90						0			0			221.38	
37	(cc/min)	1282						0			0			2854	
38	Heat (BTU/hr)														
39	CP (BTU/lb F)	6.246						6.246			6.246			6.246	
40	HHV (BTU/lb)	6.8						6.8			6.8			6.8	
41	HHV (BTU/lb)	0						0			0			0	
42	LVV (BTU/lb)	0						0			0			0	
43	Sensible Heat above														
44	50 F Basis stream	64						64			64			64	
45	Latent Heat of														
46	Water Basis stream	0						0			0			0	
47															
48	Chemical Heat														
49	(Btu/lb) Ash	6.09						6.09			6.09			6.09	
50	Sensible Heat	6.48						6.48			6.48			6.48	
51	above 50 F Mixture													1.15	
52	Latent Heat	6.04						6.04			6.04			6.04	
53	of Water Mixture													0.08	
54	Total Heat (Btu/hr)	0.51						0.51			0.51			1.22	
55															
56															
57	C														
58	H														
59	O														
60	N														
61	S														
62	CaO														
63	H ₂ O														
64	H ₂ Cl														
65	KCl														
66	CaSO ₄														
67	Ca														
68	CaS														
69	ASH, Inerts (pph)														
70	Total Solids (pph)														
71	Total Flow (pph)	5814						0			0			13500	
72															
73	Total Flow (pph)	1.58						0.00			0.00			3.75	
74	Pressure (psig)	338						400			400			325	
75	Temperature (F)	400												400	
76															
77															
78															

37

DOE - GPJF - PyGas™ (Base Case 2 TPH)			325 psig Operation - Specified Design										10/19/95 14:40	
Design Support Documents, Mass Balance			Using Thermexcel (Assume 50% Devolatilization)										Page 6	
Stream No.	10	10a	10b	10c	10d	10e	10f	10g	10h	10i	10j	10k	10l	10m
Identification	Feed to Pyrolyzer	Products of Pyrolysis - Gases	Assumed	Pyrolysis - Solids	Assumed Pyrolytic	Gases - Upper Portion of Gasifier	Solids - Upper portion of Gasifier							
From	Coal, Sulfur, Air, Steam	Pyrolyzer Section	N in Coal to H ₂ in Gas	Pyrolyzer Product	Sulfur Capture	Pyrolyzer Section	Pyrolyzer Section							
To	Pyrolyzer Inlet	Upper Area of Gasifier	90.00% Conversion	Upper Area of Gasifier	0%	Fixed Bed	Fixed Bed							
Gas	lb/hr	lb-mole/hr	wt %	lb/hr	wt %	lb/hr	lb-mole/hr	wt %	lb/hr	lb-mole/hr	wt %	lb/hr	wt %	Bed Volume
CO	28.010	0	2342	83.61	23.62	18.22	2609	83.13	26.30	21.41				
H ₂	2.016	0	180	89.29	1.81	20.53	181	79.77	1.62	18.34				
CO ₂	44.010	3	1284	29.18	12.95	6.71	865	19.66	8.72	4.52				
H ₂ O	18.015	711	648	35.86	6.51	8.24	818	45.38	8.24	10.43				
CH ₄	18.042	0	95	8.92	0.98	1.36	95	5.92	0.98	1.36				
C ₂ H ₆	30.069	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
H ₂ S	34.078	0	61	1.79	0.61	0.41	61	1.79	0.61	0.41				
CO ₂	60.070	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
H ₂	28.015	5164	5120	182.77	51.63	42.02	5120	182.77	51.63	42.02				
Ar	59.948	136	136	3.40	1.37	0.78	136	3.40	1.37	0.78				
HCl	36.481	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
HCN	27.028	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
NH ₃	17.030	0	54	3.15	0.54	0.72	54	3.15	0.54	0.72				
CS ₂	76.131	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
SO ₂	64.059	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
NO	30.006	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
O ₂	31.999	1775	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
NaCl	58.487	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
KCl	74.596	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
CaSO ₄	136.142	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
Ca(OH) ₂	74.095	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
Cl ₂	58.079	0	0	0.00	0.00	0.00	0	0.00	0.00	0.00				
Total Gas (lb/hr)	7789		9917	434.97	100.00	100.00	9917	434.97	100.00	100.00				
Volumetric Flow Rate (STP 14.7 psia, 60°F)		85	459	Exit Velocity (ft/sec) = 2.60			459	Actual Density						
(acfm)		1704	2746				2746	0.338 lbm/ft ³						
(acfm) (Gas Constant Used=1545)														
Heat (BTU/hr)														
Cp (BTU/lb-F)	8.394		8.343				8.341				8.341			
H ₂ (BTU/hr)	12500		2466				2436				2436			
LHV (BTU/hr)	11844		2253				2278				2278			
Sensible Heat above														
50 F Sulfur steam														
Latent Heat of														
Water Sulfur steam														
Chemical Heat	47.77		22.34	Pyrolysis Gas LHV	20.19		22.51				20.19			
(LHV) MBtu/hr				155 Btu/lb	1.08		5.16				1.08			
Sensible Heat	6.36		5.19	142 Btu/lb										
above 50 F MBtu/hr														
Latent Heat	6.72		6.61				6.77				6.60			
of Water MBtu/hr														
Total Heat (MBtu/hr)	48.66		28.15				28.43				21.26			
C	2805						1402				1402	68%		
H	188						0				0	0%		
O	192						0				0	0%		
N	49						57				57	3%		
S	114													
CaO	0													
H ₂ O	40													
NaCl	0													
KCl	0													
CaSO ₄	0													
Ca	0													
CaS	0													
ASH, Inerts (pph)	611						611				611	30%		
Total Solids (pph)	4000						2071				2071	100%		
Total Flow (pph)	11786		9917				2071				2071			
Total Flow (ppg)	3.27		2.75				0.58				0.58			
Pressure (psig)	325		325				325				325			
Temperature (F)	125		1585				1585				1585			

DOE - GPF - PyGas™ (Base Case 2 TPH)		325 psi Operation - Specified Design						10/18/95 14:40				
Design Support Document, Mass Balance		Using Thomas Model (Assume 50% Devolatilization)						Page 7				
Stream No.		18a				18f		Uncomb	18g		Grass 3/A 8.48	
8 Identification		Gases Evolved through Gasification				Air & Carbon		% of C	Hot Coal Gas@		Air/Grass Carbon= 4.27	
7 From		Down Through Fixed Char Bed				Gaseous		48.43%	Lower Bed		Steam/Grass Carbon= 1.71	
8 To		Stoichiometric Reaction Point				Above Grass			Exit		H2 in coal H2O Conc. 8.6%	
9 Gas	mol wt	lb/hr	lb-mole/hr	wt %	mol %	lb/hr	wt %		lb/hr	lb-mole/hr	wt %	mol %
11 CO	28.010	2809	93.13	26.30	21.41				2226	79.47	23.97	20.37
12 H2	2.016	161	79.77	1.62	18.34				103	51.25	1.11	13.14
13 CO2	44.010	865	19.66	8.72	4.52				1176	26.72	12.68	8.85
14 H2O	18.015	818	45.38	8.24	10.43				1365	76.86	14.91	19.70
15 CH4	16.042	95	5.92	0.96	1.36				0	0.00	0.00	0.00
16 C2H6	30.068	0	0.00	0.00	0.00				0	0.00	0.00	0.00
17 H2S	34.076	81	1.79	0.81	0.41				81	1.79	0.68	0.48
18 COS	80.070	0	0.00	0.00	0.00				0	0.00	0.00	0.00
19 N2	28.013	5120	182.77	51.63	42.02				4261	152.12	45.89	39.00
20 Ar	39.948	136	3.40	1.37	0.78				75	1.87	0.80	0.48
21 HCl	36.461	0	0.00	0.00	0.00				0	0.00	0.00	0.00
22 HCN	27.026	0	0.00	0.00	0.00				0	0.00	0.00	0.00
23 NH3	17.030	54	3.15	0.54	0.72				0	0.00	0.00	0.00
24 CS2	76.131	0	0.00	0.00	0.00				0	0.00	0.00	0.00
25 SO2	64.059	0	0.00	0.00	0.00				0	0.00	0.00	0.00
26 NO	30.006	0	0.00	0.00	0.00				0	0.00	0.00	0.00
27 O2	31.999	0	0.00	0.00	0.00				0	0.00	0.00	0.00
28 NaCl	58.497	0	0.00	0.00	0.00				0	0.00	0.00	0.00
29 KCl	74.596	0	0.00	0.00	0.00				0	0.00	0.00	0.00
30 CaSO4	136.142	0	0.00	0.00	0.00				0	0.00	0.00	0.00
31 Ca(OH)2	74.095	0	0.00	0.00	0.00				0	0.00	0.00	0.00
32 CaO	56.078	0	0.00	0.00	0.00				0	0.00	0.00	0.00
33 Total Gas (lb/hr)		9917	434.97	100.00	100.00				9266	390.07	100.00	100.00
34												
35 Volumetric Flow Rates (STP 14.7 psia, 50°F)		489							419	0.25 lbs top of fixed bed		
36 (acfm)		2746							2463			
37 (acfm)												
38												
39 Heat (BTU/hr)												
40 Cp (BTU/lb F)		6341				6341			6332			
41 HHV (BTU/lb)		2458				9998			1918.4			
42 LHV (BTU/lb)		2279				9998			1559.2			
43 Sensible Heat above												
44 50 F Blurb steam		515				520			475			
45 Latent Heat of												
46 Water Blurb steam		79				0			136			
47												
48 Chemical Heat		22.73	Low Blurb Gas HHV		18.14				15.41	Low Blurb Gas LHV		
49 (LHV) MBtu/hr						156 Blurbact				135 Blurbact		
50 Sensible Heat		5.16				142 Blurbact	1.03		4.41		106 Blurbact	
51 above 50 F MBtu/hr												
52 Latent Heat		8.77					8.88		1.28			
53 of Water MBtu/hr												
54 Total Heat (MBtu/hr)		28.65					20.17		21.08			
55												
56												
57 C	12.011					1358	69%					
58 H	1.008											
59 O	16.000					23	1%					
60 N	14.007											
61 S	32.060											
62 CaO	56.078											
63 H2O	18.016											
64 NaCl	58.497											
65 KCl	74.596											
66 CaSO4	136.142											
67 Ca	40.080					0	0%					
68 CaS	72.140					0	0%					
69 ASH						593	30%					
70 Total Solids						1974	100%					
71 Total Flow (pph)		10015				1974			9266			
72												
73 Total Flow (pps)		2.78				0.55			2.58			
74 Pressure (psig)		325				325			325			
75 Temperature (F)		1565				1565			1491			
76												

2 DOE - GPF - PyGas™ (Base Case 2 TPH)			325 psi Operation - Specified Design					10/18/95		2
3 Design Support Document, Mass Balance			Using Thermexcel (Assume 50% Devolatilization)					Page 8		3
4	5	6	7					8	9	10
11	12	13	14					15	16	17
18	19	20	21					22	23	24
26	27	28	29					30	31	32
34	35	36	37					38	39	40
42	43	44	45					46	47	48
50	51	52	53					54	55	56
58	59	60	61					62	63	64
66	67	68	69					70	71	72
74	75	76	77					78	79	80
82	83	84	85					86	87	88
90	91	92	93					94	95	96
98	99	100	101					102	103	104
106	107	108	109					110	111	112
114	115	116	117					118	119	120
122	123	124	125					126	127	128
130	131	132	133					134	135	136
138	139	140	141					142	143	144
146	147	148	149					150	151	152
154	155	156	157					158	159	160
162	163	164	165					166	167	168
170	171	172	173					174	175	176
178	179	180	181					182	183	184
186	187	188	189					190	191	192
194	195	196	197					198	199	200
202	203	204	205					206	207	208
210	211	212	213					214	215	216
218	219	220	221					222	223	224
226	227	228	229					230	231	232
234	235	236	237					238	239	240
242	243	244	245					246	247	248
250	251	252	253					254	255	256
258	259	260	261					262	263	264
266	267	268	269					270	271	272
274	275	276	277					278	279	280
282	283	284	285					286	287	288
290	291	292	293					294	295	296
298	299	300	301					302	303	304
306	307	308	309					310	311	312
314	315	316	317					318	319	320
322	323	324	325					326	327	328
330	331	332	333					334	335	336
338	339	340	341					342	343	344
346	347	348	349					350	351	352
354	355	356	357					358	359	360
362	363	364	365					366	367	368
370	371	372	373					374	375	376
378	379	380	381					382	383	384
386	387	388	389					390	391	392
394	395	396	397					398	399	400
402	403	404	405					406	407	408
410	411	412	413					414	415	416
418	419	420	421					422	423	424
426	427	428	429					430	431	432
434	435	436	437					438	439	440
442	443	444	445					446	447	448
450	451	452	453					454	455	456
458	459	460	461					462	463	464
466	467	468	469					470	471	472
474	475	476	477					478	479	480
482	483	484	485					486	487	488
490	491	492	493					494	495	496
498	499	500	497					498	499	500
502	503	504	505					506	507	508
510	511	512	509					510	511	512
514	515	516	511					512	513	514
518	519	520	515					516	517	518
522	523	524	519					520	521	522
526	527	528	523					524	525	526
530	531	532	527					528	529	530
534	535	536	531					532	533	534
538	539	540	535					536	537	538
542	543	544	539					540	541	542
546	547	548	543					544	545	546
550	551	552	547					548	549	550
554	555	556	551					552	553	554
558	559	560	555					556	557	558
562	563	564	559					560	561	562
566	567	568	563					564	565	566
570	571	572	567					568	569	570
574	575	576	571					572	573	574
578	579	580	575					576	577	578
582	583	584	579					580	581	582
586	587	588	583					584	585	586
590	591	592	587					588	589	590
594	595	596	591					592	593	594
598	599	600	595					596	597	598
602	603	604	599					600	601	602
606	607	608	603					604	605	606
610	611	612	607					608	609	610
614	615	616	611					612	613	614
618	619	620	615					616	617	618
622	623	624	619					620	621	622
626	627	628	623					624	625	626
630	631	632	627					628	629	630
634	635	636	631					632	633	634
638	639	640	635					636	637	638
642	643	644	639					640	641	642
646	647	648	643					644	645	646
650	651	652	647					648	649	650
654	655	656	651					652	653	654
658	659	660	655					656	657	658
662	663	664	659					660	661	662
666	667	668	663					664	665	666
670	671	672	667					668	669	670
674	675	676	671					672	673	674
678	679	680	675					676	677	678
682	683	684	679					680	681	682
686	687	688	683					684	685	686

[illegible]

DOE - QP - CRSS Coal Gasification Process	Using Thermocouple (Assume 50% Conversion)	325 psi Operation - Specified Design	10/19/85 14:40
Stream No.	15a	15b	15c
From	Service Water	Service Water	Service Water
Gas	Hot Water	Hot Water	Hot Water
CO	28.01	28.01	28.01
H2	2.016	2.016	2.016
CO2	44.01	44.01	44.01
H2O	18.015	18.015	18.015
CH4	18.042	18.042	18.042
C2H6	30.068	30.068	30.068
H2S	34.078	34.078	34.078
COB	60.07	60.07	60.07
N2	28.013	28.013	28.013
Ar	38.948	38.948	38.948
HCl	38.441	38.441	38.441
HCN	27.028	27.028	27.028
NH3	17.03	17.03	17.03
C5H2	78.131	78.131	78.131
SO2	64.058	64.058	64.058
NO	30.008	30.008	30.008
O2	31.998	31.998	31.998
HCl	64.487	64.487	64.487
CASO4	74.596	74.596	74.596
CaOH2	134.148	134.148	134.148
C12	74.09474	74.09474	74.09474
Total Gas (lb/hr)	38.5	38.5	38.5
Valuometric Flow Rate (BTP 14.7 psia, 32°F)			
(acfm)			
(acfm)			
Heat (BTU/hr)			
CP (BTU/hr)			
HTV (BTU/hr)			
LTW (BTU/hr)			
Sensible Heat above			
50 F Basis above			
Latent Heat of			
Water Basis above			
Chromic Heat			
RTV Heat			
Sensible Heat			
Latent Heat			
Water Basis			
Total Heat (MBtu/hr)			
C	12.0105	12.0105	12.0105
H	1.008	1.008	1.008
O	15.9995	15.9995	15.9995
N	14.0065	14.0065	14.0065
S	32.06	32.06	32.06
CaOH2	74.096	74.096	74.096
H2O	18.0155	18.0155	18.0155
HCl	64.487	64.487	64.487
KCl	74.596	74.596	74.596
CASO4	134.148	134.148	134.148
Ca	40.08	40.08	40.08
CAS	72.14	72.14	72.14
ASH, knots (gph)			
Total Solids (gph)	35	35	35
Total Flow (gph)	35	35	35
Pressure (psig)	0	0	0
Temperature (°F)	80	80	80
CO	28.01	28.01	28.01
H2	2.016	2.016	2.016
CO2	44.01	44.01	44.01
H2O	18.015	18.015	18.015
CH4	18.042	18.042	18.042
C2H6	30.068	30.068	30.068
H2S	34.078	34.078	34.078
COB	60.07	60.07	60.07
N2	28.013	28.013	28.013
Ar	38.948	38.948	38.948
HCl	38.441	38.441	38.441
HCN	27.028	27.028	27.028
NH3	17.03	17.03	17.03
C5H2	78.131	78.131	78.131
SO2	64.058	64.058	64.058
NO	30.008	30.008	30.008
O2	31.998	31.998	31.998
HCl	64.487	64.487	64.487
CASO4	74.596	74.596	74.596
CaOH2	134.148	134.148	134.148
C12	74.09474	74.09474	74.09474
Total Gas (lb/hr)	38.5	38.5	38.5
Valuometric Flow Rate (BTP 14.7 psia, 32°F)			
(acfm)			
(acfm)			
Heat (BTU/hr)			
CP (BTU/hr)			
HTV (BTU/hr)			
LTW (BTU/hr)			
Sensible Heat above			
50 F Basis above			
Latent Heat of			
Water Basis above			
Chromic Heat			
RTV Heat			
Sensible Heat			
Latent Heat			
Water Basis			
Total Heat (MBtu/hr)			
C	12.0105	12.0105	12.0105
H	1.008	1.008	1.008
O	15.9995	15.9995	15.9995
N	14.0065	14.0065	14.0065
S	32.06	32.06	32.06
CaOH2	74.096	74.096	74.096
H2O	18.0155	18.0155	18.0155
HCl	64.487	64.487	64.487
KCl	74.596	74.596	74.596
CASO4	134.148	134.148	134.148
Ca	40.08	40.08	40.08
CAS	72.14	72.14	72.14
ASH, knots (gph)			
Total Solids (gph)	35	35	35
Total Flow (gph)	35	35	35
Pressure (psig)	0	0	0
Temperature (°F)	80	80	80
CO	28.01	28.01	28.01
H2	2.016	2.016	2.016
CO2	44.01	44.01	44.01
H2O	18.015	18.015	18.015
CH4	18.042	18.042	18.042
C2H6	30.068	30.068	30.068
H2S	34.078	34.078	34.078
COB	60.07	60.07	60.07
N2	28.013	28.013	28.013
Ar	38.948	38.948	38.948
HCl	38.441	38.441	38.441
HCN	27.028	27.028	27.028
NH3	17.03	17.03	17.03
C5H2	78.131	78.131	78.131
SO2	64.058	64.058	64.058
NO	30.008	30.008	30.008
O2	31.998	31.998	31.998
HCl	64.487	64.487	64.487
CASO4	74.596	74.596	74.596
CaOH2	134.148	134.148	134.148
C12	74.09474	74.09474	74.09474
Total Gas (lb/hr)	38.5	38.5	38.5
Valuometric Flow Rate (BTP 14.7 psia, 32°F)			
(acfm)			
(acfm)			
Heat (BTU/hr)			
CP (BTU/hr)			
HTV (BTU/hr)			
LTW (BTU/hr)			
Sensible Heat above			
50 F Basis above			
Latent Heat of			
Water Basis above			
Chromic Heat			
RTV Heat			
Sensible Heat			
Latent Heat			
Water Basis			
Total Heat (MBtu/hr)			
C	12.0105	12.0105	12.0105
H	1.008	1.008	1.008
O	15.9995	15.9995	15.9995
N	14.0065	14.0065	14.0065
S	32.06	32.06	32.06
CaOH2	74.096	74.096	74.096
H2O	18.0155	18.0155	18.0155
HCl	64.487	64.487	64.487
KCl	74.596	74.596	74.596
CASO4	134.148	134.148	134.148
Ca	40.08	40.08	40.08
CAS	72.14	72.14	72.14
ASH, knots (gph)			
Total Solids (gph)	35	35	35
Total Flow (gph)	35	35	35
Pressure (psig)	0	0	0
Temperature (°F)	80	80	80
CO	28.01	28.01	28.01
H2	2.016	2.016	2.016
CO2	44.01	44.01	44.01
H2O	18.015	18.015	18.015
CH4	18.042	18.042	18.042
C2H6	30.068	30.068	30.068
H2S	34.078	34.078	34.078
COB	60.07	60.07	60.07
N2	28.013	28.013	28.013
Ar	38.948	38.948	38.948
HCl	38.441	38.441	38.441
HCN	27.028	27.028	27.028
NH3	17.03	17.03	17.03
C5H2	78.131	78.131	78.131
SO2	64.058	64.058	64.058
NO	30.008	30.008	30.008
O2	31.998	31.998	31.998
HCl	64.487	64.487	64.487
CASO4	74.596	74.596	74.596
CaOH2	134.148	134.148	134.148
C12	74.09474	74.09474	74.09474
Total Gas (lb/hr)	38.5	38.5	38.5
Valuometric Flow Rate (BTP 14.7 psia, 32°F)			
(acfm)			
(acfm)			
Heat (BTU/hr)			
CP (BTU/hr)			
HTV (BTU/hr)			
LTW (BTU/hr)			
Sensible Heat above			
50 F Basis above			
Latent Heat of			
Water Basis above			
Chromic Heat			
RTV Heat			
Sensible Heat			
Latent Heat			
Water Basis			
Total Heat (MBtu/hr)			
C	12.0105	12.0105	12.0105
H	1.008	1.008	1.008
O	15.9995	15.9995	15.9995
N	14.0065	14.0065	14.0065
S	32.06	32.06	32.06
CaOH2	74.096	74.096	74.096
H2O	18.0155	18.0155	18.0155
HCl	64.487	64.487	64.487
KCl	74.596	74.596	74.596
CASO4	134.148	134.148	134.148
Ca	40.08	40.08	40.08
CAS	72.14	72.14	72.14
ASH, knots (gph)			
Total Solids (gph)	35	35	35
Total Flow (gph)	35	35	35
Pressure (psig)	0	0	0
Temperature (°F)	80	80	80
CO	28.01	28.01	28.01
H2	2.016	2.016	2.016
CO2	44.01	44.01	44.01
H2O	18.015	18.015	18.015
CH4	18.042	18.042	18.042
C2H6	30.068	30.068	30.068
H2S	34.078	34.078	34.078
COB	60.07	60.07	60.07
N2	28.013	28.013	28.013
Ar	38.948	38.948	38.948
HCl	38.441	38.441	38.441
HCN	27.028	27.028	27.028
NH3	17.03	17.03	17.03
C5H2	78.131	78.131	78.131
SO2	64.058	64.058	64.058
NO	30.008	30.008	30.008
O2	31.998	31.998	31.998
HCl	64.487	64.487	64.487
CASO4	74.596	74.596	74.596
CaOH2	134.148	134.148	134.148
C12	74.09474	74.09474	74.09474
Total Gas (lb/hr)	38.5	38.5	38.5
Valuometric Flow Rate (BTP 14.7 psia, 32°F)			
(acfm)			
(acfm)			
Heat (BTU/hr)			
CP (BTU/hr)			
HTV (BTU/hr)			
LTW (BTU/hr)			
Sensible Heat above			
50 F Basis above			
Latent Heat of			
Water Basis above			
Chromic Heat			
RTV Heat			
Sensible Heat			
Latent Heat			
Water Basis			
Total Heat (MBtu/hr)			
C	12.0105	12.0105	12.0105
H	1.008	1.008	1.008
O	15.9995	15.9995	15.9995
N	14.0065	14.0065	14.0065
S	32.06	32.06	32.06
CaOH2	74.096	74.096	74.096
H2O	18.0155	18.0155	18.0155
HCl	64.487	64.487	64.487
KCl	74.596	74.596	74.596
CASO4	134.148	134.148	134.148
Ca	40.08	40.08	40.08
CAS	72.14	72.14	72.14
ASH, knots (gph)			
Total Solids (gph)	35	35	35
Total Flow (gph)	35	35	35
Pressure (psig)	0	0	0
Temperature (°F)	80	80	80
CO	28.01	28.01	28.01
H2	2.016	2.016	2.016
CO2	44.01	44.01	44.01
H2O	18.015	18.015	18.015
CH4	18.042	18.042	18.042
C2H6	30.068	30.068	30.068
H2S	34.078	34.078	34.078
COB	60.07	60.07	60.07
N2	28.013	28.013	28.013
Ar	38.948	38.948	38.948
HCl	38.441	38.441	38.441
HCN	27.028	27.028	27.028
NH3	17.03	17.03	17.03
C5H2	78.131	78.131	78.131
SO2	64.058	64.058	64.058
NO	30.008	30.008	30.008
O2	31.998	31.998	31.998
HCl	64.487	64.487	64.487
CASO4	74.596	74.596	74.596
CaOH2	134.148	134.148	134.148
C12	74.09474	74.09474	74.09474
Total Gas (lb/hr)	38.5	38.5	38.5
Valuometric Flow Rate (BTP 14.7 psia, 32°F)			
(acfm)			
(acfm)			
Heat (BTU/hr)			
CP (BTU/hr)			
HTV (BTU/hr)			
LTW (BTU/hr)</			

DOE - GPIF - PyGas™ (Base Case 2 TPH)		325 psi Operation - Specified Design										10/18/95 14:40									
Using Thermexcel (Assume 50% Devolatilization)		Page 11										Design Support Document, Mass Balance									
Stream No. Identification From To Gas	Net Wt	19a Excess Steam Waste Heat Boiler Vent lb/hr	19 Total Steam Gen. Waste Heat Boiler Process & Vents lb/hr	20 Feedwater Deaerator OPF FW Pump lb/hr	20a Make-up Water Service Water Chem. Treatment Tank lb/hr	20b Make-up OPF Feedwater Pump Cooler Jacket lb/hr	21 Flue Gas (Phase 1) Waste Heat Boiler Caustic Scrubber lb/hr lb-mole/hr wt % mol %				29 Emergency Flare Gasifier Atmosphere lb/hr	Criteria Pollutants Fl. Margin Station Stack (Normal) lb/hr			Criteria Pollutants Fl. Margin Station Stack (OPF Operating) lb/hr			Criteria Pollutants Fl. Margin Station Change Due To OPF %			
CO	28.010	1319	4318				7	0.2	0.01	0.01	4835	SO ₂ NO _x Particulates	24,860 5,443 471	24,840 5,442 465	-0.08% -0.0002% -1.28%						
H ₂	2.016										264										
CO ₂	44.010										2041										
H ₂ O	18.015								10502	238.6	15.0	9.5	2202	SO ₂ NO _x Particulates	Coal Gasified HRSG to Exhaust ESP	4.8 lb/MM Btu 0.40 lb/MM Btu 0.2 lb/MM Btu					
CH ₄	18.042								8903	494.2	12.69	19.75	95								
C ₂ H ₆	30.068									0.0	0.00	0.00	122								
H ₂ S	34.078									0.0	0.00	0.00									
COS	60.070									0.0	0.00	0.00									
N ₂	28.013									0.0	0.00	0.00									
Ar	39.948								43661	1558.6	62.25	62.29	9381	Criteria Pollutants Fl. Margin Station Stack (Normal) lb/hr	Criteria Pollutants Fl. Margin Station Stack (OPF Operating) lb/hr	Criteria Pollutants Fl. Margin Station Change Due To OPF %					
HCl	36.481								1112	27.8	1.59	1.11	210								
HCN	27.026									0.0	0.00	0.00	54								
NH ₃	17.030									0.0	0.00	0.00									
CS ₂	78.131									0.0	0.00	0.00									
SO ₂	64.059									0.0	0.00	0.00		SO ₂ NO _x Particulates	24,976 9,366 473	24,735 9,366 468	-0.96% -0.0002% -1.28%				
NO	30.008						229	3.8	0.33	0.14	25										
O ₂	31.999						13	0.4	0.02	0.02	26										
NaCl	58.497						5715	178.6	8.15	7.14											
KCl	74.598							0.0	0.00	0.00											
CaSO ₄	136.142							0.0	0.00	0.00											
Ca(OH) ₂	74.095							0.0	0.00	0.00											
Cl ₂	35.500							0.0	0.00	0.00											
Total Gas (lb/hr)		1319	4318				70134	2502	100	100	1920										
Volumetric Flow Rates (STP 14.7 psia, 50°F)		8.31					73118				676										
(acfm)			77				17117				5209										
(scfm)			1121																		
Heat (BTU/hr)		1279	1062		196		196														
Q _p (BTU/hr F)		Total Heat In Steam	Heat Added to FW				8.341				0.33										
H ₂ O (BTU/hr)							6.4				3188										
U _H (BTU/hr)							6.4				3038										
Sensible Heat above							41.50				0.0										
50 F Shell steam																					
Latent Heat of																					
Water Shell steam							41.50				0.00										
Chemical Heat							8.03				36										
(U _H) MBtu/hr																					
Sensible Heat							6.4				6										
above 50 F MBtu/hr																					
Latent Heat							8.02				2										
of Water MBtu/hr																					
Total Heat (MBtu/hr)		2	5		1		0.4	50.64			46										
Total Heat In Steam			Heat Added to FW																		
C	12.011				Column 19a Plus 1% For Blowdown	Column 20a 95% Of Col. 20 & 20b					4.9										
H	1.008																				
O	16.000																				
N	14.007																				
S	32.060																				
CaO	56.079																				
H ₂ O	18.018																				
NaCl	58.497				4361					2000											
KCl	74.598																				
CaSO ₄	136.142																				
Ca	40.080																				
CaS	72.140																				
ASH, Inerts (pph)											2.1										
Total Solids (pph)											6.9										
Total Flow (pph)		1319	4318		4361					2000	7										
							70141				1927										
Total Flow (pps)		0	1		1		1	19			5										
Pressure (psig)		415	415		5		200	348		0	345										
Temperature (F)		850	850		227		170	170		1800	1023										

Mass & Energy Balance		DOE - GPIF - CRSS Coal Gasification Process				325 psi Operation - Specified Design		10/19/95 14:40	
Estimated Trace Metals Emissions for NEPA Report		Typical Expected Case				Page 12			
From	To	Trace Elements Normal Ft. Martin Ash Ft. Martin Ash Landfill lb/yr	Trace Elements Normal Ft. Martin Flue Gas Ft. Martin Stack lb/yr	Trace Elements GPIF Ash Ft. Martin Ash Landfill lb/yr	Trace Elements GPIF Flue Gas Ft. Martin Stack lb/yr	Trace Elements Combined Ash Ft. Martin Ash Landfill lb/yr	Trace Elements Combined Flue Gas Ft. Martin Stack lb/yr	Trace Elements Change Due To GPIF Ft. Martin Ash Landfill %	Trace Elements Change Due To GPIF Ft. Martin Stack %
NOTE: THE VALUES ON THIS PAGE HAVE BEEN CARRIED OUT TO SUFFICIENT SIGNIFICANT FIGURES TO ARITHMETICALLY COMPUTE. THEY ARE NOT REFLECTIVE OF EXACTING MEASUREMENTS, BUT DO REPRESENT "TYPICAL" VALUES BASED ON RELEVANT PUBLICATIONS IN THE LITERATURE.									
Antimony		0.7421	0.0042	0.0087	0.000014	0.73645	0.00413	-0.761	-0.600
Arsenic		14.6723	0.2557	0.0967	0.000407	14.46589	0.25117	-1.270	-0.668
Barium		105.3615	0.3785	0.6800	0.00017	104.00876	0.37137	-1.284	-0.712
Beryllium		1.362	0.0064	0.0090	0.000004	1.34472	0.00628	-1.269	-0.705
Boron		27.2296	3.0518	0.2073	0.00272	26.91159	2.99564	-1.168	-0.695
Cadmium		0.2905	0.0019	0.0021	0.0000027	0.28697	0.00187	-1.218	-0.875
Chromium		9.2404	0.0896	0.0603	0.000068	9.12246	0.08794	-1.276	-0.070
Cobalt		3.7805	0.0136	0.0247	0.000007	3.73223	0.01334	-1.277	-0.071
Copper		9.894	0.0581	0.0643	0.000038	9.77545	0.05702	-1.198	-0.704
Lead		6.759	0.0830	0.0447	0.000079	6.67327	0.08148	-1.268	-0.693
Manganese		26.625	0.1210	0.1843	0.000059	26.29566	0.11872	-1.237	-0.710
Mercury		0.0125	0.1863	0.0004	0.000300	0.01263	0.18301	1.004	-0.668
Molybdenum		2.0337	0.0190	0.0150	0.000012	2.00946	0.01865	-1.192	-0.704
Nickel		8.6515	0.0565	0.0560	0.000043	8.54059	0.05545	-1.282	-0.700
Selenium		1.5642	0.3472	0.0112	0.000260	1.54649	0.34076	-1.132	-0.700
Vanadium		13.5963	0.0877	0.0910	0.000055	13.42499	0.08606	-1.260	-0.705
Uranium		1.3015	0.0047	0.0091	0.0000017	1.28549	0.00461	-1.230	-0.711
Thorium		1.9533	0.0071	0.0130	0.000003	1.95804	0.00697	-1.271	-0.711
TOTAL TRACE METALS		235.10	4.77	1.58	0.004	232.15	4.68	-1.086	-0.678
Normal Criteria Particulates (Ash, Limestone, Carbon Loss)		92729	331	697	0.446	92560	325		
TOTALS (Particulates & Trace Metals)		92964	336	800	0.45	92792.48	329.97	-1.00	-0.678
Estimated Trace Metals Emissions for NEPA Report		Worst Expected Case							
From	To	Trace Elements Normal Ft. Martin Ash Ft. Martin Ash Landfill lb/yr	Trace Elements Normal Ft. Martin Flue Gas Ft. Martin Stack lb/yr	Trace Elements GPIF Ash Ft. Martin Ash Landfill lb/yr	Trace Elements GPIF Flue Gas Ft. Martin Stack lb/yr	Trace Elements Combined Ash Ft. Martin Ash Landfill lb/yr	Trace Elements Combined Flue Gas Ft. Martin Stack lb/yr	Trace Elements Change Due To GPIF Ft. Martin Ash Landfill %	Trace Elements Change Due To GPIF Ft. Martin Stack %
Antimony		0.7421	0.0042	0.0087	0.000014	0.73651	0.00415	-0.34	-0.45
Arsenic		14.6723	0.2557	0.0967	0.000407	14.54251	0.25216	-0.88	-0.52
Barium		105.3615	0.3785	0.6800	0.000170	104.41530	0.37283	-0.90	-0.57
Beryllium		1.3620	0.0064	0.0090	0.000004	1.34988	0.00631	-0.84	-0.54
Boron		27.2296	3.0518	0.2073	0.002717	27.01666	3.00741	-0.76	-0.55
Cadmium		0.2905	0.0019	0.0021	0.0000027	0.28600	0.00187	-0.83	-0.53
Chromium		9.2404	0.0896	0.0603	0.000068	9.15811	0.08829	-0.89	-0.55
Cobalt		3.7805	0.0136	0.0247	0.000007	3.74682	0.01340	-0.89	-0.56
Copper		9.8940	0.0581	0.0643	0.000038	9.80562	0.05724	-0.89	-0.56
Lead		6.7590	0.0830	0.0447	0.000079	6.69935	0.08180	-0.89	-0.55
Manganese		26.6250	0.1210	0.1843	0.000059	26.39839	0.11919	-0.85	-0.56
Mercury		0.0125	0.1863	0.0004	0.000300	0.01267	0.18372	1.30	-0.52
Molybdenum		2.0337	0.0190	0.0150	0.000012	2.01731	0.01872	-0.81	-0.56
Nickel		8.6515	0.0565	0.0560	0.000043	8.57397	0.05567	-0.90	-0.55
Selenium		1.5642	0.3472	0.0112	0.000260	1.55122	0.34210	-0.83	-0.55
Vanadium		13.5963	0.0877	0.0910	0.000055	13.47745	0.08640	-0.87	-0.56
Uranium		1.3015	0.0047	0.0091	0.0000017	1.29051	0.00463	-0.84	-0.57
Thorium		1.9533	0.0071	0.0130	0.000003	1.95562	0.00699	-0.89	-0.57
TOTAL TRACE METALS		235.10	4.77	1.58	0.004	233.05	4.70	1.23	-0.53
Normal Criteria Particulates (Ash, Limestone, Carbon Loss)		92729	331	697	0.446	93870	327		
TOTALS (Particulates & Trace Metals)		92964	336	800	0.45	94193.19	331.79	-0.71	-0.53

10/18/95 14:40

45

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 1
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: AA
DESCRIPTION: GASIFER PROCESS

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1AA-COND-1	ASH DUSTLESS UNLOADER		By Contractor				95 06	28
1AA-CONV-1	BOTTOM ASH COOLING CONVEYOR		By Contractor				95 02	7
1AA-CONV-2	FINES COOLING CONVEYOR		By Contractor				95 06	28
1AA-CYCL-1	NO.1 GAS CYCLONE		By Contractor				94 12	18
1AA-DCOL-1	ASH SILO DUST COLLECTOR		By Contractor				95 08	4
1AA-ELEV-1	ASH BUCKET ELEVATOR		By Contractor				95 06	28
1AA-FDR-1	CYCLONE FINES WEIGH BELT FEEDER		By Contractor				95 06	28
1AA-FDR-2	BOTTOM ASH WEIGH BELT FEEDER		By Contractor				95 06	28

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: AA
DESCRIPTION: GASIFIER PROCESS

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 2
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1AA-HPR-1	BOTTOM ASH LOCK HOPPER		By Contractor				94 12 15	
1AA-HPR-2	BOTTOM ASH COOLING CONVEYOR FEED HOPPER		By Contractor				94 12 15	
1AA-HPR-3	CYCLONE FINES SURGE HOPPER		By Contractor				94 10 16	
1AA-HPR-4	CYCLONE FINES LOCK HOPPER		By Contractor				94 10 16	
1AA-HPR-5	FINES COOLING CONVEYOR FEED HOPPER		By Contractor				94 12 7	
1AA-HX-1	GASIFIER CONDENSING HEAT EXCHANGER		By Contractor				95 06 28	
1AA-MO-1	GASIFIER COOLING WATER PUMP NO.1 MOTOR		By Contractor	6.00 HP 1800 RPM M			94 12 6	
1AA-MO-2	GASIFIER COOLING WATER PUMP NO.2 MOTOR		By Contractor	6.00 HP 1800 RPM M			94 12 6	

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: AA
DESCRIPTION: GASIFER PROCESS

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 3
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
							REV	
1AA-MO-3	MOTOR, BOTTOM ASH COOLING CONVEYOR		By Contractor	M			95 07 17	
1AA-MO-4	FINES COOLING CONVEYOR MOTOR		By Contractor	M			95 07 17	
1AA-MO-5	CYCLONE FINES WEIGHBELT FEEDER MOTOR		By Contractor	M				
1AA-MO-6	BOTTOM ASH WEIGHBELT FEEDER MOTOR		By Contractor	5.00 HP 1800 RPM M			94 12 6	
1AA-MO-7	GRATE DRIVE NO.1 MOTOR		By Contractor	6.00 HP 1800 RPM M			94 12 6	
1AA-MO-8	GRATE DRIVE NO.2 MOTOR		By Contractor	6.00 HP 1800 RPM M			94 12 6	
1AA-MO-9	ASH BUCKET ELEVATOR MOTOR		By Contractor	M			95 02 6	
1AA-MO-10	FINE SAMPLER MOTOR		By Contractor	M			95 06 28	

87

Jacobs-Sirrinc Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: AA
DESCRIPTION: GASIFER PROCESS

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 4
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OF SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
							REV	
1AA-MO-11	BOTTOM ASH SAMPLER MOTOR		By Contractor	M			95 06 28	
1AA-MO-12	MOTOR, ASH SILO DUST COLLECTOR		By Contractor	M			95 08 4	
1AA-MO-13	ASH DUSTLESS UNLOADER MOTOR		By Contractor	M				
1AA-P-1	GASIFIER COOLING WATER PUMP NO.1		By Contractor	M			94 10 16	
1AA-P-2	GASIFIER COOLING WATER PUMP NO.2		By Contractor	M			94 10 16	
1AA-RFV-1	PyGas REACTOR		By Contractor				94 10 16	
1AA-SD-1	GASIFER JACKET STEAM DRUM		By Contractor				94 12 18	
1AA-SILO-1	ASH SILO		By Contractor				95 06 28	

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: AA
DESCRIPTION: GASIFER PROCESS

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 5
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1AA-SMX-1	FINES SAMPLER		By Contractor				95 06 28	
1AA-SMX-2	BOTTOM ASH SAMPLER		By Contractor				95 06 28	
1AA-STK-1	RUPTURE DISK STACK		By Contractor				95 06 28	

50

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 6
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: DG
DESCRIPTION: FUEL GAS SUPPLY SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DG-STR-1	NATURAL GAS STRAINER NO.1		By Contractor				95 08	4
1DG-STR-2	NATURAL GAS STRAINER NO.2		By Contractor				95 08	4

51

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 7
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: DH
DESCRIPTION: COAL RECEIVING, STORAGE AND RECLAIM SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1DH-CHT-1	DISCHARGE CHUTE		By Contractor					
1DH-CHT-2	DISCHARGE CHUTE		By Contractor					
1DH-CHT-3	DISCHARGE CHUTE		By Contractor					
1DH-CHT-4	DISCHARGE CHUTE		By Contractor				94 06 17	
1DH-CHT-5	DISCHARGE CHUTE		By Contractor					
1DH-CHT-6	COAL BY-PASS CHUTE		By Contractor					
1DH-CHT-7	DISCHARGE CHUTE		By Contractor				95 02 7	
1DH-CONV-1	COAL SCREW CONVEYOR		By Contractor				94 09 29	

M

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 8
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: DH
DESCRIPTION: COAL RECEIVING, STORAGE AND RECLAIM SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DH-CONV-2	COAL BIN DISCHARGER		By Contractor					94 06 20
				M				
1DH-DCOL-1	COAL STORAGE BIN DUST COLLECTOR		By Contractor					
1DH-DVTV-1	COAL BY-PASS DIVERter VALVE		By Contractor					
1DH-ELEV-1	COAL BUCKET ELEVATOR		By Contractor					
53 1DH-FAN-1	COAL STORAGE BIN DUST COLLECTOR FAN		By Contractor					
				M				
1DH-FDR-1	COAL SCREW FEEDER		By Contractor					
				M				
1DH-FDR-2	COAL SCREW FEEDER		By Contractor					
				M				
1DH-HPR-1	COAL CHARGE HOPPER		By Contractor					94 07 5

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: DH

DESCRIPTION: COAL RECEIVING, STORAGE AND RECLAIM SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 9
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OF SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DH-MO-1	MOTOR, COAL SCREW FEEDER		By Contractor	15.00 HP 1800 RPM M			94 12	6
1DH-MO-2	MOTOR, COAL BUCKET ELEVATOR		By Contractor	7.50 HP 1800 RPM M			94 12	6
1DH-MO-3	MOTOR, COAL SCREW CONVEYOR		By Contractor	3.00 HP 1800 RPM M			94 12	6
54 1DH-MO-4	MOTOR, COAL STORAGE BIN DISCHARGER		By Contractor	2.00 HP 1800 RPM M			94 12	6
1DH-MO-5	MOTOR, COAL STORAGE BIN DUST COLLECTOR FAN		By Contractor	7.50 HP 1800 RPM M			94 12	6
1DH-MO-6	MOTOR, COAL SCREW FEEDER		By Contractor	3.00 HP 1800 RPM M			94 12	6
1DH-PSX-1	COAL STORAGE BIN AIR CANNONS		By Contractor				94 12	18
1DH-TARP-1	COAL STORAGE PILE TARPAULIN		By Contractor					

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 10
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: DH
DESCRIPTION: COAL RECEIVING, STORAGE AND RECLAIM SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1DH-TARP-2	COKE STORAGE PILE TARPAULIN		By Contractor					95 02 14
1DH-TK-1	COAL STORAGE BIN		By Contractor					

55

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: DJ

DESCRIPTION: COAL PREPARATION AND LIMESTONE SYSTEM

EQUIPMENT LIST
FOR

Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 11

REV.: 3

DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DJ-AL-1	ROTARY VALVE CRUSHED COAL NO.1		By Contractor					
1DJ-AL-2	ROTARY VALVE CRUSHED COAL NO.2		By Contractor					
1DJ-AL-3	COAL PREP. ROTARY VALVE		By Contractor					
1DJ-BLO-1	BLOWER, CRUSHED COAL TRANSFER		By Contractor					
56 1DJ-CHT-1	DISCHARGE CHUTE		By Contractor		M			
1DJ-CHT-2	DISCHARGE CHUTE		By Contractor					
1DJ-CHT-3	DISCHARGE CHUTE		By Contractor					
1DJ-CHT-4	FINES CHUTE		By Contractor					

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: DJ

DESCRIPTION: COAL PREPARATION AND LIMESTONE SYSTEM

EQUIPMENT LIST

FOR

Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 12

REV.: 3

DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DJ-CHT-5	ACCEPTS CHUTE		By Contractor					
1DJ-CHT-6	DISCHARGE CHUTE		By Contractor					
1DJ-CHT-7	DISCHARGE CHUTE		By Contractor					
1DJ-CHT-8	SAMPLE CHUTE		By Contractor					
57 1DJ-CHT-9	DISCHARGE CHUTE		By Contractor					
1DJ-CHT-13	DISCHARGE CHUTE		By Contractor				95 02	7
1DJ-CHT-14	DISCHARGE CHUTE		By Contractor				95 02	8
1DJ-CLF-1	COAL CLASSIFIER		By Contractor					

M

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: DJ

DESCRIPTION: COAL PREPARATION AND LIMESTONE SYSTEM

EQUIPMENT LIST

FOR

Department of Energy

Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 13

REV.: 3

DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DJ-CRSH-1	COAL CRUSHER		By Contractor					
				M				
1DJ-CYCL-1	CYCLONE RECEIVER CRUSHED COAL		By Contractor					
1DJ-DCOL-1	COAL PREP. DUST COLLECTOR		By Contractor					
1DJ-DRY-1	COAL SCREW/ DRYER		By Contractor					
				M				
1DJ-FAN-1	OIL HEATER FAN		By Contractor					
				M				
1DJ-FAN-2	COAL PREP. DUST COLLECTOR FAN		By Contractor					
				M				
1DJ-FDR-1	COAL WEIGHBELT FEEDER		By Contractor					
				M				
1DJ-HPR-1	ROTARY VALVE VENT HOPPER		By Contractor					

58

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 14
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: DJ

DESCRIPTION: COAL PREPARATION AND LIMESTONE SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1DJ-HX-1	OIL HEATER		By Contractor					
1DJ-MO-1	MOTOR, COAL CRUSHER		By Contractor	20.00 HP 1800 RPM M			94 12 6	
1DJ-MO-2	MOTOR, COAL SCREW/DRYER		By Contractor	15.00 HP 1800 RPM M			94 12 6	
1DJ-MO-3	MOTOR, OIL HEATER FAN		By Contractor	20.00 HP 1800 RPM M			94 12 6	
1DJ-MO-4	MOTOR, OIL HEATER PUMP		By Contractor	15.00 HP 1800 RPM M			94 12 6	
1DJ-MO-5	MOTOR, BLOWER, CRUSHED COAL TRANSFER		By Contractor	20.00 HP 1800 RPM M			94 12 6	
1DJ-MO-6	MOTOR, ROTARY VALVE, CRUSHED COAL NO.1		By Contractor	1.00 HP 1800 RPM M			94 12 6	
1DJ-MO-7	MOTOR, ROTARY VALVE, CRUSHED COAL NO.2		By Contractor	1.00 HP 1800 RPM M			94 12 6	

59

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: DJ

DESCRIPTION: COAL PREPARATION AND LIMESTONE SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 15
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1DJ-MO-8	MOTOR, COAL CLASSIFIER		By Contractor	1.50 HP 1800 RPM M			94 12	6
1DJ-MO-9	MOTOR, COAL WEIGHTBELT FEEDER		By Contractor	1.00 HP 1800 RPM M			94 12	6
1DJ-MO-10	MOTOR, COAL SAMPLER		By Contractor	0.50 HP 1800 RPM M			94 12	6
1DJ-MO-11	MOTOR, COAL PREP. DUST COLLECTOR FAN		By Contractor	25.00 HP 1800 RPM M			94 12	6
1DJ-MO-12	MOTOR, COAL PREP. ROTARY VALVE		By Contractor	1.00 HP 1800 RPM M			94 12	6
1DJ-P-1	OIL HEATER PUMP		By Contractor		M			
1DJ-SMX-1	COAL SAMPLER		By Contractor					
1DJ-TK-1	FINES TOTE BIN		By Contractor					

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: DJ
DESCRIPTION: COAL PREPARATION AND LIMESTONE SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 16
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1DJ-TK-2	COAL SURGE BIN		By Contractor					
1DJ-TK-3	COAL SAMPLER CONTAINER		By Contractor					
1DJ-TK-4	TOTE BIN		By Contractor					
1DJ-TK-5	COKE/LIMESTONE BIN		By Contractor					

95 06 28

19

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 17
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: DP
DESCRIPTION: PYROLYZER FEED SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1DP-FDR-1	ROTARY FEEDER		By Contractor					
1DP-HFR-1	CHARGE HOPPER		By Contractor					
1DP-HFR-2	TRANSFER HOPPER		By Contractor					
1DP-MO-1	MOTOR, ROTARY FEEDER		By Contractor	3.00 HP 1800 RPM M			94 12 6	
1DP-TK-1	SURGE BIN		By Contractor					

69
27

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: EA

DESCRIPTION: MEDIUM-VOLTAGE POWER SYSTEM (601V - 15KV)

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 18
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1EA-HVSW-1	4.16KV, 250MVA, MED. VOLTAGE SWITCH GEAR & MOTOR CONTROL WITH METERERING SECTION.		By Contractor				94 12 18	
1EA-XFRM-1	MASTER UNIT SUB STATION TRANSFORMER (11.5 KV - 4160 VOLTS)		By Contractor					
1EA-XFRM-2	LOW VOLTAGE LOAD CENTER TRANSFORMER (11.5 KV-480 VOLTS)		By Contractor				94 12 20	

63

Jacobs-Sirrine Engineers

SIRRIINE PROJECT:16N25706
GPIF

SYSTEM CODE: EC
DESCRIPTION: LOW-VOLTAGE POWER SYSTEM (600V AND LESS)

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 19
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1EC-CAB-1	(5) PANEL CABINET FOR FIREALAR PAGING SYSTEM PANEL, SECURITY PANEL, AND CO2 PANEL.		By Contractor					94 12 18
1EC-MCC-1	480V, 3 WIRE, NEMA 12 MOTOR CONTROL CENTER		By Contractor					
1EC-MCC-2	480V, 3 WIRE, NEMA 3R MOTOR CONTROL CENTER		By Contractor					
1EC-MCC-3	480V, 3 WIRE FUEL HANDLING MOTOR CONTROL CENTER		By Contractor					94 12 20
1EC-MCC-4	480V, 3 WIRE ESSENTIAL POWER MOTOR CONTROL CENTER		By Contractor					94 12 20
1EC-UPS-1	480V, 30KVA UNINTERRUPTABLE POWER SUPPLY WITH (2)200A, 3 PHASE, 4 WIRE PANELS CONSISTING OF 42 CIRCUIT BREAK		By Contractor					
1EC-XFRM-4	575V, 4 WIRE, 112.5 KVA TRANSFORMER		By Contractor					
1EC-XFRM-5	575-200/120 4 WIRE, 75 KVA TRANSFORMER		By Contractor					

69
44

Jacobs-Sirrine Engineers

SIRRIINE PROJECT:16N25706
GPIF

SYSTEM CODE: GA
DESCRIPTION: COMBUSTION GAS DESULFURIZATION SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 20
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OF SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1GA-BLO-1	SCRUBBER WASTE WATER OXIDATION BLOWER		By Contractor				95 04	3
1GA-CHTR-1	FLUE GAS REHEATER		By Contractor				95 04	3
1GA-DMP-1	FLUE GAS DAMPER		By Contractor				95 04	3
1GA-FAN-1	FLUE GAS REHEATER COMBUSTION AIR FAN		By Contractor				95 04	3
65-1GA-FAN-2	ID FAN		By Contractor				95 08	29
1GA-HX-1	QUENCH CHAMBER		By Contractor				95 06	28
1GA-MO-1	SCRUBBER RECYCLE PUMP MOTOR		By Contractor				95 04	3
1GA-MO-2	CAUSTIC INJECTION PUMP MOTOR		By Contractor.				95 04	3

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: GA

DESCRIPTION: COMBUSTION GAS DESULFURIZATION SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 21
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1GA-MO-3	CONDENSATE DRAIN PUMP MOTOR		By Contractor	M			95 04	3
1GA-MO-5	FLUE GAS REHEATER COMBUSTION AIR FAN MOTOR		By Contractor	M			95 04	3
1GA-MO-6	SCRUBBER WASTE WATER OXIDATION BLOWER MOTOR		By Contractor	M			95 04	3
1GA-MO-7	FLUE GAS DAMPER MOTOR		By Contractor	M			95 08	2
1GA-MO-8	ID FAN MOTOR		By Contractor	M			95 08	29
1GA-P-1	SCRUBBER RECYCLE PUMP		By Contractor	M			95 04	3
1GA-P-2	CAUSTIC INJECTION PUMP		By Contractor	M			95 04	3
1GA-P-3	CONDENSATE DRAIN PUMP		By Contractor	M			95 04	3

66

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: GA

DESCRIPTION: COMBUSTION GAS DESULFURIZATION SYSTEM

EQUIPMENT LIST

FOR

Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 22

REV.: 3

DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1GA-SCG-1	CAUSTIC SCRUBBER		By Contractor				95 04	3
1GA-TK-1	CAUSTIC STORAGE TANK		By Contractor				95 04	3
1GA-TK-2	CONDENSATE DRAIN TANK		By Contractor				95 07	10

67

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: GG

DESCRIPTION: PROCESS VENT SYSTEM

EQUIPMENT LIST

FOR

Department of Energy

Gasification Product Improvement Facility

ISSUED AS Rev.1

PAGE: 23

REV.: 3

DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1GG-CYCL-1	VENT CYCLONE		By Contractor				94 10	16
1GG-HPR-1	VENT CYCLONE HOPPER		By Contractor				94 10	16
1GG-STK-1	FLARE STACK		By Contractor				94 12	7
1GG-TK-1	FLARE INSTRUMENT AIR RECEIVER		By Contractor				95 06	28

89

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: GH
DESCRIPTION:

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 24
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OF SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN.	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1GH-FAN-1	FD FAN		By Contractor	M				95 07 12
1GH-INCIN-1	INCINERATOR		By Contractor					95 08 29
1GH-MO-1	FD FAN MOTOR		By Contractor	M				95 07 12

69

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 25
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: KD

DESCRIPTION: CONDENSATE AND FEEDWATER CHEMISTRY CONTROL SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1KD-MO-1	PHOSPHATE METERING PUMP MOTOR		By Contractor	0.25 HP 1800 RPM M			94 12	6
1KD-MO-2	NEUTALIZING AMINE METERING PUMP MOTOR		By Contractor	0.25 HP 1800 RPM M			94 12	6
1KD-MO-3	OXYGEN SCAVENGER METERING PUMP MOTOR		By Contractor	0.25 HP 1800 RPM M			94 12	6
1KD-P-1	PHOSPHATE METERING PUMP		By Contractor	M			94 10	16
1KD-P-2	NEUTALIZING AMINE METERING PUMP		By Contractor	M			94 10	16
1KD-P-3	OXYGEN SCAVENGER METERING PUMP		By Contractor	M			94 10	16

70

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: KK
DESCRIPTION: POTABLE WATER SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 26
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1KK-MO-1	POTABLE WATER BOOSTER PUMP NO.1 MOTOR		By Contractor	3.00 HP 1800 RPM M			94 12	6
1KK-MO-2	POTABLE WATER BOOSTER PUMP NO.2 MOTOR		By Contractor	3.00 HP 1800 RPM M			94 12	6
1KK-P-1	POTABLE WATER BOOSTER PUMP NO.1		By Contractor	M				
1KK-P-2	POTABLE WATER BOOSTER PUMP NO.2		By Contractor	M				
1KK-TK-1	POTABLE WATER STORAGE TANK		By Contractor					

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: KV
DESCRIPTION: AUXILIARY WATER SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 27
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1KV-MO-1	COOLING WATER TRANSFER PUMP NO.1 MOTOR		By Contractor	80.00 HP 1800 RPM M				94 12 15
1KV-MO-2	COOLING WATER TRANSFER PUMP NO.2 MOTOR		By Contractor	80.00 HP 1800 RPM M				94 12 15
1KV-P-1	COOLING WATER TRANSFER PUMP NO.1		By Contractor	M				94 12 7
1KV-P-2	COOLING WATER TRANSFER PUMP NO.2		By Contractor	M				94 12 7

72

Jacobs-Sirrine Engineers

SIRRIINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 28
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: KW

DESCRIPTION: SERVICE WATER SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1KW-MO-1	SERVICE WATER PUMP MOTOR		By Contractor	M			95 06	28
1KW-P-1	SERVICE WATER PUMP		By Contractor	M			95 06	28
1KW-TK-1	FIRE & SERVICE WATER STORAGE TANK		By Contractor				94 12	7

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: LD
DESCRIPTION: COMPRESSED AIR SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 29
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OF SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE REV	REV FLAG
1LD-DRY-1	INSTRUMENT AIR DRYER		By Contractor				94 12	7
1LD-FLT-1	DRYER PREFILTER		By Contractor				94 12	7
1LD-FLT-2	DRYER AFTERFILTER		By Contractor				94 12	7
1LD-TK-1	INSTRUMENT AIR RECEIVER		By Contractor				94 12	7
1LD-TK-2	FUEL FEED SYSTEM INSTRUMENT AIR RECEIVER		By Contractor				95 07	10

74

Jacobs-Sirrine Engineers

SIRRIINE PROJECT:16N25706
GPIF

SYSTEM CODE: LF
DESCRIPTION: SERVICE AIR SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 30
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1LF-CMP-1	PROCESS AIR COMPRESSOR		By Contractor					
				M				
1LF-CMP-2	PROCESS BOOSTER COMPRESSOR		By Contractor				95 06 28	
1LF-CMP-3	PLANT AIR COMPRESSOR AND RECEIVER PACKAGE		By Contractor				95 06 28	
1LF-DRY-1	FUEL FEED AIR DRYER		By Contractor					
1LF-FLT-1	INLET FILTER SILENCER		By Contractor					
1LF-FLT-2	DRYER PREFILTER		By Contractor					
1LF-FLT-3	DRYER AFTERFILTER		By Contractor					
1LF-HX-1	1st STAGE INTERCOOLER		By Contractor				94 12 7	

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: LF
DESCRIPTION: SERVICE AIR SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 31
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1LF-HX-2	2nd STAGE INTERCOOLER		By Contractor				94 12	7
1LF-HX-3	3rd STAGE INTERCOOLER		By Contractor				94 12	7
1LF-HX-4	4th STAGE INTERCOOLER		By Contractor				94 12	7
1LF-HX-5	RECYCLE COOLER		By Contractor				95 02	6
96 1LF-HX-6	LUBE OIL COOLER		By Contractor				95 06	28
1LF-HX-7	FUEL FEED AIR COOLER		By Contractor				94 12	7
1LF-MO-1	PROCESS AIR COMPRESSOR MOTOR		By Contractor	3000.00 HP 1800 RPM M			95 02	7
1LF-MO-2	PROCESS BOOSTER COMPRESSOR MOTOR		By Contractor				95 06	28

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 32
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: LF
DESCRIPTION: SERVICE AIR SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1LF-SIL-1	BLOWOFF SILENCER		By Contractor					
1LF-TK-1	PROCESS AIR RECEIVER		By Contractor					
1LF-TK-2	FUEL FEED AIR RECEIVER		By Contractor					95 06 28

77

Jacobs-Sirrine Engineers

SIRRIINE PROJECT:16N25706
GPIF

SYSTEM CODE: LK
DESCRIPTION: NITROGEN SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 33
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1LK-HX-1	NITROGEN HEATER		By Contractor.				95 02	6
1LK-MO-1	NITROGEN PUMP NO.1		By Contractor	40.00 HP 1800 RPM M			94 12	6
1LK-MO-2	NITROGEN PUMP NO.2		By Contractor	40.00 HP 1800 RPM M			94 12	6
1LK-P-1	NITROGEN PUMP NO.1		By Contractor	M			94 12	7
1LK-P-2	NITROGEN PUMP NO.2		By Contractor	M			94 12	7
1LK-TK-1	NITROGEN STORAGE TANK NO.1		By Contractor				94 12	7
1LK-TK-2	NITROGEN STORAGE TANK NO.2		By Contractor				94 12	7
1LK-TK-3	HIGH PRESSURE NITROGEN SURGE TANK		By Contractor				94 12	7

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: LK
DESCRIPTION: NITROGEN SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 34
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1LK-VAP-1	L.P.NITROGEN VAPORIZER		By Contractor					
1LK-VAP-2	H.P.NITROGEN VAPORIZER		By Contractor				95 02	6

79

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: SB

DESCRIPTION: MAIN STEAM SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 35
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1SB-BLR-1	PACKAGE BOILER		By Contractor					94 12 18
1SB-FAN-1	FD FAN		By Contractor					95 07 17
				M				
1SB-MO-1	FD FAN MOTOR		By Contractor					95 07 17
				M				
1SB-SIL-1	S.H. VENT SILENCER		By Contractor					94 12 18
08								
1SB-SIL-2	DRUM VENT SILENCER NO.1		By Contractor					94 12 18
1SB-SIL-3	DRUM VENT SILENCER NO.2		By Contractor					94 12 18
1SB-STK-1	STACK		By Contractor					95 07 12
1SB-TK-1	CBD TANK		By Contractor					

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: SJ

DESCRIPTION: FEEDWATER SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 36
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1SJ-DEA-1	DEAERATOR		By Contractor					
1SJ-MO-1	BOILER FEEDWATER PUMP MOTOR		By Contractor	25.00 HP 1800 RPM M			94 12	6
1SJ-MO-2	GASIFIER CW MAKEUP PUMP NO.1 MOTOR		By Contractor	300.00 HP 1800 RPM M			94 12	15
18 1SJ-MO-3	GASIFIER CW MAKEUP PUMP NO.2 MOTOR		By Contractor	300.00 HP 1800 RPM M			94 12	6
1SJ-P-1	BOILER FEEDWATER PUMP		By Contractor	M				
1SJ-P-2	GASIFIER CW MAKEUP NO.1		By Contractor	M			94 12	7
1SJ-P-3	GASIFIER CW MAKEUP PUMP NO.2		By Contractor	M				

Jacobs-Sirrinc Engineers

SIRRINE PROJECT:16N25706
GPIF

SYSTEM CODE: VE

DESCRIPTION: ACCESS CORRIDORS ENVIRONMENTAL CONTROL SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 37
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1VE-ACU-1	A.C.UNIT CONTROL/RACK ROOM		By Contractor				94 12	6
1VE-ACU-2	A.C.UNIT OFFICE/ELECT.RM.		By Contractor				94 12	6
1VE-ACU-3	A.C.UNIT COAL HANDL.MCC ROOM		By Contractor				94 12	6
1VE-EHTR-1	ELECT UNIT HEATER NO.1 FIRE PUMP HOUSE		By Contractor	10.00 KW			94 12	6
1VE-EHTR-2	ELEC UNIT HEATER NO.2 FIRE PUMP HOUSE		By Contractor	10.00 KW			94 12	6
1VE-EHTR-3	ELECT UNIT HEATER NO.1 COMPRESSOR ROOM		By Contractor				94 12	18
1VE-EHTR-4	ELECT UNIT HEATER NO.4 COMPRESSOR ROOM		By Contractor	10.00 KW			94 12	6
1VE-EHTR-5	ELECT UNIT HEATER NO.5 COMPRESSOR		By Contractor	2.00 KW			94 12	6

Jacobs-Sirrine Engineers

SIRRIINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 38
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: VE
DESCRIPTION: ACCESS CORRIDORS ENVIRONMENTAL CONTROL SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1VE-EHTR-6	ELECT UNIT HEATER NO.1 MAINT. RM		By Contractor	3.00 KW			94 12	6
1VE-EHTR-7	ELECT UNIT HEATER NO.2 MAINT. RM		By Contractor	2.00 KW			94 12	6
1VE-EHTR-8	WALL HEATER F.P.VAIVE HOUSE		By Contractor	3.00 KW			94 12	6
1VE-EHTR-9	ELCT RH NO.1 TOILET		By Contractor	2.00 KW			94 12	6
1VE-EHTR-10	ELECT RH NO.2 TOILET		By Contractor	3.00 KW			94 12	6
1VE-EHTR-11	ELECT. DUCT HEATER CONTROL/I.O.ROOM/LAB		By Contractor	5.00 KW			94 12	6
1VE-EHTR-12	ELECT. DUCT HEATER ELECT. RM.		By Contractor				94 12	18
1VE-EHTR-13	ELECT. DUCT HEATER COAL HANDL. MCC ROOM		By Contractor				95 07	17

Jacobs-Sirrine Engineers

SIRRINE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 39
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: VE
DESCRIPTION: ACCESS CORRIDORS ENVIRONMENTAL CONTROL SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1VE-FAN-1	VENT FAN MAINT.ROOM		By Contractor	M			94 12 18	
1VE-FAN-2	TOILET EXHAUST FAN		By Contractor	M			94 12 18	
1VE-FAN-3	EXHAUST FAN UPS ROOM		By Contractor	M			94 12 18	
1VE-FAN-4	VENT FAN COMPRESSOR ROOM		By Contractor	M			94 12 18	
1VE-FAN-5	VENT FAN COMPRESSOR ROOM		By Contractor	M			94 12 18	
1VE-FAN-6	EXHAUST FAN F.P.VALVE HOUSE		By Contractor	M			94 12 18	
1VE-FAN-7	LAB HOOD S.A.FAN		By Contractor	M			94 12 18	
1VE-FAN-7	FAN MOTOR		By Contractor	M			94 12 18	

78

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 40
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: VE

DESCRIPTION: ACCESS CORRIDORS ENVIRONMENTAL CONTROL SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1VE-FAN-8	VENT FAN FIRE PUMP HSE		By Contractor					94 12 18
				M				
1VE-LH-1	CHEMICAL LAB HOOD		By Contractor					94 12 18
1VE-LV-1	MOTORIZED O.A. LOUVER MAINT.RM		By Contractor					94 12 18
1VE-LV-2	MOTORIZED O.A. LOUVER COMPRESSOR RM		By Contractor					94 12 18
85 1VE-LV-3	MOTORIZED O.A. LOUVER FIRE PUMP HOUSE		By Contractor					94 12 18
1VE-MO-2	FAN MOTOR		By Contractor	0.25 HP				94 12 6
				M				
1VE-MO-2	FAN MOTOR		By Contractor	0.25 HP				94 12 6
				M				
1VE-MO-3	FAN MOTOR		By Contractor	0.17 HP 1800 RPM				94 12 6
				M				

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 41
REV.: 3
DATE: 11-Sep-1995

SYSTEM CODE: VE

DESCRIPTION: ACCESS CORRIDORS ENVIRONMENTAL CONTROL SYSTEM

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1VE-MO-4	FAN MOTOR		By Contractor	1.00 HP 1800 RPM M			94 12	6
1VE-MO-5	FAN MOTOR		By Contractor	0.05 HP 1800 RPM M			94 12	6
1VE-MO-6	FAN MOTOR		By Contractor	0.33 HP 1800 RPM M			94 12	6
1VE-MO-8	FAN MOTOR		By Contractor	0.33 HP 1800 RPM M			94 12	6
1VE-MO-9	MOTORIZED LOUVER MAINT RM		By Contractor	0.17 HP 1800 RPM M			94 12	6
1VE-MO-10	MOTORIZED LOUVER COMPRESSOR RM		By Contractor		M		95 07	17
1VE-MO-11	MOTORIZED LOUVER FIRE PUMP HOUSE		By Contractor		M		95 07	17

Jacobs-Sirrine Engineers

SIRRIE PROJECT:16N25706
GPIF

SYSTEM CODE: WS
DESCRIPTION: WASTE TREATMENT SYSTEM

EQUIPMENT LIST
FOR
Department of Energy
Gasification Product Improvement Facility
ISSUED AS Rev.1

PAGE: 42
REV.: 3
DATE: 11-Sep-1995

EQUIPMENT NO.	EQUIPMENT NAME & DESCRIPTION	VENDOR PO NUMBER BUDGET COST CCN	CONSTRUCTION RESPONSIBILITY	DESIGN PWR OP SPEED DRIVER	EQ WT (EMPTY) MTL CONSTRN	APPROVAL STATUS DESIGN STATUS USE STATUS	SPEC ISSUE	REV FLAG
1WS-MO-1	STORM/PROCESS WASTE SUMP PUMP NO.1 MOTOR		By Contractor	5.00 HP 1800 RPM M			94 12	6
1WS-MO-2	STORM/PROCESS WASTE SUMP PUMP NO.2 MOTOR		By Contractor	5.00 HP 1800 RPM M			94 12	15
1WS-MO-3	SANITARY WASTE DOSING PUMP NO.1		By Contractor	15.00 HP 1800 RPM M			94 12	6
1WS-MO-4	SANITARY WASTE DOSING PUMP NO.2 MOTOR		By Contractor	2.00 HP 1800 RPM M			94 12	15
1WS-P-1	STORM/PROCESS WASTE SUMP PUMP NO.1		By Contractor				95 06	28
1WS-P-2	STORM/PROCESS WASTE SUMP PUMP NO.2		By Contractor				95 06	28
1WS-P-3	SANITARY WASTE DOSING PUMP NO.1		By Contractor				95 07	10
1WS-P-4	SANITARY WASTE DOSING PUMP NO.2		By Contractor				95 07	10

GPIF PROJECT
JACOBS-SIRRINE PROJECT NO. 16N25706

PROCESS DESIGN BASIS INDEX

August 28, 1995

DOCUMENT NUMBER	DOCUMENT TITLE
DBR-1AA-1	GASIFIER DESIGN PRESSURE
DBR-1AA-2	GASIFIER COOLING
40-1AA-1	GASIFIER
40-1AA-2	GAS CLEAN-UP SYSTEM
40-1AA-3	GASIFIER ASH HANDLING
40-1AA-4	SOLID WASTE DISPOSAL
40-1DG-1	NATURAL GAS DISTRIBUTION
40-1GA-1	FLUE GAS DESULFURIZATION SYSTEM
40-1GG-1	LOCK HOPPER VENT SYSTEM
40-1GG-2	FLARE SYSTEM
40-1GH-1	INCINERATOR SYSTEM
40-1KK-1	POTABLE WATER SYSTEM
40-1KV-1	AUXILIARY WATER DISTRIBUTION
40-1KW-1	SERVICE WATER SYSTEM
40-1LD-1	PLANT & INSTRUMENT AIR SYSTEMS
40-1LF-1	PROCESS AIR SYSTEM
40-1LK-1	NITROGEN STORAGE DISTRIBUTION
40-1SB-1	PACKAGE BOILER
40-1SJ-1	CONDENSATE/DEAERATOR/FEEDWATER
40-1WS-1	PROCESS WASTE WATER DISTRIBUTION
82-1DH-1	COAL STORAGE BIN
82-1DH-2	COAL STORAGE BIN DISCHARGER
82-1DH-3	COAL SCREW CONVEYORS & FEEDERS
82-1DH-4	COAL BUCKET ELEVATOR
82-1DH-5	COAL STORAGE BIN VENT DUST COLLECTOR & EXHAUST FAN
82-1DJ-1	COAL SCREW DRYER
82-1DJ-2	COAL CRUSHER
82-1DJ-3	COAL CLASSIFIER
82-1DJ-4	COAL WEIGH BELT FEEDER/SAMPLER
82-1DJ-5	COAL SURGE BIN
82-1DJ-6	COKE WEIGHBELT FEEDER
82-1DJ-7	COKE SURGE BIN
82-1DJ-8	TRUCK UNLOADING PIPE & TARGET BOX
82-1DJ-9	COAL PREPARATION DUST COLLECTOR w/ EXHAUSTER FAN
82-1DJ-10	COAL TRANSFER SYSTEM
82-1DP-1	CHARGE HOPPER, TRANSFER HOPPER, SURGE BIN

SYSTEM PROCESS DESIGN BASIS

PDB No. DBR-1AA-1

System Name: Gasifier Design Pressure
Flow Sheet No: 16N25706-40-F-1AA-1

I. DESIGN PHILOSOPHY

GASIFIER CONFIGURATION

1. The PyGas™ gasifier is an air blown dry bottom gasifier designed for an operating pressure of 325 psig.
2. The gasifier is shown in Figure 1. The internal diameter of the vessel is 5 feet. The vessel houses a rotating grate, which supports the gasifier fixed bed, a central pyrolyzer tube, and an upper shroud attached to the top of the vessel. The vessel consists of a dome with a top flanged connection, a central section, and a bottom flanged section. The vessel is double-walled and designed for evaporative water cooling. The vessel heads are refractory lined.
3. The lower portion of the pyrolyzer tube extends through the bottom of the vessel.
4. The gasifier has openings for process inlet and outlet flows including air, steam, nitrogen, coal and limestone inlet flows, product gas outlet flow, and ash and solids discharge. Openings are also included for the vessel access, the rotating grate drive shaft and pressure relief. In addition, there are openings for inlet water and outlet steam/water lines for the vessel cooling jacket as well as cooling circuits for internal gasifier components. The vessel contains a number of instrument connections.
5. The pressure vessel, as shown in Figure 1, will be designed in accordance with ASME Boiler and Pressure Vessel Code, Section VIII, Division 1. This code shall also be used to establish allowable stresses for certain nonpressure boundary parts such as vessel support attachments. It is noted that Section VIII, Division 1 provides all safety attributes of Section I of the code but Section VIII, Division 1 goes beyond Section I to provide additional assurance of safety. Because the gasification process temperatures range from 1100°F to 2500°F, the cooling system and refractory lined surface will be designed to limit material temperatures of the pressure boundary and internals to levels that maintain stress limits in accordance with code requirements. The outer vessel will be constructed of carbon steel with a design temperature of 700°F. Metals selected for the internal components will follow the latest code requirements.
6. Refractory and insulating materials are considered to be maintenance materials and their replacement is a function of unit operation, availability, and performance.

DESIGN PRESSURE

1. The design pressure for the vessel outer shell is 540 psig. This pressure is calculated based on the vessel inner shell maximum pressure of 420 psig and the pressure differential between the vessel cooling jacket and the gas side.
2. The inner vessel wall will be designed for 140 psi differential pressure.
3. The design pressure of the steam drum is 540 psig.
4. The start-up pressure is 150 psig. The vessel design pressure of 540 psig is higher than explosion pressures predicted for 150 psig start-up conditions.

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-1

System Name: Gasifier Design Pressure
Flow Sheet No: 16N25706-40-F-1AA-1

Figure 1. General Gasifier Arrangement.

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-1

System Name: Gasifier Design Pressure
Flow Sheet No: 16N25706-40-F-1AA-1

PRESSURE RELIEF

1. The ASME Code requires that pressure safety relief devices be installed on the process gas side as well as on the water/steam cooling circuits. In addition, pressure relief devices will be required to limit the inlet pressure of process flow streams (air, steam, nitrogen). A system schematic listing operating pressures and pressure relief set points is shown in Figure 2.
2. Pressure relief valves on the steam drum will be reclosing type. Because of the dirty environment in the gasifier, a reclosing type of pressure relief device can not be used for relieving the gasifier overpressure. A rupture disk will be used as the gas side pressure relief device.
3. The pressure relief devices will be designed for overpressure only and not for explosion at the 325 psig gasification operating condition. The GPIF control system will be designed to prevent this abnormal condition.
4. The steam drum reclosing type pressure relief valve will be set at 486 psig and the non-reclosing type safety valve at 540 psig. The safety valve will be designed to relieve the full capacity of the steam circuit. Steam line from the drum to the gasifier will be equipped with a check valve to prevent contamination from the dirty gases. This is described in the gasifier cooling system process design.
5. The GPIF gasifier vessel will be designed for a maximum gas side pressure equal to the convey system inlet pressure of 373 psig (Ref. JSE Letter No 475 dated 5/31/95 on System Design Pressures). The GPIF will have upstream air, steam and nitrogen pressure reliefs to insure this gas side pressure is not exceeded.
6. The vessel contains a rupture disk designed for 420 psig with a design margin of -10%. The rupture disk will be exposed to high temperatures and will need a protective heat shield which may be cooled by nitrogen.
7. A manually operated valve will also be installed on the gasifier to bring down the pressure in the vessel as part of normal shut down procedure. This line will not be designed for emergency pressure relief.

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-1

System Name: Gasifier Design Pressure
Flow Sheet No: 16N25706-40-F-1AA-1

Figure 2. Gasifier Safety and Pressure Relief.

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-1

System Name: Gasifier Design Pressure
Flow Sheet No: 16N25706-40-F-1AA-1

II. DESIGN NOTES

1. The Rev. 1 design is based on the Jacobs-Sirrinc Letter No. 475 on system design pressures, dated 5/31/95 for the 5' ID vessel and the 325 psig, 4000 lb/hr coal operation.

2. Vessel Outer Shell Design Pressure:

Maximum gasifier pressure at the hot gas outlet	373 psig
Differential pressure across the cooling jacket inner wall	70 psi
Design margin for the vessel pressure	20%
Vessel outer shell design pressure (to nearest 10 psi)	$(373 + 70) \times 1.2 = 532 \cong 540$ psig

3. Drum Design Pressure and Pressure Relief:

Steam drum design pressure	540 psig
Non-reclosing drum safety valve set point	540 psig
Margin for the reclosing drum pressure relief valve	10%
Reclosing drum pressure relief valve set point	$540 - (0.1)(540) = 486$ psig

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

I. DESIGN PHILOSOPHY

1. The primary function of the cooling system is to cool the gasifier vessel, pyrolyzer, and the shroud to maintain these sections under their metal temperature limits. Figure 3 shows the gasifier cooling circuits and major components.
2. The cooling medium is water. The cooling is performed by evaporation.
3. The cooling circuits operate under forced circulation with a circulation rate sufficient to avoid overheating of the metal.
4. The cooling circuits are designed to operate at a higher pressure than the gasification process.
5. The four cooling circuits are connected into one common steam drum.
6. The steam drum has one reclosing type pressure relief valve and one non-reclosing type safety valve.
7. The make-up water is supplied to the steam drum.
8. During normal operation, the generated steam in the system is used in the gasification process and/or condensed back into the steam drum.
9. As shown in Figure 3, the cooling system is connected to (i) the gasifier outlet pipe, (ii) the gasifier grate/air/steam feed line, and (iii) steam drum through a water cooled condenser.

Loop (i) contains a control valve with a differential pressure between the gasifier and steam drum controller. In a situation of gas side breakdown where a rapid reduction of gasifier pressure occurs compared to the steam drum pressure, the differential pressure between the gasifier and steam drum will increase to the high alarm limit. At this point, the differential pressure controller will send signals to open the control valve in this loop and release steam to bring the differential pressure within the limit, thus preventing rupturing of the gasifier inner wall.

Loops (ii) and (iii) branch off of a three way flow control valve. Through loop (ii) the cooling side is open to the gasifier, and the pressure in the cooling circuits follow the gas side pressure and is maintained at higher pressure. Loop (ii) contains an orifice and a check valve. The excess steam not required for the gasifier process will be condensed and returned to the steam drum through loop (iii).

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

Figure 3. Gasifier Cooling Circuits.

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

II. DESIGN NOTES

1. Table 1 summarizes the pressure, flow and predicted temperature at various zones for the design, high, and low operating temperature cases.
 2. For design and high temperature cases, the gasifier gas side operating pressure is 325 psig at the gasifier hot gas outlet and the water circuit pressure is 395 psig. For the low temperature case, the gas side operating pressure is 200 psig at the gasifier hot gas outlet and the water circuit pressure is 270 psig.
 3. Pyrolyzer jacket fluid bed side is refractory lined. All other cooling surfaces are bare wall.
 4. For gasifier cooling component dimensions, refer to Riley drawing No. 93856-8-2641-10-05 (enclosed).
 5. The Design, High and Low operating temperature case parameters are shown in Tables 2 through 4 respectively. Data for High and Low Temperature Cases for Rev-1 was linearly extrapolated from Rev-1 Design Case.
- Ref. i) JSE Material Balance for Design Case dated 5/31/95 contained in JSE Letter No 477 dated 6/1/95, and
ii) JSE Letter No 384 dated 3/15/95 for Rev-0 Process Design Basis.

Surface areas, estimated mean temperature differences, overall heat transfer coefficients, heat flux, heat flows and steam generated are given for 11 heat transfer sections. The heat transfer sections are shown in Figure 4. The total predicted heat transfer to the cooling system for the design, high and low temperature cases are about 7, 11, and 5 million Btu/hr respectively. The total steam generated for the design, high and low temperature cases is 8,900, 13,300 and 5,300 lb/hr respectively.

SYSTEM PROCESS DESIGN BASIS

PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

Table 1 – Predicted Temperature at Key Locations

Description	Design Case	High Temp. Case	Low Temp. Case
Pressure, psig	325	325	150
Pyrolyzer Air/Coal Ratio	1.72	2.5	1.13
Flows, lb/hr:			
– Coal Input	4000	4000	2000
– Product Gas From Pyrolyzer	10225	14950	6090
– Product Gas From Fixed Bed	9535	9535	1525
– Fines @ Gasifier Exit	1000	1000	500
– Total Out @ Gasifier Exit	20760	25485	8115
Temperature, °F:			
– Pyrolyzer Exit	1690	1856	1500
– Dome	1690	2300*	1500
– Inner Annulus Entry	1548	2063	1256
– Inner Annulus Exit	1202	1625	780
– Fixed Bed Exit	1450	1700	1400
– Outer Annulus Entry	1186	1485	725
– Gasifier Outlet Nozzle	1023	1277	575

* Includes Top Air Injector Flow

93856/Tham
08/31/95

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

Table 2 — Heat Transfer Analysis — Design Case (325 psig & 2 t/hr coal)

Location No.	Cooling System Component/ Heat Source	Surface Area ft ²	Mean T ° °F	Heat Transfer Coefft, U Btu/hr-ft ² -°F	Heat Flux Density Btu/hr-ft ²	Heat Flow X 10 ⁶ Btu/hr	Steam Generated lb/hr	Heat/ Steam Flow %
1	Pyrolyzer Jacket:							
4	Fluidized Bed **	103.31	1248	8	9679	1.00	1255	
5	Shroud Inner Annulus	21.99	917	28	25682	0.56	709	
6	Fixed Bed — Char	42.41	1440	13	18856	0.80	1003	
6	Fixed Bed — Ash	42.41	225	14	3096	0.13	165	
	Total Pyrolyzer Jacket	210.13				2.50	3131	35.08
2	Shroud Tube:							
3	Dome Region	19.48	1183	25	29584	0.58	723	
10	Inner Annulus	27.72	917	28	25682	0.71	893	
10	Outer Annulus	52.97	657	12	7885	0.42	524	
	Total Shroud Tube	100.17				1.71	2140	23.97
9	Vessel Jacket:							
8	Outer Annulus/Freeboard	141.02	694	12	8330	1.17	1474	
7	Fixed Bed — Char	58.90	1440	16	22634	1.33	1673	
7	Fixed Bed — Ash	58.90	225	27	6173	0.36	456	
	Total Vessel Jacket	258.83				2.87	3603	40.36
11	Gas Outlet Nozzle	5.59	578	13	7520	0.04	53	
	Total	574.71				7.12	8926	100.00

* = Cooling Media: Water at saturated temperature of 447 °F
** = Refractory Lined

GPIF/ 93856
THAM 08/31/95

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

Table 3 - Heat Transfer Analysis - High Temperature Case (325 psig & 2 t/hr coa

Location No.	Cooling System Component/ Heat Source	Surface Area ft ²	Mean T * °F	Heat Transfer Coefft, U Btu/hr-ft ² -°F	Heat Flux Density Btu/hr-ft ²	Heat Flow X 10 ⁶ Btu/hr	Steam Generated lb/hr	Heat/Steam Flow %
1	Pyrolizer Jacket:							
4	Fluidized Bed**	103.31	1400	8	10831	1.12	1404	
5	Shroud Inner Annulus	21.99	1385	35	48488	1.07	1338	
6	Fixed Bed - Char	42.41	1615	16	26276	1.11	1398	
	Fixed Bed - Ash	42.41	225	14	3095	0.13	165	
	Total Pyrolizer Jacket	210.13				3.43	4304	32.35
2	Shroud Tube:							
3	Dome Region	19.48	1745	40	69782	1.36	1705	
10	Inner Annulus	27.72	1385	35	48488	1.34	1686	
	Outer Annulus	52.97	934	13	12142	0.64	807	
	Total Shroud Tube	100.17				3.35	4198	31.55
9	Vessel Jacket:							
8	Outer Annulus/Freeboard	141.02	981	13	12749	1.80	2256	
7	Fixed Bed - Char	58.90	1615	17	27111	1.60	2003	
	Fixed Bed - Ash	58.90	225	27	6171	0.36	456	
	Total Vessel Jacket	258.83				3.76	4715	35.44
11	Gas Outlet Nozzle	5.59	834	15	12505	0.07	88	
	Total	574.71				10.61	13305	100.00

* = Cooling Media: Water at saturated temperature of 447 °F
** = Refractory Lined

GPIF/ 93856
THAM 08/31/95

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

Table 4 - Heat Transfer Analysis - Low Temperature Case (150 psig & 1 t/hr coal)

Location No.	Cooling System Component/ Heat Source	Surface Area ft ²	Mean T * °F	Heat Transfer Coefft, U Btu/hr-ft ² -°F	Heat Flux Density Btu/hr-ft ²	Heat Flow X 10 ⁶ Btu/hr	Steam Generated lb/hr	Heat/Steam Flow %
1	Pyrolizer Jacket:							
4	Fluidized Bed	103.31	1118	8	8653	0.89	1043	
5	Shroud Inner Annulus	21.99	622	24	14932	0.33	383	
6	Fixed Bed - Char	42.41	1446	7	10683	0.45	529	
6	Fixed Bed - Ash	42.41	295	12	3578	0.15	177	
	Total Pyrolizer Jacket	210.13				1.83	2132	40.62
2	Shroud Tube:							
3	Dome Region	19.48	1019	22	22418	0.44	509	
10	Inner Annulus	27.72	622	24	14932	0.41	483	
10	Outer Annulus	52.97	280	10	2801	0.15	173	
	Total Shroud Tube	100.17				1.00	1166	22.21
9	Vessel Jacket:							
8	Outer Annulus/Freeboard	141.02	317	10	3168	0.45	521	
7	Fixed Bed - Char	58.90	1446	10	15147	0.89	1041	
7	Fixed Bed - Ash	58.90	295	18	5429	0.32	373	
	Total Vessel Jacket	258.83				1.66	1936	36.88
11	Gas Outlet Nozzle	5.59	212	11	2327	0.01	15	
	Total	574.71				4.50	5248	100.00

* = Cooling Media: Water at saturated temperature of 366 °F
** = Refractory Lined

GPIF/ 93856
THAM 08/31/95

SYSTEM PROCESS DESIGN BASIS
PDB No. DBR-1AA-2

System Name: Gasifier Cooling
Flow Sheet No: 16N25706-40-F-1AA-3

Figure 4. Cooling Section Identification..

101

TABLE OF CONTENTS

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

PARAGRAPH

1. GENERAL
2. ITEMS SUPPLIED BY RILEY
3. ITEMS SUPPLIED BY JACOBS-SIRRINE
4. CODES AND STANDARDS
5. TERMINAL POINTS
6. CONSTRUCTION AND DESIGN REQUIREMENTS

ATTACHMENTS

- A. DESIGN CRITERIA
- B. ANTICIPATED RANGES OF OPERATION
- C. BID TABULATION SHEETS
- D. STRUCTURAL DESIGN CRITERIA
- E. PROCESS DESIGN BASIS FLOW SHEET
- F. GASIFIER LOAD SHEET
- G. START-UP, SHUT-DOWN, EMERGENCY, PROCESS STATES
- H. PROCESS STATES MAP

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

(325 psi OPERATING PRESSURE & 2300°F PEAK OPERATING TEMPERATURE)

1. GENERAL

1.1 This specification covers the furnishing of one (1) complete natural gas preheated coal gasifier (PyGas™) conforming to United States Patent Numbers 5,133,780, and 5,145,490, complete with all required accessories.

1.2 The PyGas™ gasifier shall be designed to generate low BTU, high pressure, high temperature coal gas produced at the Gasification Product Improvement Facility at Fort Martin Generating Station near Morgantown, West Virginia. Coal gas flow will be controlled by air flow from an air compressor designed to produce 325 psi operating pressure at the pyrolyzer outlet to the PyGas™ gasifier.

1.3 The intended function of this PyGas™ gasifier is to combine a variety of air and steam with coal feed flows to continuously generate low Btu gas (80 Btu/dscf to 180 Btu/dscf) of suitable heating value and sensible heat to fire either a gas turbine or a boiler downstream.

1.4 The quantity of coal gas to be generated is based on the coal, air, and steam feed flow rates, as well as the efficiency of coal conversion within the PyGas™ coal gasifier. The anticipated coal throughput shall be from 1 ton per hour to 2 tons per hour.

1.5 The PyGas™ coal gasifier shall be shop assembled to the extent shipping limits will permit.

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

2. ITEMS FURNISHED BY DB-RILEY

2.1 The following is a list of items to be supplied by the Riley. This list is not intended to be all inclusive, it is only a general list. Riley is to include all items required to constitute a complete unit and system. The system shall include the following as a minimum:

2.1.1 High pressure PyGas™ gasifier steam generating vessel cooling walls (5 ft inside diameter) with external steam drum, steam separating drum internals, and (optional cooled) upper shroud and (optional cooled) pyrolyzer tube. The upper shroud shall be designed to minimize fines carryover and system pressure drop to acceptable levels for continuous efficient system operation.

(NOTE: If the cooled option is selected, each cooled section must be integrated into the gasifier gas or steam generation circuit. Since this unit is intended to confirm commercial design-ability, separate cooled circuits shall not be utilized).

2.1.2 Natural gas fueled preheat burner, gasifier system safety vent and rupture disk (set to relieve at 420 psi), field instruments and control devices, trap and vent valves, flame detectors, and a PLC based logic control system. Capacity of pre-heat burner to be sufficient to pre-heat the pyrolyzer tube to 1000°F within three hours. Location of pre-heat burner to insure fluidization during the transition from pre-heat to coal ignition (both to proceed simultaneously until coal ignition is established), all at sub-stoichiometric conditions.

2.1.3 A crushed coal (1/4" x 0") and limestone (50 mesh mean diameter) pressurization lock designed for 325 psi operating pressure, and capable of pneumatically feeding coal and limestone into the PyGas™ gasifier inlet. Jacobs-Sirrinc will develop and specify this lock for DB Riley to purchase and furnish.

2.1.4 An ash (up to 5" x 0" lumps) depressurization lock designed for 325 psi operating pressure, and capable of removing hot fused ash as well as ash fines from the PyGas™ gasifier grate dump outlet. Jacobs-Sirrinc will develop and specify this lock for DB Riley to purchase and furnish.

2.1.5 A rotating and reversible grate, complete with planetary hydraulic type drive for producing a fixed-gasification bed, crushing ash clinkers, and for removing ash from the fixed-bed. The grate shall be partitioned to admit externally controlled air/steam blast flows via three discrete sealed annuli beneath the grate. Grate speed turndown to be a minimum of ten to one. Grate support bearings to be arranged such that the grate rotates in a continuous centered position (include thrust bearings) to assure a proper seal between the rotating grate and the fixed pyrolyzer outside diameter.

2.1.6 A pyrolyzer tube (water cooled at DB Riley option), to include an externally accessible flanged cone assembly which permits complete removal of pyrolyzer internals. Tube to have an inside diameter at the cone-cylinder interface consistent with a superficial velocity of 3 ft/sec, and a 20% larger inside diameter at the pyrolyzer exit. This pyrolyzer tube shall be cooled (if DB Riley selects a water cooled design) using a shell within shell arrangement. The pyrolyzer exit shall be completely unrestrictive to char overflow. An arrangement using under-grate steam for cooling is preferred.

(NOTE: If the water cooled option is selected, each water cooled section must be integrated into the gasifier steam generation circuit. Since this unit is intended to confirm commercial design-ability, separate water cooled circuits shall not be utilized).

2.1.7 A vertically oriented coal/coke/limestone pneumatic injection nozzle sized for sufficient momentum to produce a 10 foot pyrolyzer jet penetration under specification coal operation.

2. ITEMS FURNISHED BY RILEY - Continued

2.1.8 A pyrolyzer fluidizing air outer annulus around the feed nozzle sized to maintain at least minimum fluidization velocities. This outer annulus shall also be designed for future acceptance of returned hot cyclone solids to the pyrolyzer.

2.1.9 An emergency pyrolyzer solids removal drain pipe located in the fluidizing air outer annulus sized for a minimum of 1 1/2 inch clear space shall be provided.

2.1.10 A top air/steam injection nozzle located at the centerline of the upper vessel dome designed to admit air and steam at up to 0.8 air/coal and 0.4 steam/coal ratios respectively. A flanged connection shall be included at the top dome for removal of this top dome nozzle. Initially, this flange will be blanked-off.

2.1.11 A tempering air feed control system designed to monitor and feed-back a signal to maintain a pre-determined set point feed temperature (from 125°F to 150°F) to the PyGas™ coal gasifier inlet. Jacobs-Sirrinc will develop and specify this item for DB Riley to purchase and furnish.

2.1.12 Provisions for fifteen pyrolyzer tube temperature control thermocouple locations to be fabricated in the pyrolyzer tube for field-mounting of thermocouples.

2.1.13 Provisions for nine upper shroud PyGas™ gasifier temperature control thermocouple locations to be fabricated in the inner annulus shroud walls for field-mounting of thermocouples.

2.1.14 Provisions for two upper shroud PyGas™ gasifier PSIT furnished GASTEMP™ temperature control monitor locations to be fabricated in the upper dome vessel walls for field-mounting of the GASTEMP™ temperature monitor and feedback control device.

2.1.15 Provisions for one upper shroud PyGas™ gasifier PSIT furnished Alpha-NH3™ ammonia monitor location to be fabricated in the upper dome vessel walls for field-mounting of the Alpha-NH3™ ammonia monitor and feedback control device.

2.1.16 Provisions for twenty PyGas™ gasifier vessel temperature control thermocouple locations to be fabricated in the vessel walls for field-mounting of thermocouples.

2.1.17 A man-way access port through the water-cooled PyGas™ vessel walls for access to the gasifier internals (located above fixed-bed solids operating level).

2.1.18 A lower vessel flange for access to the gasifier grate and under-grate internals.

2.1.19 Steel support legs designed for supporting the PyGas™ gasifier vessel at the grate drive pinion and sprocket elevation to minimize thermal expansion impact on alignment.

2.1.20 Four pyrolyzer cone air sweeping nozzle connections and internal piping for solids flow promotion to be located at the pyrolyzer cone-tube transition connection.

2.1.21 Either a pressurized rotary feeder or a fluidized proportioning vessel for transitioning from batch to continuous feed to the PyGas™ gasifier to be located at the coal/limestone lock outlet. Feeder or proportioner turndown to be a minimum of ten to one. Jacobs-Sirrinc will develop design basis and specifications for this item for DB Riley to purchase and furnish.

2. ITEMS FURNISHED BY RILEY - Continued

2.1.22 All pneumatic coal/coke/limestone interconnecting piping between the pressure lock rotary feeder or fluidized proportioner outlet flange and the gasifier. This pipe shall be designed for 373 psi operation, minimization of abrasion and solids saltation, insulated and lagged.

2.1.23 The Pyrolyzer shall be refractory lined in the vicinity of the cone to facilitate pre-heat to 1000°F.

2.1.24 Valved connections for feedwater controls shall be included.

2.1.25 Vent, drain, blowdown, chemical feed, instrument air, and fill piping, to within 12" of PyGas™ gasifier base. The gasifier shall be designed to be completely drainable and nitrogen inerted on both the water cooling and coal gas generation sides between tests.

2.1.26 All integral piping and valves associated with the PyGas™ gasifier unit island. Jacobs-Sirrinc will develop design basis and specifications for this item for DB Riley to purchase and furnish.

2.1.27 PyGas™ gasifier insulation, casing, and lagging.

2.1.28 SAMA drawing of recommended control strategy.

2.1.29 Technical supervision of installation and start-up.

2.1.30 Any special tools required for maintenance and operation including tools required for tube preparation.

2.1.31 All labor for unloading and transporting the equipment furnished by DB Riley from point of delivery to site of installation and placing same on foundations.

2.1.32 All labor to completely install the equipment and materials specified, including the field assembly of such boiler appurtenances that could not be included on the shop assembled unit.

2.1.33 Installation of local control panel, tubing, wiring, etc.

2.1.34 Pressure tap provisions shall be designed and fabricated at the pyrolyzer coal/coke/limestone feed nozzle inlet, fluidizing air outer annulus inlet, emergency solids removal pipe inlet, future recycled hot cyclone return inlet to the inner annulus; three located equispaced circumferentially at the top of gasifier at the dome away from top dome air/steam injector influence; three equispaced circumferentially through the pressure vessel at the grate elevation, three equispaced circumferentially at the outer annulus mid-point, one in the hot raw gas exit, one at the top dome air/steam injection nozzle, and one for each of the three undergrate air injection annuli.

2.1.35 Air sampling ports shall be designed and fabricated in the conveying air line, fluidizing air line, top air injection nozzle, and the undergrate air feed streams.

2.1.36 A raw gas sampling port shall be designed and fabricated at the PyGas™ gasifier outlet nozzle.

2. ITEMS FURNISHED BY RILEY - Continued

2.1.37 An upper gasifier (cooled at DB RILEY option) outer annulus shroud sealed between the gasifier dome and the hot raw gas exit nozzle, and open ended at the bottom to allow products of pyrolysis to continuously evacuate during operation. This shroud shall be tapered to increase its diameter as the products of pyrolysis proceed down-ward and around it at the open bottom end. This shroud shall be cooled (if DB RILEY selects a cooled design) using a tube within tube lances arrangement with welded fins. Fines carryover and pressure drop shall be minimized by design to produce continuous efficient operation. A future internal cyclone design shall be developed in anticipation of the potential need to restrict fines carry-over. A decision whether and when to apply this internal cyclones design will be made at some later date. The upper shroud shall be designed to facilitate the simple addition of the internal cyclone design if needed.

(NOTE: If the cooled option is selected, each cooled section must be integrated into the gasifier gas or steam generation circuit. Since this unit is intended to confirm commercial design-ability, separate cooled circuits shall not be utilized).

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

3. ANCILLARY ITEMS SPECIFIED BY JACOBS-SIRRINE

3.1 The following is a list of items to be specified by Jacobs-Sirrinc and purchased by DB Riley.

3.1.1 Foundations and anchor bolts.

3.1.2 Air piping to and gasifier flow control valves.

3.1.3 Steam piping to and gasifier flow control valves.

3.1.4 Feedwater piping to gasifier inlet stop-check valve.

3.1.5 Instrument air.

3.1.6 Blowdown piping from specified terminal points, 12" above PyGas™ gasifier base.

3.1.7 Chemical feed and fill piping to specified terminal points 12" above PyGas™ gasifier base.

3.1.8 Drain and rupture disk vent piping from specified terminal points 12" above PyGas™ gasifier.

3.1.9 All steam and feedwater piping insulation external from PyGas™ gasifier casing.

3.1.10 PyGas™ gasifier boilout including required chemicals and disposal thereof.

3.1.11 Coal/coke/limestone feeds to the pressure lock inlet flange.

3.1.12 Electric power to all drives and final elements at required conditions.

3.1.13 Hydrostatic test of DB Riley's steam generation system between control valves and gasifier steam drum outlet non-return valve.

3.1.14 Freeze protection.

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

4. CODES AND STANDARDS

4.1 The equipment furnished by DB Riley shall be designed in accordance with the latest edition, latest addenda of the following codes and standards (as applicable).

4.1.1 ASME - American Society of Mechanical Engineers.

4.1.2 ABMA - American Boiler Manufacturers Association.

4.1.3 ASTM - American Society for Testing and Materials.

4.1.4 AISC - American Institute of Steel Construction.

4.1.5 HEI - Heat Exchanger Institute.

4.1.6 OSHA - Occupational Safety and Health Act.

4.1.7 NEC - National Electrical Code.

4.1.8 NEMA - National Electrical Manufacturers Association

4.1.9 TEMA - Tubular Exchanger Manufacturers Association.

4.1.10 CAGI - Compressed Air and Gas Institute.

4.1.11 ISA - Instrument Society of America.

4.1.12 ICEA - Insulated Cable Engineers of America.

4.1.13 IEEE - Institute of Electrical and Electronics Engineers.

4.1.14 AFBMA - American Gear Manufacturer's Association.

4.1.15 AGMA - American Gear Manufacturer's Association.

4.1.16 ANSI - American National Standards Institute.

4.1.17 NFPA - National Fire Protection Association.

4.1.18 All applicable state and local laws, ordinances or regulations.

4.1.19 The steam generating unit shall be inspected and stamped by a National Board of Boiler and Pressure Vessel Inspectors and registered with the National Boards.

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

5. TERMINAL POINTS

5.1 The following terminal points shall apply to PURCHASER furnished equipment and systems:

5.1.1 Air/Gas

5.1.1.1 Coal conveying air at rotary feeder or fluidized proportioner inlet flange.

5.1.1.2 Coal/coke/limestone pressure lock air intake flange.

5.1.1.3 Pyrolyzer outer annulus fluidizing air inlet nozzle flange.

5.1.1.4 Top dome inlet air/steam nozzle flange.

5.1.1.5 Undergrate inlet air nozzle inlet flange.

5.1.1.6 PyGas™ gasifier hot raw gas outlet water cooled nozzle outlet flange.

5.1.2 Fuel Piping

5.1.2.1 Coal gas supply to Waste Heat Boiler (WHB)

5.1.2.2 Natural Gas supply.

5.1.2.3 Gasifier system vent flow inlet at gasifier top rupture disk outlet flange.

5.1.3 Steam/Water

5.1.3.1 Pyrolyzer fluidizing outer annulus line at gasifier nozzle inlet flange.

5.1.3.2 Top dome injection air/steam nozzle inlet flange.

5.1.3.3 Under-grate feed at inlet nozzle flange.

5.1.3.4 Hot raw gas gasifier outlet water spray injection point.

5.1.3.5 Bottom ash depressurization lock vessel inlet flange.

5.1.3.6 Gasifier fire fighting deluge ring.

5.1.3.7 Instrument wiring connections, as required.

5.1.4 Feedwater

5.1.4.1 Inlet to feed stop and check valves at the PyGas™ gasifier inlet.

5.1.4.2 Inlet to chemical feed stop valves.

5.1.4.3 Outlet of second valve for each gasifier vent and drain.

5. TERMINAL POINTS - Continued

5.1.5 Gasifier Cooling Water.

5.1.5.1 Outlet of second valve for each waterwall drain.

5.1.5.2 Outlet of intermittent blowdown valves.

5.1.5.3 Outlet of second valve on water level instrumentation connections.

5.1.5.4 Outlet of second valve on continuous blowdown connection.

5.1.5.5 Out of drum water gauge drain valves.

5.1.6 Instrument wiring connections, as required.

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

6. CONSTRUCTION AND DESIGN REQUIREMENTS

6.1 Casing

6.1.1 The PyGas™ gasifier setting shall be designed and constructed gas tight. Riley shall furnish all insulation of proper material and thickness for insulating the space under the casing, including items necessary to support the insulation. The maximum possible welded wall shell construction shall be used to prevent gas leakage from within the gasifier to the outer casing and into the operating area.

6.1.2 All necessary access doors shall be furnished by the DB Riley.

6.1.3 The gasifier vessel shall be completely water cooled above the grate elevation to the upper flange. The water wall shells shall be designed to withstand the maximum rupture disk relief pressure capability.

6.1.5 The casing shall be constructed of ribbed aluminum for the entire height of the setting. The casing shall be properly reinforced and stiffened with structural members to provide rigidity and prevent buckling.

6.2 Gasifier Drum

6.2.1 The gasifier drum shall be fitted with proper drum internals such that when the gasifier is operating at maximum pounds steam per hour, carryover shall be less than 0.1 micro mho as cation-free conductivity and sodium levels of less than 3 ppm when leaving steam drum if steam must meet Ft Martin quality. If not connected to Ft. Martin, steam quality shall be per ABMA standards for the operating pressure and temperature level specified.

6.3 Nozzles

6.3.1 All nozzles on drums and headers shall be forged steel, weld end type.

6.4 Steam Temperature

6.4.1 Permanent thermocouples shall be provided to monitor steam temperature during start-up and shutdown. The number and location of the thermocouples shall be as recommended by DB Riley for successful start-up and shutdown of the unit.

6.5 Stress Relief

6.5.1 All pyrolyzer and inner annulus shroud elements shall be stress relieved with all welded attachments for supporting, etc., in place at the factory.

6.6 Gasifier Accessories

6.6.1 The following accessories shall be furnished with the gasifier, including all brackets, supports, etc., for attaching accessories to gasifier:

6.6.1.1 One inlet for feeding water to the unit shall be provided. Furnish stop valve and check valve or ASME Code approved combination stop-check valve for the inlet. Valves to be weld end, ANSI 600 pound rating.

6.6.1.2 Drum safety valves - Consolidated, or equal.

6. CONSTRUCTION AND DESIGN REQUIREMENTS - Continued

6.6.1.3 Steam outlet header safety valves - Consolidated, or equal.

6.6.1.4 One bi-color, multi-port water gauge complete with illuminator, reflector hood, mirror, and floor stand. Gauge shall be as manufactured by Yarway or Diamond and shall be approved by the manufacturer for this service. Provide isolating valves in accordance with ASME Code. Provide one (1) Hydrastep drum level indication system for indication and tripping functions. The hydrastep unit shall be supplied with indication at the feedwater control valve and remote indication in the control room operators panel. Provide one set of double valved connections for the feedwater control level transmitter.

6.6.1.5 Lower drum tandem weld end type blow-off valves - Yarway or Edwards .

6.6.1.6 Provide connection on steam drum with internal collecting pipe for continuous blow-down. Provide two welded bonnet, weld end stop valves - Hancock, Yarway or Edwards.

6.6.1.7 Provide connection on steam drum with Type 304 stainless steel internal distribution pipe for chemical feed. Provide two Type 304 stainless steel welded bonnet, weld end stop valves - Hancock, Yarway or Edwards.

6.6.1.8 Provide steam sample connections in saturated steam header. Each connection to be doubled valved with welded bonnet, weld end stop valves - Hancock, Yarway or Edwards.

6.6.1.9 Provide steam drum vent connection double valved with welded bonnet, weld end stop valves - Hancock, Yarway, or Edwards.

6.6.1.10 Two shut-off valves shall be furnished by Riley for each miscellaneous high pressure connection on the boiler. Each valve shall be weld end, welded bonnet, Hancock, Yarway, or Edwards, and the boiler proposal shall list the number, size, manufacture, figure number and use for each set of valves being furnished.

6.7.3 Couplings

6.7.3.1 DB Riley shall furnish gear type couplings as manufactured by Falk or equal. Coupling halves shall be correctly bored and keyed for the fan and motor shafts. The fan half coupling and motor half coupling shall be mounted. Riley shall also furnish the coupling guard.

6.8 Fuel Burning Equipment

6.8.1 Fuel

6.8.1.1 Natural Gas: Natural gas shall be the primary fuel for pre-heat if available.

6.8.1.2 No. 2 Oil: No. 2 Oil shall be the alternate fuel for pre-heat only if natural gas is not available.

6.8.2 Burners

6.8.2.1 DB Riley shall furnish burner assemblies for the efficient burning of the fuels specified herein.

6.8.2.2 The pre-heater assembly shall include a natural gas burner suitable for the pre-heating function. The pre-heat burner shall be capable of 2 to 1 turndown under modulating control with stable fires and no indication of instability or poor combustion.

6.11.2.3 The pre-heater assembly shall include a Natural Gas electric ignitor and traveling flame front.

6. CONSTRUCTION AND DESIGN REQUIREMENTS - Continued

6.11.2.4 DB Riley shall determine the proper location in the pyrolyzer feed tube annuli to inject air and steam into the pyrolyzer to assure fluidization during start-up.

6.11.2.6 The pre-heater assembly shall include a natural gas and air pre-mixing device designed for automatic or remote manual operation. It shall be designed to be capable of directly pre-heating the pyrolyzer.

6.11.3 Pre-heater piping, valves and in-line instruments shall be by DB Riley. Jacobs-Sirrinc will develop design basis and specifications for this item for DB Riley to purchase and furnish.

6.11.4 Flame Failure Safety Controls

6.11.4.1 DB Riley shall furnish a complete Burner Management System for control of the natural gas fired pyrolyzer cone pre-heater, including pre-heat to combustion. The system shall consist of the field instruments and control devices, the safety shutoff and vent valves, and an Allen-Bradley PLC-5 logic control system. All logic design and devices shall be FM approved and in compliance with NFPA.

6.11.4.2 DB Riley supplied logic systems shall interface to a DCS system through an Allen-Bradley Data Highway Plus communications network. The PLC system supplied shall connect through its Data Highway Plus port of this network. The logic shall be programmed such that the operator control, monitoring and alarming will be through this interface. DB Riley shall build a data transfer table within the PLC. The ladders and the DCS shall read and write data in this table for the monitoring, alarm and control functions. Operator initiated actions from the control room will be writes to this data table and shall be used in the ladders to initiate the desired control function. Status and alarm conditions will be read from this table by the DCS. The logic shall be built such that the DCS can read the cause of a trip (first out function). Coordination of the data table will be required during the design stage.

6.11.4.3 DB Riley shall furnish flame detectors for each fuel input point at the pre-heater. Loss of flame shall cause an immediate and safe trip of the pre-heat fuel at any time during the pre-heat cycle.

6.11.4.4 The Burner Management System PLC and electronics shall be supplied in a free standing cabinet with prewired terminal strips for connection of the field wiring. Complete documentation and wiring diagrams shall be supplied. The PLC programming and documentation shall be supplied on Allen-Bradley 6200 software. The cabinet will be installed in the DCS I/O room.

6.11.4.5 DB Riley shall provide a complete description of the Pre-heat Burner Management System hardware and control. Jacobs-Sirrinc will develop design basis and specifications for this item for DB Riley to purchase and furnish.

6.11.4.6 DB Riley shall provide a complete description of the top dome air/steam nozzle GASTEMP temperature monitoring and feedback system hardware and control.

6.12 Motors

Grate Drives:

Each grate drive requires a motor driven hydraulic pump. These motors shall be TEFC. Consult the Jacobs-Sirrinc furnished electrical equipment specifications for further details.

Cooling Water Spray:

The coal gas cooling water spray shall include a motor driven pump. This motor shall be TEFC. Consult the Jacobs-Sirrinc furnished electrical equipment specifications for further details.

6.12.1 All motors will be furnished by DB Riley (unless otherwise specified herein).

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

ATTACHMENT A

DESIGN CRITERIA

1.0 COAL GAS CONDITIONS AT GASIFIER OUTLET:

1.1	Maximum Continuous Rating Coal Gas Flow Rate (lbs/hr): (5/31/95 Mass Balance - 325 psig)	<u>18.900</u>
1.2	Operating Gasifier Outlet Coal Gas Pressure (psig): (Pyrolyzer Inlet Pressure 333 psig, Anticipated Gasifier Delta P=8 psi)	<u>325</u>
1.3	Phase I Operating Gasifier Outlet Coal Gas Temperature (°F): (347-Stainless Steel Piping Design Limit Less 15 °F Operating Margin)	<u>1085</u>
	Phase II Operating Gasifier Outlet Coal Gas Temperature (°F): (includes water cooled outlet nozzle, refractory lined cyclone & piping to HGCU flange)	<u>N/A</u>
1.4	Design Gasifier Outlet Coal Gas Pressure (psig):	<u>By DB Riley</u>
1.5	Design Gasifier Outlet Coal Gas Temperature (°F):	<u>By DB Riley</u>

2.0 FEEDWATER CONDITIONS AT GASIFIER INLET:

2.1	Temperature (°F): (per Site Access Agreement)	<u>170</u>
-----	--	------------

3.0	MAXIMUM GASIFIER OPERATING TEMPERATURE (°F): (Peak Anticipated Top dome air/steam injector and Fixed-bed Temperatures)	<u>2300</u>
-----	---	-------------

4.0 FUELS:

4.1 Coal Gas Leaving gasifier (Page 9 Mass Balance 5/3/95 column 12) based on METC specification coal analysis.

4.1.1 Constituent Analysis (Percent by Wt.):

NH ₃	<u>0.28</u>
CO	<u>25.40</u>
H ₂	<u>1.39</u>
CO ₂	<u>10.48</u>
CH ₄	<u>0.50</u>
N ₂	<u>48.97</u>
H ₂ S	<u>0.64</u>
H ₂ O	<u>11.23</u>
Ar	<u>1.10</u>
Total	<u>100.00</u>

PyGas™ GASIFIER DESIGN CRITERIA (continued)

4.1.2	Coal Gas Heating Value (Btu/# HHV): (Mass Balance - 325 psig, Column 12)	<u>1995</u>
4.1.3	Coal Gas Temperature (°F): (Mass Balance - 325 psig, Column 12)	<u>1023 F</u>
4.1.4	Coal Gas Flow (lb/hr): (Mass Balance - 325 psig, Column 12)	<u>18.900</u>
4.1.5	Coal Gas Specific Volume: (Mass Balance - 325 psig, Column 10h)	<u>54 to 86 scf/lb</u>
4.2	<u>Natural Gas</u>	
4.2.1	Elemental Analysis:	<u>85% methane (minimum)</u>
4.2.2	Heating Value:	<u>1000 Btu/scf</u>
4.3	<u>Coal & Dolomite/Limestone Throughput</u>	
4.3.1	The gasifier coal feed rate shall be controlled to from 1 ton per hour to 2 tons per hour per METC ammended contract specifications.	
4.3.2	The gasifier dolomite/limestone feed rate shall vary from zero to 0.6 tons per hour based on coal with a maximum of 4% sulfur content, and a calcium to coal molar ratio of 2.5. Feed shall be from the coke bin, and test durations using dolomite/limestone shall be limited by coke bin capacity.	
4.3.3	The anticipated dolomite/limestone feed rate shall be from zero (Mass Balance Specification Coal Case - 325 psig) to 800 pounds per hour based on METC specification coal analysis, 2.8% sulfur coal on an as received basis, and a calcium to coal molar ratio of 2.5.	
4.4	<u>Ambient Conditions</u>	
4.4.1	Temperature:	
4.4.1.1	Minimum Ambient Temperature (°F):	<u>-20</u>
4.4.1.2	Maximum Ambient Temperature (°F):	<u>120</u>
4.4.2	Performance Ambient Conditions:	
4.4.2.1	Temperature (°F):	<u>80</u>
4.4.2.2	Relative Humidity (%):	<u>60</u>
4.4.3	Elevation (feet above sea level): (from Ft. Martin Certified Topographical Drawings)	<u>820</u>

PyGas™ GASIFIER DESIGN CRITERIA (continued)

4.4.4	Utilities:	Operating Pressure (psig)	Operating Temperature (°F)	Design Pressure (psig)	Design Temperature (°F)
	Compressed Air	373	400	by DB Riley	by DB Riley
	Cooling Water	375 (at grade)	105	by DB Riley	by DB Riley
	Process Steam to Gasifier	353	530	by DB Riley	by DB Riley
4.4.5	Electricity:	<u>Later</u>	HP	<u>Later</u>	HP
	Volts		4160	480	120
	Phase		3	3	1
	Hertz		60	60	60
4.4.6	Gasifier Cooling Criteria (at 50-million Btu/hr Coal Input):				
	Pyrolyzer Tube:	1.25-million Btu/hr Maximum, 1-million Btu/hr Preferred			
	Shroud:	2-million Btu/hr Maximum			
	Water Jacket:	4-million Btu/hr Maximum			
	Outlet Gas Nozzle:	2-million Btu/hr Maximum; If not water cooled, 0.25-million Btu/hr.			

End of Attachment A

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

ATTACHMENT B

ANTICIPATED RANGES OF OPERATION

PyGas™ GASIFIER

1.0	COAL GAS CONDITIONS AT GASIFIER :	MINIMUM (Appendix (A-9)/2) (400 psig)	MAXIMUM (Appendix (A-9)/2) (400 psig)
1.1	Coal Gas Flow Rate (lbs/hr):	<u>7.000</u>	<u>20.000</u>
1.2	Operating Gasifier Inlet Coal Gas Pressure (psig): (Pyrolyzer Inlet Pressure 325 psig, Anticipated Gasifier Delta P=15 psi)	<u>30</u>	<u>325</u>
1.3	Operating Gasifier Coal Gas Product Temperature (°F): (Mass Balance, Column 10h)	<u>800</u>	<u>1087</u>
1.4	Operating Gasifier Outlet Coal Gas Temperature (°F): (High Alloy Steel Piping Design Limit Less 15°F Operating Margin)	<u>1000</u>	<u>1085</u>
1.5	Operating Gasifier Peak Top & Fixed-bed Temperature (°F): (Minimum Basis from Bill Early, Maximum Basis Riley Morgan Profile)	<u>1800</u>	<u>2300</u>
4.0	FUELS:		
4.1	<u>Coal Gas</u> Leaving gasifier (Mass Balance column 12) based on METC specification coal analysis.		
4.1.1	Constituent Analysis (Percent by Vol.):	MINIMUM (Apdx A-2&A-8)	MAXIMUM (Apdx A-4&A-8)
	CO	<u>17.75</u>	<u>20.06</u>
	H2	<u>8.49</u>	<u>10.15</u>
	CO2	<u>5.58</u>	<u>4.54</u>
	H2O	<u>17.05</u>	<u>16.77</u>
	CH4	<u>00.00</u>	<u>01.39</u>
	H2S	<u>00.12</u>	<u>00.34</u>
	N2	<u>44.82</u>	<u>50.03</u>
	Ar	<u>00.66</u>	<u>00.93</u>
	NH3	<u>00.27</u>	<u>00.35</u>
	TOTAL	<u>Not Additive</u>	<u>Not Additive</u>

PyGas™ GASIFIER DESIGN CRITERIA (continued)		MINIMUM	MAXIMUM
4.1.2	Coal Gas Heating Value (Btu/# HHV): (Mass Balance - 5/31/95 & 325 psig, Column 12)	<u>1335</u>	<u>2014</u>
4.1.3	Coal Gas Heating Value (Btu/dscf): (Mass Balance - 5/31/95 & 325 psig, Column 10h)	<u>103</u>	<u>146</u>
4.1.4	Future Phase II HGCU Input Coal Gas Temperature (°F): (Mass Balance - 325 psig, Column 12)	<u>1000</u>	<u>1087</u>
4.1.5	Coal Gas Specific Volume (scf/lb): (Mass Balance - 325 psig, Column 12)	<u>54</u>	<u>86</u>
4.2	<u>Coal Throughput</u>		
4.2.1	The Gasifier Coal Feed Rate (short tons per hour) (per METC contract specifications)	<u>1</u>	<u>2</u>
4.3	<u>Dolomite/Limestone Throughput</u>		
4.3.1	The Gasifier Dolomite/Limestone Feed Rate (short tons per hour) (based on coal with a max. of 4% sulfur content, and a calcium to coal molar ratio of 2.5)	<u>0</u>	<u>1</u>
4.4	<u>Pyrolyzer Air Feed</u>		
4.4.1	Pyrolyzer Conveying Air Feed Rate (lb/hr) (per Mass Balance - 325 psig, Appendix A-9 Column 9b/2) (adjustments to these figures are anticipated depending upon each sub-system vendor's requirements)	<u>1,200</u>	<u>4,000</u>
4.4.2	Pyrolyzer Fluidizing Air Feed Rate (lb/hr) (per Mass Balance - 325 psig, Appendix A-9 Column 9c/2)	<u>2,200</u>	<u>3,000</u>
4.4.3	Pyrolyzer Sweeping Air Feed Rate (lb/hr) (per Project Team Agreement)	<u>0</u>	<u>0</u>
4.5	<u>Pyrolyzer Steam Feed</u>		
4.5.1	Pyrolyzer Conveying Air Feed System Steam Rate (lb/hr) (per Mass Balance - 325 psig, Appendix A-9 Column 9b)	<u>0</u>	<u>0</u>
4.5.2	Pyrolyzer Fluidizing Air Feed System Steam Rate (lb/hr) (per Riley Research)	<u>0</u>	<u>750</u>
4.5.3	Pyrolyzer Sweeping Steam Feed Rate (lb/hr) (per Riley Research)	<u>0</u>	<u>250</u>

PyGas™ GASIFIER DESIGN CRITERIA (continued)		MINIMUM	MAXIMUM
4.6	<u>Gasifier Top Dome Air Feed</u>		
4.6.1	Top Dome Air Feed Rate (lb/hr) (per Mass Balance - Appendix A-8&2 Column 9e/2)	<u>0</u>	<u>3,200</u>
4.7	<u>Gasifier Top Dome Steam Feed</u>		
4.7.1	Top Dome Steam Feed Rate (lb/hr) (per Mass Balance - Appendix A-8&9 Column 11a/2 & Jacobs-Surrine)	<u>0</u>	<u>750</u>
4.8	<u>Gasifier Under-grate Air Feed</u>		
4.8.1	Gasifier Under-grate Air Feed Rate (lb/hr) (per Mass Balance - Appendix A-1&3 Column 9d/2)	<u>750</u>	<u>4,900</u>
4.9	<u>Gasifier Under-grate Steam Feed</u>		
4.9.1	Gasifier Under-grate Steam Feed Rate (lb/hr) (per Mass Balance - Appendix A-3&9 Column 11c/2)	<u>550</u>	<u>2,700</u>

End of Attachment B

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

ATTACHMENT C

TABULATION SHEETS

THIS TABULATION SHEET FORMS A PART OF

PROJECT NO. _____

DATED: _____

NAME OF VENDOR: _____

DATE SUBMITTED: _____

NOTES:

- (1) If space is insufficient, use Remarks Sheet at end of this specification.
- (2) Items not applicable should be marked "NA".

1.0 GASIFIER

1.1 Type: Fluid-bed/Fixed-bed Hybrid

1.2 Number of Drums and Size:

1.2.1 Upper - inch diameter x feet long, number manholes: _____

1.2.2 Lower - inch diameter x feet long, number manholes: _____

1.3 Design Pressure of Drums: _____ psi

1.4 Pyrolyzer Cooling Surface: _____ sq.ft.

1.5 Shroud Cooling Surface: _____ sq.ft.

1.6 Water Jacket Cooling Surface: _____ sq.ft.

1.7 Outlet Nozzle Water Cooling Surface: _____ sq.ft.

1.8 Air Heater Heating Surface: _____ sq.ft.

1.9 Superheater Heating Surface: _____ sq.ft.

1.10 If fins are used, give percent of fin area taken
as heating surface: _____ percent

1.11 Weight of Water in Gasifier at Normal Operating
Level: _____ pounds

1.12 Weight of Water in Gasifier at Full Condition
for Hydrostatic Test: _____ pounds

TABULATION SHEETS (continued)

1.13	Are All Water Jackets, Tubes and Drums Completely Drainable by Gravity?	<u>Yes ()</u>	<u>No (X)</u>
2.0	PYROLYZER		
2.1	Cone Height:	<u> </u>	<u>feet-inch(es)</u>
2.2	Cylinder Diameter:	<u> </u>	<u>feet-inch(es)</u>
2.3	Cylinder Height:	<u> </u>	<u>feet-inch(es)</u>
2.4	Pyrolyzer Volume:	<u> </u>	<u>cubic feet</u>
2.5	Pyrolyzer Effective Project Radiant Surface Based on ABMA Standard:	<u> </u>	<u>sq.ft. "EPRS"</u>
2.6	Centerline of Lower Drum Above Foundation:	<u> </u>	<u>feet-inch(es)</u>
2.7	Centerline of Steam Drum Above Foundation:	<u> </u>	<u>feet-inch(es)</u>
2.8	Overall Height of Gasifier Above Foundation (including safety rupture disk):	<u> </u>	<u>feet-inch(es)</u>
2.9	Size and Spacing of Vessel Wall Jacket:	<u> "/" </u>	<u> "/" centers</u>
2.10	Thickness and Type of Outer Vessel Jacket Wall:	<u> </u>	<u>inch-gauge</u>
2.11	Thickness and Type of Inner Vessel Jacket Wall:	<u> </u>	<u>inch-gauge</u>
2.12	Insulation Thickness, Type:	<u> </u>	
2.12.1	Top and Sides:	<u> </u>	<u>inch(es)</u>
2.12.2	Bottom:	<u> </u>	<u>inch(es)</u>
2.12.3	Circumferential:	<u> </u>	<u>inch(es)</u>
2.13	Gasifier Casing Material Thickness and Type:	<u> </u>	
2.13.1	Top and Sides:	<u> </u>	<u>inch(es)</u>
2.13.2	Bottom:	<u> </u>	<u>inch(es)</u>
2.13.3	Circumferential:	<u> </u>	<u>inch(es)</u>
2.14	Number Observation Ports, Nitrogen Cooled?	<u>Yes ()</u>	<u>No (X)</u>

TABULATION SHEETS (continued)

3.0 GASIFIER ACCESSORIES

3.1 Feed Stop and Check Valves, Number:

3.1.1 Figure Number:

3.1.2 Make:

3.1.3 Size:

3.2 Safety Rupture Disk, Number:

3.2.1 Figure Number:

3.2.2 Make:

3.2.3 Size:

3.3 Water Column, Number:

3.3.1 Figure Number:

3.3.2 Make:

3.3.3 Size:

3.4 Drum Blow-Off Valves, Number:

3.4.1 Figure Number:

3.4.2 Make:

3.4.3 Size:

3.5 Water Jacket Header Blow-Off Valves, Number:

3.5.1 Figure Number:

3.5.2 Make:

3.5.3 Size:

3.6 Drum Pressure Gauge, Location:

3.6.1 Figure Number:

3.6.2 Make:

TABULATION SHEETS (continued)

3.6.3	Size:	_____
3.7	Superheater Pressure Gauge, Location:	_____
3.7.1	Figure Number:	_____
3.7.2	Make:	_____
3.7.3	Size:	_____
3.8	Remote Level Indicator, Location:	_____
3.8.1	Figure Number:	_____
3.8.2	Make:	_____
3.8.3	Size:	_____
3.8.4	Type:	_____
3.8.5	Quantity:	_____
4.0	COAL/LIMESTONE PRESSURE LOCK	
4.1	Manufacturer:	_____
4.2	Type:	_____
4.3	Number:	_____
4.4	Length:	_____
4.5	Diameter:	_____
4.6	Are Units Completely Installed and Piped When Gasifier is Shipped?	Yes () No ()
4.7	Are controls included	Yes (X) No ()
4.8	Control Manufacturer and Type:	_____
5.0	GASIFIER BOTTOM ASH PRESSURE LOCK	
5.1	Manufacturer:	_____
5.2	Type:	_____
5.3	Number:	_____

TABULATION SHEETS (continued)

5.4	Length:	_____
5.5	Diameter:	_____
5.6	Are Units Completely Installed and Piped When Gasifier is Shipped?	Yes () No ()
5.7	Are controls included	Yes (X) No ()
5.8	Control Manufacturer and Type:	_____
6.0	PIPING	
6.1	Thickness of Air Nozzles:	_____ inch(es)
6.2	Thickness of Gas Nozzles:	_____ inch(es)
6.3	Quantity of Valves:	_____
6.4	Location of Valves:	_____
6.5	Type of Valves:	_____
7.0	TOP DOME AIR/STEAM INJECTOR	
7.1	Type:	_____
7.2	Size:	_____
7.3	Manufacturer:	_____
7.4	Injection Nozzle Type and Manufacturer:	_____
7.5	Injection Cone Angle :	Yes () No ()
7.6	Injector Swirl Number:	_____ CFM. F
7.7	Throughput Capacity at Test Block Conditions:	_____ CFM. F
7.8	Static Pressure at Gasifier Continuous Rating:	_____ iwg
7.9	Static Pressure at Test Block Conditions:	_____ iwg
8.0	ROTATING/REVERSING GRATE	
8.1	Type of Grate:	_____
8.2	Manufacturer:	_____

TABULATION SHEETS (continued)

8.3	Maximum Rotational Speed:	_____ rev/hr
8.4	Minimum Rotational Speed:	_____ rev/hr
8.5	Required Pressure of Air/Steam at Undergrate Header:	_____ psig
8.6	Grate Drive Type	_____ Planetary Hydraulic _____
8.7	Location to Pressure Vessel	_____ Inboard (X) Outboard () _____
8.8	Thrust Bearing Clearance to Pyrolyzer Seal	_____ (mm) _____
9.0	PRE-HEAT BURNER - NATURAL GAS	
9.1	Type of Pre-heater Burner:	_____ Fluidized-cone direct _____
9.2	Quantity of Burner Assemblies:	_____ one natural gas _____
9.3	Quantity of Gas Guns in Each Assembly:	_____ two, ignitor & direct _____
9.4	Maximum Fuel Burning Capacity of Each Natural Gas Burner:	_____ cubic feet/hour _____
9.5	Minimum Fuel Burning Capacity of Each Oil Burner:	_____ N/A gallons/hour _____
9.6	Required Pressure of Gas/Oil at Burner Piping Inlet:	_____ psig _____
9.7	Required Temperature of Gas/Oil at Burner Piping Inlet:	_____ F _____
9.8	Required Atomizing Steam or Air Pressure at Burner Piping Inlet:	_____ N/A psig _____
9.9	Atomizing Steam Required in Percent of Steam Generated, by Weight:	_____ N/A % _____
9.10	Quantity of Compressed Air Required at Maximum Fuel Burning Capacity:	_____ scfm _____
10.0	CONTROLS	
10.1	Is the Down Level Monitoring System Supplied?	_____ Yes () No () _____
10.2	Manufacturer and Model:	_____ _____
10.3	Flame Sensor Quantity & Type:	_____ _____

TABULATION SHEETS (continued)

10.4	Burner Management System Supplied?	Yes () No ()
10.5	Manufacturer and Series:	_____
10.6	Is the SAMA drawing included?	Yes () No ()
10.7	Are damper actuators supplied?	Yes () No ()
10.8	Quantity Manufacturer and Type:	_____
10.9	Natural Gas Oil Control Valve, Number:	_____
10.9.1	Figure Number:	_____
10.9.2	Make:	_____
10.9.3	Size:	_____
10.10	No. 2 Fuel Oil Control Valve, Number:	_____
10.10.1	Figure Number:	_____
10.10.2	Make:	_____
10.10.3	Size:	_____
10.11	Is System Schematic Drawing Included?	Yes () No ()
11.0	HEAT TRAP	
11.1	Type:	_____
11.2	Manufacturer:	_____
11.3	Size:	_____
11.4	Heating Surface:	_____ sq.ft.
11.5	Sootblowers Number and Manufacturer:	_____ N/A
11.6	Steam Coil Air Heater Included:	Yes () No ()
11.6.1	Tube Material:	_____
11.6.2	Fin Material and Coating:	_____

TABULATION SHEETS (continued)

12.0 PERFORMANCE - PREDICTED

12.1	Pounds of Gasifier Steam Produced Per Hour Continuous:	_____	psig at	FTT
12.2	Pre-heat Pyrolyzer Cone Heat Liberation - Gas:	_____	BTU/hr-cu.ft.	
12.3	Pre-heat Pyrolyzer Cone Heat Liberation - Oil:	_____	BTU/hr-cu.ft.	
12.4	Pre-heat Pyrolyzer Cone Net Heat Release - Gas:	_____	BTU/hr-sq.ft.	"EPRS"
12.5	Pre-heat Pyrolyzer Cone Net Heat Release - Oil:	_____	BTU/hr-sq.ft.	"EPRS"
12.6	CO ₂ in Pre-heat Flue Gas at Gasifier Outlet:	_____	percent	
12.7	Quantity of Fuel Fired - Natural Gas:	_____	cu.ft.	
12.8	Quantity of Fuel Fired - No. 2 Oil:	_____	gallon/hour	
12.9	Gas Pressure Drop Through System to Pyrolyzer Cone:	_____	psi	
12.10	Temperature Gas Entering Pyrolyzer Cone - Natural Gas:	_____	F	
12.11	Temperature Gas Entering Pyrolyzer Cone - No. 2 Oil:	_____	F	
12.12	Temperature Gas Leaving Pyrolyzer Cone - Natural Gas:	_____	F	
12.13	Temperature Gas Leaving Pyrolyzer Cone - No. 2 Oil:	_____	F	
12.14	Quantity of Flue Gas Leaving the Pyrolyzer Cone - Natural Gas:	_____	DSCFM	
		_____	AWCFM	
		_____	pounds/hour	
12.15	Quantity of Flue Gas Leaving the Pyrolyzer Cone - No. 2 Oil:	_____	DSCFM	
		_____	AWCFM	
		_____	pounds/hour	
12.16	Quantity of Air Entering Pre-heat Burner - Natural Gas:	_____	CFM	
		_____	pounds/hour	
12.17	Quantity of Air Entering Pre-heat Burner- No. 2 Oil:	_____	CFM	
		_____	pounds/hour	
12.18	Temperature of Feedwater to Gasifier:	_____	170°	F
12.19	Temperature of Air Entering the Pyrolyzer:	_____	400°	F
12.20	Temperature of Air Entering Fixed-bed Vessel:	_____	400°	F

TABULATION SHEETS (continued)

12.21	Draft Loss Through Pyrolyzer and Fixed-bed:	_____	psi
12.22	Maximum Steam Generating Capacity at Above Pressure and Temperature - 2-hour Period:	_____	(%/hr)
12.23	Maximum Allowable Gasifier Water Concentration:	_____	ppm
12.24	Solids in Steam Outlet:	_____	ppm
12.25	Maximum Percent Moisture in Steam at Outlet:	_____	percent
12.26	Combined Efficiency of Gasifier Steam Generation and Fuel Burning Equipment:	Natural Gas _____	percent
		No. 2 oil _____	percent
12.27	Opening Pressure Setting of Top Safety on Gasifier Steam Drum (per Site Access Agreement) :	_____ was 950 psig now 374 psig	
12.28	Maximum Quantity of Feedwater Required When All Safety Valves are Blowing:	_____	pounds/hour
12.29	Gasifier Feedwater Pressure Required at Pump Side of Feed Stop and Check Valves When All Safety Valves are Blowing:	_____	psig
12.30	Gasifier Feedwater Pressure Required at Pump Side of Feed Stop and Check Valves at Rated Continuous Steam Generation:	_____	psig
12.31	Steam Pressure Drop Across Gasifier System:	_____	psi
13.0	PREDICTED PERFORMANCE OF GASIFIER COOLING STEAM GENERATION SYSTEM		
13.1	Fuel:	_____	
13.2	Process Steam Flow (Gasifier) with _____ F Feedwater:	_____	pounds/hour
13.3	Pressure at Process Steam (Gasifier Cooling) Outlet:	_____	psig
13.4	Combined Efficiency:	_____	percent
13.5	Total Solids Content in Process Steam:	_____	ppm
13.6	Process Steam Outlet Temperature:	_____	°F

End of Attachment C

PyGas™ GASIFIER
PRESSURE VESSEL
STRUCTURAL DESIGN CRITERIA

Prepared by _____ Date _____

Approved by _____ Date _____

Approved by _____ Date _____

January, 1995

PyGas™ GASIFIER VESSEL
STRUCTURAL INTEGRITY

MECHANICAL DESIGN

PROCESS DESIGN

FABRICATION & INSTALLATION

INSPECTION

HYDROTEST

INSTRUMENTATION & CONTROL

OPERATION & MAINTENANCE

PRESSURE RELIEF

GPIF

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 GENERAL	1
2.0 SCOPE	2
2.1 Pressure Boundary Components	2
2.2 Internals Requiring Structural Design	2
3.0 APPLICABLE CONSTRUCTION CODES	3
3.1 Design of Pressure Boundary and Pressure Boundary Parts	3
3.2 Design of the Gasifier for Seismic Loads	3
4.0 DESIGN CONDITIONS	4
4.1 Ambient Conditions	4
4.2 Design Pressure	4
4.3 Design Temperature	4
5.0 LOADINGS	5
5.1 Piping and External Attachments	5
5.2 Thermal Loadings	5
5.3 Abnormal Process Reactions	5
5.4 Seismic Loading	6
6.0 MATERIALS	7
7.0 CORROSION ALLOWANCE	8
8.0 HYDROSTATIC TESTING	9
9.0 PRESSURE RELIEF DEVICES	10
10.0 REFERENCES	11

GPIF PROJECT PyGas™ GASIFIER VESSEL
APPLICABLE ASME BOILER CODE SECTION

SECTION I VS. SECTION VIII, DIV. 1

- SECTION I APPLIES TO POWER BOILERS; PyGas™ VESSEL IS PRIMARILY A PROCESS VESSEL
- SECTION VIII INCLUDES PROVISIONS FOR UNFIRED STEAM BOILERS
- SECTION VIII, DIV. 1 USED AS DESIGN BASIS FOR PROCESS REACTOR VESSELS; SOME ARE USED TO CONTAIN COMBUSTION
 - PFB SYSTEM
- BOLTED CLOSURE RULES INCLUDED IN SECTION VIII, DIV. 1
- OTHER GASIFIER VESSELS CONSTRUCTED IN ACCORDANCE WITH SECTION VIII, DIV. 1
 - GREAT PLAINS GASIFICATION PROJECT
 - PIÑON PINES
- FOR PRESSURE RELIEF, SECTION I IS APPLICABLE TO BOILERS
- MORE STRINGENT HYDROSTATIC TEST REQUIREMENTS PER SECTION VIII, DIV. 1
- FULL RADIOGRAPHY REQUIRED FOR BUTT WELDS PER SECTION VIII, DIV. 1 FOR VESSELS CONTAINING LETHAL GAS

SECTION 2

2.0 SCOPE

Structural design of the PyGas™ vessel includes the following items.

2.1 PRESSURE BOUNDARY COMPONENTS

- Intermediate water-cooled outer shell
- Upper head and air inlet
- Lower head
- Coal inlet shell assembly
- Bolted closures
- Removable coal/air nozzles
- Gas product outlet
- Access penetration
- Other nozzles and penetrations including reinforcement
- Vessel shell support attachments

2.2 INTERNALS REQUIRING STRUCTURAL DESIGN

- Pyrolyzer tube including cooling system
- Water-cooled upper shroud
- Shell cooling system inner wall
- Shell cooling system headers
- Shroud cooling system headers
- Pyrolyzer cooling system headers
- Support of grate
- Grate drive shaft penetration

DESIGN INPUTS REQUIRED FOR
STRUCTURAL DESIGN

- DESIGN PRESSURE
 - MAXIMUM ALLOWABLE WORKING PRESSURE
 - MARGIN
 - DIFFERENTIAL PRESSURE
- DESIGN TEMPERATURE
 - METAL TEMPERATURE
- OPERATIONAL CYCLES
 - PRESSURE TIME HISTORY
 - TEMPERATURE TIME HISTORY
- ABNORMAL PROCESS REACTIONS
 - EXPLOSIONS
- SEISMIC LOADING
 - BOCA 1990

PRESSURE BOUNDARY DESIGN CONDITIONS

- PROCESS CHAMBER
 - 510 PSIG
- COOLING JACKET OUTER SHELL
 - 660 PSIG
- COOLING JACKET INNER SHELL
 - 150 PSID
- DESIGN TEMPERATURE
 - 700°F (METAL TEMP)

HEAD

Tue Jan 10 08:42:06 1995

FE/PIPE Version 2.7

PRESSURE RELIEF DEVICES

- REQUIRED BY CODE

- LIMITS MAX PRESSURE IN VESSEL OR CHAMBER

- 110% P_{DES} - SINGLE DEVICE
- 116% P_{DES} - MULTIPLE DEVICES

- HOW DO WE MEET CODE?

- SELECT DEVICE SIZE
- SELECT LOCATION
- ANALYZE PROCESS TO SHOW PRESSURE LIMITS ARE NOT EXCEEDED
 - INCLUDE EFFECTS OF RELIEF DEVICE, VESSEL CONFIGURATION AND VENT PIPING (LOSSES)

- SET PRESSURE LIMITED TO P_{DES} IN GENERAL

- CERTIFICATION AND STAMPING REQUIRED

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-1

Equipment Name: PyGas™ Coal Gasifier

Equipment No. 1AA-RPV-1

System Name: Coal Gasifier Island

Flowsheet No. 16N25706-40-F-1AA-001

SYSTEM EQUIPMENT SPECIFICS

1. Gasifier & system to be designed per U.S. Patents 5,133,780, & 5,145,490.
2. Provisions for coal, air & steam injection per mass balances columns 7, 9 & 11.
3. Gasifier to operate at 325 psig at pyrolyzer inlet nozzle.
4. Pyrolyzer operating temperature range is 1300°F to 2000°F.
5. Top gas & fixed-bed operating range 1500°F to 2200°F (peak 2300°F).

REV. 1

Gasifier Load Sheet
Gasifier Flows, Pressures, & Temperatures

10/19/95 15:39

	C. System Dry	D. Ready For Ignition	E. Pyrolyzer In Service (Start-up)	F. Fixed-bed Ignited (Start-up)	G. DualBeds In Service 30 psig	H. Steady State 325 psig	H. Steady State Hot Hold (Min Flows)	H. Steady State Future Top Air/Steam
Pyrolyzer Nozzle:								
Coal Convey Line:								
Air Flow (lb/hr) (9b):	-	397	3,175	3,175	3,175	3,969	3,175	3,969
Air Viscosity (Cp):	-	0.04	0.002	0.002	0.024	0.024	0.024	0.024
Kinematic Visc., (cs):	-	13.21	2.45	2.45	1.72	0.84	0.84	0.84
Coke Flow (lb/hr) (8):	-	-	3,969	3,969	-	-	-	-
Coal Flow (lb/hr) (7g):	-	-	-	-	400	4,000	1,774	4,000
Limestone Flow (lb/hr) (7h):	-	-	0	0	0	0	0	0
Air Pressure (psig) (10):	-	30	30	30	30	325	325	325
Air/Coke/Coal Temp. (°F) (10):	-	-	125	125	125	125	125	125
Fluidization Annulus:								
Air Flow (lb/hr) (9c):	-	292	441	441	573	2,919	1,264	2,919
Air Pressure (psig) (9c):	-	-	30	30	30	325	325	325
Air Temp. (°F) (9c):	-	-	400	400	400	400	400	400
Steam Flow (lb/hr):	-	-	-	-	-	-	-	-
Steam Pressure (psig):	-	-	353	353	353	353	353	353
Steam Temperature (°F):	-	-	530	530	530	530	530	530
Outer Char Sampling Annulus:								
Air Flow (lb/hr):	-	750	-	-	-	-	-	-
Air Pressure (psig):	-	30	-	-	-	-	-	-
Air Temp. (°F):	-	400	-	-	-	-	-	-
Steam Flow (lb/hr) (11b):	-	62	62	100	33	417	46	417
Steam Pressure (psig) (11b):	-	-	353	353	353	353	353	353
Steam Temperature (°F) (11b):	-	-	530	530	530	530	530	530
Cone Sweep Steam:								
Steam Flow (lb/hr) (11b):	-	62	62	100	100	250	250	250
Steam Pressure (psig) (11b):	-	-	353	353	353	353	353	353
Steam Temperature (°F) (11b):	-	-	530	530	530	530	530	530
Pyrolyzer Superficial Velocity (fps) (10a):	-	5.44	14.90	8.27	4.55	4.54	2.00	4.54
Top Air/Steam Nozzle:								
Air Flow (lb/hr) (9a):	-	-	-	-	-	-	-	2,200
Air Pressure (psig) (9a):	-	-	-	-	-	-	-	332
Air Temp. (°F) (9a):	-	-	-	-	-	-	-	400
Steam Flow (lb/hr) (11a):	-	-	-	-	-	-	-	778
Steam Pressure (psig) (11a):	-	-	-	-	-	-	-	332
Steam Temperature (°F) (11a):	-	-	-	-	-	-	-	530
Undergrate Blast:								
Air Flow (lb/hr) (9d):	5,193	415	415	1,072	763	5,238	1,596	1,721
Air Pressure (psig) (9d):	30	30	30	30	30	328	328	328
Air Temp. (°F) (9d):	400	400	400	400	400	400	400	400
Steam Flow (lb/hr) (11c):	-	1,662	1,662	482	298	2,032	603	640
Steam Pressure (psig) (11c):	-	31	31	31	31	332	332	332
Steam Temperature (°F) (11c):	-	530	530	530	530	530	530	530
Jacket Heat-up WHB Steams:								
Steam Flow (lb/hr):	5,640	5,640	5,076	4,568	-	-	-	-
Steam Pressure (psig):	353	353	353	353	-	-	-	-
Steam Temperature (°F):	353 (Tsat=435)	530	530	530	-	-	-	-
Excess Jacket Steam Condensed:								
Steam Flow (lb/hr):	-	-	-	-	932	2,330	2,330	2,330
Steam Pressure (psig):	-	-	-	-	353	353	353	353
Steam Temperature (°F):	-	-	-	-	274	274	274	274
Raw Coal Gas Output :								
Coal Gas Flow (lb/hr) (10h):	-	-	-	5,371	6,274	21,155	11,037	19,224
Coal Gas Pressure (psig) (10h):	-	-	-	28	25	319	319	319
Coal Gas Temp. (°F) (10h):	-	-	-	1083	1083	1083	975	1083
Coal Gas HHV (Btu/dscf) (10h):	-	-	-	113	150	149	150	140
Gas Cooling Water Spray:								
Steam & Water Flow (lb/hr) (12a,12b):	-	-	-	0	0	0	0	0
Water Pressure (psig) (12a,12b):	-	-	-	35	35	334	334	334
Water Temp. (°F) (12a,12b):	-	-	-	170	170	170	227	227
Cooled Coal Gas Output :								
Coal Gas Flow (lb/hr) (12):	-	-	-	5,371	6,274	21,155	11,037	19,224
Coal Gas Pressure (psig) (12):	-	-	-	27	27	319	319	319
Coal Gas Temp. (°F) (12):	-	-	-	1083	1083	1083	1083	1083
Coal Gas HHV (Btu/dscf) (12):	-	-	80	91	150	149	150	140

400 Psig DESIGN

PYROLIZER DESIGN SUMMARY					A/C = 1.72
Low Load vs Pressure Relation	Design	W = kP		W = kP ⁿ	
Load, %	100	76	52	87	72
DESIGN PARAMETERS					
Coal flow rate, lb/hr	8000	6071	4142	6969	5756
Limestone flow rate, lb/hr	1884	1430	975	1641	1356
Total Solids Flow, lb/hr	9884	7501	5117	8610	7112
Pressure Scale Down Index, n	—	1.0	1.0	0.5	0.5
Pyrolizer Bed Pressure, psig (linear W/ % load)	400	300	200	300	200
Pyrolizer Bed Pressure, psia (linear W/ % load)	415	315	215	315	215
Pyrolizer Bed Temperature, °F	1600	1600	1600	1600	1600
Total Pyrolizer Air/ Coal Ratio (From Mass Bal. Sheets)	1.72	1.72	1.72	1.72	1.72
Total Pyrolizer Air/ Coal Ratio (Calc. For Heat Req'd.)	1.71	1.82	2.14	1.78	1.90
Total Pyrolizer Air/Solids Ratio	1.39	1.39	1.39	1.39	1.39
Transport Air/Solids Flow Ratio	0.8000	0.8000	0.8000	0.6969	0.5764

SOLID PARTICLE SIZE					
Solid Particle Diameter For Design, mm	3.00	3.00	3.00	3.00	3.00
Solid Particle Maximum Diameter, mm	6.35	6.35	6.35	6.35	6.35
Solid Particle Minimum Diameter, mm	1.00	1.00	1.00	1.00	1.00
Sphericity for Bituminous Coal	0.86	0.86	0.86	0.86	0.86
Sphericity* Coal Particle Design Diameter, mm	2.58	2.58	2.58	2.58	2.58
Sphericity* Coal Particle Maximum Diameter, mm	5.46	5.46	5.46	5.46	5.46
Sphericity* Coal Particle Minimum Diameter, mm	0.86	0.86	0.86	0.86	0.86

FLUIDIZATION VELOCITIES					
Char Density(Assumed), lbm/ft ³	60	60	60	60	60
Voidage @ Minimum Fluidization Condition	0.44	0.44	0.44	0.44	0.44
Minimum Fluid'n Vel. For Design Particle Dia., ft/sec	1.06	1.20	1.40	1.20	1.40
Minimum Fluid'n Vel. For Max. Particle Dia., ft/sec	3.56	4.07	4.88	4.07	4.88
Minimum Fluid'n Vel. For Min. Particle Dia., ft/sec	0.37	0.39	0.42	0.39	0.42
Terminal Velocity For Design Particle Dia., ft/sec	8.89	10.07	11.94	10.07	11.94
Terminal Velocity For Max. Particle Dia., ft/sec	14.14	16.12	19.29	16.12	19.29
Terminal Velocity For Min. Particle Dia., ft/sec	3.95	4.40	5.07	4.40	5.07
Jetting Region Bed Voidage(Rihardson & Zaki)	0.68	0.65	0.61	0.68	0.69
Jetting Region Bed Voidage(Linear Fn(Umf, Ucf & Emf))	0.60	0.57	0.54	0.60	0.61
Fluidiz'n Vel. @ Jet Region Flows & Linear fn Void, ft/sec	3.24	3.24	3.25	3.72	4.52
Bubbling Region Bed Voidage(Richardson & Zaki)	0.73	0.70	0.66	0.74	0.75
Bubbling Region Bed Voidage(Linear Fn(Umf, Ucf & Emf))	0.65	0.62	0.58	0.65	0.66
Fluidiz'n Vel. @ Linear fn. void & Py. Flows, ft/sec	3.96	3.98	4.01	4.56	5.58
Bubbling Region Bed Voidage(Jovanovic - Fast Bubble)	0.68	0.68	0.68	0.71	0.74
Fluidiz'n Vel. @ Jovanovic Void & Py. Flows, ft/sec	4.48	5.06	5.98	5.40	6.97

GPIF

PAGE: 1 OF 4

PYROLIZER DESIGN SUMMARY**A/C = 1.72**

Low Load vs Pressure Relation	Design	W = kP		W = kP ⁿ	
Load, %	100	76	52	87	72
INNER JET					
Solids Transport Air (Inner Jet) Flow, lb/hr	7907	6000	4094	6000	4099
Solids Transport Air Pr. @ Injection pt., psig	400	300	200	300	200
Solids Transport Air Temp. @ Injection pt., °F	125	125	125	125	125
Solids Transport Air (Inner Jet) Flow, ft ³ /sec	1.152	1.152	1.152	1.152	1.154
Solids Transport Pipe (2-1/2" Sch.160) ID, in.	2.125	2.125	2.125	2.125	2.125
Air Vel. @ Solids Transport Pipe Exit (Vi), ft/sec	46.8	46.8	46.8	46.8	46.8

OUTER JET

Total Outer Jet Air Flow, lb/hr	5868	4453	3038	6000	5812
Air Temperature @ Injection pt., °F	400	400	400	400	400
Total Outer Jet Air flow, ft ³ /sec	1.257	1.257	1.257	1.693	2.405
Outer Jet Air Annulus Gap, in.	0.4755	0.4755	0.4755	0.475	0.475
Outer Jet Air Pipe (4" Sch.80) ID, in.	3.826	3.826	3.826	3.826	3.826
Outer Jet Air Superficial Vel. in Annulus, ft/sec(Vo)	36.2	36.2	36.2	48.7	69.2

CHAR REMOVAL ANNULUS

Total Fluidizing Steam Flow, lb/hr	1334	1012	691	1162	960
Steam Pressure @ Injection pt. °F	400	300	200	300	200
Steam Temperature @ Injection pt., °F	610	610	610	610	610
Total Fluidizing Steam flow, ft ³ /sec	0.57	0.57	0.57	0.66	0.79
% Of Total Fluidizing Steam Through Annulus	70	70	70	70	70
Steam Flow Through The Char Removal Annulus, lb/hr	934	709	483	813	672
Char Removal Annulus Gap, in.	1.25	1.25	1.25	1.25	1.25
Char Removal Annulus Outer Pipe ID, in.	8.063	8.063	8.063	8.063	8.063
Superficial Velocity in Char Removal Annulus, ft/sec(Va)	1.64	1.64	1.64	1.88	2.27
Multiplying factor of U _{mf} for Va	1.54	1.37	1.16	1.57	1.62

SPARGER # 1

Design Steam Flow For Each Sparger 1 & 2, lb/hr	560	425	290	488	403
Design Steam Flow For Each Sparger 1 & 2, ft ³ /sec	0.240	0.240	0.240	0.275	0.333
Sparger annulus 1 outer pipe (5" sch80) ID, in.	4.813	4.813	4.813	4.813	4.813
Sparger annulus 1 gap, in.	0.1565	0.1565	0.1565	0.156	0.156
Velocity in the Sparger Annulus 1, ft/sec	15.1	15.1	15.1	17.3	21.0
Number Of Orifices In Sparger 1	12	12	12	12	12
Diameter Of Each Orifice Of Sparger 1, in.	0.22	0.22	0.22	0.22	0.22
Steam Velocity @ Each Orifice Of Sparger 1, ft/sec	73.7	73.7	73.7	84.6	102.4

SPARGER # 2

Sparger Annulus 2 (6" sch80) ID, in.	5.761	5.761	5.761	5.761	5.761
Sparger Annulus 2 gap, in.	0.099	0.099	0.099	0.099	0.099
Velocity in the Sparger Annulus 2, ft/sec	19.6	19.6	19.6	22.5	27.2
Number of Orifices In Sparger 2	12	12	12	12	12
Diameter Of Each Orifice Of Sparger 2, in.	0.25	0.25	0.25	0.25	0.25
Steam Velocity @ Each Orifice Of Sparger 2, ft/sec	58.6	58.6	58.6	67.3	81.4

GPIF

PAGE: 2 OF 4

PYROLYZER DESIGN SUMMARY**A/C = 1.72**

Low Load vs Pressure Relation	Design	W = kP		W = kP ⁿ	
Load, %	100	76	52	87	72
CONICAL GRID					
Steam Flow For Conical Grid, lb/hr	400	304	207	349	288
Steam Flow For Conical Grid, ft ³ /sec	0.17	0.17	0.17	0.20	0.24
Total Number Of Tubes In The Cone	12	12	12	12	12
ID of Each Tube, in.	0.213	0.213	0.213	0.213	0.213
Velocity @ The Exit Of Each Tube, ft/sec	57.4	57.4	57.4	57.4	57.4

JET HEIGHT CALCULATION(YANG'S CORRELATION)

ID of support air annulus outer pipe*7.65, ft	2.439	2.439	2.439	2.439	2.439
Area corresponding to ID of air annulus out. pipe, ft ²	0.0798	0.0798	0.0798	0.0798	0.0798
(Ucf)atmospheric/(Ucf)pressurized Ratio	3.88	3.39	2.82	3.43	2.91
1/(particle density-gas density), ft ³ /lb	0.0111	0.0111	0.0111	0.0111	0.0111
1/(gravity(32.174)*ID of air annul out. pipe),(sec/ft) ²	0.0975	0.0975	0.0975	0.0975	0.0975
Flow area of transport Noz. & air annulus, ft ²	0.0594	0.0594	0.0594	0.0594	0.0594
Equivalent Diameter for flow area, ft	0.2750	0.2750	0.2750	0.2750	0.2750
Jet Momentum based on ID of Annulus, lb/ft-sec²					
Jet Momentum Due To Transport Air, lb/ft-sec ²	1287	977	666	976	668
Jet Momentum Due To Solids, lb/ft-sec ²	1303	958	620	1100	863
Jet Momentum Due to Support Air, lb/ft-sec ²	738	560	382	1017	1399
Total Jet Momentum, lb/ft-sec ²	3328	2495	1669	3093	2931
Overall Jet Ht. based on ID of Air Annulus, ft	8.5	6.9	5.3	7.7	7.0
Overall Jet Ht. based on equiv. ID of flow area, ft.	8.4	6.9	5.2	7.7	6.9

JET BUBBLE SIZE & JET HALF ANGLE

Total air through jet nozzle, lb/hr	13775	10453	7132	12000	9912
Pyrolizer Bed Pressure, psig	400	300	200	300	200
Pyrolizer Bed Temperature, °F	1600	1600	1600	1600	1600
Air Density @ Bed Pr. & Temp., lb/ft ³	0.5433	0.4123	0.2813	0.412	0.281
Total Jet Air Volumetric flow, ft ³ /sec	7.042	7.042	7.042	8.084	9.787
Bubble Dia. based on Bosev et al(1969), in.	17	17	17	18	19
Bubble Dia. based on Davidson & Harrison, in.	17	17	17	18	19
Max. Bubble Dia. based on volume of Jet air & Umf, in	25	23	21	25	25
Bubble Vol. based on Bosev et al(1969), in.	1.54	1.54	1.54	1.80	2.24
Bubble Vol. based on Davidson & Harrison, in.	1.49	1.49	1.49	1.76	2.21
Max. Bubble Vol. based on Max. bubble Dia., in	4.55	3.80	2.99	4.68	4.89
Jet half Angle based on Bosev et al., deg	3.6	4.4	5.7	4.2	5.1
Jet Half Angle based on Davidson & Harrison, in.	3.5	4.3	5.7	4.2	5.1
Jet half Angle based on Max. bubble Dia., deg	5.7	6.4	7.6	6.3	7.1
Bubble Rise Vel., ub, ft/sec (Eqn 12.6-Davidson)	4.80	4.80	4.80	4.94	5.13

GPIF

PAGE: 3 OF 4

PYROLIZER DESIGN SUMMARY					A/C = 1.72
Low Load vs Pressure Relation	Design	W = kP			W = kP^n
Load, %	100	76	52	87	72
CHECK ON SOLIDS RESIDENCE TIME ABOVE THE JET TOP FOR 100% DEVOLATILIZATION					
Avg. Solids Residence Time Above the Jet, min.	12.75	12.02	20.86	9.10	11.13
Time Req'd. For 100% Devolatilization (Pillai, 1981)	Coal Analysis Used				
Coal Type	In Mass Bal. A-8	Fl. Martin	Fl. Martin	Fl. Martin	Fl. Martin
		Mapco#2	Mettiki#2	Consol#2	
Free Swelling Index(FSI) of the Coal	Assume <6	Assume >6	3.5	9	7.5
Coal Volatiles, % (dry ash free)	36.4	36.4	41.0	21.6	40.0
Average Bed Temperature, °F	1600	1600	1600	1600	1600
Design Particle Size With Sphericity, mm	2.58	2.58	2.58	2.58	2.58
Time for 100% Devolatilization, tv—press., min.	0.23	0.62	0.22	0.54	0.59
Maximum Particle Size With Sphericity, mm	5.46	5.46	5.46	5.46	5.46
Time for 100% Devolatilization, tv—press., min.	0.44	0.118	0.39	0.91	1.09
Minimum Particle Size With Sphericity, mm	0.86	0.86	0.86	0.86	0.86
Time for 100% Devolatilization, tv—press., min.	0.09	0.24	0.09	0.25	0.25
Conclusion: There is enough Residence Time Above The Jet Top For 100% Devolatilization					

FLOW VELOCITY ALONG THE JET AXIS					
Distance Downstream of Jet Entry, x, ft	25	25	25	25	25
Average Jet Inj. Vel @ Noz. Exit, ft/sec	44.1	44.1	44.1	47.3	54.5
Overall Bed Density, lb/ft^3	21.5	23.3	25.4	21.1	20.5
Flow Velocity @ x along the Jet Axis(Slip Vel.)	1.10	0.92	0.73	1.07	1.06
Terminal Velocity For Min. Particle Dia., ft/sec	3.95	4.40	5.07	4.40	5.07
Terminal Velocity For Design Particle Dia., ft/sec	8.89	10.07	11.94	10.07	11.94
(Jet Flow Vel. + Comp. Fluid Vel.) ft/sec	4.33	4.16	3.98	4.79	5.58
CHAR TO COAL CONCENTRATION ALONG THE JET HEIGHT					
Coal Concentration @ x, lb/ft^3	0.22	0.20	0.17	0.20	0.17
Diff. bet. Char Conc. in Bed & Jet Axis, lb/ft^3	12.24	15.96	22.16	14.19	16.93
Char Concentration @ x, lb/ft^3	8.94	7.12	3.11	6.66	3.35
Distance from jet nozzle on Jet Axis @ 0.5 sec, ft	5.2	4.8	4.3	5.2	5.1
Char./Coal Conc. @ time = 0.5 sec	-35	-57	-102	-50	-77
Distance from jet nozzle on Jet Axis @ 1 sec, ft	7.4	6.8	6.0	7.3	7.3
Char./Coal Conc. @ time = 1 sec	-27	-46	-92	-41	-66
Time To Reach Top of Jet Height, sec	1.3	1.1	0.8	1.1	0.9
Char./Coal Conc. @ Top of jet	32	32	30	32	34
Time To Reach Top of Pyrolizer, sec	14	17	21	14	14
Char./Coal Conc. @ Top of Pyrolizer	37	28	2	27	7
Along the Jet Axis, Residence Time Above Jet Top, sec	12.64	15.63	20.32	13.01	13.35

SUPERFICIAL GAS VELOCITY PROFILE					
Gas Flow @ Pyrolizer Bottom, lb/hr	15109	11466	7822	13162	10871
Gas Temperature @ Pyrolizer Bottom, °F	1600	1600	1600	1600	1600
Gas Velocity in Pyrolizer(21"Dia) ft/sec	3.24	3.24	3.25	3.72	4.52
Pyrolizer Product Gas Flow, lb/hr	19496	14795	10094	16984	14028
Pyrolizer Product Gas Temperature @ Its Outlet, °F	1637	1637	1637	1637	1637
Gas Velocity in Pyrolizer(24"Dia) ft/sec	3.96	3.98	4.01	4.56	5.58
Gas Superficial Vel., Inlet to the inner annulus, ft/sec	5.51	5.33	5.01	6.12	6.96
(Gas+Fines) Velocity, inlet to the inner annulus, ft/sec	7.32	7.08	6.66	8.13	9.25
Gas Superficial Vel., Outlet of the inner annulus, ft/sec	3.11	3.01	2.83	3.45	3.93
(Gas+Fines) Vel., Outlet of the inner annulus, ft/sec	4.12	3.98	3.74	4.57	5.20
Gas Velocity, Fixed Bed Exit, ft/sec	0.44	0.45	0.45	0.51	0.63
Gas Vel. - Outer Annulus @ Shroud Bot., ft/sec	1.07	1.06	1.08	1.22	1.50

GPIF

PyGas™ COAL GASIFIER
PDB No. 40-1AA-1

**MAJOR PHILOSOPHY FOR SAFE OPERATION
(HAZOPS CREDO)**

1. The incinerator/WHB is the primary disposal method of the coal gas.
2. The most environmentally friendly way of consuming coal gas is in the incinerator/WHB.
3. Coal gas produced from the gasifier will normally flow to the incinerator/WHB.
4. Only in an emergency will coal gas be diverted to the flare.
5. The gasifier outlet rupture disk is the code compliant gas pressure relief safety.
6. Venting to the flare is an emergency shut-down operation for equipment & personnel protection.
7. Gasifier testing should only proceed if the incinerator/WHB is in service.
8. The coal preparation system shall be operated as a direct fired system per NFPA.
9. The oxygen concentration leaving the pyrolyzer tube should not be allowed to exceed 1% vol when either the pyrolyzer or the fixed-bed are generating coal gas.
10. The oxygen concentration leaving the fixed-bed should not be allowed to exceed 4% vol whenever either the pyrolyzer or the fixed-bed are generating coal gas.

**NORMAL START-UP,
NORMAL SHUT-DOWN,
EMERGENCY SHUT-DOWN TO INCINERATOR/WHB,
EMERGENCY SHUT-DOWN TO FLARE,
UNCONTROLLED EMERGENCY SHUTDOWN**

The following reflects the conceptualized normal start-up procedure assuming "cold" start-up conditions. It should be anticipated that all safety related interlocks and permissives to include all fail-safe equipment design considerations will be integrated into this plan as the detailed design process continues.

NORMAL START-UP

(Verify all cooling water systems are filled and in operation)

1. START INCINERATOR/WHB AND BRING TO OPERATING CONDITION
2. PROVE GASIFIER WATER JACKET COOLING CIRCULATION
3. NITROGEN PURGE THE GASIFIER INTO THE INCINERATOR/WHB
4. PRE-HEAT GASIFIER JACKET COOLING SYSTEM WITH STEAM
(flow and rate of temperature rise per mechanical design requirements)
WHEN GASIFIER DRUM TEMPERATURE EXCEEDS SATURATION, STEAM
WILL VENT THROUGH THE GRATE PREVENTING PREMATURE IGNITION
OF FIXED-BED. MAINTAIN MINIMUM STEAM FLOW.
5. START AIR COMPRESSOR AND BUILD PRESSURE (within mechanical stress
limit constraints) TO START-UP PRESSURE
(approximately 30 psi gas side pressure)
(air flows into INCINERATOR/WHB);
PROVE INCINERATOR/WHB COAL GAS FLAME SCANNER SEES STABILIZATION
FLAME, AND EMERGENCY FLARE READY PERMISSIVE IS MET
6. PREHEAT PYROLYZER CONE WITH NATURAL GAS (Direct Combustion in
Fluidized Cone) (flow and rate of temperature rise per mechanical design requirements)
UNTIL TEMPERATURE REACHES 1000°F (anticipate several hours)
7. ADJUST PYROLYZER AIR AND STEAM FLOW TO MINIMUM FLUIDIZATION
FLOW RATE (at proper ratio for startup; air flow to reach set point pyrolyzer
operating temperature and steam flow will be required in both the coal conveying and
pyrolyzer fluidization streams)
BYPASS BALANCE OF COMPRESSOR AIR TO ATMOSPHERE (if necessary)
8. ADD COKE, CHAR OR LOW VOLATILE NON-CAKING COAL TO PYROLYZER
AT MINIMUM FLOW RATE
(approximately one tenth of maximum rotary feeder speed)

9. RAISE PYROLYZER TEMPERATURE TO SET POINT (approx. 1600°F), THEN SHUT DOWN DIRECT PRE-HEATING (will likely take several minutes), AND BUILD SOLIDS BED IN PYROLYZER.
10. SWITCH TO TEST COAL WHEN PYROLYZER LEVEL INDICATOR/MONITOR INDICATES PYROLYZER SOLIDS OVERFLOW (prevents caking before bed can accept increased coal flow)
11. AS COAL RATE IS INCREASED, ADJUST PYROLYZER AIR FLOW TO MAINTAIN SET POINT TEMPERATURE, AND DECREASE STEAM FLOW WHILE MAINTAINING ABOVE MINIMUM FLUIDIZATION FLOW (may be automatically controlled)
12. WHEN INDICATOR/MONITOR INDICATES PROPER FIXED-BED SOLIDS LEVEL, TURN ON GRATE AIR AND INCREASE GRATE STEAM TO MAINTAIN SET POINT PEAK BED TEMPERATURE (approximately 2300°F; may be automatically or manually controlled)
13. GRATE ROTATION IS INITIATED WHEN INDICATOR/MONITOR INDICATES HIGH SOLIDS LEVEL
14. GRATE SPEED IS PROPORTIONED BY COAL FEED RATE AND TRIMMED BY ABOVE GRATE TEMPERATURE SET POINT (decreases speed as temperature increases, and the reverse)
15. HIGH INNER ANNULUS DELTA PRESSURE OVERRIDES TEMPERATURE CONTROL OF GRATE SPEED AND INCREASES GRATE SPEED UNTIL INDICATOR/MONITOR INDICATES LOSS OF BED LEVEL. HIGH ABOVE GRATE TEMPERATURE INCREASES GRATE STEAM FLOW.

NORMAL SHUT-DOWN

1. RAMP OPERATING PRESSURE TO 30 PSI.
(rate of temperature decline per mechanical design requirements)
2. REDUCE COAL FEED TO MINIMUM FEED RATE (Approximately 10%).
3. STOP COAL FEED.
4. PURGE PYROLYZER INVENTORY; CONTROL PYROLYZER OPERATING TO 1500°F TO PREVENT AGGLOMERATION
5. START DIRECT PRE-HEAT NATURAL GAS BURNER TO CONTROL RATE OF PYROLYZER CONE TEMPERATURE DECLINE IF NECESSARY
(rate of temperature decline per mechanical design requirements)
6. STOP AIR FLOW TO PYROLYZER. AS PYROLYZER TEMPERATURE DECREASES, REDUCE STEAM FLOW (may be automatic)
7. ALLOW FIXED-BED TO BURN-OUT CONTROLLING PEAK BED TEMPERATURE AT SETPOINT
8. STOP ALL AIR FLOW & INDIRECT HEATER & CONTINUE REDUCING STEAM FLOW THROUGH PYROLYZER & GRATE UNTIL ITS TEMPERATURE IS CLOSE TO WATER JACKET (rate of temperature decline per mechanical design requirements); THEN STOP STEAM FLOW & PURGE WITH NITROGEN.
9. REMOVE REMAINING SOLIDS FROM FIXED-BED VIA THE GRATE AND PRESSURE LOCKS
10. CONTINUE NITROGEN FLOW THROUGH GRATE UNTIL ITS TEMPERATURE IS CLOSE TO WATER JACKET; THEN STOP NITROGEN FLOW
11. INERT WITH NITROGEN, AND ISOLATE WITH A NITROGEN BLANKET TO PROTECT AGAINST FIRES AND CORROSION
(important note: bypass this step if personnel expect to enter system within 2 days)
12. SHUT DOWN THE INCINERATOR/WHB
13. CLOSE FLUE GAS ISOLATION DAMPER TO FT MARTIN
14. SHUT DOWN ALL WATER COOLING CIRCUITS
15. NITROGEN BLANKET ALL WATER CIRCUITS TO PROTECT AGAINST CORROSION
(important note: bypass this step if personnel expect to enter system within 2 days)
16. WHEN COOL, AIR PURGE SYSTEM THROUGH THE INCINERATOR/WHB PRIOR TO ALLOWING ANY PERSONNEL ENTRY INTO THE SYSTEM.

CONTROLLED EMERGENCY SHUTDOWN TO INCINERATOR/WHB

INITIATED AUTOMATICALLY OR BY OPERATOR

COVERS THE FOLLOWING CASES:

1. LOSS OF COAL FEED
2. WATER LEAK INTO SHELL
3. HIGH TEMPERATURE ALARM ON GASIFIER OUTLET

PROCEDURE:

1. STOP COAL AND AIR COMPRESSOR
2. DEPRESSURIZE SYSTEM TO INCINERATOR/WHB AT A CONTROLLED RATE
USING STEAM
(rate of pressure decline per mechanical design requirements)
3. REDUCE STEAM TO PYROLYZER & GASIFIER TO MINIMUM
4. CLOSE FLUE GAS ISOLATION DAMPER TO FT MARTIN
5. DRAIN PYROLYZER CHAR THROUGH ASH LOCK SYSTEM
6. INERT WITH NITROGEN
(important note: bypass this step if personnel expect to enter system within 2 days)
7. EITHER CONTINUE SHUT-DOWN FOLLOWING NORMAL SHUT-DOWN
PROCEDURES, OR LEAVE SYSTEM BLANKETED UNTIL READY FOR
RESTART (OPERATOR DECISION)

CONTROLLED EMERGENCY SHUTDOWN TO FLARE (OR INCINERATOR/WHB STUB STACK)

INITIATED AUTOMATICALLY OR BY OPERATOR

COVERS THE FOLLOWING CASES:

1. LOSS OF ELECTRIC POWER
2. INCINERATOR/WHB GOES DOWN
3. FORT MARTIN GOES DOWN

ITEMS IN THE PROCEDURE ARE LISTED SEQUENTIALLY,
HOWEVER, EVENTS 1 THRU 4 ARE SIMULTANEOUS
(by control system)

PROCEDURE:

1. TRIP AIR COMPRESSOR
2. STOP COAL AND AIR TO GASIFIER
3. OPEN FLARE (OR INCINERATOR/WHB STUB STACK) CONTROL VALVE
AND DEPRESSURIZE SYSTEM AT A CONTROLLED RATE
(rate of pressure decline per mechanical design requirements)
4. DEPRESSURIZE SYSTEM TO INCINERATOR/WHB AT A CONTROLLED RATE
USING STEAM (rate of pressure decline per mechanical design requirements)
5. REDUCE STEAM TO PYROLYZER & GASIFIER TO MINIMUM
6. TRIP VENT SYSTEM
7. CLOSE FLUE GAS ISOLATION DAMPER TO FT MARTIN
8. DRAIN PYROLYZER CHAR THROUGH ASH LOCK SYSTEM
9. INERT WITH NITROGEN
(important note: bypass this step if personnel expect to enter system within 2 days)
10. CLOSE FLARE (OR INCINERATOR/WHB) CONTROL VALVE AND LEAVE
SYSTEM UNDER NITROGEN BLANKET
(important note: bypass this step if personnel expect to enter system within 2 days)
11. EITHER CONTINUE SHUT-DOWN FOLLOWING NORMAL SHUT-DOWN
PROCEDURES, OR LEAVE SYSTEM BLANKETED UNTIL READY FOR
RESTART (OPERATOR DECISION)

UNCONTROLLED EMERGENCY SHUTDOWN

INITIATED AUTOMATICALLY

COVERS THE FOLLOWING CASES:

1. PRESSURE RELIEF THROUGH RUPTURE DISK

ITEMS IN THE PROCEDURE ARE LISTED SEQUENTIALLY,
HOWEVER, EVENTS 1 THROUGH 6 ARE SIMULTANEOUS
(by control system)

PROCEDURE:

1. TRIP AIR COMPRESSOR
2. STOP COAL AND AIR TO GASIFIER
3. TRIP INCINERATOR/WHB
4. CLOSE FLUE GAS ISOLATION DAMPER TO FT MARTIN
5. INERT GASIFIER WITH STEAM
6. INERT WITH NITROGEN
7. CONTINUE SHUT-DOWN FOLLOWING NORMAL SHUT-DOWN PROCEDURES

**STATES /Sub-states SUBSYSTEM STATUS
 (TRANSITIONS)**

CONSTRAINTS

**Locked Out
 (Inerted/Idle)**

All systems locked out.

Warning alarm permissive.

A Ready for Start-up All systems ready.

All permissives met.

**System Purged
 (Idle/Purge)**

Incinerator/WHB then gasifier are
 air purged using induced draft fan.

Prerequisite to personnel entry.
 O2 test must prove air present.
 Flue gas isolation damper to Ft.
 Martin then closed. ID fan then
 tripped & proven shut down.

**Precharged
 (Purge/Pre-Charge)**

Fixed-bed is manually loaded
 with startup materials.

Breathing air introduced into
 gasifier. Other gasifier
 systems locked-out.

**Nitrogen Purged
 (Pre-Charge/Inerted)**

Nitrogen system on with continuous
 flow through gasifier out flare stack
 until O2 < 5%.

This step not necessary if startup is
 imminent (within one day).

**Water Filled
 (Inerted/Water Filled)**

WHB water drum level proven.
 Gasifier water drum level proven.

Condensate water (110°F max) used
 to fill both WHB circuits & gasifier
 jacket prior to start-up.

**Water Circulating
 (Water Full/Circ.)**

WHB circulating water pump on.
 Gasifier circulating water pump on.

Proven water circulation is a WHB
 & gasifier start-up permissive.

B WHB in Service Generating Steam at 353 psig/530°F

WHB prerequisite to Gasifier opn.

**Incinerator Spt Fuel Burn
 (Idle/WHB In Service)**

Incinerator firing on support fuel.

Boiler drum water temperature rise
 rate during start-up of 100°F/hour.

**Start-up System :
 Cold Stand-by
 (Circ./Ready)**

Air compressor on and receiver at minimum
 pressure (in venting mode).

Gasifier purging and drying-out
 with compressed air decompressing
 through system to Incinerator/WHB.

**Steam Pre-heat Method
 (Ready/Pre-heat)**

Jacket water heater and pump is in service.
 Steam the cooling circuit to pre-heat water.

Water jacket and gasifier water cooled
 internals always at slightly higher
 pressure than gasifier gas side (well
 within maximum full load differential
 pressure). Rate of gasifier drum
 water temperature rise limit is 100°F
 per hour.

STATES /Sub-states (TRANSITIONS)	SUBSYSTEM STATUS	CONSTRAINTS
Alternate Start-up System Gas Pre-heat Method (Ready/Pre-heat)	Unheated jacket water (approx. 110°F). Indirect natural gas pre-heat burner in service. 1200°F heated compressed air entering pyrolyzer.	WHB must be in service. Heat water until rate of gasifier drum temperature rise becomes less than 100°F per hour. Then add "shot of solid fuel" to pyrolyzer. When pyrolyzer temperature starts to rise, set solid fuel feed rate to minimum. Raise gasifier cooling water temperature at 100°F per hour until steam pressure exceeds air pressure.
C System Dry	Pre-heat in Service.	530°F Superheated Steam available.
Cone Air Pre-heat (Ready/Cone Pre-heat)	Introduce pre-heated air into pyrolyzer and steam & nitrogen into fixed-bed. Use jacket.auxiliary indirect air pre-heater & sand to heat pyrolyzer refractory.	Pressure balance maintained between jacket & gasifier. Also between nitrogen and air flows. Flow and pressure dependent upon pressure letdown system. Steam/nitrogen maintained below minimum fluidization velocity in fixed-bed. Preheater output. Materials thermal stress constraints. Maintain steam/nitrogen purge in the fixed-bed to prevent premature ignition and moisture condensation. Pressure ramp limited by gasifier steam condensation temperature. Gasifier train through WHB must be above condensation temperature.
D Ready for Ignition	Pre-heat system in operation.	1000°F cone temperature reached by burning natural gas in fluidized cone.
Coke Pre-heat (Cone PH/Coke PH)	Conveying coke with hot air and sustain substoichiometric air to heat the pyrolyzer.	Maintain velocities below the point of solid fuel feed carryover during building of pyrolyzer solids inventory. Maintain maximum combustion temperatures below ash fusion temperatures by introducing annular steam flow when necessary. Maintain minimum fluidization of solids.

STATES /Sub-states (TRANSITIONS)	SUBSYSTEM STATUS	CONSTRAINTS
Bed-building (Coke PH/Bed Bldg)	Build coke bed in pyrolyzer sufficient to obtain coke ignition while continuing to pre-heat the pyrolyzer. Continue conveying coal/coke to completely fill the pyrolyzer. Shut down pyrolyzer cone pre-heater.	Coke feed rate. Solids entrainment velocity. Minimum fluidization velocity. Coke bed level below the water walls to minimize heat losses until ignition is achieved. Maintain sufficient oxygen to offset increased heat losses due to water walls. Maintain velocities below the point of jet penetration through the bed to prevent hot char carryover. Maintain temperatures above dew-point of sulfur when feeding coal.
E Pyrolyzer in Service	Char/Air/Steam feed to pyrolyzer.	Char inventory built.
Direct Grate Heating Hot Char (Bed-Bldg/Grate Ign)	Allow hot pyrolyzer char to overflow the pyrolyzer and fall onto the grate below. Operate grate for at least one revolution.	Pyrolyzer temperature >1200°F. Grate Oxygen concentration <4%. Assure hot char distribution.
F Fixed-bed Ignited	Char/Air/Steam feed to fixed-bed.	Several feet of hot char (at 1600°F) inventory built on fixed-bed.
Fixed-bed Building (Grate Ign/Bed Bldg)	Ignite fixed-bed. Start flow of air and steam under the grate. Pyrolyzer char overflowing.	Adjust air flow to retain the combustion zone within the bed (ie no oxygen breakthrough). Adjust steam to keep peak temperature below ash fusion temperature. Maintain grate rotation to ensure uniform solids bed temperature profile.

**STATES /Sub-states SUBSYSTEM STATUS
(TRANSITIONS)**

G Dual-beds in Service Char/Air/Steam feed to pyrolyzer
and fixed-bed.

Pressure Ramp Incrementally increase the pressure by
(Bed Bldg/Pres Ramp) increasing throughput.

Coal Feed Switching from coke to coal feed.
(Pres Ramp/Coal Feed)

H Steady State All test load required systems in service.

Gasification Low sulfur bituminous coal.
(Coal Feed/Gasification)

CONSTRAINTS

Oxygen at outlet < 4% vol.

Fluidization air flow in fluid-bed.
Stay below fines entrainment
velocity. Avoid channeling in fixed-
bed by maintaining sufficient grate
steam flow to maintain peak fixed-bed
temperatures below ash fusion
temperature. Maintain water jacket
and gasifier pressure balance. Adjust
air flows in fixed-bed and air/coke
ratio in pyrolyzer to compensate for
higher wall temperatures and lower
heat losses at lower pressures by
maintaining set-point temperatures.
coke feed ramp. Balance input
flows in fixed-bed to prevent gases
from penetrating the fixed-bed.

Adjust the coal/coke, air and steam
flows in the nozzle to maintain
desired reaction temperature.
Maintain fluidization and sub-
entrainment velocity in the pyrolyzer.
Maintain desired pyrolyzer jet
penetration momentum by operating
at appropriate coal/air/steam flows.

No transients.

Adjust the grate speed to keep the bed
level from raising above the shroud
(high bed level) during tests which do
not call for inner annulus solids
inventory (initial tests). Adjust the
grate air flow to consume carbon
laden ash. Adjust grate steam flow
to control peak fixed-bed temperature
below the ash fusion temperature.
Increase low solids bed-level by
reducing grate speed. Raise peak
fixed-bed temperature elevation by
increasing grate air/steam flow.
Lower peak fixed-bed temperature
elevation by reducing grate air/steam
flow (within ash carbon loss
limitations).

STATES /Sub-states SUBSYSTEM STATUS
(TRANSITIONS)

CONSTRAINTS

Hot Hold (Stdy State/Min Opn)	Minimum pyrolyzer coal feed & fluidization. Pyrolyzer air flow at minimum operating temperature. Minimized fixed-bed air, steam, & bottom ash (grate speed) flows.	Coal caking characteristics will affect minimum pyrolyzer velocities and operating temperature. When fixed-bed combustion zone moves up-ward to top of bed and temperature cannot be maintained, stop under-grate air & steam flows. When fixed-bed temperature becomes reduced to below 800°F, abort test and shut-down.
Co-flow Bed Building (Gasif/CF Bed Bldg)	Adjust the grate speed to raise the fixed-bed level above the shroud.	Avoid high pressure drop in the inner annulus. Avoid filling outer annulus with solids to gasifier outlet gas nozzle.
Sub-bituminous Coal Gasification (CF Bed Bldg/Sub-bit Gasif)	Switching from coke to sub-bituminous coal.	Adjust the coal/coke, air and steam flows in the nozzle to maintain desired reaction temperature. Maintain fluidization and sub-entrainment velocity in the pyrolyzer. Maintain desired pyrolyzer jet penetration momentum by operating at appropriate coal/air/steam flows.
High Sulfur Bituminous Gasification (CF Bed Bldg/Bit Coal Gasif)	Switching from coke to high sulfur bituminous coal	Not an option unless previous testing with limestone proves sufficient sulfur capture, or previous testing with Phase II HGCU provided sufficient sulfur capture. Adjust the coal/coke, air and steam flows in the nozzle to maintain desired reaction temperature. Maintain fluidization and sub-entrainment velocity in the pyrolyzer. Maintain desired pyrolyzer jet penetration momentum by operating at appropriate coal/air/steam flows.
Coal Plus Limestone Gasification (Coal Gasif/Sorb Feed)	Co-feeding of pressure lock with coke and limestone.	Wall temperatures above lime hydration temperature. Do not feed limestone at flow rates which produce low temperature eutectics when combined with coal ash (prior ash analysis information required).
Top Injection (Sorb Feed/Top Air Injection)	Introduce Air and/or steam into top injector.	Max. temperature below ash fusion temperature. Materials temperature constraint. Insure top air/steam injector has been added to system.

**STATES /Sub-states SUBSYSTEM STATUS
 (TRANSITIONS)**

CONSTRAINTS

I Test Complete All test load required systems in service.

No transients.

J Minimum Pressure Opn Ramp down complete.

30 psig pressure.

Bed Burnout Purge fluid-bed & burn-out fixed-bed.
(TA Inject/Bed Burn) Produce a benign ash.

Low pressure operation similar to start-up sequence. Preclude mixing of reducing and oxidizing gases. Avoid entrainment of solids.

Controlled Shut-down Gradually reduce pressure and temperature
General by decreasing throughput.

Steam from gasifier drum used to balance pressure. Follow bed-burnout.

K Compressor Off Coal feed also off.

Use superheated steam to gasifier outlet to maintain system pressure under controlled pressure ramp-down.

L Locked Out All systems off.

Nitrogen inerted unless personnel entry is anticipated. System cooled to 150°F.

Controlled Emergency Loss of Coal Feed
Shut-down via WHB
(Opn/Cntr Shut-dn WHB)

Follow NORMAL SHUT-DOWN procedure. Extend the process while attempting to reestablish coal feed. If cause is found and corrected, follow NORMAL START-UP procedure from appropriate STATUS STATE.

**Water Leak Into
 Gasifier Vessel**

Follow NORMAL SHUT-DOWN procedure with HRSG incineration.

**High Gasifier Exit
 Gas Temperature**
 Increasing steam flow has failed.

Follow NORMAL SHUT-DOWN procedure. Accelerate the process to reduce operating pressure to a safe level. If cause is found and corrected, follow NORMAL START-UP procedure from point of pressure raising.

**Loss of Gasifier
 Water Cooling**

Follow NORMAL SHUT-DOWN procedure. Accelerate the process. If cause is found and corrected, follow NORMAL START-UP procedure from appropriate STATUS STATE.

**STATES /Sub-states SUBSYSTEM STATUS
(TRANSITIONS)**

CONSTRAINTS

I WHB Trip Could be anywhere in start-up.

Controlled emergency shutdown required. No further testing allowed.

Controlled Emergency Ft. Martin Trip
Shut-down to Flare
or Incinerator Dump Stack
(Opn/Cntr Shut-dn Flare)

Trip WHB. Trip air compressor. Follow NORMAL SHUT-DOWN procedure. Accelerate the process. If cause is found and corrected, follow NORMAL START-UP procedure from appropriate STATUS STATE.

Loss of
Ft. Martin Condensate

Trip Incin. Trip air compressor. Follow NORMAL SHUT-DOWN procedure. Accelerate the process. If cause is found and corrected, follow NORMAL START-UP procedure from appropriate STATUS STATE.

Incinerator/WHB - Trip

Incinerator/WHB has tripped. Trip air compressor. Follow NORMAL SHUT-DOWN procedure. Accelerate the process. If cause is found and corrected, follow NORMAL START-UP procedure from appropriate STATUS STATE.

Loss of Electric Power

Incinerator/WHB has tripped. Uninterruptable power source (UPS) backup system employed. Accelerate the process. If cause is found and corrected, follow NORMAL START-UP procedure from appropriate STATUS STATE.

I Overpressurization Gasifier rupture disk has relieved.
Flare stack control valve (or Incinerator
stub stack) has opened, and flare stack
(or incinerator stub stack) is in service.

Vent steam to gasifier to control pressure let-down ramp to 180°F per hour. Isolate and trip air compressor. Stop coal feed. Inert with nitrogen.

10/19/95 15:02

PROCESS STATES MAP - Pyrolyzer in Service to Steady State

PROCESS STATES → E Pyrolyzer in Svcs 1.7 hrs F Fixed-bed Ignited 0.3 hrs G Dual-bed in Svcs 0.3 hrs H Steady State Total Svcs

Process Transitions → Fixed-bed Light-off Initial Grate Rotation Pressure Raising

PROCESS STATES MAP - Test Completed Normal Shut-down

LEGEND:

PROCESS STATES HANDLE NAMES: H=HOLD
 STATE TRANSITIONS: A.R.C. etc.
 KEY CONSTRAINTS: < >
 OPTICAL PROCESS VARIABLES: OPT VAR
 DRAWING MECHANISMS: New Unit
 WHB STEAM FLOW: HSB
 GASIFIER STEAM FLOW: GSB
 NITROGEN FLOW: NBN
 COMP. PROG. AIR FLOW: AAAA
 TRANSITION DRIVING MECHANISMS: < >
 OPERATIONAL: < >
 EXCESS HEAT: BSB

162

PROCESS STATES MAP - Emergency Shut-down via Flare Stack

PROCESS STATES MAP - Emergency Shut-down via Flare Stack

PROCESS STATES

- I Lockout Out
- J Mtn. Pressure Opn.
- K Compressor Off
- L Locked Out

163

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1AA-2

System Name Gas Clean Up System
Flowsheet No. 16N25706-40-F-1AA-002

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1AA-2

System Name Gas Clean Up System
Flowsheet No. 16N25706-40-F-1AA-002

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-2

System Name Gas Clean-Up System
Flowsheet No. 16N25706-40-F-1AA-002

I. DESIGN PHILOSOPHY

1. The purpose of the Gas Clean-Up System is to remove gasifier char fines from the coal gas stream. The fines are removed from the gas stream by a cyclone prior to the gas entering the incinerator.
2. Space for a future backup cyclone system has been saved in the building.
3. Each cyclone is designed to the following specifications:
 - a. Coal Gas Flow Rate = 18,878 Lbs./Hr. (19,822 Lbs./Hr. Maximum. See Note 9 Under Design Notes)
 - b. Fines Flow Rate to Cyclone = 83 Lbs./Hr. (Normal)
500 Lbs./Hr. (Maximum)
 - c. Total Gas and Fines = 18,961 Lbs./Hr. (Normal)
20,322 Lbs./Hr. (Maximum)
 - d. Actual Cubic Feet Per Minute = 665 ACFM @ 18,878 lbs/hr
 - e. Temperatures:
Normal = 1023°F
Maximum = 1100°F
 - f. Pressure: To Cyclone
Normal = 324 PSIG
Maximum = 420 PSIG
 - g. Fines Removal Efficiency = 90%
(Actual will be Based on Vendor Selection)

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-2

System Name Gas Clean-Up System
Flowsheet No. 16N25706-40-F-1AA-002

h. Fines Particle Size Distribution

Diameter <u>MM</u>	<u>Microns</u>	Weight % <u>Less Than</u>
0.180	180	100
0.150	150	91
0.125	125	84
0.106	106	80
0.073	73	67
0.043	43	53
0.010	10	31

i. Solids Particle Density = 60 Lb./Ft.³

j. Gas Composition

	<u>Inlet Gas</u> <u>Wt %</u>
CO	25.41
H ₂	1.39
CO ₂	10.48
H ₂ O	11.23
CH ₄	0.50
H ₂ S	0.64
N ₂	48.97
AR	1.10
NH ₃	<u>0.28</u>
	100.00

k. Gas Molecular Weight = 23.25

l. Materials of Construction:

Shell - Carbon Steel
Lining (Approximate) - 3" refractory layer for insulation and 3" refractory layer for abrasion (assuming a cyclone outside metal surface temperature of less than 270°F)

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-2

System Name	<u>Gas Clean-Up System</u>
Flowsheet No.	<u>16N25706-40-F-1AA-002</u>

Outlet Tube -	Stainless Steel
Inlet Nozzle -	Refractory lined transition, round to rectangular

The exact material thicknesses will be determined by vendor.

m. Pressure drop across the cyclone will be determined by vendor at time of purchase.

4. Gasifier char fines that discharge from the bottom of the cyclone are collected in a Cyclone Fines Lock Hopper. Fines from the lock hopper fall into a Fines Cooling Conveyor Feed Hopper where they are fed to and cooled by the Fines Cooling Conveyor. Cooled fines discharge onto a Cyclone Fines Weigh Belt Feeder for weighing and conveying into the Ash Bucket Elevator. Samples of the fines are also taken from the weigh belt feeder.

The Ash Bucket Elevator delivers a mixture of fines and bottom ash to an Ash Silo. The fines/ash mixture flows through a dustless rotary conditioner and falls into a truck for delivery to a landfill.

This process design basis document ends at the outlet of the Fines Cooling Conveyor as shown on pages 1 and 2. (See Process Design Basis 40-1AA-4 for weight belt feeder, bucket elevator and ash silo.)

5. The following is a description of the Gas Clean-Up System Operation.

- a. Cyclone Fines Collecting System

- 1) Start fines cooling conveyor. Open cooling water supply valve(s) to conveyor (line 15 on sketch, page 2).
- 2) The initial starting of the Cyclone Fines Lock Hopper requires a hopper warm-up sequence that brings the hopper's internal temperature to a temperature approaching that of the hot nitrogen. All valves surrounding the lock hopper are closed except the nitrogen fill Valve 9 and the lock hopper vent Valve 8. This allows hot nitrogen to pass through the lock hopper for vessel warming.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-2

System Name	<u>Gas Clean-Up System</u>
Flowsheet No.	<u>16N25706-40-F-1AA-002</u>

- 3) After initial hopper warm-up the vent Valve 8 is closed while the nitrogen Valve 9 remains open to fill the hopper to its required internal pressure. This pressure will be 2 PSI to 10 PSI below the cyclone operating pressure to induce fines flow to the lock hopper and minimize fines re-entrainment when gas is displaced by solids. Once pressure is reached nitrogen Valve 9 is closed.
- 4) Positive pressure sealing inlet Valve 4 is opened then inlet Valve 3 is opened to allow cyclone fines to fall into the lock hopper.
- 5) When hopper level has reached its desired height of 70% full, inlet Valve 3 is closed followed by positive pressure sealing inlet Valve 4. Lock hopper filling time is based on percent of rated load of gasifier and lock hopper volume and will vary with cyclone particulate loading. (See Note 4).
- 6) After Valves 3 and 4 are closed and the lock hopper is going through its normal fines removal cycle, fines are collecting in the cyclone fines surge hopper located between the cyclone and lock hopper inlet Valve 3.
- 7) The cyclone fines surge hopper collects cyclone fines during the lock hopper's depressurizing and dumping cycle. The surge hopper will have the capacity to store as a minimum the quantity of fines that collect during one lock hopper dump cycle. Re-entrainment of fines by the cyclone's vortex action is also prevented by having the surge hopper located below the cyclone fines outlet. Fines re-entrainment is prevented due to the fact that a cyclone vortex is broken and unable to reach down into the surge hopper.
- 8) Open vent Valve 8 to vent remaining nitrogen/coal gas mixture to vent system. Vent Valve 8 remains open while the lock hopper's internal pressure is reduced to 2 psig or less.
- 9) After pressure constraint is met, open positive sealing dump Valve 5 allowing fines to drop into Fines Cooling Conveyor Feed Hopper. Space has been allocated for a future sealing valve located downstream of Valve 5 as shown on drawing on page 1.
- 10) When the lock hopper is indicated as empty, close dump Valve 5.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-2

System Name Gas Clean-Up System
Flowsheet No. 16N25706-40-F-1AA-002

- 11) The lock hopper cycle time that is required to size the Cyclone Fines Surge Hopper will initially be established by approximation calculations on the lock hopper's vent line. An orifice in the vent line can be field modified based on actual operating tests to increase or decrease lock hopper venting time, therefore minimizing fines carryover to the vent system.
- 12) Open nitrogen fill Valve 9 allowing the lock hopper and vent line to purge for 5 to 10 seconds.
- 13) Close vent Valve 8 and allow the cyclone fines lock hopper to repressurize starting the cycle over.
- 14) The cyclone lock hopper and surge hopper will be designed for the same maximum pressure and temperature as the gasifier.
- 15) At this time fines have been deposited into the low pressure, Fines Cooling Conveyor Feed Hopper. This hopper will be sized to hold 1.5 times the volumetric capacity of the fines lock hopper. The equipment above the feed hopper is going through another cycle. The feed hopper is equipped with a vent Valve 12. If a plug occurs, nitrogen Valve 13 can be opened after Valve 12 is opened to facilitate unplugging hopper. If cracked open Valves 12 and 13 can also be used to cool the fines before they are delivered to the cooling conveyor. Care must be taken to prevent excessive nitrogen flow because of potential fines re-entrainment and carryover to the vent system.
- 16) Fines are removed from the feed hopper by a water cooled, screw type fines cooling conveyor. Fines will be removed at a maximum rate of 500 lbs./hr. and will be cooled from 1100°F maximum to 200°F before being discharged to a weigh belt feeder. Cooling water at a flow determined after equipment purchase will be used to cool the conveyor's screw and outer jacket. The fines cooling conveyor is driven by a variable speed drive.

b. Interlocks

Interlocks are provided to help prevent inadvertent sequencing of the cyclone fines lock hopper valves. The interlocks are as follows:

- 1) The lock hopper fines dump Valve 5 cannot open until pressure in lock hopper is less than 2 psig.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-2

System Name	<u>Gas Clean-Up System</u>
Flowsheet No.	<u>16N25706-40-F-1AA-002</u>

- 2) Lock hopper fines dump Valve 5 cannot open if nitrogen fill Valve 9 is open.
- 3) Lock hopper fines dump Valve 5 cannot open unless vent Valve 8 is open.
- 4) Lock hopper fines dump Valve 5 and lock hopper fines inlet Valves 3 and 4 cannot be open at the same time.
- 5) Lock hopper fines inlet Valves 3 and 4 cannot open if nitrogen fill Valve 9 is open.
- 6) Lock hopper fines inlet Valves 3 and 4 and lock hopper vent Valve 8 cannot be opened at the same time.
- 7) The nitrogen fill Valve 9 cannot be opened if the lock hopper fines inlet Valve 4 or the lock hopper fines dump Valve 5 is open.
- 8) Lock hopper fines inlet Valve 3 cannot be opened until lock hopper fines positive sealing Valve 4 has been opened.
- 9) Dump Valve 5 cannot be opened if water (Line 15) is not proven to fines cooling conveyor screw and conveyor motor is not operating (screw is not turning).
- 10) Dump Valve 5 cannot be opened if low pressure nitrogen Valve 14 is closed.
- 11) The weigh belt feeder and bucket elevator motors will be interlocked to start when fines cooling conveyor motor starts.
- 12) Loss of electricity or instrument air pressure will cause the cyclone fines lock hopper to depressurize by opening vent Valve 8.

c. Miscellaneous

- 1) Nitrogen Valves 10 and 11 are used to purge or unplug fine lines or valves.
- 2) The operator should use caution when using these valves.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-2

System Name Gas Clean-Up System
Flowsheet No. 16N25706-40-F-1AA-002

II. DESIGN CRITERIA

GAS CLEAN-UP SYSTEM - NORMAL 400# GASIFIER OPERATION											
ITEM	Process Stream	Maximum Flow		Normal Flow		Minimum Flow		Maximum Temp. °F	Normal Temp. °F	Maximum Pressure PSIG	Normal Pressure PSIG
Item No.		Gas	Fines	Gas	Fines	Gas	Fines				
1	Coal Gas to Cyclone	* 20.32 M Note 9	500 Lb/Hr	*18.878 M	83 Lb/Hr	* M Note 3	Note 3	1100 Note 1	1023	440	324 Note 10
2	Coal Gas to Incinerator	* 20.32 M Note 9	150 Lb/Hr Note 8	*18.878 M	8 Lb/Hr Note 7	Note 3	Note 3	1100 Note 1	1023	440	321 Note 11
3	Cycl. Fines L.H. Inlet	500 Lb/Hr Note 4		75 Lb/Hr		___ Lb/Hr		1100 Note 1	1023	440	321
4	Cycl. Fines L.H. Inlet	500 Lb/Hr Note 4		75 Lb/Hr		___ Lb/Hr		1100 Note 1	1023	440	321
5	Cycl. Fines L.H. Dump	500 Lb/Hr Note 4		75 Lb/Hr		___ Lb/Hr		1100 Note 1	1023	Note 2	0
6	Cycl. Fines to Cooling Conveyor	500 Lb/Hr Note 4		75 Lb/Hr		___ Lb/Hr		1100 Note 1	1023	10	0
7	Cycl. Fines to Weigh Belt Feeder	500 Lb/Hr Note 4		75 Lb/Hr				220	200	10	0
8	Cycl. Fines L.H. Vent	Note 5		Note 5				1100 Note 1	1023	440	322 Note 13
9	Cycl. Fines L.H. Nitrogen Fill	Note 6		Note 6				465	Hold	374	324
10	Nitrogen Purge - HP	Note 6		Note 6				465	Hold	374	324
11	Nitrogen Purge - LP	Note 6		Note 6				100	Hold	10	2
12	Fines Cooling Conv. F.H. Vent	Hold		Hold		Hold		1100	1023	10	2
13	Nitrogen Purge - LP	Note 6		Note 6				100	Hold	10	2
14	Nitrogen Purge - LP	Note 6		Note 6				100	Hold	10	2
15	Cooling Water In	Note 12		Note 12		Note 12		Hold	Hold	100	Hold
16	Cooling Water Out	Note 12		Note 12		Note 12		Hold	Hold	100	Hold

* M = 1000 Lb/hr

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-2

System Name Gas Clean-Up System
Flowsheet No. 16N25706-40-F-1AA-002

II. DESIGN CRITERIA - Continued

The fines lock hopper system is designed to the following design criteria:

1. Fines Particles:

Fines Particle Density = 60 Lb/Ft³

Fines Bed Density = 25 Lb/Ft³

Note: Particle and bed density is assumed. 25 Lb/Ft³ is based on an assumed voidage of 0.58.

2. Lock hopper and surge hopper will be fabricated from refractory lined carbon steel or non-refractory lined stainless steel per most economical design. If refractory is used the lock hopper's skin temperature will not exceed 240°F. Interconnecting piping will be made of stainless steel.
3. The lock hopper and surge hopper outlet cones will have an angle of 70° from horizontal to help ash flow.

4. Ash Composition:

"Later"

5. Expected composition at expected normal output.

C	52 Lb/Hr
CaO	0 Lb/Hr
Inerts	<u>23 Lbs/Hr</u>
Total Solids	75 Lb/Hr

Composition at normal output taken from 325 psig mass balance dated 5-31-95, stream 14a.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-2

System Name	<u>Gas Clean-Up System</u>
Flowsheet No.	<u>16N25706-40-F-1AA-002</u>

III. DESIGN NOTES

1. 1100°F is based on maximum upset temperature from gasifier.
2. Cyclone fines lock hopper dump valve must hold against maximum pressure in cyclone which is 440 psig. The valve will open normally against 2 psig or less after lock hopper is vented.
3. From 200 psig mass balance. Note: This column does not show minimums at 200 psig operation.
4. 500 Lb./Hr. of fines is the anticipated maximum flow from the cyclone to the lock hopper. 75 Lb./Hr. is the anticipated normal flow to the lock hopper based on the May 31, 1995 mass balance. The lock hopper will be designed for three dump cycles per hour at the 500 Lb./Hr. flow rate. This equates to 167 Lb./Hr. per cycle, at a normal level of 70% full in the lock hopper. The calculated lock hopper size (based on 500 Lb./Hr.) will yield 2.2 hours between cycles at the normal flow rate of 75 Lb./Hr. Operating experience based on actual fines flow will show the optimum cycle time for the lock hopper. It is anticipated that one dump cycle per hour or 167 Lb./Hr. of fines would be optimum for fines removal and minimal valve cycle time.
5. The vent time for a dump cycle will be calculated based on a 1/4" orifice located in the vent pipe adjacent to the lock hopper. The orifice will set the depressurization time and the dump cycle time.
6. Nitrogen fill time of lock hopper will be based on 1/2" pipe and valve(s). Nitrogen purge will be accomplished with 1/2" pipe and valve(s). Pipe and valve size will be re-evaluated based on line loss due to routing.
7. 8 Lb./Hr. based on 90% efficiency from cyclone. Actual efficiency and mass carryover from cyclone will be determined during cyclone purchase.
8. 150 Lb./Hr. based on assumed derated cyclone efficiency of 70%.
9. 20,320 Lb./Hr. includes a 5% margin for equipment sizing on normal coal gas flow of 18,878 Lb./Hr. (stream 12 on mass balance dated June 1, 1995 plus 500 Lb./Hr. of fines in gas, i.e., $1.05 \times 18,878 = 19,822 + 500 = 20,320$).
10. 324 psig taken from mass balance dated May 31, 1995, Stream No. 10L.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-2

System Name	<u>Gas Clean-Up System</u>
Flowsheet No.	<u>16N25706-40-F-1AA-002</u>

11. Assuming 3 psi pressure drop across the Cyclone (324 psig-3 psig = 321 psig).
12. Flow requirements after equipment purchase.
13. Pressure in lock hopper is normally 2 to 10 psig (field adjustable) below cyclone pressure.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom
Ash Cooling Conveyor Feed
Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom
Ash Cooling Conveyor Feed
Hopper, and Bottom Ash Cooling Conveyor)

Flowsheet No. 16N25706-40-F-1AA-004

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

I. DESIGN PHILOSOPHY

1. The Gasifier Ash Handling System is made-up of several key pieces of equipment which are as follows:

- a. Bottom Ash Lock Hopper
- b. Bottom Ash Cooling Conveyor Feed Hopper
- c. Bottom Ash Cooling Conveyor
- d. Weigh Belt Feeder
- e. Ash Bucket Elevator
- f. Ash Silo/Ash Dustless Unloader

Gasifier ash that discharges from the undergrate area of the gasifier is collected in a bottom ash lock hopper. Ash from the lock hopper falls into a bottom ash cooling conveyor feed hopper where it is fed to and cooled by the bottom ash cooling conveyor. Cooled ash discharges onto a bottom ash weigh belt feeder for weighing and conveying into the ash bucket elevator. Samples of the ash are also taken from the weigh belt feeder.

The ash bucket elevator delivers a mixture of ash and fines to an ash silo. The ash/fines mixture flows through a dustless rotary conditioner and falls into a truck for delivery to a landfill.

This System Process Design Basis addresses a. bottom ash lock hopper, b. bottom ash cooling conveyor feed hopper, and c. the bottom ash cooling conveyor only. Other PDB's address the remaining key equipment.

2. The following is a description of the bottom ash collecting system operation.

- a. Bottom Ash Collecting System:

- 1) Start Bottom Ash Cooling Conveyor. Open cooling water supply valve(s) to conveyor (Line 14 on sketch, page 2).
- 2) The initial starting of the Bottom Ash Lock Hopper requires a hopper warm-up sequence that brings the hopper's internal temperature to the temperature approaching that of the superheated steam. All valves surrounding the lock hopper are closed except the steam fill Valve 8 and the lock hopper vent Valve 6. This allows superheated steam to pass through the lock hopper for warming.
- 3) Once the hopper temperature has reached a temperature that closely approaches the superheated steam temperature, shut steam Valve 8 and open nitrogen Valve 7. Nitrogen flow through the lock hopper is for dry out purposes. Dry vessel for 3 to 5 minutes.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

- 4) After initial warm-up and dry-out, close the nitrogen Valve 7 and vent Valve 6. Open steam fill Valve 8 to fill the hopper to its required internal pressure. This pressure will be 2 psi above the gasifier undergrate pressure to minimize coal gas migration and to prevent ash impaction. Once internal hopper pressure is reached, steam Valve 8 is closed.
- 5) Positive sealing inlet Valve 2 is opened, then inlet Valve 1 is opened to allow bottom ash to fall into the Bottom Ash Lock Hopper. Valve 1 blocks ash flow so that Valve 2 can provide positive without having ash on the valve. Lock hopper pressure will then equalize with gasifier pressure.
- 6) When hopper level has reached its desired height of 70% full, inlet Valve 1 is closed followed by positive sealing inlet Valve 2. Hopper filling time is based on rated load of gasifier and lock hopper volume. A gain Valve 1 blocks ash from Valve 2.
- 7) After Valves 1 and 2 are closed and the lock hopper is going through its normal cycle, bottom ash is collecting in the pipe line between the gasifier and the lock hopper's inlet Valve 1. One cycle of fines therefore collect in the pipe.
- 8) Open vent Valve 6 to vent remaining steam/coal gas mixture to vent system. Vent Valve 6 remains open while the lock hopper's internal pressure is reduced to 2 PSIG or less.
- 9) After pressure constraint is met, open positive sealing dump Valve 3 allowing ash to drop into the bottom ash cooling conveyor feed hopper. Space has been allocated for a future sealing valve located downstream of Valve 3 as shown on sketch on page 1.
- 10) When the hopper is indicated empty close dump Valve 3 and vent Valve 6.
- 11) The lock hopper cycle time that is required to size the bottom ash connecting pipeline, i.e., between the gasifier outlet flange and the lock hopper inlet flange, will initially be established by approximation calculations on the lock hopper's vent line. An orifice in the vent line can be field modified based on actual operating tests to increase or decrease lock hopper venting time, therefore minimizing fines carryover to the vent system. The interconnecting pipe will be 10" I.D. stainless steel.
- 12) Open nitrogen purge Valve 10 and allow the vent line to purge for 3 to 4 seconds. Close purge Valve 10.
- 13) Open steam Valve 8 and allow the Bottom Ash Lock Hopper to repressurize, starting the cycle over.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

b. Interlocks

Interlocks are provided to help prevent inadvertent sequencing of the Bottom Ash Lock Hopper valves. The interlocks are as follows:

- 1) The lock hopper ash dump Valve 3 cannot open until pressure in lock hopper is less than 2 psig.
- 2) Lock hopper ash dump Valve 3 cannot open if nitrogen fill Valve 7 or steam fill Valve 8 is open.
- 3) Lock hopper ash dump Valve 3 cannot open unless vent Valve 6 is open.
- 4) Lock hopper ash dump Valve 3 and lock hopper ash inlet Valves 1 and 2 cannot be open at the same time.
- 5) Lock hopper ash inlet Valves 1 and 2 cannot open if steam fill Valve 8 or nitrogen fill Valve 7 is open.
- 6) Lock hopper ash inlet Valves 1 and 2 and lock hopper vent Valve 6 cannot be opened at the same time.
- 7) The steam fill Valve 8 or the nitrogen fill Valve 7 cannot be opened if the lock hopper ash inlet Valve 2 or the lock hopper ash dump Valve 3 is open.
- 8) Lock hopper ash inlet Valve 1 cannot be opened until lock hopper ash positive sealing Valve 2 has been opened. Lock hopper inlet Valve 2 cannot be closed until inlet valve 1 is closed.
- 9) Dump Valve 3 cannot be opened if water (Line 14) is not proven to bottom ash cooling screw and conveyor motor is not operating (screw is not turning).
- 10) Dump Valve 3 cannot be opened if low pressure nitrogen Valve 13 is closed.
- 11) The weigh belt feeder and bucket elevator motors will be interlocked to start when bottom ash cooling conveyor motor starts.
- 12) Loss of electricity or instrument air pressure will cause the bottom ash lock hopper to depressurize by opening vent Valve 6. Inlet valves 1 and 2 will also close.

Gasification Production Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-40-006
Sirrinc Job No. 16N25706

Page No. 6 of 9
Date 2-8-95
Revised 8-28-95
Rev. 1

SYSTEM PROCESS DESIGN BASIS

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

c. Miscellaneous

- 1) Nitrogen Valves 9 and 12 are used to purge or unplug ash lines or valves and the vent line.
- 2) The operator should use caution when using nitrogen purge valves.

Gasification Production Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-40-006
Sirrinc Job No. 16N25706

Page No. 7 of 9
Date 2-8-95
Revised 8-28-95
Rev. 1

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAX FLOW	NORM FLOW	MIN. FLOW	MAX. TEMP. °F	NORM TEMP. °F	MAX. PRESS. PSIG	NORM PRESS. PSIG
1	BOTTOM ASH L.H. INLET	1000 LB/HR NOTE 2 AND 4	832 LB/HR NOTE 1 AND 4	NOTE 3 AND 4	750	560 NOTE 10	440	324 NOTE 7
2	BOTTOM ASH L.H. INLET	1000 LB/HR NOTE 2 AND 4	832 LB/HR NOTE 1 AND 4	NOTE 3 AND 4	750	560 NOTE 10	440	324 NOTE 7
3	BOTTOM ASH L.H. DUMP	1000 LB/HR NOTE 2 AND 4	832 LB/HR NOTE 1 AND 4	NOTE 3 AND 4	750	560 NOTE 10	NOTE 8	2
4	BOTTOM ASH TO BOTTOM ASH COOLING CONVEYOR	1000 LB/HR NOTE 2 AND 4	832 LB/HR NOTE 1 AND 4	NOTE 3 AND 4	750	560 NOTE 10	10	2
5	BOTTOM ASH TO WEIGH BELT FEEDER	1000 LB/HR	832 LB/HR	NOTE 3	220	200	10	2
6	BOTTOM ASH L.H. VENT	NOTE 5	NOTE 5	NOTE 5	750	560 NOTE 10	NOTE 5	326 NOTE 7
7	BOTTOM ASH L.H. NITROGEN FILL	NOTE 6	NOTE 6	NOTE 6	465	HOLD	374	324
8	BOTTOM ASH L.H. STEAM FILL	NOTE 6	NOTE 6	NOTE 6	560	600	374 PSIG	HOLD
9	NITROGEN PURGE - HP	NOTE 6	NOTE 6	NOTE 6	465	HOLD	374	324
10	NITROGEN PURGE - HP	NOTE 6	NOTE 6	NOTE 6	465	HOLD	374	324
11	BOTTOM ASH COOLING CONV. FEED HOPPER VENT	HOLD	HOLD	HOLD	750	560 NOTE 10	10	0
12	NITROGEN PURGE - LP	NOTE 6	NOTE 6	NOTE 6	100	HOLD	10	2
13	NITROGEN PURGE - LP	NOTE 6	NOTE 6	NOTE 6	100	HOLD	10	2
14	COOLING WATER IN	NOTE 9	NOTE 9	NOTE 9	HOLD	HOLD	100	HOLD
15	COOLING WATER OUT	NOTE 9	NOTE 9	NOTE 9	HOLD	HOLD	100	HOLD

Gasification Production Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-40-006
Sirrinc Job No. 16N25706

Page No. 8 of 9
Date 2-8-95
Revised 8-28-95
Rev. 1

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

II. DESIGN CRITERIA - Continued

The Bottom Ash Lock Hopper System is designed to the following design criteria:

1. Ash particles

Ash Particle Density = 60 Lb/Ft³
Ash Bed Density = 40 Lb/Ft³

Note: Particle and bed density is assumed. 40 Lb/Ft³ is based on an assumed voidage of 0.33.

2. Lock hopper will be fabricated from refractory lined carbon steel or non-refractory lined stainless steel per most economical design. If refractory is used the lock hopper's skin temperature will not exceed 240°F Interconnecting piping will be made of stainless steel.

3. The lock hopper outlet cone will have an angle of 70° from horizontal to help ash flow.

4. Ash Composition: Expected composition as an oxide.

SiO ₂	
Al ₂ O ₃	
Fe ₂ O ₃	
TiO ₂	
MgO	"LATER"
MnO	
P ₂ O ₅	
K ₂ O	
CaO	

5. Expected composition at normal output.

C	19 Lb/Hr
CaO	100 Lb/Hr
Inerts	713 Lb/Hr
Total Solids	832 Lb/Hr

Composition at normal output taken from 325 psig mass balance dated 5-31-95, Stream 14.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1AA-3

System Name Gasifier Ash Handling (Bottom Ash Lock Hopper, Bottom Ash Cooling Conveyor Feed Hopper, and Bottom Ash Cooling Conveyor)
Flowsheet No. 16N25706-40-F-1AA-004

III. DESIGN NOTES

1. 832 Lb/Hr of bottom ash taken from 325 psi mass balance, Rev. 0 dated 5-31-95.
2. Maximum ash flow of 1000 Lb/Hr is 20% higher than mass balance ash flow for safety margin.
3. Minimum bottom ash flow is taken from 200 psi mass balance. Absolute minimum will be a function of gasifier turndown at 200 psig operation.
4. The lock hopper will be designed for one dump cycle per hour at 1000 Lb/Hr flow rate. The hopper will go into a dump cycle when the lock hopper level reaches 70% full. Operating experience based on actual ash flow will show the optimum cycle time for the lock hopper.
5. The vent time for a dump cycle will be based on a 1/4" orifice located in the vent pipe line adjacent to the lock hopper. The orifice will set the depressurization time and the dump cycle time.
6. Nitrogen and steam fill time of lock hopper will be based on 1/2" pipe and valve(s). Nitrogen purge will be accomplished with 1/2" pipe and valve(s). Pipe and valve size will be re-evaluated based on line loss due to routing.
7. Internal pressure of bottom ash lock hopper will be approximately 2 psi higher or 326 psig.
8. Bottom ash lock hopper dump valves must hold against maximum pressure in gasifier which is 440 psig. The valves will open normally against 2 psig or less after lock hopper is vented.
9. Flow requirements after equipment purchase.
10. Per Riley.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA - 4

System Name Solid Waste Disposal System

Flowsheet No. 16N25706-40-F-1AA-005

EQUIPMENT

- Cyclone Fines Weighbelt Feeder (Eq. No. 1AA-FDR-1)
- Bottom Ash Weighbelt Feeder (Eq. No. 1AA-FDR-2)
- Fines Sample Container (Eq. No. 1AA-VSL-1)
- Bottom Ash Sample Vessel (Eq. No. 1AA-VSL-2)
- Fines Sampler (Eq. No. 1AA-SMX-1)
- Bottom Ash Sampler (Eq. No. 1AA-SMX-2)
- Ash Bucket Elevator (Eq. No. 1AA-ELEV-1)
- Ash Silo (Eq. No. 1AA-SILO-1)
- Ash Dustless Unloader (Eq. No. 1AA-COND-1)
- Ash Silo Dust Collector (Eq.No. 1AA-DCOL-1)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA - 4

System Name Solid Waste Disposal System

Flowsheet No. 16N25706-40-F-1AA-005

I. DESIGN PHILOSOPHY

1. The primary functions of the Solid Waste Disposal System is to weigh, collect and provide a means of disposing the process gas cyclone fines and gasifier bottom ash.
2. The bottom ash and cyclone fines are continuously transferred (individually) to the weighbelt feeders by the cyclone fines and bottom ash conveyors.
3. The weighbelt feeders weigh and record the "throughput" of cyclone fines and bottom ash.
4. Samplers on the ends of the weighbelt feeders provide a means of sampling fines and ash by diverting a portion of the fines/ash to sample bins.
5. Fines and ash discharged from the weighbelt feeders are directed to the inlet of the bucket elevator.
6. The bucket elevator lifts the combined fines and ash and discharges the mixture into the ash silo. A filter in the silo vent prevents fines from escaping to the atmosphere.
7. An unloader mounted at the bottom of the ash silo discharges the stored ash/fines into an ash removal truck.
8. Service water is injected into the unloader to reduce the dust emissions during the unloading process.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1AA - 4

System Name Solid Waste Disposal System

Flowsheet No. 16N25706-40-F-1AA-005

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAXIMUM FLOW #/HR (or as noted)	NORMAL FLOW #/HR (or as noted)	MINIMUM FLOW #/HR (or as noted)	MAXIMUM TEMP. °F	NORMAL TEMP. °F	MAXIMUM PRESS. PSIG	NORMAL PRESS. PSIG
1	Cyclone Fines from Conveyor	500	(See Mass Balance)	(See Mass Balance)	200	(See Mass Balance)	2	(See Mass Balance)
2	Bottom Ash from Conveyor	1,000	(See Mass Balance)	(See Mass Balance)	750	(See Mass Balance)	10	(See Mass Balance)
3	Combined Ash from Bucket Elevator	1,500	Hold	Hold	Hold	Hold	atmos.	atmos.
4	Ash Discharged from Unloader	1,500	(See Mass Balance)	(See Mass Balance)	Hold	(See Mass Balance)	atmos.	atmos.
5	Service Water	Hold	(See Mass Balance)	(See Mass Balance)	Hold	(See Mass Balance)	Hold	(See Mass Balance)

PDB No. 40-1AA - 4

Flowsheet No. 16N25706-40-F-1AA-005

1. Current design is based on the Mass Balance dated 5/31/95.
2. Cyclone fines bulk density is assumed to be 25 #/ft³.
3. Cyclone fines size distribution is assumed to be : 50% less than 30 microns.
 50% greater than 30 microns.
4. Bottom ash bulk density is assumed to be 50 #/ft³.
5. The ash silo is sized to allow for 45 hours of continuous bucket elevator discharge at maximum design conditions. (LATER #/hr of fines/ash) 45 hours of storage is based on the ash removal schedule as defined in the Site Access Agreement. With normal ash hauling hours being from 7:00 a.m. to 2:30 p.m. Monday through Friday and from 7:00 a.m. to 12:00 noon Saturdays, the longest period of time when no ash is removed is 43 hours. (From 2:30 p.m. on Saturday to 7:00 a.m. on Monday) To be conservative, an additional hour was added to the beginning and the end of the 43 hour time period to allow for minor deviations from the hauling schedule.
6. A temperature drop of LATER °F is assumed across the weighbelt feeders.
7. A temperature drop of LATER °F is assumed across the ash bucket elevator.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1DG - 1

System Name Natural Gas Distribution
Flowsheet No. 16N25706-40-F-1DG-001

Natural Gas Distribution

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1DG - 1

System Name Natural Gas Distribution
Flowsheet No. 16N25706-40-F-1DG-001

I. DESIGN PHILOSOPHY

- 1) Hope Gas acquires any permits required for running the pipeline to the facility. Hope Gas provides a natural gas metering station that measures the gas consumption and regulates the gas pressure. Jacobs-Sirrine is responsible for the piping design downstream of the metering station.
- 2) Allegheny Power grants Hope Gas an easement for Hope Gas to establish a meter site on Allegheny Power property. The approximate size of the station is 20' x 20'.
- 3) Natural gas supply to the facility is uninterrupted. A firm gas supply is required in order to start up, operate, and shut down the facility.
- 4) Gas piping is designed for the maximum pressure attainable from the Hope metering station. No safety valve is required.
- 5) A duplex strainer removes any foreign matter entrained within the gas.
- 6) The main shutoff valve (QV-1) and the flare shutoff valve (QV-2) are located downstream of the strainer. Each is interlocked to automatically close under emergency low pressure conditions (fire, explosion, etc.). Two separate lines are provided in order to always have a natural gas supply to safely incinerate coal gas. If a low pressure occurs at the coal dryer, for example, QV-1 shuts down the main gas line, but the flare is still available. Likewise, if QV-2 shuts down the flare gas supply, the HRSG is still available. Each gas line has a different routing so that an emergency condition in one part of the facility does not take down both lines.
- 7) Natural gas is not used for building heating. Electric unit heaters will be used.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1DG - 1

System Name Natural Gas Distribution
Flowsheet No. 16N25706-40-F-1DG-001

II. DESIGN CRITERIA

1) Stream Data (Note 1)

ITEM	PROCESS STREAM	MAX FLOW MMBTU /HR	NORM FLOW MMBTU /HR	MAX FLOW SCFM	NORM FLOW SCFM	MAX PRESS PSIG	NORM PRESS PSIG
1	Natural Gas Supply	Note 3	34.00	Note 3	529.00	Note 4	40
2	Main Supply Line	Note 3	33.80	Note 3	525.90	Note 4	40
3	Package Boiler	8.00	3.00	124.0	46.7	Note 2	Note 2
4	Gas to Warm Up Heater	1.00	0.00	31.1	0.0	Note 2	Note 2
5	Gas to Coal Dryer	3.00	3.00	46.7	46.7	Note 2	Note 2
6	Gas to F.G. Reheater	12.00	12.00	186.7	186.7	Note 2	Note 2
7	Flare Supply Line	15.35	0.20	238.8	3.1	Note 4	40
8	Flare Assist Gas	15.0	0.00	233.4	0.0	Note 4	40
9	Flare Ignitor Gas	0.15	0.00	2.3	0.0	15	10
10	Flare Pilot Gas	0.20	0.20	3.1	3.1	15	10
11	Incinerator	Note 2	Note 2	Note 2	Note 2	Note 4	Note 2

2) Composition

CONSTITUENT	FORMULA	MASS %	VOL %
Methane	CH ₄	81.20	90.42
Ethane	C ₂ H ₆	9.22	5.48
Propane	C ₃ H ₈	3.46	1.40
Isobutane	C ₄ H ₁₀	2.42	0.74
Nitrogen	N ₂	1.98	1.26
Carbon Dioxide	CO ₂	1.72	0.70
Total		100.00	100.00

3) Molecular Weight - 17.86

4) Lower Heating Value - LHV 967 BTU/SCF
20,503 BTU/LB

5) Higher Heating Value - HHV 1,071 BTU/SCF
22,711 BTU/LB

192

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1DG - 1

System Name Natural Gas Distribution
Flowsheet No. 16N25706-40-F-1DG-001

III. DESIGN NOTES

- 1) Standard conditions for natural gas are 60 deg F and 30" Hg (14.73 psia). The specific volume of Hope gas is 21.2 scf/lb.
- 2) Per Vendor.
- 3) Later.
- 4) Per Hope Gas.
- 5) The gas system is designed per NFPA requirements for Seismic Zone 1.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1GA-1

System Name FGD System
Flowsheet No. 16N25706-40-F-1GA-001

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1GA-1

System Name FGD System
Flowsheet No. 16N25706-40-F-1GA-001

I. DESIGN PHILOSOPHY

1. The purpose of the FGD System (Flue Gas Desulfurization System) is to remove sulfur dioxide (SO₂) from the HRSG flue gas to assure that permit conditions are met at all times.
2. A caustic soda-based wet scrubbing system is used for ease of operation and low capital cost.
3. The scrubber is designed to achieve up to 90% removal of SO₂.
4. Reagent is injected into a caustic scrubber spray tower reactor where the solution absorbs the SO₂. The reagent reacts to form a solution of sodium sulfate and sodium sulfite.
5. Reagent is recirculated through the reactor and fresh reagent is added to maintain a pH setpoint necessary to meet the SO₂ emission limit. Spent reagent is bled from the system to the sewer to Fort Martin.
6. Reagent is aerated in the scrubber reactor basin with an air sparge to oxidize sulfites to sulfates prior to discharge to the Fort Martin wastewater treatment system. The spent solution contains up to 15% dissolved solids, primarily sodium sulfate, after oxidation.
7. Flue gas entering the scrubber is quenched with a water quench prior to entering the spray tower. Flue gas leaving the scrubber passes through a demister into exit ductwork saturated with moisture at 182 F.
8. The treated flue gas passes through an I.D. fan, is reheated to 250 F, and discharged to the duct running to the Fort Martin precipitator inlet breeching. The FGD system and reheater are isolated from the duct with a knife gate damper.
9. The FGD system is designed for outdoor operation, to accommodate widely varying operating conditions and for intermittent operation. The components are equipped to be flushed at the completion of and operating run to minimize corrosion and prevent solids deposits setting up between runs.
10. The system design life is five years. The materials of construction for the reactor is carbon steel with two coats of high temperature coal tar epoxy coating. Spray piping and nozzles are 304 stainless steel.
11. External piping, recycle pump and valves are FRP construction.
12. Pressure drop through the FGD system is approximately 6" WG at full load.
13. The caustic truck unloading station is curbed to prevent release of caustic in case of a spill. The caustic storage tank and scrubber tower are also diked to provide secondary containment.
14. Service water is added to the reactor basin to maintain level, replacing evaporation and spent reagent volume. Service water is also used as required to quench incoming flue gas from 1800 F to below 500 F.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1GA-1

System Name FGD System
Flowsheet No. 16N25706-40-F-1GA-001

II. DESIGN CRITERIA

Strm No.	Process Stream	Max Flow (#/hr) or as noted	Max Flow (acfm)	Temperature (°F)	Pressure (psig)	Constituent as noted
1	Service Water Make-up	16 gpm	-	80	80	-
2	50 % Caustic Solution	0.67 gpm	-	25	55	256 lbs/hr NaOH
3	Flue Gas From Burner	67,863	66,683	1800	-0.36	237 lb/hr SO ₂
4	Service Water Quench	48 gpm	-	60	80	-
5	Reagent Recycle	1,006 gpm	-	180	55	-
6	Reagent Feed	1,000 gpm	-	180	40	-
7	Oxidation Air	2,700	600	80	10	-
8	Flue Gas to I.D. Fan	93,682	26,111	182	-0.58	22.9lb/hr SO ₂
9	Reheater Combustion Air	2,555	568	80	0.36	
10	Natural Gas to Reheater	135	2	80	20	
11	Flue Gas to Fort Martin	96,372	28,636	250	0.36	8 lb/hr solids
12	Waste Reagent	5.8 gpm	-	180	5	15% TDS

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1GA-1

System Name FGD System
Flowsheet No. 16N25706-40-F-1GA-001

III. DESIGN NOTES

1. Current design is based on the Revision 1 of the Base Case, 2 TPH, Mass and Energy Balance, dated 8/24/95 for 325 psig operation.
2. Current design is based on using caustic soda as the reagent. The caustic tank is designed to hold 6,000 gallons of 50% caustic soda solution, commercial grade. The tank is insulated and heated with an electric heater to maintain the caustic in liquid form.
3. Current design is based on flue gas reheat to 250 F. Although this is the minimum delivery temperature allowed under the Site Access Agreement with Fort Martin, the parties have concluded that the quantity of flue gas involved is so small relative to that at the existing Fort Martin unit, that this temperature is adequate.
4. The caustic scrubber reactor tower is approximately 42 feet high and 8 feet in diameter.
5. Current design is to oxidize reagent in the scrubber basin using an air sparge. The bleed stream off of the recycle line will be about 15% sodium sulfate solution, and discharged to the Fort Martin sewer.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 1

System Name Lockhopper Vent System
Flowsheet No. 16N25706-40-F-GG-001

EQUIPMENT:

Vent Cyclone - 1GG-CYCL-1
Vent Cyclone Hopper - 1GG-HPR-1

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 1

System Name Lockhopper Vent System
Flowsheet No. 16N25706-40-F-GG-001

I. DESIGN PHILOSOPHY

- 1) The lockhopper vent system vents coal gas from the lockhoppers to the incinerator. Under normal conditions the oxygen concentration of the gas within the system is below the limiting oxidant concentration, and the gas within the system (by itself) is noncombustible. However, if the coal gas is exposed to oxygen, it has the potential to autoignite due to its high temperature.
- 2) A lockhopper is depressurized by opening its vent valve. A stellite orifice in the vent line sets the vent flowrate. The depressurization rate is not precisely controlled, but it is kept within a given range. If the vessel depressurizes too quickly, then there is excessive particulate carryover. Conversely, if the vessel depressurizes too slowly, then the lockhopper emptying cycle time is excessive. The time to depressurize depends on the amount of ash / fines in the lockhopper and the amount of coal gas above the ash / fines. After the vessel depressurizes, the lockhopper is drained .
- 3) The lockhopper vent valves are interlocked so that only one lockhopper can be vented at a time. Each lockhopper has a separate vent line (there is not a main header) in order to minimize particulate fallout. In addition, each vent line has a nitrogen purge connection.
- 4) The Vent System allows the lockhoppers to depressurize to 2 psig.
- 5) A vent cyclone is located downstream of the lockhoppers. It removes entrained particulate that carries over into the vent system. A rupture disk on the cyclone is set at 150 psig.
- 6) A vent cyclone hopper beneath the vent cyclone stores the fly ash particulate that falls out in the cyclone. This hopper empties intermittently by gravity. During normal system operation QV-3 is open and QV-4 is closed. During an emptying cycle QV-3 closes and QV-4 opens. If a plug develops in the ash line, then QV-4 also closes, and the hopper is pressurized with heated nitrogen. QV-4 reopens and the plug is blown free.
- 7) Vent flow is diverted to the flare if the incinerator trips. QV-1 and QV-2 are interlocked. Under normal conditions QV-1 is open and QV-2 is closed. If the incinerator trips then QV-1 closes and QV-2 opens.
- 8) All lines and equipment within the system are insulated and heat traced in order to prevent the condensation of any vapor (condensate and particulate form mud in the system).
- 9) All lines within the vent system are purged with heated nitrogen on a regular basis in order to prevent the accumulation of particulate within the lines.
- 10) Before gasifier startup the vent system is purged of air (with nitrogen) into the incinerator. After a gasifier shutdown, the vent system is purged of coal gas (with nitrogen) into the incinerator.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 1

System Name Lockhopper Vent System
Flowsheet No. 16N25706-40-F-GG-001

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAX FLOW LB/HR	NORM FLOW LB/HR	MAX TEMP DEG F	NORM TEMP DEG F	MAX PRESS PSIG	NORM PRESS PSIG	MN PRESS PSIG
1	Gasifier LH Vent	3000	0	1100	560	420	2	0
2	No.1 Cycl. LH Vent	1500	0	1100	1086	420	2	0
3	No.2 Cycl. LH Vent	1500	0	1100	1086	420	2	0
4	Pyrolyzer LH Vent	500	0	1100	650	420	2	0
5	Vent to Incin	3000	0	1100	400	150	-1	0
6	Vent to Flare	3000	0	1100	400	150	0	0
7	Vent Cyclone Ash	Note 1	0	1100	400	150	0	0
8	Cyclone Hopper Ash	Note 1	0	1100	400	150	2	0

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 1

System Name Lockhopper Vent System
Flowsheet No. 16N25706-40-F-GG-001

III. DESIGN NOTES

1) Later

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

EQUIPMENT:

Flare - 1GG-STK-1
Instrument Air Receiver - 1GG-RCV-1

202

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

I. DESIGN PHILOSOPHY

- 1) The flare incinerates coal gas during emergency conditions when the incinerator goes down. Whenever the incinerator is operating, coal gas is burned in the incinerator even during gasifier startup and shutdown. If the incinerator shuts down, the gasifier is interlocked to immediately trip.
- 2) The following streams divert to the flare if the incinerator goes down:
 - a) gasifier bleed
 - b) lockhopper vent system bleed
 - c) incinerator bleed
- 3) The flare is designed for 10% of the gasifier coal gas outlet design flow and the maximum lockhopper vent system flow (both flows simultaneously).
- 4) The flare tip is designed for a maximum exit velocity of 60 ft/sec.
- 5) Assist gas (natural gas) is added to the flare tip in order to maintain a combined gas heating value of 200 Btu/scf. This heating value is needed to ensure complete combustion of the coal gas. The natural gas flow rate is adjusted based on the coal gas flow and heating value. The combined gas at the flare tip always has minimum heating value of 200 Btu/scf.
- 6) The flare is located on the roof of the reactor tower.
- 7) The flare height is based on a maximum radiation rate at the base of the stack of 1500 Btu/hr/sq ft. At this radiation rate the exposure time necessary to reach the pain threshold is 16 seconds (Note 1). Personnel wearing appropriate clothing may perform emergency action lasting several minutes. Equipment on the roof, and the roofing construction material must be capable of withstanding a heat density of 1500 Btu/hr/sq ft.
- 8) The minimum flare height available is 30 feet. At low tip velocities the flame may be drawn to the low pressure area on the downwind side of the stack, down along the stack. A minimum height of 30 feet ensures that the flame is always a safe distance above the roof. Low tip velocity can occur as the gasifier's pressure decays after an emergency shutdown.
- 9) The flare stack is constructed of stainless steel or refractory lined carbon steel. The flare stack is not insulated. Vent piping to the flare is insulated where needed for personnel protection. Coal gas flare systems that are in continuous operation are normally insulated to prevent line plugging due to condensation and particulate. Since the GPIF flare is not normally in operation, it is not insulated. When the GPIF flare system is used, the flare burner and all lines within the flare system must be purged before the flare can be brought on-line for the next test run.
- 10) Before each test run the entire flare vent system is purged with nitrogen. If there is oxygen in the flare system, a flashback and deflagration may occur within the flare system.
- 11) An integral fluidic seal (velocity seal) is incorporated into the flare tip. It is continuously purged with nitrogen to ensure that air does not enter into the flare stack. Nitrogen connections are provided on each vent line to the flare to allow continuous purging of each line if required.
- 12) Several pilot burners are located in the flare tip. The pilots are lit before the gasifier operation starts. Each pilot has its own thermocouple to monitor ignition and normal operation. If for some reason the pilots go out during operation, they automatically reignite. Oxygen for the continuous pilot is supplied from ambient air at the pilot.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

- 13) A flame front generator ignites the pilots. Compressed air and natural gas are mixed outside the base of the stack to form a combustible mixture. An ignition panel at the base of the stack generates a spark, and the resulting flame front ignites the pilots. The instrument air system supplies the compressed air to the ignition system until the pilot ignites. An air receiver is located in the supply line to the flare to ensure that an adequate air supply is always available.
- 14) During the bid period an enclosed flare (incinerator) will be evaluated as an option.
- 15) During the bid period an insulated flare stack will be evaluated as an option.
- 16) Flare Startup
- a) Nitrogen purge vent lines and flare stack.
 - b) Nitrogen seal the flare tip.
 - c) Ignite pilots. (The pilots are ignited after the system is nitrogen purged. During a shutdown oxygen and coal gas can form a combustible mixture within the vent system. This mixture can ignite when exposed to a flame (if a pilot were lit) and cause a flashback within the stack).
- 17) Flare Standby Operation
- a) Continuously seal the flare tip with nitrogen. (The vent system may also be continuously sealed/purged with nitrogen based on recommendations from the flare vendor).
 - b) Continuously seal the flare vent piping with nitrogen (if flare manufacturer recommends).
 - c) Continuously burn flare pilots.
- 18) Flare Operation (Incinerator Trips)
- a) QV-1, QV-2, and QV-3 are interlocked. QV-1 and QV-2 close, and QV-3 opens. Coal gas diverts to the flare.
 - b) QV-4, QV-5, QV-6, and QV-7 are interlocked. QV-4 and QV-5 close, and QV-6 and QV-7 open. Lockhopper vent gas diverts to the flare.
 - c) Continuously monitor flowrate and heating value of the gas flow to the flare. Automatically adjust the natural gas assist flow (FCV) to maintain a combined gas heating value of greater than 200 Btu/scf.
 - d) Depressurize coal gas system to the flare.
 - e) Nitrogen purge the coal gas system to the flare.
 - f) Lock up coal gas system under nitrogen blanket. Shut down flare.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

II. DESIGN CRITERIA

A) Process Streams

1) Operating Conditions

ITEM	PROCESS STREAM	Flare in Standby Mode (Incinerator Running)			Flare in Operation (Incinerator Down)		
		NORM FLOW LB/HR	NORM PRESS PSIG	NORM TEMP DEG F	NORM FLOW LB/HR	NORM PRESS PSIG	NORM TEMP DEG F
1	Coal Gas to Incin	18,878	30	1217	0	30	1217
2	Coal Gas to Flare	0	30	1217	5000	30	1217
3	C.G. at Flare Inlet	0	0	60	5000	2	1217
4	L.H. Vent to Ejector	3000	0	400	0	0	400
5	L.H. Vent to Flare	0	0	60	3000	10	400
6	Natural Gas Supply	8.8	40	60	676	40	60
7	N.G. Assist Gas	0	0	60	660	10	60
8	N.G. Ignitor Gas	0	10	60	0	10	60
9	N.G. Pilot Gas	8.8	10	60	8.8	10	60
10	Gas to Flare Tip	21.7	0	60	11,452	1	800
11	Air from Receiver	0	100	60	0	100	60
12	Air to Ignitor	0	20	60	0	20	60
13	N2 Tip Seal	21.7	30	60	21.7	30	60
14	N2 Main Purge	0	30	60	0	30	60
15	N2 L.H. Purge	0	30	60	0	30	60
16	N2 QV-1,2 Purge	0	30	60	0	30	60

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

2) Design Conditions (Notes 2,3,4,5)

ITEM	PROCESS STREAM	MAX FLOW LB/HR	MAX FLOW SCFM	MAX PRESS PSIG	MAX TEMP DEG F
1	Coal Gas to Incin	18,878	5213	660	1500
2	Coal Gas to Flare	7770	2146	660	1500
3	C.G. at Flare Inlet	7770	2146	10	1500
4	L.H. Vent to Ejector	3000	829	150	1500
5	L.H. Vent to Flare	3000	829	150	1500
6	Natural Gas Supply	676	239	Note 8	90
7	N.G. Assist Gas	660	233	Note 8	90
8	N.G. Ignitor Gas	6.5	2.3	15	90
9	N.G. Pilot Gas	8.8	3.1	15	90
10	Gas to Flare Tip	11,452	4046	40	90
11	Air from Receiver	137	30	125	90
12	Air to Ignitor	137	30	30	90
13	N2 Tip Seal	21.7	5	50	90
14	N2 Main Purge	1519	350	50	90
15	N2 L.H. Purge	1519	350	50	90
16	N2 QV-1,2 Purge	434	100	50	90

B) Coal Gas Data (Note 6)

1) Composition

CONSTITUENT	FORMULA	MASS %	VOL %
Carbon Monoxide	CO	25.46	21.13
Hydrogen	H2	1.38	15.91
Carbon Dioxide	CO2	10.57	5.58
Water	H2O	11.41	14.73
Methane	CH4	0.49	0.71
Hydrogen Sulfide	H2S	0.17	0.12
Nitrogen	N2	49.15	40.80
Argon	Ar	1.09	0.64
Ammonia	NH3	0.28	0.38
Total		100.00	100.00

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

2) Coal Gas Properties

Molecular Weight	23.25
Lower Heating Value - Btu/SCF	118
Higher Heating Value - Btu/SCF	127
Lower Heating Value - Btu/lb	1958
Higher Heating Value - Btu/lb	2106

C) Natural Gas Data (Note 7)

1) Composition

CONSTITUENT	FORMULA	MASS %	VOL %
Methane	CH ₄	81.20	90.42
Ethane	C ₂ H ₆	9.22	5.48
Propane	C ₃ H ₈	3.46	1.40
Isobutane	C ₄ H ₁₀	2.42	0.74
Nitrogen	N ₂	1.98	1.26
Carbon Dioxide	CO ₂	1.72	0.70
Total		100.00	100.00

2) Natural Gas Properties (Note 2)

Molecular Weight	17.86
Lower Heating Value - Btu/SCF	967
Higher Heating Value - Btu/SCF	1,071
Lower Heating Value - Btu/lb	20,503
Higher Heating Value - Btu/lb	22,711

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1GG - 2

System Name Flare System
Flowsheet No. 16N25706-40-F-GG-001

III. DESIGN NOTES

- 1) Per API 521, p 35.
- 2) Standard conditions for natural gas are 30" Hg (14.73 psia) and 60 deg F. The specific volume of Hope gas is 21.2 scf/lb.
- 3) Standard conditions for nitrogen are 14.7 psia and 70 deg F. The specific volume of nitrogen is 13.8 scf/lb.
- 4) Standard conditions for instrument air are 14.7 psia, 59 deg F, and 36% RH. The specific volume of standard air is 13.16 scf/lb.
- 5) Standard conditions for waste gas (coal gas) to a flare are 14.7 psia and 68 deg F per 40 CFR 60.18. The specific volume of the design coal gas to the flare is 16.57 scf/lb.
- 6) Per Mass Balance - 3/22/95.
- 7) Per Natural Gas Distribution Process Design Basis.
- 8) Per Hope Gas.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1GH-1
System Name Incineration System
Flowsheet No. 16N25706-40-F-GH-001

EQUIPMENT:

Incinerator - 1GH-INCN-1
FD Fan - 1GH-FAN-1

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-IGH-1

System Name Incineration System

Flowsheet No. 16N25706-40-F-GH-001

I. DESIGN PHILOSOPHY

- 1) The incinerator burns the coal gas so that it can be safely released to the atmosphere. The residence time in the coal gas within the incinerator is one second.
- 2) The temperature within the incinerator is controlled to 2000 deg F. The heating loop is controlled by the natural gas fuel control valve. The cooling loop is controlled by the FD fan VFD.
- 3) The coal gas enters the incinerator through a stainless steel burner.
- 4) The forced draft fan supplies the combustion air (and quench air) to the incinerator . A variable frequency drive (VFD) controls the speed of the fan motor.
- 5) The incinerator is a vertical, cylindrical, down-fired unit constructed of refractory lined carbon steel. It is approximately nine feet in diameter and twenty-five feet tall. The coal gas inlet to the incinerator is approximately the same elevation as the coal gas outlet from the cyclone.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40-1GH-1
System Name Incineration System
Flowsheet No. 16N25706-40-F-GH-001

II. DESIGN CRITERIA

A) Process Streams (Notes 1,2,3)

ITEM	PROCESS STREAM	MAX FLOW LB/HR	MAX FLOW SCFM	MAX PRESS PSIG	MAX TEMP DEG F
1	Gasifier Coal Gas	18,878	5213	30	1150
2	LH Vents	3000	829	30	1150
3	Coal Gas to Incin.	21,878	6042	30	1150
4	FD Fan Air	Note 4	Note 4	1	100
5	Natural Gas Supply	Note 4	Note 4	60	100
6	N.G. Burner Gas	Note 4	Note 4	60	100
7	N.G. Ignitor Gas	Note 4	Note 4	60	100
8	Inst. Air to Ignitor	Note 4	Note 4	120	100
9	Flue Gas	Note 4	Note 4	1	2100

B) Coal Gas Data (Note 5)

1) Coal Gas Composition

CONSTITUENT	FORMULA	MASS %	VOL %
Carbon Monoxide	CO	25.40	21.08
Hydrogen	H2	1.39	16.04
Carbon Dioxide	CO2	10.48	5.54
Water	H2O	11.23	14.49
Methane	CH4	0.50	0.73
Hydrogen Sulfide	H2S	0.64	0.44
Nitrogen	N2	48.98	40.65
Argon	Ar	1.10	0.64
Ammonia	NH3	0.28	0.39
Total		100.00	100.00

2) Coal Gas Properties

Molecular Weight	23.25
Higher Heating Value - Btu/scf	127

211

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1GH-1

System Name Incineration System

Flowsheet No. 16N25706-40-F-GH-001

Higher Heating Value - Btu/lb	2147
-------------------------------	------

C) Particulate Data (Particulate in coal gas going to the incinerator)

- 1) Max Particulate - 125 lb/hr (Note 6)
- 2) Particulate Composition - Wt% (Note 5)

Carbon	70
Ash	30

3) Ash Composition - (Note 7)

CONSTITUENT	FORMULA	MASS %
Silica	SiO ₂	55.19
Alumina	Al ₂ O ₃	31.11
Iron (III) Oxide	Fe ₂ O ₃	7.08
Titania	TiO ₂	1.49
Magnesia	MgO	1.22
Manganese Oxide	MnO	0.08
Phosphorus (V) Oxide	P ₂ O ₅	0.27
Potassium Oxide	K ₂ O	2.66
Calcium Oxide	CaO	0.90
Total		100.00

4) Ash Fusion Temp - 2200 Deg F. (Note 7)

5) Particulate Size Distribution - It is anticipated that 95% of the particulate is between 1-5 micron (Note 8).

D) Natural Gas Data (Note 9)

1) Natural Gas Composition

CONSTITUENT	FORMULA	MASS %	VOL %
Methane	CH ₄	81.20	90.42
Ethane	C ₂ H ₆	9.22	5.48
Propane	C ₃ H ₈	3.46	1.40
Isobutane	C ₄ H ₁₀	2.42	0.74
Nitrogen	N ₂	1.98	1.26
Carbon Dioxide	CO ₂	1.72	0.70
Total		100.00	100.00

212

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1GH-1

System Name Incineration System

Flowsheet No. 16N25706-40-F-GH-001

2) Natural Gas Properties

Molecular Weight	17.86
Higher Heating Value - Btu/SCF	1,071
Higher Heating Value - Btu/lb	22,711

SYSTEM PROCESS DESIGN BASIS

PDB No. 40-1GH-1

System Name Incineration System

Flowsheet No. 16N25706-40-F-GH-001

III. DESIGN NOTES

- 1) Standard conditions for waste gas (coal gas) are 14.7 psia and 68 deg F per 40 CFR 60.18. The specific volume of the design coal gas is 16.57 scf/lb.
- 2) Standard conditions for natural gas are 30" Hg (14.73 psia) and 60 deg F. The specific volume of Hope gas is 21.2 scf/lb.
- 3) Standard conditions for instrument air are 14.7 psia, 59 deg F, and 36% RH. The specific volume of standard air is 13.16 scf/lb.
- 4) Per Vendor
- 5) Per Mass Balance - 5/31/95.
- 6) Per cyclone Process Design Basis.
- 7) Per Task IV report.
- 8) Based on correlating the Bacho particulate curve with the cyclone efficiency curve.
- 9) Per Natural Gas Distribution Process Design Basis.
- 10) Incinerator will be arranged vertical with flow down, per manufacturer recommendation when particulate is present in fuel.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KK - 1

System Name Potable Water Sytem

Flowsheet No. 16N25706-40-F-1KK-001

EQUIPMENT

Potable Water Storage Tank (Eq. No. 1KK-TK-1)

Potable Water Booster Pumps (Eq. Nos. 1KK-P-1, 1KK-P-2)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KK - 1

System Name Potable Water Sytem

Flowsheet No. 16N25706-40-F-1KK-001

I. DESIGN PHILOSOPHY

1. The function of the Potable Water System is to receive and store potable water from the Fort Martin Station and forward the water to the various GPIF users.
2. Potable water is received at 1 gpm and stored in 500 gallon capacity storage tank. With only 1 gpm of makeup flow being available, the potable water must be stored for peak use periods.
3. The Potable Water Booster Pumps take suction directly from the storage tank. The potable water is forwarded to the GPIF distribution header and in turn, available to the users. Potable water is also forwarded to the Department of Energy (DOE) trailers.
4. A bladder tank located downstream of the pumps maintains constant pressure on the distribution header at all flow conditions. This tank monitors system pressure regulates pump operation based on increases and decreases in system pressure.
5. This system provides water for the plants safety showers, and domestic plumbing needs. (Toilets, showers, sinks, etc.)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KK - 1

System Name Potable Water Sytem

Flowsheet No. 16N25706-40-F-1KK-001

II. DESIGN CRITERIA

ITEM NO.	PROCESS STREAM	MAXIMUM FLOW GPM	NORMAL FLOW GPM	MINIMUM FLOW GPM	MAXIMUM TEMP. °F	MINIMUM TEMP. °F	MAXIMUM PRESS. PSIG	MINIMUM PRESS. PSIG
1	Potable Water from Ft. Martin	Hold	1	1	55	55	150	150
2	Potable Water to GPIF	Hold	65	65	Ambient	Ambient	30	30
3	Potable Water to DOE Trailers	Hold	Hold	Hold	Ambient	Ambient	30	30

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KK - 1

System Name Potable Water Sytem

Flowsheet No. 16N25706-40-F-1KK-001

III. DESIGN NOTES

1. Potable water design flow rates will be determined once the plant layout and potable water users are finalized.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KV - 1

System Name Auxiliary Water Distribution (Cooling Water)

Flowsheet No. 16N25706-40-F-KV-001

EQUIPMENT

Cooling Water Transfer Pumps (Eq. Nos. 1KV-P-1, 1KV-P-2)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KV - 1

System Name Auxiliary Water Distribution (Cooling Water)
Flowsheet No. 16N25706-40-F-KV-001

I. DESIGN PHILOSOPHY

1. The function of Cooling Water System is to provide cooling water to the Process Air Compressor, Fuel Feed Air Cooler, Gasifier Condenser, Fines Conveyor, Bottom Ash Conveyor and other miscellaneous plant components that require cooling water.
2. The two 50% capacity Cooling Water Transfer Pumps take suction from the existing Fort Martin Station Unit No. 2 Cooling Tower Basin and forward cooling water to the Gasification Product Improvement Facility (GPIF).
3. During normal or emergency plant shut down, only one of the two Cooling Water Transfer Pumps is required to be operational in order to provide cooling water for shutdown.
4. The Cooling Water Transfer Pumps are self priming, centrifugal horizontal type pumps. Foot valves are installed on the cooling water suction line inlet to maintain prime during GPIF and system shutdown.
5. After passing through the cooling heat exchangers the cooling water is returned back to the Fort Martin cooling tower.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KV - 1

System Name Auxiliary Water Distribution (Cooling Water)
Flowsheet No. 16N25706-40-F-KV-001

II. DESIGN CRITERIA

ITEM NO.	PROCESS STREAM	MAX. FLOW (gpm)	MIN. FLOW (gpm)	NORMAL FLOW (gpm)	MAX. TEMP. (°F)	MIN. TEMP. (°F)	MAX. PRESS. (psig)	MIN. PRESS. (psig)
1	Cooling Water Transfer Pump Discharge	Hold	Hold	Hold	150	Hold	100	30
2	Inlet to Process Air Compressor	Hold	Hold	Hold	150	Hold	100	30
3	Inlet to Fuel Feed Air Cooler	50	35	10	150	85	100	40
4	Inlet to Gasifier Condenser	Hold	Hold	Hold	150	85	100	40
5	Inlet to Fines Conveyor	Hold	Hold	Hold	150	85	100	40
6	Inlet to Bottom Ash Conveyor	Hold	Hold	Hold	150	85	100	40
7	Header to Miscellaneous Plant Cooling	Hold	Hold	Hold	150	85	100	40
8	Outlet from Process Air Compressor	Hold	Hold	Hold	150	105	100	30
9	Outlet from Fuel Feed Air Cooler	Hold	Hold	Hold	150	105	100	30
10	Outlet from Gasifier Condenser	Hold	Hold	Hold	150	105	100	30
11	Outlet from Fines Conveyor	Hold	Hold	Hold	Hold	Hold	100	30
12	Outlet from Bottom Ash Conveyor	Hold	Hold	Hold	Hold	Hold	100	30
13	Header from Miscellaneous Plant Cooling	Hold	Hold	Hold	150	Hold	100	30
14	Return to Fort Martin Cooling Tower	Hold	Hold	Hold	150	Hold	100	30

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KV - 1

System Name Auxiliary Water Distribution (Cooling Water)
Flowsheet No. 16N25706-40-F-KV-001

III. DESIGN NOTES

1. Current design is based on the Mass Balance dated (later).
2. Design criteria will be finalized when equipment design and selection is completed.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KW - 1

System Name Service Water System

Flowsheet No. 16N25706-40-F-1KW-001

EQUIPMENT

Fire & Service Water Storage Tank (Eq. No. 1KW-TK-1)

Service Water Pump (Eq. No. 1KW-P-1)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KW - 1

System Name Service Water System

Flowsheet No. 16N25706-40-F-1KW-001

I. DESIGN PHILOSOPHY

1. The function of the Service Water System is to receive, store and distribute service water from Fort Martin station to the various GPIF users.
2. The Fire & Service Water Storage Tank receives and collects service water from Fort Martin. The tank provides an inventory of both fire protection water and pretreated boiler feedwater.
3. A level control valve, located at the inlet to the storage tank, maintains tank level by modulating service water inlet flow.
4. The Service Water Pump takes suction from the storage tank and forwards the water to the inlet to the portable water treatment skid. The inlet to the Service Water pump suction line is located at a tank level above the dedicated fire protection water level.
5. Required minimum flow is maintained for the Service Water Pump by continuously recirculating a portion of pump discharge flow back to the storage tank.
6. Service water to the Condensate Collector Tank, Blowoff Tank, coal receiving and prep area, Flue Gas Scrubber, the Ash Silo and the plant hose stations is pipe directly from the Fort Martin service water supply header. Pressure to these users is adequate as provided by the Fort Martin service water pumps.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KW - 1

System Name Service Water System

Flowsheet No. 16N25706-40-F-1KW-001

II. DESIGN CRITERIA

ITEM NO.	PROCESS STEAM	MAXIMUM FLOW GPM	NORMAL FLOW GPM	MINIMUM FLOW GPM	MAXIMUM TEMP. °F	MINIMUM TEMP. °F	MAXIMUM PRESS. PSIG	MINIMUM PRESS. PSIG
1	Service Water from Ft. Martin	Hold	Hold	Hold	90	60	100	75
2	Service Water to Storage Tank	Hold	Hold	Hold	90	60	100	75
3	Service Water to Portable Water Treatment System	Hold	Hold	Hold	90	60	100	70
4	Service Water to Condensate Collector Tank	Hold	Hold	Hold	90	60	80	40
5	Service Water to Blowoff Tank	Hold	Hold	0	90	60	80	40
6	Service Water to Coal Prep and Receiving Area	Hold	Hold	0	90	60	80	40
7	Service Water to Flue Gas Scrubber	Hold	Hold	0	90	60	80	40
8	Service Water to Ash Silo	Hold	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)
9	Service Water to Hose Stations	Hold	0	0	90	60	80	40

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1KW - 1

System Name Service Water System

Flowsheet No. 16N25706-40-F-1KW-001

III. DESIGN NOTES

1. Current design is based on Mass Balance dated (later).
2. This document does not describe the Fire Protection System.
3. The capacity of the Fire & Service Water Storage Tank is (later) gallons. This is based on (later) gallons of fire protection water and (later) gallons of service water.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LD - 1

System Name Plant and Instrument Air Systems

Flow sheet No. 16N25706-40-F-1LD-001

EQUIPMENT

Dryer Prefilter (Eq. No. 1LD-FLT-1)
 Instrument Air Dryer (Eq. No. 1LD-DRY-1)
 Dryer Afterfilter (Eq. No. 1LD-FLT-2)
 Instrument Air Receiver (Eq. No. 1LD-TK-1)
 Fuel Feed System Instrument Air Receiver (1LD-TK-2)
 Flare System Air Receiver (Eq. No. 1GG-TK-1)

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LD - 1
System Name Plant and Instrument Air Systems
Flow sheet No. 16N25706-40-F-1LD-001

DESIGN PHILOSOPHY

1. The Instrument Air System shall be designed to provide instrument quality air (-40 °F pressure dew point) to users in the GPIF facility.
2. While the GPIF will operate on a schedule of two weeks operating and down for six weeks, the Instrument Air System shall be designed to operate continuously.
3. Instrument Air shall be provided from an interface with the Process Air System. A pressure reducing valve shall be used to reduce Process Air pressure to approximately 100 psig for use in the Instrument Air System.
4. The design pressure of the Instrument Air System shall be 125 psig. All piping, vessels, and equipment shall have an ASME pressure rating of this value.
5. The capacity of the Instrument Air Dryer shall be determined, in part, by the purge flow technology used by the dryer ultimately selected. Instrument Air System Vendors will recommend a system configuration based upon specified system requirements and economic parameters agreed to by JSE, R/S, and the DOE.
6. The Instrument Air Receiver volume in cubic feet shall equal 30 seconds (.5 minutes) of additional flow at a rate of 100 scfm.. This flow shall be adequate for meeting the anticipated flow surges in the Instrument Air System.
7. The Instrument Air Dryer shall be a dual tower desiccant-type dryer. This dryer shall be designed to deliver 350 SCFM to the facility's Instrument Air System. During normal operation, one tower will be in service while the other is undergoing regeneration. Regeneration shall be controlled on either a timed cycle or by monitoring the exit humidity of the regenerating bed.. The dried compressed air will have a pressure dew point of at least -40 °F.
8. The maximum pressure drop across the instrument air dryer shall be 5 psi at rated flow and pressure.
9. The dryer prefilter shall be designed to capture all liquid and solid particles greater than 0.9 microns in size. The maximum pressure drop associated with a saturated filter at rated flow and pressure shall be 2 psi .
10. The dryer afterfilter shall be designed to capture all desiccant particles greater than 0.9 microns in size that may escape from the desiccant towers. The maximum pressure drop associated with a completely saturated afterfilter shall be 3 psi.
11. The Instrument Air System will supply the instrument air needs of the Coal Preparation Facility. The interface with this facility shall be the Fuel Feed System Instrument Air Receiver Tank sized to handle the intermittent air flows associated with the air cannons and dustbins on the coal silo. The current estimate for size of this receiver is 14.5 ft³.
12. Instrument Air will also be supplied to the Flare System. Instrument air will be required for the flame front ignitors. The interface with this system will also be an air receiver (Flare System Air Receiver) tank sized to handle the air requirements of the Flare System. It is currently estimated that this receiver will be approximately 8 ft³. Air for this purpose will come off the Instrument Air System at a location upstream of the interface between the Instrument Air and Nitrogen Backup System. A check valve will prevent nitrogen from getting into the Flare System's ignitors.
13. Because the Instrument Air System will not be on emergency power, the backup system for instruments shall be nitrogen from the nitrogen distribution system. At least one nitrogen pump shall be on standby power so that nitrogen will always be available for critical uses.
14. The conversion between SCF and lbs. for this document is 0.076 lbs/ft³.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LD - 1

System Name Plant and Instrument Air Systems

Flow sheet No. 16N25706-40-F-1LD-001

Instrument Air System Profile

Stream No.	Process Stream	Normal Flow (PPH)	Maximum Flow ** (PPH)	Normal Temp. (°F)	Maximum Temp. (°F)	Normal Pressure (psig)	Maximum Pressure (psig)
1	Process Air	1,058	1,603	70	100	487	550
2	Process Air	1,058	1,603	70	100	105	125
3	Condensate	0	25	70	100	105	125
4	Condensate	0	5	70	100	103	125
5	Dryer Purge	80	80	70	100	10	125
6	Instrument Air	978	1,493	70	100	95	125
7	Instrument Air To Facility	932	1,219	70	100	93	125
8	Instrument Air To Fuel Feed	46	274	70	100	93	125
9	Instrument Air To Flare	0	90	70	100	93	125
10	Instrument Air To Flare	0	90	70	100	20	25
11	Nitrogen To Instrument Air	0	1,493	60	90	95	125

DESIGN NOTES

1. ** The following is the basis for Instrument Air System component sizing: These flow are the basis for system design (see Average Usage column below). Note that individual flows are not necessarily cumulative

GPIF Instrument Air Estimates (PPH)

	(a) Minimum Usage During Shutdown	(b) Minimum Usage During Normal Operation	(c) Average Usage During Normal Operation (Assumes 60% Utilization)	(d) Maximum Air Demand (100 % Utilization)
Instrument Air To Facility	18	18	1089	1796
Instrument Air To MH	23	91	274	456
Instrument Air To Flare	--	--	--	--
Losses (5 % Dryer Purge)	2.35	6	80	131
(10% Leakage)	5	13	160	265
Total	47	128	1603	2649

- a These figures represent the facility's instrument requirement when the GPIF is down during the six week data evaluation period. Because the process air compressors will not be operating during this time, this flowrate also represents the base nitrogen demand by the Instrument Air System.
- b These figures represent the estimated minimum instrument air demand during normal GPIF operation.
- c Normal instrument air demand is based upon a conservative estimate of equipment utilization of 60% of system maximum demand.
- d These figures represent all instrumentation and other users in operation concurrently.

229

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LD - 1
System Name Plant and Instrument Air Systems
Flow sheet No. 16N25706-40-F-1LD-001

2. Instrument air requirements were estimated by summarizing all instruments loops and the air requirements of each type.
3. An Instrument Air Dryer size of 350 SCFM is recommended based upon the estimate air requirements of the facility. This unit sizing reflects very little contingency when compared to the normal usage figure. However, the utilization figure used to estimate normal usage is very conservative and therefore has contingency already included. In addition, the Instrument Air System will have a nitrogen backup that will supplement the system to maintain optimum system operating pressure.
4. Plant Air shall be provided by a separate compressor / receiver / dryer designed to provide air for less critical uses . The capacity of this system shall be 100 SCFM. Compressed air from this system shall be used for pneumatic tools and housekeeping. The following is an estimate of anticipated plant air users and their consumption.

Estimated Plant Air Usage

Pneumatic Tools

Tool	No.	Air Requirement (SCFM)	
		Per Tool	Total
Drills	2	35	70
Grinders	2	50	100
Sm. Screw Driver	3	12	36
Lrg.. Screw Driver	2	30	60
Riveters	1	35	35
Hoist	3	35	105

Sub-Total =	406
Tool Utilization Factor (15%)	61

Total Plant Air Usage	SCFM
------------------------------	-------------

Pneumatic Tools	61
Hose Stations (Cleaning)	20
Leakage (15%)	14

Total =	<div style="border: 1px solid black; padding: 2px 10px;">95</div>
---------	---

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LF - 1

System Name Process Air System

Flow sheet No. 16N25706-40-F-1LF-001

EQUIPMENT

Inlet Filter / Silencer (Eq. No. 1LF-FLT-1)
 Process Air Compressor (Eq. No. 1LF-CMP-1)
 Process Booster Compressor (Eq. No. 1LF-CMP-2)
 1st Stage Intercooler (Eq. No. 1LF-HX-1)
 2nd Stage Intercooler (Eq. No. 1LF-HX-2)
 3rd Stage Intercooler (Eq. No. 1LF-HX-3)
 4th Stage Intercooler (Eq. No. 1LF-HX-4)
 Recycle Cooler (Eq. No. 1LF-HX-5)

Blowoff Silencer (Eq. No. 1LF-SIL-1)
 Process Air Receiver (Eq. No. 1LF-TK-1)
 Fuel Air Cooler (Eq. No. 1LF-HX-7)
 Fuel Feed Air Dryer (Eq. No. 1LF-DRY-1)
 Fuel Feed Air Receiver (Eq. No. 1LF-Tk-2)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LF - 1

System Name Process Air System

Flow sheet No. 16N25706-40-F-1LF-001

DESIGN PHILOSOPHY

1. The process air compressors provide high pressure compressed air to the pyrolizer coal feed system , the Pygas Gasifier, and the Instrument Air System.
2. The process air compressors shall be a multi-stage centrifugal compressor followed by a two stage, balanced-opposed, reciprocating booster compressor designed to take atmospheric air and compress it to varying operating pressures. While the "design" discharge of the final stage of this system shall be 500 psig, the system shall be designed to operate from pressures near atmospheric up to the design pressure.
3. The varying flow and pressure requirements of the process shall be regulated by the operation of the air compressors' inlet guide vanes, blow-off system, recycle system and process pressure / flow control valves. The two compressors shall be designed to operate independently of each other. Capacity control of the reciprocating compressor shall be achieved by a pressure/flow controller sensing the process requirements and regulating a bypass valve that will direct the compressor's discharge to either the process or recycle it back to the compressor's suction. The recycled flow shall be cooled in the recycle cooler to prevent overheating of the compressor. The centrifugal compressor's capacity control system will also sense the changing flow/pressure requirements simultaneously and will regulate its inlet guide vanes and blowoff valve as necessary to maintain process conditions and prevent compressor surging.
4. Each air compressor shall be a complete, self contained units with all necessary controls for continuous, multi-pressure operation, and unit protection.
5. The air compressors shall be designed to support the facility schedule of two weeks operating and down for six weeks throughout the year.
6. The compressor shall be equipped with intercoolers between each stage of compression to cool inlet air and eliminate moisture. Each cooler shall be equipped with automatic condensate drainage traps.
7. The Process Air System will be designed to allow the discharge temperature from the final stage compression to vary from a low temperature of approximately 150 °F to a maximum temperature of approximately 400 °F. The discharge temperature will be adjusted by the regulation of cooling water flow to the intercoolers of the centrifugal and reciprocating compressors. The final temperature will be limited only by the site requirement that no single motor can exceed 2000 HP.
8. The high temperature, high pressure, compressed air leaving the air compressors is anticipated to have less than a 3 % degree of saturation due to intercooling between stages.
9. Compressor Design Ambient Conditions: Dry Bulb: 0 °F Winter
90 °F Summer
Humidity: 49 % RH
10. The air compressors shall be shop assembled. Due to the anticipated size of these units, some disassembly maybe necessary to get them into the building.
11. The air compressors shall be designed for indoor operation.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LF - 1

System Name Process Air System

Flow sheet No. 16N25706-40-F-1LF-001

12. The Process Air Receiving Tank will act as a dampener for process flow transients. The receiver shall be designed to supply the intermittent air requirements of process users to minimize compressor capacity. Current estimates of system receiver capacity are ~ 300 ft³. This volume is equivalent to approximately 100 SCFM of additional capacity assuming a 10 psi drop in system operating pressure over two minutes. Any moisture accumulating in the receiver shall be removed with automatic condensate traps. The air receiving tank shall be a carbon steel, ASME coded vessel. It shall be equipped with a safety valve set at 10% above compressor design pressure.
13. The Fuel Feed Air Cooler will reduce the hot process and instrument air temperature to approximately 100 °F to allow desiccant air drying. This cooler shall be a water cooled shell and tube heat exchanger designed for high pressure air applications. Air will flow in the tubes and water on the shell-side of this exchanger. A relief valve shall be installed on the shell-side to prevent over-pressurization due to thermal expansion. The cooler shall be equipped with moisture separating equipment to allow the removal of condensation. Moisture accumulating in the air cooler shall be removed with moisture traps. The Fuel Feed Air Cooler sizing shall be based upon the final capacity of the Fuel Feed Air Dryer and the air requirements of the Instrument Air System (see Design Note (1) below).
14. The Fuel Feed Air Dryer shall be designed to dry the saturated, high pressure compressed air from approximately 100 °F to a pressure dew point of -40 °F. This air quality is necessary to prevent instrumentation freeze-up and the "caking" of the crushed coal in the pneumatic convey system. The dryer shall be a dual tower type with one desiccant bed undergoing regeneration at all times. The anticipated purge flow will be ~ 5% of dryer throughput. Final dryer sizing shall be based upon the dryer technology selected and the dryer's actual purge requirements (see Design Note (1) below).
15. The Fuel Feed Air Receiving Tank shall be designed to accommodate the transient flows associated with the fuel feed system. On the basis of the latest information from the fuel feed conveyor vendor, the flow rate due to lock vessel pressurization/depressurization is estimated to be 39 SCFM. Based upon a repressurization time of 130 seconds, the air receiver will have a volume of 60 ft³. The air receiver shall be an ASME coded vessel designed for the maximum system operating pressure. Since this system will be design for instrument quality air, no condensate traps shall be installed on the receiver. However, the receiver shall be equipped with drain plugs.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LF - 1

System Name Process Air System

Flow sheet No. 16N25706-40-F-1LF-001

Design Criteria

325 Psig Gasifier Operation

Steam No.	Process Stream	Normal Flow (#/hr) Appx. A-8	Maximum Flow (#/hr) (Design *)	Normal Temp. (°F)	Maximum Temp. (°F)	Normal Pressure (psig)	Maximum Pressure (psig)
1	Inlet Air	16,277	19,212	70	90	14.52 **	14.6 **
2	Inlet Air	16,277	19,212	70	90	14.21**	14.3 **
3	Condensate	300	360	-	-	-	-
4	C.W. Supply	23,725	28,000	85	85	40	60
5	C.W. Return	23,725	28,000	105	105	30	60
6	Compressor Blowoff	0	0	105	105	120	138
7	Centrifugal Discharge	15,977	18,852	105	105	120	138 ❖
8	Recip. Discharge	15,893	18,752	350	400	500	550
9	Recip. Recycle	0	0	105	105	120	138
10	Air Cooler Inlet	5,837	7,551	350	400	492	550
11	Air Cooler Outlet	5,812	7,521	70	100	487	550
12	Dryer Purge	247 ****	296 ****	70	100	484	550
13	Air To Fuel Feed	4,492 ***	5,622	70	100	474	550
14	Air To Instr. Air System	1,058	1,603	70	100	487	550
15	Air To Gasifier	9,506	11,407	350	400	492	550-
16	Condensate	5	6	350	400	500	550
17	Condensate	25	30	350	400	492	550
18	C.W. Supply	11,860	14,000	85	95	40	60
19	C.W. Return	11,860	14,000	105	115	30	60
20	Condensate	84	100	200	215	500	550
21	C.W. Supply	0	14,000	85	95	40	60
22	C.W. Return	0	14,000	105	115	30	60
23	C.W. Supply	17,500	22,650	85	95	40	60
24	C.W. Return	17,500	22,650	105	115	30	60

- * This data reflects a 20 % contingency added to " normal " flow (process flow only) requirements @ 325 psig gasifier operation.
- ** Units for these data are psia.
- *** These flows will occasionally be increased by ~ 39 SCFM when the charge and transfer hoppers in the fuel conveying system undergo pressure equalization.
- **** Actual dryer purge flow will depend upon the dryer technology eventually chosen. Compressor sizing calculations have assumed a 5% purge flowrate.
- ❖ Assumes that the rise to surge pressure is 15% above design pressure.

234

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LF - 1

System Name Process Air System

Flow sheet No. 16N25706-40-F-1LF-001

DESIGN NOTES:

- 1) The following is the basis for process air compressors, air cooler, and air dryer sizing.

Estimated Based Upon 5/31/95 Mass Balance
Unless Otherwise Noted.

Process	Air Flowrate	
Pyrolyzer (Stream No. [9c])	3,579	lb/hr
Gasifier (Stream No. [9d])	5,927	lb/hr
Coal Conveying ([9b])	4,492 *	lb/hr
Sub-total =	14,013	lb/hr
Air Receiver Losses	5	lb/hr
Fuel Feed Air Dryer Purge	247	lb/hr
Mass Loss From Fuel Feed Air Cooler	25	lb/hr
Compressor Losses	384	lb/hr
Sub-total =	661	lb/hr
Total =	14,674	lb/hr
Instrument Air Requirement	1,603	lb/hr

Fuel Feed Air Dryer Capacity		
To Process	5,622 **	lb/hr
Purge	296	lb/hr
Total	5,918	lb/hr
(Includes 20% Contingency)		

Fuel Feed Air Cooler Capacity		
To Air Dryer	5,918	lb/hr
To P & I Air	1,603	lb/hr
Condensate Losses	5	lb/hr
Total =	7,526	lb/hr

Sub-total Inlet Air Flow =	16,277	lb/hr	(Without Contingency)
----------------------------	--------	-------	-----------------------

<u>Design Basis</u>	Total Inlet Air Flow =	19,212	lb/hr	(Value includes a 20% contingency for process air requirements only)
	Delivered Air Flow =	18,750	lb/hr	

- Data from the 5/31/95 Rich Sadowski Mass Balance estimates this value to be 3309 lbs/hr, however Clyde Pneumatic Conveying's estimate is 4492 lbs/hr (985.4 SCFM) per 6/9/95 memo to Joe Bushek.

** This value includes an additional 178 lbs/hr (39 SCFM) of air losses from lock vessels. (per Clyde memo dated 6/9/95 to Joe Bushek)

- 2) The "Design" discharge pressure of the air compressor is 500 psig. This pressure was defined as follows:

Minimum pressure to fuel delivery system:	441 psig
Line loss between fuel feed dryer and convey system	8 psi
Fuel Feed Dryer and Filter Δ P	10 psi
Line loss between fuel feed air dryer and air cooler	3 psi
Fuel Feed Cooler Δ P	5 psi
Line loss between fuel feed air cooler and receiver	3 psi
Air Receiver Δ P	2.5 psi
Line loss between receiver and compressor discharge	2.5 psi
Contingency	25 psi
Total =	500 psig .

235

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LF - 1

System Name Process Air System

Flow sheet No. 16N25706-40-F-1LF-001

**** All line loss values include at least a 30% contingency on equivalent length values.**

- 3) A 20 % contingency has been added to the flow data. Process flow data is from Mass Balance for 325 psig Base Operation dated 5/31/95..
- 4) Minimum compressor flow is based on a 60 % turndown capability in air compressor throughput before encountering compressor surge limitations.
- 5) Normal operation assumes process operating as illustrated in Design Note (1) without miscellaneous conveyor system losses.
- 6) The periodic instantaneous air requirements of the miscellaneous conveyor system users and other non-continuous users have not been added to the air compressor capacity. This requirement is being designed into the Process and Fuel Feed Air Receiving Tanks' capacity.
- 7) Compressor mass losses are estimated to be approximately 2% . These losses are those associated with moisture/air removal in the intercoolers between stages of compression.
- 8) The maximum system pressure is based upon a compressor / system safety valve setting of 110 % of the compressor design pressure of 500 psig (i.e. safety valve setting of 550 psig).

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

Nitrogen Storage and Distribution

EQUIPMENT:

Nitrogen Storage Tank No. 1 - 1LK-TK-1
Nitrogen Storage Tank No. 2 - 1LK-TK-2
Low Pressure Nitrogen Vaporizer - 1LK-VAP-1
High Pressure Nitrogen Vaporizer - 1LK-VAP-2
Nitrogen Pump No. 1 - 1LK-P-1
Nitrogen Pump No. 2 - 1LK-P-2
High Pressure Nitrogen Surge Tank - 1LK-TK-1
Nitrogen Heater - 1LK-HX-1

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

Nitrogen Storage and Distribution

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

I. DESIGN PHILOSOPHY

- 1) The facility requires nitrogen during four time periods; normal operation, gasifier transition, facility downtime, and utilities upset. Nitrogen use during these periods is as follows:

A) Normal Operation

- a) Inert Cyclone Lockhoppers - Depressurize lockhopper to vent system. Dump ash. Pressurize lockhopper with nitrogen.
- b) Inert Pyrolyzer Lockhopper - Depressurize lockhopper to vent system. Dump ash. Pressurize lockhopper with nitrogen.
- c) Seal Flare Tip - Continuously supply nitrogen to the flare tip to prevent air from entering into the flare vent system (the flare vent system is an inert atmosphere).
- d) Seal Rupture Disk Stack - Continuously supply nitrogen to the rupture disk stack tip to prevent air from entering into rupture disk stack vent system.
- e) Purge Lockhopper Vent System - Intermittently purge lockhopper vent system in order to prevent plugging from coal and ash particles.
- f) Purge Pressure Transmitters - Continuously seal pressure transmitter tubing in order to keep clear of coal and ash particles.
- g) Seal/Cool Equipment - Nitrogen seal and/or cool equipment in contact with coal gas (ash/fines conveyor, gasifier rupture disk, high temperature valves, etc.)

B) Gasifier Transition (Note 4)

1) Startup

- a) Pressure Test - Pressurize the gasifier system with nitrogen and monitor the leak rate.
- b) Vent Purge - Purge the flare vent piping and the rupture disk stack vent piping with nitrogen.
- c) Purge/Dry-out - Heat lockhoppers and lockhopper vent system with steam. Dry-out lockhoppers and vent system with nitrogen.
- d) Pyrolyzer Bed Building - Feed coke to pyrolyzer to build the pyrolyzer bed. Add nitrogen and steam to the fixed bed to maintain the oxygen concentration below the combustion limit.

- 2) Hot Hold - *No nitrogen required* (Note 5).

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

3) Normal Shutdown

- a) Purge Pyrolyzer Solids - Stop coal flow. Purge pyrolyzer solids with steam. *No nitrogen required.*
- b) Burn-out Fixed Bed - Air and steam to fixed bed. *No nitrogen flow to fixed bed.* Nitrogen inert lockhoppers and vent system.
- c) Purge and Inert - Steam purge gasifier system. Nitrogen to pyrolyzer and fixed bed for 15 minutes to dry out entire system. Lock up system under a nitrogen blanket unless personnel entry is anticipated.

4) Emergency Shutdown via Flare Stack

- a) Reduce pressure via Flare - Depressurize system to 6 psig through the gasifier bleed control valve. *No nitrogen required.*
- b) Dump Pyrolyzer Solids / Inert Fixed Bed - Minimum steam flow to pyrolyzer and fixed bed. *No nitrogen flow to gasifier.* Nitrogen inert lockhoppers and vent system.
- c) Inert - Nitrogen to pyrolyzer and fixed bed for 15 minutes to inert and dry out the gasifier. Lock up system under a nitrogen blanket unless personnel entry is anticipated.

5) Emergency Shutdown via Rupture Disk

- a) Reduce pressure via Rupture Disk - Depressurize system to 6 psig through the gasifier rupture disk. Add steam to pyrolyzer and fixed bed to control the rate of pressure decay. *No nitrogen required.*
- b) Dump Pyrolyzer Solids / Inert Fixed Bed - Minimum steam flow to pyrolyzer and fixed bed. *No nitrogen flow to gasifier.* Nitrogen inert lockhoppers and vent system.
- c) Inert - Nitrogen to pyrolyzer and fixed bed for 15 minutes to inert and dry out the gasifier. Replace rupture disk. Nitrogen purge and blanket coal gas system unless personnel entry is anticipated.

C) Facility Downtime - Nitrogen is used during plant downtime to blanket the following systems for corrosion protection (unless personnel entry is anticipated):

- a) water side of gasifier
- b) gas side of gasifier
- c) cooling water system

D) Utilities Upset

- a) Nitrogen is used as the backup fluid for the instrument air system if the instrument air compressor fails.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

- 2) The system (except for the heater) is leased from a nitrogen supplier. The initial lease duration is seven years.
 - 3) Liquid nitrogen is shipped to the facility and is stored in two cryogenic nitrogen storage tanks.
 - 4) A low pressure ambient vaporizer gasifies the liquid nitrogen. A PCV downstream of the vaporizer maintains the low pressure nitrogen system at 120 psig. The low pressure nitrogen system is used for instrument air backup, flare and rupture disk stack purging and sealing, and equipment blanketing. During the bid period the low pressure system is evaluated to determine its cost effectiveness (Depending on the lease cost of the low pressure vaporizer, it may be more economical to take everything from the high pressure system, and eliminate the low pressure system).
 - 5) Two full size, cryogenic, rotary, positive displacement pumps are located downstream of the liquid storage tank. One pump cycles on and off based on the nitrogen demand. The other pump serves as a backup. Pump discharge pressure is approximately 2350 psig.
 - 6) A high pressure ambient vaporizer gasifies the high pressure liquid nitrogen. The vaporizer is sized so that it can handle the total flow from both pumps running simultaneously.
 - 7) High pressure nitrogen storage tubes are located downstream of the vaporizer. The tubes have enough storage capacity to handle peak nitrogen requirements. (One high pressure nitrogen storage tank may be more economical than high pressure storage tubes. This option is evaluated during the bid period). A PCV downstream of the storage tubes maintains the high pressure nitrogen system at 420 psig. A safety valve is located downstream of the PCV and is set at 460 psig.
 - 8) High pressure steam heats the nitrogen to 400 deg F (the same as process air) in a carbon steel shell and tube heat exchanger. The nitrogen is heated so that it does not condense any vapors when admitted into the system. Steam supply to the heater is from the 400 psig steam header. In addition, natural gas and electric heaters are evaluated during the bid period.
 - 9) A PCV maintains the 420# header at 420 psig. A safety valve downstream of the PCV is set at 460 psig. The 420# header supplies nitrogen to the gasifier, lockhoppers, lockhopper vent system, and transmitter purge header.
 - 10) A PCV maintains the 120# header at 120 psig. A safety valve downstream of the PCV is set at 150 psig. The 120# header supplies nitrogen to the vent system hoppers.
 - 11) Nitrogen Purging:
 - a) Purging is accomplished by mixing (dilution purging), and requires ten volumes to assure that the vessel is completely purged.
 - b) When purging a vessel into service (air to nitrogen to coal gas) the goal is to reduce the oxygen level to less than 25% of the LOC (limiting oxidant concentration) of the coal gas. Proper instrumentation is required to ensure that purging requirements are met.
 - c) When purging a vessel out of service (coal gas to nitrogen to air) the goal is to reduce the fuel concentration to less than 25% of the LEL (lower explosive limit) of the coal gas. Proper instrumentation is required to ensure that purging requirements are met.
 - d) NFPA 325M (Fire Hazard Properties of Flammable Liquids, Gases, and Volatile Solids) states that at high temperatures the LEL of a fuel is lowered and NFPA 69 (Explosion Prevention Systems) states that at high temperatures the LOC of a fuel is lowered. However, no published data exist quantifying by how much these limits are reduced. To account for this uncertainty, the purge system is designed to reduce both the LOC and the LEL to 25% of their values at standard conditions.
- 241

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAX FLOW SCFM	NORM FLOW SCFM (Note 6)	AVG FLOW SCFM (Note 7)	NORM PRESS PSIG	NORM TEMP DEG F
1	Liquid Nitrogen	Note 2	Note 2	Note 2	150	-270
2	From LP Vaporizer	Note 2	Note 2	Note 2	150	50
3	LP Nitrogen	400	10	10	120	50
4	From Cryogenic Pumps	Note 2	Note 2	Note 2	2350	-250
5	From HP Vaporizer	Note 2	Note 2	Note 2	2300	50
6	From Surge Tank	Note 3	Note 3	Note 3	2300	60
7	HP Nitrogen	Note 3	Note 3	Note 3	700	60
8	From N2 Heater	Note 3	Note 3	Note 3	700	400
9	HP Steam	Note 2	Note 2	Note 2	400	475
10	Condensate	Note 2	Note 2	Note 2	400	475
11	420# Nitrogen	Note 3	Note 3	Note 3	420	400
12	To Pyrolyzer	Note 3	0	0	420	400
13	To Pyro Fluid Nozzles	Note 3	0	0	420	400
14	To Grate	Note 3	0	0	420	400
15	Pyrolyzer LH	300	0	1	420	400
16	Bottom Ash LH Vent	5000	0	92	420	400
17	No. 1 Cyclone LH	3000	0	14	420	400
18	No. 2 Cyclone LH	3000	0	7	420	400
19	Transmit Purge Hdr.	Note 3	Note 3	Note 3	420	400
20	Vent Cycl. Hopper	100	0	0	120	400
21	Instrument Air Backup	350	0	0	120	50
22	To Flare Seal	5	5	5	30	50
23	To Rupture Disk Stack	5	5	5	30	50
24	Deacerator Blanket	350	0	0	30	50
25	Cooling Jacket Blanket	350	0	0	30	50
26	To Flare Vent Piping	350	0	0	30	50
27	To Rupture Vent Piping	350	0	0	30	50
28	120# Nitrogen	3000	18	18	120	400
29	No. 1 Cycl. LH Vent	3000	0	25	420	400
30	No. 2 Cycl. LH Vent	3000	0	13	420	400
31	Pyrolyzer LH Vent	300	0	1	420	400

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1LK - 1

System Name Nitrogen Storage & Distribution
Flowsheet No. 16N25706-40-F-LK-001

III. DESIGN NOTES

- 1) Standard conditions for nitrogen are 14.7 psia and 70 deg F. The specific volume of nitrogen is 13.8 scf/lb.
- 2) Per Vendor.
- 3) Later.
- 4) Per Process States Map in Rev. "0" Gasifier Process Design Basis. All of the process transition states are not listed. Only those transition states that relate to nitrogen usage are listed in this document. For a complete list of process transitions, refer to the Process States Map.
- 5) Per "Hot Hold" Mass Balance, 3/22/95.
- 6) "Normal Flow" is the typical stream flow rate during normal GPIF operation. A normal flow of zero implies that the stream is not normally in operation.
- 7) "Average Flow" is the average stream flow rate during normal GPIF operation.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1SB - 1

System Name Package Boiler System

Flowsheet No. 16N25706-40-F-1SB-001

EQUIPMENT

Package Boiler (Equipment No. 1SJ-BLR-001)

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1SB - 1

System Name Package Boiler System
Flowsheet No. 16N25706-40-F-1SB-001

I. DESIGN PHILOSOPHY

1. Product gas to be burned in an incinerator without heat recovery, and steam generation.
2. Export no steam to Fort Martin host.
3. Utilize a small package boiler to provide steam for the gasifier process, and for utilities.
4. Package boiler outlet steam conditions will match gasifier requirements rather than any "host" requirements.
5. Use natural gas as fuel for the package boiler.
6. Exhaust package boiler flue gas directly to the atmosphere without any environmental treatment.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1SB - 1

System Name Package Boiler Sytem
Flowsheet No. 16N25706-40-F-1SB-001

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAXIMUM FLOW #/HR(or as noted)	NORMAL FLOW #/HR(or as noted)	MINIMUM FLOW #/HR(or as noted)	MAXIMUM TEMP. F	NORMAL TEMP. F	MAXIMUM PRESSURE PSIG	MIMIMUM PRESSURE PRIG
1	FEEDWATE R	6000	(See mass balance)	LATER	212	212	LATER VENDOR	LATER VENDOR
2	NATURAL GAS	LATER VENDOR	LATER VENDOR	LATER	Ambient	Ambient	40	LATER
3	FLUE GAS	LATER VENDOR	LATER VENDOR	LATER	300	250	LATER VENDOR	LATER VENDOR
4	STEAM	6000	(See mass balance)	LATER	560	550	500	400
5	COMBUST. AIR	LATER VENDOR	LATER VENDOR	LATER VENDOR	100	80(normal)	LATER VENDOR	LATER VENDOR
6	FLUE GAS RECIRC.	LATER VENDOR	LATER VENDOR	LATER VENDOR	300	250	LATER VENDOR	LATER VENDOR

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1SB - 1

System Name Package Boiler Sytem

Flowsheet No. 16N25706-40-F-1SB-001

III. DESIGN NOTES

1. Some package boiler manufacturers will require a separate, natural gas fired superheater, to provide superheated steam.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1SJ - 1

System Name Condensate/Deaerator/Feedwater

Flowsheet No. 16N25706-40-F-1SJ-001

EQUIPMENT

Deaerator (Eq. No. 1SJ-DEA-1)

Boiler Feedwater Pump (Eq. No. 1SJ-P-1)

Gasifier Cooling Water Pumps 1 and 2 (Eq. Nos. 1SJ-P-2, 1SJ-P-3)

248

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1SJ - 1

System Name Condensate/Deaerator/Feedwater
Flowsheet No. 16N25706-40-F-1SJ-001

I. DESIGN PHILOSOPHY

1. The function of the Deaerator/Feedwater System is to provide deaerated feedwater to the boiler steam drum. Deaerated feedwater is also utilized for makeup to the gasifier cooling water system, and for gasifier outlet temperature control during upset conditions.
2. Fort Martin service water is utilized as the raw water supply for the feedwater system.
3. The service water is forwarded from the Service & Fire Water Storage tank to the inlet to the Portable Water Treatment System. The treated water is then forwarded to Deaerator.
4. Boiler steam, in conjunction with the deaerator internals, reduces the levels of dissolved gases in the treated water. The expunged gases are vented to atmosphere. The deaerated water is then stored in the storage tank section of the deaerator unit for use as feedwater.
5. An oxygen scavenger is injected into the feedwater storage tank to further reduce the oxygen content. A neutralizing amine is added for pH control.
6. The Boiler Feedwater Pump takes suction from the storage tank. The feedwater pump suction line also provides water to the two Gasifier Cooling Water Makeup Pumps.
7. The boiler feedwater pump discharge line is piped to the economizer section of the Package Boiler.
8. A branch of the boiler feedwater provides high pressure water to the gasifier out for temperature control. Spray water to the gasifier outlet is not required during normal conditions.
9. An ARC valve is located downstream of the feedwater pump discharge in order to maintain minimum flow requirements at all plant conditions. The ARC valve recirculates all or a portion of feedwater pump flow back to the feedwater storage tank.. A backpressure regulator located in the recirculation line at the deaerator, provides constant backpressure on the ARC valve and prevents steam flashing in the recirculation line.
10. The Portable Water Treatment system is a "once-through" system..
11. Elevation of Deaerator/Feedwater Storage Tank will be based on required net positive suction head of the boiler feedwater pump at deaerator operating pressure with a minimum 10% margin of safety added.
12. The storage capacity of the deaerator is sized to provide 15 minutes of feedwater and gasifier cooling water makeup flows with zero condensate makeup flow. Normal level in the storage tank will be 2/3 of the tank diameter above the tank bottom. The storage tank is equipped with a high level dump line that discharges to the Blowoff Tank.
13. The operating pressure of the Deaerator is 5 psig. This produces a feedwater temperature of 227 °F.
14. The feedwater pump flow is based on requirements to the boiler. A margin of 10% was added to the calculated value in determining this value. The feedwater pumps total head is based on system losses, static head and drum pressure. A margin of 25% was added to the calculated pressure drop in determining this number.

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1SJ - 1

System Name Condensate/Deaerator/Feedwater
Flowsheet No. 16N25706-40-F-1SJ-001

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAXIMUM FLOW #/HR (or as noted)	NORMAL FLOW #/HR (or as noted)	MINIMUM FLOW #/HR (or as noted)	MAXIMUM TEMP. °F	MINIMUM TEMP. °F	MAXIMUM PRESS.. PSIG	MINIMUM PRESS.. PSIG
1	Service Water from Storage Tank	Hold	Hold	Hold	90	70	100	(See Mass Balance)
2	Treated Water from Water Treatment System	Hold	(See Mass Balance)	(See Mass Balance)	90	(See Mass Balance)	100	(See Mass Balance)
3	Steam	Hold	(See Mass Balance)	(See Mass Balance)	250	(See Mass Balance)	10	(See Mass Balance)
4	FW Pump Suction	Hold	(See Mass Balance)	(See Mass Balance)	250	(See Mass Balance)	10	(See Mass Balance)
5	FW from Gasifier Cooling Water Pumps	10	(See Mass Balance)	(See Mass Balance)	250	(See Mass Balance)	Hold	(See Mass Balance)
6	FW to Boiler	Hold	(See Mass Balance)	(See Mass Balance)	250	(See Mass Balance)	Hold	(See Mass Balance)
7	FW to Gasifier Outlet	Hold	0	0	250	227	Hold	Hold

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1SJ - 1

System Name Condensate/Deaerator/Feedwater
Flowsheet No. 16N25706-40-F-1SJ-001

III. DESIGN NOTES

1. Current design is as based on Mass Balance dated (later). Design will be finalized when detailed information on the boiler is received from the manufacturer.
2. Steam flow to the Deaerator was estimated at 5% of the feedwater outlet flow. The actual amount will be finalized once design on the feedwater system is complete.
3. The elevation of the Deaerator normal water level is estimated at 20 feet above grade.
4. Conductivity of the drum water will be controlled by continuously blowing down the steam drum. A blowdown of 1% of steam outlet flow has been assumed.
5. Steam produced by the Gasifier Cooling Water System is independent from steam generated in the boiler. Steam generated in the gasifier cooling water system is used strictly condensed, except for a very small flow into the gasifier..

SYSTEM PROCESS DESIGN BASIS
PDB No. 40 - 1WS - 1
System Name Process Waste Water Distribution
Flowsheet No. 16N25706-40-F-1WS-002

EQUIPMENT

Storm/Process Waste Sump Pumps (Eq. Nos. 1WS-P-1, 1WS-P-2)

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - IWS - 1

System Name Process Waste Water Distribution

Flowsheet No. 16N25706-40-F-IWS-002

I. DESIGN PHILOSOPHY

1. The function of the Process Waste Water Distribution System is to collect and forward the GPIF waste water to the Fort Martin waste water system.
2. The Storm/Process Waste Sump collects condensate from the GPIF to Fort Martin steam line, waste water from the fire pump house floor drains, waste water from the miscellaneous plant floor drains, process water from the boiler blowoff tank, and coal pile runoff (rain) water.
3. One of two 100% capacity Storm/Process Waste Sump Pumps forwards the waste water along the pipe bridge to the Fort Martin waste water system.
4. Flue gas scrubber waste water ties into the storm/process waste water line downstream of the sump pumps and is also forwarded to Fort Martin.

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1WS - 1

System Name Process Waste Water Distribution

Flowsheet No. 16N25706-40-F-1WS-002

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	MAXIMUM FLOW GPM	NORMAL FLOW GPM	MINIMUM FLOW GPM	MAXIMUM TEMP. °F	MINIMUM TEMP. °F	MAXIMUM PRESS.. PSIG	MINIMUM PRESS.. PSIG
1	From Condensate Collection Tank	Hold	Hold	Hold	Hold	Hold	Hold	Hold
2	From Fire Pump House Drains	Hold	Hold	Hold	Hold	Hold	Hold	Hold
3	From Miscellaneous Drains	Hold	Hold	Hold	Hold	Hold	Hold	Hold
4	From Blowoff Tank	Hold	Hold	Hold	Hold	Hold	Hold	Hold
5	Coal Pile Run-off	Hold	Hold	Hold	Hold	Hold	Hold	Hold
6	Process Waste Pump Discharge	Hold	Hold	Hold	Hold	Hold	Hold	Hold
7	Scrubber Waste Water	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)	(See Mass Balance)
8	Waste Water to Fort Martin	Hold	Hold	Hold	Hold	Hold	Hold	Hold

SYSTEM PROCESS DESIGN BASIS

PDB No. 40 - 1WS - 1

System Name Process Waste Water Distribution

Flowsheet No. 16N25706-40-F-1WS-002

III. DESIGN NOTES

1. Current design is based on Mass Balance dated (later).
2. The Storm/Process Waste Sump is sized to hold 20,000 gallons of water. This capacity along with the rainwater storage capability of the coal yard is based on the 10 year 24 hour storm as depicted in West Virginia Erosion and Sediment Control Handbook for Developing Areas.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 1

Equipment Name Coal Storage Bin
Equipment No. 1DH-TK-1
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

PROCESS DESIGN BASIS
PDB No. 82-IDH-1

Equipment Name	<u>Coal Storage Bin</u>
Equipment No.	<u>1DH-TK-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Storage Bin provides several hours of live fuel inventory for the PyGas™ Coal Gasifier.
2. The PyGas™ Coal Gasifier and Coal Storage Bin will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
3. The Coal Storage Bin will be installed outdoors. See Design Notes for ambient weather criteria.
4. Coal feed to the bin will be continuous 8 hours per day 7 days per week during each two week period of operation.
5. The minimum and maximum capacity of coal flow to the Coal Storage Bin will be based on the 7 day, 24 hour average operating capacity of the Mass Balance being handled in a 8 hour operating period, 7 days per week.
6. The Coal Storage Bin discharge will be assisted utilizing a Vibratory Bin Discharger and multiple Air Cannons.

PROCESS DESIGN BASIS
PDB No. 82-IDH-1

Equipment Name Coal Storage Bin
Equipment No. 1DH-TK-1
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COAL IN	18878	(See Mass Bal.)		130	(See Mass Bal.)		
2	PRODUCT COAL OUT	6675	(See Mass Bal.)		130	(See Mass Bal.)		
3	BIN VENT (SOLIDS)	4	(See Mass Bal.)		100	(See Mass Bal.)		
	BIN VENT (GAS)	6188						

1. Hours Storage Available	19
2. Effective Bin Volume	1520 Ft ³ , 38 Tons
3. Bin Diameter	12'-0"
4. Discharge Cone Angle	60° (Min)
5. Bin Discharger Size	6'-0" Dia. (Min)

PROCESS DESIGN BASIS
PDB No. 82-IDH-1

Equipment Name	<u>Coal Storage Bin</u>
Equipment No.	<u>1DH-TK-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

II. DESIGN CRITERIA - (cont'd.)

6. Basic design loads include live, wind, and earthquake in addition to dead loads. Minimum basic loads shall be:

Roof Load:	Roof Live Load = 100 psf (No Reduction Allowed)
Snow Load:	PG = 30 psf Ground Snow Load, Snow Exposure Factor $C_e = 0.9$
Wind Load:	70 mph, Exposure C
Seismic:	$A_v = < 0.05$, $A_a = < 0.05$, Hazard Exposure Group = 1 Soil - Profile Type = S_3
Importance Factor (I):	I (Snow) = 1.0, I (Wind) = 1.0

7. Snow and wind loading shall be in accordance with the West Virginia State Building Code (BOCA), latest edition, and Factory Mutual Standards.
8. Combinations of the loads shall be as specified in the West Virginia State Building Code (BOCA), latest edition.

PROCESS DESIGN BASIS

PDB No. 82-IDH-1

Equipment Name	<u>Coal Storage Bin</u>
Equipment No.	<u>1DH-TK-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES

- Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.

2. Coal Type	Bituminous
3. Coal Moisture	6%
4. Coal Specific Heat	0.30 Btu/Lb.-F
5. Coal Bulk Density	50 #/Ft ³
6. Angle of Repose	35 deg.
7. Coal Grindability Index	40-90
8. Coal Feed:	

<u>Size Analysis</u>	<u>Sample</u>
(As Received)	(Estimated)

+1-1/2"		0.0%
-1-1/2	+1	6.3%
-1	+3/4	7.3%
-3/4	+1/2	8.5%
-1/2	+3/8	8.4%
-3/8	+1/4	11.7%
-1/4	+#4 (Mesh)	8.2%
-4	+6	7.7%
-6	+16	19.6%
-16	+30	8.3%
-30	+50	5.1%
-50	+100	3.6%
-100	+200	2.1%
-200		3.2%

Note: The coal size gradation analysis shown above is taken from the Riley Fuels Laboratory Test Report for three coals used at the Fort Martin Facility dated February 1, 1994. The size gradation for Consol #2 coal was used.

- Design Operating Temperature 100°F

PROCESS DESIGN BASIS

PDB No. 82-IDH-1

Equipment Name	<u>Coal Storage Bin</u>
Equipment No.	<u>1DH-TK-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES (cont'd.)

10. Ambient Weather
Criteria

Design Temperature:

Dry Bulb:

Winter -	-20°F (lowest on record-use for freeze protection)
Winter -	4° F (99%)
Summer -	90° (99%)

Wet Bulb: 74° (99%)

Performance Temperature: 80°

Performance Relative Humidity: 60%

11. All data, i.e. capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum required.

12. Bin nozzles required for:

Material Inlet
Dust Collector
Top Manway
Continuous Level Monitor
Vac/Press. Relief Hatch
High Level Control
Low Level Control
Bottom Manway
Air Cannons (4)
Bin Discharger
Vent from Bucket Elevator

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 2

Equipment Name Coal Storage Bin Discharger
Equipment No. 1DH-CONV-2
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

PROCESS DESIGN BASIS
PDB No. 82-IDH-2

Equipment Name	<u>Coal Storage Bin Discharger</u>
Equipment No.	<u>1DH-CONV-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-F-1DH-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Storage Bin Discharger will promote coal feed from the Coal Storage Bin and deliver it to the Coal Screw Feeder.
2. The PyGas TMCoal Gasifier and Coal Storage Bin Discharger will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
3. The Coal Storage Bin Discharger will be installed outdoors. See Design Notes for ambient weather criteria.

PROCESS DESIGN BASIS
PDB No. 82-IDH-2

Equipment Name Coal Storage Bin Discharger
Equipment No. 1DH-CONV-2
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Product Coal In	6675	(See Mass Bal.)		130	(See Mass Bal.)		
2	Product Coal Out	6675	(See Mass Bal.)		130	(See Mass Bal.)		

PROCESS DESIGN BASIS

PDB No. 82-IDH-2

Equipment Name	<u>Coal Storage Bin Discharger</u>
Equipment No.	<u>1DH-CONV-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES

- Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.
- Coal Type Bituminous
- Coal Moisture 6%
- Coal Specific Heat 0.30 Btu/Lb-F
- Coal Bulk Density 50 #/Ft³
- Coal Grindability Index 40-90
- Angle of Repose 35 deg.
- Coal Feed

<u>Size Analysis</u> (As Received)	<u>Sample</u> (Estimated)
+ 1-1/2	0.0%
-1-1/2 + 1	6.3%
-1 + 3/4	7.3%
-3/4 + 1/2	8.5%
-1/2 + 3/8	8.4%
-3/8 + 1/4	11.7%
-1/4 + #4 (mesh)	8.2%
-4 + 6	7.7%
-6 + 16	19.6%
-16 + 30	8.3%
-30 + 50	5.1%
-50 + 100	3.6%
-100 + 200	2.1%
-200	3.2%

Note: The coal size gradation analysis shown above is taken from the Riley Fuels Laboratory Test Report for three coals used at the Fort Martin Facility dated February 1, 1994. The size gradation for Consol #2 was used.

PROCESS DESIGN BASIS

PDB No. 82-IDH-2

Equipment Name	<u>Coal Storage Bin Discharger</u>
Equipment No.	<u>1DH-CONV-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES (cont'd.)

9. Design Operating
Temperature 100°F

10. Ambient Weather
Criteria

Design Temperature:

Dry Bulb:

Winter -	-20°F (lowest on record-use for freeze protection)
Winter -	4° F (99%)
Summer -	90° (99%)

Wet Bulb: 74° (99%)

Performance Temperature: 80°

Performance Relative Humidity: 60%

11. All data, i.e. capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum required.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 3

Flowsheet No. 16N25706-82-F-1DH-001

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 3

Equipment Name Coal Screw Conveyor
Equipment No. 1DH-CONV-1
System Name Coal Receiving, Storage, & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 3

Equipment Name Coal Screw Feeder
Equipment No. 1DH-FDR-2
System Name Coal Receiving, Storage, & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

PROCESS DESIGN BASIS
PDB No. 82-IDH-3

Equipment Name	<u>Screw Conveyors & Feeders</u>
Equipment No.	<u>1DH-FDR-1; 1DH-CONV-1; 1DH-FDR-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

I. DESIGN PHILOSOPHY

1. The screw conveyors and feeders transport coal or coke breeze from point to point in the process.
2. The PyGas™ Coal Gasifier and Coal Screw Feeder 1DH-FDR-2 will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period. The Coal Screw Feeder 1DH-FDR-1 and Coal Screw Conveyor 1DH-CONV-1 will operate continuously 8 hours per day, 7 days per week for the two week periods.
3. The minimum and maximum capacity of the Coal Screw Feeder 1DH-FDR-1 and Coal Screw Conveyor 1DH-CONV-1 will be based on the 7 day, 24-hour average operating capacity of the Mass Balance being handled in a 8-hour operating period, 7-days per week.
4. The screw conveyors and feeders will be installed outdoors. See Design Notes for ambient weather criteria.
5. The minimum conveyor and feeder size is 12" diameter.
6. Coke breeze will be handled by the coal handling equipment for use as a start-up fuel and potentially as a "Hot Hold" condition fuel in the PyGas™ Coal Gasifier at a reduced capacity.

270

PROCESS DESIGN BASIS
PDB No. 82-IDH-3

Equipment Name Coal Screw Feeder
Equipment No. 1DH-FDR-1
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

II. DESIGN CRITERIA

COAL HANDLING OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COAL IN	18878	15102	15102	130	(SEE MASS BAL.)		
2	PRODUCT COAL OUT	18878	15102	15102	130	(SEE MASS BAL.)		

COKE HANDLING OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COKE BREEZE IN	9439	7551	7551	130	(SEE MASS BAL.)		
2	PRODUCT COKE BREEZE OUT	9439	7551	7551	130	(SEE MASS BAL.)		

271

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-009
Sirrinc Job No. 16N25706

Page No. 6 of 9
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDH-3

Equipment Name	<u>Coal Screw Conveyor</u>
Equipment No.	<u>1DH-CONV-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

II. DESIGN CRITERIA

COAL HANDLING OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	PRODUCT COAL IN	18878	15102	15102	130	(SEE MASS BAL.)		
2	PRODUCT COAL OUT	18878	15102	15102	130	(SEE MASS BAL.)		

COKE HANDLING OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	PRODUCT COKE BREEZE IN	9439	7551	7551	130	(SEE MASS BAL.)		
3	PRODUCT COKE BREEZE OUT	9439	7551	7551	130	(SEE MASS BAL.)		

272

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-009
Sirrinc Job No. 16N25706

Page No. 7 of 9
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDH-3

Equipment Name	<u>Coal Screw Feeder</u>
Equipment No.	<u>1DH-FDR-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-00</u>

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS. STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COAL IN	6675	(SEE MASS BAL.)		130	(SEE MASS BAL.)		
2	PRODUCT COAL OUT	6675	(SEE MASS BAL.)		130	(SEE MASS BAL.)		

PROCESS DESIGN BASIS

PDB No. 82-IDH-3

Equipment Name	<u>Screw Conveyors & Feeders</u>
Equipment No.	<u>1DH-FDR-1; 1DH-CONV-1; 1DH-FDR-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES

- Product coal and coke breeze flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal and coke breeze flows, Mass and Energy Balance results, to allow for operation variations.
- The maximum and minimum flow rates for coke breeze are based on the coal feed capacity with a density of 50 pcf and are reduced by 50% when handling coke breeze with a density of 25 pcf.

3. Coal Type	Bituminous
4. Coal Moisture	6%
Coke Moisture	0%
5. Coal Specific Heat	0.30 Btu/lb. -F
6. Coal Bulk Density	50#/Ft ³
Coke Breeze Bulk Density	25-35#/Ft ³
7. Coal Grindability Index	40 - 90
8. Coke Breeze Size	-1/4" x 0"

9. Coal Feed:

<u>Size Analysis</u>	<u>Sample</u>
(As Received)	

	+1-1/2"	0.0%
-1-1/2	+1	6.3%
-1	+3/4	7.3%
-3/4	+1/2	8.5%
-1/2	+3/8	8.4%
-3/8	+1/4	11.7%
-1/4	+#4 (Mesh)	8.2%
-4	+6	7.7%
-6	+16	19.6%
-16	+30	8.3%
-30	+56	5.1%
-50	+100	3.6%
-100	+200	2.1%
-200		3.2%

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-009
Sirmine Job No. 16N25706

Page No. 9 of 9
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDH-3

Equipment Name	<u>Screw Conveyors & Feeders</u>
Equipment No.	<u>1DH-FDR-1; 1DH-CONV-1; 1DH-FDR-2</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III DESIGN NOTES - Continued

Note: The coal size gradation analysis shown above is taken from the Riley Fuels Laboratory Test Report for three coals used at the Fort Martin Facility dated February 1, 1994. The size gradation for Consol #2 coal was used.

10. Design Operating 130°F
Temperature

11. Ambient Weather Criteria

Design Temperature:

Dry Bulb:

Winter

-20°F (lowest on record-use for freeze protection)

Winter

4°F (99%)

Summer

90°F (99%)

Wet Bulb:

74°F (99%)

Performance Temperature:

80°F

Performance Relative Humidity:

60%

12. All data, i.e., capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum requirement.

275

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 4

Equipment Name Coal Bucket Elevator
Equipment No. 1DH-ELEV-1
System Name Coal Receiving, Storage, & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

PROCESS DESIGN BASIS
PDB No. 82-IDH-4

Equipment Name	<u>Coal Bucket Elevator</u>
Equipment No.	<u>1DH-ELEV-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Bucket Elevator will receive the coal or coke breeze from the Coal Screw Feeder and raise the coal or coke breeze and discharge to the Coal Screw Conveyor.
2. The PyGas™ Coal Gasifier and Coal Bucket Elevator will operate continuously, 8 hours per day, 7 days per week for two week periods and be out of service for six weeks between each period.
3. The minimum and maximum capacity of the Coal Bucket Elevator will be based on the 7 day, 24-hour average operating capacity of the Mass Balance being handled in a 8-hour operating period, 7 days per week.
4. The Coal Bucket Elevator will be installed outdoors. See Design Notes for ambient weather design criteria.
5. The vent gas from the Coal Bucket Elevator will be piped to the Coal Storage Bin.
6. The Coal Bucket Elevator will be free standing design with bracing to the Coal Storage Bin for stability.
7. Coke breeze will be handled by the Coal Bucket Elevator for use as a start-up fuel and potentially as a "Hot Hold" condition fuel in the PyGas™ Coal Gasifier at a reduced capacity.

277

PROCESS DESIGN BASIS
PDB No. 82-IDH-4

Equipment Name	<u>Coal Bucket Elevator</u>
Equipment No.	<u>1DH-ELEV-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

II. DESIGN CRITERIA

NORMAL COAL HANDLING OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR	MAX. FLOW #/HR	MIN. FLOW #/HR	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS. PSIG
1	Product Coal In	18878	15102	15102	130	(SEE MASS BAL.)		
2	Product Coal Out	18689	14951	14951	130	(SEE MASS BAL.)		
3	Dust Vent (Solids)	189	151	151	130	(SEE MASS BAL.)		

COKE HANDLING OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR	MAX. FLOW #/HR	MIN. FLOW #/HR	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS. PSIG
1	Product Coke Breeze In	9439	7551	7551	130	(SEE MASS BAL.)		
2	Product Coke Breeze Out	9345	7475	7475	130	(SEE MASS BAL.)		
3	Dust Vent (Solids)	94	76	76	130	(SEE MASS BAL.)		

278

PROCESS DESIGN BASIS
PDB No. 82-IDH-4

Equipment Name	<u>Coal Bucket Elevator</u>
Equipment No.	<u>1DH-ELEV-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES

- Product coal and coke breeze flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal and coke breeze flows, Mass and Energy Balance results, to allow for operation variations.
- The maximum and minimum flow rates for coke breeze are based on the coal feed capacity with a density of 50 pcf and are reduced by 50% when handling coke breeze with a density of 25 pcf.
- Coal Type Bituminous
- Coal Moisture 6%
- Coke Breeze Moisture 0%
- Coal Specific Heat 0.30 Btu/Lb-F
- Coal Bulk Density 50 #/Ft³
- Coke Breeze Bulk Density 25-35 #/ft³
- Coal Grindability Index 40-90
- Coke Breeze Size -1/4" x 0
- Coal Feed:

Size Analysis
(As Received)

Sample

	+1-1/2"	0.0%
-1-1/2	+1	6.3%
-1	+3/4	7.3%
-3/4	+1/2	8.5%
-1/2	+3/8	8.4%
-3/8	+1/4	11.7%
-1/4	+#4 (Mesh)	8.2%
-4	+6	7.7%
-6	+16	19.6%
-16	+30	8.3%
-30	+56	5.1%
-50	+100	3.6%
-100	+200	2.1%
-200		3.2%

PROCESS DESIGN BASIS
PDB No. 82-IDH-4

Equipment Name	<u>Coal Bucket Elevator</u>
Equipment No.	<u>IDH-ELEV-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

III. DESIGN NOTES - Continued

Note: The coal size gradation analysis shown above is taken from the Riley Fuels Laboratory Test Report for three coals used at the Fort Martin Facility dated February 1, 1994. The size gradation for Consol #2 coal was used.

10. Design Operating 130°F
Temperature

11. Ambient Weather
Criteria

Design Temperature:

Dry Bulb:

Winter - -20°F (lowest on record-use for
freeze protection)

Winter - 4°F (99%)

Summer - 90°F (99%)

Wet Bulk: 74°F (99%)

Performance Temperature: 80°F

Performance Relative
Humidity: 60%

12. All data, i.e., capacities, flows, sizes etc., indicated in
the Process Design Basis is to be considered the minimum
requirement.

280

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DH - 5

Equipment Name Coal Storage Bin Vent Dust Collector w/Exhaust Fan
Equipment No. 1DH-DCOL-1 and 1DH-FAN-2
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DH-001

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-004
Sirrinc Job No. 16N25706

Page No. 2 of 4
Date 8-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDH-5

Equipment Name	<u>Coal Storage Bin Vent Dust Collector w/Exhaust Fan</u>
Equipment No.	<u>1DH-DCOL-1 and 1DH-FAN-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DH-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Storage Bin Vent Dust Collector with exhaust fan will gather coal dust from the Coal Storage Bin.
2. The dust collector will operate continuously, 24 hours per day, for two week periods, and be out of service for six weeks between each period.
3. The dust collector will be installed outdoors. See Design Notes for ambient weather criteria.
4. Sensors will be provided on the dust collector for monitoring the differential pressure across the filter bags. A high differential pressure detected will sound an audible alarm and shut down the storage bin feed equipment.
5. The dust collector filter bags will include an integral grounding wire to prevent dust ignition from a static charge. All other areas of the dust collector exposed to dust and/or gas flow will include grounding devices to prevent the development and conductance of a static charge.

282

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-004
Sirrinc Job No. 16N25706

Page No. 3 of 4
Date 8-28-95
Rev. 1

PROCESS DESIGN BASIS

PDB No. 82-IDH-5

Equipment Name Coal Storage Bin Vent Dust Collector w/Exhaust Fan
Equipment No. 1DH-DCOL-1 and 1DH-FAN-1
System Name Coal Receiving, Storage & Reclaim
Flowsheet No. 16N25706-82-F-1DJ-001

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Dust Vent (Solids) (Gas)	1992 6188	(See Mass Bal.)		100	(See Mass Bal.)		
2	Exhaust Vent (Solids) (Gas)	3.98 6188	(See Mass Bal.)		100	(See Mass Bal.)		

283

PROCESS DESIGN BASIS
PDB No. 82-IDH-5

Equipment Name	<u>Coal Storage Bin Vent Dust Collector w/Exhaust Fan</u>
Equipment No.	<u>1DH-DCOL-1 and 1DH-FAN-1</u>
System Name	<u>Coal Receiving, Storage & Reclaim</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III DESIGN NOTES

1. Coal dust and exhaust flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum flow, Mass and Energy Balance results, to allow for operation variations.
2. Material Handling Coal dust from storage bin loading via bucket elevator and screw conveyor and vent from high pressure charge hopper.
3. Particle Size 100 mesh to and including 0.5 micron.
4. Moisture Content 1 to 6%
5. Design Operating Temperature 100°F
6. Efficiency Required 99.8%
7. Cloth to Air Ratio 6 to 1 minimum
8. Bag Cleaning Reverse pulse jet compressed air
9. Compressed Air Available Instrument air -
100 psig @ 100°F
10. Classification Class II, Division 2, Groups E & F
11. Motor Voltage Available 460 voltage, 3 phase, 60 hertz
12. Control Voltage Available 120 volt AC
13. Ambient Weather Criteria
Design Temperature:
Dry Bulb:
Winter -20°F (lowest on record-use for freeze protection)
Winter 4°F (99%)
Summer 90°F (99%)
Wet Bulb: 74°F (99%)
Performance Temperature: 80°F
Performance Relative Humidity: 60%
14. The dust collector will be complete with internal fire protection system.
15. All data, i.e., capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 1

Equipment Name Coal Screw Dryer
Equipment No. 1DJ-DRY-1
System Name Coal Preparation, & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 1

Equipment Name Oil Heater
Equipment No. 1DJ-HX-1
System Name Coal Preparation, & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-002
Simine Job No. 16N25706

Page No. 3 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-1

Equipment Name	Coal Screw Dryer
Equipment No.	1DJ-DRY-1
System Name	Coal Preparation & Limestone System
Flowsheet No.	16N25706-82-F-1DJ-001

I. DESIGN PHILOSOPHY

1. The Coal Screw Dryer will reduce the moisture of the crushed coal to less than 1%.
2. The PyGas™ Coal Gasifier and Coal Screw Dryer will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
3. The Coal Screw Dryer will be installed outdoors. See Design Notes for ambient weather design criteria.
4. The vent gas from the Coal Screw Dryer will be piped to the Coal Preparation Dust Collector.
5. Hot oil will be circulated through hollow flight screws in the dryer. The oil will be heated in a natural gas fired oil heater.
6. Oil heater controls will include a flame safety system.

287

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-002
Sirrinc Job No. 16N25706

Page No. 4 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-1

Equipment Name	<u>Coal Screw Dryer</u>
Equipment No.	<u>1DJ-DRY-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
Item	Process Stream	Design Flow #/Hr.	Max. Flow #/Hr.	Min. Flow #/Hr.	Max. Temp. °F	Min. Temp °F	Max. Press Psig	Min. Press Psig
1	Product Coal In	6608	(See Mass Bal.)		200	(See Mass Bal.)		
2	Product Coal Out	6542	(See Mass Bal.)		250	(See Mass Bal.)		
3	Dust Vent (Solids)	66	(See Mass Bal.)		150	(See Mass Bal.)		
4	Natural Gas	By Vendor	(See Mass Bal.)		N/A	(See Mass Bal.)		

288

PROCESS DESIGN BASIS
PDB No. 82-IDJ-1

Equipment Name	<u>Coal Screw Dryer</u>
Equipment No.	<u>1DJ-DRY-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES

1. Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow the operation variations.

2. Coal Type	Bituminous
3. Coal Moisture	6%
4. Coal Specific Heat	0.30 Btu/Lb-F
5. Coal Bulk Density	50#/Ft ³
6. Coal Grindability Index	40-90
7. Crushed Coal Feed:	

Size Analysis

(Anticipated)

-3/8 + 1/4
-1/4 + 1/8
-1/8 + 10 (mesh)
-10 + 20
-20 + 40
-40 + 100
-100 + 200

Sample

(Estimated)

3%
14%
15%
30%
20%
9%
5%

8. Target Outlet Moisture	<1.0%
9. Natural Gas	Available at 35 to 60 psig
10. Ambient Weather Criteria	

Design Temperature:

Dry Bulb:

Winter

-20°F (lowest on record-use for freeze protection)

Winter

4°F (99%)

Summer

90°F (99%)

Wet Bulb:

74°F (99%)

Performance Temperature:

80°F

Performance Relative Humidity:

60%

11. All data, i.e., capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 2

Equipment Name Coal Crusher
Equipment No. 1DJ-CRSH-1
System Name Coal Preparation, & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-003
Sirrinc Job No. 16N25706

Page No. 2 of 4
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-2

Equipment Name	<u>Coal Crusher</u>
Equipment No.	<u>1DJ-CRSH-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Crusher will reduce the incoming coal size to between -1/4 x 50 mesh for burning in the PyGas™ Coal Gasifier.
2. The Coal Crusher will be installed outdoors. See Design Notes for ambient weather design criteria.
3. The vent gas from the Coal Crusher will be piped to the Coal Preparation Dust Collector.
4. The Coal Crusher will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
5. The crusher will be roll or ring type with two stage crushing to minimize fines generation.
6. The coal grindability and sulfur content will vary with the specific test to be conducted.
7. A screw feeder will provide flow rate control to the coal crusher.

291

Gasification Improvement Facility
 Fort Martin Station, West Virginia
 Specification No. 16N25706-82-003
 Sirrine Job No. 16N25706

Page No. 3 of 4
 Date 08-28-95
 Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-2

Equipment Name	<u>Coal Crusher</u>
Equipment No.	<u>1DJ-CRSH-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Product Coal In	6675	(See Mass Bal.)		100	(See Mass Bal.)		
2	Product Coal Out	6608	(See Mass Bal.)		200	(See Mass Bal.)		
3	Dust Vent (Solids)	67	(See Mass Bal.)		150	(See Mass Bal.)		

PROCESS DESIGN BASIS

PDB No. 82-IDJ-2

Equipment Name	<u>Coal Crusher</u>
Equipment No.	<u>1DJ-CRSH-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III DESIGN NOTES

- Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.
- Coal Type Bituminous
- Coal Moisture 6%
- Coal Specific Heat 0.30 Btu/Lb-F
- Crushed Coal Target Size -1/4 x 50 mesh
- Coal Bulk Density 50 #/Ft³
- Coal Grindability Index 40-90
- Coal Feed:

<u>Size Analysis</u>	<u>Sample</u>
(As Received)	(Estimated)
+1-1/2"	0.0%
-1-1/2 +1	6.3%
-1 +3/4	7.3%
-3/4 +1/2	8.5%
-1/2 +3/8	8.4%
-3/8 +1/4	11.7%
-1/4 + #4 (Mesh)	8.2%
-4 +6	7.7%
-6 +16	19.6%
-16 +30	8.3%
-30 +50	5.1%
-50 +100	3.6%
-100 +200	2.1%
-200	3.2%
- Design Operating Temperature 150°F
- Ambient Weather Criteria

Design Temperature:	
Dry Bulb:	
Winter	-20°F (lowest on record-use for freeze protection)
Winter	4°F (99%)
Summer	90°F (99%)
Wet Bulb:	74°F (99%)
Performance Temperature:	80°F
Performance Relative Humidity:	60%
- All data, i.e., capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 3

Equipment Name Coal Classifier
Equipment No. 1DJ-CLF-1
System Name Coal Preparation, & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-82-005
Sirrinc Job No. 16N25706

Page No. 2 of 4
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-3

Equipment Name	<u>Coal Classifier</u>
Equipment No.	<u>1DJ-CLF-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Classifier will separate out the fines fraction (<50 mesh) of the crushed coal stream in preparation for burning in the PyGas™ Coal Gasifier.
2. The PyGas™ Coal Gasifier and Coal Classifier will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period..
3. The Coal Classifier will be installed outdoors. See Design Notes for ambient weather design criteria.
4. The vent gas from the Coal Classifier will be piped to the Coal Preparation Dust Collector.

295

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-82-005
Sirrinc Job No. 16N25706

Page No. 3 of 4
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-3

Equipment Name	<u>Coal Classifier</u>
Equipment No.	<u>1DJ-CLF-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Product Coal In	6412	(See Mass Bal.)		200	(See Mass Bal.)		
2	Product Coal Out	5205	(See Mass Bal.)		200	(See Mass Bal.)		
3	Coal Fines	1143	(See Mass Bal.)		200	(See Mass Bal.)		
4	Dust Vent (Solids)	64	(See Mass Bal.)		150	(See Mass Bal.)		

296

PROCESS DESIGN BASIS
PDB No. 82-IDJ-3

Equipment Name	<u>Coal Classifier</u>
Equipment No.	<u>1DJ-CLF-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III DESIGN NOTES

1. Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.

2. Coal Type:	Bituminous
3. Coal Moisture:	<1%
4. Coal Specific Heat:	0.30 Btu/Lb-F
5. Coal Bulk Density:	50#/Ft ³
6. Coal Grindability Index:	40-90
7. Crushed Coal Size (Target):	-1/4 x 50 mesh
8. Crushed Coal Feed:	

<u>Size Analysis</u> (Anticipated)	<u>Sample</u> (Estimated)
-3/8 +1/4	3%
-1/4 +1/4	14%
-1/8 +10 (mesh)	15%
-10 +20	30%
-20 +40	20%
-40 +100	9%
-100 +200	8.2%

9. Ambient Weather Criteria

Design Temperature:	
Winter	-20°F (lowest on record-use for freeze protection)
Winter	4°F (99%)
Summer	90°F (99%)
Wet Bulb:	74°F (99%)
Performance Temperature:	80°F
Performance Relative Humidity:	60%

10. All data, i.e., capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 4

Equipment Name Coal Weighbelt Feeder / Sampler
Equipment No. 1DJ-FDR-1, 1DJ-SMX-1
System Name Coal Preparation, & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

PROCESS DESIGN BASIS
PDB No. IDJ-4

Equipment Name	<u>Coal Weighbelt Feeder/Sampler</u>
Equipment No.	<u>1DJ-FDR-1, 1DJ-SMX-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Weighbelt Feeder/Sampler provides an accurate metering of coal fuel for combustion in the PyGas™ Coal Gasifier.
2. The PyGas™ Coal Gasifier and Coal Weighbelt Feeder/Sampler will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
3. The Coal Weighbelt Feeder/Sampler will be installed outdoors. See Design Notes for ambient weather design criteria.
4. The vent gas from the Coal Weighbelt Feeder/Sampler will be piped to the Coal Preparation Dust Collector.
5. The Coal Weighbelt Feeder will provide a controlled continuous feed rate to the Surge Bin of the Pyrolizer Feed System.
6. A cross-cut Sampler will be integrated into the discharge chute of the Coal Weighbelt Feeder.
7. Cross-cut samples of the coal discharge will be taken at intervals in accordance with ASTM requirements. Samples will be discharged to containers on the ground floor for lab analysis pick-up.
8. The Coal Weighbelt Feeder/Sampler will be totally enclosed and dust tight.

299

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-006
Sirrine Job No. 16N25706

Page No. 3 of 4
Date 8-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. IDJ-4

Equipment Name	<u>Coal Weightbelt Feeder/Sampler</u>
Equipment No.	<u>1DJ-FDR-1, 1DJ-SMX-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COAL IN	5153	(SEE MASS BAL.)		200	(SEE MASS BAL.)		
2	PRODUCT COAL OUT	5102	(SEE MASS BAL.)		175	(SEE MASS BAL.)		
3	DUST VENT (SOLIDS)	51	(SEE MASS BAL.)		125	(SEE MASS BAL.)		

300

PROCESS DESIGN BASIS

PDB No. IDJ-4

Equipment Name	<u>Coal Weightbelt Feeder/Sampler</u>
Equipment No.	<u>1DJ-FDR-1, 1DJ-SMX-1</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES

1. Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.
2. Coal Type Bituminous
3. Coal Moisture <1%
4. Coal Specific Heat 0.30 Btu/lb-F
5. Crushed Coal Size -1/4 x 50 mesh
6. Coal Bulk Density 50 #/Ft³
7. Coal Grindability Index 40-90
8. Crushed Coal Feed to Classifier

<u>Size Analysis</u>		<u>Sample</u>
(As Received)		(Estimated)
-3/8	+1/4	3%
-1/4	1/8	14%
-1/8	+10 (mesh)	15%
-10	+20	30%
-20	+40	20%
-40	+100	9%
-100	+200	5%

Note: The estimated coal size gradation shown above after crushing is based on the American Pulverizer analysis of a crusher discharge to produce 1/4" top size coal with the feed as depicted in the Riley Fuels Laboratory Test Report dated February 1, 1994.

9. Ambient Weather Criteria

Design Temperature:

Dry Bulb:

Winter: -20°F (lowest on record-use for freeze protection)

Winter: 4°F (99%)

Summer: 90°F (99%)

Wet Bulb: 74°F (99%)

Performance Temperature: 80°F

Performance Relative

Humidity: 60%

10. All data, i.e., capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 5

Equipment Name Coal Surge Bin
Equipment No. 1DJ-TK-2
System Name Coal Preparation, & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

PROCESS DESIGN BASIS
PDB No. 82-IDJ-5

Equipment Name	<u>Coal Surge Bin</u>
Equipment No.	<u>1DJ-TK-2</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Surge Bin provides temporary surge capacity for feed to the Coal Weighbelt Feeder.
2. The PyGas™ Coal Gasifier and Coal Surge Bin will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
3. The Coal Surge Bin will be installed outdoors. See Design Notes for ambient weather criteria.

PROCESS DESIGN BASIS
PDB No. 82-IDJ-5

Equipment Name	<u>Coal Surge Bin</u>
Equipment No.	<u>1DJ-TK-2</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COAL IN	5205	(See Mass Bal.)		200	(See Mass Bal.)		
2	PRODUCT COAL OUT	5153	(See Mass Bal.)		200	(See Mass Bal.)		
3	DUST VENT (SOLIDS)	52	(See Mass Bal.)		150	(See Mass Bal.)		

1. Hours Storage Available	0.167 (10 Minutes)
2. Effective Bin Volume	15 Ft. ³
3. Bin Diameter	3'-0" (Min)
4. Discharge Cone Angle	60° (Min)

PROCESS DESIGN BASIS
PDB No. 82-IDJ-5

Equipment Name	<u>Coal Surge Bin</u>
Equipment No.	<u>1DJ-TK-2</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES

1. Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.

2. Coal Type	Bituminous
3. Coal Moisture	<1%
4. Coal Specific Heat	0.30 Btu/Lb.-F
5. Coal Bulk Density	50 #/Ft ³
6. Coal Angle of Repose	35 deg.
7. Coal Grindability Index	40-90

8. <u>Size Analysis</u>	<u>Sample</u>
(As Received)	(Estimated)

-3/8	+1/4	3%
-1/4	+1/4	14%
-1/8	+10(mesh)	15%
-10	+20	30%
-20	+40	20%
-40	+100	9%
-100	+200	5%

Note: The estimated coal size gradation shown above after crushing is based on the American Pulverizer analysis of a crusher discharge to produce 1/4" top size coal with the feed as depicted in the Riley Fuels Laboratory Test Report dated February 1, 1994.

PROCESS DESIGN BASIS
PDB No. 82-IDJ-5

Equipment Name	<u>Coal Surge Bin</u>
Equipment No.	<u>1DJ-TK-2</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES (cont'd.)

9. Ambient Weather
Criteria

Design Temperature:

Dry Bulb:

Winter -	-20°F (lowest on record-use for freeze protection)
Winter -	4° F (99%)
Summer -	90° (99%)

Wet Bulb: 74° (99%)

Performance Temperature: 80°

Performance Relative Humidity: 60%

10. All data, i.e. capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum required.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 6

Equipment Name Coke Weighbelt Feeder
Equipment No. 1DJ-FDR-3
System Name Coal Preparation and Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

PROCESS DESIGN BASIS
PDB No. 82-IDJ-6

Equipment Name	<u>Coke Weighbelt Feeder</u>
Equipment No.	<u>1DJ-FDR-3</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coke Weighbelt Feeder provides an accurate metering of coke breeze for combustion in the PyGas™ Coal Gasifier during the start-up mode.
2. During desulfurization testing, the Coke Weighbelt Feeder provides an accurate metering of limestone for combustion in the gasifier.
3. The PyGas™ Coal Gasifier and Coke Weighbelt Feeder will operate continuously during the start-up phase.
4. Upon reaching the desired temperature and pressure in the gasifier start-up mode for coal feed, the feed of coke breeze will be reduced as the coal feed is increased.
5. The Coke Weighbelt Feeder will be installed outdoors. See Design Notes for ambient weather criteria.
6. The vent gas from the Coke Weighbelt Feeder will be piped to the Coal Preparation Dust Collector.
7. The Coke Weighbelt Feeder will provide a controlled continuous feed rate to the Surge Bin of the Pyrolizer Feed System.
8. The Coke Weighbelt Feeder will be totally enclosed and dust tight.
9. Coke breeze will be handled by the coal handling equipment for use as a start-up fuel and potentially as a "Hot Hold" condition fuel in the PyGas™ Coal Gasifier at a reduced capacity.

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-006
Sirrinc Job No. 16N25706

Page No. 3 of 4
Date 8-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-6

Equipment Name Coke Weightbelt Feeder
Equipment No. 1DJ-FDR-3
System Name Coal Preparation & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

II. DESIGN CRITERIA

GASIFIER START-UP OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COKE IN	505	(SEE MASS BAL.)		130	(SEE MASS BAL.)		
2	PRODUCT COKE OUT	500	(SEE MASS BAL.)		130	(SEE MASS BAL.)		
3	DUST VENT (SOLIDS)	5	(SEE MASS BAL.)		100	(SEE MASS BAL.)		

GASIFIER START-UP OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT LIMESTONE IN	1215	(See Mass Bal.)		130	80	14.9	10
2	PRODUCT LIMESTONE OUT	1203	(See Mass Bal.)		130	(See Mass Bal.)		
3	DUST VENT (SOLIDS)	12	(See Mass Bal.)		100	(See Mass Bal.)		

PROCESS DESIGN BASIS
PDB No. 82-IDJ-6

Equipment Name	<u>Coke Weightbelt Feeder</u>
Equipment No.	<u>1DJ-FDR-3</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES

1. Product coke breeze flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coke breeze flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.
2. Coke Moisture 0%
Limestone Moisture 1%
3. Coke Breeze Size -1/4" x 0
Limestone Size -1/8" x 200 Mesh
4. Coke Bulk Density 25-35 #/Ft³
Limestone Bulk Density 68 #/ft³
5. All data, i.e., capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 7

Equipment Name Coke Surge Bin
Equipment No. 1DJ-TK-7
System Name Coal Preparation and Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 7

Equipment Name Coke Surge Bin
Equipment No. 1DJ-TK-7
System Name Coal Preparation and Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

I. DESIGN PHILOSOPHY

1. The Coke Bin provides live storage of coke breeze for feed to the Coke Weighbelt Feeder during the start-up mode and potential "Hot Hold" condition of the PyGas™ Coal Gasifier.
2. During desulfurization testing, the Coke Bin will provide several hours of live sorbent inventory for the PyGas™ Coal Gasifier.
3. The PyGas™ Coal Gasifier and Coke Bin will operate continuously, during the start-up mode and desulfurization testing.
4. The Coke Bin will be installed outdoors. See Design Notes for ambient weather criteria.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 7

Equipment Name Coke Surge Bin
Equipment No. 1DJ-TK-7
System Name Coal Preparation and Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

II. DESIGN CRITERIA

GASIFIER START-UP OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
1	PRODUCT COKE BREEZE IN	9439	7551	7551	130	(See Mass Bal.)		
2	PRODUCT COKE BREEZE OUT	505	(See Mass Bal.)		130	(See Mass Bal.)		
3	DUST VENT (SOLIDS)	94	(See Mass Bal.)		100	(See Mass Bal.)		

DESULFURIZATION TESTING								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS. PSIG	MIN. PRESS. PSIG
4	PRODUCT LIMESTONE IN	20,000	8080*	4040	130	80	14.9	10
5	PRODUCT LIMESTONE OUT	1215	(See Mass Bal.)		130	(See Mass Bal.)		
6	DUST VENT (SOLIDS)	200	(See Mass Bal.)		100	(See Mass Bal.)		

* Maximum flow is based on actual truck unloading duration of 4 hours in a 8 hour day.

1. Hours Storage Available	16.875 Hours
2. Effective Bin Volume	270 Ft. ³
3. Bin Diameter	5'-0" (Min)
4. Discharge Cone Angle	60° (Min)

jrm/82-007C.doc

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 7

Equipment Name Coke Surge Bin
Equipment No. 1DJ-TK-7
System Name Coal Preparation and Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

III. DESIGN NOTES

1. Product coke breeze and limestone flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coke breeze and limestone flows, Mass and Energy Balance results, to allow for operation variations.
2. The maximum and minimum flow rates for coke breeze are based on the coal feed capacity with a density of 50 pcf and are reduced by 50% when handling coke breeze with a density of 25 pcf.
3. Coke Breeze Moisture 0%
Limestone Moisture 1%
4. Coke Breeze Bulk Density 25-35#/Ft³
Limestone Bulk Density 68#/Ft³
5. Coke Breeze Angle of Repose 45 deg.
Limestone Angle of Repose 45 deg.
6. Coke Breeze Size -1/4" x 0
Limestone Size -1/8" x 200 mesh
7. Ambient Weather Criteria

Design Temperature:

Dry Bulb:

Winter -	-20°F (lowest on record-use for freeze protection)
Winter -	4° F (99%)
Summer -	90° (99%)

Wet Bulb: 74° (99%)

Performance Temperature: 80°F

Performance Relative Humidity: 60%

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 7

Equipment Name Coke Surge Bin
Equipment No. 1DJ-TK-7
System Name Coal Preparation and Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

8. All data, i.e. capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum required.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 8

Equipment Name Truck Unload Pipe and Target Box
Equipment No. 1DJ-PSX-2 & 1DJ-RCV-1
System Name Limestone Unloading System
Flowsheet No. 16N25706-82-F-1DJ-001

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-012
Sirrinc Job No. 16N25706

Page No. 2 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-8

Equipment Name	<u>Truck Unload Pipe and Target Box</u>
Equipment No.	<u>1DJ-PSX-2 and 1DJ-RCV-1</u>
System Name	<u>Limestone Unloading System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Limestone Unloading System receives bulk limestone from a self-unloading truck at ground elevation and directs to the top inlet of the Coke Storage Bin.
2. The Limestone Unloading System will operate intermittently, 8 hours per day, 5 days per week for two week periods and be out of service for six weeks between each period.
3. The minimum and maximum capacity of limestone flow through the Limestone Unloading System to the Coke Storage Bin will be based on the 7 day, 24 hour average operating capacity of the Mass Balance being handled in a 8 hour operating period, 5 days per week.
4. The Limestone Unloading System will be installed outdoors. See Design Notes for ambient weather criteria.

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-012
Sirrinc Job No. 16N25706

Page No. 3 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-8

Equipment Name	<u>Truck Unload Pipe and Target Box</u>
Equipment No.	<u>1DJ-PSX-2 and 1DJ-RCV-1</u>
System Name	<u>Limestone Unloading System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

II. DESIGN CRITERIA

ITEM	PROCESS STREAM	DESIGN FLOW #/HR	MAX FLOW #/HR	MIN FLOW #/HR	MAX TEMP °F	MIN TEMP °F	MAX PRESS PSIG	MIN PRESS PSIG
1	Product Limestone In	20000	8080*	4040	130	80	14.9	10

* Maximum flow rate is based on actual truck unloading duration of 4 hours in a 8 hour day.

PROCESS DESIGN BASIS
PDB No. 82-IDJ-8

Equipment Name	<u>Truck Unload Pipe and Target Box</u>
Equipment No.	<u>1DJ-PSX-2 and 1DJ-RCV-1</u>
System Name	<u>Limestone Unloading System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES

1. Product limestone flow rates are from the Mass and Energy Balances. Design condition is approximately 95 percent above the maximum limestone flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations, 7 day material receipts in 5 days and rapid truck turnaround..
2. Limestone Size -1/8 x 200 mesh
3. Limestone Bulk Density 68 #/Ft³
4. Angle of Repose 30 deg.
5. Moisture Content 1 %
6. Limestone Feed Rate to Gasifier 962 #/hour
23,088 #/day @ 24 hours/day
(325 psig operation) 161,616 #/week @ 24 hours/day
7. Limestone Truck Capacity 20,000#
8. Limestone Truck Unload Capacity 20,000 #/hour maximum
9. Truck Delivery Schedule 1.62 (2) per day @ 5 days/week for 7 days
10. Truck Turnaround 4.95 (4) hrs/truck
11. Ambient Weather Criteria

Design Temperature:

Dry Bulb:

Winter - -20°F (lowest on record-use
for freeze protection)

Winter - 4° F (99%)

Summer - 90° (99%)

Wet Bulb: 74° (99%)

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-012
Sirrinc Job No. 16N25706

Page No. 5 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS

PDB No. 82-IDJ-8

Equipment Name	<u>Truck Unload Pipe and Target Box</u>
Equipment No.	<u>1DJ-PSX-2 and 1DJ-RCV-1</u>
System Name	<u>Limestone Unloading System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III. DESIGN NOTES (cont'd.)

Performance Temperature: 80°

Performance Relative Humidity: 60%

12. All data, i.e. capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum required.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 9

Equipment Name Coal Preparation Dust Collector w/Exhaust Fan
Equipment No. 1DJ-DCOL-1 and 1DJ-FAN-2
System Name Coal Preparation & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

PROCESS DESIGN BASIS
PDB No. 82-IDJ-9

Equipment Name	<u>Coal Preparation Dust Collector w/Exhaust Fan</u>
Equipment No.	<u>1DJ-DCOL-1 and 1DJ-FAN-2</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Preparation Dust Collector with exhaust fan will gather dust from the Coal Crusher, Coal Dryer, Coal Transfer System, Coal Weighbelt Feeder, Charge Hopper, Coke Bin And Coke Weighbelt Feeder, Coal Classifier, and Coal Surge Bin.
2. The dust collector will operate continuously, 24 hours per day, for two week periods, and be out of service for six weeks between each period.
3. The dust collector will be installed outdoors. See Design Notes for ambient weather criteria.
4. The Coal Preparation Dust Collector will include an airlock rotary valve for discharge of the collected dust to a tote bin. The dust collector discharge hopper will be sized to allow the airlock to be stopped for 15 minutes during tote bin change out.
5. A high level control will be provided in the dust collector discharge hopper to prevent excessive back-up of material.
6. Sensors will be provided on the dust collector for monitoring the differential pressure across the filter bags. A high differential pressure detected will sound an audible alarm and shutdown the coal preparation system equipment.
7. The dust collector filter bags will include an integral grounding wire to prevent dust ignition from a static charge. All other areas of the dust collector exposed to dust and/or gas flow will include grounding devices to prevent the development and conductance of a static charge.

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-004
Sirrinc Job No. 16N25706

Page No. 3 of 4
Date 8-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-IDJ-9

Equipment Name Coal Preparation Dust Collector w/Exhaust Fan
Equipment No. 1DJ-DCOL-1 and 1DJ-FAN-2
System Name Coal Preparation & Limestone System
Flowsheet No. 16N25706-82-F-1DJ-001

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Dust Vent (Solids) (Gas)	1089 16875	(See Mass Bal.)		250	(See Mass Bal.)		
2	Exhaust Vent (Solids) (Gas)	2.18 16875	(See Mass Bal.)		250	(See Mass Bal.)		
3	Fines to Tote Bin	1086.8	(See Mass Bal.)		250	(See Mass Bal.)		

PROCESS DESIGN BASIS
PDB No. 82-IDJ-9

Equipment Name	<u>Coal Preparation Dust Collector w/Exhaust Fan</u>
Equipment No.	<u>1DJ-DCOL-1 and 1DJ-FAN-2</u>
System Name	<u>Coal Preparation & Limestone System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III DESIGN NOTES

1. Coal dust and exhaust flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum flow, Mass and Energy Balance results, to allow for operation variations.
2. Material Handling Coal dust collected from the coal preparation process of crushing, drying, and handling for feed to the gasifier.
3. Particle Size 100 mesh to and including 0.5 micron.
4. Moisture Content 1 to 6%
5. Design Operating Temperature 250°F
6. Efficiency Required 99.8%
7. Cloth to Air Ratio 6 to 1 minimum
8. Bag Cleaning Reverse pulse jet compressed air
9. Compressed Air Available Instrument air -
100 psig @ 100°F
10. Classification Class II, Division 2, Groups E & F
11. Motor Voltage Available 460 voltage, 3 phase, 60 hertz
12. Control Voltage Available 120 volt AC
13. Ambient Weather Criteria
Design Temperature:
Dry Bulb:
Winter -20°F (lowest on record-use for freeze protection)
Winter 4°F (99%)
Summer 90°F (99%)
Wet Bulb: 74°F (99%)
Performance Temperature: 80°F
Performance Relative Humidity: 60%
14. All data, i.e., capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DJ - 10

System Name Coal Transfer System

Flowsheet No. 16N25706-82-F-1DJ-001

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-82-005
Sirrinc Job No. 16N25706

Page No. 2 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS

PDB No. 82-1DJ-10

Equipment Name	_____
Equipment No.	_____
System Name	<u>Coal Transfer System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

I. DESIGN PHILOSOPHY

1. The Coal Transfer System conveys dried, crushed coal to the next unit operation which is classification (fines removal).
2. The PyGas™ Coal Gasifier and Coal Transfer System will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
3. The Coal Transfer System will be installed outdoors. See Design Notes for ambient weather criteria.
4. The vent gas from the Coal Transfer System will be piped to the Cal Preparation Dust Collector.

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-82-005
Sitrine Job No. 16N25706

Page No. 3 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS
PDB No. 82-1DJ-10

Equipment Name _____
Equipment No. _____
System Name Coal Transfer System
Flowsheet No. 16N25706-82-F-1DJ-001

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR.	MAX. FLOW #/HR.	MIN. FLOW #/HR.	MAX. TEMP. °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Product Coal In	6542	(See Mass Bal.)		250	(See Mass Bal.)		
2	Product Coal Transfer	6477	(See Mass Bal.)		225	(See Mass Bal.)		
3	Product Coal Out	6412	(See Mass Bal.)		200	(See Mass Bal.)		
4	Dust Vent (Solids)	65	(See Mass Bal.)		150	(See Mass Bal.)		
5	Dust Vent (Solids)	65	(See Mass Bal.)		150	(See Mass Bal.)		

PROCESS DESIGN BASIS
PDB No. 82-1DJ-10

Equipment Name	_____
Equipment No.	_____
System Name	<u>Coal Transfer System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

III DESIGN NOTES

1. Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 20 percent above the maximum coal flow, Appendix A-8, Mass and Energy Balance results, to allow for operation variations.

2. Coal Type:	Bituminous
3. Coal Moisture:	<1%
4. Coal Specific Heat:	0.30 Btu/Lb-F
5. Coal Bulk Density:	50#/Ft ³
6. Coal Grindability Index:	40-90
7. Crushed Coal Feed	

<u>Size Analysis</u> (Anticipated)	<u>Sample</u> (Estimated)
---------------------------------------	------------------------------

-3/8	+1/4	3%
-1/4	+1/4	14%
-1/8	+10 (mesh)	15%
-10	+20	30%
-20	+40	20%
-40	+100	9%
-100	+200	5%

Note: The estimated coal size gradation shown above after crushing is based on the American Pulverizer analysis of a crusher discharge to produce 1/4" top size coal with the feed as depicted in the Riley Fuels Laboratory Test Report dated February 1, 1994.

Gasification Improvement Facility
Fort Martin Station, West Virginia
Specification No. 16N25706-82-82-005
Sirrinc Job No. 16N25706

Page No. 5 of 5
Date 08-28-95
Rev. 1

PROCESS DESIGN BASIS

PDB No. 82-1DJ-10

Equipment Name	_____
Equipment No.	_____
System Name	<u>Coal Transfer System</u>
Flowsheet No.	<u>16N25706-82-F-1DJ-001</u>

8. Ambient Weather Criteria

Design Temperature:

Dry Bulb:

Winter - -20°F (lowest on record-use for freeze protection)

Winter - 4°F (99%)

Summer - 90°F (99%)

Wet Bulb: 74°F (99%)

Performance Temperature: 80°F

Performance Relative Humidity: 60%

9. All data, i.e., capacities, flows, sizes, etc., indicated in the Process Design Basis is to be considered the minimum requirement.

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DP - 1

Equipment Name Charge Hopper / Transfer Hopper

Equipment No. 1DP-HPR-1, 1DP-HPR-2, & 1DP-TK-1

System Name Pyrolizer Feed System

Flowsheet No. 16N25706-82-F-1DP-001

sj/form

330

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DP - 1

Equipment Name Surge Bin
Equipment No. 1DP-TK-1
System Name Pyrolizer Feed System
Flowsheet No. 16N25706-82-F-1DP-001

Effective Vessel Volume:

16 Ft³ @ 50#/Ft³

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DP - 1

Equipment Name Charge Hopper
Equipment No. 1DP-HPR-1
System Name Pyrolizer Feed System
Flowsheet No. 16N25706-82-F-1DP-001

SYSTEM PROCESS DESIGN BASIS

PDB No. 82 - 1DP - 1

Equipment Name Transfer Hopper
Equipment No. 1DP-HPR-2
System Name Pyrolizer Feed System
Flowsheet No. 16N25706-82-F-1DP-001

PROCESS DESIGN BASIS
PDB No. 82-1DP-1

Equipment Name	<u>Charge Hopper, Transfer Hopper, Surge Bin</u>
Equipment No.	<u>1DP-HPR-1, 1DP-HPR-2, 1DP-TK-1</u>
System Name	<u>Pyrolizer Feed System</u>
Flowsheet No.	<u>16N25706-82-F-1DP-001</u>

I. DESIGN PHILOSOPHY

1. The Pyrolizer Feed System will transport coal to the PyGas™ Coal Gasifier fuel inlet with 325 psig back pressure under normal operation. During desulfurization testing, the Pyrolizer Feed System will transport a mixture of coal and limestone to the gasifier.
2. The Pyrolizer Feed System will provide a continuous feed of coal to the PyGas™ Coal Gasifier from the Transfer Hopper. Transfer of material from the Surge Bin to the Charge Hopper and Charge Hopper to Transfer Hopper will be on a batch basis. A batch is discharged to the Transfer Hopper from the Charge Hopper when the Transfer Hopper reaches a half full state.
3. The Rotary Feeder below the Transfer Hopper and Charge Hopper discharge cycles per hour will provide feed rate control to the PyGas™ Coal Gasifier.
4. The PyGas™ Coal Gasifier and Pyrolizer Feed System will operate continuously, 24 hours per day, for two week periods and be out of service for six weeks between each period.
5. The Pyrolizer Feed System will be installed outdoors. See Design Notes for ambient weather design criteria.
6. The vent gas from the Charge Hopper will be piped to the Coal Storage Bin. The vent line will be sized for increasing gas volume as pressure decreases.
7. The start-up pressure of the PyGas™ Coal Gasifier will be approximately 30 psig. The gasifier pressure and fuel flow rate will increase as the gasifier reaches operating temperature.
8. Coke breeze will be handled by the Pyrolizer Feed System for use as a start-up fuel in the PyGas™ Coal Gasifier at a reduced capacity. During start-up, as the pressure and temperature increases in the PyGas™ Coal Gasifier, the coke breeze feed will be reduced while introducing the coal or coal/limestone mixture into the Pyrolizer Feed System until operating parameters are achieved.

PROCESS DESIGN BASIS
PDB No. 82-1DP-1

Equipment Name Charge Hopper, Transfer Hopper, Surge Bin
Equipment No. 1DP-HPR-1, 1DP-HPR-2, 1DP-TK-1
System Name Pyrolizer Feed System
Flowsheet No. 16N25706-82-F-1DP-001

II. DESIGN CRITERIA

NORMAL 325# GASIFIER OPERATION								
ITEM	PROCESS STREAM	DESIGN FLOW #/HR	MAX. FLOW #/HR	MIN. FLOW #/HR	MAX. TEMP °F	MIN. TEMP. °F	MAX. PRESS PSIG	MIN. PRESS PSIG
1	Product Coal In	5,102	(See Mass Bal.)		175	(See Mass Bal.)		
2	Product Coal Out	4,445	(See Mass Bal.)		175	(See Mass Bal.)		
3	Conveying Gas In	390	(See Mass Bal.)		100	(See Mass Bal.)		
4	Dust Vent (Solids)	45	(See Mass Bal.)		125	(See Mass Bal.)		
5	Dust Vent (Solids)	51	(See Mass Bal.)		125	(See Mass Bal.)		

6. The coal instantaneous discharge rate from Surge Bin to Charge Hopper is 130,909 lbs/hr based on discharging 8 ft³ of 50 lb/ft³ material (400 lbs.) in 11 seconds.
7. During desulfurization testing, the coal/limestone mixture instantaneous discharge rate from Surge Bin to Charge Hopper is 141,382 lbs/hr based on discharging 8 ft³ of 54 lb/ft³ material (432 lbs.) in 11 seconds.
8. The coal instantaneous discharge rate from Charge Hopper to Transfer Hopper is 31,304 lbs/hr based on discharging 8 ft³ of 50 lb/ft³ material (400 lbs) in 46 seconds.
9. During desulfurization testing, the coal/limestone mixture instantaneous discharge rate from Charge Hopper to Transfer Hopper is 33,809 lbs/hr based on discharging 8 ft³ of 54 lb/ft³ material (432 lbs.) in 46 seconds.
10. Compressed conveying gas to the Pyrolizer Feed System will be at minus 40 degrees F dew point to prevent condensation from forming in the conveying pipe during winter operation.

PROCESS DESIGN BASIS
PDB No. 82-1DP-1

Equipment Name	<u>Charge Hopper, Transfer Hopper, Surge Bin</u>
Equipment No.	<u>1DP-HPR-1, 1DP-HPR-2, 1DP-TK-1</u>
System Name	<u>Pyrolizer Feed System</u>
Flowsheet No.	<u>16N25706-82-F-1DP-001</u>

III. DESIGN NOTES

1. Product coal flow rates are from the Mass and Energy Balances. Design condition is approximately 10 percent above the maximum coal flow, Mass and Energy Balance results, to allow for operation variations.
2. Coal Moisture < 1.0%
3. Coal Specific Heat 0.30 Btu/lb-F
4. Crushed Coal Size -1/4 x 50 mesh
5. Coal Bulk Density 50 #/Ft³
6. Coal Grindability Index 40-90
7. Limestone Size -1/8 x 200 mesh
8. Limestone Bulk Density 68 #/Ft³
9. Angle of Repose 30 deg.
10. Fuel Mixture to Gasifier 81% coal, 19% limestone
11. Coal/Limestone Bulk Density 54 #/cubic feet (average)
12. Crushed Coal Feed:

<u>Size Analysis</u>	<u>Sample</u>
(Anticipated)	(Estimated)
-3/8 + 1/4	3%
-1/4 + 1/8	14%
-1/8 + 10 (mesh)	15%
-10 + 20	30%
-20 + 40	20%
-40 + 100	9%
-100 + 200	5%
13. Ambient Weather Criteria

Design Temperature:	
Dry Bulb:	
Winter	
Winter	-20°F (lowest on record for freeze protection)
Summer	4°F (99%)
Wet Bulb:	90°F (99%)
Performance Temperature:	74°F (99%)
Performance Relative Humidity:	80°F
	60%
14. Surge Bin Capacity 16 cubic feet (effective volume required)
15. Charge Hopper Capacity 8 cubic feet (effective volume required)
16. Transfer Hopper Capacity 16 cubic feet (effective volume required)

PROCESS DESIGN BASIS

Equipment Name	<u>Charge Hopper, Transfer Hopper, Surge Bin</u>
Equipment No.	<u>1DP-HPR-1, 1DP-HPR-2, 1DP-TK-1</u>
System Name	<u>Pyrolizer Feed System</u>
Flowsheet No.	<u>16N25706-82-F-1DP-001</u>

III. DESIGN NOTES - Continued

17. Gasifier Operating Pressure	325 psig
18. System Operating Pressure
(Anticipated)	390 psig
19. Design Operating Temperature	175 deg. F.
20. Charge Hopper Cycles	9.26 per hr.
Charge Hopper Fill Time	5 seconds
Transfer Hopper Fill Time	46 seconds
Pressure Balance Time	60 sec.
Charge Hopper Vent Time	60 sec.
Total Cycle Time	177 sec.
21. Coke Breeze
Bulk Density
Size	25-35#/Ft ³
1/4 inch minus
22. All data, i.e., capacities, flows, sizes etc., indicated in the Process Design Basis is to be considered the minimum requirement.	
23. The Surge Bin, Charge Hopper and Transfer Hopper will be complete with a fire protection system.	

**Gasification Product Improvement Facility
Fort Martin Station, West Virginia
Sirriner Job No. 16N25706**

Drawing List

<u>Drawing Number</u>	<u>Drawing Description</u>
16N25706-40-LE-001	Flow Diagram Legend
16N25706-40-1AA-001	Flow Diagram Gasifier System
16N25706-40-1AA-002	Flow Diagram Gasifier Gas Clean-Up System
16N25706-40-1AA-003	Flow Diagram Gasifier Cooling Water
16N25706-40-1AA-004	Flow Diagram Gasifier Ash Handling
16N25706-40-1AA-005	Flow Diagram Solid Waste Disposal System
16N25706-40-1DG-001	Flow Diagram Natural Gas Distribution
16N25706-40-1GA-001	Flow Diagram Flue Gas Desulfurization System
16N25706-40-1GG-001	Flow Diagram Process Vent Distribution
16N25706-40-1GH-001	Flow Diagram Incinerator
16N25706-40-1KD-001	Flow Diagram Chemical Feed System
16N25706-40-1KK-001	Flow Diagram Potable Water System
16N25706-40-1KV-001	Flow Diagram Auxiliary Water Distribution
16N25706-40-1KW-001	Flow Diagram Service Water System
16N25706-40-1LD-001	Flow Diagram Plant and Instrument Air System
16N25706-40-1LF-001	Flow Diagram Process Air System
16N25706-40-1LK-001	Flow Diagram Nitrogen Storage and Distribution
16N25706-40-1SB-001	Flow Diagram Natural Gas Package Boiler
16N25706-40-1SB-002	Flow Diagram Steam Distribution
16N25706-40-1SJ-001	Flow Diagram Feedwater System
16N25706-40-1WS-001	Flow Diagram Solid Waste Treatment System
16N25706-40-1WS-002	Flow Diagram Process Waste Water Distribution
16N25706-82-1DJ-001	Flow Diagram Coal Preparation and Limestone System
16N25706-82-1DH-001	Flow Diagram Coal Receiving, Storage, and Reclaim
16N25706-82-1DP-001	Flow Diagram Pyrolyzer Feed System

NOTES

1. STREAM NUMBERS DENOTED BY RECIPES TO TASKS.
2. STREAM NUMBERS TO APPENDIX "A" OF THE CONCEPTUAL DESIGN REPORT.
3. COM. NO. 1000000 IS A PREVIEW AND DATED 10-10-93.
4. NORMAL OPERATING IN THE OPERATING DESIGN CONSIDERATION TABLES SETTING TO 100 PSIG GASIFIER OPERATION.
5. THE CAPACITIES SHOWN ARE BASED ON HANDLING A COM. LIMESTONE WASTE AT 50 PCF AND IS PROVIDED BY THE PER. LEGAL AND HANDLING CODE WASTE AT 25 PCF.
6. COM. AND DUST WASTE ARE FED SEPARATELY THROUGH A COMMON DUST CHUTE TO THE WASTE BIN. BOTH FEEDS ARE SEPARATED EXCEPT DURING START-UP CHARGE OVER FROM COM. WASTE TO COM.
7. LIMESTONE WILL BE FED TO THE GASIFIER THROUGH THE COM. SYSTEM FOR DEMONSTRATION TESTS.

REVISIONS

NO.	REV.	DESCRIPTION
4	1	ON REVISED CONTROL SCHEME.
4	2	ADD SERVICE WATER NOSE STATION. ISSUED AS REV. 1.
3	1	REVISED PER DOE COMMENTS. ISSUED FOR DESIGN.
2	1	REVISED PER S/W/S/S SCOPE REVISED. ISSUED FOR COMMENTS.
1	1	REVISED STREAM SYMBOLS. ISSUED FOR DESIGN.
1	2	ISSUED FOR APPROVAL. COMMENTS.
1	3	PHILIPINITY FOR INFORMATION.
1	4	ISSUED FOR TASK 4 REPORT.
1	5	ISSUED FOR REVIEW.
1	6	ISSUED FOR COMMENTS.

DESIGNATION

NOTE: CHARGE ALL REVISIONS, REVISIONS, AND APPROVALS TO THE DESIGN. APPROVALS ONLY CHARGE AND APPROVALS ONLY REVISIONS.

ISSUE CODE: C (C) M (M) F (F) D (D) H (H)

PHILIPINITY: D (D) M (M) F (F) D (D) H (H)

DESIGN: C (C) M (M) F (F) D (D) H (H)

SEAL

SIGNATURE _____

DATE _____

EX. LINE: 1000000 DATE: 06-19-93

BY: J. J. RUTZKY JACOBS

EN: J. J. RUTZKY JACOBS

DATE: 06-19-93

FILE NO. 10-10-93 (1000000) (1000000)

JACOBS-SIMONE ENGINEERING
a division of Jacobs Engineering Group Inc.

GPPI PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC28202

DRAWING TITLE
FLOW DIAGRAM
PYROLYZER
FEED SYSTEM

CLIENT DRAWING NUMBER

JACOBS-SIMONE DRAWING NUMBER
1000000-02-F-100-001

35		36		37							
VE SEAL AIR		CONVEYING AIR		(DELETED)							
PSIG	DEG.F	PPH	PSIG	DEG.F							
440	100	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500
350	100	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500

363

[illegible][illegible]

SEAL

SIGNATURE

DATE

MR. J. PIERCE	DATE 05-20-63
DR. B. V. DICK	ACCNO
DR.	FILE NUMBER J040
DR. R. V. DICK	JOB NO. 23704
CARD FILE NO. 10, AL DTC 108 1247050 175000. 407	

JE JACOBS-LEVINE ENGINEERS,
a division of Jacobs Engineering Group

GPIF PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC28202

DRAWING TITLE

FLOW DIAGRAM
PROCESS
WASTE WATER
DISTRIBUTION

CLIENT DRAWING NUMBER

JACOBS-SIMONE DRAWING NUMBER
1E29706-40-E-1RS-002

Copyright Jacobs-Sixtine Engineers as of Last Date Indicated

TER												
10.F												
CE1												
CE1

[illegible]

359

358

LINE NUMBER	1	2	3	4	5
DESCRIPTION:	NO HEATER CONDENSATE	SERVICE WATER	TREATED SERVICE WATER	NITROGEN	DA OVERFLOW
UNITS	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG
MAXIMUM DESIGN	HOLD 420 650	HOLD 100 90	HOLD 100 90	HOLD 150 100	15 10
MAXIMUM OPERATING					
NORMAL OPERATING	HOLD 420 550	HOLD HOLD 80	(SEE MASS BALANCE)	HOLD 30 50	0 5
MINIMUM OPERATING	HOLD 300 500	HOLD HOLD 70	(SEE MASS BALANCE)	HOLD 20 50	0 5
REVISION DATE					

LINE NUMBER	11	12	13	14	15
DESCRIPTION:	CASIFIER COOLING WATER MAKEUP	OPW SUCTION	FEEDWATER TO BOILER	GAS OUTLET SPRAY WATER	
UNITS	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG Deg.F	
MAXIMUM DESIGN	10 HOLD 250	HOLD 10 250	HOLD HOLD 250	HOLD HOLD 250	
MAXIMUM OPERATING					
NORMAL OPERATING	(SEE MASS BALANCE)	(SEE MASS BALANCE)	(SEE MASS BALANCE)	0 HOLD 227	
MINIMUM OPERATING	(SEE MASS BALANCE)	(SEE MASS BALANCE)	(SEE MASS BALANCE)	0 HOLD 227	
REVISION DATE

NOTE 1

1. STREAM BALANCE SHEET
REFERS TO DATA ON STREAM
NUMBERS IN THIS BALANCE

NOTE 2

2. INITIAL OPERATIONS TO THE OPERATING
DESIGN CONDITIONS (AND) REFERS TO
325 PSIG GASIFIER AND 150 PSIG
STEAM TO THE GASIFIER
PRESSURE GASIFIER OPERATION

4	01	REVISED OFFPAGE
4	02	CONNECTOR
4	03	ISSUED AS REV. 1
3	01	REVISED PER DEPARTMENT
3	02	OF ENERGY COMMENTS
3	03	ISSUED FOR DESIGN
2	01	REVISED PER 5/15/95 SCOP
2	02	REVIEW, ISSUED FOR
2	03	COMMENTS
1	01	REVISED TITLE, STREAM
1	02	SYMBOLS, DATA, DELETED
1	03	STEAM TO THE GASIFIER
1	04	AND HEATER
1	05	ISSUED FOR DESIGN
0	01	REVISED DATA & NOTES FOR
0	02	ADD PSIG OPERATION
0	03	CHANGED ONE NO FROM
0	04	1000/100-40-F-150-001
0	05	ISSUED FOR APPROVAL
G	01	ISSUED FOR REVIEW
G	02	ONLY
F	01	ISSUED FOR INFORMATION
F	02	ONLY
E	01	ISSUED FOR REVIEW
E	02	ONLY
D	01	ISSUED FOR INTERNAL
D	02	REVIEW
C	01	ISSUED FOR TASK & REPORT
C	02	ONLY
B	01	ISSUED FOR REVIEW
B	02	ONLY
A	01	ISSUED FOR ESTIMATE
A	02	ONLY

REVISION

NOTE:
CIRCLE ALL REVISIONS, INDICATE
DATE, NUMBER, NAME AND
REASON, INITIAL ONLY CIRCLE AND
DATE AND NAME REVISIONS.

SYMBOL CODE (C) INITIAL, (D) CONSTANT
(A) PROPORTION (B) INITIAL, (C) PUNC. (D)
(E) DESIGN (F) BIDS (G) H

SEAL

SIGNATURE

DATE

DR. J. PIERCE DATE 04-21-93
PROJ. M. V. BLOD FILE J040
DR. J. PIERCE J040
DATE 04-21-93 J040
CIVIL FILE 04-21-93 J040

JE JACOBS-ENGINEERING
A Division of Jacobs Engineering Group Inc.

GPJF PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC28202

DRAWING TITLE

FLOW DIAGRAM
STEAM
DISTRIBUTION

CLIENT DRAWING NUMBER

JACOBS-ENGINEERING DRAWING NUMBER
16023706-40-F-150-002

6				7				8				9				10			
STEAM TO H.P. H2 HIR				STEAM TO GASIFIER				STEAM TO GRATE 85H L.M.				STEAM TO GASIFIER				STEAM TO GASIFIER			
16	Deg°F	PPH	PSIG	Deg°F	PPH	PSIG	Deg°F	PPH	PSIG	Deg°F	PPH	PSIG	Deg°F	PPH	PSIG	Deg°F	PPH	PSIG	Deg°F
		2000	460	600				HOLD	460	600	HOLD	460	600	HOLD	460	600			
BA LANCE1	HOLD	420	550	1500	360	500	1500	360	500	1500	360	500	1500	360	500	1500	360	500	1500
BA LANCE1	HOLD	360	500	1500	360	500	1500	360	500	1500	360	500	1500	360	500	1500	360	500	1500

357

[illegible]

356

JACOBS-SIRNINE DRAWING NUMBER
16425706-40-E-11K-001

355

11/15/81
11/15/81 11:30 AM 11/15/81 11:30 AM

11/15/81 11:30 AM 11/15/81 11:30 AM

LINE NUMBER	1	2	3	4	5
DESCRIPTION	LP N2 USERS			HP N2 USERS	
UNITS	PPH	PSIG	Deg. F	SCFM	PSIG
MAXIMUM DESIGN	HOLD	150	100	HOLD	150
MAXIMUM OPERATING	HOLD	150	100	HOLD	150
NORMAL OPERATING	HOLD	120	50	HOLD	120
MINIMUM OPERATING	HOLD	100	50	HOLD	100
REVISION DATE					

LINE NUMBER	11	12	13	14	15
DESCRIPTION	N2 TO CYCLONE LN			N2 TO TRANSMITTER PURGE	
UNITS	SCFM	PSIG	Deg. F	SCFM	PSIG
MAXIMUM DESIGN	HOLD	350	400	HOLD	350
MAXIMUM OPERATING	HOLD	350	400	HOLD	350
NORMAL OPERATING	HOLD	350	400	HOLD	350
MINIMUM OPERATING	HOLD	350	400	HOLD	350
REVISION DATE

[illegible]

353

12-16-1968 11:12 AM
 12-16-1968 10:10:37 PIDECE 100716 040

LINE NUMBER	1	2	3	4
DESCRIPTION:	PLANT AIR	PROCESS AIR	H2 BACKUP	INSTRUMENT AIR
UNITS	SCFM PSIG Deg.F	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PSIG Deg.F
MAXIMUM DESIGN	100 125 100	160 125 100	1493 150 100	2000 125 100
MAXIMUM OPERATING	0 100 85	105 105 70	0 120 50	932 93 70
MINIMUM OPERATING	HOLD 100 1058	HOLD HOLD HOLD	0 100 50	HOLD 93 60
REVISION DATE				
LINE NUMBER				
DESCRIPTION:				
UNITS				
MAXIMUM DESIGN				
MAXIMUM OPERATING				
NORMAL OPERATING				
MINIMUM OPERATING

JACOBS-SIMONE DRAWING NUMBER
1025706-40-F-1X8-001

352

NOTES

1. SYSTEM PLANNING REVISIONS
2. POTABLE WATER BOOSTER PUMPS

REVISIONS

REV.	NO.	DATE	DESCRIPTION
1	1	06-21-83	REVISED PROCESS DESIGN
2	2	06-21-83	REVISED FOR BOUWMEESTER
3	3	06-21-83	REVISED FOR DESIGN
4	4	06-21-83	REVISED POTABLE WATER FROM
5	5	06-21-83	REVISED POTABLE WATER FROM
6	6	06-21-83	REVISED POTABLE WATER FROM
7	7	06-21-83	REVISED POTABLE WATER FROM
8	8	06-21-83	REVISED POTABLE WATER FROM
9	9	06-21-83	REVISED POTABLE WATER FROM
10	10	06-21-83	REVISED POTABLE WATER FROM
11	11	06-21-83	REVISED POTABLE WATER FROM
12	12	06-21-83	REVISED POTABLE WATER FROM
13	13	06-21-83	REVISED POTABLE WATER FROM
14	14	06-21-83	REVISED POTABLE WATER FROM
15	15	06-21-83	REVISED POTABLE WATER FROM
16	16	06-21-83	REVISED POTABLE WATER FROM
17	17	06-21-83	REVISED POTABLE WATER FROM
18	18	06-21-83	REVISED POTABLE WATER FROM
19	19	06-21-83	REVISED POTABLE WATER FROM
20	20	06-21-83	REVISED POTABLE WATER FROM
21	21	06-21-83	REVISED POTABLE WATER FROM
22	22	06-21-83	REVISED POTABLE WATER FROM
23	23	06-21-83	REVISED POTABLE WATER FROM
24	24	06-21-83	REVISED POTABLE WATER FROM
25	25	06-21-83	REVISED POTABLE WATER FROM
26	26	06-21-83	REVISED POTABLE WATER FROM
27	27	06-21-83	REVISED POTABLE WATER FROM
28	28	06-21-83	REVISED POTABLE WATER FROM
29	29	06-21-83	REVISED POTABLE WATER FROM
30	30	06-21-83	REVISED POTABLE WATER FROM
31	31	06-21-83	REVISED POTABLE WATER FROM
32	32	06-21-83	REVISED POTABLE WATER FROM
33	33	06-21-83	REVISED POTABLE WATER FROM
34	34	06-21-83	REVISED POTABLE WATER FROM
35	35	06-21-83	REVISED POTABLE WATER FROM
36	36	06-21-83	REVISED POTABLE WATER FROM
37	37	06-21-83	REVISED POTABLE WATER FROM
38	38	06-21-83	REVISED POTABLE WATER FROM
39	39	06-21-83	REVISED POTABLE WATER FROM
40	40	06-21-83	REVISED POTABLE WATER FROM
41	41	06-21-83	REVISED POTABLE WATER FROM
42	42	06-21-83	REVISED POTABLE WATER FROM
43	43	06-21-83	REVISED POTABLE WATER FROM
44	44	06-21-83	REVISED POTABLE WATER FROM
45	45	06-21-83	REVISED POTABLE WATER FROM
46	46	06-21-83	REVISED POTABLE WATER FROM
47	47	06-21-83	REVISED POTABLE WATER FROM
48	48	06-21-83	REVISED POTABLE WATER FROM
49	49	06-21-83	REVISED POTABLE WATER FROM
50	50	06-21-83	REVISED POTABLE WATER FROM
51	51	06-21-83	REVISED POTABLE WATER FROM
52	52	06-21-83	REVISED POTABLE WATER FROM
53	53	06-21-83	REVISED POTABLE WATER FROM
54	54	06-21-83	REVISED POTABLE WATER FROM
55	55	06-21-83	REVISED POTABLE WATER FROM
56	56	06-21-83	REVISED POTABLE WATER FROM
57	57	06-21-83	REVISED POTABLE WATER FROM
58	58	06-21-83	REVISED POTABLE WATER FROM
59	59	06-21-83	REVISED POTABLE WATER FROM
60	60	06-21-83	REVISED POTABLE WATER FROM
61	61	06-21-83	REVISED POTABLE WATER FROM
62	62	06-21-83	REVISED POTABLE WATER FROM
63	63	06-21-83	REVISED POTABLE WATER FROM
64	64	06-21-83	REVISED POTABLE WATER FROM
65	65	06-21-83	REVISED POTABLE WATER FROM
66	66	06-21-83	REVISED POTABLE WATER FROM
67	67	06-21-83	REVISED POTABLE WATER FROM
68	68	06-21-83	REVISED POTABLE WATER FROM
69	69	06-21-83	REVISED POTABLE WATER FROM
70	70	06-21-83	REVISED POTABLE WATER FROM
71	71	06-21-83	REVISED POTABLE WATER FROM
72	72	06-21-83	REVISED POTABLE WATER FROM
73	73	06-21-83	REVISED POTABLE WATER FROM
74	74	06-21-83	REVISED POTABLE WATER FROM
75	75	06-21-83	REVISED POTABLE WATER FROM
76	76	06-21-83	REVISED POTABLE WATER FROM
77	77	06-21-83	REVISED POTABLE WATER FROM
78	78	06-21-83	REVISED POTABLE WATER FROM
79	79	06-21-83	REVISED POTABLE WATER FROM
80	80	06-21-83	REVISED POTABLE WATER FROM
81	81	06-21-83	REVISED POTABLE WATER FROM
82	82	06-21-83	REVISED POTABLE WATER FROM
83	83	06-21-83	REVISED POTABLE WATER FROM
84	84	06-21-83	REVISED POTABLE WATER FROM
85	85	06-21-83	REVISED POTABLE WATER FROM
86	86	06-21-83	REVISED POTABLE WATER FROM
87	87	06-21-83	REVISED POTABLE WATER FROM
88	88	06-21-83	REVISED POTABLE WATER FROM
89	89	06-21-83	REVISED POTABLE WATER FROM
90	90	06-21-83	REVISED POTABLE WATER FROM
91	91	06-21-83	REVISED POTABLE WATER FROM
92	92	06-21-83	REVISED POTABLE WATER FROM
93	93	06-21-83	REVISED POTABLE WATER FROM
94	94	06-21-83	REVISED POTABLE WATER FROM
95	95	06-21-83	REVISED POTABLE WATER FROM
96	96	06-21-83	REVISED POTABLE WATER FROM
97	97	06-21-83	REVISED POTABLE WATER FROM
98	98	06-21-83	REVISED POTABLE WATER FROM
99	99	06-21-83	REVISED POTABLE WATER FROM
100	100	06-21-83	REVISED POTABLE WATER FROM

SEAL

SIGNATURE

DATE

JE JACOBS-ENGINEERING INCORPORATED
a Division of Jacobs Engineering Group Inc.

GPIF PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC26202-1

DRAWING TITLE
FLOW DIAGRAM
POTABLE WATER
SYSTEM

CLIENT DRAWING NUMBER

JACOBS-ENGINEERING DRAWING NUMBER
1002706-40-F-100-001

NOTES

1. THIS DRAWING SHOWS THE LAYOUT OF THE FEED SYSTEM TO THE DISTRIBUTION SYSTEM.
2. NORMAL OPERATION TO THE DISTRIBUTION SYSTEM IS THROUGH THE FEED SYSTEM. FEED SYSTEM IS TO BE USED FOR FEEDING TO THE DISTRIBUTION SYSTEM.

3	REVISED LATEST DESIGN
2	REVISED AS REV. 1
1	REVISED FOR DEPARTMENT
0	REVISED FOR DEPARTMENT
F	REVISED FOR DEPARTMENT
E	REVISED FOR DEPARTMENT
D	REVISED FOR DEPARTMENT
C	REVISED FOR DEPARTMENT
B	REVISED FOR DEPARTMENT
A	REVISED FOR DEPARTMENT

NOTE: THIS DRAWING IS TO BE USED FOR FEEDING TO THE DISTRIBUTION SYSTEM.

SEAL

SIGNATURE _____

DATE _____

BY: J. J. JENSEN DATE: 10-10-53

BY: B. V. JENSEN DATE: 10-10-53

BY: B. V. JENSEN DATE: 10-10-53

BY: B. V. JENSEN DATE: 10-10-53

JE

JACOBSON ENGINEERS
A Division of Jacobs Engineering Group Inc.

GPIF PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC28202

DRAWING TITLE
FLOW DIAGRAM
CHEMICAL
FEED SYSTEM

CLIENT DRAWING NUMBER

JACOBSON ENGINEERS DRAWING NUMBER
10423706-40-F-100-001

Copyright Jacobson-Engineers as of Last Date Indicated

[illegible]

SEAL

SIGNATURE

DATE

DR. G. W. LEDBETTER	DATE
PHYS.	JAN 28 1968
CL.	F.R.E.
	ALABAMA
SPC. H. S. STONE	JOB NO. 1049700
CAP F.R.E. NO. 18, INC 100-124705430-001. 00F-1

JACOBSON-SELIGSON ENGINEERING
a division of Jacobs Engineering Group Inc.

GPIF PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC28202

DRAWING TITLE

FLOW DIAGRAM
INCINERATOR

CLIENT DRAWING NUMBER

JACOBS-SIGNING DRAWING HEADER
1625706-40-F-101-001

[illegible]

348

11:12:13
11:12:13
11:12:13

11:12:13
11:12:13
11:12:13

LINE NUMBER	1	2	3	4	5
DESCRIPTION:	COAL GAS			NITROGEN	
UNITS	PPH	PSIG	Deg.F	PPH	PSIG
MAXIMUM DESIGN	HOLD	420	1150	HOLD	60
MAXIMUM OPERATING				150	100
NORMAL OPERATING	{1SEC MASS BALANCE}			30	50
MINIMUM OPERATING	{1SEC MASS BALANCE}			20	0
REVISION DATE					

LINE NUMBER	11	12	13
DESCRIPTION:	VENT ASH		
UNITS	PPH	PSIG	Deg.F
MAXIMUM DESIGN			
MAXIMUM OPERATING			
NORMAL OPERATING	HOLD		
MINIMUM OPERATING			
REVISION DATE

5			6			7			8			9			10		
SCRUBBER WATER OUTLET			SCRUBBER RECIRCULATION			SCRUBBER FLUE GAS OUTLET			COMBUSTION AIR			FLUE GAS RO-CATER OUTLET			OXIDATION BLOWER FLOW		
GPM	PSIG	Deg.F	GPM	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F
3012	5	200	(SEE MASS BALANCE)			(SEE MASS BALANCE)			(SEE MASS BALANCE)			(SEE MASS BALANCE)			(SEE MASS BALANCE)		
			(SEE MASS BALANCE)			(SEE MASS BALANCE)			(SEE MASS BALANCE)			(SEE MASS BALANCE)			(SEE MASS BALANCE)		

13																	
CONDENSATE																	
GPM	PSIG	Deg.F															

12-50-1-1000 11/21/14 11/21/14 11/21/14

LINE NUMBER	1	2	3	4
DESCRIPTION:	NATURAL GAS	CAUSTIC	HRSG FLUE GAS	SERVICE WATER MAKEUP
UNITS	SCFM PSIG Deg.F	GPM PSIG Deg.F	PPH PSIG Deg.F	GPM PSIG Deg.F
MAXIMUM DESIGN				
MAXIMUM OPERATING				
NORMAL OPERATING	(SEE MASS BALANCE)	1.5 2 60	(SEE MASS BALANCE)	31 80 60
MINIMUM OPERATING	(SEE MASS BALANCE)		(SEE MASS BALANCE)	
REVISION DATE				

LINE NUMBER	11	12	13	14
DESCRIPTION:		WASTE WATER	WASTE WATER	SERVICE WATER
UNITS	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG Deg.F	GPM PSIG Deg.F
MAXIMUM DESIGN				
MAXIMUM OPERATING				
NORMAL OPERATING		(SEE MASS BALANCE)	(SEE MASS BALANCE)	(SEE MASS BALANCE)
MINIMUM OPERATING		(SEE MASS BALANCE)	(SEE MASS BALANCE)	(SEE MASS BALANCE)
REVISION DATE

5		6			7								
NAT. GAS ANALYZER		W.G. TO FLUX GAS PUMP/FAIR			NATURAL GAS TO PACKER DOLLER								
PSIG	DEG°F	PPH	PSIG	DEG°F	PPH	PSIG	DEG°F						
60	100		60			60	100						
SS BALANCE	()	()	WASS BALANCE	()	()	()	WASS BALANCE	()					
SS BALANCE	()	()	WASS BALANCE	()	()	()	WASS BALANCE	()					

345

Copyright Jacobs-Sirrine Engineering as of Last Date Indicated

[illegible]

344

JACOBS-SIARINE DRAWING NUMBER
16K23706-40-F-1AA-004

Copyright Joseph-Girling Engineers as of Last Date Indicated

343

		6			7			8			9			10		
		STEAM / C.W. FROM POLYMERIZER			STEAM / C.W. FROM UPPER JACKET			STEAM/EN FROM LOWER JACKET			SHOULD COOLING WATER			UPPER JACKET COOLING WATER		
SIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	CPM	PSIG	Deg.F	CPM	PSIG	Deg.F
LEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY
LEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY
LEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY
LEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY	RILEY

		16			17			18						
		COOLING WATER FROM DOWN			STEAM TO GASIFIER			PLOWDOWN						
SIG	Deg.F	CPM	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F				
LD	HOLD	RILEY	RILEY	RILEY	HOLD	RILEY	RILEY	RILEY	RILEY	RILEY				
LD	HOLD	RILEY	RILEY	RILEY	1000	RILEY	RILEY	RILEY	RILEY	RILEY				
LD	HOLD	RILEY	RILEY	RILEY	500	RILEY	RILEY	RILEY	RILEY	RILEY				

342

LINE NUMBER	1	2	3	4	5
DESCRIPTION:	WARM UP STEAM			STEAM FROM DRUM	
UNITS	PPH	PSIG	Deg.F	PPH	PSIG
MAXIMUM DESIGN	HOLD	460	810	HOLD	227
NORMAL OPERATING					
MINIMUM OPERATING	0	420	600	HOLD	227
REVISION DATE					

LINE NUMBER	11	12	13	14	15
DESCRIPTION:	COOLING WATER FROM GAS COND.			COOLING WATER TO GAS COND.	
UNITS	PPH	PSIG	Deg.F	PPH	PSIG
MAXIMUM DESIGN	RILEY	RILEY	RILEY	RILEY	RILEY
NORMAL OPERATING	RILEY	RILEY	RILEY	RILEY	RILEY
MINIMUM OPERATING	RILEY	RILEY	RILEY	RILEY	RILEY
REVISION DATE

LINE NUMBER	1	2	3	4	5
DESCRIPTION:	COAL GAS	N2	N2	N2	FINE
UNITS	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PS
MAXIMUM DESIGN	20,320 420 1100	HOLD 374 465	HOLD 374 465	HOLD 10 100	500 420
MAXIMUM OPERATING	(SEE MASS BALANCE)	(SEE PDB)	(SEE PDB)	HOLD 2 50	(SEE MASS)
NORMAL OPERATING	(SEE MASS BALANCE)	(SEE PDB)	(SEE PDB)	HOLD 2 50	(SEE MASS)
MINIMUM OPERATING	(SEE MASS BALANCE)	(SEE PDB)	(SEE PDB)	HOLD 2 50	(SEE MASS)
REVISION DATE					

LINE NUMBER	11	12	13	14	15
DESCRIPTION:	N2	COAL GAS	N2	N2	LH VC
UNITS	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PSIG Deg.F	PPH PS
MAXIMUM DESIGN	HOLD 10 100	19,970 420 1100	HOLD 10 100	10 100	HOLD 420
MAXIMUM OPERATING	HOLD 2 50	(SEE MASS BALANCE)	(SEE PDB)	(SEE PDB)	HOLD 420
NORMAL OPERATING	HOLD 2 50	(SEE MASS BALANCE)	(SEE PDB)	(SEE PDB)	HOLD 420
MINIMUM OPERATING	HOLD 2 50	(SEE MASS BALANCE)	(SEE PDB)	(SEE PDB)	HOLD 420
REVISION DATE

6				7				8				9				10			
GRATE				STEAM TO PYROLYZER			H2 TO PYROLYZER			SLEEPING STEAM TO COKE			STEAM TO PYROLYZER COKE						
ID	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F			
14	410				700		374	600			700		374	600	700		374	600	
\$ BALANCE)				ISSEE MASS BALANCE)				HOLD				ISSEE MASS BALANCE)				ISSEE MASS BALANCE)			
\$ BALANCE)				ISSEE MASS BALANCE)								ISSEE MASS BALANCE)				ISSEE MASS BALANCE)			

16				17				18				19				20			
AIR				NATURAL GAS						COAL GAS									
ID	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F	PPH	PSIG	Deg.F			
14	150				HOLD	60	AMB				20320		420	1100	HOLD		320	90	
\$ BALANCE)				HOLD				RILEY				ISSEE MASS BALANCE)				HOLD			
\$ BALANCE)				HOLD				RILEY				ISSEE MASS BALANCE)				HOLD			

11-111111
11-111111
11-111111

LINE NUMBER	1	2	3	4	
DESCRIPTION:	AIR TO GASIFIER TOP			STEAM TO GRATE	
UNITS	PPH	PSIG	Deg.F	PPH	PSIG
MAXIMUM DESIGN	FUTURE	374	410	FUTURE	374
MAXIMUM OPERATING	FUTURE	FUTURE	FUTURE	FUTURE	FUTURE
NORMAL OPERATING	FUTURE	FUTURE	FUTURE	FUTURE	FUTURE
MINIMUM OPERATING	FUTURE	FUTURE	FUTURE	FUTURE	FUTURE
REVISION DATE					

LINE NUMBER	11	12	13	14	15
DESCRIPTION:	STEAM TO PYROLYZER			GRATE ASH	
UNITS	PPH	PSIG	Deg.F	PPH	PSIG
MAXIMUM DESIGN	200	374	600	1000	420
MAXIMUM OPERATING	FUTURE	FUTURE	FUTURE	FUTURE	FUTURE
NORMAL OPERATING	FUTURE	FUTURE	FUTURE	FUTURE	FUTURE
MINIMUM OPERATING	FUTURE	FUTURE	FUTURE	FUTURE	FUTURE
REVISION DATE					

LEGEND

PROCESS VARIABLE

1

1

1

11

A

—

1

—(F)— FLOW DEVICE*

LEVEL: INSTRUMENT

1 (SEE PROCESS VARIABLE
TABLE FOR INSTRUMENT
DESCRIPTION)

CONTROL VALVE
MOTOR OPERATED

PROCESS VARIABLE TABLE

4. VARIABLE DESCRIPTION

IDENTIFIER	NUMBER OF DRAWINGS
AA - GASIFIER SYSTEM & GASIFIER SUB SYSTEMS	3
AB - NATURAL GAS SYSTEM	1
DA - COAL RECEIVING & STORAGE SYSTEM	1
DJ - COAL AND LIMESTONE PREPARATION SYSTEM	1
DP - COAL AND LIMESTONE FEED SYSTEM	1
GA - FLUE GAS DESULFURIZATION SYSTEM	1
GG - PROCESS VENT SYSTEM	1
GI - INCINERATOR	1
JO - CONDENSATE AND FEEDWATER CHEMISTRY CONTROL SYSTEM	1
KD - POTABLE WATER DISTRIBUTION SYSTEM	1
KV - AUXILIARY COOLING WATER SYSTEM	1
KW - SERVICE WATER SYSTEM	1
LD - INSTRUMENT AIR SUPPLY SYSTEM	1
LE - LEGEND SHEET	1
LF - PROCESS AIR SYSTEM	1
LI - HYDROGEN SYSTEM	1
MB - YARD FACILITIES	0
SB - RAIN STORM SYSTEM	2
SJ - FEEDWATER SYSTEM	2
VS - WASTE MANAGEMENT SYSTEM	2
TOTAL DRAWINGS	23

 FLOW STREAM SYMBOLS

DRAWING REVISION SYMBOLS

EQUIPMENT IDENTIFIER

AGT - AGITATOR
 ACU - AIR CONDITIONING UNIT
 AHU - AIR HANDLING UNIT
 ASX - AIR COOLAN
 AL - AIR LOCK
 BLD - BLOWER
 BLR - BOILER
 BWN - BURNER
 CAB - CABINET
 CH - CHUTE
 CHV - CIRCULATORY HEATER
 CLF - CLASSIFIER
 CYCL - CLOGGING
 CMP - COMPRESSOR
 COH - CONDITIONER
 CONV - CONVEYOR
 CLR - COOLER
 CRSH - CRUSHER
 DMP - DAMPER
 DCA - DECAURATOR
 DG - DIESEL GENERATOR
 DRY - DRYER
 DUCT - DUCT
 DCOL - DUST COLLECTOR
 EDH - EDUCTOR, EJECTOR
 ETR - ELECTRIC UNIT HEATER
 ELEV - ELEVATOR
 HPR - HOPPER
 FAN - FAN
 FAR - FLAME ARRESTER
 FDR - FEEDER
 FLT - FILTER
 HI - HEAT EXCHANGER
 HOI - HOIST
 HPR - HOPPER
 DCHG - DICHROMATOR
 LDR - LADDER
 LH - LAD HOOD
 LV - LOUVER
 M - MOTOR
 MCC - MOTOR CONTROL CENTER
 MZL - MIZZLE
 P - PUMP
 RPV - REACTOR
 AL - ROTARY VALVE
 RCV - RECEIVER
 RPD - RUMPLE DISH
 SUX - SAMPLER
 SCG - SCRUBBER
 SEP - SEPARATOR
 SIL - SILENCER
 SLD - SILD
 STX - STACK
 SD - STEAM DRUM
 STR - STRAINER
 HVSR - HIGH VOLTAGE
 TK - TANK
 TRAP - TRAPPAUL
 TRFM - TRANSFORMER
 UPS - UNINTERRUPTIBLE POWER SUPPLY
 VAP - VAPORIZATOR
 VSL - VESSEL

SEAL

SIGNATURE

DATE

DA, D.V. LEDBETTER	DATE 09-07-94
DSGN, N.V. DUCH	JACD83
CH.	FILE
	NUMBER
DPC H.A. STOKES	JOB NO. 25706
CAO FILE NO. 18, M. DKE100:1247050HE001.4CL.1	

JE JACOBS-SIRINE ENGINEERS,
a division of Jacobs Engineering Group Inc.

GPIF PROJECT
U.S. DEPT. OF ENERGY
DE-AC21-92MC28202

DRAWING TITLE

FLOW DIAGRAM
LEGEND

CLIENT DRAWING NUMBER

JACOBS-SIRRIE DRAWING NUMBER
16N25706-40-LE-001

Consent: Jacoby;Sitting (consent) 23 of 27 Date: 100-6036

339

FLOW DIAG

DRAWING NUMBER LEGEND

FLOW LEGEND

MISCELLANEOUS PIPING/EQUIPMENT

EQUIPMENT SYMBOLS

FIN/

SEE PK FOR FIN